

SOP-24 Shell-and-Tube Heat Exchanger Cleaning (Rev 2)

Standard Operating Procedure - Prayag Petro Refinery - Unit 2

Prayag Petro Refinery - Unit 2

1. Scope

Feed/effluent exchanger E-301

2. Applicable Equipment

E-301

3. Referenced Standards

OISD-STD-105 clause 5.1

4. Procedure

1. Isolate and drain E-301; obtain work permit per OISD-STD-105 cl. 5.1.
2. Remove channel cover; inspect channel gasket condition.
3. Hydro-jet tube bundle; record differential pressure improvement.