

SOP-30 Field Instrument Calibration (Rev 1)

Standard Operating Procedure - Prayag Petro Refinery - Unit 2

Prayag Petro Refinery - Unit 2

1. Scope

Feed section instruments PT-108 and FV-112 positioner

2. Applicable Equipment

PT-108, FV-112

3. Referenced Standards

OISD-STD-105 clause 5.1

4. Procedure

1. Raise permit; place loop under maintenance.
2. Apply 5-point calibration to PT-108; record as-found/as-left.
3. Stroke FV-112 and calibrate positioner 0-100%.