



**ELECTRICAL SPECIFICATION** 

IEC: 60137:2017

- 1) Rated Voltage......1.1kV.
- 2) Dry Power Frequency Withstand Voltage Test (One Minute)......10kV.
- 3) Maximum Current Capacity: 4000A

## OTHER:-

- 1) End Copper Palm Will be Electrotinned 12 to 15 Microns.
- 2) Electroytic Copper With High Electrical Conductivity.
- 3) Colour Brick red.

THE COPYRIGHT OF THESE DRAWINGS AND
OF ALL ANNEXES WHITCH ARE ENTRUSTED
TO A PERSON'S CARE ALWAYS REMAIN THE
PROPERTY OF OUR FIRM. THEY MUST NOT
BE COPIED OR DUPLICATED.NOT SHOWN TO
OR PLACED AT THE DISPOSAL OF THIRD
PERSONS WITHOUT OUR WRITTEN CONSENT.

REV	. MODIFICATION	DATE	APPD	

## 1.1kV Epoxy Bushing

## MANUFACTURER SUNSHINE ENGINEERING

Email :- sunshineengineering23@gmail.com Mob. :- +91 7499544230

All dimensions are in mm							
SCALE	NTS	REF.					
DRG	UKN	PROJECTION					
CHD	Pitale	· 🗐 🕀					
APPD	Pitale	Drawing No.	Rev				
DATE	06/02/22	SE/EB01/006					