

INSTRUMENT SOCIETY OF AMERICA TABLE

	FIRST LETTER(S)		SUCCEEDING LETTERS		
	PROCESS OR INITIATING VARIABLE	MODIFIER	READOUT OR PASSIVE FUNCTION	OUTPUT FUNCTION	MODIFIER
A	ANALYSIS		ALARM		
B	BURNER FLAME		USERS CHOICE(*)	USERS CHOICE(*)	USERS CHOICE(*)
C	CONDUCTIVITY			CONTROL DAMPER	
D	DENSITY (S.G.)	DIFFERENTIAL			
E	VOLTAGE		PRIMARY ELEMENT		
F	FLOW RATE	RATIO			
G	GAUGE		GLASS	GATE	
H	HAND (MANUAL)				HIGH
I	CURRENT		INDICATE		
J	POWER	SCAN			
K	TIME OR SCHEDULE			CONTROL STATION	
L	LEVEL		LIGHT (PILOT)		LOW
M	MOISTURE				
N	USERS CHOICE (*)		USERS CHOICE(*)	USERS CHOICE(*)	USERS CHOICE(*)
O	USERS CHOICE (*)		ORIFICE		
P	PRESSURE (OR VACUUM)		POINT (TEST CONN)		
Q	QUANTITY OR EVENT (*)	INTEGRATE	INTEGRATE		
R	NUCLEAR RADIATION		RECORD OR PRINT		
S	SPEED OR FREQUENCY	SAFETY		SWITCH	
T	TEMPERATURE			TRANSMIT	
U	MULTIVARIABLE (*)		MULTIFUNCTION (*)		
V	VISCOSITY			VALVE, DAMPER, LOUVER, ACTUATING ELEMENT, UNSPECIFIED CORRECTING UNIT	
W	WEIGHT OR FORCE		WELL		
X	UNCLASSIFIED (*)		UNCLASSIFIED (*)	UNCLASSIFIED(*)	UNCLASSIFIED(*)
Y	USERS CHOICE (*)			RELAY OR COMPUTE(*)	
Z	POSITION			DRIVE, ACTUATE OR UNCLASSIFIED FINAL CONTROL ELEMENT	
(*)	WHEN USED EXPLANATION IS SHOWN ADJACENT TO INSTRUMENT SYMBOL. SEE DEVICE TYPE AND FUNCTION LIST.				

INSTRUMENT LETTER DESIGNATION

CODE	CODE	DESCRIPTION
AA		ANALYTICAL ALARM
	AALL	ANALYTICAL ALARM LOW LOW
	AAL	ANALYTICAL ALARM LOW
	AAH	ANALYTICAL ALARM HIGH
	AAHH	ANALYTICAL ALARM HIGH HIGH
AE		ANALYTICAL ELEMENT
AET		ANALYTICAL ELEMENT TRANSMITTER
AI		ANALYTICAL INDICATOR
AC		ANALYTICAL CONTROLLER
AIC		ANALYTICAL INDICATING CONTROLLER
AT		ANALYTICAL TRANSMITTER
AIT		ANALYTICAL INDICATING TRANSMITTER
ACV		ANALYTICAL CONTROL VALVE
AV		ANALYTICAL VALVE
AY		ANALYTICAL SIGNAL CONVERTER
CA		CONDUCTIVITY ALARM
	CALL	CONDUCTIVITY ALARM LOW LOW
	CAL	CONDUCTIVITY ALARM LOW
	CAH	CONDUCTIVITY ALARM HIGH
	CAHH	CONDUCTIVITY ALARM HIGH HIGH
CE		CONDUCTIVITY ELEMENT
CET		CONDUCTIVITY ELEMENT TRANSMITTER
CI		CONDUCTIVITY INDICATOR
CIC		CONDUCTIVITY INDICATING CONTROLLER
CC		CONDUCTIVITY CONTROLLER
CIT		CONDUCTIVITY INDICATING TRANSMITTER
CT		CONDUCTIVITY TRANSMITTER
CV		CONTROL VALVE
D		DAMPER MOTOR OR ACTUATOR
EI		VOLTAGE INDICATOR
EA		VOLTAGE ALARM
	EALL	VOLTAGE ALARM LOW LOW
	EAL	VOLTAGE ALARM LOW
	EAH	VOLTAGE ALARM HIGH
	EAHH	VOLTAGE ALARM HIGH HIGH
ENT		ENTHALPY TRANSMITTER
ES		VOLTAGE SWITCH
	ESLL	VOLTAGE SWITCH LOW LOW
	ESL	VOLTAGE SWITCH LOW
	ESH	VOLTAGE SWITCH HIGH
	ESHH	VOLTAGE SWITCH HIGH HIGH
ET		VOLTAGE TRANSMITTER
EY		VOLTAGE SIGNAL CONVERTER
FA		FLOW ALARM
	FALL	FLOW ALARM LOW LOW
	FAL	FLOW ALARM LOW
	FAH	FLOW ALARM HIGH
	FAHH	FLOW ALARM HIGH HIGH
FS		FLOW SWITCH
	FSLL	FLOW SWITCH LOW LOW
	FSL	FLOW SWITCH LOW
	FSH	FLOW SWITCH HIGH
	FSHH	FLOW SWITCH HIGH HIGH
FC		FLOW CONTROLLER
FIC		FLOW INDICATING CONTROLLER
FCV		FLOW CONTROL VALVE
FE		FLOW ELEMENT
FET		FLOW ELEMENT/TRANSMITTER
FI		FLOW INDICATOR
FIT		FLOW INDICATING TRANSMITTER
FQ		FLOW TOTALIZER
FQA		FLOW TOTALIZER ALARM
FQI		FLOW TOTALIZER INDICATOR
FQIT		FLOW TOTALIZER INDICATING TRANSMITTER
FQT		FLOW TOTALIZER TRANSMITTER
FT		FLOW TRANSMITTER
FV		FLOW VALVE
FY		FLOW SIGNAL CONVERTER
HD		HEAT DETECTOR
HK		MANUAL VARIABLE CONTROL
HS		HAND SWITCH
HSD		HIGH SENSITIVITY SMOKE DETECTOR,AIR SAMPLING TUBES (VESDA OR HSSD) SMOKE DETECTOR ALARM
HSI		HAND SWITCH POSITION INDICATOR
HY		HAND SWITCH POSITION RELAY
IC		CURRENT CONTROL
II		CURRENT INDICATOR
IA		CURRENT ALARM
	IALL	CURRENT ALARM LOW LOW
	IAL	CURRENT ALARM LOW
	IAH	CURRENT ALARM HIGH
	IAHH	CURRENT ALARM HIGH HIGH
IS		CURRENT SWITCH
	ISLL	CURRENT SWITCH LOW LOW
	ISL	CURRENT SWITCH LOW
	ISH	CURRENT SWITCH HIGH
	ISHH	CURRENT SWITCH HIGH HIGH
IT		CURRENT TRANSMITTER
IY		CURRENT SIGNAL CONVERTER
JC		POWER CONTROL
JI		POWER (WATT) INDICATOR
JIC		POWER INDICATING CONTROL
JIT		POWER INDICATING TRANSMITTER
JT		POWER (WATT) TRANSMITTER
JY		POWER SIGNAL CONVERTER
KI		TIMER/COUNTER (DERIVED)
KOI		TIMER/COUNTER ACCUMULATE INDICATING
KY		TIMER/COUNTER (FIELD DEVICES)
LA		LEVEL ALARM
	LALL	LEVEL ALARM LOW LOW
	LAL	LEVEL ALARM LOW

CODE	CODE	DESCRIPTION
	LAH	LEVEL ALARM HIGH
	LAHH	LEVEL ALARM HIGH HIGH
LS		LEVEL SWITCH
	LSLL	LEVEL SWITCH LOW LOW
	LSL	LEVEL SWITCH LOW
	LSH	LEVEL SWITCH HIGH
	LSHH	LEVEL SWITCH HIGH HIGH
LC		LEVEL CONTROLLER
LCV		LEVEL CONTROL VALVE
LE		LEVEL ELEMENT
LIC		LEVEL INDICATING CONTROLLER
LIT		LEVEL INDICATING TRANSMITTER
LT		LEVEL TRANSMITTER
LV		LEVEL VALVE
LY		LEVEL SIGNAL CONVERTER
LI		LEVEL INDICATOR
M		MOTOR
MA		HUMIDITY ALARM
	MALL	HUMIDITY ALARM LOW LOW
	MAL	HUMIDITY ALARM LOW
	MAH	HUMIDITY ALARM HIGH
	MAHH	HUMIDITY ALARM HIGH HIGH
MC		HUMIDITY CONTROLLER
MD		MOTOR CONTROL DAMPER
MCV		HUMIDITY CONTROL VALVE
ME		HUMIDITY ELEMENT
MET		HUMIDITY ELEMENT TRANSMITTER
MI		HUMIDITY INDICATOR
MIC		HUMIDITY INDICATING CONTROLLER
MV		HUMIDITY HAND VALVE
MY		HUMIDITY SIGNAL CONVERTER
PA		PRESSURE ALARM
	PALL	PRESSURE ALARM LOW LOW
	PAL	PRESSURE ALARM LOW
	PAH	PRESSURE ALARM HIGH
	PAHH	PRESSURE ALARM HIGH HIGH
PS		PRESSURE SWITCH
	PSLL	PRESSURE SWITCH LOW LOW
	PSL	PRESSURE SWITCH LOW
	PSH	PRESSURE SWITCH HIGH
	PSHH	PRESSURE SWITCH HIGH HIGH
PCV		PRESSURE CONTROL VALVE
PCD		PRESSURE CONTROL DAMPER
PD		PNEUMATIC DAMPER ACTUATOR
PDAL		PRESSURE DIFFERENTIAL ALARM LOW
PDI		PRESSURE DIFFERENTIAL INDICATOR
PDS		PRESSURE DIFFERENTIAL SWITCH
PDT		PRESSURE DIFFERENTIAL TRANSMITTER
PDZ		DAMPER POSITIONER
PI		PRESSURE INDICATOR
PIC		PRESSURE INDICATING CONTROLLER
PIS		PRESSURE INDICATING SWITCH
PIT		PRESSURE INDICATING TRANSMITTER
PRV		PRESSURE RECORDING VALVE
PSS		PRESSURE SAFETY SWITCH
PSV		PRESSURE SAFETY VALVE
PT		PRESSURE TRANSMITTER
PV		PRESSURE VALVE
PY		PRESSURE SIGNAL CONVERTER
QA		FAULT INDICATION (DERIVED)
QE		RUPTURE DISK
QI		STATUS INDICATOR (DERIVED)
QIK		EQUIPMENT INDICATING SEQUENCER
QK		EQUIPMENT SEQUENCER
QL		STATUS INDICATOR (FIELD)
QS		STATUS SWITCH
RA		RESISTIVITY ALARM
	RALL	RESISTIVITY ALARM LOW LOW
	RAL	RESISTIVITY ALARM LOW
	RAH	RESISTIVITY ALARM HIGH
	RAHH	RESISTIVITY ALARM HIGH HIGH
RI		RESISTIVITY INDICATOR
	RILL	RESISTIVITY INDICATOR LOW LOW
	RIL	RESISTIVITY INDICATOR LOW
	RIH	RESISTIVITY INDICATOR HIGH
	RIHH	RESISTIVITY INDICATOR HIGH HIGH
RCV		RESISTIVITY CONTROL VALVE
RE		RESISTIVITY ELEMENT
RET		RESISTIVITY ELEMENT TRANSMITTER
RIT		RESISTIVITY INDICATING TRANSMITTER
RY		RESISTIVITY SIGNAL CONVERTER
SC		SPEED CONTROLLER
SCM		SPEED CONTROL MANUAL
SI		SPEED INDICATOR
SPD		SPRINKLER DETECTOR
ST		SPEED TRANSMITTER
TA		TEMPERATURE ALARM
	TALL	TEMPERATURE ALARM LOW LOW
	TAL	TEMPERATURE ALARM LOW
	TAH	TEMPERATURE ALARM HIGH
	TAHH	TEMPERATURE ALARM HIGH HIGH
TS		TEMPERATURE SWITCH
	TSLL	TEMPERATURE SWITCH LOW LOW
	TSL	TEMPERATURE SWITCH LOW
	TSH	TEMPERATURE SWITCH HIGH
	TSHH	TEMPERATURE SWITCH HIGH HIGH
TC		TEMPERATURE CONTROLLER
TCD		TEMPERATURE CONTROL DAMPER
TCV		TEMPERATURE CONTROL VALVE
TE		TEMPERATURE ELEMENT
TET		TEMPERATURE ELEMENT TRANSMITTER
TI		TEMPERATURE INDICATOR
TIT		TEMPERATURE INDICATING TRANSMITTER
TIC		TEMPERATURE INDICATING CONTROLLER

[illegible]

OWNER / DEVELOPER



ARCHITECTURAL CONSULTANT

CIVIL & STRUCTURAL CONSULTANT

MECHANICAL & ELECTRICAL CONSULTANT


DESIGN MANAGER



PROJECT ADDRESS

North Coast Drive, Singapore

KEY PLAN



Secret
R3
Level

FOR REVIEW

[illegible]

PROJECT TITLE
Micron F10E Probe Project

PROJECT PHASE

A&E

DRAWING TITLE

SYMBOL LEGEND
CONTROL SYSTEM

DESIGNED :	設計者	DRAWN :	作者	CHECKED :	審圖員
DATE :	02/12/26	JOB NO. :		SCALE :	
Micon DRAWING NO.	F01-F10E-PFD-S0-00-K-104				REV
CTCI DRAWING NO.					A
Reference Model					
CTCI				SHEET: 1 OF 1	SIZE A1