

[illegible]

PLATE TYPE HEAT EXCHANGER																	
UNIT MARK	LOCATION	SERVICE	FLUID	HOT SIDE				COLD SIDE				HEAT EXCHANGED Kw	DESIGN PRESSURE Barg	PLATE MATERIAL	PLATE SEALING MATERIAL	REMARKS	
				FLOW RATE(m3/h)	INLET TEMP.(°C)	OUTLET TEMP.(°C)	PRESSURE DROP(kPa)	FLOW RATE(m3/h)	INLET TEMP.(°C)	OUTLET TEMP.(°C)	PRESSURE DROP(kPa)						
FAL-PCW-HEX-101	FAB L30	L20 15.5°C SYSTEM	WATER	4.10	20.0	15.5	< 50	369	12.0	17.0	< 50	2135	10	SUS 304	EPDM	(50K)	
FAL-PCW-HEX-102	FAB L30	L20 15.5°C SYSTEM	WATER	4.10	20.0	15.5	< 50	369	12.0	17.0	< 50	2135	10	SUS 304	EPDM	(50K)	
FAL-PCW-HEX-103	FAB L30	L20 15.5°C SYSTEM	WATER	4.10	20.0	15.5	< 50	369	12.0	17.0	< 50	2135	10	SUS 304	EPDM	(50K)	
FAL-PCW-HEX-104	FAB L30	L20 15.5°C SYSTEM	WATER	4.10	20.0	15.5	< 50	369	12.0	17.0	< 50	2135	10	SUS 304	EPDM	(200K)	
FAL-PCW-HEX-105	FAB L30	L20 15.5°C SYSTEM	WATER	4.10	20.0	15.5	< 50	369	12.0	17.0	< 50	2135	10	SUS 304	EPDM	(200K)	
FAL-PCW-HEX-106	FAB L30	L20 15.5°C SYSTEM	WATER	4.10	20.0	15.5	< 50	369	12.0	17.0	< 50	2135	10	SUS 304	EPDM	(200K) (STANDBY)	
FAL-PCW-HEX-107	FAB L30	L20 15.5°C SYSTEM	WATER	4.10	20.0	15.5	< 50	369	12.0	17.0	< 50	2135	10	SUS 304	EPDM	(200K) (FUTURE)	

[illegible]

WATER TANK SCHEDULE									
UNIT MARK	LOCATION	SERVICE	CAPACITY M3	MATERIAL		ELECTRICAL DATA			REMARKS
				SHELL	BLADDER	KW	VOLTAGE	CLASS	
FAL-PCW-ET-101	FAB L30	L20 15.5°C SYSTEM	25	STAINLESS STEEL	--				(50K)

OWNER / DEVELOPER

micon®

ARCHITECTURAL CONSULTANT

JJP ARCHITECTS & PLANNERS
潘冀聯合建築師

CIVIL & STRUCTURAL CONSULTANT

TEAM 群策工程股份有限公司

MECHANICAL & ELECTRICAL CONSULTANT & CONTRACTOR

uis Limited Integrated Services

漢唐集成股份有限公司

SUB-CONTRACTOR

PROJECT ADDRESS

KEY PLAN

A REV DATE DESCRIPTION Revisions ISSUED BY

EQUIPMENT SCHEDULE - PCW SYSTEM

DRAWING NO.

DESIGNED : CHEN DRAWN : CHEN CHECKED : CHUNG SIR

DATE : 2024/11/20 JOB NO.: SCALE: N.T.S.

DE_F1_ALL_B0001_D_WPCW_0001-00

REV 0 SIZE A1 SHEET: