

EXHAUST FAN SCHEDULE																	
UNIT MARK	LOCATION	SERVICE	CMH	M/S	FAN		WHEEL TYPE	DRIVE	ESP Pa	THRUST N	SOUND PRESS. 45" AT 10m dBA	SOUND POWER dBA	MOTOR			REMARK	
					TYPE	RPM							BHP	KW	VOLTAGE		TYPE
F1-C3-EF-1001	CUB3 L01	CABLE ROOM	11,000	-	WALL MOUNTED	-	PROPELLER	DIRECT	62.5	-	-	-	-	2.2	3/460/60	TEFC	MOTOR IE 4
F1-C3-EF-1002	CUB3 L10	CABLE ROOM	11,000	-	WALL MOUNTED	-	PROPELLER	DIRECT	62.5	-	-	-	-	2.2	3/460/60	TEFC	MOTOR IE 4
F1-C3-EF-1003	CUB3 L10	CHILLER ROOM	30,000	-	AXIAL FAN	-	AIRFOIL	DIRECT	500	-	-	-	-	7.5	3/460/60	TEFC	MOTOR IE 4
F1-C3-EF-1004	CUB3 L10	CHILLER ROOM	30,000	-	AXIAL FAN	-	AIRFOIL	DIRECT	500	-	-	-	-	7.5	3/460/60	TEFC	MOTOR IE 4
F1-C3-EF-1005	CUB3 L10	FIRE PUMP ROOM	8,000	-	WALL MOUNTED	-	PROPELLER	DIRECT	62.5	-	-	-	-	0.74	3/460/60	TEFC	MOTOR IE 4
F1-C3-EF-1006	CUB3 L10	FIRE PUMP ROOM	7,000	-	INLINE FAN	-	BACKWARD INCLINED	BELT	375	-	-	-	-	2.2	3/460/60	TEFC	MOTOR IE 4 使用防爆型馬達
F1-C3-EF-1007	CUB3 L10	TOILET	1,000	-	WALL MOUNTED	-	PROPELLER	DIRECT	62.5	-	-	-	-	0.09	1/208/60	TEFC	MOTOR IE 4
F1-C3-EF-1008	CUB3 L20	滅火銅頭室	3,500	-	INLINE FAN	-	BACKWARD INCLINED	BELT	500	-	-	-	-	1.1	3/460/60	TEFC	MOTOR IE 4
F1-C3-EF-1009	CUB3 L30	DIESEL TANK ROOM	3,500	-	INLINE FAN	-	BACKWARD INCLINED	BELT	500	-	-	-	-	1.1	3/460/60	TEFC	MOTOR IE 4 使用防爆型馬達
F1-C3-EF-1010	CUB3 LR1	ELEVATOR ROOM	3900	-	WALL MOUNTED	-	PROPELLER	DIRECT	62.5	-	-	-	-	0.2	1/208/60	TEFC	MOTOR IE 4
F1-C3-EF-1011	CUB3 L10	DIESEL STORAGE TANK	3500	-	INLINE FAN	-	BACKWARD INCLINED	BELT	500	-	-	-	-	1.1	3/460/60	TEFC	MOTOR IE 4 使用防爆型馬達

FUEL OIL PUMP SCHEDULE													
UNIT MARK	SERVICE	TYPE	SUCTION SIZE A	DISCHARGE SIZE A	FLOW L/S	HEAD M	BHP	RPM	MOTOR		FLUID	REMARKS	
									HP	VOLTAGE			TYPE
F1-FOP-001	FUEL OIL SUPPLY PUMP	自吸式離心泵浦	50	40	3.89	80	-	-	7	3/480/60	TEFC	FUEL	EXPLSION PROOF
F1-FOP-002	FUEL OIL SUPPLY PUMP	自吸式離心泵浦	50	40	3.89	80	-	-	7	3/480/60	TEFC	FUEL	EXPLSION PROOF, STANDBY
F1-WOCP-001	WASTE WATER & OIL PUMP	沉水式	-	-	1.3	10	-	-	15	3/480/60	TEFC	FUEL	EXPLSION PROOF
F1-WOCP-002	WASTE WATER & OIL PUMP	沉水式	-	-	1.3	10	-	-	15	3/480/60	TEFC	FUEL	EXPLSION PROOF, STANDBY

FUEL OIL STORAGE TANK SCHEDULE							
UNIT MARK	SERVICE	MATERIAL	EFFECTIVE TANK CAPACITY (M ³)	DIMENSION (mm)	REMARKS		
F1-POST-001	FUEL OIL DAILY TANK	CARBON STEEL	80	-	內部噴砂 外部噴砂加防鏽處理	WITH SUPPORTING STEEL FRAME	須符合消防規定之漏火試驗

FUEL OIL DAILY TANK SCHEDULE						
UNIT MARK	SERVICE	MATERIAL	EFFECTIVE TANK CAPACITY (M ³)	DIMENSION (mm)	REMARKS	
F1-CDT-001	FUEL OIL DAILY TANK	碳鋼 (SS400)	8.5	-	內部噴砂 外部噴砂加防腐處理	WITH SUPPORTING STEEL FRAME 須符合消防規定之漏水試驗
F1-CDT-002	FUEL OIL DAILY TANK	碳鋼 (SS400)	8.5	-	內部噴砂 外部噴砂加防腐處理	WITH SUPPORTING STEEL FRAME 須符合消防規定之漏水試驗

UNIT MARK	QTY	LOCATION	AIR FLOW CMH	ESP(po)	COOLING COIL										MOTOR			REMARKS
					TOTAL KW	SENSIBLE KW	EAT °C		LAT °C		L/S	EWT °C	LWT °C	WATTS	POWER SOURCE	TYPE		
							DB	WB	DB	WB								
④	—	—	684	50	2.74	1.95	26	20.3	17.6	16.4	0.22	12	14.9	95	1/208/60	—	吊掛隱藏式小型送風機 (附溫度控制器及控制面板) CEILING RECESSED TYPE	
⑥	18	—	1044	50	4.07	2.9	26	20.3	17.6	16.4	0.33	12	14.9	142	1/208/60	—	吊掛隱藏式小型送風機 (附溫度控制器及控制面板) CEILING RECESSED TYPE	
⑧	—	—	1359	50	5.4	3.84	26	20.3	17.6	16.4	0.43	12	14.9	166	1/208/60	—	吊掛隱藏式小型送風機 (附溫度控制器及控制面板) CEILING RECESSED TYPE	
⑩	20	—	1728	50	6.4	4.61	26	20.3	17.6	16.4	0.55	12	14.9	228	1/208/60	—	吊掛隱藏式小型送風機 (附溫度控制器及控制面板) CEILING RECESSED TYPE	
⑫	—	—	2052	50	7.69	5.59	26	20.3	17.6	16.4	0.65	12	14.9	285	1/208/60	—	吊掛隱藏式小型送風機 (附溫度控制器及控制面板) CEILING RECESSED TYPE	

UNIT MARK	LOCATION	SERVICE	QTY	FAN					COOLING COIL								MOTOR			REMARKS		
				TYPE	CMH	ESP(pa)	DRIVE TYPE	RPM	CAP(KW)		FAT°C		AIR ΔP Pa	EWI %	LWT °C	WIR ΔP KPa	L/S	HP	VOLTAGE		TYPE	
									TOTAL	SENSIBLE	DB	FAT°C										WB
F1-F-PAH-1015	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1016	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	(STANDBY) 使用自壓排水器
F1-F-PAH-1017	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1018	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	6000	250	BELT	—	36	25.4	29.0	22.0	—	12	20	<50	1.0	3	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1019	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	6000	250	BELT	—	36	25.4	29.0	22.0	—	12	20	<50	1.0	3	3/460/60	ODP	IE: 4	(STANDBY) 使用自壓排水器
F1-F-PAH-1020	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1021	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1022	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1023	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	(STANDBY) 使用自壓排水器
F1-F-PAH-1024	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	6000	250	BELT	—	36	25.4	29.0	22.0	—	12	20	<50	1.0	3	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1025	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	6000	250	BELT	—	36	25.4	29.0	22.0	—	12	20	<50	1.0	3	3/460/60	ODP	IE: 4	(STANDBY) 使用自壓排水器
F1-F-PAH-1026	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1027	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	(STANDBY) 使用自壓排水器
F1-F-PAH-1028	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	27600	250	BELT	—	192	128	29.0	22.0	—	12	20	<50	5.6	15	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1029	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	6000	250	BELT	—	36	25.4	29.0	22.0	—	12	20	<50	1.0	3	3/460/60	ODP	IE: 4	使用自壓排水器
F1-F-PAH-1030	FAB LEVEL 05	SUBSTATION	1	FORWARD CURVED	6000	250	BELT	—	36	25.4	29.0	22.0	—	12	20	<50	1.0	3	3/460/60	ODP	IE: 4	(STANDBY) 使用自壓排水器
F1-F-PAH-1031	OFFICE	L30	1	BACKWARD CURVED	30000	500	—	—	294	158	27.8	21.9	—	5	13	<50	8.8	30	3/460/60	ODP		附屬/出風外氣閥門開機 (MERV 13) W/ VFD, IE4
F1-F-PAH-1032	OFFICE	L30	1	BACKWARD CURVED	30000	500	—	—	294	158	27.8	21.9	—	5	13	<50	8.8	30	3/460/60	ODP		附屬/出風外氣閥門開機 (MERV 13) W/ VFD, IE4 (STANDBY)

SEPARATED AIR CONDITIONER SCHEDULE						
UNIT MARK	SERVICE	冷卻能力 KW	運轉電流 A	消耗功率 W	VOLTAGE	REMARKS
F1-G-AC-01	GUARD ROOM	(2.1-7.2)	9.0-2.6	3800-570	1/220/60	CSPF>3.81

KEY PLAN

	SHEET:	SIZE
--	--------	------