



| BOREHOLE RECORD | | | | | | | | | | |
|--|------------|--|--|--|---------------------|-----|---|---------------------------|----|--|
| Contract No. 14356/96 | | Client Severfield Reeve | | | | | | | | |
| Ground Level | | Location Huthwaite, Sutton in Ashfield | | | | | | | | |
| BOREHOLE No. 4 | | Date December 1996 | | | | | | | | |
| Depth | Thick-ness | Legend | Description of Strata | Type of Sample | C kN/m ² | M % | Ø | Density kg/m ³ | N | |
| 0.700 | 0.700 | | Made up ground, topsoil and clay fill | | | | | | | |
| 1.300 | 1.300 | | Made up ground, firm to compact grey brown mottled silty clay fill | 1.000 P | | | | | 15 | |
| 2.000 | 2.000 | | | 2.000 P | No impression | | | | 25 | |
| 2.500 | 0.500 | | Very compact limestone boulder | | | | | | | |
| 3.400 | 0.900 | | Stiff to very stiff grey brown mottled silty clay | 3.200 P | | | | | 30 | |
| 3.700 | 0.300 | | Siltstone | | | | | | | |
| Water Struck at Dry Standing Water Level | | | | | | | | | | |
| Undisturbed Sample | | | U | J. T. HYMAS (Site Investigation) LTD. 12 Yarm Road, Stockton-on-Tees, Cleveland TS18 3NE Tel. 01642 607083 Fax. 01642 612355 | | | | | | |
| Disturbed Sample | | | O | | | | | | | |
| Penetration Test | | | P | | | | | | | |
| Cohesion | | | C | | | | | | | |
| Angle of Internal Friction | | | Ø | | | | | | | |
| Moisture Content % | | | M | | | | | | | |
| Standard Penetration Value | | | N | | | | | | | |

