



Norwest Holst Soil Engineering Ltd.						Borehole No. 49	
Contract No. F5353		BOREHOLE LOG		Sheet 1 of 1			
Location Higham / Whiteborough				Chainage			
Client Severn Trent Water Authority				Ground Level 123.10 m.A.O.D.			
Method of Boring Percussion		SK 45NW 224		Date 23/10/82			
Diameter of Borehole 150 mm							
Description of Strata	Legend	Depth Below G.L. (m)	O.D. Level (m)	Casing Depth at Sampling	Sampling and Coring	"N"/R.O.D.%	Daily Progress
MADE GROUND: Ash and domestic waste.		0.50	122.60		0.50		
Firm brown and grey mottled slightly silty CLAY.		1.70	121.40		1.50	(50)	
Stiff brown and grey laminated silty shaly CLAY with weathered sandstone bands.		3.75	119.35		2.50	(94)	
Grey weathered MUDSTONE,		5.00	118.10		3.50	(100)	
End of borehole.					4.70	(106)	
					S	61	

Type of Sample

S.P.T. Undisturbed

C.P.T. Vane

Jar Water

Bulk Piezometer

Remarks (Observations of Ground Water etc.)

Borehole dry.
Borehole cased to 3.00 m.
() Blows to drive U100.

Water levels are subject to seasonal or tidal variations and should not be taken as constant