
Python calculation for heat pump SIN-11TU

Parametric Heat Pump calculation

Dani Carbonell

dani.carbonell@solarenergy.ch

2019/03/12 at: 16:08:22 h

Table 1: Fitted coefficients for the heat pump.

Coefficient	Description	[kW]
PQ_1	1 st condenser polynomial coefficient	1.0347e+01
PQ_2	2 st condenser polynomial coefficient	1.1794e+02
PQ_3	3 st condenser polynomial coefficient	2.9112e+01
PQ_4	4 st condenser polynomial coefficient	-2.0540e+02
PQ_5	5 st condenser polynomial coefficient	6.8104e+01
PQ_6	6 st condenser polynomial coefficient	-1.4845e+02
$PCOP_1$	1 st COP polynomial coefficient	7.3541e+00
$PCOP_2$	2 st COP polynomial coefficient	7.4987e+01
$PCOP_3$	3 st COP polynomial coefficient	-1.0135e+01
$PCOP_4$	4 st COP polynomial coefficient	-2.9177e+02
$PCOP_5$	5 st COP polynomial coefficient	-3.3744e+01
$PCOP_6$	6 st COP polynomial coefficient	-6.5273e+01
\dot{m}_{cond}	1900.00 [kg/h]	
\dot{m}_{evap}	1900.00 [kg/h]	
COP_{nom} (B0W35)	4.90	
$Q_{c,nom}$ (B0W35)	10.97 kW	
COP_{nom} (B2W35)	5.19	
$Q_{c,nom}$ (B2W35)	11.60 kW	
COP_{nom} (B10W35)	6.32	
$Q_{c,nom}$ (B10W35)	14.19 kW	

Table 2: Predicting results of the heat pump.

$T_{evap,in}$ °C	$T_{evap,out}$ °C	$T_{cond,in}$ °C	$T_{cond,out}$ °C	COP [-]	Q_{cond} [kW]	Q_{evap} [kW]	W_{comp} [kW]	\dot{m}_{cond} kg/h	\dot{m}_{evap} kg/h	ΔT_{evap} K	ΔT_{cond} K
-7.00	-10.31	26.03	30.00	4.17	8.77	6.67	2.11	1900	1900	3.3	4.0
-7.00	-10.17	34.77	38.75	3.65	8.80	6.39	2.41	1900	1900	3.2	4.0
-7.00	-9.83	43.63	47.50	3.00	8.56	5.71	2.85	1900	1900	2.8	3.9
-7.00	-9.19	52.62	56.25	2.21	8.03	4.40	3.63	1900	1900	2.2	3.6
-7.00	-7.76	61.72	65.00	1.27	7.26	1.54	5.72	1900	1900	0.8	3.3
-4.00	-7.79	25.61	30.00	4.65	9.71	7.62	2.09	1900	1900	3.8	4.4
-4.00	-7.62	34.37	38.75	4.05	9.69	7.30	2.39	1900	1900	3.6	4.4
-4.00	-7.25	43.25	47.50	3.31	9.39	6.55	2.84	1900	1900	3.3	4.2
-4.00	-6.57	52.27	56.25	2.42	8.81	5.17	3.63	1900	1900	2.6	4.0
-4.00	-5.09	61.39	65.00	1.38	7.98	2.20	5.78	1900	1900	1.1	3.6
-1.00	-5.27	25.18	30.00	5.14	10.67	8.59	2.08	1900	1900	4.3	4.8
-1.00	-5.08	33.96	38.75	4.44	10.59	8.21	2.38	1900	1900	4.1	4.8
-1.00	-4.67	42.87	47.50	3.61	10.24	7.40	2.84	1900	1900	3.7	4.6
-1.00	-3.95	51.91	56.25	2.63	9.60	5.95	3.65	1900	1900	3.0	4.3
-1.00	-2.43	61.06	65.00	1.49	8.72	2.87	5.85	1900	1900	1.4	3.9
2.00	-2.75	24.74	30.00	5.62	11.64	9.57	2.07	1900	1900	4.8	5.3
2.00	-2.53	33.54	38.75	4.83	11.51	9.13	2.38	1900	1900	4.5	5.2
2.00	-2.10	42.48	47.50	3.91	11.10	8.26	2.84	1900	1900	4.1	5.0
2.00	-1.34	51.54	56.25	2.83	10.40	6.73	3.67	1900	1900	3.3	4.7
2.00	0.24	60.71	65.00	1.60	9.48	3.54	5.93	1900	1900	1.8	4.3
5.00	-0.24	24.29	30.00	6.10	12.63	10.56	2.07	1900	1900	5.2	5.7
5.00	0.00	33.12	38.75	5.22	12.45	10.06	2.38	1900	1900	5.0	5.6
5.00	0.47	42.08	47.50	4.21	11.98	9.13	2.85	1900	1900	4.5	5.4
5.00	1.26	51.17	56.25	3.03	11.23	7.53	3.70	1900	1900	3.7	5.1
5.00	2.90	60.37	65.00	1.70	10.25	4.22	6.03	1900	1900	2.1	4.6
8.00	2.26	23.84	30.00	6.58	13.63	11.56	2.07	1900	1900	5.7	6.2
8.00	2.53	32.69	38.75	5.61	13.40	11.01	2.39	1900	1900	5.5	6.1
8.00	3.03	41.68	47.50	4.50	12.88	10.01	2.86	1900	1900	5.0	5.8
8.00	3.86	50.79	56.25	3.23	12.07	8.34	3.73	1900	1900	4.1	5.5
8.00	5.56	60.01	65.00	1.80	11.04	4.91	6.13	1900	1900	2.4	5.0
11.00	4.76	23.37	30.00	7.05	14.65	12.58	2.08	1900	1900	6.2	6.6
11.00	5.06	32.25	38.75	5.99	14.36	11.97	2.40	1900	1900	5.9	6.5
11.00	5.58	41.27	47.50	4.79	13.79	10.91	2.88	1900	1900	5.4	6.2
11.00	6.45	50.40	56.25	3.43	12.93	9.16	3.77	1900	1900	4.5	5.8
11.00	8.22	59.64	65.00	1.90	11.85	5.61	6.24	1900	1900	2.8	5.4
14.00	7.24	22.90	30.00	7.53	15.69	13.61	2.08	1900	1900	6.8	7.1
14.00	7.57	31.81	38.75	6.38	15.35	12.94	2.41	1900	1900	6.4	6.9
14.00	8.13	40.84	47.50	5.08	14.72	11.82	2.90	1900	1900	5.9	6.7
14.00	9.04	50.01	56.25	3.62	13.80	9.99	3.81	1900	1900	5.0	6.2
14.00	10.86	59.27	65.00	1.99	12.67	6.31	6.36	1900	1900	3.1	5.7
17.00	9.73	22.43	30.00	8.00	16.74	14.65	2.09	1900	1900	7.3	7.6
17.00	10.08	31.36	38.75	6.76	16.35	13.93	2.42	1900	1900	6.9	7.4
17.00	10.67	40.42	47.50	5.37	15.66	12.74	2.92	1900	1900	6.3	7.1
17.00	11.62	49.61	56.25	3.81	14.69	10.84	3.85	1900	1900	5.4	6.6
17.00	13.51	58.89	65.00	2.09	13.51	7.03	6.48	1900	1900	3.5	6.1
20.00	12.20	21.95	30.00	8.47	17.81	15.71	2.10	1900	1900	7.8	8.1
20.00	12.59	30.90	38.75	7.14	17.36	14.93	2.43	1900	1900	7.4	7.9
20.00	13.21	39.98	47.50	5.65	16.62	13.68	2.94	1900	1900	6.8	7.5
20.00	14.19	49.19	56.25	4.00	15.60	11.70	3.90	1900	1900	5.8	7.1
20.00	16.14	58.50	65.00	2.18	14.37	7.77	6.60	1900	1900	3.9	6.5

Meier/SIN-11TU/SIN-11TU-Cop.pdf




Figure 1: COP Results for the heat pump at the selected points

Meier/SIN-11TU/SIN-11TU-Qc.pdf




Figure 2: Q_c Results for the heat pump at the selected points