INSTITUT FÜR SOLARTECHNIK

HSR HOCHSCHULE FÜR TECHNIK RAPPERSWIL
FHO Fachhochschule Ostschweiz

Python calculation for heat pump SIN-130TE

Parametric Heat Pump calculation

Dani Carbonell
dani.carbonell@solarenergy.ch

2019/03/12 at: 16:08:25 h

Table 1: Fitted coefficients for the heat pump.

Coefficient	Description	$[kW]$
PQ_1	1^{st} *condenser polynomial coefficient*	1.1017e+02
PQ_2	2^{st} *condenser polynomial coefficient*	8.3243e+02
PQ_3	3^{st} *condenser polynomial coefficient*	4.1398e+02
PQ_4	4^{st} *condenser polynomial coefficient*	-2.2461e+00
PQ_5	5^{st} *condenser polynomial coefficient*	3.3288e+02
PQ_6	6^{st} *condenser polynomial coefficient*	-2.1955e+03
$PCOP_1$	1^{st} *COP polynomial coefficient*	5.2782e+00
$PCOP_2$	2^{st} *COP polynomial coefficient*	3.3528e+01
$PCOP_3$	3^{st} *COP polynomial coefficient*	2.0320e+00
$PCOP_4$	4^{st} *COP polynomial coefficient*	-7.8493e+01
$PCOP_5$	5^{st} *COP polynomial coefficient*	7.6224e+00
$PCOP_6$	6^{st} *COP polynomial coefficient*	-8.5718e+01
$\dot{m}_{cond}$	21000.00 $[kg/h]$	
$\dot{m}_{evap}$	21000.00 $[kg/h]$	
COP_{nom} (B0W35)	4.12	
$Q_{c,nom}$ (B0W35)	122.04 kW	
COP_{nom} (B2W35)	4.30	
$Q_{c,nom}$ (B2W35)	127.77 kW	
COP_{nom} (B10W35)	5.00	
$Q_{c,nom}$ (B10W35)	151.00 kW	

Table 2: Predicting results of the heat pump.

$T_{evap,in}$ °C	$T_{evap,out}$ °C	$T_{cond,in}$ °C	$T_{cond,out}$ °C	COP [–]	Q_{cond} [kW]	Q_{evap} [kW]	W_{comp} [kW]	$\dot{m}_{cond}$ kg/h	$\dot{m}_{evap}$ kg/h	ΔT_{evap} K	ΔT_{cond} K
-7.00	-10.42	25.77	30.00	3.79	103.36	76.06	27.30	21000	21000	3.4	4.2
-7.00	-10.14	34.64	38.75	3.29	100.38	69.88	30.51	21000	21000	3.1	4.1
-7.00	-9.58	43.69	47.50	2.62	93.15	57.54	35.61	21000	21000	2.6	3.8
-7.00	-8.59	52.90	56.25	1.76	81.77	35.29	46.48	21000	21000	1.6	3.3
-7.00	-5.96	62.22	65.00	0.75	67.97	-23.20	91.17	21000	21000	-1.0	2.8
-4.00	-7.78	25.43	30.00	4.05	111.78	84.21	27.57	21000	21000	3.8	4.6
-4.00	-7.51	34.29	38.75	3.54	108.89	78.09	30.80	21000	21000	3.5	4.5
-4.00	-6.96	43.34	47.50	2.84	101.74	65.90	35.85	21000	21000	3.0	4.2
-4.00	-5.99	52.55	56.25	1.96	90.44	44.26	46.18	21000	21000	2.0	3.7
-4.00	-3.67	61.88	65.00	0.91	76.27	-7.26	83.53	21000	21000	-0.3	3.1
-1.00	-5.15	25.08	30.00	4.32	120.26	92.45	27.81	21000	21000	4.2	4.9
-1.00	-4.88	33.94	38.75	3.78	117.46	86.41	31.05	21000	21000	3.9	4.8
-1.00	-4.34	42.98	47.50	3.06	110.41	74.36	36.04	21000	21000	3.3	4.5
-1.00	-3.39	52.19	56.25	2.16	99.17	53.26	45.91	21000	21000	2.4	4.1
-1.00	-1.30	61.53	65.00	1.09	84.78	6.71	78.07	21000	21000	0.3	3.5
2.00	-2.53	24.73	30.00	4.60	128.80	100.78	28.02	21000	21000	4.5	5.3
2.00	-2.26	33.59	38.75	4.03	126.09	94.83	31.26	21000	21000	4.3	5.2
2.00	-1.73	42.63	47.50	3.29	119.13	82.93	36.20	21000	21000	3.7	4.9
2.00	-0.80	51.83	56.25	2.36	107.97	62.31	45.66	21000	21000	2.8	4.4
2.00	1.13	61.18	65.00	1.26	93.44	19.47	73.97	21000	21000	0.9	3.8
5.00	0.09	24.38	30.00	4.87	137.41	109.21	28.21	21000	21000	4.9	5.6
5.00	0.36	33.24	38.75	4.29	134.79	103.34	31.45	21000	21000	4.6	5.5
5.00	0.89	42.27	47.50	3.52	127.92	91.59	36.33	21000	21000	4.1	5.2
5.00	1.79	51.47	56.25	2.57	116.83	71.40	45.43	21000	21000	3.2	4.8
5.00	3.59	60.82	65.00	1.44	102.22	31.44	70.77	21000	21000	1.4	4.2
8.00	2.71	24.02	30.00	5.15	146.08	117.71	28.37	21000	21000	5.3	6.0
8.00	2.97	32.88	38.75	4.54	143.55	111.94	31.61	21000	21000	5.0	5.9
8.00	3.49	41.90	47.50	3.75	136.77	100.33	36.44	21000	21000	4.5	5.6
8.00	4.38	51.10	56.25	2.78	125.77	80.55	45.21	21000	21000	3.6	5.1
8.00	6.07	60.45	65.00	1.63	111.11	42.90	68.21	21000	21000	1.9	4.5
11.00	5.33	23.67	30.00	5.43	154.82	126.30	28.52	21000	21000	5.7	6.3
11.00	5.58	32.52	38.75	4.80	152.38	120.62	31.76	21000	21000	5.4	6.2
11.00	6.10	41.54	47.50	3.99	145.69	109.16	36.52	21000	21000	4.9	6.0
11.00	6.97	50.74	56.25	2.99	134.76	89.75	45.01	21000	21000	4.0	5.5
11.00	8.57	60.09	65.00	1.82	120.09	53.99	66.11	21000	21000	2.4	4.9
14.00	7.94	23.31	30.00	5.71	163.61	134.97	28.65	21000	21000	6.1	6.7
14.00	8.19	32.15	38.75	5.06	161.26	129.38	31.88	21000	21000	5.8	6.6
14.00	8.70	41.17	47.50	4.23	154.66	118.07	36.59	21000	21000	5.3	6.3
14.00	9.55	50.37	56.25	3.21	143.83	99.01	44.82	21000	21000	4.4	5.9
14.00	11.09	59.72	65.00	2.01	129.16	64.83	64.34	21000	21000	2.9	5.3
17.00	10.54	22.94	30.00	6.00	172.47	143.71	28.76	21000	21000	6.5	7.1
17.00	10.79	31.79	38.75	5.32	170.21	138.23	31.99	21000	21000	6.2	7.0
17.00	11.29	40.80	47.50	4.47	163.71	127.06	36.65	21000	21000	5.7	6.7
17.00	12.13	49.99	56.25	3.43	152.96	108.33	44.63	21000	21000	4.9	6.3
17.00	13.61	59.34	65.00	2.20	138.32	75.49	62.82	21000	21000	3.4	5.7
20.00	13.15	22.58	30.00	6.28	181.40	152.53	28.87	21000	21000	6.9	7.4
20.00	13.39	31.42	38.75	5.59	179.23	147.14	32.08	21000	21000	6.6	7.3
20.00	13.88	40.43	47.50	4.71	172.82	136.12	36.69	21000	21000	6.1	7.1
20.00	14.71	49.62	56.25	3.65	162.16	117.70	44.45	21000	21000	5.3	6.6
20.00	16.14	58.96	65.00	2.40	147.55	86.03	61.51	21000	21000	3.9	6.0

Meier/SIN-130TE/SIN-130TE-Cop.pdf



Figure 1: COP Results for the heat pump at the selected points

Meier/SIN-130TE/SIN-130TE-Qc.pdf



Figure 2: Q_c Results for the heat pump at the selected points