



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services
Sepoy Bazar, P.O.: Medinipur, P.S.: Kotwali, Pin:- 721101

Memo no.: FSR/0125186231500164

Date: 04-10-2023

From:

Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services

To: SWAMI VIBEKANANDA COLLEGE OF EDUCATION

MOUZA - AURANGABAD, J.L.NO.- 151 IN R.S. PLOT NO.- 1530, L.R.PLOT NO.- 1859, P.S.- KESHIARY, DIST.- PASCHIM MEDINIPUR, UNDER 7 NO. KESHIARY GRAM PANCHAYET, PIN - 721133

Sub: Fire Safety Certificate of an Existing G+II Storied Building, the Named in Style "SWAMI VIVEKANANDA COLLEGE OF EDUCATION" under group of Educational building, at Mouza- Aurangabad, J.L No.- 151 in Plot No.- 1530, P.S- Keshiary, Dist.- Paschim Medinipur, under 7 no. Keshiary Gram Panchayet, PIN - 721133.

This is in reference to your application no. 0125189231500096 dated 11-09-2023 regarding the Fire Safety Certificate of an Existing G+II Storied Building, the Named in Style "SWAMI VIVEKANANDA COLLEGE OF EDUCATION" under group of Educational building, at Mouza- Aurangabad, J.L No.- 151 in Plot No.- 1530, P.S- Keshiary, Dist.- Paschim Medinipur, under 7 no. Keshiary Gram Panchayet, PIN - 721133.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

Conditional Fire safety Certificate allow, subject to comply the following Condition with in Six month and informed to this end by written with photo proof.

Condition :-

1. Provide Under ground Reservoir having capacities minimum 30000 ltrs.
2. Pumps driven facilities will be auto mode.

Except those above, the general Recommendations are as follows:-

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No perking will be allowed on the driveway.

2. Directional sign and escape route shall be displayed prominently.

3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. The interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
5. The notice of Fire Fighting and Evacuation with "Exit Sign" from the building shall be prepared and displayed at all vulnerable places of the building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing
7. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
8. First – Aid Fire Fighting system shall be provided as per I.S Specification.
9. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
10. If required the old line shall have to be replace with new line the cables shall always be laid in M.S. conduit pipes continuously bounded to the earth.
11. Periodical flashing of water from the Hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
12. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
13. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling and ducts.
14. A Fire control room with close circuit T.V. system will have to be installed which will observe all the floor of the building
15. Transformer and Switch Gear room shall be protected with automatic CO2 or D.C.P. Fire extinguisher conforming I.S. Specification.
16. A Firemen shall be maintained round the clock for safety of the building.
17. This Fire Safety Certificate is valid for three year and has to be renewed every three year from the date of issue of this letter.
18. Each three year a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the Life & Fire Safety arrangements and installation of the building

N.B: No addition and alteration without prior permission of West Bengal Fire & Emergency Services. Otherwise the Fire Safety certificate will be treated as cancelled.

Signature valid

Digitally Signed
Name: Bani Kumar Choudhury
Date: 04-Oct-2023 20:01:12
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Paschim Medinipur
West Bengal Fire & Emergency Services