

기관부 분기별 안전 점검표
ENGINE DEPT. QUARTERLY SAFETY CHECKLIST

-. Date :

-. Ship's Name :

발전기 GENERATOR

Item	Check point	Standard Value	Result of inspection
No. 1 D/E	Air Circuit Breaker 및 중요계기의 작동상태 확인 Check air circuit breaker & operating condition of important gauge		
	Check Engine Performance		
	Stator Insulation Test	5 MΩ	
	D/E F.O Leakage Alarm		
No. 2 D/E	Air Circuit Breaker 및 중요계기의 작동상태 확인 Check air circuit breaker & operating condition of important gauge		
	Check Engine Performance		
	Stator Insulation Test	5 MΩ	
	D/E F.O Leakage Alarm		
No. 3 D/E	Air Circuit Breaker 및 중요계기의 작동상태 확인 Check air circuit breaker & operating condition of important gauge		
	Check Engine Performance		
	Stator Insulation Test	5 MΩ	
	D/E F.O Leakage Alarm		
No. 4 D/E	Air Circuit Breaker 및 중요계기의 작동상태 확인 Check air circuit breaker & operating condition of important gauge		
	Check Engine Performance		
	Stator Insulation Test	5 MΩ	
	D/E F.O Leakage Alarm		

비상 설비 EMERGENCY EQUIPMENT

Item	Check point	Result of inspection
비상전원공급 Emergency Electric Power Supply	주 전원 OFF에 따른 비상전원이 45초 이내 투입여부 확인 (RTS설치된 선박은 RTS 수행 가능) "Check whether the emergency power is supplied within 45 seconds after the main power is turned off (For vessels equipped with RTS, RTS can be performed).	
Emergency Shut Off System	Test Emergency Shut Off for fuel valve	
	Test Emergency Stop for Engine Room Vent Fan and Fuel Oil pump	
Emergency generator	Check battery	
	과급기 Blower 및 공기 필터 소재 Clean blower and Air filter(or cleaner) for Super-charger	