

JOINT INSPECTION REPORT

ILLUMINATION SYSTEM IN 1x250MW,DPL EXTN UNIT# EXTN 8

The Following points are finalized at presence of BHEL/PSER-DPL Site & also BHEL-PEM- New Delhi dated on 25/06/2014 regarding Power Supply of exhaust fan located near Toilet at different areas of Plant. These are given below.

1. 28 No's extra Switch board type (SWB1) are to be erected for Supply of exhaust fan, located at different areas of Power House and also other auxiliary building. The locations of Switch board are not to be shown in our as built drawing. These are to be installed as per availability of work front.
2. The above items (i.e. SWB1) and Other Wiring materials like Conduit, PVC CU Wire are to be included in Our LOT-4 quantity Clearance.
3. Power Supply are to be given to the Switch board from nearest lighting Junction box.
4. E& C rate are to be given for the above extra work as per work order (Ref PSER: PUR:DPL:SLS:2013:P-152:PO:13:PP:0015:PUR:104 date 09-07-2013) .
5. Amendment are to be done from BHEL/PSER-Kolkata Office for the Station Lighting System for 1x250MW Durgapur TPS (Unit-8), Durgapur. West Bengal.

Schami

BAJAJELECTRICALLIMITED.

SWARNENDU CHATTORAJ
Asst. Mgr. (ESP-BU)
BAJAJELECTRICALLTD.
DPL. Extn. Unit # 8, Durgapur,
W.B.-713201

Pratap Bhattacharya
BHEL-DPL SITE