

CR-E6522E TC150 Report

Compliance Report



Map Height & Width:	8.50 X 11.00 in			
Time Zone:	Pacific Standard Time			
Exclusion Radius:	50 m			
Report Mode:	Standard			
NE Lat & NE Long	37.42060 X -121.97250			
SW Lat & SW Long	37.41570 X -121.98390			

\sim		
	GAP Investigation Complete	
	CGI Investigation Complete	
Report Creation D	Pate 6/28/2016 3:46 PM PDT	

LISA™ Investigation Complete

Approver Name

Approver Signature

Date

Date Printed: 6/28/2016 3:46 PM PDT Report Author: AutomationAdmin Software Version: 2.3.0.1ab1f57 1 of 3



CR-E6522E

TC150 Report



Copper Cast Iron Small Boundary Un-protected Steel Other Plastic Big Boundary Protected Steel PE Plastic

View Table Selected Views Show ghlight GAP Assets **Show Assets** Gaps Show LISAs Show Indications Show Field Notes Boundaries Show Breadcrumk Show FOV Base Map Show X X X First View Мар

Selected Driving Surveys | Selected Driving Surveys | Start Date | St

Isotopic Analysis Table

Surveyor	Date/Time	Result	Isotopic Value/ Uncertainty(‰)	Field Notes
Software Car	12/14/2015 3:29 PM PST	Not Natural Gas	-54.72+/-0.43	1. Not Natural Gas
Software Car	12/14/2015 3:41 PM PST	Capture Canceled	0.00+/-0.00	1. IsO Cap canceled

Indication Table

LISA #	Surveyor	Date/Time	Amplit ude (ppm)	Concentra tion(ppm)	Ethane/Methane Ratio and Uncertainty(%)	Disposition	Confidence in Disposition (%)	Field Notes
1	Software Car	12/14/2015 3:26 PM PST	12.3	15.56	N/A	Possible Natural Gas	N/A	1. 15.6/12.30
2	Software Car	12/14/2015 3:28 PM PST	9.44	9.44	N/A	Possible Natural Gas	N/A	1. 13.7/8.20 2. 13.0/7.97 3. 9.4/9.44

Date Printed: 6/28/2016 3:46 PM PDT Report Author: AutomationAdmin Software Version: 2.3.0.1ab1f57 2 of 3

PICΔRRO Surveyor[™]

CR-E6522E TC150 Report

Surveys Mains and Services at Driving Speeds

LISA #	Surveyor	Date/Time	Amplit ude (ppm)	Concentra tion(ppm)	Ethane/Methane Ratio and Uncertainty(%)	Disposition	Confidence in Disposition (%)	Field Notes
3	Software Car	12/14/2015 3:28 PM PST	3.02	6.01	N/A	Possible Natural Gas	N/A	1. 6.0/3.02
] 4	Software Car	12/14/2015 3:27 PM PST	0.4	2.77	N/A	Possible Natural Gas	N/A	

Date Printed: 6/28/2016 3:46 PM PDT Report Author: AutomationAdmin Software Version: 2.3.0.1ab1f57 3 of 3