

VANTARA PETROCHEM - UNIT 3

PRESSURE SAFETY VALVE TEST REPORT

Report Number:	INS-2023-PSV301-001
Equipment Tag:	PSV-301
Protected Equipment:	V-310 Pressure Vessel
Test Date:	2023-08-05
Tester:	Arvind Menon (EMP-005)
Test Type:	Annual PSV Verification - Bench Test

TEST RESULTS

Parameter	Nameplate	As Found	As Left	Tolerance
Set Pressure (bar)	13.2	13.4	13.2	+/- 3%
Blowdown (%)	7%	8%	7%	5-10%
Seat Tightness	No Leak	Pass	Pass	API 527

CERTIFICATION

PSV-301 tested and certified per API 576 requirements.
Valve adjusted and resealed. New lead seal applied.
Certificate valid until: 2024-08-05

Certified By: Arvind Menon
Reference: PESO Rules, Rule 14