

# VANTARA PETROCHEM - UNIT 3

## STORAGE TANK INSPECTION REPORT

|                  |                                   |
|------------------|-----------------------------------|
| Report Number:   | INS-2023-T401-001                 |
| Equipment Tag:   | T-401                             |
| Equipment Type:  | Intermediate Naphtha Storage Tank |
| Inspection Date: | 2023-04-22                        |
| Inspector:       | Arvind Menon (EMP-005)            |
| Inspection Type: | Internal Inspection per API 653   |

### INSPECTION FINDINGS

#### Floor Plates:

- MFL scan completed, no significant wall loss detected
- Minimum thickness 8.2mm (nominal 9.5mm) - acceptable
- No underside corrosion indications

#### Shell Plates:

- UT thickness survey on all courses
- All readings within acceptable limits
- No pitting or localized corrosion observed

#### Roof:

- Floating roof in good condition
- Rim seal intact
- Drain system functional

#### Appurtenances:

- All nozzles satisfactory
- Gauge hatch gasket replaced (minor wear noted)
- Level instrument connections intact

### CONCLUSION

Tank T-401 is FIT FOR SERVICE.

Next internal inspection due: April 2025 (24-month interval per API 653)

Inspector: Arvind Menon, API 653 Certified

Date: 2023-04-22