

VANTARA PETROCHEM - UNIT 3

FIRED HEATER INSPECTION REPORT

Report Number:	INS-2024-H501-001
Equipment Tag:	H-501
Equipment Type:	Crude Charge Heater
Inspection Date:	2024-01-20
Inspector:	Arvind Menon (EMP-005)
Inspection Type:	Tube Skin Temperature Survey + Visual

INSPECTION FINDINGS

Tube Condition:

- Infrared thermography survey completed
- Maximum tube skin temperature: 365°C (design limit: 380°C)
- No hot spots detected following decoking (ref: WO-2023-019)

Refractory:

- Minor spalling in radiant section - localized repair completed
- Convection section refractory satisfactory

Burners:

- All burners inspected - flame patterns acceptable
- Burner tips cleaned during December 2023 maintenance

CERTIFICATION

H-501 is FIT FOR SERVICE.
Next inspection: January 2025 or at turnaround

Inspector: Arvind Menon
Date: 2024-01-20