

VANTARA PETROCHEM - UNIT 3

STANDARD OPERATING PROCEDURE

EMERGENCY SHUTDOWN PROCEDURE

Document Number:	SOP-ESD-001
Revision:	Rev 2
Effective Date:	2023-01-15
Classification:	CRITICAL

EMERGENCY SHUTDOWN TRIGGERS

- Major hydrocarbon leak
- Fire or explosion
- Loss of utilities (steam, air, power)
- High-high pressure or temperature alarms
- Toxic gas release

ESD ACTIONS

Level 1 - Equipment ESD:

- Trips individual equipment (pump, compressor, heater)
- Operator can initiate from field or control room

Level 2 - Unit ESD:

- Trips entire CDU unit
- Closes all feed valves
- Trips all fired equipment
- Depressures to flare

Level 3 - Plant ESD:

- Full plant emergency shutdown
- Initiated only by Shift Supervisor or Plant Manager

POST-ESD ACTIONS

- Account for all personnel
- Assess situation before any restart
- Document incident per INC procedure