

VANTARA PETROCHEM - UNIT 3

STANDARD OPERATING PROCEDURE

LOCKOUT-TAGOUT (LOTO) PROCEDURE

Document Number:	SOP-LOTO-001
Revision:	Rev 2
Effective Date:	2022-06-15
Review Date:	2024-06-15
Author:	Kavitha Reddy, HSE
Approved By:	Plant Manager

1. PURPOSE

This procedure establishes requirements for the lockout and tagout of energy isolating devices to prevent injury to personnel during maintenance activities.

2. SCOPE

Applies to all maintenance activities on rotating equipment, pressure systems, electrical systems, and any equipment with potential stored energy.

3. PROCEDURE

3.1 Preparation

- Identify all energy sources for the equipment
- Notify affected personnel of impending shutdown
- Obtain LOTO equipment (locks, tags, chains, blocks)

3.2 Equipment Shutdown

- Shut down equipment using normal operating procedures
- Operate the energy isolating devices to isolate equipment from energy sources

3.3 Lockout/Tagout Application

- Apply locks to each energy isolating device
- Apply tags indicating the equipment is locked out
- Each worker applies their own personal lock

3.4 Stored Energy Release

- Release any stored energy (hydraulic, pneumatic, spring, gravitational)
- Block or support equipment as necessary

3.5 Perform Maintenance Work

- Proceed with maintenance activities

- Keep all LOTO devices in place until work is complete

3.6 Restoration

- Verify all tools and personnel are clear
- Remove each person's lock in reverse order of application
- Notify affected personnel before energizing

4. REFERENCES

- OSHA 29 CFR 1910.147
- IS 14489:2018 (Lockout-Tagout Procedures)