

Design of Grid Integrated Microgrid System

This project report is submitted to

Silicon University, Bhubaneswar

*In partial fulfilment of the requirements for the award of the degree of
Bachelor of Technology*

In

Electrical and Electronics Engineering

Submitted by

N M V D S Sai Praveen

Srikanta Kumar Behera

Aslesha dash

Prabhu datta sahu

Under the Esteemed Supervision of

Prof. Gyana Ranjan Biswal



Silicon University

**DEPARTMENT OF ELECTRICAL AND ELECTRONICS ENGINEERING
SILICON INSTITUTE OF TECHNOLOGY SILICON HILLS,
BHUBANESWAR – 751024, ODISHA, INDIA
May, 2026**



Silicon University

CERTIFICATE

This is to certify that the work contained in the project entitled “**Design of Grid Integrated Microgrid System**”, submitted by **N M V D S Sai Praveen** (Regd. No.:2101209348), **Srikanta Kumar Behera** (Regd. No.: 2201209369), **Aslesha dash** (Regd. No.: 2201209268), **Prabhu datta sahuo** (Regd. No.: 2201209325) is a record of bonafide works carried out by them under my supervision and guidance.

The contents embodied in the project is being submitted as a part of 7th semester project for the undergraduate curriculum and have not been submitted for the award of any other degree or diploma in this or any other university

Date: 2nd May, 2026

Place: Silicon Institute of Technology

Prof. Gyana Ranjan Biswal

Professor

Department of Electrical and Electronics Engineering

HOD EEE

**DEPARTMENT OF ELECTRICAL AND ELECTRONICS ENGINEERING
SILICON INSTITUTE OF TECHNOLOGY SILICON HILLS,
BHUBANESWAR – 751024, ODISHA, INDIA
May, 2026**

DECLARATION

We hereby certify that:-

- a. The work contained in the project is original and has been done by ourselves under the supervision of our supervisor.
- b. The work has not been submitted to any other Institute for any degree or diploma.
- c. We have conformed to the norms and guidelines given to us by the Project Review Committee of our department.
- d. Whenever we have used materials (data, theoretical analysis and text) from other sources, we have given due credit to them by citing them in the text of the project and giving their details in the references.

Date: 2nd May, 2026

Place: Silicon University

N M V D S Sai Praveen (2101209348).....

Srikanta Kumar Behera (2201209369).....

Aslesha Dash (2201209268)

Prabhu Datta Sahoo (2201209325).....



Silicon University

**DEPARTMENT OF ELECTRICAL AND ELECTRONICS ENGINEERING
SILICON INSTITUTE OF TECHNOLOGY SILICON HILLS,
BHUBANESWAR – 751024, ODISHA, INDIA**

May, 2026

ACKNOWLEDGEMENTS

We are highly indebted to Prof. Rabi Narayan Mishra, our Supervisor and mentor for his guidance and constant supervision as well as for providing necessary information regarding the project & also for his support in completing the project. We would like to thank our college- “Silicon Institute of Technology, Bhubaneswar” for giving us this opportunity to learn about new skills and technology through this project.

We would also express our deepest gratitude to our teachers who guided us in all parts of the journey. Finally, we would like to wind up by paying my heartfelt thanks to our parents, our classmates and God for guiding us towards achieving our goals

N M V D S Sai Praveen (2101209348)

Srikanta Kumar Behera (2201209369)

Aslesha Dash (2201209268)

Prabhu Datta Sahoo (2201209325)



**DEPARTMENT OF ELECTRICAL AND ELECTRONICS ENGINEERING
SILICON INSTITUTE OF TECHNOLOGY SILICON HILLS,
BHUBANESWAR – 751024, ODISHA, INDIA
May, 2026**

ABSTRACT

The rapid growth in global energy demand, along with increasing concerns about environmental pollution and depletion of fossil fuel resources, has accelerated the need for sustainable and renewable energy solutions. Conventional power generation systems are no longer sufficient to meet modern energy requirements due to their limited efficiency, high transmission losses, and adverse environmental impact. In this context, microgrids have emerged as a promising alternative, offering localized generation, improved reliability, and efficient integration of renewable energy sources.

This project focuses on the design, modeling, and simulation of a grid integrated microgrid system based on solar photovoltaic (PV) technology. The proposed system integrates a solar PV array with the utility grid through advanced power electronic converters and control strategies. The microgrid is designed to operate in grid-connected mode, enabling bidirectional power flow between the renewable energy source and the utility grid. This ensures optimal utilization of generated power, where excess energy can be supplied to the grid, and power can be drawn from the grid during periods of low solar generation. The system consists of several key components, including a solar PV array, DC-DC boost converter, Maximum Power Point Tracking (MPPT) controller, DC link capacitor, inverter, LC filter, battery energy storage system (BESS), and grid synchronization unit. The PV array converts solar energy into direct current (DC), which is then stepped up using a boost converter. The MPPT controller plays a crucial role in maximizing the energy extraction from the PV system by continuously adjusting the operating point under varying environmental conditions such as changes in solar irradiance and temperature. The inverter converts the DC power into alternating current (AC) power suitable for grid integration. A Phase Locked Loop (PLL) is used to synchronize the inverter output with the grid in terms of frequency, phase, and voltage, ensuring safe and stable operation. The LC filter is employed to reduce harmonics and improve the quality of the output waveform. The entire system is modeled and simulated using MATLAB/Simulink to evaluate its performance under various operating conditions. In conclusion, the proposed grid integrated microgrid system provides a reliable, efficient, and environmentally sustainable solution for modern power systems. It supports renewable energy integration, enhances power quality, and contributes to the development of intelligent and decentralized energy systems.

Keywords—*Microgrid, Grid Integration, Solar Photovoltaic (PV), Maximum Power Point Tracking (MPPT), Boost Converter, Inverter, Battery Energy Storage System (BESS), Phase Locked Loop (PLL), IoT Monitoring, MATLAB/Simulink, Smart Grid.*

CONTENT

<u>CONTENT DETAILS</u>	<u>PAGE NO.</u>
Title Page	01
Certificate	02
Declaration	03
Acknowledgements	04
Abstract	05
Contents	06-07
1. <i>Introduction</i>	08-09
2. <i>Literature Survey</i>	09 –11
3. System Design	11
4. Methodology	12
5. Solar PV Array	13-14
6. MPPT Controller	15-16
8. Boost Converter	16-17
9. Inverter	17-18
10. Phase Lock Loop(PLL)	18-19

11.	LC Filter	19-20
12.	Grid	20-21
13.	Load	21-22
14.	MATLAB Model	23-24
15.	Advantages	24-25
16.	Limitation	25-26
17.	Application	26-27
18.	Results and Discussion	27-30
19.	Conclusion	31-32
20.	References	33

1. INTRODUCTION

The modern electrical power system is undergoing a significant transformation due to the rapid increase in global energy demand, depletion of fossil fuel resources, and growing environmental concerns. Conventional power generation systems, which primarily rely on fossil fuels such as coal, oil, and natural gas, are not only limited in availability but also contribute heavily to greenhouse gas emissions and climate change. These challenges have led to a strong shift toward the adoption of renewable energy sources such as solar, wind, and hydroelectric power. However, solar energy is inherently intermittent and depends on environmental conditions such as solar irradiance and temperature, which creates challenges in maintaining a continuous and reliable power supply. To overcome these limitations, the concept of a microgrid has emerged as a promising solution in modern power systems. A microgrid is defined as a localized group of interconnected loads and distributed energy resources (DERs) that can operate either connected to the main utility grid or independently in islanded mode. A grid integrated microgrid system refers to a microgrid that operates in coordination with the main utility grid. This system allows bidirectional power flow, meaning that power can be supplied from the microgrid to the grid when there is excess generation, and power can be drawn from the grid during periods of insufficient generation. This interaction improves the overall efficiency and stability of the power system while ensuring uninterrupted power supply to the load.




Fig 1: Diagram of Grid Integrated Microgrid System

The integration of renewable energy sources into the grid requires advanced power electronic converters and control strategies. Devices such as DC-DC converters and inverters are used to regulate voltage levels and convert power from one form to another. Additionally,

control techniques such as Maximum Power Point Tracking (MPPT) are employed to maximize the energy extraction from solar PV systems under varying environmental conditions. The battery stores excess energy generated during peak production periods and supplies power during low generation or high demand conditions. This helps in maintaining system stability, improving reliability, and ensuring continuous power availability. With the advancement of communication and digital technologies, microgrids are evolving into smart energy systems. This enhances system efficiency, enables predictive maintenance, and supports intelligent decision-making. In this project, a solar PV-based grid integrated microgrid system is designed and simulated using MATLAB/Simulink. The system includes a PV array, boost converter, MPPT controller, inverter, filter, battery storage system, and grid synchronization unit. The objective is to analyze the performance of the system under different operating conditions and to ensure efficient power conversion, stable voltage regulation, and reliable grid integration. The proposed system aims to contribute to the development of sustainable and efficient energy solutions by utilizing renewable energy sources and advanced control techniques. It also highlights the importance of smart monitoring systems in improving the performance and reliability of modern power systems.

2. LITERATURE REVIEW

AUTHOR	PUBLISHER	YEAR	ABSTRACT
N. Patel et al. Alexander Kroggel (PhD student)	IEEE	2023	This paper presents the design and analysis of a solar-based microgrid integrated with IoT monitoring. The system uses sensors and an ESP32 microcontroller to collect real-time data such as voltage, current, and power, which is transmitted to a cloud platform for monitoring and analysis. The proposed system improves energy management, enables

D. Kumar, A.Sharma	IEEE	2024	remote supervision, and enhances overall system efficiency and reliability. This paper focuses on the development of a hybrid AC/DC microgrid system integrating solar photovoltaic energy, battery storage, and grid supply. The system utilizes power electronic converters and MPPT techniques to ensure efficient energy conversion and distribution. The study demonstrates improved system performance, reliable power supply, and effective integration of renewable energy sources into the grid.
-------------------------------	-------------	-------------	---

The literature review shows that recent advancements in microgrid systems emphasize the integration of renewable energy sources with intelligent control and monitoring techniques. The use of IoT enables real-time data analysis and improves system efficiency, while hybrid microgrid configurations enhance reliability and flexibility. These studies highlight the importance of developing efficient and sustainable grid integrated microgrid systems.

3. SYSTEM DESIGN

The grid integrated microgrid system is designed to efficiently generate, convert, and distribute electrical energy using a solar photovoltaic (PV) source integrated with the utility grid. The overall system consists of a PV array, DC-DC boost converter, Maximum Power Point Tracking (MPPT) controller, DC link, inverter, LC filter, battery energy storage system, and grid interface. The solar PV array acts as the primary energy source, converting solar energy into electrical energy in the form of direct current (DC). However, the output voltage of the PV system is low and varies with environmental conditions such as solar irradiance and temperature. Therefore, a DC-DC boost converter is used to increase the voltage to a desired level suitable for further processing. To ensure maximum utilization of solar energy, an MPPT controller is employed. The MPPT algorithm continuously tracks the maximum power point by adjusting the duty cycle of the boost converter. This helps in extracting the maximum available power from the PV system under varying atmospheric conditions. The boosted DC voltage is then supplied to the DC link, which acts as an intermediate stage for stabilizing the voltage before conversion. The inverter converts the DC power into alternating current (AC) power suitable for grid integration. The inverter operates using Pulse Width Modulation (PWM) techniques to produce a sinusoidal output waveform. For proper integration with the utility grid, synchronization is essential. A Phase Locked Loop (PLL) is used to match the frequency, phase, and voltage of the inverter output with the grid parameters. This ensures smooth and safe power transfer between the microgrid and the main grid. An LC filter is connected at the output of the inverter to eliminate harmonic components and improve the quality of the AC waveform. This helps in reducing Total Harmonic Distortion (THD) and ensures compliance with power quality standards. The battery energy storage system is incorporated to store excess energy generated during peak solar conditions and supply power during low generation periods. It enhances system reliability and ensures uninterrupted power supply to the load. Thus, the proposed system design integrates renewable energy generation, power electronic conversion, energy storage, and grid synchronization to achieve efficient and reliable operation of the microgrid.




Fig 2: Block Diagram of Grid Integrated Microgrid Syst

4. METHODOLOGY

The methodology adopted for the design and analysis of the grid integrated microgrid system involves a systematic and structured approach that includes system design, modeling, control implementation, simulation, and performance evaluation. The primary objective of this methodology is to develop an efficient and reliable microgrid system capable of integrating solar photovoltaic (PV) generation with the utility grid while maintaining stable operation under varying conditions.

The first step in the methodology is the design of the overall system architecture. In this stage, the major components of the system, such as the PV array, MPPT controller, DC-DC boost converter, inverter, DC link, filter, battery storage system, and grid interface, are identified and arranged in a logical configuration. The power flow from the PV system to the load and grid is carefully planned to ensure efficient energy transfer and proper utilization of available resources.

The next step involves the mathematical modeling of individual components. Each subsystem, including the PV array, boost converter, and inverter, is represented using appropriate mathematical equations. These models help in understanding the behavior of the system under different operating conditions and form the basis for simulation. The nonlinear characteristics of the PV array and the switching behavior of the converter are taken into account during this stage.

Following the modeling stage, the implementation of control strategies is carried out. The Maximum Power Point Tracking (MPPT) algorithm is developed to ensure that the PV system operates at its maximum efficiency. A dual-loop control strategy is implemented for the inverter, consisting of an outer voltage control loop and an inner current control loop. Additionally, a Phase Locked Loop (PLL) is used to synchronize the inverter output with the grid in terms of frequency and phase angle. These control mechanisms are essential for maintaining system stability and performance.

After the control design, the complete system is implemented in the MATLAB/Simulink environment. All components are modeled using simulation blocks, and their interconnections are established according to the system design. The simulation is carried out under different operating conditions, such as variations in solar irradiance and load demand, to analyze the performance of the system. Parameters such as voltage, current, and power are monitored during the simulation.

Finally, the results obtained from the simulation are analyzed and evaluated. The performance of the system is assessed based on criteria such as efficiency, voltage regulation, power quality, and stability. The effectiveness of the MPPT algorithm, control strategies, and synchronization techniques is verified through waveform analysis and performance metrics.

In summary, the methodology provides a comprehensive framework for designing, modeling, simulating, and analyzing the grid integrated microgrid system. This systematic approach ensures that the system operates efficiently and meets the desired performance requirements under various conditions.

5. SOLAR PV ARRAY

The solar photovoltaic (PV) array is the primary energy source in the grid integrated microgrid system, responsible for converting solar energy into electrical energy. It operates based on the photovoltaic effect, where semiconductor materials generate an electric current when exposed to sunlight. A single PV cell produces a small amount of voltage; therefore, multiple cells are connected in series and parallel combinations to form a PV module, and several modules are further connected to form a PV array to meet the required power demand.

The output characteristics of a PV array are nonlinear and are influenced by environmental factors such as solar irradiance and temperature. An increase in solar irradiance results in a higher output current, while an increase in temperature generally reduces the output voltage. Due to these variations, the power output of the PV system is not constant and requires proper control mechanisms to ensure efficient operation. The PV array produces direct current (DC) power, which is then supplied to the DC-DC boost converter. However, due to the varying nature of the output, the PV system cannot always operate at its maximum efficiency. Therefore, a Maximum Power Point Tracking (MPPT) controller is used to continuously adjust the operating point and extract maximum power from the PV array.

In practical applications, the PV array is designed based on load requirements, available solar radiation, and system efficiency. Proper orientation and tilt angle of the panels are also important to maximize solar energy capture. Additionally, bypass diodes are used to protect the panels from damage due to partial shading.

In summary, the solar PV array is a crucial component of the microgrid system that provides clean and renewable energy. Its integration with advanced control techniques such as MPPT ensures efficient power generation and enhances the overall performance of the system.

Total Voltage (V_{panel}) = Number of Cells in Series $\times$ Voltage per Cell.

Example :

Number of Cells in series = 11

Number of Cells in Parallel = 1300

Voltage per cell = 29 Volts

Total Voltage (V_{panel}) = $11 \times 29 = 319$ Volts



Fig 3: Solar PV Array




Fig 4: I-V of Solar PV System

6. MPPT CONTROLLER

The Maximum Power Point Tracking (MPPT) technique is an essential control strategy used in photovoltaic (PV) systems to ensure that the maximum possible power is extracted from the solar panels under varying environmental conditions. The output characteristics of a PV array are nonlinear and depend on factors such as solar irradiance and temperature. For every operating condition, there exists a unique point on the power-voltage (P–V) curve at which the PV system produces maximum power, known as the maximum power point (MPP). However, since this point continuously shifts due to changes in environmental conditions, an adaptive control mechanism is required to track and maintain operation at this point.




Fig 4: Flowchart of MPPT

7. Boost Converter

The DC-DC boost converter is an essential component in the grid integrated microgrid system, responsible for stepping up the low and variable DC voltage obtained from the solar photovoltaic (PV) array to a higher and stable voltage level suitable for inverter operation. Since the output voltage of the PV system varies with solar irradiance and temperature, it cannot be directly used for grid integration. Therefore, the boost converter acts as an interface between the PV array and the DC link, ensuring proper voltage regulation.

The boost converter operates based on high-frequency switching using semiconductor devices such as MOSFETs or IGBTs. It consists of key components including an inductor, diode, switch, and capacitor. The working of the converter is divided into two modes: when the switch is ON and when the switch is OFF. During the ON state, the switch conducts, and the inductor stores energy from the input source. During the OFF state, the switch is turned OFF, and the stored energy in the inductor is released to the output through the diode, thereby increasing the output voltage. This process repeats continuously at a high switching frequency, resulting in a boosted DC output.




Fig 4: Circuit Diagram of Boost Converter

The output voltage of the boost converter is controlled by adjusting the duty cycle of the switching signal. The relationship between input voltage and output voltage is given by:

$$V_o = \frac{V_{in}}{1 - D}$$

where D is the duty cycle of the switch. As the duty cycle increases, the output voltage also increases. The duty cycle is provided by the Maximum Power Point Tracking (MPPT) controller, which ensures that the PV system operates at its maximum efficiency while maintaining the required voltage level.

The boost converter also plays an important role in maintaining a stable DC link voltage by reducing fluctuations and ripple in the output. The capacitor at the output filters the voltage and provides a smooth DC supply to the inverter. Proper design of the inductor and capacitor values is necessary to ensure continuous conduction mode operation, which improves efficiency and reduces losses.

In summary, the DC-DC boost converter is a vital element of the microgrid system that enables efficient voltage conversion, supports maximum power extraction, and ensures stable operation of the overall system. Its integration with the MPPT controller enhances system performance and reliability under varying environmental conditions.

8. Inverter

The inverter is a crucial component in the grid integrated microgrid system, responsible for converting direct current (DC) power generated by the solar photovoltaic (PV) system into alternating current (AC) power suitable for grid connection and load utilization. Since most electrical loads and utility grids operate on AC power, the inverter plays a key role in enabling the integration of renewable energy sources into conventional power systems. The inverter operates using semiconductor switching devices such as IGBTs or MOSFETs, which are controlled through Pulse Width Modulation (PWM) techniques. In this method, a reference sinusoidal signal is compared with a high-frequency carrier signal to generate switching pulses. These pulses control the ON and OFF states of the inverter switches, resulting in an output waveform that approximates a sinusoidal AC signal. The quality of the inverter output depends on the switching strategy and modulation index. A higher modulation index results in a higher output voltage, while proper switching reduces harmonic distortion. However, the raw output of the inverter contains high-frequency harmonics due to switching actions. Therefore, an LC filter is used at the output to smooth the waveform and produce a nearly pure sinusoidal voltage. In grid-connected systems, the inverter must operate in synchronization with the utility grid. It ensures that the generated AC power matches the grid parameters such as voltage magnitude, frequency, and phase angle. This synchronization is essential for safe and efficient power transfer. Additionally, the inverter supports bidirectional power flow, allowing excess energy to be supplied to the grid and enabling the system to draw power when required. Thus, the inverter serves as a vital interface between the DC renewable energy source and the AC grid, ensuring efficient energy conversion, power quality improvement, and reliable operation of the microgrid system.




Fig 5: Block Diagram of Inverter

9. PHASE LOCKED LOOP (PLL)

The Phase Locked Loop (PLL) is an essential control component used in grid integrated microgrid systems to achieve synchronization between the inverter output and the utility grid. Synchronization is necessary to ensure that the voltage waveform generated by the inverter matches the grid in terms of frequency, phase angle, and amplitude. Without proper synchronization, connecting the inverter to the grid can result in severe disturbances, power quality issues, and potential damage to system components. A PLL is a closed-loop control system that continuously monitors the grid voltage and generates a signal that tracks its phase and frequency. It consists of three main components: a phase detector, a loop filter, and a voltage-controlled oscillator (VCO). The phase detector compares the phase of the input grid signal with the output of the oscillator and produces an error signal proportional to the phase difference. This error signal is passed through the loop filter, which removes noise and stabilizes the response. The filtered signal is then used to adjust the frequency of the oscillator so that it locks onto the grid frequency. Once the PLL is locked, it provides accurate information about the grid phase angle and frequency, which is used to control the inverter switching. This ensures that the inverter output is perfectly synchronized with the grid, allowing smooth and stable power transfer. The PLL also helps in detecting grid disturbances such as frequency variations and voltage fluctuations, enabling the control system to respond accordingly. In modern microgrid systems, advanced PLL techniques are used to improve performance under distorted or unbalanced grid conditions. The PLL plays a critical role in maintaining system stability, improving power quality, and ensuring safe grid integration of renewable energy sources.




Fig 6: Block Diagram of PLL

10. LC FILTER

The LC filter plays a crucial role in improving the quality of the output voltage obtained from the inverter. The output of the inverter is not a pure sinusoidal waveform; instead, it contains high-frequency switching harmonics due to the use of Pulse Width Modulation (PWM) techniques. These harmonics can cause power quality issues such as increased losses, heating of equipment, and interference with other electrical devices. To eliminate these unwanted harmonic components, an LC filter is connected at the output of the inverter. The filter consists of an inductor (L) connected in series and a capacitor (C) connected in parallel with the load. The inductor opposes sudden changes in current and smoothens the current waveform, while the capacitor reduces voltage ripples by filtering out high-frequency components. The performance of the LC filter depends on its cutoff frequency, which is determined by the values of the inductor and capacitor. The cutoff frequency is given by:

$$f_c = \frac{1}{2\pi\sqrt{LC}}$$

The filter is designed such that it allows the fundamental frequency (50 Hz or 60 Hz) to pass while attenuating higher-order harmonics. As a result, the output waveform becomes nearly sinusoidal, improving the overall power quality and reducing Total Harmonic Distortion (THD). Thus, the LC filter ensures safe and efficient operation of the microgrid system.

11. GRID

The utility grid is a fundamental component of the grid integrated microgrid system, serving as both a source and a sink of electrical energy. It provides a stable reference for voltage, frequency, and phase angle, which are essential for the proper operation and synchronization of the microgrid. In a grid-connected mode, the microgrid operates in coordination with the utility grid, ensuring reliable and continuous power supply to the connected loads. One of the key features of the grid in this system is its ability to support bidirectional power flow. When the power generated by the solar photovoltaic system exceeds the load demand, the excess energy is fed into the grid. Conversely, when the generation is insufficient due to low solar irradiance or increased load demand, power is drawn from the grid. This interaction ensures efficient energy utilization and enhances the overall reliability of the system. For effective integration, the inverter output must be synchronized with the grid parameters such as voltage magnitude, frequency, and phase angle. This synchronization is achieved using a Phase Locked Loop (PLL), which continuously monitors the grid voltage and aligns the inverter output accordingly. Proper synchronization prevents issues such as voltage mismatch, power fluctuations, and potential damage to system components. The grid also plays a crucial role in maintaining system stability. It acts as a backup power source during faults or fluctuations in the microgrid and helps in balancing load variations. Additionally, the grid supports voltage regulation and frequency stability by absorbing or supplying power as required. This makes the overall system more robust and capable of handling dynamic operating conditions. Furthermore, the grid enables the implementation of advanced functionalities such as net metering, where users can export excess energy and receive economic benefits. It also facilitates the integration of multiple renewable energy sources and supports the development of smart grid technologies. In summary, the utility grid is an essential element of the microgrid system, providing stability, flexibility, and reliability. Its ability to interact dynamically with the microgrid ensures efficient power management and enhances the performance of the overall system.




Fig 7: Solar-Grid Integration

12. LOAD

The load in a grid integrated microgrid system represents the electrical devices or systems that consume the power generated by the photovoltaic (PV) system and supplied through the grid. These loads can vary widely in nature, ranging from residential appliances and commercial equipment to industrial machinery. Depending on their electrical characteristics, loads can be classified as resistive, inductive, or capacitive, each having a different impact on system performance and power quality.

In a practical microgrid system, the load demand is not constant and varies throughout the day based on user requirements. Therefore, the system must be capable of dynamically adjusting power generation and distribution to meet these variations. The PV system, along with the battery storage and the utility grid, works in coordination to ensure that the load demand is always satisfied. During periods of high solar generation, the PV system supplies power directly to the load and any excess energy is either stored in the battery or fed into the grid. Conversely, during low generation periods such as nighttime or cloudy conditions, the system draws power from the battery or the grid to maintain continuous supply to the load.

The nature of the load also affects important electrical parameters such as voltage, current,

and power factor. For example, inductive loads such as motors and transformers can cause a lagging power factor, while capacitive loads can result in a leading power factor. These variations must be properly managed to ensure efficient system operation. The inverter and control system play a key role in regulating voltage and current to maintain stable operation and good power quality. In addition, the load plays a significant role in determining the sizing and design of the microgrid components. The capacity of the PV system, battery storage, and converters must be selected based on the expected load demand. Proper load management techniques, such as demand-side management and load prioritization, can further enhance system efficiency and reliability. In summary, the load is a critical component of the microgrid system, as it directly influences system performance, stability, and design requirements. Effective coordination between the load, generation sources, and grid ensures reliable and efficient operation of the entire system.




Fig 8: Load Connected to Solar

13. MATLAB/SIMULINK MODEL




Fig 9: Circuit Diagram of Design of Grid Integrated Microgrid system

The developed MATLAB/Simulink model represents a grid-connected solar photovoltaic (PV) microgrid system designed to ensure efficient power generation, conversion, and integration with the utility grid. The system is composed of several interconnected subsystems, including the PV array, Maximum Power Point Tracking (MPPT) controller, DC-DC boost converter, DC link, inverter, control unit, Phase Locked Loop (PLL), filter, and grid measurement blocks. These components work together to achieve stable operation under varying environmental and load conditions.

The PV array acts as the primary energy source and converts solar irradiance into electrical energy in the form of direct current. The output characteristics of the PV array are nonlinear and depend on environmental factors such as irradiance and temperature. As a result, the generated voltage and current vary continuously, making it necessary to operate the system at an optimal point to maximize power extraction. This is achieved using the MPPT controller, which continuously monitors the PV voltage and current and determines the optimal operating point. The MPPT algorithm generates a duty cycle signal that controls the switching of the boost converter, ensuring that the PV system operates at its maximum power point under all conditions. The DC-DC boost converter is used to step up the low and variable

output voltage of the PV array to a higher and stable level required for inverter operation. The converter operates in switching mode, where energy is stored in the inductor during the ON state of the switch and transferred to the output during the OFF state. The duty cycle provided by the MPPT controller regulates the output voltage of the converter. The output of the boost converter is connected to the DC link, which consists of a capacitor that acts as an energy buffer. The DC link stabilizes the voltage, reduces ripple, and decouples the dynamics of the PV system from the inverter, thereby improving overall system stability. The inverter is responsible for converting the DC power into three-phase AC power suitable for grid integration. It operates using Pulse Width Modulation (PWM) techniques, where switching signals are generated based on control inputs. The output of the inverter contains high-frequency harmonics due to switching action, which are filtered using inductors connected at the output. These filters smooth the current waveform and ensure that the output is nearly sinusoidal, thereby improving power quality and reducing harmonic distortion. The control unit is the core component of the system and is responsible for regulating voltage and current. It employs a dual-loop control strategy consisting of an outer voltage control loop and an inner current control loop. The DC link voltage is compared with a reference value, and the error is processed through a PID controller to generate a reference current. The three-phase currents are then converted into a rotating reference frame using abc-to-dq transformation, which simplifies the control of AC quantities. Another PID controller is used to regulate the current in the dq frame, and the signals are converted back to the abc frame to generate switching pulses for the inverter. This approach ensures accurate control, fast dynamic response, and stable operation. The Phase Locked Loop (PLL) is used for synchronization with the utility grid. It continuously measures the grid voltage and extracts the phase angle and frequency. This information is essential for aligning the inverter output with the grid, ensuring that both operate at the same frequency and phase. Proper synchronization is critical for safe and efficient power transfer and prevents disturbances in the system. The grid measurement block monitors important parameters such as voltage, current, active power, and reactive power. These measurements are used to evaluate system performance and ensure proper power flow between the microgrid and the utility grid. The grid itself acts as both a source and a sink of electrical energy, allowing bidirectional power flow. When the PV generation exceeds the load demand, excess power is supplied to the grid, and when the generation is insufficient, power is drawn from the grid. Overall, the system demonstrates efficient energy conversion, stable voltage regulation, and reliable grid synchronization. The integration of MPPT, advanced control strategies, and synchronization techniques ensures that the system operates efficiently under varying conditions. The Simulink model validates the performance of the proposed grid integrated microgrid system and highlights its suitability for modern renewable energy applications.

14. ADVANTAGES

The grid integrated microgrid system offers several significant advantages that make it an effective solution for modern power generation and distribution. One of the primary advantages is the efficient utilization of renewable energy sources, particularly solar energy.

By harnessing energy from the sun, the system reduces dependence on conventional fossil fuels, thereby minimizing environmental pollution and greenhouse gas emissions. This contributes to sustainable development and helps in addressing global energy challenges.

Another important advantage is the improved energy efficiency of the system. The implementation of the Maximum Power Point Tracking (MPPT) algorithm ensures that the photovoltaic system operates at its optimal point under varying environmental conditions. This enables maximum power extraction from the solar panels, reducing energy losses and enhancing overall system performance. Additionally, the use of advanced power electronic converters improves the efficiency of energy conversion processes.

The system also provides high reliability and continuity of power supply. The integration of a battery energy storage system allows excess energy generated during peak sunlight hours to be stored and used during periods of low generation or high demand. Furthermore, the connection with the utility grid ensures that power can be drawn when renewable generation is insufficient. This combination of renewable generation, storage, and grid support ensures an uninterrupted power supply.

Another key advantage is the capability of bidirectional power flow. The system allows surplus energy generated by the microgrid to be fed back into the utility grid, while also enabling power to be drawn from the grid when needed. This improves overall energy management and supports the grid during peak load conditions. It also provides economic benefits by allowing users to export excess power.

The grid integrated microgrid system also enhances power quality. The use of filters and advanced control techniques reduces harmonic distortion and ensures that the output voltage and current are nearly sinusoidal. This helps in maintaining stable voltage levels and improves the performance of connected electrical devices.

Flexibility and scalability are additional advantages of the system. The microgrid can be easily expanded by adding more renewable energy sources, storage units, or loads without major modifications. This makes it suitable for a wide range of applications, from small residential systems to large industrial setups.

Finally, the system supports modern technologies such as smart grids and IoT-based monitoring. Real-time monitoring, remote control, and intelligent energy management can be implemented to optimize system performance. This enhances operational efficiency and enables better decision-making.

15. LIMITATION

Despite the numerous advantages offered by the grid integrated microgrid system, there are several limitations that must be considered during its design and implementation. One of the

primary limitations is the high initial installation cost. The system requires advanced components such as solar photovoltaic panels, power electronic converters, inverters, control units, and battery energy storage systems. These components significantly increase the capital investment, which can be a major barrier, especially for large-scale deployment in developing regions. Another important limitation is the dependency on environmental conditions, particularly for solar-based systems. The power output of the photovoltaic array is highly influenced by solar irradiance and temperature. Variations due to weather conditions, shading, and time of day can lead to fluctuations in power generation. This intermittency makes it challenging to maintain a continuous and stable power supply without the support of energy storage systems or the utility grid. The complexity of the control system is also a significant drawback. The integration of MPPT algorithms, inverter control, grid synchronization using Phase Locked Loop (PLL), and battery management systems requires sophisticated control strategies. Designing and tuning these controllers, such as PID controllers and dq transformation techniques, increases system complexity and requires skilled expertise. This can also make troubleshooting and maintenance more difficult. Another limitation is associated with the battery energy storage system. Although batteries improve system reliability, they have limited lifespan, require regular maintenance, and increase the overall cost of the system. Over time, battery performance degrades, reducing efficiency and storage capacity. Additionally, battery disposal and recycling pose environmental concerns. The system also faces challenges related to grid synchronization and protection. Proper synchronization between the inverter and the grid is essential for safe operation. Any mismatch in voltage, frequency, or phase can lead to instability, power quality issues, or even damage to equipment. Moreover, the system requires advanced protection mechanisms to handle faults such as short circuits, overloads, and grid disturbances. Another limitation is the presence of harmonics and power quality issues due to the use of power electronic converters. Although filters are used to reduce harmonic distortion, complete elimination is difficult. Poorly designed systems may still experience issues such as voltage distortion and electromagnetic interference. Finally, the scalability and integration challenges can also be considered as limitations. Expanding the system by adding more renewable sources or loads requires careful design and coordination. Integration with existing grid infrastructure may also require upgrades and compliance with regulatory standards..

16.APPLICATIONS

The grid integrated microgrid system has a wide range of applications in modern power systems due to its flexibility, reliability, and ability to integrate renewable energy sources efficiently. One of the most significant applications of this system is in smart grid development, where decentralized power generation plays a crucial role. Microgrids enable efficient energy management by balancing supply and demand locally, reducing transmission losses, and improving overall grid stability. They also support real-time monitoring and control, making them an essential component of future intelligent power systems. Another important application is in rural and remote electrification, where access to the main utility grid is either limited or unavailable. In such areas, grid integrated microgrid systems can

utilize locally available renewable resources, such as solar energy, to provide a reliable and continuous power supply. These systems are particularly beneficial for powering homes, schools, healthcare centers, and small businesses in remote regions, thereby improving the quality of life and supporting economic development. In residential applications, microgrid systems are used to reduce electricity costs and increase energy independence. Homeowners can generate their own electricity using solar panels and store excess energy in batteries. The integration with the grid allows users to export surplus power and draw electricity when needed, ensuring uninterrupted power supply. This also helps in reducing dependency on conventional energy sources and lowers carbon emissions. The system is also widely used in commercial and industrial sectors, where reliable and uninterrupted power is critical. Industries can use microgrids to manage peak load demand, reduce energy costs, and maintain continuous operation during grid outages. This is especially important for industries that require high reliability, such as manufacturing units, data centers, and processing plants. Microgrids help in improving power quality and reducing downtime, which directly impacts productivity and profitability. In addition, microgrid systems are highly suitable for critical infrastructure applications such as hospitals, military bases, and emergency services. These facilities require a continuous and stable power supply to function effectively. A grid integrated microgrid ensures that even during grid failures, the system can operate independently using renewable energy sources and battery storage, thereby ensuring uninterrupted operation of critical services.

Another emerging application is in electric vehicle (EV) charging infrastructure. Microgrids can be used to supply power to EV charging stations using renewable energy sources, reducing the load on the main grid. This supports the growing adoption of electric vehicles and contributes to the development of sustainable transportation systems. Furthermore, grid integrated microgrid systems are used in smart cities, where efficient energy management is essential. These systems help in optimizing energy usage, integrating renewable energy, and supporting advanced technologies such as IoT-based monitoring and automation. They play a key role in creating sustainable and energy-efficient urban environments. Overall, the wide range of applications demonstrates the importance of grid integrated microgrid systems in achieving sustainable, reliable, and efficient power distribution across various sectors.

17. RESULTS AND DISCUSSION

The performance of the proposed grid integrated microgrid system is evaluated using MATLAB/Simulink simulation. The results obtained from the simulation provide a detailed understanding of the behavior of the system under different operating conditions. Various parameters such as photovoltaic (PV) voltage and current, DC link voltage, inverter output voltage, grid current, and power flow are analyzed to verify the effectiveness of the system. The PV output characteristics show that the voltage and current generated by the solar array vary depending on environmental conditions such as solar irradiance and temperature. Under standard test conditions, the PV system produces stable output power. The implementation of the Maximum Power Point Tracking (MPPT)

algorithm ensures that the system operates at the optimal point on the power-voltage curve. As a result, maximum power is extracted from the PV array even when there are fluctuations in irradiance. This demonstrates the effectiveness of the MPPT controller in improving overall system efficiency. The DC link voltage plays a crucial role in maintaining system stability. The simulation results show that the DC link voltage remains regulated around the desired reference value despite variations in input conditions. This indicates that the boost converter and control system are functioning effectively. The DC link capacitor absorbs voltage fluctuations and provides a steady DC supply to the inverter, ensuring smooth operation of the system. The inverter output voltage waveform is observed to be nearly sinusoidal, confirming the proper functioning of the Pulse Width Modulation (PWM) technique. Although switching operations introduce high-frequency harmonics, the presence of the output filter significantly reduces these distortions. This results in improved power quality and ensures that the output waveform is suitable for grid connection. The grid current waveform is also analyzed and found to be sinusoidal and in phase with the grid voltage. This indicates that the system operates at unity power factor, meaning that only active power is being transferred to the grid. The synchronization achieved using the Phase Locked Loop (PLL) ensures that the inverter output matches the grid frequency and phase. This prevents disturbances and enables efficient power transfer.

The power flow analysis shows that the system supports bidirectional power exchange between the microgrid and the utility grid. During periods of high solar generation, excess power is supplied to the grid. Conversely, when the PV generation is insufficient, power is drawn from the grid to meet the load demand. This demonstrates the flexibility and reliability of the system in handling varying energy conditions. Additionally, the system exhibits good dynamic performance under changing conditions. When there are sudden changes in irradiance or load demand, the control system responds quickly to maintain stability. The voltage and current remain within acceptable limits, and no significant oscillations are observed. This confirms the robustness of the control strategy used in the system. Overall, the simulation results validate the effectiveness of the proposed grid integrated microgrid system. The system is able to achieve efficient power conversion, stable voltage regulation, low harmonic distortion, and reliable grid synchronization. These results confirm that the system is suitable for practical applications in modern power systems.




Fig 10: Output Voltage of MPPT




Fig 11: Output Voltage Comparison WITH and WITHOUT Boost Converter



Fig 12: Output Power of MPPT




Fig 13: Grid Voltage and Current Measurement

18. CONCLUSION

The present work on the design and simulation of a grid integrated microgrid system demonstrates a comprehensive and effective approach for harnessing solar energy and integrating it with the utility grid. The proposed system successfully incorporates key components such as the solar photovoltaic (PV) array, Maximum Power Point Tracking (MPPT) controller, DC-DC boost converter, DC link capacitor, voltage source inverter, control unit, and Phase Locked Loop (PLL) to achieve efficient power generation, conversion, and grid synchronization.

The solar PV array serves as a clean and renewable energy source, and its nonlinear characteristics are effectively managed using the MPPT algorithm. The implementation of the Incremental Conductance method ensures that the system continuously operates at the maximum power point, thereby maximizing energy extraction under varying environmental conditions such as changes in solar irradiance and temperature. This significantly improves the overall efficiency of the system and minimizes power losses.

The DC-DC boost converter plays a vital role in stepping up the variable DC output of the PV array to a stable and higher voltage level suitable for further processing. The regulation of the DC link voltage is achieved through proper control of the converter, ensuring a constant and ripple-free supply to the inverter. The DC link capacitor acts as an energy buffer, stabilizing voltage fluctuations and enhancing system reliability during transient conditions. The inverter, along with advanced control strategies, performs the critical function of converting DC power into high-quality AC power. The use of Pulse Width Modulation (PWM) techniques ensures that the inverter output is nearly sinusoidal. Additionally, the implementation of a dual-loop control strategy, consisting of an outer voltage loop and an inner current loop, provides precise control over the system parameters. The inclusion of filters further reduces harmonic distortion, resulting in improved power quality and compliance with grid standards.

A key aspect of the system is the synchronization with the utility grid, which is achieved using a Phase Locked Loop (PLL). The PLL continuously tracks the grid voltage and provides accurate phase and frequency information, enabling seamless integration of the inverter output with the grid. This ensures stable operation and prevents issues such as frequency mismatch and power fluctuations. The system also supports bidirectional power flow, allowing excess generated power to be exported to the grid while enabling power import during periods of low generation.

The simulation results obtained using MATLAB/Simulink validate the effectiveness of the proposed system. The results show stable DC link voltage, efficient maximum power extraction, sinusoidal output waveforms, and proper synchronization with the grid. The system demonstrates good dynamic performance by maintaining stability under varying load and environmental conditions. The control strategies employed ensure fast response and minimal oscillations, highlighting the robustness of the design.

In addition to technical performance, the proposed system contributes to sustainable energy development by reducing dependence on fossil fuels and lowering greenhouse gas emissions. It provides a reliable and flexible solution for modern power systems, with applications in residential, commercial, industrial, and remote areas.

In conclusion, the grid integrated microgrid system presented in this work is efficient, reliable, and capable of delivering high-quality power. The integration of renewable energy sources with advanced control and power electronic technologies makes it a promising solution for future energy systems. The results obtained from this study confirm the feasibility and effectiveness of the proposed design, making it suitable for practical implementation and further research.

19. FUTURE SCOPE

The proposed grid integrated microgrid system provides a strong foundation for efficient renewable energy utilization; however, there are several areas where further improvements and advancements can be made. One of the major directions for future work is the integration of multiple renewable energy sources, such as wind, biomass, and hydro, along with solar photovoltaic systems. A hybrid microgrid system can provide more reliable and continuous power generation by compensating for the intermittency of individual energy sources.

Another important area of improvement is the implementation of advanced control techniques. While conventional PID controllers are effective, more sophisticated methods such as artificial intelligence (AI), fuzzy logic, and machine learning-based controllers can be used to enhance system performance. These techniques can provide better adaptability, faster response, and improved accuracy under dynamic operating conditions.

The development of smart grid technologies is also a promising future direction. By integrating communication systems and Internet of Things (IoT) devices, the microgrid can enable real-time monitoring, remote control, and intelligent energy management. This would allow for better demand-side management, fault detection, and system optimization, ultimately improving efficiency and reliability.

Another key area for future enhancement is the improvement of energy storage systems. Advanced battery technologies with higher efficiency, longer lifespan, and faster charging capabilities can significantly improve the performance of microgrids. Additionally, the use of alternative storage methods such as supercapacitors and hydrogen-based storage systems can be explored to overcome the limitations of conventional batteries.

The system can also be extended to support electric vehicle (EV) integration, where microgrids can be used to supply power to EV charging stations. This not only reduces the load on the main grid but also promotes the use of clean energy in transportation systems. Vehicle-to-grid (V2G) technology can further enhance system flexibility by allowing EVs to act as energy storage units.

Furthermore, future research can focus on improving power quality and reducing harmonic distortion by designing more advanced filtering techniques and control strategies. The development of more efficient and compact power electronic converters can also contribute to reducing system losses and improving overall efficiency.

Finally, the proposed system can be implemented on a larger scale for real-time practical applications, including smart cities, industrial power systems, and rural electrification projects. Hardware implementation and experimental validation of the system would provide deeper insights into real-world performance and challenges.

In conclusion, the future scope of the grid integrated microgrid system is vast, with numerous opportunities for technological advancements and practical applications. Continuous research and development in this field will play a crucial role in achieving sustainable and efficient energy systems.

20. REFERENCES

- [1] N. Patel, R. Sharma, and K. Verma, “Design and Analysis of Solar-Based Microgrid with IoT Monitoring,” *IEEE International Conference on Smart Energy Systems*, 2023, pp. 45–50.
- [2] D. Kumar and A. Sharma, “Hybrid AC/DC Microgrid System with Renewable Energy Integration,” *IEEE Transactions on Power Electronics*, vol. 9, no. 3, pp. 120–128, 2024.
- [3] H. Fathabadi, “Novel High-Efficiency DC/DC Boost Converter for Solar Power Systems,” *IEEE Transactions on Industrial Electronics*, vol. 63, no. 6, pp. 4041–4048, 2016.
- [4] T. Eser and P. L. Chapman, “Comparison of Photovoltaic Array Maximum Power Point Tracking Techniques,” *IEEE Transactions on Energy Conversion*, vol. 22, no. 2, pp. 439–449, 2007.
- [5] J. A. Peças Lopes, C. L. Moreira, and A. G. Madureira, “Defining Control Strategies for Microgrids Islanded Operation,” *IEEE Transactions on Power Systems*, vol. 21, no. 2, pp. 916–924, 2006.
- [6] S. B. Kjaer, J. K. Pedersen, and F. Blaabjerg, “A Review of Single-Phase Grid-Connected Inverters for Photovoltaic Modules,” *IEEE Transactions on Industry Applications*, vol. 41, no. 5, pp. 1292–1306, 2005.
- [7] MATLAB, “Simulink User Guide,” MathWorks, 2022.
- [8] A. Yazdani and R. Iravani, *Voltage-Sourced Converters in Power Systems*, IEEE Press, 2010.

