

Heat Transfer and Fluid Flow Calculations of Industrial Shell Boilers and Evaluation of Operation Conditions – Draft

Saif-Aldain Aqel

2025

Contents

1	Introduction	3
2	Industrial Application of Shell Boilers	4
2.1	Typical Industries	4
2.2	Typical Steam Duties	5
2.3	Advantages and Limitations	5
2.3.1	Advantages	5
2.3.2	Limitations	6
2.4	Typical Multi-Pass Layout	6
3	Boiler Geometry and Configuration	8
3.1	Overall layout	8
3.2	Drum configuration	9
3.3	Consolidated geometry and surface specification	9
4	Combustion Model	11
4.1	Fuel composition	11
4.2	Stoichiometric O ₂ requirement	12
4.3	Air–fuel ratio and excess air λ	13
4.3.1	Stoichiometric O ₂ requirement (per mole of fuel mixture)	14
4.3.2	Actual O ₂ supplied	14
4.3.3	Air required	15
4.3.4	Air–fuel ratio	15
4.4	Lower heating value (LHV) and heat release	15
4.4.1	Method	16
4.4.2	Numerical results for the present fuel	17
4.4.3	Total heat input to the boiler Q _{in}	18
4.5	Adiabatic flame temperature	19
4.5.1	Thermodynamic formulation	19
4.5.2	Implementation	20
4.5.3	Numerical result for the present case	21
4.6	Flue-gas composition	21
4.6.1	Definitions and distinction	22
4.6.2	Equilibrium flue gas at adiabatic conditions	22

4.6.3	Fully burnt boiler flue gas	24
4.6.4	Output fields	25
5	Heat-Transfer Calculations	27
5.1	Fundamental heat-balance equations	27
5.2	Local energy balance	27
5.3	Overall conductance and resistance network	28
5.4	Stage- and boiler-level duties	29
5.5	Gas-side	30
5.5.1	Single-tube and reversal-chamber (internal)	30
5.5.2	Tube-bank (internal)	31
5.5.3	Economizer (external)	32
5.5.4	Gas radiation model	33
5.6	Water-side	35
5.6.1	Economizer (internal)	35
5.6.2	Tube-bank (external)	37
5.6.3	Treatment of boiling	38
5.7	Per-step resistance insertion	39
5.8	Wall-temperature update and thermal convergence	40
6	Hydraulic Calculations	42
6.1	Gas-Side ΔP per Stage	43
6.2	Water-Side ΔP per Stage	43
6.3	Total Boiler ΔP and Stack Pressure	44
6.4	Consolidated ΔP Table (from solver output)	44
7	Boiler Performance Results	46
7.1	Energy balance (Q_{in} , Q_{useful})	46
7.2	Efficiencies (direct and indirect)	47
7.3	Steam generation rate and mass-flow convergence	47
7.4	Stage level performance	48
7.5	Overall boiler summary	49
8	Sensitivity Analysis	50
8.1	Excess Air Ratio	50
8.2	Drum Pressure	50
9	Conclusion	51

Chapter 1

Introduction

placeholder

Chapter 2

Industrial Application of Shell Boilers

2.1 Typical Industries

Shell (fire-tube) boilers are widely used in small-to-medium steam and hot-water duties where compactness, robustness, and simple operation are prioritized over very high pressure or very large throughput. Typical sectors include:

- Food and beverage
 - Breweries, dairies, sugar refineries
 - Canneries, bakeries, confectionery plants
 - CIP (clean-in-place) systems and sterilization
- Chemical and pharmaceutical
 - Fine chemicals, specialty chemicals
 - Active pharmaceutical ingredient (API) and formulation plants
 - Steam for reactors, jacket heating, and clean steam generators
- Textiles and paper
 - Dyeing, washing, drying, and calendaring operations
 - Small paper mills and converting facilities
- Healthcare and institutional
 - Hospitals, clinics, and laboratories (space heating, humidification, sterilizers, autoclaves)
 - Universities, office complexes, district heating sub-plants
- Light manufacturing and general industry
 - Metal finishing, surface treatment, and cleaning
 - Rubber and plastics processing
 - Laundry services and commercial dry-cleaning

2.2 Typical Steam Duties

Shell boilers are normally applied in low-to-medium pressure ranges and moderate steam capacities:

- Typical operating pressure range:
 - Saturated steam: 6–25 bar, occasionally up to 30 bar
 - Hot-water service: 10–16 bar
- Steam-generation rates (order of magnitude):
 - Small units: 0.5–5 t/h
 - Medium units: 5–20 t/h
 - Large shell boilers (upper practical range): 20–40 t/h, beyond which water-tube designs are usually preferred

2.3 Advantages and Limitations

2.3.1 Advantages

- Compact and integrated construction
 - Furnace, passes, and steam/water space are combined in a single pressure body.
 - Relatively small footprint and simple installation.
- Operational simplicity
 - Straightforward start-up and shutdown procedures.
 - Typically tolerant of moderate load swings and cycling (within design limits).
 - Often delivered as packaged units with burner, controls, and safety devices pre-engineered.
- Low-to-moderate capital cost
 - Attractive for small and medium plants, boiler houses, and decentralized steam supply.
- Good part-load performance
 - Large water content provides thermal buffer, reducing short-cycling of the burner.
 - Reasonable efficiency across a wide load range, especially with economizers.
- Maintenance and inspection
 - Accessible gas passes and tube bundles (depending on design) for cleaning and inspection.
 - Long-established technology with wide service and parts availability.

2.3.2 Limitations

- Pressure and capacity limits
 - Practical upper bounds on shell diameter and plate thickness limit maximum pressure and steam rate.
 - For very high pressure (e.g., >40–60 bar) or very large capacities, water-tube boilers are more suitable.
- Response time
 - Large water inventory slows thermal response to rapid, large load changes compared with water-tube boilers.
- Efficiency ceiling
 - Radiative and convective heat-transfer surfaces are constrained by geometry.
 - Very high efficiencies often require additional heat-recovery equipment (economizers, condensing stages, air preheaters).
- Transport and installation constraints
 - Shell diameter and weight can be limited by route and lifting capacity.
 - Retrofitting within existing boiler houses may be constrained by overall envelope.

2.4 Typical Multi-Pass Layout

Industrial shell boilers typically adopt multi-pass fire-tube configurations to enhance convective heat transfer and maintain acceptable gas-side velocities:

- Two-pass layout
 - First pass: large diameter furnace tube running from burner front to rear tubeplate.
 - Second pass: return of flue gas through banks of small-diameter fire-tubes back to the front tubeplate and flue outlet.
 - Simpler construction but lower total heat-transfer surface compared with three-pass designs.
- Three-pass layout (most common for industrial shell boilers)
 - Pass 1: large diameter furnace tube running from burner front to rear tubeplate.
 - Pass 2: First bank of smoke-tubes (typically reversing at the rear turnaround chamber).
 - Pass 3: Second bank of smoke-tubes.
 - Provides higher overall heat-transfer surface, more uniform gas cooling, and lower exit-gas temperatures.
- Extended heat-recovery sections

- Economizer: additional convective heat exchanger in the flue-gas path downstream of the boiler to preheat feedwater.
- Air preheater / condensing sections (optional): for high-efficiency systems using suitable fuels and materials.
- Flow arrangement
 - Gas-side: burner → furnace (Pass 1) → turnaround chamber → tube bank(s) (Passes 2 and 3) → stack.
 - Water/steam side: natural circulation between heated tube surfaces and the upper steam space within the drum/shell; feedwater introduced at cooler regions (often via economizer), steam drawn from the top of the shell.

This multi-pass concept underpins the subsequent detailed modelling of each convective and radiative heat-transfer stage HX_1-HX_6 in the simulation.

Chapter 3

Boiler Geometry and Configuration

The simulated unit is a three-pass fire-tube shell boiler with six distinct gas-side heat-transfer stages and a single common steam drum on the water/steam side. Hot flue gas from the burner traverses a radiative furnace, two reversal chambers, two convective tube banks, and a final economiser before leaving to the stack. The water/steam side is treated as a single circulating system coupled to all pressure parts.

3.1 Overall layout

The gas path is represented as:

$$\text{Burner} \rightarrow \text{HX}_1 \rightarrow \text{HX}_2 \rightarrow \text{HX}_3 \rightarrow \text{HX}_4 \rightarrow \text{HX}_5 \rightarrow \text{HX}_6 \rightarrow \text{stack}$$

with the following interpretation:

- HX_1 – Furnace (first pass, `single_tube`)
Large, single furnace tube where combustion products enter directly from the burner and transfer heat mainly by radiation and high-temperature convection to the surrounding water/steam.
- HX_2 – First reversal chamber (`reversal_chamber`)
Short cylindrical wet back chamber that turns the flow from the furnace outlet into the first convective tube bank (gas direction change = 180°).
- HX_3 – First convective tube bank (second pass, `tube_bank`)
Bank of small diameter fire tubes arranged in a staggered pattern inside the shell; flue gas flows inside of the tubes, water/steam outside.
- HX_4 – Second reversal chamber (`reversal_chamber`)
Second turning chamber redirecting gas from the first to the second tube bank.

- HX_5 – Second convective tube bank (third pass, `tube_bank`)
Second fire-tube bundle, again in cross-flow, representing the last in-boiler convective pass.
- HX_6 – Economiser (`economiser`)
Separate, downstream tube bank used to preheat feedwater in single-phase operation before entering the drum/boiler circuit.

Pool boiling is enabled for HX_1 – HX_5 (pressure parts); HX_6 is explicitly single-phase on the water side.

3.2 Drum configuration

The boiler has a single horizontal steam drum described by the `Drum` object. Its inner diameter is

$$D_{i,\text{drum}} = 4.5 \text{ m}$$

and its length

$$L_{\text{drum}} = 5.0 \text{ m}$$

.

The drum is not modelled with internal separators or circulation hardware. It simply supplies the saturated water/steam state at boiler pressure, while all circulation effects are represented by the single 1-D water/steam stream used in the heat-transfer stages.

3.3 Consolidated geometry and surface specification

Table 3-1 summarises the principal geometric inputs used in the simulation for the drum and all six heat-transfer stages. Values are taken directly from the YAML configuration files (`drum.yaml` and `stages.yaml`).

Element	Kind	Di [m]	L [m]	N_tubes [-]	Wall t [mm]	Roughness [μm]	Pool boiling [-]
DRUM	drum	4.50	5.00	–	–	0.5	–
HX_1	single_tube	1.40	5.276	1	2.9	0.5	true
HX_2	reversal_ch.	1.60	0.80	1	2.9	0.5	true
HX_3	tube_bank	0.076	4.975	118	2.9	0.5	true
HX_4	reversal_ch.	1.60	0.80	1	2.9	0.5	true
HX_5	tube_bank	0.076	5.620	100	2.9	0.5	true
HX_6	economiser	0.076	7.50	160	2.5	0.5	false

All pressure-part stages (HX_1 – HX_5) share the same steel wall thermal conductivity of $k_{\text{wall}} = 16 \text{ W/m/K}$. The economiser (HX_6) is modelled with a higher wall conductivity $k_{\text{wall}} = 30 \text{ W/m/K}$ and a clean surface (zero fouling thickness) to represent a best-case heat-recovery configuration.

Chapter 4

Combustion Model

4.1 Fuel composition

The boiler is fired with a natural-gas-type fuel defined in the simulation input (`config/fuel.yaml`).

The fuel is supplied at $300K$ and $1.013 \times 10^5 Pa$ with a mass flow rate of $0.5 kg/s$. Its composition is specified on a mass-fraction basis and converted internally to mole fractions for all stoichiometric and thermodynamic calculations.

Table 4-1 summarises the fuel composition in both mass and mole fraction form.

Component	Formula	Mass fraction w_i [-]	Mole fraction x_i [-]	Comment
Methane	CH_4	0.80	0.8895	Main combustible, dominant contributor to LHV
Ethane	C_2H_6	0.10	0.0593	Heavier hydrocarbon, increases LHV and required O_2
Propane	C_3H_8	0.04	0.0162	Heavier hydrocarbon, raises flame temperature
n-Butane	C_4H_{10}	0.01	0.00307	Minor heavy hydrocarbon fraction
Hydrogen sulfide	H_2S	0.01	0.00523	Sulfur-bearing contaminant $\rightarrow SO_2$ in flue gas
Nitrogen	N_2	0.02	0.0127	Inert ballast in the fuel stream
Carbon dioxide	CO_2	0.01	0.00405	Inert (already fully oxidised)
Water vapour	H_2O	0.01	0.00990	Moisture carried with the fuel

The mass fractions sum to 1.0 by definition. The mole fractions x_i are obtained from

$$x_i = \frac{\frac{w_i}{M_i}}{\sum_j \frac{w_j}{M_j}}$$

where M_i is the molar mass of species i from `molar_masses` in `common/constants.py`. The resulting fuel mixture is therefore predominantly methane with small amounts of heavier hydrocarbons and trace inert/contaminant species, representative of a typical processed natural gas for boiler firing.

4.2 Stoichiometric O_2 requirement

Evaluate the stoichiometric oxygen requirement via the function `stoich_O2_required_per_mol` in `combustion/flue.py`. The algorithm is:

1. Use per-mole-of-species stoichiometric O_2 factors $\nu_{O_2,i}$ from `O2_per_mol` in `common/constants.py`:

Species	Global reaction (complete combustion)	$\nu_{O_2,i}$ [mol O_2 / mol species]
CH_4	$CH_4 + 2 O_2 \rightarrow CO_2 + 2 H_2O$	2.0
C_2H_6	$C_2H_6 + 3.5 O_2 \rightarrow 2 CO_2 + 3 H_2O$	3.5
C_3H_8	$C_3H_8 + 5 O_2 \rightarrow 3 CO_2 + 4 H_2O$	5.0
C_4H_{10}	$C_4H_{10} + 6.5 O_2 \rightarrow 4 CO_2 + 5 H_2O$	6.5
H_2S	$H_2S + 1 O_2 \rightarrow SO_2 + H_2O$	1.0
N_2, CO_2, H_2O	Inert/fully oxidised \rightarrow no additional O_2	0.0

2. Compute the stoichiometric O_2 requirement per mole of fuel mixture as

$$\nu_{O_2,stoich} = \sum_i x_i \nu_{O_2,i}$$

Using the mole fractions from Section 4.1 for the present fuel:

- $x_{CH_4} = 0.8895$
- $x_{C_2H_6} = 0.0593$
- $x_{C_3H_8} = 0.0162$
- $x_{C_4H_{10}} = 0.00307$
- $x_{H_2S} = 0.00523$

- remaining species: x_{N_2} , x_{CO_2} , x_{H_2O} are inert in the stoichiometric balance.

Hence

$$\begin{aligned}\nu_{O_2, \text{stoich}} &= 0.8895 \cdot 2.0 + 0.0593 \cdot 3.5 + 0.0162 \cdot 5.0 + 0.00307 \cdot 6.5 + 0.00523 \cdot 1.0 \\ &\approx 2.09 \text{ mol } O_2 \text{ per mol fuel mixture}\end{aligned}$$

This is exactly what `stoich_O2_required_per_mol_fuel` returns:

```
def stoich_O2_required_per_mol_fuel(fuel: GasStream) -> Q_:
    fuel_x = to_mole(fuel.comp)
    total = sum(fuel_x[k] * O2_per_mol.get(k, 0.0) for k in fuel_x)
    return Q_(total, "dimensionless")
```

For later hydraulic and performance interpretation, it is also useful to express this on a mass basis.

For 1 kg of fuel, the total fuel moles are

$$n_{\text{fuel}, \text{total}} = \sum_i \frac{w_i}{M_i} \approx 56.1 \text{ mol fuel/kg}$$

Thus the stoichiometric O_2 requirement per unit fuel mass is

$$n_{O_2, \text{stoich}}^{(m)} = \nu_{O_2, \text{stoich}} n_{\text{fuel}, \text{total}} \approx 2.09 \times 56.1 \approx 1.17 \times 10^2 \text{ mol } O_2/\text{kg fuel}$$

Converting to mass of O_2 per kg of fuel:

$$\dot{m}_{O_2, \text{stoich}} = n_{O_2, \text{stoich}}^{(m)} M_{O_2} \approx 117.3 \text{ mol/kg} \times 0.031998 \text{ kg/mol} \approx 3.75 \text{ kg } O_2/\text{kg fuel}$$

So, for this fuel:

- Stoichiometric oxygen requirement:

$$\nu_{O_2, \text{stoich}} \approx 2.09 \text{ mol } O_2 \text{ per mol fuel mixture}$$

- Equivalent mass requirement:

$$\dot{m}_{O_2, \text{stoich}} \approx 3.75 \text{ kg } O_2 \text{ per kg fuel}$$

4.3 Air–fuel ratio and excess air λ

The simulation specifies an excess air ratio

$$\lambda = 1.1$$

in `config/operation.yaml`. This value enters the calculation through `air_flow_rates(air, fuel, excess)` in `combustion/flue.py`.

4.3.1 Stoichiometric O₂ requirement (per mole of fuel mixture)

From Section 4.2:

$$\nu_{\text{O}_2, \text{stoich}} = 2.09 \text{ mol O}_2/\text{mol fuel}$$

4.3.2 Actual O₂ supplied

Using:

$$\dot{n}_{\text{O}_2, \text{actual}} = \lambda \dot{n}_{\text{O}_2, \text{stoich}}$$

Thus:

$$\dot{n}_{\text{O}_2, \text{actual}} = 1.1 \nu_{\text{O}_2, \text{stoich}} \dot{n}_{\text{fuel}}$$

The molar fuel flow is determined from the mass-flow rate:

- Fuel mass flow:

$$\dot{m}_f = 0.5 \text{ kg/s}$$

- Total moles per unit mass of fuel mixture (from the mixture molar mass calculation):

$$n_{\text{fuel, total}} \approx 56.1 \text{ mol/kg}$$

- Therefore the total molar fuel flow:

$$\dot{n}_f = 56.1 \times 0.5 \approx 28.05 \text{ mol/s}$$

Hence the stoichiometric and actual O₂ flows are:

$$\dot{n}_{\text{O}_2, \text{stoich}} = 2.09 \times 28.05 = 58.7 \text{ mol/s}$$

$$\dot{n}_{\text{O}_2, \text{actual}} = 1.1 \times 58.7 = 64.6 \text{ mol/s}$$

4.3.3 Air required

Air O₂ mole fraction (from `air.yaml`):

$$x_{\text{O}_2, \text{air}} = 0.2095$$

Thus:

$$\dot{n}_{\text{air}} = \frac{\dot{n}_{\text{O}_2, \text{actual}}}{x_{\text{O}_2, \text{air}}} = \frac{64.6}{0.2095} \approx 308 \text{ mol/s}$$

The air molar mass (mixture weighted) is:

$$M_{\text{air}} \approx 0.02897 \text{ kg/mol}$$

Therefore the mass-based air flow rate:

$$\dot{m}_{\text{air}} = \dot{n}_{\text{air}} M_{\text{air}} \approx 308 \times 0.02897 \approx 8.93 \text{ kg/s}$$

4.3.4 Air–fuel ratio

Mass-based air–fuel ratio:

$$\text{AFR} = \frac{\dot{m}_{\text{air}}}{\dot{m}_f} = \frac{8.93}{0.5} \approx 17.9$$

4.4 Lower heating value (LHV) and heat release

The fuel lower and higher heating values, and the corresponding firing rate, are evaluated in `combustion/heat.py` by the function `compute_LHV_HHV(fuel)` and then used by `total_input_heat(fuel, air)`.

4.4.1 Method

4.4.1.1 Latent heat of water

Obtain the latent heat of vaporisation of water at the reference pressure $P_{\text{ref}} = 101,325 \text{ Pa}$ from the IAPWS-97 correlation:

```
latent_H2O = WaterProps.h_g(P_ref) - WaterProps.h_f(P_ref)
```

where:

- h_g is the saturated vapour enthalpy,
- h_f is the saturated liquid enthalpy.

4.4.1.2 Reference formation enthalpies

Standard formation enthalpies Δh_f° (at 298.15 K, 1 bar) are taken from `common/constants.py` in kJ/mol:

Species	Δh_f° [kJ/mol]
CH_4	-74.8
C_2H_6	-84.7
C_3H_8	-103.8
C_4H_{10}	-126.1
SO_2	-296.8
CO_2	-393.5
$\text{H}_2\text{O}(l)$	-285.5

4.4.1.3 Products for HHV and LHV

For each fuel species, complete combustion is considered:

- $\text{CH}_4 + 2 \text{O}_2 \rightarrow \text{CO}_2 + 2 \text{H}_2\text{O}$
- $\text{C}_2\text{H}_6 + 3.5 \text{O}_2 \rightarrow 2 \text{CO}_2 + 3 \text{H}_2\text{O}$

Builds product formation enthalpies for:

- HHV assumption: water as liquid (condensed)
- LHV assumption: water as vapour (no condensation heat recovered)

```
H2O_liq = _dHf["H2O"] # kJ/mol
H2O_vap = _dHf["H2O"] + latent_H2O * M_H2O # (kJ/kg) * (kg/mol)
```

Then, looping over the *molar* fuel composition `mol_comp = to_mole(fuel.comp)`:

```
react = 0
HHV_p = 0
LHV_p = 0
```

```

for comp, x in mol_comp.items():
    dh = _dHf.get(comp, 0)
    react += x * dh

    C, H = parse_CH(comp)
    if C is not None:
        HHV_p += x * (C * _dHf["CO2"] + (H/2) * H2O_liq)
        LHV_p += x * (C * _dHf["CO2"] + (H/2) * H2O_vap)
    elif comp == "H2S":
        HHV_p += x * (_dHf["SO2"] + H2O_liq)
        LHV_p += x * (_dHf["SO2"] + H2O_vap)
    else:
        HHV_p += x * dh
        LHV_p += x * dh

```

Here:

- `react` represents the mixture-averaged formation enthalpy of the fuel (kJ/mol),
- `HHV_p`, `LHV_p` represent the mixture-averaged formation enthalpy of the ideal products for HHV and LHV definitions.

4.4.1.4 Mixture HHV and LHV (molar, then mass-based)

The mixture molar higher and lower heating values are:

$$\text{HHV}_{\text{mol}} = h_{\text{react}} - h_{\text{prod,HHV}}, \quad \text{LHV}_{\text{mol}} = h_{\text{react}} - h_{\text{prod,LHV}}$$

$$\begin{aligned} \text{HHV}_{\text{mol}} &= \text{react} - \text{HHV}_p && \# \text{ kJ/mol} \\ \text{LHV}_{\text{mol}} &= \text{react} - \text{LHV}_p && \# \text{ kJ/mol} \end{aligned}$$

These are converted to mass-based heating values using the mixture molar mass M_{mix} from `mix_molar_mass(mol_comp)`:

$$\begin{aligned} \text{HHV}_{\text{kg}} &= \text{HHV}_{\text{mol}} / M_{\text{mix}} && \# \text{ kJ/kg} \\ \text{LHV}_{\text{kg}} &= \text{LHV}_{\text{mol}} / M_{\text{mix}} && \# \text{ kJ/kg} \end{aligned}$$

The function returns these, together with the corresponding firing powers:

$$\begin{aligned} P_{\text{HHV}} &= (\text{HHV}_{\text{kg}} * \text{fuel.mass_flow}).\text{to}(\text{"kW"}) \\ P_{\text{LHV}} &= (\text{LHV}_{\text{kg}} * \text{fuel.mass_flow}).\text{to}(\text{"kW"}) \end{aligned}$$

4.4.2 Numerical results for the present fuel

For the fuel specified above, the mixture heating values are:

- Higher heating value (HHV, mass-based):

$$\text{HHV}_{\text{mix}} \approx 52 \text{ MJ/kg}$$

- Lower heating value (LHV, mass-based):

$$\text{LHV}_{\text{mix}} \approx 47 \text{ MJ/kg}$$

For the specified fuel mass flow rate:

$$\dot{m}_f = 0.5 \text{ kg/s}$$

the resulting firing rates are:

- On an HHV basis:

$$P_{\text{HHV}} = \dot{m}_f \text{HHV}_{\text{mix}} \approx 0.5 \times 52 \text{ MJ/s} \approx 26 \text{ MW}$$

- On an LHV basis (used consistently in the simulation):

$$P_{\text{LHV}} = \dot{m}_f \text{LHV}_{\text{mix}} \approx 0.5 \times 47 \text{ MJ/s} \approx 23.6 \text{ MW}$$

These correspond directly to `P_HHV` and `P_LHV` returned by `compute_LHV_HHV`.

4.4.3 Total heat input to the boiler Q_{in}

The function `total_input_heat(fuel, air)` combines chemical and sensible contributions:

```
def total_input_heat(fuel, air):
    _, _, _, power_LHV = compute_LHV_HHV(fuel)
    fuel_sens = sensible_heat(fuel)
    air_sens = sensible_heat(air)
    Q_in = (power_LHV + fuel_sens + air_sens).to("kW")
    return power_LHV, Q_in
```

where `sensible_heat(stream)` uses:

$$Q_{\text{sens}} = \dot{m} c_p (T - T_{\text{ref}})$$

Both fuel and air enter at 300 K, while the reference is 298.15 K; the resulting sensible contributions are small compared with the chemical term P_{LHV} (on the order of tens of kW versus tens of MW). Therefore, numerically:

- LHV-based chemical heat input:

$$P_{\text{LHV}} \approx 23.6 \text{ MW}$$

- Total heat input including sensible:

$$Q_{\text{in}} \approx P_{\text{LHV}} + Q_{\text{sens,fuel}} + Q_{\text{sens,air}} \approx 23.6 \text{ MW} \quad (\text{increase} < 0.1\%)$$

The quantity Q_{in} in the `CombustionResult` object is thus interpreted in the rest of the boiler model as the total LHV-based heat release available to be transferred to the water/steam side.

4.5 Adiabatic flame temperature

The adiabatic flame temperature T_{ad} is evaluated in the model by the function `adiabatic_flame_T(air, fuel)` in `combustion/adiabatic_flame_temperature`. This routine uses Cantera and an enthalpy–pressure equilibrium (HP) calculation to determine the final equilibrium temperature and composition of the flue gas, assuming:

- complete mixing of fuel and air,
- no heat losses to the surroundings (adiabatic),
- constant system pressure (equal to the air/fuel inlet pressure),
- chemical equilibrium among all gas species in `config/flue_cantera.yaml`.

4.5.1 Thermodynamic formulation

Let the fuel and air streams be characterised by:

- mass flows $\dot{m}_{\text{fuel}}, \dot{m}_{\text{air}}$,
- inlet temperatures $T_{\text{fuel}}, T_{\text{air}}$,
- pressure P ,
- compositions (mole fractions) $X_{\text{fuel}}, X_{\text{air}}$.

The total inlet enthalpy rate of the unmixed reactants is

$$\dot{H}_{\text{react}} = \dot{m}_{\text{air}} h_{\text{air}}(T_{\text{air}}, P, X_{\text{air}}) + \dot{m}_{\text{fuel}} h_{\text{fuel}}(T_{\text{fuel}}, P, X_{\text{fuel}})$$

The total mass flow is

$$\dot{m}_{\text{tot}} = \dot{m}_{\text{air}} + \dot{m}_{\text{fuel}}$$

so the mixture-averaged specific enthalpy of the reactants is

$$h_{\text{target}} = \frac{\dot{H}_{\text{react}}}{\dot{m}_{\text{tot}}}$$

The adiabatic, constant-pressure equilibrium state is then defined by the constraints:

$$\begin{aligned} h_{\text{products}}(T_{\text{ad}}, P, \mathbf{X}_{\text{eq}}) &= h_{\text{target}} \\ P_{\text{out}} &= P \\ \mathbf{X}_{\text{eq}} &\text{ satisfies chemical equilibrium at } (T_{\text{ad}}, P) \end{aligned}$$

Cantera is used to enforce this condition via its HP equilibrium mode.

4.5.2 Implementation

Key steps from `adiabatic_flame_T`:

1. Convert the mass-based composition of fuel and air to mole fractions using `to_mole(...)` (from `combustion/mass_mole.py`).
2. Create three Cantera Solution objects using the mechanism `config/flue_cantera.yaml`:

```
gas_air = ct.Solution("config/flue_cantera.yaml", "gas_mixture")
gas_fuel = ct.Solution("config/flue_cantera.yaml", "gas_mixture")
gas_mix = ct.Solution("config/flue_cantera.yaml", "gas_mixture")
```

3. Set the inlet states of the separate streams:

```
gas_air.TPX = T_air, P_Pa, X_air
gas_fuel.TPX = T_fuel, P_Pa, X_fuel
```

4. Compute reactant enthalpy rate and target specific enthalpy:

```
Hdot_react = m_air * gas_air.enthalpy_mass + m_fuel * gas_fuel.enthalpy_mass
h_target = Hdot_react / m_tot # J/kg of mixture
```

5. Build the overall reactant composition $\mathbf{X}_{\text{react}}$ from the molar flow rates of each component in each stream:

```
n_air = molar_flow(air.comp, air.mass_flow)
n_fuel = molar_flow(fuel.comp, fuel.mass_flow)

# Accumulate species molar flow rates
n_dot_sp = {}
X_react = {k: v / n_sum for k, v in n_dot_sp.items() }
```

6. Initialise the mixture and perform HP equilibrium:

```

gas_mix.TPX = 300.0, P_Pa, X_react      # initial guess for T
gas_mix.HP   = h_target, P_Pa          # enforce (H,P)
gas_mix.equilibrate("HP")              # chemical equilibrium

```

7. Construct the resulting flue-gas stream:

```

Y_eq = gas_mix.Y      # equilibrium mass fractions
comp_eq = {sp: Q_(float(Y_eq[i]), "") for i, sp in enumerate(gas_mix.sp)}
          if Y_eq[i] > 1e-15}

flue = GasStream(
    mass_flow = Q_(m_tot, "kg/s"),
    T          = Q_(gas_mix.T, "K"),
    P          = air.P,
    comp       = comp_eq,
)

```

The adiabatic flame temperature is then available as `flue.T` and is also stored in `CombustionResult.T_ad`.

4.5.3 Numerical result for the present case

For the given conditions:

- Fuel: natural-gas-type mixture from Section 4.1,
 $\dot{m}_{\text{fuel}} = 0.5 \text{ kg/s}$, $T_{\text{fuel}} = 300 \text{ K}$, $1.013 \times 10^5 \text{ Pa}$.
- Air: dry air at 300 K and $1.013 \times 10^5 \text{ Pa}$, composition from `config/air.yaml`.
- Excess air: $\lambda = 1.1$ (10 % excess air).

the HP-equilibrium calculation yields an adiabatic flame temperature on the order of:

$$T_{\text{ad}} \approx 2,050 \text{ K} \quad (\approx 1,780^\circ\text{C})$$

This value is consistent with typical adiabatic flame temperatures for natural gas with around 10 % excess air and confirms that the combustion zone (furnace) operates at very high gas temperatures, driving strong radiative and convective heat transfer to the shell-side water/steam.

The scalar `T_ad` is passed forward and written into the boiler summary CSV (`*_boiler_summary.csv`) for reference and later comparison with non-adiabatic stack temperatures obtained from the full boiler simulation.

4.6 Flue-gas composition

In the combustion model two different flue-gas streams are distinguished:

1. An **equilibrium flue gas at adiabatic flame conditions** (`flue_ad`), obtained from high-temperature HP equilibrium in Cantera.
2. A **fully burnt boiler flue gas** (`flue`), obtained from pure stoichiometry with excess air and no dissociation, used throughout the heat-exchanger network.

Both are represented as `GasStream` objects and stored in the `CombustionResult`, but they serve different purposes in the boiler calculation.

4.6.1 Definitions and distinction

- **Equilibrium flue gas (`flue_ad`)**

- Thermodynamic state: high-temperature HP equilibrium at the adiabatic flame temperature.
- Contains all equilibrium species allowed by the mechanism (major products + dissociation products + radicals).
- Used only to:
 - * determine the adiabatic flame temperature T_{ad} ,
 - * report equilibrium composition in diagnostics/CSV.

- **Fully burnt flue gas (`flue`)**

- Thermodynamic state: chemically frozen, fully burnt mixture at the same temperature and pressure as the equilibrium gas at burner exit.
- Contains only “engineering” products (CO_2 , H_2O , SO_2 , O_2 , N_2 , Ar) with no CO , H_2 , NO_x or radicals.
- Used as the hot-side gas in all boiler heat-transfer and pressure-drop calculations.

Hence, equilibrium chemistry is confined to the flame-temperature calculation, while the boiler itself is solved with a simplified, fully burnt flue gas consistent with complete combustion and 10 % excess air.

4.6.2 Equilibrium flue gas at adiabatic conditions

The adiabatic flame calculation is performed in `combustion/adiabatic_flame_temperature` via the function `adiabatic_flame_T(air, fuel)`:

- The inlet **air** and **fuel** streams are:

- represented as `GasStream` objects (mass flow, T , P , mass fractions),
- converted to mole fractions (`to_mole`) and set into separate Cantera Solution objects (`gas_air`, `gas_fuel`) based on `config/flue_cantera.yaml`.

- A mixed-reactant state is constructed at constant pressure:
 - Total enthalpy flow of reactants:

$$\dot{H}_{\text{react}} = \dot{m}_{\text{air}} h_{\text{air}} + \dot{m}_{\text{fuel}} h_{\text{fuel}}$$

- Target specific enthalpy:

$$h_{\text{target}} = \dot{H}_{\text{react}} / \dot{m}_{\text{tot}}$$

- Overall reactant mole fractions are built from molar flow rates of air and fuel.
- The mixture is then set in Cantera (gas_mix) with:

- composition X_{react} ,
 - pressure $P = P_{\text{air}}$,
 - specific enthalpy $h = h_{\text{target}}$,
 - and equilibrated under HP constraints:

```
gas_mix.TPX = 300.0, P_Pa, X_react    # T placeholder
gas_mix.HP = h_target, P_Pa
gas_mix.equilibrate("HP")
```

- After equilibrium:

- The **adiabatic flame temperature** is gas_mix.T.
 - The **equilibrium mass fractions** are read from gas_mix.Y:

```
Y_eq = gas_mix.Y
comp_eq = {
    sp: Q_(float(Y_eq[i]), "")
    for i, sp in enumerate(gas_mix.species_names)
    if Y_eq[i] > 1e-15
}
```

- These are stored in the equilibrium flue-gas stream:

```
flue_ad = GasStream(
    mass_flow = Q_(m_tot, "kg/s"),
    T          = Q_(gas_mix.T, "K"),
    P          = air.P,
    comp       = comp_eq,
)
```

Typical equilibrium composition ($\lambda = 1.1$, natural gas, $T_{\text{ad}} \approx 2050$ K) is:

- Major species:
 - $\text{CO}_2 \approx 0.085\text{--}0.095$
 - $\text{H}_2\text{O} \approx 0.075\text{--}0.085$

- $O_2 \approx 0.020\text{--}0.030$ (excess air)
- $N_2 \approx 0.78\text{--}0.80$
- Dissociation / minor species:
 - $CO \approx 10^{-3}$
 - $H_2 \approx 10^{-4}$
 - $NO \approx 10^{-4}\text{--}10^{-5}$
 - OH, O , radicals $< 10^{-6}$
 - $SO_2 = 10^{-4}$ (from fuel H_2S)

This composition is physically consistent with high-temperature equilibrium at $2000K$ and slight dissociation.

The object `flue_ad` is stored in `CombustionResult` and is only used to:

- provide T_{ad} and equilibrium composition to the boiler summary CSV,
- support diagnostic post-processing.

It is **not** used directly in the heat-exchanger network.

4.6.3 Fully burnt boiler flue gas

The boiler thermal model requires a chemically simple flue-gas mixture to compute heat transfer and pressure drop. For that purpose a **fully burnt** flue gas is constructed in `combustion/flue.py` and `combustion/combustor.py`:

1. In `Combustor.run()` the air mass flow is first set from stoichiometry plus excess air:

```
air.mass_flow = air_flow_rates(air, fuel, self.excess_air_
```

2. The fully burnt flue-gas composition is then computed from pure stoichiometry:

```
mass_comp_burnt, m_dot_flue = from_fuel_and_air(fuel, air)
```

- `from_fuel_and_air` assumes complete oxidation of:
 - C-containing species $\rightarrow CO_2$,
 - $H \rightarrow H_2O$,
 - $S \rightarrow SO_2$,
- including CO_2 and H_2O already present in the inlet fuel and air.
- The allowed product set is:
 - $CO_2, H_2O, SO_2, O_2, N_2, Ar$.
- Residual O_2 is determined by the imposed excess air ratio λ ; there is no CO , H_2 , NO_x , or radicals in this stream.

Internally, `from_fuel_and_air` works with molar balances:

- determines stoichiometric O_2 demand per mole of fuel (`stoich_o2_required_per_`

- combines fuel and air mole fractions to get:

$$\dot{n}_{\text{CO}_2}, \dot{n}_{\text{H}_2\text{O}}, \dot{n}_{\text{SO}_2}, \dot{n}_{\text{O}_2}, \dot{n}_{\text{N}_2}, \dot{n}_{\text{Ar}}$$

- normalises by total moles to obtain mole fractions, converts to mass fractions (to `mass`), and returns both:
 - `mass_comp` (mass fractions),
 - `m_dot` (total mass flow of flue gas).

3. The fully burnt flue-gas stream is then created as:

```
flue_boiler = GasStream(
    mass_flow = Q_(m_dot_flue, "kg/s"),
    T          = T_ad,          # assume recombination to near T
    P          = air.P,
    comp       = {sp: Q_(y, "") for sp, y in mass_comp_burnt})
```

4. `CombustionResult` is populated with both flue streams:

```
return CombustionResult(
    LHV          = power_LHV,
    Q_in         = Q_in,
    T_ad         = T_ad,
    flue         = flue_boiler, # fully burnt flue used in
    flue_ad      = flue_ad,     # equilibrium flue at T_ad (
    fuel_LHV_mass = LHV_mass,
    fuel_P_LHV    = P_LHV,
)
```

The **boiler solver** (`run_hx`) always receives `combustion.flue` (i.e. `flue_boiler`) as its gas inlet, and this fully burnt composition is used for:

- gas properties (`cp`, `p`, `μ`, `k`),
- heat-transfer coefficients,
- radiative heat transfer (emissivity based on $\text{CO}_2/\text{H}_2\text{O}/\text{SO}_2$),
- pressure-drop estimates and stack temperature.

Thus, the equilibrium flue gas provides a physically consistent high-temperature reference, while the fully burnt flue gas represents the practical working fluid in the convective–radiative sections of the boiler.

4.6.4 Output fields

The flue-gas information exposed to the rest of the model and to the post-processing is encapsulated in `CombustionResult`:

```

@dataclass(frozen=True)
class CombustionResult:
    LHV: Q_
    Q_in: Q_
    T_ad: Q_
    flue: GasStream          # fully-burnt flue used in all boiler HX calculations
    flue_ad: GasStream | None = None  # equilibrium flue at boiler inlet
    fuel_LHV_mass: Q_ | None = None
    fuel_P_LHV: Q_ | None = None

```

The relevant report/CSV entries are:

Field	Meaning
T_ad	Adiabatic flame temperature from HP equilibrium
flue_adGasStream	of equilibrium flue gas (adiabatic composition, diagnostics)
flue	GasStream of fully burnt flue gas used in all boiler HX calculations

This completes the description of how flue-gas composition is defined, distinguished, and used in the boiler model.

Chapter 5

Heat-Transfer Calculations

5.1 Fundamental heat-balance equations

The boiler is modelled as a one-dimensional counter-current heat exchanger composed of six stages (HX₁–HX₅). Heat transfer is resolved along the gas flow direction x , while water flows in the opposite direction. Each stage is discretized into segments of length dx ; all local quantities are defined per unit length.

- Notation (per segment)
 - x – axial coordinate along the gas flow [m]
 - dx – marching step in x [m]
 - \dot{m}_g, \dot{m}_w – gas and water mass flow rates [kg/s]
 - $T_g(x), T_w(x)$ – bulk gas and water temperatures [K]
 - $T_{gw}(x), T_{ww}(x)$ – gas-side and water-side wall temperatures [K]
 - $h_g(x), h_w(x)$ – total gas-side and water-side heat-transfer coefficients [W/m²·K]
 - P_g, P_w – gas-side and water-side wetted perimeters [m]
 - $q'(x)$ – linear heat flux (heat per unit length) [W/m]
 - $UA'(x)$ – overall conductance per unit length [W/K/m]
-

5.2 Local energy balance

For each differential segment of length dx , the model enforces a one-dimensional steady-state energy balance between the gas, the water and the tube wall:

- Heat transferred across the wall:

$$q'(x) = U A'(x) [T_g(x) - T_w(x)]$$

- Relation to the segment duty:

$$dQ(x) = q'(x) dx$$

- Gas stream:

$$dQ(x) = -\dot{m}_g dh_g(x) \Rightarrow \frac{dh_g}{dx} = -\frac{q'(x)}{\dot{m}_g}$$

- Water stream:

$$dQ(x) = +\dot{m}_w dh_w(x) \Rightarrow \frac{dh_w}{dx} = +\frac{q'(x)}{\dot{m}_w}$$

In the numerical implementation these equations are applied in finite-difference form over each marching step:

$$Q_{\text{step}} = q'(x) \Delta x$$

$$\Delta h_g = -\frac{Q_{\text{step}}}{\dot{m}_g}, \quad \Delta h_w = +\frac{Q_{\text{step}}}{\dot{m}_w}$$

5.3 Overall conductance and resistance network

The overall conductance per unit length $U A'(x)$ is obtained from a radial series of thermal resistances per unit length:

- Gas-side convection:

$$R'_g = \frac{1}{h_g(x) P_g}$$

- Gas-side fouling:

$$R'_{fg} = R'_{fi}(P_g) \quad (\text{from specified fouling thickness and conductivity})$$

- Tube wall:

$$R'_w = \frac{\ln(D_o/D_i)}{2\pi k_w}$$

- Water-side fouling:

$$R'_{fc} = R'_{fo}(P_w)$$

- Water-side convection:

$$R'_c = \frac{1}{h_w(x) P_w}$$

where D_i and D_o are the tube inner and outer diameters and k_w is the tube wall thermal conductivity. Combining these contributions:

$$\frac{1}{UA'(x)} = R'_g + R'_{fg} + R'_w + R'_{fc} + R'_c$$

or equivalently,

$$UA'(x) = \left[\frac{1}{h_g P_g} + R'_{fg} + R'_w + R'_{fc} + \frac{1}{h_w P_w} \right]^{-1}$$

The linear heat flux then follows directly:

$$q'(x) = UA'(x) [T_g(x) - T_w(x)]$$

5.4 Stage- and boiler-level duties

For a stage of length L_j , the stage heat duty and stage-level conductance are obtained by integrating the local quantities along x :

$$Q_{\text{stage},j} = \int_0^{L_j} q'(x) dx \approx \sum_i q'_i \Delta x_i$$

$$(UA)_j = \int_0^{L_j} UA'(x) dx \approx \sum_i UA'_i \Delta x_i$$

The total useful boiler duty is the sum of all stage duties:

$$Q_{\text{useful}} = \sum_{j=1}^6 Q_{\text{stage},j}$$

These integrated quantities are later used in the performance and efficiency evaluation (Section 7) and for constructing stage-wise summary tables.

5.5 Gas-side

Gas-side heat transfer is computed with geometry-aware correlations based on local gas properties from Cantera (GasProps) and stage-specific geometry from the GeometryBuilder. For each marching step, the total gas-side HTC is split into a convective and a radiative contribution:

$$h_{g,\text{tot}} = h_{g,\text{conv}} + h_{g,\text{rad}}$$

The implementation uses the helper `gas_htc_parts(g, spec, T_{gw})`, which returns $(h_{g,\text{conv}}, h_{g,\text{rad}})$ in $\text{W/m}^2\cdot\text{K}$, and then sums them in `gas_htc`.

5.5.1 Single-tube and reversal-chamber (internal)

Stages of kind "single_tube" and "reversal_chamber" are treated as internal forced convection in a circular duct. The characteristic quantities are:

- Diameter: $D = D_i$ (tube inner diameter)
- Length: L (stage inner length)
- Flow area: $A = A_{\text{hot,flow}}$ (from geometry builder)
- Velocity:

$$V = \frac{\dot{m}_g}{\rho_g A}$$

- Reynolds and Prandtl numbers:

$$\text{Re} = \frac{\rho_g V D}{\mu_g}, \quad \text{Pr} = \frac{c_{p,g} \mu_g}{k_g}$$

Local gas properties $\rho_g, \mu_g, k_g, c_{p,g}$ are obtained from the Cantera mixture at the local gas temperature and pressure.

Laminar/developing flow (Graetz-type)

For $Re < 2300$, uses a Graetz correlation for thermally developing laminar flow:

$$Gz = Re Pr \frac{D}{L}$$

$$Nu = 3.66 + \frac{0.0668 Gz}{1 + 0.04 Gz^{2/3}}$$

(Incropera et al. 2011)

Turbulent flow (Gnielinski with Petukhov friction factor)

For $Re \geq 2300$, the Gnielinski correlation is applied with a Petukhov friction factor:

$$f = (0.79 \ln Re - 1.64)^{-2}$$

(Munson et al. 2013)

$$Nu = \frac{\frac{f}{8}(Re - 1000) Pr}{1 + 12.7 \sqrt{\frac{f}{8}} (Pr^{2/3} - 1)}$$

(Incropera et al. 2011) The local convective heat-transfer coefficient is then:

$$h_{g,conv} = \frac{Nu k_g}{D}$$

(Incropera et al. 2011)

This same internal correlation is used for "single_tube", "reversal_chamber" and "tube_bank" gas-side flow (see below).

5.5.2 Tube-bank (internal)

Stages "tube_bank" correspond to tube bundles inside the shell. In this model, the gas side is still treated as internal flow inside the tubes:

- Hot side (gas): inside tubes (inner diameter D_i), using the same internal forced convection model as in Section 5.2.1.

Thus the gas-side convective HTC in tube-bank stages is:

$$h_{g,\text{conv}}^{(\text{HX3,5})} = \frac{\text{Nu}_{\text{internal}}(\text{Re}, \text{Pr}) k_g}{D_i}$$

with $\text{Nu}_{\text{internal}}$ given by the Graetz/Gnielinski formulation above, and Re , Pr computed from the local gas properties and tube hydraulic diameter.

5.5.3 Economizer (external)

The economizer "economiser" stage reverses the roles: gas flows outside the tubes in crossflow, while water flows inside. The gas-side convection is then modelled as external crossflow over a tube bank.

Key geometry quantities (from GeometryBuilder for the economizer):

- Tube outer diameter: $D = D_o$
- Gas-side crossflow area: $A_{\text{bulk}} = A_{\text{hot,flow}}$
- Optional maximum/mean velocity factor:

$$V_{\text{bulk}} = \frac{\dot{m}_g}{\rho_g A_{\text{bulk}}}, \quad V = u_{\text{max}} V_{\text{bulk}}$$

where u_{max} is calculated depending on the tube bank arrangement and spacing between tubes.

- Reynolds and Prandtl numbers:

$$\text{Re} = \frac{\rho_g V D}{\mu_g}, \quad \text{Pr} = \frac{c_{p,g} \mu_g}{k_g}$$

For "economiser" stages the primary correlation is a banded Zukauskas form for crossflow over tube banks:

$$\text{Nu} = C \text{Re}^m \text{Pr}^n$$

(Incropera et al. 2011)

where the coefficients C, m are selected from standard bands as a function of Reynolds number and tube arrangement (inline vs staggered), and the exponent n is:

$$n = \begin{cases} 0.36, & \text{Pr} \leq 10 \\ 0.25, & \text{Pr} > 10 \end{cases}$$

If Re falls outside the tabulated bands, the model falls back to the Churchill–Bernstein correlation for crossflow over a single cylinder:

$$\text{Nu} = 0.3 + \frac{0.62 \text{Re}^{1/2} \text{Pr}^{1/3}}{[1 + (0.4/\text{Pr})^{2/3}]^{1/4}} \left[1 + \left(\frac{\text{Re}}{282000} \right)^{5/8} \right]^{4/5}$$

(Incropera et al. 2011) The gas-side convective HTC in the economizer is then:

$$h_{g,\text{conv}}^{(\text{HX6})} = \frac{\text{Nu } k_g}{D_o}$$

(Incropera et al. 2011)

5.5.4 Gas radiation model

Radiative heat transfer from the flue gas to the furnace surfaces is explicitly accounted for by a participating-medium model for the $\text{H}_2\text{O}/\text{CO}_2$ mixture. The implementation follows a simplified Smith–Shen–Friedman style four-gray model.

For each step, the gas emissivity is computed as:

1. Partial pressures of participating species:

$$p_{\text{H}_2\text{O}} = y_{\text{H}_2\text{O}} P, \quad p_{\text{CO}_2} = y_{\text{CO}_2} P$$

(Modest 2013) where y_i are molar (or mass-fraction-equivalent) composition entries from the flue gas stream, and P is the local gas pressure.

2. Mean beam length:

$$L_b = \begin{cases} L_{\text{rad,override}}, & \text{if specified in the stage} \\ 0.9 D_{h,\text{gas}}, & \text{otherwise} \end{cases}$$

(Modest 2013) with $D_{h,\text{gas}}$ the gas-side hydraulic diameter.

3. Effective optical thickness in each gray band:

$$p_{\text{ratio}} = \frac{p_{\text{H}_2\text{O}} + p_{\text{CO}_2}}{P_{\text{atm}}}$$

(Modest 2013)

$$\tau_j = K_j \left(\frac{T}{1000 \text{ K}} \right)^{T_{\text{exp}}} p_{\text{ratio}} L_b$$

(Modest 2013)

where K_j and weighting factors A_j are fixed band coefficients, T is the gas temperature, and T_{exp} is a temperature exponent (default 0.65, configurable per stage via `rad_Texp`).

4. Total gas emissivity:

$$\varepsilon_g = 1 - \sum_{j=1}^4 A_j \exp(-\tau_j)$$

(Modest 2013) with ε_g constrained to $[0, 1]$.

A mean-film temperature is used for the linearized radiative HTC:

$$T_{\text{film}} = \frac{T_g + T_{gw}}{2}$$

$$h_{g,\text{rad}} = 4 \sigma F \varepsilon_g T_{\text{film}}^3$$

(Modest 2013)

where:

- σ is the Stefan–Boltzmann constant,
- F is an effective view factor (default 1.0 or stage-specific `rad_F`).

The gas-side total HTC reported and used in the resistance network is then:

$$h_{g,\text{tot}} = h_{g,\text{conv}} + h_{g,\text{rad}}$$

and the corresponding convective/radiative contributions to the linear heat flux are tracked via:

$$q'_{\text{conv}} = q' \frac{h_{g,\text{conv}}}{h_{g,\text{tot}}}, \quad q'_{\text{rad}} = q' - q'_{\text{conv}}$$

These diagnostics are later integrated on a per-stage basis to quantify the share of convective vs radiative heat transfer in each section of the boiler.

5.6 Water-side

Water-side heat transfer is modelled with geometry-dependent correlations using local water properties from the `WaterProps` helper. The water side appears in two configurations:

1. Water inside tubes (economizer)
2. Water outside tubes in crossflow (HX₁-HX₅)

The total water-side HTC is computed at each marching step as:

$$h_w = h_{w,\text{conv}}$$

Water-side radiation is neglected.

In the present work, the water-side model is used in two distinct regimes:

- HX₁–HX₅ are treated as boiling surfaces in contact with a pool at saturation temperature. In these stages the bulk water temperature is forced to $T^* \text{ sat}(p)$ and the heat-transfer coefficient is obtained from a pure pool-boiling correlation.
- HX₆ (economizer) is treated as a single-phase / flow-boiling tube bundle with water flowing inside the tubes and heated by the flue-gas crossflow.

The underlying implementation is more general (it contains a full Chen-type flow-boiling formulation valid for internal forced convection), but for the final boiler calculations this capability is only used in the economizer; in HX₁–HX₅ the water side is deliberately simplified to a pool-boiling model.

5.6.1 Economizer (internal)

For the economiser stage (kind "economiser", HX₆), where water flows inside the tubes, the model uses standard internal-flow correlations augmented with a viscosity-ratio correction and, when needed, a Chen-type flow-boiling enhancement. The tube inner diameter D_i is used as characteristic length.

5.6.1.1 Velocity and nondimensional groups

$$V_w = \frac{\dot{m}_w}{\rho_w A_{\text{cold,flow}}}$$
$$\text{Re}_w = \frac{\rho_w V_w D_i}{\mu_w}, \quad \text{Pr}_w = \frac{c_{p,w} \mu_w}{k_w}$$

Local water-side properties $\rho_w, \mu_w, k_w, c_{p,w}$ are evaluated at the bulk water temperature.

5.6.1.2 Laminar regime ($\text{Re} < 2300$)

For fully developed laminar internal flow in a circular tube:

$$\text{Nu}_w = 3.66$$

(Incropera et al. 2011) For developing laminar flow, the same Graetz form used on the gas side is applied:

$$\text{Gz}_w = \text{Re}_w \text{Pr}_w \frac{D_i}{L}$$
$$\text{Nu}_w = 3.66 + \frac{0.0668 \text{Gz}_w}{1 + 0.04 \text{Gz}_w^{2/3}}$$

(Incropera et al. 2011)

5.6.1.3 Turbulent regime ($\text{Re} \geq 2300$)

The Gnielinski correlation is used:

$$f_w = (0.79 \ln \text{Re}_w - 1.64)^{-2}$$

(Munson et al. 2013)

$$\text{Nu}_w = \frac{\frac{f_w}{8} (\text{Re}_w - 1000) \text{Pr}_w}{1 + 12.7 \sqrt{\frac{f_w}{8}} (\text{Pr}_w^{2/3} - 1)}$$

(Incropera et al. 2011) In the implementation, the Nusselt number is multiplied by a viscosity-ratio correction $(\mu_b/\mu_w)^{0.11}$ evaluated at bulk and wall temperatures, following the common Gnielinski extension for heated internal flow.

Finally:

$$h_{w,\text{conv}} = \frac{\text{Nu}_w k_w}{D_i}$$

(Incropera et al. 2011)

5.6.2 Tube-bank (external)

In the boiling sections (HX₁–HX₅) the water occupies the shell-side region around the heated tubes. When a crossflow description is needed (e.g. in HX₃ and HX₅), a Zukauskas-type correlation is applied for flow over a tube bundle on the water side, using the outer tube diameter D_o and the cold-side flow area $A_{\text{cold,flow}}$ supplied by the geometry builder.

5.6.2.1 Geometry inputs from GeometryBuilder

- Tube outer diameter: D_o
- Cold-side flow area: $A_{\text{cold,flow}}$
- Water velocity:

$$V_w = \frac{\dot{m}_w}{\rho_w A_{\text{cold,flow}}}$$

- Reynolds and Prandtl numbers:

$$\text{Re}_w = \frac{\rho_w V_w D_o}{\mu_w}, \quad \text{Pr}_w = \frac{c_{p,w} \mu_w}{k_w}$$

5.6.2.2 Zukauskas banded correlation

$$\text{Nu}_w = C \text{Re}_w^m \text{Pr}_w^n$$

Coefficient selection:

- C, m chosen based on the Reynolds band and bundle arrangement (inline or staggered).
- Exponent n :

$$n = \begin{cases} 0.36, & \text{Pr}_w \leq 10 \\ 0.25, & \text{Pr}_w > 10 \end{cases}$$

If the Reynolds number lies outside the valid Zukauskas range, the model falls back to Churchill–Bernstein:

$$\text{Nu}_w = 0.3 + \frac{0.62 \text{Re}_w^{1/2} \text{Pr}_w^{1/3}}{[1 + (0.4/\text{Pr}_w)^{2/3}]^{1/4}} \left[1 + \left(\frac{\text{Re}_w}{282000} \right)^{5/8} \right]^{4/5}$$

(Incropera et al. 2011)

The external HTC is then:

$$h_{w,\text{conv}} = \frac{\text{Nu}_w k_w}{D_o}$$

5.6.3 Treatment of boiling

Boiling is treated differently in the pool-boiling stages (HX_1–HX_5) and in the economiser (HX_6).

5.6.3.1 Pool-boiling

For stages flagged as `pool_boiling = true` (HX_1–HX_5), the water side is deliberately simplified to a pure pool-boiling model:

- The bulk water temperature entering the wall-energy balance is fixed at the saturation temperature corresponding to the local pressure:

$$T_w = T_{\text{sat}}(p_w).$$

- The water-side heat-transfer coefficient is taken from a Cooper-type pool-boiling correlation:

$$h_{w,\text{nb}} = h_{\text{Cooper}}(p_w, q'')$$

(Incropera et al. 2011) where q'' is the local heat flux on the water side and the roughness of the boiling surface enters through the correlation.

- This nucleate-boiling coefficient is used directly as the water-side HTC:

$$h_w = h_{w,\text{nb}},$$

and the region is always tagged as “boiling” in the post-processing.

In other words, HX_1–HX_5 are modelled as heated surfaces immersed in a saturated pool, with boiling controlled by the local heat flux and surface roughness rather than by a detailed prediction of the liquid velocity. This reflects the natural-circulation behavior of the boiler riser and furnace sections and follows the modelling simplification requested for the thesis.

5.6.3.2 Economizer

For the economizer stage HX_6 (`pool_boiling = false`), the model uses a more general internal-flow formulation that can represent both single-phase convection and flow boiling:

1. Boiling detection.

A helper function checks whether the local state falls into the saturation enthalpy interval $[h_f(p), h_g(p)]$ or, for slightly subcooled liquid, whether the wall superheat exceeds a threshold. If neither condition is met, the flow is treated as single-phase liquid.

2. Single-phase regime.

In single-phase operation, the water-side HTC is computed from an internal forced-convection correlation (Gnielinski with viscosity-ratio correction), as described in Section 5.3.1.

3. Flow-boiling regime (Chen-type model).

When boiling is detected, the HTC is assembled from a liquid-only contribution and a nucleate-boiling contribution:

$$h_{lo} = \text{single-phase liquid HTC at } T_{\text{sat}}(p),$$

$$h_{nb} = h_{\text{Cooper}}(p, q''),$$

$$h_w = F h_{lo} + S h_{nb}.$$

(Incropera et al. 2011) The factor F accounts for the effect of two-phase flow on the convective heat transfer (via a Martinelli-type parameter), while S modulates the nucleate-boiling contribution as a function of Reynolds number and mass flux. Both are bounded to remain within reasonable engineering limits.

In the present thesis, this full Chen-type flow-boiling capability is only exercised in the economizer stage. In the main boiling sections (HX_1–HX_5), where circulation is dominated by buoyancy and the flow pattern is closer to pool boiling, the simpler pool-boiling representation described above is preferred.

5.7 Per-step resistance insertion

The water-side resistance per unit length used in the overall UA' assembly is:

$$R'_c = \frac{1}{h_w P_w}$$

where the wetted perimeter is:

- $P_w = \pi D_i$ when water is inside the tubes.
- $P_w = N_{\text{tubes}} \pi D_o$ effective per bundle pitch when water is outside tubes, handled automatically by GeometryBuilder.

Fouling is added in series:

$$R'_{fc} = \frac{\delta_{f,\text{water}}}{k_{f,\text{water}} P_w}$$

Total water-side contribution:

$$R'_{w,\text{side}} = R'_{fc} + R'_c$$

This resistance is passed into the overall conductance formulation (Section 5.1.2).

5.8 Wall-temperature update and thermal convergence

The tube wall temperatures on the gas and water sides, T_{gw} and T_{ww} , are updated using a two-node wall model in each marching step.

Given $q'(x)$, the wall-side energy balances yield:

$$T_{gw} = T_g - \frac{q'}{h_{g,\text{tot}}}$$

$$T_{ww} = T_w + \frac{q'}{h_w}$$

The wall conduction temperature drop is:

$$\Delta T_{\text{wall}} = T_{gw} - T_{ww}$$

which is also equal to:

$$\Delta T_{\text{wall}} = q' [R'_{fg} + R'_w + R'_{fc}]$$

A consistency check is applied; if the implied wall temperature difference from conduction differs from the one implied by convection, the marching solver iterates the HTC evaluation once with relaxed updates (default under-relaxation factor 0.35). Full Picard iteration is omitted for performance reasons.

In the actual implementation this consistency check is performed by iterating on T_{gw} , T_{ww} , and q' using the full resistance network (gas convection, gas fouling, wall, water fouling, water convection), with an under-relaxation factor applied to both wall temperatures and the linear heat flux.

If temperature overshoot (negative film coefficient, reversed driving force) is detected within a step, the step is automatically halved and recomputed.

Chapter 6

Hydraulic Calculations

Hydraulic behaviour is extracted directly from the solver through the per-step pressure-drop decomposition implemented in `heat/solver.py(_gas_dp_components, pressure_drop_gas)` and accumulated at the stage level in `heat/solver.py::solve` and in the boiler summary computed by `heat/postproc.py::summary_from_profile`

The model divides gas-side pressure losses into:

- Frictional losses:
Computed by Colebrook–White (turbulent), laminar $64/\text{Re}$, and a linear transitional blend for $2300 < \text{Re} < 4000$.
The per-step drop is

$$\Delta P_{\text{fric}} = -f \frac{\Delta x}{D_h} \left(\frac{\rho V^2}{2} \right)$$

where f is obtained from `_friction_factor()` and hydraulic diameter, velocity, and density come from the local gas state.

- Minor losses:
Applied using per-stage catalogue K -values.
For reversal chambers, inlet/outlet nozzle K plus bend-equivalent loss are included; tube-banks default to zero unless specified.
In `solve_stage`, the total per-stage loss coefficient K_{sum} is uniformly distributed across N steps:

$$K_{\text{per step}} = \frac{K_{\text{sum}}}{N}$$

The per-step minor loss is

$$\Delta P_{\text{minor}} = -K_{\text{per step}} \left(\frac{\rho V^2}{2} \right)$$

- Total gas-side drop:

$$\Delta P_{\text{total}} = \Delta P_{\text{fric}} + \Delta P_{\text{minor}}$$

Water-side pressure losses are intentionally not included in this model (water at constant pressure).

6.1 Gas-Side ΔP per Stage

During each call to `solve_stage`, the solver marches through all steps and accumulates:

- `dP_stage_fric`
- `dP_stage_minor`
- `dP_stage_total`

These appear in each stage row of `summary_rows` returned by `run_hx()`. An example schema from `summary_from_profile()`:

```
"ΔP_stage_fric[Pa]": dP_fric,
"ΔP_stage_minor[Pa]": dP_minor,
"ΔP_stage_total[Pa]": dP_total,
```

Values are integrated over the entire stage length:

$$\Delta P_{\text{stage}} = \sum_{i=1}^N \Delta P(i)$$

6.2 Water-Side ΔP per Stage

The present solver does not compute water-side frictional or accelerational pressure losses.

From the code (`update_water_after_step`), pressure remains constant:

```
WaterStream(mass_flow=w.mass_flow, h=h_new, P=w.P)
```

Thus:

- Water-side ΔP per stage = 0 Pa
- Total water-side ΔP = 0 Pa

This assumption is consistent with pool-boiling and saturated-drum configurations where the water is not routed through high-velocity conduits.

6.3 Total Boiler ΔP and Stack Pressure

The boiler-level gas-side pressure drop is assembled in the `TOTAL_BOILER` row of `summary_from_profile()`:

```
"ΔP_stage_fric[Pa]": dP_total_fric,
"ΔP_stage_minor[Pa]": dP_total_minor,
"ΔP_stage_total[Pa]": dP_total_total,
```

This yields:

- Total frictional drop:

$$\Delta P_{\text{fric,tot}} = \sum_{k=1}^6 \Delta P_{\text{fric},k}$$

- Total minor-loss drop:

$$\Delta P_{\text{minor,tot}} = \sum_{k=1}^6 \Delta P_{\text{minor},k}$$

- Overall boiler gas-side drop:

$$\Delta P_{\text{boiler}} = \Delta P_{\text{fric,tot}} + \Delta P_{\text{minor,tot}}$$

Stack exit pressure is simply the outlet gas pressure after stage 6:

`gas_out.P`

reported separately in the boiler summary.

6.4 Consolidated ΔP Table (from solver output)

A typical extracted table structure (values populated after running `main.py`):

Stage	Kind	ΔP_{fric} [Pa]	ΔP_{minor} [Pa]	ΔP_{total} [Pa]
HX_1	single_tube
HX_2	reversal_chamber
HX_3	tube_bank
HX_4	reversal_chamber
HX_5	tube_bank
HX_6	economiser	0	0	0
TOTAL	—	Σ	Σ	Σ

HX_6 (economiser) contributes zero ΔP by design (`_gas_dp_components` returns 0 for this stage).

The table is directly generated as part of `summary_rows` once `main.py` completes the mass-flow/efficiency iteration and writes final CSVs.

Chapter 7

Boiler Performance Results

This section summarizes the boiler level performance obtained from the coupled combustion–heat-transfer simulation. All numerical values are extracted from the stage summary and boiler summary data produced by the post-processing step (fields `Q_stage[MW]`, `UA_stage[MW/K]`, `η_direct[-]`, `η_indirect[-]`, `Q_total_useful[MW]`, `Q_in_total[MW]`, `P_LHV[MW]`, `stack_temperature[°C]` etc.).

7.1 Energy balance (Q_{in} , Q_{useful})

The total useful heat transferred from the flue gas to the water/steam side is obtained by integrating the local line heat flux $q'(x)$ over all stages:

$$Q_{useful} = \sum_{k=1}^6 Q_{stage,k} = \sum_{k=1}^6 \int_{stage\ k} q'(x) dx$$

In the implementation this appears as the sum of `Q_stage[MW]` over all stages in `summary_rows`, with the boiler-level result reported in the `TOTAL_BOILER` row as `Q_total_useful[MW]`.

The total input heat from combustion Q_{in} is taken from the combustion module as the rate of heat release from complete fuel burnout (field `Q_in_total[MW]`):

$$Q_{in} = Q_{in,total}$$

For reference, the firing rate on an LHV basis is also reported as `P_LHV[MW]`, obtained from the fuel lower heating value and the fuel mass flow rate.

A concise numerical statement:

- $Q_{in} = Q_{in,total} =$
- $Q_{useful} = Q_{total,useful} =$

7.2 Efficiencies (direct and indirect)

Two boiler efficiencies are reported:

- Direct efficiency (LHV basis)
Direct efficiency is defined as the ratio of useful heat transferred to the firing rate based on fuel LHV:

$$\eta_{\text{direct}} = \frac{Q_{\text{useful}}}{P_{\text{LHV}}}$$

where P_{LHV} is the firing capacity (field P_{LHV} [MW]).

- Indirect efficiency (heat-balance basis)
Indirect efficiency is defined as the ratio of useful heat to the total heat released by combustion:

$$\eta_{\text{indirect}} = \frac{Q_{\text{losses}}}{Q_{\text{in}}}$$

In the post-processing, these appear as the boiler-level fields:

- Direct (LHV) efficiency: $\eta_{\text{direct}} =$
- Indirect efficiency: $\eta_{\text{indirect}} =$

7.3 Steam generation rate and mass-flow convergence

The water/steam mass flow rate is not prescribed but obtained iteratively from an assumed overall boiler efficiency and the combustion heat input. At each iteration n the code:

1. Assumes an efficiency $\eta^{(n)}$.
2. Computes the target useful duty:

$$Q_{\text{target}}^{(n)} = \eta^{(n)} Q_{\text{in}}$$

3. Determines the required water mass flow $\dot{m}_w^{(n)}$ from the enthalpy rise between feed-water and saturated steam at drum pressure:

$$\dot{m}_w^{(n)} = \frac{Q_{\text{target}}^{(n)}}{h_{\text{steam}}(P_{\text{drum}}) - h_{\text{fw}}}$$

4. Runs the full multi-stage heat-exchanger model with $\dot{m}_w^{(n)}$ and reads back the resulting indirect efficiency $\eta_{\text{indirect}}^{(n)}$.
5. Sets the next efficiency guess $\eta^{(n+1)} = \eta_{\text{indirect}}^{(n)}$ and repeats until the mass-flow change is below the specified tolerance:

$$|\dot{m}_w^{(n)} - \dot{m}_w^{(n-1)}| < 10^{-3} \text{ kg/s}$$

The final converged values to be reported are:

- Converged feedwater/steam mass flow:

$$\dot{m}_w = [m_w, \text{ kg/s}]$$

- Number of outer iterations to achieve $|\Delta \dot{m}_w| < 10^{-3} \text{ kg/s}$:

$$N_{\text{iter}} = [N]$$

In the narrative, this subsection should state that the mass-flow/efficiency fixed point converged and that the final efficiency used in the performance summary is the converged η_{indirect} .

7.4 Stage level performance

Stage level performance is summarized from the per-stage rows in the summary table returned by the post-processor. For each stage k the following quantities are available:

- Heat duty: Q_{stage} [MW]
- Overall conductance: UA_{stage} [MW/K]
- Gas inlet/outlet temperatures: gas_in_T [°C], gas_out_T [°C]
- Water inlet/outlet temperatures: $water_in_T$ [°C], $water_out_T$ [°C]
- Gas side pressure drops: $\Delta P_{\text{stage_fric}}$ [Pa], $\Delta P_{\text{stage_minor}}$ [Pa], $\Delta P_{\text{stage_total}}$ [Pa]
- Decomposition of duty into convection and radiation: $Q_{\text{conv_stage}}$ [MW], $Q_{\text{rad_stage}}$ [MW]

Kind	$T_{g,in}$ [°C]	$T_{g,out}$ [°C]	$T_{w,in}$ [°C]	$T_{w,out}$ [°C]	Q_{stage} [MW]	UA_{stage} [MW/K]	ΔP_{stage} [Pa]
single tube	[·]	[·]	[·]	[·]	[·]	[·]	[·]
reversal ch.	[·]	[·]	[·]	[·]	[·]	[·]	[·]
tube bank	[·]	[·]	[·]	[·]	[·]	[·]	[·]

Kind	$T_{g,in}$ [°C]	$T_{g,out}$ [°C]	$T_{w,in}$ [°C]	$T_{w,out}$ [°C]	Q_{stage} [MW]	UA_{stage} [MW/K]	ΔP_{stage} [Pa]
reversal	[·]	[·]	[·]	[·]	[·]	[·]	[·]
ch.	[·]	[·]	[·]	[·]	[·]	[·]	[·]
tube	[·]	[·]	[·]	[·]	[·]	[·]	[·]
bank	[·]	[·]	[·]	[·]	[·]	[·]	[·]
economizer	[·]	[·]	[·]	[·]	[·]	[·]	[·]

7.5 Overall boiler summary

The overall boiler performance is finally summarized using the boiler summary table:

Quantity	Symbol	Value
Fuel firing (LHV basis)	P_{LHV}	
Total heat input (combustion)	Q_{in}	
Useful heat to water/steam	Q_{useful}	
Direct efficiency (LHV basis)	η_{direct}	
Indirect efficiency	$\eta_{indirect}$	
Stack gas temperature	T_{stack}	
Gas side friction loss	ΔP_{fric}	
Gas side minor losses	ΔP_{minor}	
Total gas side pressure drop	ΔP_{tot}	
Total convective heat transfer	Q_{conv}	
Total radiative heat transfer	Q_{rad}	

These boiler-level results provide the basis for the sensitivity analysis in Section 8 and for comparing alternative design or operating scenarios.

Chapter 8

Sensitivity Analysis

8.1 Excess Air Ratio

8.2 Drum Pressure

Chapter 9

Conclusion

placeholder

Incropera, Frank P., David P. DeWitt, Theodore L. Bergman, and Adrienne Lavine. 2011. *Fundamentals of Heat and Mass Transfer*. 7th ed. Wiley.

Modest, Michael F. 2013. *Radiative Heat Transfer*. 3rd ed. Academic Press.

Munson, Bruce R., Donald F. Young, and Theodore H. Okiishi. 2013. *Fundamentals of Fluid Mechanics*. 7th ed. Wiley.