

Two Tank Interacting System

GROUP NO: 5

NAMES:

Sayan Dasgoswami 21EE62R11

Sai Joshitha Annareddy 21EE62R10

Pooja Singh Patle 21EE62R02

OBJECTIVE:

Control of Two Tank Interacting System using

1. State feedback controller design.
2. Observer based controller design.
3. Linear Quadratic Regulator (LQR) based controller design.

ABSTRACT:

Liquid tanks which are generally used in industrial facilities have strategic importance because of significance of storage which are highly important for human life. In the process of industrial applications, frequently it is essential to may be store up in tanks and transferred to other tanks as per requirement. It is often necessary to keep the liquid at a certain height or within a certain range. Liquid level control is used in for different industrial applications, like in food processing, water purification systems, filtration, pharmaceutical industries, etc. The state space method of system design is a generalized time domain method for modelling, analysing and designing a wide range of control systems. The two-tank interacting system is a non-linear system, hence the project deals with linearisation of a non-linear model and to develop controllers to control the linear as well as the actual non-linear model.

STATE FEEDBACK CONTROLLER DESIGN

A. LINEAR MODEL:




Figure 1: Two interacting tank system

i) For tank-1:

$$A_1 \frac{dh_1}{dt} = q_{in} - q_1$$

$$q_1 = \frac{h_1 - h_2}{R_1}$$

Hence,

$$A_1 \frac{dh_1}{dt} = q_{in} - \frac{h_1 - h_2}{R_1}$$

$$\frac{dh_1}{dt} = (q_{in} - \frac{h_1 - h_2}{R_1})/A_1 \quad (1)$$

Time constant for tank-1 = $\tau_1 = R_1 A_1$

ii) For tank-2:

$$A_2 \frac{dh_1}{dt} = q_1 - q_0$$

Hence,

$$A_2 \frac{dh_1}{dt} = (h_1 - h_2)/(R_1) - (h_2)/(R_2)$$

$$\frac{dh_1}{dt} = (h_1 - h_2)/(A_2 R_1) - (h_2)/(A_2 R_2) \quad (2)$$

Time constant for tank-2 = $\tau_2 = R_2 A_2$

Where:

1. h_1 (m) = The height of the liquid level in tank-1
2. h_2 (m) = The height of the liquid level in tank-2
3. q_{in} (m³/sec) = Volumetric flow into tank-1
4. q_1 (m³/sec) = Volumetric flow rate from tank-1
5. q_0 (m³/sec) = Volumetric flow rate from tank-2
6. A_1 (m²) = Cross sectional area of tank-1
7. A_2 (m²) = Cross sectional area of tank-2
8. R_1, R_2 = Resistance parameter (valve) in flow line

1. SPECIFICATION TABLE:

Condition	Flow in LPH	Height of tank-1 (mm)	Height of tank-2 (mm)	Area of tank-1 = area of tank-2	Time constant of tank-1	Time constant of tank-2
Final state after step change	300	100	50	$100 \text{ cm}^2 = 0.01 \text{ m}^2$	$\tau_1 = 9 \text{ s}$	$\tau_2 = 3.6 \text{ s}$
Initial state	100	50	30	$100 \text{ cm}^2 = 0.01 \text{ m}^2$	$\tau_1 = 9 \text{ s}$	$\tau_2 = 3.6 \text{ s}$

2. CONTROLLER DESIGN:

a) Model Specifications:

1. Damping ratio (ζ) = 1.739

2. Natural Frequency (ω_n) = 31.62 rad/sec

b) Design algorithm and steps:

Step 1: State space representation of the system

We have two states h_1 and h_2 . Let $h_1 = x_1$ and $h_2 = x_2$

Hence, the state space equation is given as:

$$\begin{bmatrix} \frac{dx_1}{dt} \\ \frac{dx_2}{dt} \end{bmatrix} = \begin{bmatrix} -\frac{1}{R_1 A_1} & \frac{1}{R_1 A_1} \\ \frac{1}{R_1 A_2} & -\frac{1}{R_2 A_2} \left(1 + \frac{R_2}{R_1} \right) \end{bmatrix} \begin{bmatrix} x_1 \\ x_2 \end{bmatrix} + \begin{bmatrix} \frac{1}{A_1} \\ 0 \end{bmatrix} q_{in}$$

The output equation is given as:

$$y = x_2 = \begin{bmatrix} 0 & 1 \end{bmatrix} \begin{bmatrix} x_1 \\ x_2 \end{bmatrix}$$

Step 2: Calculation of values of elements of A, B matrices

$$R_1 = \tau_1 / A_1 = 900 \text{ s/m}^2$$

$$R_2 = \tau_2 / A_2 = 360 \text{ s/m}^2$$

Therefore,

$$A = \begin{bmatrix} -0.11 & 0.11 \\ 0.11 & -0.388 \end{bmatrix}, \quad B = \begin{bmatrix} 100 \\ 0 \end{bmatrix}$$

Where:

A = State matrix (2×2)

B = Input matrix (2×1)

Step 3: System Dynamics

$$\dot{x} = Ax + Bu$$

where:

x = state vector (2×1)

u = control signal (scalar)

A = State matrix (2×2)

B = Input matrix (2×1)

As we are designing the controller based on State feedback control

Hence,

$$u = -Kx$$

where:

K = State feedback gain matrix (1×2) = $[k_1 \quad k_2]$

Step 4: Check controllability condition for given system:

$$\text{Controllability Matrix} = M_c = [B \quad AB] = (2700 \ 0) = 2700 \neq 0$$

Hence M_c is a full rank matrix with rank = 2. So, the given system is controllable.

Step 5: Desired closed loop characteristic equation

$$s^2 + (2\zeta\omega_n)s + \omega_n^2 = 0$$

$$s^2 + 110s + 1000 = 0$$

Step 6: The closed loop State matrix = $A - BK$

Hence, closed loop characteristic equation is given as $|sI - A + BK| = 0$

$$\begin{vmatrix} s + 0.11 + 100k_1 & -0.11 + 100k_2 \\ -0.11 & s + 0.388 \end{vmatrix} = 0$$

$$s^2 + (0.498 + 100k_1)s + (38.8k_1 + 27k_2 + 0.013) = 0$$

By comparing the above equation with desired closed loop characteristic equation, we get

$k_1 = 1.09$ and $k_2 = 87.12$.

Therefore $K = [1.09 \quad 87.12]$.

Value of K from Ackerman's formula using MATLAB gives $K = [1.09 \quad 87.12]$.

Step 7: MATLAB Model and Simulation

a) Simulink Model:




Figure 2: Simulink Model of Linear Two Tank interacting system with state feedback control.

b) Subsystem:




Figure 3: Simulink Model of Linear Two Tank interacting system

c) MATLAB Code:

```
clear all;clc
k1 = 1.09;k2 = 87.12;
h1_0=0;
h2_0=1;
h2eq=0;
h1eq = 0.38*h2eq/0.11;
ueq = (0.11*h1eq-0.11*h2eq)/100;

sim('twotank');
t = ans.simout.time();
y1 = ans.simout.data(:,1);
y2 = ans.simout.data(:,2);
subplot(211);plot(t,y2,'b','linewidth',1); xlabel('time');grid on
subplot(212);hold on;plot(t,y1,'b','linewidth',1); grid on
```

d) Simulation Results(graph):




Figure 4: Response curve of closed-loop control system with initial condition [0 1].

B. Performance of controller on Non-Linear Model:




Figure 5: Two interacting tank system

Mathematical Modelling:

$$A1 \frac{dh_1}{dt} = q_{in} - \rho_1 \sqrt{\rho g (h_1 - h_2)}$$

$$A2 \frac{dh_2}{dt} = \rho_1 \sqrt{\rho g (h_1 - h_2)} - \rho_2 \sqrt{\rho g h_2}$$

Where:

1. h_1 (m) = The height of the liquid level in tank-1
2. h_2 (m) = The height of the liquid level in tank-2
3. q_{in} (m^3/sec) = Volumetric flow into tank-1
4. q_1 (m^3/sec) = Volumetric flow rate from tank-1
5. q_0 (m^3/sec) = Volumetric flow rate from tank-2
6. A_1 (m^2) = Cross sectional area of tank-1
7. A_2 (m^2) = Cross sectional area of tank-2
8. R_1, R_2 = Resistance parameter (valve) in flow line
9. ρ_1 = Proportionality constant of Tank 1
10. ρ_2 = Proportionality constant of Tank 2
11. $\rho = 1$ = specific gravity of water

The same value of State feedback gain matrix is used to check the performance of the controller on non-linear system

1. Simulink Model:




Figure 6: Simulink Model of Non-linear Two Tank interacting system with state feedback control.




Figure 7: Subsystem

2. MATLAB Code:

```
clear all;clc
p1 = 1.262*10e-4;
p2 = 1.262*10e-4;
p=1;
A = 0.01;
g = 9.8066;
h2=0;
h1 = 2*h2;
u = 0.2*p2*sqrt(h2*g);
A_1 = [-0.0625 0.0625;0.0625 0.1248];
B = [100;0];
```

```
k1 = 1.09;k2 = 87.12;
sim('non_linearmodel');
t = ans.simout.time();
y1 = ans.simout.data(:,1);
y2 = ans.simout.data(:,2);

subplot(211);plot(t,y2,'b','Linewidth',1);
subplot(212);plot(t,y1,'r','Linewidth',1);
```

3. Plots:




Figure 8: Response curve of closed-loop control system with initial condition $[0 \ 1]$.

C. Performance comparison:

The performance of the designed State Feedback controller on the linear and the non-linear system is compared with each other.




Figure 9: Response curve of linear and nonlinear system with initial condition $[1 \ 1]$.

OBSERVER BASED CONTROLLER DESIGN

Case 1:

Given data:

Desired closed loop pole location $J = [-10, -100]$

Observer Pole Locations $L = [-1+j*2, -1-j*2]$

Step 1: Check the observability condition of the system. The observability matrix is

$$O = [C^T \ A^T C^T] \\ = \begin{bmatrix} 0 & 0.1111 \\ 1 & -0.3889 \end{bmatrix} \neq 0$$

We find that $O \neq 0$, rank of observability matrix $O=2$. Hence the system is completely state observable.

Step 2: Assume that the state x is to be approximated by the state x' of the dynamic model of observer

$$\dot{x}' = A x' + B u + K_e (y - y') \\ y' = C x'$$

where x' is the estimated state and Cx' is the estimated output. The matrix K_e is called observer gain matrix.

$$\dot{x}' = [A - K_e C] x' + B u + K_e y$$

The system equation which is already known is given as

$$\dot{x} = A x + B u \\ y = C x$$

Now the observer error equation is defined as:

$$x - x' = [A - K_e C] x - x'$$

where the above dynamics is error vector and the dynamic behaviour depends on eigen values of $[A - K_e C]$.

Step 3: By defining the desired state feedback gain matrix $K_e = [K_{e1} \ K_{e2}]^T$

$$|sI - A + K_e C| = 0 \\ s^2 + (0.5 + K_{e2})s + (0.0308 + (K_{e1} + K_{e2})/9) = 0 \dots (a)$$

Step 4: Comparing (a) with the desired characteristics equation from desired poles(L) = $[-1+j*2, -1-j*2]$

$$(s+1+j2)(s+1-j2)=0$$

$$s^2+2s+5=0$$

$$Ke1 = 43.22$$

$$Ke2 = 1.5$$

Step 5: For calculating $k = [k1 \ k2]$ for given closed loop poles(J)= $[-10, -100]$

$$|SI-A+Bk|=0$$

$$s^2+(0.5+100k1)s+(38.89k1+0.16666+11.11k2)=0 \dots(b)$$

comparing (b) with $s^2+110s+1000=0$

$$k1= 1.095$$

$$k2=86.15$$

$k1 \ k2$ can also be calculated in MATLAB using acker formula which is mentioned in below code.

Step 6:

a. Simulink model:




Figure 10: Observer based Simulink model.

Subsystem (system block)




Figure 11:Subsystem(system)

Subsystem (Observer)




Figure 12: Subsystem (Observer)

b. Matlab Code:

```
clc
clear all
close all
tsim=2
qeq=0
h1eq=0
h2eq=0
A=[-1/9 1/9;1/9 -0.3889]
B=[100;0]
C=[0 1]
A11=A(1,1)
A12=A(1,2)
A21=A(2,1)
A22=A(2,2)
B1=B(1)
h1_init=0
h2_init=1
Ac=[A zeros(2,1);-C 0]
Bc=[B;0]
poles=[-10,-100]
k=acker(A,B,poles)
%case:1
k1=1.095
k2=86.15
Ke1=43.22
Ke2=1.5
sim("observerbaseddesign");
t=ans.tout
x1=ans.system.data(:,1)
x2=ans.system.data(:,2)
z1=ans.observer.data(:,1)
z2=ans.observer.data(:,2)
subplot(211)
plot(t,x1,"linewidth",2);
hold on;
plot(t,z1,"linewidth",1.5);
legend("actual","estimated")
xlabel("time")
ylabel("x1")
title("Height of tank1(h1)")
hold on;
subplot(212)
plot(t,x2,"linewidth",2);
hold on;
plot(t,z2,"linewidth",1.5);
title("Height of tank1(h2)")
legend("actual","estimated")
xlabel("time")
```

```
ylabel("x2")
hold off;
```

c. Simulation Results(graph):




Figure 13: Response curve of actual output and estimated output of system with full order observer with initial condition [0 1].

Case 2:

Given:

Desired closed loop pole location of $J = [-1+2j, -1-2j]$;

Observer pole location, $L = [-10, -100]$;

Step 1: Desired state feedback matrix $K_e = [K_{e1} \ K_{e2}]^T$

$$|sI - A - K_e C| = 0$$

$$s^2 + (0.5 + K_{e2})s + (0.0308 + 0.11(K_{e1} + K_{e2})) = 0 \dots (a)$$

Step 2: Comparing above equation with desired characteristic equation with poles

$$L = [-10, -100]$$

$$(s+10)(s+100) = 0$$

$$s^2 + 110s + 1000 = 0$$

$$K_{e1} = 8981.12$$

$$K_{e2} = 109.51$$

Step3: For calculating $k = [k_1 \ k_2]$ for given closed loop poles $J = [-1+2j, -1-2j]$

$$|sI - A + Bk| = 0$$

$$s^2 + (0.5 + 100k_1)s + (38.89k_1 + 0.1666 + 11.11k_2) = 0 \dots\dots(b)$$

Comparing equation (b) with $s^2 + 2s + 5 = 0$

$$k_1 = 0.0151$$

$$k_2 = 0.3997$$

Step 4:

a. Matlab code:

```
clc;
close all;
clear all;
a_11=-.11;
a_12=.11;
a_21=.11;
a_22=-.38;
b_11= 100;
b_21= 0;
A=[a_11 a_12; a_21 a_22];
B=[b_11; b_21];
C=[0 1];
P= ctrb(A,B);
M= obsv(A,C);
%case_2
poles=[-1+2j, -1-2j];
k= acker(A,B,poles);
k_1= k(1,1);
k_2= k(1,2);
k_e_1=8981.12;
k_e_2=109.51;
sim('linearmpcontrollerobserver.slx');
t=simout.time;
m = simout.data;
x__1=m(:,1);
x__2=m(:,2);
x__1hat=m(:,3);
x__2hat=m(:,4);
subplot(2,1,1)
plot(t,x__1,'linewidth',1.5);
hold on;grid on;
plot(t,x__1hat);
hold on;grid on;
xlabel('time');
ylabel('x_1');
title('height of tank 1');
subplot(2,1,2)
```

```

plot(t,x__2,'linewidth',1.5);
hold on; grid on;
plot(t,x__2hat);
hold on; grid on;
xlabel('time');
ylabel('x_2');
title('height of tank 2');

```

b. Simulation Results:





Figure 14: Response curve of actual output and estimated output of system with full order observer with initial condition $[0 \ 1]$ for case 2

Performance comparison:






Figure 15 : Response curve of actual output and estimated output of system with full order observer with initial condition $[1 \ 1]$ and system with initial condition $[0 \ 1]$.

LQR based controller

Step 1:

Controllability Matrix = $M_c = [B \ AB] = (2700 \ -0) = 2700 \neq 0$

Hence M_c is a full rank matrix with rank = 2. So, the given system is controllable.

Check the observability condition of the system. The observability matrix is

$$O = [C^T \ A^T C^T] \\ = \begin{bmatrix} 0 & 0.1111 \\ 1 & -0.3889 \end{bmatrix} \Rightarrow -0.1111 \neq 0$$

We find that $O \neq 0$, rank of observability matrix $O=2$. Hence the system is completely state observable.

System is both controllable and observable

Step 2:

Here in this case, number of uncontrollable states is 0 indicating that all the states are controllable. Therefore, the design of LQR controller is possible. The performance of LQR control is measured by performance index,

$$J = \int_0^{\infty} (x^T Q x + u^T R u) dt$$

Q and R are chosen according to the requirement from the reference

$$Q = C^T C = \begin{bmatrix} 0 & 0 \\ 0 & 1 \end{bmatrix};$$

$$R = 1;$$

Step 3:

The law of LQR controller is “ $u = -kx$ ” that reduce the state fluctuation. This gain is called LQ-optimal gain. Control action is based on the state of process. The optimal state feedback gain is obtained by solving ARE (Algebraic Riccati Equation).

Algebraic Riccati Equation is

$$A^T P + P A + Q - P B R^{-1} B^T P = 0$$

Solution P is needed to compute the optimal feedback gain K

$$P = \begin{bmatrix} 0.0004 & 0.0085 \\ 0.0085 & 0.3613 \end{bmatrix}$$

$$K_{opt} = R^{-1} B^T P$$

$$K_{opt} = [0.0423, 0.8490]$$

Step 4:

$$J = (x_0)^T P (x_0) \quad (x_0 = [0 \ 1]^T)$$

$$= 0.3613.$$

Step 5:

a. MATLAB code:

```
clc
clear all
close all
qeq=0
h1eq=0
h2eq=0
A=[-1/9 1/9;1/9 -0.3889]
B=[100;0]
C=[0 1]
Q=C'*C
P=ctrb(A,B);
M=obsv(A,C);
R=1
[k,p,e]=lqr(A,B,Q,R,0)
k1=k(1)
k2=k(2)
A11=A(1,1)
A12=A(1,2)
```

```

A21=A(2,1)
A22=A(2,2)
B1=B(1)
sim("statefeedback",5);
t=ans.tout
x1=ans.simout.data(:,1)
x2=ans.simout.data(:,2)
subplot(211)
plot(t,x1);
xlabel("time")
ylabel("x1")
title("Height of tank1(h1)")
hold on;
subplot(212)
plot(t,x2);
title("Height of tank2(h2)")
xlabel("time")
ylabel("x2")
hold on;

```

Simulation Result:




Figure 16: Response curve of system with lqr based controller with $Q = \begin{bmatrix} 0 & 0 \\ 0 & 1 \end{bmatrix}$, $R=1$.

Comparison graphs for different values of Q and R:




Figure 17: Response curves of system with lqr based controller with different values of Q and $R=1$.




Figure 18: Response curves of system with lqr based controller with different values of Q and $R=0.25$.




Figure 19: Response curves of system with lqr based controller with different values of R and $Q = \begin{bmatrix} 0 & 0 \\ 0 & 1 \end{bmatrix}$.




Figure 20: Comparison of response curves of controller with optimized k values (lqr based controller) with state feedback controller.

SUMMARY AND CONCLUSIONS:

Both linear and non linear are tracking the desired set point but the linear one has less undershoot compared to nonlinear. With respect to linear system, Nonlinear has 7.46% more undershoot.

In observer-based model the actual output and the estimated output coincides for same initial conditions. Both observer and the system start with different initial values for the states but finally observer tracks the actual states.

If R is decreased, then the states converge faster and more input effort is required.

If R is increased, then the states converge slower and less input effort is required.

LQR based design gives 83.58% less undershoot than state feedback design.

REFERENCES:

- [1] K. Anbumani, R. Rani Hemamalini, "linear Quadratic Regulator for three Interacting Cylindrical Tank Control", International Journal of Recent Technology and Engineering (IJRTE) ISSN: 2277-3878, Volume-8, Issue-1S4, June 2019.
- [2] K. Ogata, Modern Control Engineering, 3rd edition, Prentice Hall, New Jersey, 1997.
- [3] Roman A. Michurin¹, Anatolii Schagin², "Increase the Accuracy of the DC Motor Control System with a Linear-Quadratic Regulator", 978-1-5386-4340-2/18, 2018 IEEE.
- [4] Amitava Biswas, Gargee Chakraborty, "Full Order Observer Controller Design for Two Interacting Tank System Based on State Space Approach" Department of Applied Physics, Calcutta University, 92, A. P.C Road, Kolkata-700009, INDIA, July 2017.