

TSTRANSCO Transmission Losses for the month of June-2023					
EBC Data					
		INPUT	OUTPUT		
		NET ENERGY in MU	DISCOM	MU	
TSGENCO	TOTAL	2345.22			
	TSGENCO-THERMAL	2291.24	TSSPDCL	4294.68	
	TSGENCO-HYDEL	53.98	TSNPDCL	1419.86	
C.T.U			Total Discom	5714.55	
	CGS(Injection at TS-Periphery)	2624.69			
CPPs	TOTAL	47.57			
	132kv Laxmi Tulasi	0.01			
	132 kV Orient Cement	0.34			
	220KV Navabharat Energy India Ltd (NBEIL)-I	11.85			
	220KV Navabharat Energy India Ltd (NBEIL)-II	11.91			
	132KV Penna Power-I	0.00			
	132KV Penna Power-II	0.00			
	132KV Deccan Cements	0.01			
	132 kV Madhucon	0.00			
	132kv SCCL 30MW Solar Plant (Manuguru)	3.59			
	220 kV Heavy Water Plant#1	0.00			
	220 kV Heavy Water Plant#2	2.11			
	132kV PSR Green Power Proj. pvt. Ltd.	0.00			
	220KV RFCL	0.04			
	132 kV Kesoram	0.00			
	132 kV Sitapuram Power Limited	0.00			
	132 kV Anjaini Port Land Cement	0.00			
	132kv SCCL 37 MW Solar Plant (Sitharampatnam)	5.41			
	132 kV Sitaramapatnam - NBVL (NBFA)#1	0.01			
	132 kV Sitaramapatnam - NBVL (NBFA)#2	3.49			
	132 kV Sitaramapatnam - BPBL	0.01			
	132KV Shalivahana(MSW) Green Energy Ltd.,	0.00			
	132kV Krishnaveni Sugars Ltd	0.00			
	132 kV My Home Industries Limited	1.96			
	132 kV ICL (Rassi Cements)	0.00			
	132 kV Bharat Electronics Ltd. (solar)	1.52			
	132kv SCCL Solar Power Plant (Yellandu)	5.33			
Non-Conventional (132 & 220 kV PDs)	Total	445.22			
	ACME Medak Solar energy Pvt. Ltd.	7.94			
	ACME Nizamabad Solar Energy Pvt. Ltd	8.22			
	ACME PV Powertech Pvt. Ltd. (Sadasivpet)	8.79			
	ACME Rangareddy Solar Power	4.91			
	ACME Solar Power Tech. Pvt. Ltd. (Bhongir)	8.52			
	Azure Power India Pvt. Ltd. (solar)	16.65			
	Clean Hero Wind Power	9.17			
	Clean Solar Power (Chittradurga) Pvt. Ltd	6.02			
	Clean solar	4.50			
	Dayakara Solar (P) Ltd.	5.08			
	Dinakar Solar	4.33			
	Divine Solren Pvt. Itd.	7.85			
	Energon Soleq Solar (Sadasivapet)	8.46			
	Enrich (Solar)	7.73			
	G.S.R.Sugars Pvt Ltd	-0.06			
	Ganapathi Sugars Ltd.	-0.05			
	Grahati Solar	8.68			
	Hyderabad MSW Energy Solutions PVT LTD	9.22			
	Jilesh Power Pvt. Ltd (Solar)	8.23			
	Kakatiya Cement & Sugar Industries Ltd.	-0.12			
	Karvy Solar Pvt. Ltd. (Sadasivapet)	3.21			
	Karvy solar (Mandamarry)	7.05			
	My Home Power Ltd. (NGPL)	0.00			
	Mytrah Aakash Power Pvt.,Ltd.	8.26			
	Mytrah Agriya Power Pvt. Ltd. (Solar)	8.58			
	Mytrah Agriya Power Pvt. Ltd. (solar) (Kamareddy)	8.84			
	Mytrah Vayu (Godavari) Pvt. Ltd. (Wind)	31.43			
	NEO Solren Pvt. Ltd. (solar)	6.32			
	NTPC Solar power plant (10MW)	0.88			
	Nizam Deccan Sugars Ltd	0.00			
	Param Pujya Solar Farms Ltd. Plant-I	9.35			
	Param Pujya Solar Farms Ltd. Plant-II	10.59			
	Polepally Solar Park	3.85			
	Prathamesh solar farms Ltd.	9.03			
	RDF Power Projects Pvt. Ltd.	0.00			
	Renew Mega Solar Pvt.Ltd	8.30			
	Renew Saurshakthi Pvt. Ltd.	5.39			
	Renew Solar Energy Pvt. Ltd. 220kV	27.10			
	Renew Solar Plant (Mdk. Dist.)	3.69			
	Renew Solar Pvt Ltd. (Minpur)	12.05			
	Renew Wind TN2 Solar	18.16			
	Renue Akshay Solar Plant	15.80			
	SLS Power Corp. Ltd. (Minihydel) 132KV	0.21			
	SUZLON Energy Ltd.	19.46			
	Shravana Power Projects Pvt. Ltd.	-0.02			
	Sky Power Southeast Asia III Ltd (Previously Sunshakthi solar pvt. Ltd.)	9.26			
	Sunborne Energy Tech. (P) Ltd. (Solar)	6.30			
	Sunworld Solar Power Pvt. Ltd.	4.83			
	Suprasanna Solar	3.07			
	Suraj Kiran Solar Technologies (Mdk)	9.17			
	Suraj Kiran solar (Nlg)	8.70			
	Suryoday Energy Pvt. Ltd. (Shapoorji Pallonji)(Solar)	5.64			
	Transform Sun Energy 220kV	15.31			
	Ujvalatejas Solaire Urja Pvt. Ltd. (Solar)	3.08			
	Vena Energy Solar Pvt Ltd (Previously Energon Soleq Pvt Ltd)	7.97			
	Winsol solar (Polepally)	2.57			
	Winsol solar (Tandur)	8.48			
	Zuka Solar	9.24			
IPPs	SINAGARENI	378.15		MU	in %
	TOTAL INPUT	5840.84	Total Losses	126.30	2.16
* Transmission Losses are applicable to OA Users for the period from 00:00 Hrs.of 26th July- 2023 to 24:00 Hrs of 25th Aug - 2023					
* The Transmission Losses are worked out by using MRI data.					
* MRI Data considered is from 00.00 Hr of 1st June -2023 to 24.00 Hr of 30 th June-2023 at 00.15 Hr interval.					
* The SR Losses (External Losses to TSTRANSCO) for the month of June- 2023 is 3.29%					
* Cummilative losses at TS-Periphery FY 2023-24 is 2.24%					