Schedule II

## Forms of Inspection Report [See regulation (32) and (45)] FORM I

## (Installations of voltage up to and including 250V)

Re	port									
Da	te	of	inspection	by	Electrical	Inspector	or	self-certification	by	supplier/owner/consumer
Da	te o	f last in	spection or	self-ce	rtification _					
1.	Co	onsume	r No							
2.	Voltage and system of supply:									
	(i)	Volts	·	(i	ii) No. of Pl	nases		_(iii) AC/DC		
3.	Ту	pe of w	/iring*							
			of wiring v and any othe			ping, lead cov	ered o	f teak wood batten,	conceal	led conduit, Tough Rubber
4.	Na	ame of t	the consume	er or ov	vner					
5.	Address of the consumer or owner									
6.	Location of the premises									
7.	Pa	Particulars of the installations:								
	Number				ıber	C	onnected Load in kV	W		
	(a)	(i)	Light P	oints						
		(ii)	Fan Poi	nts			_			
		(iii)	Plug Po	ints			_			
	(b) Other equipment (complete details to be furnished):									
		(i)								
		(ii)								
		Total	connected	load in	kW					
	Maximum current demand in Amps									
	(on the basis of total connected load)									
	(c) Generators: (complete detail to be enclosed)									
		Mal			No.	kVA rating		Voltage rating	Тур	e
		(i)								<u> </u>
		(ii)								<u></u>

## 8. General conditions of the installation:

Sl. No.	Regulation No.	Requirements	Report
1.	Regulation 14	(i) Is/Are there any visible sign(s) of overloading in respect of any apparatus wiring?	Yes/No
		(ii) Condition of flexible cords, sockets, switches, plug-	Satisfactory/
		pins, cut-outs and lamp holders and such other fittings.	Not Satisfactory
		(iii) General condition of wiring.	Satisfactory/
			Not Satisfactory
		(iv) Whether any unauthorized temporary installation exist?	Yes/No

2			THE GAZETTE OF INDIA: EXTRAORDINARY	[PART III—SEC.4]
			(v) State if sockets are controlled by individual switches.	Yes/No
			(vi) Any other defect or condition which may be a source of danger. If yes, give details.	Yes/No
2.		Regulation 15	Give report on condition of service lines, cables, wires, apparatus and such other fittings placed by the supplier or owner of the premises. If not satisfactory, give details.	Satisfactory/ Not Satisfactory
3.	1	Regulation 16	Whether suitable cut-outs provided by the supplier at the consumer's premises are within enclosed fire proof receptacle?	Yes/No
4.	1	Regulation 17	(i) State if switches are provided on live conductors.	Yes/No
			(ii) State if indication of a permanent nature is provided as per regulation so as to distinguish earthed or earthed neutral conductor from the live conductor.	Yes/No
			(iii) Whether a direct line is provided on the neutral in the case of single-phase double pole iron clad switches instead of fuse?	Yes/No
5.		Regulation 18	(i) State if earthed terminal is provided by the supplier.	Yes/No
			(ii) Have three pin plugs been provided for plug points?	Yes/No
			(iii) General visible condition of the earthing arrangement.	Satisfactory/ Not Satisfactory
5.		Regulation 19	Are the live parts in building inaccessible?	Yes/No
7.		Regulation 36	State insulation resistance between conductors and earth in Mega Ohms.	Mega Ohms
8.		Regulation 37	(i) State if linked switches of requisite capacity are provided near the point of commencement of supply.	Yes/No
			(ii) State if the wiring is divided in suitable number of circuits and each such circuit is protected by suitable cut-out.	Yes/No
			(iii) State if supply to each motor or apparatus is controlled by suitable linked switch.	Yes/No
9.		Regulation 43	(i) Have the frames of every generator, stationary motor and so far as practicable portable motor and the metallic parts (not intended as conductors) of all other apparatus used for regulating* or controlling electricity been earthed by two separate and distinct connections with earth?	Yes/No
			(ii) Is the earth wire free from mechanical damage?	Yes/No
			(iii) In the case of conduit, or lead covered wiring, has the conduit or lead-cover been efficiently earthed?	Yes/No
			(iv) If the consumer has his own earth-electrode, state if it is properly executed and has been tested. If yes, give value of earth resistance	Ohms
10.		Regulation 44	Whether residual current device of appropriate capacity as defined in Regulation have been provided?	Yes/No
11.		Overhead Lines	(i) State if the consumer has any overhead lines.	Yes/No
			(ii) Does the overhead line near the premises of consumer meets the requirement of regulation 60, 61 and 62? If not, give details.	Yes/No
			(iii) Is guarding provided for overhead lines as per Regulation 76?	Yes/No
			(iv) Any other remarks.	

Date:	
	Signature of the supplier/ Owner / Consumer
	Name
	Designation
	File No

To: Office of Electrical Inspector for .....

\* Not applicable to isolated wall tubes or to brackets, electroliers, switches, ceiling fans and such other fittings (other than portable hand lamps and transportable apparatus) unless provided with earth terminal.