



Office of the
Chief Electrical Inspector to Govt., Haryana
SCO 117-118, Sector-17-B, Chandigarh (e-mail: cel_goh@yahoo.com)
Telephone No. 0172-2704090, Fax No. 0172-2710171
www.celharyana.in

To

M/s. WARYAM SINGH BATRA,
PLOT NO. 1, NEAR CIVIL HOSPITAL,
RAILWAY ROAD,
YAMUNA NAGAR.

Memo No.: -3896

Dated: - 20-03-2024

Sub: -

Inspection of HT installations comprising of 1x250 KVA Transformer under Central Electricity Authority (Measures Relating to Safety & Electric Supply) Regulations, 2023.

<<<<>>>>


Reference your application No. 20240220-3872-4743.

The subject cited installation was inspected by this department and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2023 and amendments thereon. However, it is advised that: -

- Danger notice in Hindi or English and the local language of the district with a sign of skull and bones be provided on electrical installations.
- Safety equipments, earthing arrangements should be maintained in proper working conditions. Insulating floors or mats conforming to IS 15652: 2006 should be provided and maintained in proper working conditions.
- Proper earthed fencing, if metallic, of at least 1.8-meter height be provided in front of the Transformer room with gate opening outwards. Earth mats be provided in front of all electrical panels.

Approval for energization of the subject cited installation is hereby accorded subject to consistent compliance of the relevant provisions of CEA (Measures Relating to Safety & Electric Supply) Regulations, 2023 may be ensured in these installations at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

Your next inspection shall fall due in the month of March every year. You are therefore requested to deposit inspection fees as per schedule under the Head of A/c "0043—Taxes and Duties on Electricity Fees payable and apply online to this office one month before the due date.


Assistant Engineer
to Chief Electrical Inspector,
to Govt., Haryana, Chandigarh.