



Office of the
Chief Electrical Inspector to Govt., Haryana
SCO 117-118, Sector-17-B, Chandigarh (E-mail: cei_goh@yahoo.com)
Telephone No. 0172-2704090, Fax No. 0172-2710171
Website: www.ceiharyana.in

To

tarunpreet
pinjor
Dist - Panchkula, Haryana

Memo No. Panchkula/000015/2024

Dated: 21-05-2024

Sub:- **Inspection of 600 KVA Generating Set under Central Electricity Authority
(Measures Relating to safety & Electric Supply) Regulations, 2023.)**

Reference your application No. 1000081

The subject cited installation was inspected by this department on 20-05-2024 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2023 and amendments thereon. However, it is advised that: -

1. Danger Plate And Barbed wire to be provided on each pole of 11KV line.
2. Proper Earthing fencing ,if metallic,of at least 1.8-meter height be provided in front of the transformer room with gate opening outwards.
3. Danger notice in hindi or english & the local language of the district with a sign of skull & bones be provided on electrical installations.
4. Earth mats be provided in front of all electrical panels.
5. Insulating floors or mats confirming to IS 15652:2006 should be provided & maintained in proper working conditions.

Approval for energization of the subject cited installation is hereby accorded subject to consistent compliance of the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2023 may be ensured in these installations at your end. Please note that it shall be the responsibility of the owner of the electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the bureau of Indian Standards. Your next inspection shall fall due in the month of May every year. you are therefore requested to deposit inspection fees as per schedule under the Head of A/c "0043--Taxes and Duties on Electricity Fees payable and apply online to this office one month before the due date."

Assistant Engineer
to Chief Electrical Inspector
to Govt., Haryana, Chandigarh