



Office of the
Chief Electrical Inspector to Govt., Haryana
SCO 117-118, Sector-17-B, Chandigarh (e-mail: cei_goh@yahoo.com)
Telephone No. 0172-2704090, Fax No. 0172-2710171
www.ceiharyana.in

To

**M/s. DECENT INFRAHEIGHTS PVT. LTD.,
C/O THE FLOWER CITY, SECTOR 32,
KURUKSHETRA.**

Memo No.: - 3897

Dated: - 20-03-2024

Sub: -

**Inspection of New 11KV XLPE line Under Central Electricity Authority
(Measures Relating to Safety & Electric Supply) Regulations, 2023**


<<<◇>>>

Reference your application No. 20240226-5130-4582.

The subject cited installation was inspected by this department and the same is found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2023 and amendments thereon. However, it is advised that: -

- Danger plates and Barbed wire to be provided on each pole of 11 KV line.

Consistent compliance of the relevant provisions of CEA (Measures Relating to Safety & Electric Supply) Regulations, 2023 may be ensured in these installations at your end. Please note that it shall be the responsibility of the owner of electrical installations to maintain and operate the installations in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.


Assistant Engineer
to Chief Electrical Inspector,
to Govt., Haryana, Chandigarh