



PT. MUDALAYA ENERGY INDONESIA

OIL GAS STEEL FABRICATION, ELECTRICAL & ENGINEERING



PURCHASE ORDER

NO PO : PO-08/SCM-MEI/100/04/25
Date : 07 April 2025

NO FPBI : -
Project : INTERNAL (ASET)
REV : 00

To : PT. REFTECH JAYA OPTIMA
Attn : Mrs. Yolan

Hereby we are very pleased to Purchase Order for item under the following

NO	DESCRIPTION / SCOPE OF WORK	QTY	UNIT	PRICE	TOTAL PRICE
1	AIR COMPRESSOR 900850.1 Oil Separator Cartridge	1	Pcs	Rp 3,800,000	Rp 3,800,000
2	Service	1	Pcs	Rp 1,500,000	Rp 1,500,000
Sub Total					Rp 5,300,000
PPN 11%					Rp 583,000
SUB TOTAL					Rp 5,883,000

Term & Condition :

1. Validity of Quotation : 1(one) Month
2. Price : Franco FACTORY
3. Delivery Process : Sudah dikerjakan pada tanggal 25-03-2025
4. Payment : 14 days after invoice received

Contact - Ibu. Manzilah Mukarimah (0812-8542-1560)

Best Regard's


Dr. Sukma Nugraha, M.M.
President Director

: Please to discuss to solve the problem.

WORKSHOP & HEAD OFFICE
Jalan Raya Pemda Kab. Bogor
RT 03 RW 10 Pasir Jambu, Sukaraja, Bogor
Telp. +62 251 750 356 5

MACHINING WORKSHOP
Jl. Kampung Bulu Mekarsari, Tambun Selatan
Bekas, Jawa Bart 17510
Telp : + 62 21 882 498 8

www.mudalayaenergy.com

PT Reftech Jaya Optima

Taman Kopo Indah V, Ruko Sommerville No. 31

Bandung – Jawa Barat 40218

☎ 022 54417653 ✉ info@reftech.id

QUOTATION

#146-P/BDG/RJO-CRM/III/2025

25-03-2025

Quote To:

Company : PT. MUDALAYA ENERGY INDONESIA

Name PIC : Bu Rima

Phone : 081285421560

Sales :

PT Reftech Jaya Optima

No PR :

-

Email :

-

NO.	ITEM	PRICE	QTY	DISC	AMOUNT
1	AIRN COMPRESSOR 900850.1 Oil Separator Cartridge	RP 3.800.000	1 Pcs	0%	RP 3.800.000
2	SERVICE COST Jasa Pemasangan	RP 1.500.000	1 Lot	0%	RP 1.500.000

Note : -

Subtotal: Rp 5.300.000

DPP On VAT: RP 4.858.333

Tax (12%): RP 583.000

Total: Rp 5.883.000

Term & Condition

Validity Of Quotation : 1(one) Month After this Quotation Created

Price : Franco FACTORY

Delivery Process : Sudah dikerjakan pada tgl 25-03-2025

Payment : 14 days after invoice received

if you have any questions about this quotation, please contact :
Yolan Yolanda +6281210007431



PT Reftech Jaya Optima

Taman Kopo Indah V, Pulo Sommerville No. 31
Bandung - Jawa Barat 40216
☎ 022 54417653 | ✉ admin@reftech.id

SERVICE REPORT

#095-S/RJO-TSU/III/2025

2025-03-24

Customers	: PT. MUDALAYA ENERGY INDONESIA	Unit Type	: AIRN D 37-8
Address	: -	Serial Number	: D0110223-3703 - -
PIC	: Bpk. Akhbar	Running & Load	: 1986 543

Job Description : Pergantian oli sparator

Description

Sudah dilakukan pergantian oli sparator
-cek level/cukup
-cek kebocoran unit/tidak ada
-cek temprature-85c
-cek ampere-67,4/70,9/77,3A
-cek vibrasi screw depan-05,5mm/s
-cek vibrasi belakang-06,3mm/s

Recomendation

Kompresor running normal

Picture



Vibrasi depan



Vibrasi belakang




Pemasangan os



Cek return



OS baru



Running hour

LAPORAN PREVENTIVE ACTION

Nama Mesin : Compressor AIRN

No. Mesin :

Tgl : 24 Maret 2025

PERMASALAHAN :

1. Preventive Maintenance Compressor

2. Oli terbawa ke tangki angin mesin

PENYEBAB:

1. Pemeriksaan Berkala mesin (Reftech)

2. Oil Separator Rusak

TINDAKAN PREVENTIVE ACTION:

1. Penambahan Oli pada tabung separator yang terbawa ke tanki

2. Pengantian oli separator, pengecekan arus, clear hours untuk oil separator dan pengecekan vibrasi screw

FOTO PREVENTIVE ACTION :



Pembongkaran baut tabung separator



Penggantian oil separator




Penambahan dan pengisian oli di screw gearbox dan tabung oli



Pengecekan vibrasi pada screw gearbox dengan hasil vibrasi depan (05,5 mm/s)



Pengecekan vibrasi pada screw gearbox dengan hasil vibrasi depan (05,5 mm/s)



Pengecekan arus listrik motor dan fan ex blower

Dibuat Oleh

Diketahui Oleh

Maintenance

Manager

FRM-MTC-04.00