

Zone Sizing Summary for #01-9FCorridor1(LIFT)

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name #01-9FCorridor1(LIFT)
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 178.2 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	9.2	8.6	23.5 / 16.7	13.2 / 12.5	0.24	Jul 1600	3.87

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	689	0.087	0.069	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	8.7	Jul 1500	0.2	178.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#01-9FCorridor1(LIFT)	1	8.7	Jul 1500	689	0.2	178.2	3.87

Zone Sizing Summary for #01A-1F-8FCorridor1(LIFT)

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name ... **#01A-1F-8FCorridor1(LIFT)**
Equipment Class ... **TERM**
Air System Type ... **2P-FC**

Number of zones **1**
Floor Area **178.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	9.1	8.5	23.5 / 16.7	13.1 / 12.5	0.24	Aug 1600	3.79

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	676	0.085	0.068	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	8.6	Jul 1500	0.1	178.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#01A-1F-8FCor1(LIFT)	1	8.6	Jul 1500	676	0.1	178.2	3.79

Zone Sizing Summary for #02-6FCorridor2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#02-6FCorridor2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **96.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.0	3.7	23.6 / 16.9	13.2 / 12.6	0.11	Jul 1500	3.04

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	294	0.037	0.029	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.7	Jul 1500	0.1	96.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#02-6FCorridor2	1	3.7	Jul 1500	294	0.1	96.6	3.04

Zone Sizing Summary for #02A-1F-5FCorridor2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#02A-1F-5FCorridor2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **96.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.0	3.6	23.5 / 16.8	13.1 / 12.4	0.11	Aug 1400	2.97

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	287	0.036	0.029	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.6	Jul 1500	0.1	96.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#02A-1F-5FCorr2	1	3.6	Jul 1500	287	0.1	96.6	2.97

Zone Sizing Summary for #03-1F-8FIDF Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#03-1F-8FIDF Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **4.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.4	3.4	23.8 / 16.7	13.4 / 12.7	0.09	Jul 1500	57.69

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	265	0.033	0.027	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.4	Jul 1500	0.0	4.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#03-1F-8FIDF Room	1	3.4	Jul 1500	265	0.0	4.6	57.69

Zone Sizing Summary for #03-9FIDF Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#03-9FIDF Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **4.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.5	3.4	23.8 / 16.7	13.4 / 12.7	0.09	Jul 1600	58.44

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	269	0.034	0.027	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.4	Jul 1600	0.0	4.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#03-9FIDF Room	1	3.4	Jul 1600	269	0.0	4.6	58.44

Zone Sizing Summary for #04-1F-8FElec. Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#04-1F-8FElec. Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **6.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.4	1.4	23.5 / 16.4	13.1 / 12.4	0.04	Jul 1500	18.08

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	110	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.4	Jul 1500	0.0	6.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
#04-1F-8FElec. Room	1	1.4	Jul 1500	110	0.0	6.1	18.08

Zone Sizing Summary for #04-9FElec. Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#04-9FElec. Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **6.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.5	1.5	23.4 / 16.3	12.8 / 12.1	0.04	Aug 1600	18.82

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	115	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.5	Jul 1600	0.0	6.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#04-9FElec. Room	1	1.5	Jul 1600	115	0.0	6.1	18.82

Zone Sizing Summary for #05-1F-8FService Corrido

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#05-1F-8FService Corrido**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **11.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	0.6	0.5	23.6 / 17.3	13.3 / 12.7	0.02	Jul 1400	3.25

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	38	0.005	0.004	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	0.5	Jul 1500	0.0	11.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#05-1F-8FService Corrido	1	0.5	Jul 1500	38	0.0	11.8	3.25

Zone Sizing Summary for #05-9FService Corrido

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#05-9FService Corrido**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **11.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	0.7	0.6	23.6 / 17.1	13.2 / 12.6	0.02	Jul 1700	4.03

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	48	0.006	0.005	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	0.6	Jul 1700	0.0	11.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#05-9FService Corr	1	0.6	Jul 1700	48	0.0	11.8	4.03

Zone Sizing Summary for #06-B-CHW Pump Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#06-B-CHW Pump Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **54.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.0	4.9	23.5 / 16.6	13.2 / 12.6	0.13	Sep 1500	7.17

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	393	0.050	0.039	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.0	Jul 1500	0.3	54.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#06-B-CHW Pump Room	1	5.0	Jul 1500	393	0.3	54.8	7.17

Zone Sizing Summary for #07-B-ETS Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#07-B-ETS Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **88.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	8.8	8.2	23.5 / 16.6	13.0 / 12.3	0.23	Jul 1500	7.34

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	650	0.082	0.065	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	8.2	Jul 1500	0.6	88.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#07-B-ETS Room	1	8.2	Jul 1500	650	0.6	88.5	7.34

Zone Sizing Summary for #08-B-PLC Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#08-B-PLC Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **11.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.0	2.9	23.5 / 16.5	13.0 / 12.3	0.08	Jul 1700	20.65

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	231	0.029	0.023	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.9	Jul 1500	0.2	11.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#08-B-PLC Room	1	2.9	Jul 1500	231	0.2	11.2	20.65

Zone Sizing Summary for #09-B-MCC

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#09-B-MCC**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **11.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.5	3.4	23.5 / 16.4	12.9 / 12.3	0.09	Jul 1700	23.03

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	269	0.034	0.027	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.4	Jul 1500	0.3	11.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#09-B-MCC	1	3.4	Jul 1500	269	0.3	11.7	23.03

Zone Sizing Summary for #10-B-EMCC (GSM)

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#10-B-EMCC (GSM)**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **5.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.1	3.0	23.7 / 16.7	13.4 / 12.7	0.08	Jul 1500	43.92

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	242	0.030	0.024	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.1	Jul 1500	0.0	5.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#10-B-EMCC (GSM)	1	3.1	Jul 1500	242	0.0	5.5	43.92

Zone Sizing Summary for #11-B-Pool & Water Featu

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#11-B-Pool & Water Featu**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **57.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	8.4	7.9	23.5 / 16.7	13.2 / 12.5	0.22	Jul 1500	10.90

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	630	0.079	0.063	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	8.0	Jul 1500	0.0	57.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#11-B-Pool & Water Featu	1	8.0	Jul 1500	630	0.0	57.8	10.90

Zone Sizing Summary for #12-B-LandScape Storage

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#12-B-LandScape Storage**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.2	2.8	23.7 / 17.3	13.7 / 13.1	0.08	Jul 1500	7.69

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	230	0.029	0.023	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.9	Jul 1500	0.2	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#12-B-LandScape Storage	1	2.9	Jul 1500	230	0.2	29.9	7.69

Zone Sizing Summary for #13-B-EMCC (FAN RM & Ch

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#13-B-EMCC (FAN RM & Ch**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **10.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.9	3.8	23.7 / 16.7	13.4 / 12.7	0.10	Jul 1600	30.37

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	304	0.038	0.030	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.8	Jul 1500	0.0	10.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#13-B-EMCC (FAN RM & Ch	1	3.8	Jul 1500	304	0.0	10.0	30.37

Zone Sizing Summary for #14-B-GSM Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#14-B-GSM Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **14.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	19.9	19.8	23.4 / 16.2	12.8 / 12.2	0.53	Jun 1400	104.20

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	1553	0.196	0.155	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	19.7	Jul 1500	0.0	14.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#14-B-GSM Room	1	19.7	Jul 1500	1553	0.0	14.9	104.20

Zone Sizing Summary for #15-B-MTR

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#15-B-MTR**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	11.9	11.7	23.5 / 16.3	12.9 / 12.2	0.32	Jul 1500	37.36

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	915	0.115	0.092	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	11.6	Jul 1500	0.0	24.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#15-B-MTR	1	11.6	Jul 1500	915	0.0	24.5	37.36

Zone Sizing Summary for #16-B-MDF Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#16-B-MDF Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **12.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	10.4	10.3	24.0 / 16.8	13.6 / 12.9	0.28	Jul 1500	64.57

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	814	0.103	0.081	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	10.3	Jul 1500	0.0	12.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#16-B-MDF Room	1	10.3	Jul 1500	814	0.0	12.6	64.57

Zone Sizing Summary for #17-B-Engineering Store

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#17-B-Engineering Store**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **10.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.2	0.9	23.7 / 18.2	13.7 / 13.2	0.03	Jun 1500	7.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	73	0.009	0.007	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	0.9	Jul 1500	0.0	10.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#17-B-Engineering Store	1	0.9	Jul 1500	73	0.0	10.0	7.30

Zone Sizing Summary for #18,19,21-IDF,ELE,COR-

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#18,19,21-IDF,ELE,COR-**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	8.5	8.3	23.6 / 16.5	13.0 / 12.4	0.23	Jul 1600	26.89

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	653	0.082	0.065	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	8.3	Jul 1500	0.0	24.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#18-B-IDF (Core)	1	6.1	Jul 1500	482	0.0	4.7	102.48
#19-B-ELEC. RM	1	1.7	Jul 1500	132	0.0	7.9	16.66
#21-B-Corridor (IDF & EL	1	0.5	Jul 1500	40	0.0	11.7	3.42

Zone Sizing Summary for #20-B-Chemical Storage

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#20-B-Chemical Storage**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **6.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.5	1.2	23.5 / 17.4	13.1 / 12.6	0.04	Jul 1500	14.39

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	95	0.012	0.010	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.2	Jul 1500	0.0	6.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#20-B-Chemical Storage	1	1.2	Jul 1500	95	0.0	6.6	14.39

Zone Sizing Summary for #22-B-Lift Lobby

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#22-B-Lift Lobby**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **21.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.5	2.2	23.5 / 16.9	13.2 / 12.5	0.07	Jul 1400	8.13

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	175	0.022	0.017	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.2	Jul 1500	0.0	21.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#22-B-Lift Lobby	1	2.2	Jul 1500	175	0.0	21.5	8.13

Zone Sizing Summary for #23-B-Lobby

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#23-B-Lobby**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	7.2	6.6	23.5 / 16.7	13.0 / 12.4	0.19	Jul 1500	8.99

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	523	0.066	0.052	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	6.6	Jul 1500	0.0	58.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#23-B-Lobby	1	6.6	Jul 1500	523	0.0	58.2	8.99

Zone Sizing Summary for #24-B-Water Supply Pump

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#24-B-Water Supply Pump**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **37.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.6	5.1	23.5 / 16.7	13.0 / 12.4	0.15	Jul 1500	10.97

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	409	0.052	0.041	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.2	Jul 1500	0.0	37.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#24-B-Water Supply Pump	1	5.2	Jul 1500	409	0.0	37.3	10.97

Zone Sizing Summary for #25-B-Façade Cradle Stor

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#25-B-Façade Cradle Stor**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **7.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.4	23.5 / 17.3	13.2 / 12.6	0.05	Jul 1600	15.47

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	114	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.4	Jul 1500	0.0	7.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#25-B-Façade Cradle Stor	1	1.4	Jul 1500	114	0.0	7.4	15.47

Zone Sizing Summary for #26-B-Irrigation Pump Ro

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#26-B-Irrigation Pump Ro**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.3	3.9	23.5 / 16.8	13.1 / 12.5	0.11	Jul 1600	10.49

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	313	0.039	0.031	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.0	Jul 1500	0.0	29.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#26-B-Irrigation Pump Ro	1	4.0	Jul 1500	313	0.0	29.8	10.49

Zone Sizing Summary for #27,28-B-Fire PumpRM,COR

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#27,28-B-Fire PumpRM,COR**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **51.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.0	2.8	23.6 / 16.7	13.0 / 12.4	0.08	Jun 1500	4.31

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	221	0.028	0.022	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.8	Jul 1500	0.0	51.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#27-B-Fire Pump Room	1	1.9	Jul 1500	151	0.0	40.3	3.76
#28-B-Service Corridor	1	0.9	Jul 1500	70	0.0	11.0	6.34

Zone Sizing Summary for #29-B-IDF (Outside)

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#29-B-IDF (Outside)**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **6.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.0	2.9	23.7 / 16.7	13.4 / 12.7	0.08	Jul 1500	36.77

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	232	0.029	0.023	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.9	Jul 1500	0.0	6.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#29-B-IDF (Outside)	1	2.9	Jul 1500	232	0.0	6.3	36.77

Zone Sizing Summary for #30-GF-LV

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#30-GF-LV**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **79.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	14.2	13.9	23.4 / 16.3	12.8 / 12.1	0.38	Jul 1400	13.55

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	1081	0.136	0.108	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	13.7	Aug 1500	0.5	79.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#30-GF-LV	1	13.7	Aug 1500	1081	0.5	79.8	13.55

Zone Sizing Summary for #31-GF-Service Corridor

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#31-GF-Service Corridor**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **26.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.9	1.7	23.5 / 16.9	13.4 / 12.7	0.05	Jul 1300	5.41

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	142	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.8	Jul 1500	0.0	26.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#31-GF-Service Corridor	1	1.8	Jul 1500	142	0.0	26.2	5.41

Zone Sizing Summary for #32-GF-Essential LV

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#32-GF-Essential LV**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **22.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.1	3.9	23.5 / 16.5	12.9 / 12.3	0.11	Jul 1500	13.93

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	306	0.039	0.031	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.9	Aug 1500	0.1	22.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#32-GF-Essential LV	1	3.9	Aug 1500	306	0.1	22.0	13.93

Zone Sizing Summary for #33,34-GF, MOV & BULK STO

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#33,34-GF, MOV & BULK STO**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **10.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.5	0.9	23.5 / 19.0	13.0 / 12.7	0.04	Jun 1600	6.75

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	69	0.009	0.007	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	0.9	Jul 1500	0.0	10.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#33-GF-Move IN /OUT Stor	1	0.3	Jul 1500	22	0.0	5.0	4.38
#34-GF-Bulk Store	1	0.6	Jul 1500	48	0.0	5.3	8.98

Zone Sizing Summary for #35,36,37-GF-FCC,CBS,AV

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name ... **#35,36,37-GF-FCC,CBS,AV**
Equipment Class ... **TERM**
Air System Type ... **2P-FC**

Number of zones **1**
Floor Area **29.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	7.7	7.6	23.5 / 16.4	12.9 / 12.2	0.20	Jul 1500	20.17

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	593	0.075	0.059	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	7.5	Jul 1500	0.1	29.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#35-GF-FCC	1	1.2	Jul 1500	93	0.1	18.3	5.10
#36-GF-CBS	1	0.2	Jul 1500	18	0.0	5.6	3.25
#37-GF-AV	1	6.1	Jul 1500	481	0.0	5.5	87.53

Zone Sizing Summary for #38-GF-Admin

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#38-GF-Admin**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **11.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	0.8	0.7	23.5 / 17.0	12.8 / 12.2	0.02	Jun 1600	4.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	51	0.006	0.005	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	0.6	Jul 1500	0.1	11.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#38-GF-Admin	1	0.6	Jul 1500	51	0.1	11.8	4.30

Zone Sizing Summary for #39-#40-GF-Pantry-CORRIDOR ADMIN

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#39-#40-GF-Pantry-CORRIDOR ADMIN**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **11.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	0.9	0.8	23.6 / 17.2	13.6 / 13.0	0.03	Jun 1500	6.27

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	69	0.009	0.007	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	0.9	Jul 1500	0.0	11.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#39-GF-Pantry	1	0.1	Jul 1500	11	0.0	6.3	1.72
#40-GF-Corridor (Admin&P	1	0.7	Jul 1500	58	0.0	4.7	12.37

Zone Sizing Summary for #41-GF-Garbage Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#41-GF-Garbage Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **70.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.7	3.4	18.4 / 14.9	12.9 / 12.6	0.10	Jul 1300	7.29

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	513	0.065	0.051	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.4	Jul 1500	0.1	70.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#41-GF-Garbage Room	1	3.4	Jul 1500	513	0.1	70.4	7.29

Zone Sizing Summary for #42-GF-Service Corridor

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#42-GF-Service Corridor**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **52.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.4	23.6 / 17.1	13.0 / 12.4	0.04	Sep 1500	2.08

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	108	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.4	Aug 1500	0.1	52.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1 #42-GF-Service Corridor	1	1.4	Aug 1500	108	0.1	52.1	2.08

Zone Sizing Summary for #43-GF-Security Control ROOM

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#43-GF-Security Control ROOM**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **38.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.6	2.3	23.5 / 17.0	13.2 / 12.6	0.07	Jun 1500	4.92

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	190	0.024	0.019	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.4	Aug 1500	0.2	38.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#43-GF-Security Control	1	2.4	Aug 1500	190	0.2	38.6	4.92

Zone Sizing Summary for #44-GF-Security Equipment

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#44-GF-Security Equipment**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **27.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	18.7	18.4	23.4 / 16.3	12.8 / 12.2	0.50	Aug 1200	53.13

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	1445	0.182	0.145	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	18.3	Sep 1500	0.2	27.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1 #44-GF-Security Equipmen	1	18.3	Sep 1500	1445	0.2	27.2	53.13

Zone Sizing Summary for #45,46,47-GF-IDF,ELE,COR

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name .. **#45,46,47-GF-IDF,ELE,COR**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **22.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.9	2.7	23.6 / 16.8	13.4 / 12.7	0.08	Jul 1500	9.69

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	218	0.027	0.022	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.8	Jul 1500	0.0	22.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#45-GF-IDF	1	0.6	Jul 1500	48	0.0	4.5	10.71
#46-GF-ELEC. RM	1	1.3	Jul 1500	100	0.0	6.2	16.20
#47-GF-Corridor (IDF&EL	1	0.9	Jul 1500	69	0.0	11.8	5.88

Zone Sizing Summary for #48-GF-Service Lift Lobby

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#48-GF-Service Lift Lobby**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **21.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.5	2.2	23.5 / 16.8	13.0 / 12.4	0.07	Jul 1500	8.21

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	178	0.022	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Jul 1500	0.0	21.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#48-GF-Service Lift Lobb	1	2.3	Jul 1500	178	0.0	21.7	8.21

Zone Sizing Summary for #49-GF-Main Lobby

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#49-GF-Main Lobby**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **165.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	33.7	31.9	23.6 / 16.8	13.4 / 12.7	0.90	Jul 1500	15.54

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	2577	0.325	0.258	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	32.6	Jul 1500	2.2	165.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#49-GF-Main Lobby	1	32.6	Jul 1500	2577	2.2	165.8	15.54

Zone Sizing Summary for #50-GF-Changing & ShoLEFT

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#50-GF-Changing & ShoLEFT**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.8	1.6	23.6 / 16.8	13.1 / 12.5	0.05	Aug 0200	4.29

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	128	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.6	Aug 0100	0.4	29.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#50-GF-Changing&Sh LEFT	1	1.6	Aug 0100	128	0.4	29.8	4.29

Zone Sizing Summary for #51-GF-Changing&Sho RIGHT

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#51-GF-Changing&Sho RIGHT**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.4	2.3	23.7 / 16.9	13.6 / 13.0	0.06	Aug 1400	7.42

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	187	0.024	0.019	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.4	Aug 1500	0.4	25.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#51-GF-Chang & SHO RIGHT	1	2.4	Aug 1500	187	0.4	25.2	7.42

Zone Sizing Summary for #52-GF-Gym

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#52-GF-Gym**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **98.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	14.7	13.8	23.5 / 16.5	13.0 / 12.3	0.39	Sep 1600	11.13

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	1091	0.138	0.109	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	13.8	Sep 1600	1.5	98.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#52-GF-Gym	1	13.8	Sep 1600	1091	1.5	98.1	11.13

Zone Sizing Summary for #53-GF-Multipurpose & KId

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name .. **#53-GF-Multipurpose & KId**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **135.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	19.1	16.7	23.5 / 16.9	12.9 / 12.3	0.51	Sep 1400	9.66

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	1312	0.165	0.131	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	16.6	Sep 1400	1.7	135.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#53-GF-Multipurpose & KI	1	16.6	Sep 1400	1312	1.7	135.8	9.66

Zone Sizing Summary for #54-GF-Meeting Room

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#54-GF-Meeting Room**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.9	2.4	23.5 / 17.1	12.9 / 12.3	0.08	Jun 1700	14.59

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	190	0.024	0.019	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.4	Jun 1700	0.3	13.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#54-GF-Meeting Room	1	2.4	Jun 1700	190	0.3	13.0	14.59

Zone Sizing Summary for #55-GF-FM Office

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#55-GF-FM Office**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **26.6** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.3	4.0	23.5 / 16.6	13.0 / 12.4	0.11	Nov 1500	12.06

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	321	0.040	0.032	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.1	Nov 1400	0.4	26.6

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#55-GF-FM Office	1	4.1	Nov 1400	321	0.4	26.6	12.06

Zone Sizing Summary for #56-GF-Dining

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#56-GF-Dining**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **14.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.8	4.1	23.5 / 17.0	13.0 / 12.4	0.13	Nov 1400	22.90

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	323	0.041	0.032	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.1	Nov 1400	0.2	14.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#56-GF-Dining	1	4.1	Nov 1400	323	0.2	14.1	22.90

Zone Sizing Summary for #57-#58-#59-GF-Pantry-STO-CORRI

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#57-#58-#59-GF-Pantry-STO-CORRI**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **32.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.2	23.6 / 18.0	13.1 / 12.6	0.04	Jul 1500	3.02

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	97	0.012	0.010	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.2	Jul 1500	0.0	32.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#57-GF-Pantry	1	0.1	Jul 1500	10	0.0	5.6	1.70
#58-GF-Store	1	0.5	Jul 1500	41	0.0	3.2	12.94
#59-GF-Corridor	1	0.6	Jul 1500	46	0.0	23.2	1.97

Zone Sizing Summary for #60-GF-Prayer RM/Ablut(F)

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name ... **#60-GF-Prayer RM/Ablut(F)**
Equipment Class ... **TERM**
Air System Type ... **2P-FC**

Number of zones **1**
Floor Area **15.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.4	3.1	23.5 / 18.0	13.0 / 12.5	0.12	Jul 1500	15.18

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	241	0.030	0.024	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.1	Jul 1500	0.2	15.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#60-GF-PrayerRM/Ablut(F)	1	3.1	Jul 1500	241	0.2	15.9	15.18

Zone Sizing Summary for #61-GF-Prayer RM/Ablut(M)

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name ..#61-GF-Prayer RM/Ablut(M)
Equipment ClassTERM
Air System Type2P-FC

Number of zones1
Floor Area22.2 m²
LocationDubai, United Arab Emirates

Sizing Calculation Information

Calculation MonthsJan to Dec
Sizing DataCalculated

Zone L/s SizingSum of space airflow rates
Space L/s SizingIndividual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	6.0	4.2	23.5 / 18.0	13.0 / 12.5	0.16	Aug 1500	14.87

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	330	0.042	0.033	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	4.2	Aug 1500	0.3	22.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
#61-GF-PrayerRM/Ablut(M)	1	4.2	Aug 1500	330	0.3	22.2	14.87

Zone Sizing Summary for #62-STAIRCASE-3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#62-STAIRCASE-3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **188.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.6	3.3	23.6 / 18.0	13.1 / 12.6	0.12	Jun 1600	1.38

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	259	0.033	0.026	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.3	Jul 1500	0.0	188.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#62--Stair3 (1.1.L)	9	0.4	Jul 1500	29	0.0	20.9	1.38

Zone Sizing Summary for #63-STAIRCASE-2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#63-STAIRCASE-2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **193.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.5	3.3	23.6 / 17.8	13.1 / 12.5	0.12	May 1500	1.35

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	261	0.033	0.026	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.3	Jul 1500	0.0	193.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#63--Stair2 (1.1.G)	12	0.3	Jul 1500	22	0.0	16.1	1.35

Zone Sizing Summary for #64-STAIRCASE-1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **#64-STAIRCASE-1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **250.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.5	4.0	23.6 / 17.8	13.1 / 12.5	0.15	Jun 1500	1.26

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	316	0.040	0.032	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.0	Jul 1500	0.0	250.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
#64--Stair1 (1.1.11)	12	0.3	Jul 1500	26	0.0	20.9	1.26

Zone Sizing Summary for @@001-003-1-1F-2B13-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.5	23.7 / 16.9	13.5 / 12.5	0.04	Jun 1700	4.63

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	120	0.015	0.012	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.5	Jun 1700	0.2	25.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@001-1-1F-2B13-MBED	1	1.3	Jun 1700	105	0.2	15.3	6.86
@@002-1-1F-2B13-DRESS	1	0.1	Jul 1500	6	0.0	2.6	2.16
@@003-1-1F-2B13-MBATH	1	0.1	Jul 1500	9	0.0	8.0	1.15

Zone Sizing Summary for @@004-1-1F-2B13-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.4	1.3	23.5 / 16.6	13.1 / 12.1	0.04	Jun 1500	7.46

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	101	0.013	0.010	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.3	Jun 1700	0.1	13.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@004-1-1F-2B13-BED1	1	1.3	Jun 1700	101	0.1	13.5	7.46

Zone Sizing Summary for @@005-008-1-1F-2B13-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **42.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.7	5.0	23.5 / 16.6	13.0 / 12.1	0.15	Jun 1600	9.37

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	398	0.050	0.040	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.0	Jul 1600	0.5	42.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@005-1-1F-2B13-BATH	1	0.2	Jul 1500	14	0.0	4.1	3.49
@@006-1-1F-2B13-COR	1	0.7	Jul 1500	52	0.0	9.4	5.53
@@007-1-1F-2B13-KIT	1	1.0	Aug 1500	81	0.1	8.5	9.50
@@008-1-1F-2B13-LV/DN	1	3.2	Jun 1700	251	0.4	20.5	12.25

Zone Sizing Summary for @@009-015-2-1F-1B12-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.9	5.2	23.5 / 16.6	13.0 / 12.1	0.16	Jun 1600	6.92

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	410	0.052	0.041	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.2	Jun 1600	0.4	59.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@009-2-1F-1B12-BEDR	1	1.9	Jun 1700	146	0.2	15.2	9.62
@@010-2-1F-1B12-DRESS	1	0.1	Jul 1500	7	0.0	3.1	2.16
@@011-2-1F-1B12-BATH	1	0.1	Jul 1500	11	0.0	5.6	1.99
@@012-2-1F-1B12-LV/DN	1	1.8	Jun 1700	138	0.2	17.2	8.05
@@013-2-1F-1B12-KIT	1	0.9	Jul 1500	73	0.0	11.3	6.50
@@014-2-1F-1B12-COR	1	0.2	Jul 1500	16	0.0	3.8	4.24
@@015-2-1F-1B12-POW	1	0.2	Jul 1500	18	0.0	3.1	5.96

Zone Sizing Summary for @@016-022-3-1F-1B11-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.3	4.6	23.5 / 16.7	13.0 / 12.1	0.14	Jul 1600	6.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	368	0.046	0.037	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.6	Jun 1700	0.4	58.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@016-3-1F-1B11-Bed	1	1.7	Jun 1700	138	0.2	15.2	9.06
@@017-3-1F-1B11-DRES	1	0.0	Jul 1500	3	0.0	3.1	1.10
@@018-3-1F-1B11-BATH	1	0.1	Jul 1500	11	0.0	5.6	1.99
@@019-3-1F-1B11-LV/DN	1	1.6	Jun 1700	124	0.2	16.7	7.44
@@020-3-1F-1B11-KIT	1	0.8	Jul 1500	64	0.0	10.9	5.87
@@021-3-1F-1B11-COR	1	0.2	Jul 1500	12	0.0	3.8	3.19
@@022-3-1F-1B11-POW	1	0.2	Jul 1500	15	0.0	3.1	4.90

Zone Sizing Summary for @@023-029-4-1F-1B10-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.1	4.4	23.8 / 17.1	13.6 / 12.7	0.14	Jun 1700	6.07

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	361	0.046	0.036	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.5	Jun 1700	0.5	59.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@023-4-1F-1B10-BED	1	1.9	Jun 1700	147	0.3	15.3	9.62
@@024-4-1F-1B10-DRES	1	0.0	Jul 1500	3	0.0	3.1	1.10
@@025-4-1F-1B10-BATH	1	0.1	Jul 1600	8	0.0	5.6	1.38
@@026-4-1F-1B10-LV/DN	1	1.4	Jun 1700	113	0.2	16.7	6.78
@@027-4-1F-1B10-KIT	1	0.7	Jul 1500	55	0.0	11.9	4.63
@@028-4-1F-1B10-COR	1	0.2	Jul 1500	16	0.0	3.8	4.24
@@029-4-1F-1B10-POW	1	0.2	Jul 1500	18	0.0	3.1	5.96

Zone Sizing Summary for @@030-032-5-1F-2B14-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.4	2.2	23.5 / 16.4	13.0 / 12.0	0.06	Nov 1400	7.02

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	173	0.022	0.017	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.2	Nov 1400	0.2	24.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@030-5-1F-2B14-MBED	1	1.9	Nov 1400	152	0.2	14.2	10.72
@@031-5-1F-2B14-DRES	1	0.1	Jul 1500	6	0.0	2.6	2.16
@@032-5-1F-2B14-MBATH	1	0.2	Jul 1500	16	0.0	7.9	1.99

Zone Sizing Summary for @@033-5-1F-2B14-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.9	1.7	23.5 / 16.3	13.0 / 11.9	0.05	Dec 1400	10.31

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	136	0.017	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.7	Dec 1400	0.1	13.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1 @@033-5-1F-2B14-BEDR	1	1.7	Dec 1400	136	0.1	13.2	10.31

Zone Sizing Summary for @@034-037-5-1F-2B14-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.4	4.8	23.5 / 16.7	13.2 / 12.3	0.14	Oct 1500	8.94

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	388	0.049	0.039	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.8	Oct 1500	0.4	43.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@034-5-1F-2B14-BATH	1	0.2	Jul 1500	13	0.0	4.4	2.98
@@035-5-1F-2B14-COR	1	0.6	Jul 1500	45	0.0	9.7	4.67
@@036-5-1F-2B14-KIT	1	0.8	Jul 1500	64	0.1	8.5	7.55
@@037-5-1F-2B14-LV/DN	1	3.4	Nov 1500	265	0.4	20.8	12.75

Zone Sizing Summary for @@038-044-6-1F-1B15-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.7	6.0	23.5 / 16.5	13.2 / 12.2	0.18	Nov 1400	8.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	485	0.061	0.048	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	6.0	Nov 1400	0.5	58.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@038-6-1F-1B15-BEDR	1	2.5	Nov 1500	195	0.3	15.2	12.80
@@039-6-1F-1B15-DRES	1	0.1	Jul 1500	7	0.0	3.1	2.16
@@040-6-1F-1B15-BATH	1	0.1	Jul 1500	11	0.0	5.6	1.99
@@041-6-1F-1B15-LV/DN	1	2.4	Dec 1400	186	0.2	16.7	11.12
@@042-6-1F-1B15-KIT	1	0.7	Jul 1500	52	0.0	10.9	4.79
@@043-6-1F-1B15-COR	1	0.2	Jul 1500	16	0.0	3.8	4.14
@@044-6-1F-1B15-POW	1	0.2	Jul 1500	18	0.0	3.1	5.96

Zone Sizing Summary for @045-047-7-1F-2B17-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.2	2.1	23.5 / 16.6	13.4 / 12.4	0.06	Dec 1400	6.87

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	170	0.021	0.017	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.1	Nov 1400	0.3	24.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@045-7-1F-2B17-MBED	1	1.9	Nov 1400	147	0.2	14.2	10.33
@046-7-1F-2B17-DRES	1	0.0	Jul 1500	3	0.0	2.6	1.10
@047-7-1F-2B17-MBAT	1	0.3	Jul 0000	20	0.1	7.9	2.56

Zone Sizing Summary for @@048-7-1F-2B17-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.9	1.7	23.5 / 16.4	13.1 / 12.1	0.05	Nov 1400	10.29

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	136	0.017	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.7	Dec 1400	0.1	13.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1 @@048-7-1F-2B17-BED1	1	1.7	Dec 1400	136	0.1	13.2	10.29

Zone Sizing Summary for @@049-052-7-1F-2B17-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.3	3.7	23.5 / 16.8	13.2 / 12.3	0.11	Nov 1400	6.92

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	300	0.038	0.030	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.7	Nov 1400	0.2	43.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@049-7-1F-2B17-BATH	1	0.1	Jul 1500	9	0.0	4.4	2.13
@@050-7-1F-2B17-COR	1	0.5	Jul 1500	42	0.0	10.0	4.18
@@051-7-1F-2B17-KIT	1	0.7	Jul 1500	54	0.0	8.4	6.41
@@052-7-1F-2B17-LV/DN	1	2.5	Dec 1400	195	0.2	20.6	9.47

Zone Sizing Summary for @@073-075-10-1F-2B09-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.8	1.6	23.5 / 16.5	13.0 / 12.1	0.05	Jun 1000	5.20

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	130	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.6	Jul 1000	0.2	25.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@073-10-1F-2B09-MBR	1	1.5	Jul 1000	120	0.2	14.3	8.36
@@074-10-1F-2B09-DRES	1	0.0	Jul 1500	3	0.0	2.7	1.10
@@075-10-1F-2B09-MBAT	1	0.1	Jul 1500	7	0.0	8.0	0.93

Zone Sizing Summary for @@076-10-1F-2B09-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.5	23.5 / 16.4	13.0 / 12.0	0.05	Jul 1000	9.27

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	121	0.015	0.012	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.5	Jul 1000	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@076-10-1F-2B09-BED1	1	1.5	Jul 1000	121	0.1	13.1	9.27

Zone Sizing Summary for @@077-080-10-1F-2B09-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.5	3.9	23.4 / 16.7	13.1 / 12.1	0.12	Jun 1400	7.16

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	309	0.039	0.031	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.8	Jul 1500	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@077-10-1F-2B09-BATH1	1	0.2	Jul 1500	12	0.0	4.4	2.83
@@078-10-1F-2B09-COR	1	0.7	Jul 1500	53	0.0	9.8	5.39
@@079-10-1F-2B09-KIT	1	0.8	Jul 1500	62	0.0	8.5	7.31
@@080-10-1F-2B09-LIV/D	1	2.3	Jul 1000	181	0.2	20.4	8.88

Zone Sizing Summary for @@081-087-11-1F-1B08-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.4	4.7	23.6 / 16.8	13.4 / 12.4	0.14	Jul 1000	6.50

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	383	0.048	0.038	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.8	Jul 1400	0.4	58.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@081-11-1F-1B08-BEDR	1	1.9	Jul 1400	146	0.2	15.3	9.57
@@082-11-1F-1B08-DRES	1	0.0	Jul 1500	3	0.0	3.1	1.10
@@083-11-1F-1B08-BATH	1	0.1	Jul 1500	5	0.0	5.6	0.93
@@084-11-1F-1B08-LIV/D	1	1.9	Jul 1000	147	0.2	16.7	8.81
@@085-11-1F-1B08-KIT	1	0.7	Jul 1500	54	0.0	11.3	4.82
@@086-11-1F-1B08-COR	1	0.2	Jul 1500	12	0.0	3.8	3.19
@@087-11-1F-1B08-POW	1	0.2	Jul 1500	14	0.0	3.1	4.62

Zone Sizing Summary for @@088-090-12-1F-2B07-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.2	2.0	23.6 / 16.7	13.4 / 12.5	0.06	Jun 1500	6.28

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	162	0.020	0.016	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.0	Jul 1400	0.2	25.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@088-12-1F-2B07-MBED	1	1.7	Jul 1000	133	0.2	14.7	9.07
@@089-12-1F-2B07-DRES	1	0.1	Jul 1500	6	0.0	2.7	2.16
@@090-12-1F-2B07-MBATH	1	0.3	Jul 1500	23	0.0	8.4	2.72

Zone Sizing Summary for @@091-12-1F-2B07-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.6	1.4	23.5 / 16.5	12.9 / 11.9	0.04	Jul 0900	8.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	110	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.4	Jul 1000	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1 @@091-12-1F-2B07-BED1	1	1.4	Jul 1000	110	0.1	13.1	8.43

Zone Sizing Summary for @@092-095-12-1F-2B07-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.1	3.5	23.6 / 17.0	13.4 / 12.5	0.11	Jul 1500	6.51

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	280	0.035	0.028	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.5	Jul 1400	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@092-12-1F-2B07-BAT1	1	0.1	Jul 1500	12	0.0	4.4	2.64
@@093-12-1F-2B07-COR	1	0.5	Jul 1500	42	0.0	9.8	4.33
@@094-12-1F-2B07-KIT	1	0.7	Jul 1500	53	0.0	8.5	6.25
@@095-12-1F-2B07-LIV/DN	1	2.2	Jul 1000	173	0.2	20.4	8.49

Zone Sizing Summary for @@096-102-13-1F-1B06-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **60.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.5	4.9	23.6 / 16.9	13.5 / 12.6	0.15	Aug 1300	6.66

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	400	0.050	0.040	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.9	Aug 1400	0.4	60.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@096-13-1F-1B06-BEDR	1	2.1	Oct 1400	166	0.2	15.9	10.47
@@097-13-1F-1B06-DRESS	1	0.0	Jul 1500	4	0.0	3.2	1.10
@@098-13-1F-1B06-BATH	1	0.1	Jul 1500	6	0.0	6.0	0.93
@@099-13-1F-1B06-LIV/DN	1	1.8	Jul 1000	143	0.2	16.7	8.58
@@100-13-1F-1B06-KIT	1	0.7	Jul 1500	54	0.0	11.3	4.82
@@101-13-1F-1B06-COR	1	0.2	Jul 1500	12	0.0	3.8	3.19
@@102-13-1F-1B06-POW	1	0.2	Jul 1500	14	0.0	3.1	4.62

Zone Sizing Summary for @@103-109-14-1F-1B05-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.1	5.4	23.5 / 16.6	13.2 / 12.2	0.16	Sep 1400	7.33

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	436	0.055	0.044	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.5	Oct 1400	0.6	59.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@103-14-1F-1B05-BEDR	1	1.8	Oct 1400	144	0.2	15.5	9.32
@@104-14-1F-1B05-DRESS	1	0.0	Jul 1500	4	0.0	3.4	1.10
@@105-14-1F-1B05-BATH	1	0.1	Jul 1500	5	0.0	5.6	0.93
@@106-14-1F-1B05-LIV	1	2.5	Oct 1400	201	0.3	17.0	11.84
@@107-14-1F-1B05-KIT	1	0.5	Jul 1500	41	0.0	7.8	5.24
@@108-14-1F-1B05-COR	1	0.3	Jul 1500	27	0.0	7.5	3.57
@@109-14-1F-1B05-POW	1	0.2	Jul 1500	14	0.0	2.7	5.16

Zone Sizing Summary for @@110-112-15-1F-3B04-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.4	2.2	23.7 / 16.8	13.6 / 12.7	0.06	Sep 1600	6.04

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	181	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Sep 1600	0.2	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@110-15-1F-3B04-MBED	1	2.0	Sep 1600	155	0.2	15.2	10.19
@@111-15-1F-3B04-DRESS	1	0.1	Jul 1500	5	0.0	4.5	1.10
@@112-15-1F-3B04-MBAT	1	0.3	Jul 1500	21	0.0	10.2	2.05

Zone Sizing Summary for @@113-117-15-1F-3B04-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.0	2.7	23.7 / 16.8	13.6 / 12.6	0.08	Aug 1600	5.62

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	222	0.028	0.022	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.8	Aug 1600	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@113-15-1F-3B04-BEDR2	1	1.7	Jul 1700	134	0.2	11.9	11.26
@@114-15-1F-3B04-COR	1	0.6	Jul 1500	44	0.0	16.0	2.75
@@115-15-1F-3B04-MIR	1	0.4	Jul 1500	35	0.0	5.6	6.26
@@116-15-1F-3B04-MIB	1	0.0	Jul 1500	3	0.0	2.8	0.93
@@117-15-1F-3B04-POW	1	0.1	Jul 1500	6	0.0	3.2	1.99

Zone Sizing Summary for @@118-119-15-1F-3B04-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **16.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.1	2.0	23.5 / 16.4	13.0 / 12.0	0.06	Jul 1700	9.66

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	154	0.019	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.0	Jul 1700	0.1	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@118-15-1F-3B04-BeDR1	1	1.7	Jul 1700	135	0.1	11.6	11.63
@@119-15-1F-3B04-BAT1	1	0.2	Jul 1500	20	0.0	4.4	4.46

Zone Sizing Summary for @@120-121-15-1F-3B04-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **35.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.5	5.7	23.5 / 16.6	13.0 / 12.0	0.17	Oct 1500	12.80

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	453	0.057	0.045	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.7	Oct 1500	0.6	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@120-15-1F-3B04-KIT	1	1.1	Aug 1500	87	0.1	11.7	7.44
@@121-15-1F-3B04-LV/DN	1	4.6	Oct 1500	366	0.5	23.7	15.45

Zone Sizing Summary for @@122-124-16-1F-3B03-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.5	2.3	23.6 / 16.6	13.3 / 12.3	0.07	Sep 1600	6.10

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	182	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Sep 1600	0.2	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@122-16-1F-3B03-MBED	1	2.0	Sep 1600	156	0.2	15.2	10.29
@@123-16-1F-3B03-DRES	1	0.1	Jul 1500	5	0.0	4.5	1.10
@@124-16-1F-3B03-MBAT	1	0.3	Jul 1500	21	0.0	10.2	2.05

Zone Sizing Summary for @@125-129-16-1F-3B03-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.3	3.0	23.5 / 16.6	13.2 / 12.3	0.09	Jun 1600	6.16

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	243	0.031	0.024	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.1	Aug 1600	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@125-16-1F-3B03-CBED2	1	1.9	Jul 1700	146	0.2	11.9	12.29
@@126-16-1F-3B03-COR	1	0.6	Jul 1500	49	0.0	16.0	3.06
@@127-16-1F-3B03-MIR	1	0.5	Jul 1500	41	0.0	5.6	7.32
@@128-16-1F-3B03-MIB	1	0.1	Jul 1500	4	0.0	2.8	1.50
@@129-16-1F-3B03-POW	1	0.0	Jul 1500	3	0.0	3.2	0.93

Zone Sizing Summary for @@130-131-16-1F-3B03-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **16.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.0	1.8	23.5 / 16.4	13.0 / 12.0	0.05	Aug 1600	9.06

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	145	0.018	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.8	Jul 1700	0.1	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@130-16-1F-3B03-BED1	1	1.6	Jul 1700	127	0.1	11.6	10.94
@@131-16-1F-3B03-BAT1	1	0.2	Jul 1500	18	0.0	4.4	4.13

Zone Sizing Summary for @@132-133-1F-3B03-FCU-4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **35.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.0	4.2	23.5 / 16.7	12.9 / 12.0	0.13	Jul 1700	9.44

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	334	0.042	0.033	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.2	Jul 1700	0.3	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@132-16-1F-3B03-KIT	1	0.7	Jul 1500	57	0.0	11.7	4.84
@133-16-1F-3B03-LIV/D	1	3.5	Jul 1700	278	0.3	23.7	11.71

Zone Sizing Summary for @@134-136-17-1F-2B02-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.5	2.3	23.5 / 16.4	13.0 / 12.0	0.07	Aug 1600	7.27

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	180	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Aug 1600	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@134-17-1F-2B02-MBED	1	1.9	Jul 1700	147	0.2	14.4	10.20
@@135-17-1F-2B02-DRES	1	0.1	Jul 1500	6	0.0	2.7	2.16
@@136-17-1F-2B02-MBAT	1	0.3	Jul 1500	28	0.0	7.7	3.59

Zone Sizing Summary for @@137-17-1F-2B02-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.8	1.6	23.5 / 16.4	13.0 / 11.9	0.05	Jul 1700	9.86

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	129	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.6	Jul 1700	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@137-17-1F-2B02-BED1	1	1.6	Jul 1700	129	0.1	13.1	9.86

Zone Sizing Summary for @@138-141-17-1F-2B02-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.5	3.9	23.5 / 16.7	12.9 / 12.0	0.12	Aug 1600	7.04

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	304	0.038	0.030	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.8	Aug 1600	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@138-17-1F-2B02-BAT1	1	0.2	Jul 1500	12	0.0	4.4	2.79
@@139-17-1F-2B02-COR	1	0.5	Jul 1500	43	0.0	9.8	4.41
@@140-17-1F-2B02-KIT	1	0.7	Jul 1500	53	0.0	8.5	6.25
@@141-17-1F-2B02-LIV/DI	1	2.5	Jul 1700	195	0.2	20.4	9.56

Zone Sizing Summary for @@142-144-18-1F-2B01-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.5	2.3	23.5 / 16.4	13.0 / 12.0	0.07	Aug 1600	7.27

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	180	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Aug 1600	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@142-18-1F-2B01-MBED	1	1.9	Jul 1700	147	0.2	14.4	10.20
@@143-18-1F-2B01-DRES	1	0.1	Jul 1500	6	0.0	2.7	2.16
@@144-18-1F-2B01-MBA	1	0.3	Jul 1500	28	0.0	7.7	3.59

Zone Sizing Summary for @@145-18-1F-2B01-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **27.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.5	2.3	23.6 / 16.6	13.4 / 12.4	0.07	Jul 1600	6.71

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	183	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Aug 1600	0.1	27.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@145-18-1F-2B01-BED1	1	1.6	Jul 1700	128	0.1	13.1	9.75
@@147-18-1F-2B01-COR	1	0.5	Jul 1500	43	0.0	9.8	4.41
@@146-18-1F-2B01-BAT1	1	0.2	Jul 1500	12	0.0	4.4	2.79

Zone Sizing Summary for @@146-149-18-1F-2B01-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **44.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.2	4.5	23.5 / 16.6	13.0 / 12.0	0.14	Aug 1600	8.16

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	359	0.045	0.036	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.5	Aug 1600	0.2	44.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@@146-18-1F-2B01-BAT1	1	0.2	Jul 1500	12	0.0	4.4	2.79
@@147-18-1F-2B01-COR	1	0.5	Jul 1500	43	0.0	9.8	4.41
@@148-18-1F-2B01-KIT	1	1.0	Jul 1500	78	0.0	8.9	8.72
@@149-18-1F-2B01-LIV	1	2.9	Aug 1600	226	0.2	20.9	10.82

Zone Sizing Summary for @001-003-1-2F-5F-2B15-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@001-003-1-2F-5F-2B15-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.5	1.3	23.6 / 16.8	13.2 / 12.2	0.04	Jun 1700	4.06

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	105	0.013	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.3	Jun 1700	0.2	25.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@001-1-2F-5F-2B15-M.BED	1	1.2	Jun 1700	95	0.2	15.3	6.20
@002-1-2F-5F-2B15-Dress	1	0.0	Jul 1500	3	0.0	2.6	1.10
@003-1-2F-5F-2B15-M Bat	1	0.1	Jul 1500	7	0.0	8.0	0.93

Zone Sizing Summary for @004-1-2F-5F-2B15-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name @004-1-2F-5F-2B15-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.5 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.2	1.1	23.6 / 16.9	13.3 / 12.4	0.03	Jun 1600	6.44

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	87	0.011	0.009	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.1	Jun 1700	0.1	13.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@004-1-2F-5F-2B15-Bed-1	1	1.1	Jun 1700	87	0.1	13.5	6.44

Zone Sizing Summary for @005-008-1-2F-5F-2B15-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@005-008-1-2F-5F-2B15-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **42.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.1	4.5	23.5 / 16.6	13.0 / 12.1	0.14	Jul 1700	8.33

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	354	0.045	0.035	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.4	Jun 1700	0.5	42.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@005-1-2F-5F-2B15-Bath	1	0.1	Jul 1500	10	0.0	4.1	2.43
@006-1-2F-5F-2B15-Cor	1	0.5	Jul 1500	42	0.0	9.4	4.47
@007-1-2F-5F-2B15-Kit	1	0.9	Aug 1500	72	0.1	8.5	8.45
@008-1-2F-5F-2B15-LV/DN	1	2.9	Jun 1700	230	0.4	20.5	11.23

Zone Sizing Summary for @009-015-2-2F-5F-1B14-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@009-015-2-2F-5F-1B14-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.9	4.2	23.8 / 17.1	13.7 / 12.8	0.13	Jun 1700	5.89

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	349	0.044	0.035	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.4	Jun 1700	0.4	59.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@009-2-2F-5F-1B14-BedR	1	1.7	Jun 1700	131	0.2	15.2	8.60
@010-2-2F-5F-1B14-Dres	1	0.0	Jul 1500	3	0.0	3.1	1.10
@011-2-2F-5F-1B14-Bath	1	0.1	Jul 1500	5	0.0	5.6	0.93
@012-2-2F-5F-1B14-LV/DN	1	1.5	Jun 1700	121	0.2	17.2	7.03
@013-2-2F-5F-1B14-Kit	1	0.8	Jul 1500	61	0.0	11.3	5.44
@014-2-2F-5F-1B14-Cor	1	0.2	Jul 1500	12	0.0	3.8	3.19
@015-2-2F-5F-1B14-Powd	1	0.2	Jul 1500	15	0.0	3.1	4.90

Zone Sizing Summary for @016-022-3-2F-5F-1B13-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@016-022-3-2F-5F-1B13-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.8	4.1	23.8 / 17.1	13.7 / 12.7	0.13	Jun 1700	5.73

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	335	0.042	0.033	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.2	Jun 1700	0.4	58.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@017-3-2F-5F-1B13-Dres	1	0.0	Jul 1500	3	0.0	3.1	1.10
@018-3-2F-5F-1B13-Bath	1	0.1	Jul 1500	5	0.0	5.6	0.93
@019-3-2F-5F-1B13-LV/DN	1	1.4	Jun 1700	113	0.2	16.7	6.78
@020-3-2F-5F-1B13-Kit	1	0.7	Jul 1500	55	0.0	10.9	5.04
@021-3-2F-5F-1B13-Cor	1	0.2	Jul 1500	12	0.0	3.8	3.19
@022-3-2F-5F-1B13-Pow	1	0.2	Jul 1500	15	0.0	3.1	4.90
@016-3-2F-5F-1B13-Bed	1	1.7	Jun 1700	131	0.2	15.2	8.60

Zone Sizing Summary for @023-029-4-2F-5F-1B12-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@023-029-4-2F-5F-1B12-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.9	4.2	23.8 / 17.1	13.7 / 12.7	0.13	Jun 1700	5.79

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	344	0.043	0.034	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.3	Jun 1700	0.5	59.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@023-4-2F-5F-1B12-Bed	1	1.8	Jun 1700	139	0.3	15.3	9.12
@024-4-2F-5F-1B12-Dres	1	0.0	Jul 1500	3	0.0	3.1	1.10
@025-4-2F-5F-1B12-Bath	1	0.1	Jul 1600	8	0.0	5.6	1.38
@026-4-2F-5F-1B12-LV/DN	1	1.4	Jun 1700	111	0.2	16.7	6.67
@027-4-2F-5F-1B12-Kit	1	0.7	Jul 1500	55	0.0	11.9	4.63
@028-4-2F-5F-1B12-Cor	1	0.2	Jul 1500	12	0.0	3.8	3.19
@029-4-2F-5F-1B12-Pow	1	0.2	Jul 1500	15	0.0	3.1	4.90

Zone Sizing Summary for @030-032-5-2F-5F-2B16-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@030-032-5-2F-5F-2B16-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.1	1.9	23.5 / 16.4	13.0 / 12.0	0.06	Nov 1400	6.09

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	151	0.019	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.9	Dec 1400	0.2	24.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@030-5-2F-5F-2B16-MBed	1	1.8	Dec 1400	140	0.2	14.2	9.88
@031-5-2F-5F-2B16-Dre	1	0.0	Jul 1500	3	0.0	2.6	1.10
@032-5-2F-5F-2B16-MBat	1	0.1	Jul 1500	7	0.0	7.9	0.93

Zone Sizing Summary for @033-5-2F-5F-2B16-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name @033-5-2F-5F-2B16-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.2 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.9	1.7	23.5 / 16.3	13.0 / 11.9	0.05	Dec 1400	10.31

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	136	0.017	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.7	Dec 1400	0.1	13.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@033-5-2F-5F-2B16-Bed1	1	1.7	Dec 1400	136	0.1	13.2	10.31

Zone Sizing Summary for @034-037-5-2F-5F-2B16-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@034-037-5-2F-5F-2B16-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.4	4.7	23.4 / 16.7	13.2 / 12.3	0.14	Oct 1600	8.84

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	384	0.048	0.038	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.7	Oct 1500	0.4	43.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@034-5-2F-5F-2B16-Bath	1	0.1	Jul 1500	10	0.0	4.4	2.33
@035-5-2F-5F-2B16-Cor	1	0.6	Jul 1500	44	0.0	9.7	4.55
@036-5-2F-5F-2B16-Kit	1	0.8	Jul 1500	64	0.1	8.5	7.55
@037-5-2F-5F-2B16-LV/DN	1	3.4	Nov 1500	265	0.4	20.8	12.75

Zone Sizing Summary for @038-044-6-2F-5F-1B17-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@038-044-6-2F-5F-1B17-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.2	5.6	23.5 / 16.6	13.2 / 12.2	0.17	Nov 1500	7.70

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	450	0.057	0.045	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.6	Nov 1400	0.5	58.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@038-6-2F-5F-1B17-Bed	1	2.3	Nov 1500	183	0.3	15.2	12.03
@039-6-2F-5F-1B17-Dress	1	0.0	Jul 1500	3	0.0	3.1	1.10
@040-6-2F-5F-1B17-Bath	1	0.1	Jul 1500	5	0.0	5.6	0.93
@041-6-2F-5F-1B17-LV/DN	1	2.4	Dec 1400	186	0.2	16.7	11.12
@042-6-2F-5F-1B17-Kit	1	0.6	Jul 1500	44	0.0	10.9	4.07
@043-6-2F-5F-1B17-Cor	1	0.2	Jul 1500	13	0.0	3.8	3.42
@044-6-2F-5F-1B17-Pow	1	0.2	Jul 1500	15	0.0	3.1	4.90

Zone Sizing Summary for @045-047-7-2F-5F-2B19-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@045-047-7-2F-5F-2B19-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.2	2.0	23.6 / 16.7	13.6 / 12.6	0.06	Nov 1300	6.87

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	170	0.021	0.017	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.1	Nov 1400	0.3	24.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@045-7-2F-5F-2B19-M.Bed	1	1.9	Nov 1400	147	0.2	14.2	10.33
@046-7-2F-5F-2B19-Dress	1	0.0	Jul 1500	3	0.0	2.6	1.10
@047-7-2F-5F-2B19-M Bat	1	0.3	Jul 0000	20	0.1	7.9	2.56

Zone Sizing Summary for @048-7-2F-5F-2B19-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name @048-7-2F-5F-2B19-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.2 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.9	1.7	23.5 / 16.4	13.1 / 12.1	0.05	Nov 1400	10.29

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	136	0.017	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.7	Dec 1400	0.1	13.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@048-7-2F-5F-2B19-Bed1	1	1.7	Dec 1400	136	0.1	13.2	10.29

Zone Sizing Summary for @049-052-7-2F-5F-2B19-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@049-052-7-2F-5F-2B19-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.3	3.7	23.5 / 16.8	13.2 / 12.3	0.11	Nov 1400	6.92

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	300	0.038	0.030	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.7	Nov 1400	0.2	43.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@049-7-2F-5F-2B19-Bath	1	0.1	Jul 1500	9	0.0	4.4	2.13
@050-7-2F-5F-2B19-Cor)	1	0.5	Jul 1500	42	0.0	10.0	4.18
@051-7-2F-5F-2B19-Kit	1	0.7	Jul 1500	54	0.0	8.4	6.41
@052-7-2F-5F-2B19-LV/DN	1	2.5	Dec 1400	195	0.2	20.6	9.47

Zone Sizing Summary for @053-055-8-2F-8F-2B11-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@053-055-8-2F-8F-2B11-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.6	1.4	23.7 / 16.9	13.4 / 12.4	0.04	Jun 1700	4.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	111	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.4	Jun 1700	0.2	25.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@053-8-2F-578-2B11-M.Bed	1	1.3	Jun 1700	100	0.2	14.8	6.77
@054-8-2F-578-2B11-Dress	1	0.0	Jul 1500	3	0.0	2.6	1.10
@055-8-2F-578-2B11-MBath	1	0.1	Jul 1500	8	0.0	8.4	0.93

Zone Sizing Summary for @056-8-2F-8F-2B11-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name @056-8-2F-8F-2B11-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.3 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.3	1.1	23.6 / 16.8	13.2 / 12.3	0.03	Jun 1700	6.50

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	86	0.011	0.009	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.1	Jun 1700	0.1	13.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@056-8-2F-578-2B11-Bed1	1	1.1	Jun 1700	86	0.1	13.3	6.50

Zone Sizing Summary for @057-060-8-2F-8F-2B11-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@057-060-8-2F-8F-2B11-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.3	3.6	23.5 / 16.8	13.1 / 12.2	0.11	Jul 1600	6.67

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	290	0.037	0.029	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.6	Jul 1500	0.3	43.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@057-8-2F-578-2B11-Bath1	1	0.1	Jul 1500	10	0.0	4.4	2.33
@058-8-2F-5F,78-2B11-Cor	1	0.5	Jul 1500	41	0.0	9.7	4.28
@059-8-2F-5F78F-2B11-Kit	1	0.9	Aug 1600	74	0.1	9.0	8.23
@060-8-2F-578-2B11-LV/DN	1	2.1	Jul 1000	165	0.2	20.4	8.06

Zone Sizing Summary for @061-063-9-2F-8F-3B10-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@061-063-9-2F-8F-3B10-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.2	2.0	23.5 / 16.6	13.2 / 12.3	0.06	Jul 1100	5.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	161	0.020	0.016	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.0	Jul 1400	0.2	29.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@061-9-2F-578-3B10-MBed	1	1.7	Jul 1000	135	0.2	15.0	9.02
@062-9-2F-578-3B10-Dres	1	0.1	Jul 1500	5	0.0	4.5	1.10
@063-9-2F-578-3B10-M Bat	1	0.3	Jul 1500	21	0.0	10.2	2.05

Zone Sizing Summary for @064-068-9-2F-8F-3B10-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@064-068-9-2F-8F-3B10-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.9	2.6	23.5 / 16.7	13.3 / 12.3	0.08	Jul 1400	5.23

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	207	0.026	0.021	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.5	Jul 1500	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@064-9-2F-578-3B10-Bed	1	1.5	Jul 1000	116	0.2	11.9	9.77
@065-9-2F-578-3B10-Cor	1	0.5	Jul 1500	43	0.0	16.0	2.70
@066-9-2F-578-3B10-MadRm	1	0.5	Jul 1600	42	0.0	5.6	7.46
@067-9-2F-578-3B10-MaidB	1	0.0	Jul 1500	3	0.0	2.8	0.93
@068-9-2F-578-3B10-Powd	1	0.0	Jul 1500	3	0.0	3.2	0.93

Zone Sizing Summary for @069-070-9-2F-8F-3B10-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@069-070-9-2F-8F-3B10-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **15.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.6	23.4 / 16.5	13.1 / 12.1	0.05	Aug 1000	7.83

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	125	0.016	0.012	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.5	Jul 1000	0.1	15.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@069-9-2F-578-3B10-Bed1	1	1.3	Jul 1000	106	0.1	11.6	9.18
@070-9-2F-578-3B10-Bath1	1	0.2	Jul 1500	18	0.0	4.3	4.20

Zone Sizing Summary for @071-072-9-2F-8F-3B10-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@071-072-9-2F-8F-3B10-FCU4**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **36.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.1	3.4	23.5 / 17.0	13.0 / 12.1	0.11	Jul 0900	7.40

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	268	0.034	0.027	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.4	Jul 1000	0.3	36.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@071-9-2F-578-3B10-Kit	1	0.8	Jul 1500	67	0.1	12.1	5.54
@072-9-2F-578-3B10-LV/DN	1	2.5	Jul 1000	201	0.3	24.1	8.33

Zone Sizing Summary for @073-075-10-2F-8F-2B09-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@073-075-10-2F-8F-2B09-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.8	1.6	23.7 / 16.9	13.5 / 12.6	0.05	Jul 1000	5.07

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	127	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.6	Jul 1000	0.2	25.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@073-10-2F-578-2B09-MBR	1	1.5	Jul 1000	116	0.2	14.3	8.13
@074-10-2F-578-2B09-Dres	1	0.0	Jul 1500	3	0.0	2.7	1.10
@075-10-2F-578-2B09-MBat	1	0.1	Jul 1500	7	0.0	8.0	0.93

Zone Sizing Summary for @076-10-2F-8F-2B09-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name .. @076-10-2F-8F-2B09-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.6	1.4	23.5 / 16.5	13.0 / 12.0	0.04	Jul 1000	8.41

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	110	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.4	Jul 1000	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@076-10-2F-578-2B09-Bed1	1	1.4	Jul 1000	110	0.1	13.1	8.41

Zone Sizing Summary for @077-080-10-2F-8F-2B09-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@077-080-10-2F-8F-2B09-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.9	3.3	23.6 / 17.1	13.5 / 12.6	0.10	Jul 1000	6.25

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	269	0.034	0.027	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.3	Jul 1400	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@077-10-2F-578-2B09-Bat1	1	0.1	Jul 1500	10	0.0	4.4	2.33
@078-10-2F-578-2B09-Cor	1	0.5	Jul 1500	42	0.0	9.8	4.33
@079-10-2F-578-2B09-Kit	1	0.7	Jul 1500	53	0.0	8.5	6.25
@080-10-2F-578-2B09-L/D	1	2.1	Jul 1000	164	0.2	20.4	8.02

Zone Sizing Summary for @081-087-11-2F-8F-1B08-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@081-087-11-2F-8F-1B08-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.3	4.6	23.6 / 16.9	13.4 / 12.5	0.14	Jul 1000	6.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	371	0.047	0.037	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.6	Jul 1000	0.4	58.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@081-11-2F-578-1B08-BedR	1	1.8	Jul 1000	138	0.2	15.3	9.04
@082-11-2F-578-1B08-Dres	1	0.0	Jul 1500	3	0.0	3.1	1.10
@083-11-2F-578-1B08-Bath	1	0.1	Jul 1500	5	0.0	5.6	0.93
@084-11-2F-578-1B08-L/D	1	1.8	Jul 1000	143	0.2	16.7	8.58
@085-11-2F-578-1B08-Kit	1	0.7	Jul 1500	54	0.0	11.3	4.82
@086-11-2F-578-1B08-Cor	1	0.2	Jul 1500	12	0.0	3.8	3.19
@087-11-2F-578-1B08-Pow	1	0.2	Jul 1500	14	0.0	3.1	4.62

Zone Sizing Summary for @088-090-12-2F-8F-2B07-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name @088-090-12-2F-8F-2B07-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 25.8 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.9	1.7	23.6 / 16.6	13.3 / 12.3	0.05	Jul 0900	5.41

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	139	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.7	Jul 1000	0.2	25.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@088-12-2F-578-2B07-MBed	1	1.6	Jul 1000	123	0.2	14.7	8.33
@089-12-2F-578-2B07-Dres	1	0.0	Jul 1500	3	0.0	2.7	1.10
@090-12-2F-578-2B07-MBat	1	0.2	Jul 1500	14	0.0	8.4	1.66

Zone Sizing Summary for @091-12-2F-8F-2B07-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name .. @091-12-2F-8F-2B07-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.6	1.4	23.5 / 16.5	13.0 / 12.0	0.04	Jul 1000	8.41

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	110	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.4	Jul 1000	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@091-12-2F-578-2B07-Bed1	1	1.4	Jul 1000	110	0.1	13.1	8.41

Zone Sizing Summary for @092-095-12-2F-8F-2B07--FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@092-095-12-2F-8F-2B07--FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.0	3.3	23.7 / 17.3	13.8 / 12.9	0.11	Jul 1400	6.38

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	275	0.035	0.028	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.4	Jul 1400	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@092-12-2F-578-2B07-Bat1	1	0.1	Jul 1500	10	0.0	4.4	2.33
@093-12-2F-578-2B07-Cor	1	0.5	Jul 1500	42	0.0	9.8	4.33
@094-12-2F-578-2B07-Kit	1	0.7	Jul 1500	53	0.0	8.5	6.25
@095-12-2F-578-2B07-L/D	1	2.1	Jul 1000	169	0.2	20.4	8.30

Zone Sizing Summary for @096-102-13-2F-8F-1B06-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@096-102-13-2F-8F-1B06-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **60.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.5	4.8	23.5 / 16.8	13.3 / 12.4	0.15	Aug 1400	6.52

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	391	0.049	0.039	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.8	Aug 1400	0.4	60.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@096-13-2F-578-1B06-BedR	1	2.0	Oct 1400	158	0.2	15.9	9.94
@097-13-2F-578-1B06-Dres	1	0.0	Jul 1500	4	0.0	3.2	1.10
@098-13-2F-578-1B06-Bath	1	0.1	Jul 1500	6	0.0	6.0	0.93
@099-13-2F-578-1B06-L/D	1	1.8	Jul 1000	143	0.2	16.7	8.58
@100-13-2F-578-1B06-Kit	1	0.7	Jul 1500	54	0.0	11.3	4.82
@101-13-2F-578-1B06-Cor	1	0.2	Jul 1500	12	0.0	3.8	3.19
@102-13-2F-578-1B06-Pow	1	0.2	Jul 1500	14	0.0	3.1	4.62

Zone Sizing Summary for @103-109-14-2F-8F-1B05-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@103-109-14-2F-8F-1B05-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.1	5.4	23.5 / 16.6	13.2 / 12.2	0.16	Sep 1400	7.33

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	436	0.055	0.044	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.5	Oct 1400	0.6	59.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@103-14-2F-578-1B05-BedR	1	1.8	Oct 1400	144	0.2	15.5	9.32
@104-14-2F-578-1B05-Dres	1	0.0	Jul 1500	4	0.0	3.4	1.10
@105-14-2F-578-1B05-Bath	1	0.1	Jul 1500	5	0.0	5.6	0.93
@106-14-2F-578-1B05-L/D	1	2.5	Oct 1400	201	0.3	17.0	11.84
@107-14-2F-578-1B05-Kit	1	0.5	Jul 1500	41	0.0	7.8	5.24
@108-14-2F-578-1B05-Cor	1	0.3	Jul 1500	27	0.0	7.5	3.57
@109-14-2F-578-1B05-Pow	1	0.2	Jul 1500	14	0.0	2.7	5.16

Zone Sizing Summary for @110-112-15-2F-8F-3B04-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@110-112-15-2F-8F-3B04-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.6	2.3	23.5 / 16.4	13.1 / 12.1	0.07	Aug 1600	6.26

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	187	0.024	0.019	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.4	Sep 1600	0.2	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@110-15-2F-578-3B04-MBed	1	2.0	Sep 1600	161	0.2	15.2	10.62
@111-15-2F-578-3B04-Dres	1	0.1	Jul 1500	5	0.0	4.5	1.10
@112-15-2F-578-3B04-MBat	1	0.3	Jul 1500	21	0.0	10.2	2.05

Zone Sizing Summary for @113-117-15-2F-8F-3B04-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@113-117-15-2F-8F-3B04-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.1	2.8	23.5 / 16.5	13.0 / 12.0	0.08	Jul 1700	5.67

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	224	0.028	0.022	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.8	Aug 1600	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@113-15-2F-578-3B04-BdR2	1	1.8	Jul 1700	139	0.2	11.9	11.69
@114-15-2F-578-3B04-Cor	1	0.6	Jul 1500	44	0.0	16.0	2.75
@115-15-2F-578-3B04-MIR	1	0.4	Jul 1500	35	0.0	5.6	6.26
@116-15-2F-578-3B04-MIB	1	0.0	Jul 1500	3	0.0	2.8	0.93
@117-15-2F-578-3B04-Pow	1	0.0	Jul 1500	3	0.0	3.2	0.93

Zone Sizing Summary for @118-119-15-2F-8F-3B04-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@118-119-15-2F-8F-3B04-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **16.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.0	1.8	23.5 / 16.4	13.0 / 11.9	0.05	Jul 1700	8.81

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	141	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.8	Jul 1700	0.1	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@118-15-2F-578-3B04-Bed1	1	1.6	Jul 1700	123	0.1	11.6	10.59
@119-15-2F-578-3B04-Bat1	1	0.2	Jul 1500	18	0.0	4.4	4.13

Zone Sizing Summary for @120-121-15-2F-8F-3B04-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@120-121-15-2F-8F-3B04-FCU4**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **35.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.0	5.2	23.5 / 16.6	13.1 / 12.1	0.16	Oct 1600	11.80

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	418	0.053	0.042	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.3	Oct 1500	0.6	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@120-15-2F-578-3B04-Kit	1	0.9	Aug 1500	75	0.1	11.7	6.38
@121-15-2F-578-3B04-L/D	1	4.3	Oct 1500	343	0.5	23.7	14.48

Zone Sizing Summary for @122-124-16-2F-8F-3B03-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@122-124-16-2F-8F-3B03-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.4	2.2	23.7 / 16.8	13.6 / 12.7	0.06	Sep 1600	6.04

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	181	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Sep 1600	0.2	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@122-16-2F-578-3B03-MBed	1	2.0	Sep 1600	155	0.2	15.2	10.19
@123-16-2F-578-3B03-Dres	1	0.1	Jul 1500	5	0.0	4.5	1.10
@124-16-2F-578-3B03-MBat	1	0.3	Jul 1500	21	0.0	10.2	2.05

Zone Sizing Summary for @125-129-16-2F-8F-3B03-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:45PM

Air System Information

Air System Name **@125-129-16-2F-8F-3B03-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.0	2.7	23.7 / 16.9	13.6 / 12.7	0.08	Aug 1600	5.54

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	219	0.028	0.022	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.8	Aug 1600	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@125-16-2F-578-3B03-Bed2	1	1.7	Jul 1700	134	0.2	11.9	11.26
@126-16-2F-578-3B03-Cor	1	0.6	Jul 1500	44	0.0	16.0	2.75
@127-16-2F-578-3B03-MIR	1	0.4	Jul 1500	35	0.0	5.6	6.26
@128-16-2F-578-3B03-MIB	1	0.0	Jul 1500	3	0.0	2.8	0.93
@129-16-2F-578-3B03-Pow	1	0.0	Jul 1500	3	0.0	3.2	0.93

Zone Sizing Summary for @130-131-16-2F-8F-3B03-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **@130-131-16-2F-8F-3B03-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **16.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.0	1.8	23.5 / 16.4	13.0 / 11.9	0.05	Jul 1700	8.81

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	141	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.8	Jul 1700	0.1	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@130-16-2F-578-3B03-Bed1	1	1.6	Jul 1700	123	0.1	11.6	10.59
@131-16-2F-578-3B03-Bat1	1	0.2	Jul 1500	18	0.0	4.4	4.13

Zone Sizing Summary for @132-133-16-2F-8F-3B03-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **@132-133-16-2F-8F-3B03-FCU4**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **35.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.8	4.1	23.5 / 16.8	13.0 / 12.1	0.13	Sep 1600	9.11

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	323	0.041	0.032	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.1	Jul 1700	0.3	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@132-16-2F-578-3B03-Kit	1	0.7	Jul 1500	57	0.0	11.7	4.84
@133-16-2F-578-3B03-L/D	1	3.4	Jul 1700	266	0.3	23.7	11.22

Zone Sizing Summary for @134-136-17-2F-8F-2B02-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **@134-136-17-2F-8F-2B02-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.1	1.9	23.5 / 16.5	13.1 / 12.2	0.06	Aug 1700	6.22

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	154	0.019	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.9	Jul 1700	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@134-17-2F-578-2B02-MBed	1	1.7	Jul 1700	132	0.2	14.4	9.16
@135-17-2F-578-2B02-Dres	1	0.0	Jul 1500	3	0.0	2.7	1.10
@136-17-2F-578-2B02-MBat	1	0.2	Jul 1500	19	0.0	7.7	2.53

Zone Sizing Summary for @137-17-2F-8F-2B02-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name .. @137-17-2F-8F-2B02-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.8	1.6	23.5 / 16.4	13.0 / 12.0	0.05	Jul 1700	9.60

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	126	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.6	Jul 1700	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@137-17-2F-578-2B02-Bed1	1	1.6	Jul 1700	126	0.1	13.1	9.60

Zone Sizing Summary for @138-141-17-2F-8F-2B02-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **@138-141-17-2F-8F-2B02-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.3	3.7	23.5 / 16.7	12.9 / 11.9	0.12	Jul 1700	6.71

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	289	0.036	0.029	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.6	Aug 1600	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@138-17-2F-578-2B02-Cor	1	0.5	Jul 1500	42	0.0	9.8	4.33
@139-17-2F-578-2B02-Bat1	1	0.1	Jul 1500	10	0.0	4.4	2.33
@140-17-2F-578-2B02-Kit	1	0.7	Jul 1500	53	0.0	8.5	6.25
@141-17-2F-578-2B02-L/D	1	2.3	Jul 1700	183	0.2	20.4	8.99

Zone Sizing Summary for @142-144-18-2F-8F-2B01-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **@142-144-18-2F-8F-2B01-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.1	1.9	23.5 / 16.5	13.1 / 12.2	0.06	Aug 1700	6.22

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	154	0.019	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.9	Jul 1700	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@142-18-2F-578-2B01-MBed	1	1.7	Jul 1700	132	0.2	14.4	9.16
@143-18-2F-578-2B01-Dres	1	0.0	Jul 1500	3	0.0	2.7	1.10
@144-18-2F-578-2B01-MBa	1	0.2	Jul 1500	19	0.0	7.7	2.53

Zone Sizing Summary for @145-18-2F-8F-2B01-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name .. @145-18-2F-8F-2B01-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.8	1.6	23.5 / 16.4	13.0 / 12.0	0.05	Jul 1700	9.60

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	126	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.6	Jul 1700	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
@145-18-2F-578-2B01-Bed1	1	1.6	Jul 1700	126	0.1	13.1	9.60

Zone Sizing Summary for @146-149-18-2F-8F-2B01-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **@146-149-18-2F-8F-2B01-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **44.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.1	4.4	23.5 / 16.7	13.1 / 12.2	0.13	Aug 1600	7.99

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	351	0.044	0.035	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.4	Aug 1600	0.2	44.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
@146-18-2F-578-2B01-Cor	1	0.5	Jul 1500	42	0.0	9.8	4.33
@147-18-2F-578-2B01-Bat1	1	0.1	Jul 1500	10	0.0	4.4	2.33
@148-18-2F-578-2B01-Kit	1	1.0	Jul 1500	76	0.0	8.9	8.59
@149-18-2F-578-2B01-L/D	1	2.8	Aug 1600	222	0.2	20.9	10.63

Zone Sizing Summary for ^053-055-8-2F-8F-2B11-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^053-055-8-2F-8F-2B11-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 25.8 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.6	1.4	23.7 / 16.9	13.5 / 12.5	0.04	Jun 1700	4.33

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	112	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.4	Jun 1700	0.2	25.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^053-8-6F-2B11-MBED	1	1.3	Jun 1700	101	0.2	14.8	6.80
^054-8-6F-2B11-DRESS	1	0.0	Jul 1500	3	0.0	2.6	1.14
^055-8-6F-2B11-MBATH	1	0.1	Jul 1500	8	0.0	8.4	0.96

Zone Sizing Summary for ^056-8-2F-8F-2B11-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^056-8-2F-8F-2B11-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.3 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.3	1.1	23.4 / 16.5	12.8 / 11.8	0.03	Jun 1700	6.53

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	87	0.011	0.009	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.1	Jun 1700	0.1	13.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^056-8-6F-2B11-BED1	1	1.1	Jun 1700	87	0.1	13.3	6.53

Zone Sizing Summary for ^057-060-8-2F-8F-2B11-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^057-060-8-2F-8F-2B11-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 43.5 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	4.3	3.7	23.5 / 16.8	13.0 / 12.1	0.12	Jul 1500	6.70

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	292	0.037	0.029	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	3.7	Jul 1500	0.3	43.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^057-8-6F-2B11-BATH1	1	0.1	Jul 1500	10	0.0	4.4	2.36
^058-8-6F-2B11-COR	1	0.5	Jul 1500	42	0.0	9.7	4.31
^059-8-6F-2B11-KIT	1	0.9	Aug 1500	74	0.1	9.0	8.26
^060-8-6F-2B11-LV/DN	1	2.1	Jul 1000	165	0.2	20.4	8.09

Zone Sizing Summary for ^061-063-9-2F-8F-3B10-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^061-063-9-2F-8F-3B10-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 29.7 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.2	2.0	23.7 / 16.9	13.6 / 12.6	0.06	Jul 1400	5.45

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	162	0.020	0.016	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.0	Jul 1400	0.2	29.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^061-9-6F-3B10-MBED	1	1.7	Jul 1000	136	0.2	15.0	9.04
^062-9-6F-3B10-DRESS	1	0.1	Jul 1500	5	0.0	4.5	1.14
^063-9-6F-3B10-MBATH	1	0.3	Jul 1500	21	0.0	10.2	2.08

Zone Sizing Summary for ^064-068-9-2F-8F-3B10-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^064-068-9-2F-8F-3B10-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 39.5 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.8	2.5	23.7 / 17.1	13.9 / 12.9	0.07	Jul 1500	5.26

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	208	0.026	0.021	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.6	Jul 1500	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^064-9-6F-3B10-BED	1	1.5	Jul 1000	117	0.2	11.9	9.79
^065-9-6F-3B10-COR	1	0.6	Jul 1500	44	0.0	16.0	2.73
^066-9-6F-3B10-MADRM	1	0.5	Jul 1600	42	0.0	5.6	7.49
^067-9-6F-3B10-MAIDRM	1	0.0	Jul 1500	3	0.0	2.8	0.96
^068-9-6F-3B10-POWD	1	0.0	Jul 1500	3	0.0	3.2	0.96

Zone Sizing Summary for ^069-070-9-2F-8F-3B10-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^069-070-9-2F-8F-3B10-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 15.9 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.7	1.6	23.4 / 16.5	13.0 / 12.1	0.05	Jul 1000	7.86

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	125	0.016	0.012	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.5	Jul 1000	0.1	15.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^069-9-6F-3B10-BED1	1	1.4	Jul 1000	107	0.1	11.6	9.20
^070-9-6F-3B10-BATH1	1	0.2	Jul 1500	18	0.0	4.3	4.24

Zone Sizing Summary for ^071-072-9-2F-8F-3B10-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^071-072-9-2F-8F-3B10-FCU4
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 36.2 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	4.1	3.4	23.5 / 17.0	13.1 / 12.2	0.11	Jun 0900	7.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	269	0.034	0.027	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	3.4	Jul 1000	0.3	36.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^071-9-6F-3B10-KIT	1	0.9	Jul 1500	67	0.1	12.1	5.58
^072-9-6F-3B10-LV/DN	1	2.5	Jul 1000	201	0.3	24.1	8.36

Zone Sizing Summary for ^073-075-10-2F-8F-2B09-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^073-075-10-2F-8F-2B09-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 25.0 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.8	1.6	23.7 / 16.9	13.5 / 12.6	0.05	Jul 1000	5.09

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	127	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.6	Jul 1000	0.2	25.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^073-10-6F-2B09-MBR	1	1.5	Jul 1000	117	0.2	14.3	8.15
^074-10-6F-2B09-DRESS	1	0.0	Jul 1500	3	0.0	2.7	1.14
^075-10-6F-2B09-MBATH	1	0.1	Jul 1500	8	0.0	8.0	0.96

Zone Sizing Summary for ^076-10-2F-8F-2B09-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^076-10-2F-8F-2B09-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.6	1.4	23.5 / 16.5	12.9 / 12.0	0.04	Jul 1000	8.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	110	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.4	Jul 1000	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^076-10-6F-2B09-BED1	1	1.4	Jul 1000	110	0.1	13.1	8.43

Zone Sizing Summary for ^077-080-10-2F-8F-2B09-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^077-080-10-2F-8F-2B09-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 43.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	3.9	3.3	23.6 / 17.1	13.5 / 12.6	0.10	Aug 1000	6.28

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	271	0.034	0.027	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	3.3	Jul 1400	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^077-10-6F-2B09-BAT1	1	0.1	Jul 1500	10	0.0	4.4	2.36
^078-10-6F-2B09-COR	1	0.5	Jul 1500	43	0.0	9.8	4.37
^079-10-6F-2B09-KIT	1	0.7	Jul 1500	53	0.0	8.5	6.28
^080-10-6F-2B09-LIV/DN	1	2.1	Jul 1000	164	0.2	20.4	8.04

Zone Sizing Summary for ^081-087-11-2F-8F-1B08-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^081-087-11-2F-8F-1B08-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 53.3 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	5.3	4.6	23.5 / 16.7	13.1 / 12.1	0.14	Jul 1500	6.89

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	367	0.046	0.037	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	4.6	Jul 1000	0.4	53.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^081-11-6F-1B08-BEDRM	1	1.8	Jul 1000	139	0.2	15.3	9.06
^083-11-6F-1B08-DRESS	1	0.0	Jul 1500	4	0.0	3.1	1.14
^084-11-6F-1B08-LIV/DN	1	1.8	Jul 1000	144	0.2	16.7	8.61
^085-11-6F-1B08-KIT	1	0.7	Jul 1500	55	0.0	11.3	4.85
^086-11-6F-1B08-COR	1	0.2	Jul 1500	12	0.0	3.8	3.22
^087-11-6F-1B08-POW	1	0.2	Jul 1500	14	0.0	3.1	4.65

Zone Sizing Summary for ^088-090-12-2F-8F-2B07-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^088-090-12-2F-8F-2B07-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 25.8 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.9	1.7	23.7 / 16.9	13.7 / 12.7	0.05	Aug 1000	5.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	140	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.7	Jul 1000	0.2	25.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^088-12-6F-2B07-MBEDR	1	1.6	Jul 1000	123	0.2	14.7	8.36
^089-12-6F-2B07-DRESS	1	0.0	Jul 1500	3	0.0	2.7	1.14
^090-12-6F-2B07-MBAT	1	0.2	Jul 1500	14	0.0	8.4	1.70

Zone Sizing Summary for ^091-12-2F-8F-2B07-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^091-12-2F-8F-2B07-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.6	1.4	23.5 / 16.5	12.9 / 12.0	0.04	Jul 1000	8.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	110	0.014	0.011	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.4	Jul 1000	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^091-12-6F-2B07-BEDR1	1	1.4	Jul 1000	110	0.1	13.1	8.43

Zone Sizing Summary for ^092-095-12-2F-8F-2B07-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^092-095-12-2F-8F-2B07-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 43.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	4.0	3.4	23.5 / 17.0	13.4 / 12.5	0.11	Aug 1200	6.41

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	276	0.035	0.028	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	3.4	Jul 1400	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^092-12-6F-2B07-BAT1	1	0.1	Jul 1500	10	0.0	4.4	2.36
^093-12-6F-2B07-COR	1	0.5	Jul 1500	43	0.0	9.8	4.37
^094-12-6F-2B07-KIT	1	0.7	Jul 1500	53	0.0	8.5	6.28
^095-12-6F-2B07-LIV/DN	1	2.1	Jul 1000	170	0.2	20.4	8.32

Zone Sizing Summary for ^096-102-13-2F-8F-1B06-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^096-102-13-2F-8F-1B06-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 60.0 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	5.5	4.8	23.5 / 16.8	13.3 / 12.4	0.15	Jul 1500	6.55

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	393	0.050	0.039	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	4.8	Aug 1400	0.4	60.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^096-13-6F-1B06-BEDR	1	2.0	Oct 1400	159	0.2	15.9	9.97
^097-13-6F-1B06-DRESS	1	0.0	Jul 1500	4	0.0	3.2	1.14
^098-13-6F-1B06-BATH	1	0.1	Jul 1500	6	0.0	6.0	0.96
^099-13-6F-1B06-LIV/DN	1	1.8	Jul 1000	144	0.2	16.7	8.61
^100-13-6F-1B06-KIT	1	0.7	Jul 1500	55	0.0	11.3	4.85
^101-13-6F-1B06-COR	1	0.2	Jul 1500	12	0.0	3.8	3.22
^102-13-6F-1B06-POW	1	0.2	Jul 1500	14	0.0	3.1	4.65

Zone Sizing Summary for ^103-109-14-2F-8F-1B05-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^103-109-14-2F-8F-1B05-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 59.5 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	6.2	5.5	23.5 / 16.7	13.2 / 12.2	0.16	Sep 1400	7.36

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	438	0.055	0.044	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	5.5	Oct 1400	0.6	59.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^103-14-6F-1B05-BEDRM	1	1.8	Oct 1400	145	0.2	15.5	9.35
^104-14-6F-1B05-DRESS	1	0.0	Jul 1500	4	0.0	3.4	1.14
^105-14-6F-1B05-BATH	1	0.1	Jul 1500	5	0.0	5.6	0.96
^106-14-6F-1B05-LIV/DN	1	2.6	Oct 1400	202	0.3	17.0	11.87
^107-14-6F-1B05-KIT	1	0.5	Jul 1500	41	0.0	7.8	5.28
^108-14-6F-1B05-COR	1	0.3	Jul 1500	27	0.0	7.5	3.60
^109-14-6F-1B05-POWD	1	0.2	Jul 1500	14	0.0	2.7	5.20

Zone Sizing Summary for ^110-112-15-2F-8F-3B04-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^110-112-15-2F-8F-3B04-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 29.9 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.6	2.3	23.6 / 16.6	13.3 / 12.3	0.07	Sep 1600	6.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	188	0.024	0.019	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.4	Sep 1600	0.2	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^110-15-2F-6F-3B04-MBED	1	2.0	Sep 1600	162	0.2	15.2	10.65
^111-15-6F-3B04-DRESS	1	0.1	Jul 1500	5	0.0	4.5	1.14
^112-15-6F-3B04-MBAT	1	0.3	Jul 1500	21	0.0	10.2	2.08

Zone Sizing Summary for ^113-117-15-2F-8F-3B04-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^113-117-15-2F-8F-3B04-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 39.5 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	3.1	2.8	23.6 / 16.7	13.4 / 12.4	0.08	Aug 1600	5.70

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	225	0.028	0.023	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.8	Aug 1600	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^113-15-6F-3B04-BEDR2	1	1.8	Jul 1700	140	0.2	11.9	11.72
^114-15-6F-3B04-COR	1	0.6	Jul 1500	45	0.0	16.0	2.79
^115-15-6F-3B04-MIR	1	0.4	Jul 1500	35	0.0	5.6	6.30
^116-15-6F-3B04-MIB	1	0.0	Jul 1500	3	0.0	2.8	0.96
^117-15-6F-3B04-POWD	1	0.0	Jul 1500	3	0.0	3.2	0.96

Zone Sizing Summary for ^118-119-15-2F-8F-3B04-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^118-119-15-2F-8F-3B04-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 16.0 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.0	1.8	23.5 / 16.4	13.0 / 12.0	0.05	Jul 1700	8.84

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	141	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.8	Jul 1700	0.1	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^118-15-6F-3B04-BEDR1	1	1.6	Jul 1700	123	0.1	11.6	10.62
^119-15-6F-3B04-BAT1	1	0.2	Jul 1500	18	0.0	4.4	4.16

Zone Sizing Summary for ^120-121-15-2F-8F-3B04-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^120-121-15-2F-8F-3B04-FCU4
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 35.4 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	6.0	5.3	23.5 / 16.6	13.0 / 12.0	0.16	Oct 1500	11.83

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	419	0.053	0.042	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	5.3	Oct 1500	0.6	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^120-15-6F-3B04-KIT	1	0.9	Aug 1500	75	0.1	11.7	6.41
^121-15-6F-3B04-L/D	1	4.4	Oct 1500	344	0.5	23.7	14.51

Zone Sizing Summary for ^122-124-16-2F-8F-3B03-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^122-124-16-2F-8F-3B03-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 29.9 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.5	2.2	23.6 / 16.6	13.4 / 12.4	0.07	Sep 1600	6.08

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	182	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.3	Sep 1600	0.2	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^122-16-6F-3B03-MBED	1	2.0	Sep 1600	155	0.2	15.2	10.22
^123-16-6F-3B03-DRES	1	0.1	Jul 1500	5	0.0	4.5	1.14
^124-16-6F-3B03-MBATH	1	0.3	Jul 1500	21	0.0	10.2	2.08

Zone Sizing Summary for ^125-129-16-2F-8F-3B03-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^125-129-16-2F-8F-3B03-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 39.5 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	3.1	2.8	23.5 / 16.6	13.1 / 12.1	0.08	Jul 1700	5.57

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	220	0.028	0.022	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.8	Aug 1600	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^125-16-6F-3B03-BED2	1	1.7	Jul 1700	134	0.2	11.9	11.29
^126-16-6F-3B03-COR	1	0.6	Jul 1500	45	0.0	16.0	2.79
^127-16-6F-3B03-MIR	1	0.4	Jul 1500	35	0.0	5.6	6.30
^128-16-6F-3B03-MIB	1	0.0	Jul 1500	3	0.0	2.8	0.96
^129-16-6F-3B03-POW	1	0.0	Jul 1500	3	0.0	3.2	0.96

Zone Sizing Summary for ^130-131-16-2F-8F-3B03-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^130-131-16-2F-8F-3B03-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 16.0 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.0	1.8	23.5 / 16.4	13.0 / 12.0	0.05	Jul 1700	8.84

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	141	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.8	Jul 1700	0.1	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^130-16-6F-3B03-BED1	1	1.6	Jul 1700	123	0.1	11.6	10.62
^131-16-6F-3B03-BAT1	1	0.2	Jul 1500	18	0.0	4.4	4.16

Zone Sizing Summary for ^132-133-16-2F-8F-3B03-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^132-133-16-2F-8F-3B03-FCU4
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 35.4 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	4.9	4.1	23.5 / 16.8	12.9 / 12.0	0.13	Jun 1700	9.14

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	324	0.041	0.032	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	4.1	Jul 1700	0.3	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^132-16-6F-3B03-KIT	1	0.7	Jul 1500	57	0.0	11.7	4.87
^133-16-6F-3B03-LIV/DN	1	3.4	Jul 1700	267	0.3	23.7	11.25

Zone Sizing Summary for ^134-136-17-2F-8F-2B02-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^134-136-17-2F-8F-2B02-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 24.8 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.2	2.0	23.5 / 16.5	13.0 / 12.0	0.06	Jul 1700	6.26

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	155	0.020	0.016	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.0	Jul 1700	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^134-17-6F-2B02-MBED	1	1.7	Jul 1700	132	0.2	14.4	9.19
^135-17-6F-2B02-DRES	1	0.0	Jul 1500	3	0.0	2.7	1.14
^136-17-6F-2B02-MBATH	1	0.2	Jul 1500	20	0.0	7.7	2.56

Zone Sizing Summary for ^137-17-2F-8F-2B02-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^137-17-2F-8F-2B02-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.8	1.6	23.5 / 16.5	13.0 / 12.0	0.05	Jun 1700	9.63

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	126	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.6	Jul 1700	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^137-17-6F-2B02-BED1	1	1.6	Jul 1700	126	0.1	13.1	9.63

Zone Sizing Summary for ^138-141-17-2F-8F-2B02-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^138-141-17-2F-8F-2B02-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 43.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	4.3	3.6	23.6 / 17.0	13.3 / 12.4	0.11	Jul 1600	6.74

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	291	0.037	0.029	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	3.7	Aug 1600	0.2	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^138-17-6F-2B02-COR	1	0.5	Jul 1500	43	0.0	9.8	4.37
^139-17-6F-2B02-BAT1	1	0.1	Jul 1500	10	0.0	4.4	2.36
^140-17-6F-2B02-KIT	1	0.7	Jul 1500	53	0.0	8.5	6.28
^141-17-6F-2B02-LIV/DN	1	2.3	Jul 1700	184	0.2	20.4	9.02

Zone Sizing Summary for ^142-144-18-2F-8F-2B01-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^142-144-18-2F-8F-2B01-FCU1
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 24.8 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	2.2	2.0	23.5 / 16.5	13.0 / 12.0	0.06	Jul 1700	6.26

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	155	0.020	0.016	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	2.0	Jul 1700	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^142-18-6F-2B01-MBED	1	1.7	Jul 1700	132	0.2	14.4	9.19
^143-18-6F-2B01-DRESS	1	0.0	Jul 1500	3	0.0	2.7	1.14
^144-18-6F-2B01-MBAT	1	0.2	Jul 1500	20	0.0	7.7	2.56

Zone Sizing Summary for ^145-18-2F-8F-2B01-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^145-18-2F-8F-2B01-FCU2
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 13.1 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	1.8	1.6	23.5 / 16.5	13.0 / 12.0	0.05	Jun 1700	9.63

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	126	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	1.6	Jul 1700	0.1	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^145-18-6F-2B01-BED1	1	1.6	Jul 1700	126	0.1	13.1	9.63

Zone Sizing Summary for ^146-149-18-2F-8F-2B01-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name ^146-149-18-2F-8F-2B01-FCU3
Equipment Class TERM
Air System Type 2P-FC

Number of zones 1
Floor Area 44.0 m²
Location Dubai, United Arab Emirates

Sizing Calculation Information

Calculation Months Jan to Dec
Sizing Data Calculated

Zone L/s Sizing Sum of space airflow rates
Space L/s Sizing Individual peak space loads

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m ²)
Zone 1	5.0	4.4	23.5 / 16.7	13.2 / 12.2	0.13	Sep 1600	8.02

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	353	0.044	0.035	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m ²)
Zone 1	4.5	Aug 1600	0.2	44.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m ²)	Space L/(s·m ²)
Zone 1							
^146-18-6F-2B01-COR	1	0.5	Jul 1500	43	0.0	9.8	4.37
^147-18-6F-2B01-BAT1	1	0.1	Jul 1500	10	0.0	4.4	2.36
^148-18-6F-2B01-KIT	1	1.0	Jul 1500	77	0.0	8.9	8.62
^149-18-6F-2B01-LIV/DN	1	2.8	Aug 1600	223	0.2	20.9	10.67

Zone Sizing Summary for 001-003-1-6F-2B13-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **001-003-1-6F-2B13-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.8	1.6	23.6 / 16.8	13.3 / 12.4	0.05	Jun 1700	4.92

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	127	0.016	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.6	Jun 1700	0.2	25.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
001-1-RF-2B13-M.Bed	1	1.4	Jun 1700	108	0.2	15.3	7.05
002-1-RF-2B13-Dress	1	0.1	Jul 1900	5	0.0	2.6	1.98
003-1-RF-2B13-M BAT	1	0.2	Jul 1900	14	0.0	8.0	1.80

Zone Sizing Summary for 004-1-6F-2B13-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **004-1-6F-2B13-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.4	1.2	23.5 / 16.6	13.0 / 12.1	0.04	Jun 1700	7.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	99	0.012	0.010	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.2	Jun 1700	0.2	13.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
004-1-RF-2B13-Bed-1	1	1.2	Jun 1700	99	0.2	13.5	7.30

Zone Sizing Summary for 005-008-1-6F-2B13-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **005-008-1-6F-2B13-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **42.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.6	4.9	23.4 / 16.5	12.9 / 11.9	0.15	Jun 1700	9.15

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	389	0.049	0.039	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.9	Jun 1700	0.6	42.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
005-1-RF-2B13-Corri	1	0.6	Jul 1600	50	0.0	9.4	5.27
006-1-RF-2B13-Bath1	1	0.2	Jul 1700	13	0.0	4.1	3.24
007-1-RF-2B13-Kitch	1	1.0	Aug 1700	78	0.1	8.5	9.22
008-1-RF-2B13-LV/DN	1	3.1	Jun 1700	248	0.4	20.5	12.09

Zone Sizing Summary for 009-015-2-6F-1B12-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **009-015-2-6F-1B12-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.8	5.1	23.5 / 16.6	13.0 / 12.0	0.15	Jun 1700	6.73

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	399	0.050	0.040	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.0	Jun 1700	0.6	59.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
009-2-RF-1B12-Bedro	1	1.8	Jun 1700	144	0.3	15.2	9.46
010-2-RF-1B12-Dress	1	0.1	Jul 1900	6	0.0	3.1	1.98
011-2-RF-1B12-Bath	1	0.1	Jul 1900	10	0.0	5.6	1.80
012-2-RF-1B12-LV/DN	1	1.7	Jun 1700	136	0.2	17.2	7.88
013-2-RF-1B12-Kitch	1	0.9	Jul 1700	71	0.0	11.3	6.25
014-2-RF-1B12-Corri	1	0.2	Jul 1600	15	0.0	3.8	3.99
015-2-RF-1B12-Power	1	0.2	Jul 1600	18	0.0	3.1	5.70

Zone Sizing Summary for 016-022-3-6F-1B11-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **016-022-3-6F-1B11-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.4	4.7	23.7 / 16.9	13.5 / 12.5	0.14	Jun 1700	6.58

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	384	0.048	0.038	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.8	Jun 1700	0.6	58.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
016-3-RF-1B11-Bedro	1	1.8	Jun 1700	144	0.3	15.2	9.46
017-3-RF-1B11-Dress	1	0.1	Jul 1900	6	0.0	3.1	1.98
018-3-RF-1B11-Bathr	1	0.1	Jul 1900	10	0.0	5.6	1.80
019-3-RF-1B11-LV/DN	1	1.6	Jun 1700	127	0.2	16.7	7.63
020-3-RF-1B11-Kitch	1	0.8	Jul 1700	64	0.0	10.9	5.86
021-3-RF-1B11-Corri	1	0.2	Jul 1600	15	0.0	3.8	3.99
022-3-RF-1B11-Power	1	0.2	Jul 1600	18	0.0	3.1	5.70

Zone Sizing Summary for 023-029-4-6F-1B10-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **023-029-4-6F-1B10-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.6	4.9	23.6 / 16.8	13.3 / 12.4	0.15	Jun 1700	6.64

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	395	0.050	0.039	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.0	Jun 1700	0.6	59.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
023-4-RF-1B10-Bedro	1	1.9	Jun 1700	153	0.3	15.3	9.97
024-4-RF-1B10-Dress	1	0.1	Jul 1900	6	0.0	3.1	1.98
025-4-RF-1B10-Bathr	1	0.2	Jul 2000	13	0.0	5.6	2.28
026-4-RF-1B10-LV/DN	1	1.6	Jun 1700	126	0.2	16.7	7.52
027-4-RF-1B10-Kitch	1	0.8	Jul 1700	65	0.0	11.9	5.46
028-4-RF-1B10-Corri	1	0.2	Jul 1600	15	0.0	3.8	3.99
029-4-RF-1B10-Power	1	0.2	Jul 1600	18	0.0	3.1	5.70

Zone Sizing Summary for 030-032-5-6F-2B14-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **030-032-5-6F-2B14-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.2	2.0	23.6 / 16.8	13.6 / 12.6	0.06	Nov 1400	6.69

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	165	0.021	0.017	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.0	Nov 1400	0.2	24.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
030-5-RF-2B14-M.Bed	1	1.8	Nov 1400	146	0.2	14.2	10.27
031-5-RF-2B14-Dress	1	0.1	Jul 1900	5	0.0	2.6	1.98
032-5-RF-2B14-M BAT	1	0.2	Jul 1900	14	0.0	7.9	1.80

Zone Sizing Summary for 033-5-6F-2B14-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **033-5-6F-2B14-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.9	1.8	23.5 / 16.3	12.9 / 11.9	0.05	Nov 1400	10.67

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	141	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.8	Nov 1400	0.2	13.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
033-5-RF-2B14-Bed-1	1	1.8	Nov 1400	141	0.2	13.2	10.67

Zone Sizing Summary for 034-037-5-6F-2B14-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **034-037-5-6F-2B14-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.6	5.0	23.6 / 16.8	13.5 / 12.6	0.15	Oct 1500	9.50

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	412	0.052	0.041	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.1	Oct 1500	0.5	43.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
034-5-RF-2B14-Corri	1	0.7	Jul 1600	52	0.0	9.7	5.34
035-5-RF-2B14-Bath1	1	0.2	Jul 1700	14	0.0	4.4	3.14
036-5-RF-2B14-Kitch	1	0.9	Jul 1700	71	0.1	8.5	8.35
037-5-RF-2B14-LV/DN	1	3.5	Oct 1500	276	0.4	20.8	13.25

Zone Sizing Summary for 038-044-6-6F-1B15-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **038-044-6-6F-1B15-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.6	5.9	23.5 / 16.6	13.3 / 12.3	0.18	Nov 1400	8.30

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	485	0.061	0.048	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.9	Nov 1500	0.6	58.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
038-6-RF-1B15-Bedro	1	2.4	Nov 1500	190	0.3	15.2	12.48
039-6-RF-1B15-Dress	1	0.1	Jul 1900	6	0.0	3.1	1.98
040-6-RF-1B15-Bathr	1	0.1	Jul 1900	10	0.0	5.6	1.80
041-6-RF-1B15-LV/DN	1	2.4	Nov 1400	191	0.2	16.7	11.46
042-6-RF-1B15-Kitch	1	0.7	Jul 1900	54	0.0	10.9	4.94
043-6-RF-1B15-Corri	1	0.2	Jul 1600	16	0.0	3.8	4.22
044-6-RF-1B15-Power	1	0.2	Jul 1600	18	0.0	3.1	5.70

Zone Sizing Summary for 045-047-7-6F-2B17-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **045-047-7-6F-2B17-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.4	2.2	23.5 / 16.7	13.7 / 12.7	0.06	Oct 1500	7.50

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	185	0.023	0.019	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.2	Nov 1400	0.3	24.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
045-7-RF-2B17-M.Bed	1	1.9	Nov 1400	153	0.3	14.2	10.74
046-7-RF-2B17-Dress	1	0.1	Jul 1900	5	0.0	2.6	1.98
047-7-RF-2B17-M BAT	1	0.3	Jul 2100	28	0.1	7.9	3.49

Zone Sizing Summary for 048-7-6F-2B17-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **048-7-6F-2B17-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.9	1.8	23.5 / 16.3	13.0 / 11.9	0.05	Dec 1400	10.65

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	141	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.8	Nov 1400	0.2	13.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
048-7-RF-2B17-Bed-1	1	1.8	Nov 1400	141	0.2	13.2	10.65

Zone Sizing Summary for 049-052-7-6F-2B17-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **049-052-7-6F-2B17-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.5	3.9	23.4 / 16.9	13.5 / 12.5	0.12	Nov 1400	7.52

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	326	0.041	0.033	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.9	Nov 1400	0.3	43.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
049-7-RF-2B17-Corri	1	0.6	Jul 1600	50	0.0	10.0	4.98
050-7-RF-2B17-Bath1	1	0.2	Jul 1700	13	0.0	4.4	2.95
051-7-RF-2B17-Kitch	1	0.8	Jul 1700	61	0.0	8.4	7.23
052-7-RF-2B17-LV/DN	1	2.6	Nov 1400	203	0.2	20.6	9.85

Zone Sizing Summary for 053-055-8-9F-2B11-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **053-055-8-9F-2B11-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.8	1.6	23.7 / 16.9	13.5 / 12.6	0.05	Jun 1700	5.16

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	133	0.017	0.013	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.7	Jun 1700	0.2	25.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
053-8-RF-2B11-M.Bed	1	1.4	Jun 1700	113	0.2	14.8	7.63
054-8-RF-2B11-Dress	1	0.1	Jul 1900	5	0.0	2.6	1.98
055-8-RF-2B11-M BAT	1	0.2	Jul 1900	15	0.0	8.4	1.80

Zone Sizing Summary for 056-8-9F-2B11-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **056-8-9F-2B11-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.4	1.2	23.5 / 16.6	13.1 / 12.1	0.04	Jun 1600	7.35

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	98	0.012	0.010	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.2	Jun 1700	0.2	13.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
056-8-RF-2B11-Bed-1	1	1.2	Jun 1700	98	0.2	13.3	7.35

Zone Sizing Summary for 057-060-8-9F-2B11-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:46PM

Air System Information

Air System Name **057-060-8-9F-2B11-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.7	4.1	23.5 / 16.7	13.1 / 12.1	0.13	Jul 1400	7.40

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	322	0.041	0.032	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.1	Jul 1500	0.5	43.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
057-8-RF-2B11-Corri	1	0.6	Jul 1600	49	0.0	9.7	5.07
058-8-RF-2B11-Bath1	1	0.2	Jul 1700	14	0.0	4.4	3.14
059-8-RF-2B11-Kitch	1	1.0	Aug 1800	82	0.1	9.0	9.06
060-8-RF-2B11-LV/DN	1	2.2	Jul 1500	177	0.3	20.4	8.69

Zone Sizing Summary for 061-063-9-9F-3B10-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **061-063-9-9F-3B10-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.5	2.2	23.7 / 16.8	13.5 / 12.5	0.07	Jul 1500	6.16

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	183	0.023	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.3	Jul 1500	0.3	29.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
061-9-RF-3B10-M.Bed	1	1.8	Jul 1000	145	0.3	15.0	9.64
062-9-RF-3B10-Dress	1	0.1	Jul 1900	9	0.0	4.5	1.98
063-9-RF-3B10-M BAT	1	0.4	Jul 1700	29	0.0	10.2	2.87

Zone Sizing Summary for 064-068-9-9F-3B10-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **064-068-9-9F-3B10-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.1	2.8	23.7 / 16.9	13.7 / 12.8	0.08	Jul 1500	5.83

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	230	0.029	0.023	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.8	Jul 1500	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
064-9-RF-3B10-Bed-2	1	1.6	Jul 1000	124	0.2	11.9	10.39
065-9-RF-3B10-Corri	1	0.7	Jul 1700	56	0.0	16.0	3.51
066-9-RF-3B10-MaidR	1	0.5	Jul 1600	40	0.0	5.6	7.06
067-9-RF-3B10-MaidB	1	0.1	Jul 1900	5	0.0	2.8	1.80
068-9-RF-3B10-Power	1	0.1	Jul 1900	6	0.0	3.2	1.80

Zone Sizing Summary for 069-070-9-9F-3B10-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **069-070-9-9F-3B10-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **15.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.8	1.7	23.5 / 16.6	13.2 / 12.3	0.05	Jul 1000	8.51

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	135	0.017	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.7	Jul 1000	0.2	15.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
069-9-RF-3B10-Bed-1	1	1.4	Jul 1000	114	0.2	11.6	9.81
070-9-RF-3B10-Bath1	1	0.3	Jul 1600	21	0.0	4.3	5.00

Zone Sizing Summary for 071-072-9-9F-3B10-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **071-072-9-9F-3B10-FCU4**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **36.2** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.5	3.7	23.4 / 16.9	13.0 / 12.1	0.12	Jul 1500	8.09

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	293	0.037	0.029	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.6	Jul 1000	0.4	36.2

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
071-9-RF-3B10-Kitch	1	1.0	Jul 1700	77	0.1	12.1	6.36
072-9-RF-3B10-LV/DN	1	2.7	Jul 1000	216	0.3	24.1	8.96

Zone Sizing Summary for 073-075-10-9F-2B09-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **073-075-10-9F-2B09-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.0	1.8	23.6 / 16.7	13.4 / 12.4	0.05	Jul 1000	5.80

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	145	0.018	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.8	Jul 1000	0.2	25.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
073-10-RF-2B09-M.BD	1	1.6	Jul 1000	125	0.2	14.3	8.75
074-10-RF-2B09-Dres	1	0.1	Jul 1900	5	0.0	2.7	1.98
075-10-RF-2B09-MBAT	1	0.2	Jul 1900	14	0.0	8.0	1.80

Zone Sizing Summary for 076-10-9F-2B09-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **076-10-9F-2B09-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.5	23.5 / 16.4	12.9 / 11.9	0.04	Jul 1000	9.03

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	118	0.015	0.012	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.5	Jul 1000	0.2	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
076-10-RF-2B09-Bed1	1	1.5	Jul 1000	118	0.2	13.1	9.03

Zone Sizing Summary for 077-080-10-9F-2B09-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **077-080-10-9F-2B09-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.1	3.5	23.6 / 17.0	13.4 / 12.5	0.11	Jul 1600	6.56

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	283	0.036	0.028	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.5	Jul 1500	0.3	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
077-10-RF-2B09-Corr	1	0.6	Jul 1600	50	0.0	9.8	5.13
078-10-RF-2B09-BAT1	1	0.2	Jul 1700	14	0.0	4.4	3.14
079-10-RF-2B09-Kitc	1	0.8	Jul 1700	60	0.0	8.5	7.06
080-10-RF-2B09-L/D	1	2.0	Jul 1000	159	0.2	20.4	7.77

Zone Sizing Summary for 081-087-11-9F-1B08-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **081-087-11-9F-1B08-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **58.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.9	5.2	23.5 / 16.6	13.1 / 12.1	0.16	Jul 1500	7.03

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	414	0.052	0.041	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.1	Jul 1500	0.6	58.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
081-11-RF-1B08-Bedr	1	1.9	Jul 1500	148	0.3	15.3	9.69
082-11-RF-1B08-Dres	1	0.1	Jul 1900	6	0.0	3.1	1.98
083-11-RF-1B08-Bath	1	0.1	Jul 1900	10	0.0	5.6	1.80
084-11-RF-1B08-L/D	1	1.9	Jul 1000	154	0.2	16.7	9.21
085-11-RF-1B08-Kitc	1	0.8	Jul 1700	64	0.0	11.3	5.64
086-11-RF-1B08-Corr	1	0.2	Jul 1600	15	0.0	3.8	3.99
087-11-RF-1B08-Pow	1	0.2	Jul 1600	17	0.0	3.1	5.41

Zone Sizing Summary for 088-090-12-9F-2B07-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **088-090-12-9F-2B07-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **25.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.1	1.9	23.6 / 16.7	13.5 / 12.5	0.06	Jul 1000	6.12

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	158	0.020	0.016	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.9	Jul 1000	0.2	25.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
088-12-RF-2B07-MBED	1	1.7	Jul 1000	132	0.2	14.7	8.96
089-12-RF-2B07-Dres	1	0.1	Jul 1900	5	0.0	2.7	1.98
090-12-RF-2B07-MBAT	1	0.3	Jul 1800	21	0.0	8.4	2.49

Zone Sizing Summary for 091-12-9F-2B07-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **091-12-9F-2B07-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.7	1.5	23.5 / 16.4	12.9 / 11.9	0.04	Jul 1000	9.03

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	118	0.015	0.012	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.5	Jul 1000	0.2	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
091-12-RF-2B07-Bed1	1	1.5	Jul 1000	118	0.2	13.1	9.03

Zone Sizing Summary for 092-095-12-9F-2B07-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **092-095-12-9F-2B07-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.5	3.8	23.5 / 16.8	13.1 / 12.2	0.12	Jul 1500	7.10

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	306	0.039	0.031	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.8	Jul 1500	0.3	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
092-12-RF-2B07-Corr	1	0.6	Jul 1600	50	0.0	9.8	5.13
093-12-RF-2B07-BAT1	1	0.2	Jul 1700	14	0.0	4.4	3.14
094-12-RF-2B07-Kitc	1	0.8	Jul 1700	60	0.0	8.5	7.06
095-12-RF-2B07-L/D	1	2.3	Jul 1000	182	0.2	20.4	8.92

Zone Sizing Summary for 096-102-13-9F-1B06-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **096-102-13-9F-1B06-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **60.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.0	5.3	23.6 / 16.8	13.4 / 12.5	0.16	Jul 1400	7.24

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	434	0.055	0.043	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.3	Jul 1500	0.6	60.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
096-13-RF-1B06-BedR	1	2.1	Sep 1400	168	0.3	15.9	10.54
097-13-RF-1B06-Dres	1	0.1	Jul 1900	6	0.0	3.2	1.98
098-13-RF-1B06-Bath	1	0.1	Jul 1900	11	0.0	6.0	1.80
099-13-RF-1B06-L/D	1	1.9	Jul 1000	154	0.2	16.7	9.21
100-13-RF-1B06-Kitc	1	0.8	Jul 1700	64	0.0	11.3	5.64
101-13-RF-1B06-Corr	1	0.2	Jul 1600	15	0.0	3.8	3.99
102-13-RF-1B06-Powe	1	0.2	Jul 1600	17	0.0	3.1	5.41

Zone Sizing Summary for 103-109-14-9F-1B05-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **103-109-14-9F-1B05-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **59.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.6	5.9	23.5 / 16.7	13.3 / 12.4	0.17	Sep 1500	8.02

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	477	0.060	0.048	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.9	Oct 1400	0.7	59.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
103-14-RF-1B05-Bedr	1	1.9	Sep 1400	153	0.3	15.5	9.88
104-14-RF-1B05-Dres	1	0.1	Jul 1900	7	0.0	3.4	1.98
105-14-RF-1B05-Bath	1	0.1	Jul 1900	10	0.0	5.6	1.80
106-14-RF-1B05-L/D	1	2.7	Oct 1400	211	0.4	17.0	12.38
107-14-RF-1B05-Kitc	1	0.6	Jul 1900	48	0.0	7.8	6.12
108-14-RF-1B05-Corr	1	0.4	Jul 1600	33	0.0	7.5	4.37
109-14-RF-1B05-Powe	1	0.2	Jul 1600	16	0.0	2.7	5.96

Zone Sizing Summary for 110-112-15-9F-3B04-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **110-112-15-9F-3B04-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.7	2.5	23.6 / 16.6	13.4 / 12.4	0.07	Jul 1700	6.82

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	204	0.026	0.020	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.6	Sep 1600	0.3	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
110-15-RF-3B04-MBed	1	2.1	Sep 1600	166	0.3	15.2	10.91
111-15-RF-3B04-Dres	1	0.1	Jul 1900	9	0.0	4.5	1.98
112-15-RF-3B04-MBAT	1	0.4	Jul 1700	29	0.0	10.2	2.87

Zone Sizing Summary for 113-117-15-9F-3B04-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **113-117-15-9F-3B04-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.5	3.2	23.4 / 16.4	13.0 / 12.1	0.09	Jun 1600	6.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	254	0.032	0.025	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.2	Jul 1700	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
113-15-RF-3B04-Bed2	1	1.8	Jul 1700	144	0.2	11.9	12.12
114-15-RF-3B04-Corr	1	0.7	Jul 1700	57	0.0	16.0	3.56
115-15-RF-3B04-MI.R	1	0.5	Jul 1600	42	0.0	5.6	7.49
116-15-RF-3B04-MI.B	1	0.1	Jul 1900	5	0.0	2.8	1.80
117-15-RF-3B04-Powe	1	0.1	Jul 1900	6	0.0	3.2	1.80

Zone Sizing Summary for 118-119-15-PT1-3B04-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **118-119-15-PT1-3B04-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **16.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.1	1.9	23.4 / 16.3	13.0 / 12.0	0.06	Aug 1600	9.65

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	154	0.019	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.0	Jul 1700	0.2	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
118-15-RF-3B04-Bed1	1	1.7	Jul 1700	133	0.2	11.6	11.45
119-15-RF-3B04-BAT1	1	0.3	Jul 1600	22	0.0	4.4	4.92

Zone Sizing Summary for 120-121-15-PT1-3B04-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **120-121-15-PT1-3B04-FCU4**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **35.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	6.3	5.6	23.5 / 16.6	13.0 / 12.1	0.17	Oct 1500	12.47

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	441	0.056	0.044	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	5.5	Oct 1500	0.7	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
120-15-RF-3B04-Kitc	1	1.1	Aug 1800	84	0.1	11.7	7.21
121-15-RF-3B04-L/D	1	4.5	Oct 1500	357	0.5	23.7	15.07

Zone Sizing Summary for 122-124-16-PT1-3B03-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **122-124-16-PT1-3B03-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **29.9** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.7	2.5	23.6 / 16.6	13.4 / 12.4	0.07	Jul 1700	6.82

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	204	0.026	0.020	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.6	Sep 1600	0.3	29.9

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
122-16-RF-3B03-MBed	1	2.1	Sep 1600	166	0.3	15.2	10.91
123-16-RF-3B03-Dres	1	0.1	Jul 1900	9	0.0	4.5	1.98
124-16-RF-3B03-MBAT	1	0.4	Jul 1700	29	0.0	10.2	2.87

Zone Sizing Summary for 125-129-16-PT1-3B03-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **125-129-16-PT1-3B03-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **39.5** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	3.5	3.2	23.4 / 16.4	13.0 / 12.1	0.09	Jun 1600	6.43

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	254	0.032	0.025	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	3.2	Jul 1700	0.2	39.5

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
125-16-RF-3B03-Bed2	1	1.8	Jul 1700	144	0.2	11.9	12.12
126-16-RF-3B03-Corr	1	0.7	Jul 1700	57	0.0	16.0	3.56
127-16-RF-3B03-MI.R	1	0.5	Jul 1600	42	0.0	5.6	7.49
128-16-RF-3B03-MI.B	1	0.1	Jul 1900	5	0.0	2.8	1.80
129-16-RF-3B03-Powe	1	0.1	Jul 1900	6	0.0	3.2	1.80

Zone Sizing Summary for 130-131-16-PT1-3B03-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **130-131-16-PT1-3B03-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **16.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.1	1.9	23.4 / 16.3	13.0 / 12.0	0.06	Aug 1600	9.65

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	154	0.019	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.0	Jul 1700	0.2	16.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
130-16-RF-3B03-Bed1	1	1.7	Jul 1700	133	0.2	11.6	11.45
131-16-RF-3B03-BAT1	1	0.3	Jul 1600	22	0.0	4.4	4.92

Zone Sizing Summary for 132-133-16-PT1-3B03-FCU4

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **132-133-16-PT1-3B03-FCU4**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **35.4** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.2	4.5	23.5 / 16.7	12.9 / 12.0	0.14	Jul 1700	9.96

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	352	0.044	0.035	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.5	Jul 1700	0.4	35.4

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
132-16-RF-3B03-Kitc	1	0.8	Jul 1700	66	0.0	11.7	5.67
133-16-RF-3B03-L/D	1	3.6	Jul 1700	286	0.4	23.7	12.08

Zone Sizing Summary for 134-136-17-PT1-2B02-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **134-136-17-PT1-2B02-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.4	2.2	23.5 / 16.4	13.1 / 12.0	0.06	Jun 1700	7.07

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	175	0.022	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.2	Jul 1700	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
134-17-RF-2B02-MBED	1	1.8	Jul 1700	144	0.2	14.4	10.02
135-17-RF-2B02-Dres	1	0.1	Jul 1900	5	0.0	2.7	1.98
136-17-RF-2B02-MBAT	1	0.3	Jul 1700	26	0.0	7.7	3.34

Zone Sizing Summary for 137-17-PT1-2B02-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **137-17-PT1-2B02-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **27.3** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.7	2.5	23.6 / 16.6	13.4 / 12.4	0.07	Aug 1600	7.37

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	201	0.025	0.020	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.5	Jul 1700	0.2	27.3

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
137-17-RF-2B02-Bed1	1	1.7	Jul 1700	137	0.2	13.1	10.46
138-17-RF-2B02-Corr	1	0.6	Jul 1600	50	0.0	9.8	5.13
139-17-RF-2B02-BAT1	1	0.2	Jul 1700	14	0.0	4.4	3.14

Zone Sizing Summary for 138-141-17-PT1-2B02-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **138-141-17-PT1-2B02-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **43.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	4.8	4.1	23.5 / 16.7	13.0 / 12.1	0.13	Jul 1700	7.54

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	325	0.041	0.033	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.1	Jul 1700	0.3	43.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
138-17-RF-2B02-Corr	1	0.6	Jul 1600	50	0.0	9.8	5.13
139-17-RF-2B02-BAT1	1	0.2	Jul 1700	14	0.0	4.4	3.14
140-17-RF-2B02-Kitc	1	0.8	Jul 1700	60	0.0	8.5	7.06
141-17-RF-2B02-L/D	1	2.5	Jul 1700	201	0.2	20.4	9.84

Zone Sizing Summary for 142-144-18-PT1-2B01-FCU1

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **142-144-18-PT1-2B01-FCU1**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.8** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.4	2.2	23.5 / 16.4	13.1 / 12.0	0.06	Jun 1700	7.07

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	175	0.022	0.018	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.2	Jul 1700	0.2	24.8

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
142-18-RF-2B01-MBED	1	1.8	Jul 1700	144	0.2	14.4	10.02
143-18-RF-2B01-Dres	1	0.1	Jul 1900	5	0.0	2.7	1.98
144-18-RF-2B01-MBAT	1	0.3	Jul 1700	26	0.0	7.7	3.34

Zone Sizing Summary for 145-18-PT1-2B01-FCU2

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **145-18-PT1-2B01-FCU2**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **13.1** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	1.9	1.7	23.5 / 16.4	13.0 / 12.0	0.05	Jul 1700	10.46

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	137	0.017	0.014	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	1.7	Jul 1700	0.2	13.1

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
145-18-RF-2B01-Bed1	1	1.7	Jul 1700	137	0.2	13.1	10.46

Zone Sizing Summary for 146-149-18-9F-2B01-FCU3

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **146-149-18-9F-2B01-FCU3**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **44.0** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	5.6	4.9	23.5 / 16.5	12.9 / 11.9	0.15	Jul 1600	8.81

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	388	0.049	0.039	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	4.9	Jul 1700	0.3	44.0

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
146-18-RF-2B01-Corr	1	0.6	Jul 1600	50	0.0	9.8	5.13
147-18-RF-2B01-BAT1	1	0.2	Jul 1700	14	0.0	4.4	3.14
148-18-RF-2B01-Kitc	1	1.1	Jul 1600	83	0.0	8.9	9.38
149-18-RF-2B01-L/D	1	3.0	Jul 1700	240	0.2	20.9	11.49

Zone Sizing Summary for 150-153-BD1-RF--ELE-GS-STO-COR

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **150-153-BD1-RF--ELE-GS-STO-COR**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **30.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	43.5	42.7	23.2 / 15.8	12.6 / 11.5	1.16	Jul 2000	108.78

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	3340	0.421	0.334	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	42.3	Jul 1700	0.2	30.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1							
150-BD1-RF--ELE RM	1	1.0	Jul 1700	78	0.0	6.2	12.60
151-BD1-RF--GSM RM	1	40.3	Jul 1700	3181	0.1	13.7	232.22
152-BD1-RF--MEP STO	1	0.5	Jul 1600	43	0.1	3.9	10.97
153-BD1-RF--COR	1	0.5	Jul 1800	37	0.0	6.9	5.41

Zone Sizing Summary for 154-BD1-RF--PUMP RM

03. DCG BREEZE RESIDENCES (PLOT 01)_R2-05.06.2026
MIRAGE INC CONSULTANTS

08-06-2026
01:47PM

Air System Information

Air System Name **154-BD1-RF--PUMP RM**
Equipment Class **TERM**
Air System Type **2P-FC**

Number of zones **1**
Floor Area **24.7** m²
Location **Dubai, United Arab Emirates**

Sizing Calculation Information

Calculation Months **Jan to Dec**
Sizing Data **Calculated**

Zone L/s Sizing **Sum of space airflow rates**
Space L/s Sizing **Individual peak space loads**

Terminal Unit Sizing Data - Cooling

Zone Name	Total Coil Load (kW)	Sens Coil Load (kW)	Coil Entering DB / WB (°C)	Coil Leaving DB / WB (°C)	Water Flow @ 9.0 K (L/s)	Time of Peak Coil Load	Zone L/(s·m²)
Zone 1	2.3	1.9	23.7 / 17.1	13.4 / 12.4	0.06	Jul 1700	6.25

Terminal Unit Sizing Data - Heating, Fan, Ventilation

Zone Name	Heating Coil Load (kW)	Heating Coil Ent/Lvg DB (°C)	Htg Coil Water Flow @11.1 K (L/s)	Fan Design Airflow (L/s)	Fan Motor (BHP)	Fan Motor (kW)	OA Vent Design Airflow (L/s)
Zone 1	0.0	-18.3 / -18.3	0.00	154	0.019	0.015	0

Zone Peak Sensible Loads

Zone Name	Zone Cooling Sensible (kW)	Time of Peak Sensible Cooling Load	Zone Heating Load (kW)	Zone Floor Area (m²)
Zone 1	2.0	Jul 1800	0.2	24.7

Space Loads and Airflows

Zone Name / Space Name	Mult.	Cooling Sensible (kW)	Time of Peak Sensible Load	Air Flow (L/s)	Heating Load (kW)	Floor Area (m²)	Space L/(s·m²)
Zone 1 154-BD1-RF--PUMP RM	1	2.0	Jul 1800	154	0.2	24.7	6.25