Client Name: سمارت لتصنيع أبواب الطوارئ
Testing Name: Fire Resistance Test
Customer Code: BPI/H/CO.137
Test Specimen Type: Metal Door Assembly (Single leaf)
Delivery Date: 18/04/2023
Testing Date: 14/05/2023

Test Report

Single swinging metal door assembly,

Fire Resistance Test; in accordance with NFPA 252,

"Standard Methods of Fire Tests of Door Assemblies"

Client:

سمارت لتصنيع أبواب الطوارئ

May 2023

Tel : (02) 33356722 / 33356853 / 33357107 / 01120943065
FAX : (02) 33351564
P.O. BOX 1770
87 El-Tahrir St., Dokki, Cairo, Egypt

الممسوحة ضوئيا بـ CamScanner

SUMMARY

The fire resistance test was carried out on 14 May 2023 at the request of the client. The ambient temperature at the start of the test was 30°C and the mean unexposed face temperature was 32°C. Client representatives were allowed to attend and observe the test as witnesses.

A fire resistance test was conducted in accordance with NFPA 252 (Standard Methods of Fire Tests of Door Assemblies). The test specimen was a single swinging metal door assembly with dimensions (220 cm Height× 100 cm wide×5 cm thick). It was installed in an opining in a brick wall nominally 300 cm wide ×280 cm height. The door leaf was installed in the metal frame with four butt hinges (Yale) and secured by panic bar (UL-listed) door lock. The landing side of the door was exposed to the fire during the test. The installed specimen was tested as described in details hereinafter.

The tested door assembly has succeeded to meet the condition of acceptance as outlined in NFPA 252 for an actual duration of fire test of **150 minutes**. The tested door remained fastened in its original position in the test frame opening during the fire exposure and hose stream test. No flaming occurred on the unexposed surface of the door assembly during 150 minutes of the fire exposure. Slight to moderate deflection of the door leaf has been observed. The maximum temperature recorded for the unexposed surface after 30 minutes of the fire exposure was about **248°C**. The test was terminated after the end of 150 minutes as per client request.

The fire rating of the tested door assembly was specified as **2 ½ -h (150 minutes).**

Tested and report by

Dr. M. M. Ibrahim

Eng. Aya M. Zaki

Reviewed by

Ass. Prof. Hamada Shoukry

Head of Fire Dept.

Prof. Dr. S. S. Shebl

Director of institute

Prof. Dr. M. A. Hassan

Tel : (02) 33356722 / 33356853 / 33357107 / 01120943065
FAX : (02) 33351564
P.O. BOX 1770
87 El-Tahrir St., Dokki, Cairo, Egypt

الممسوحة ضوئيا بـ CamScanner

CONCLUSION

The single swinging metal door assembly was subjected to a fire resistance test in accordance with test procedure NFPA 252. It has succeeded to fulfill the requirements of the test standard for fire rating of **150 minutes** as illustrated in the following table.

Test Sample	Property	Result
Single swinging metal door assembly *Dimensions*:(220 cm H×100 cm W) *Supplier:* سمارت لتصنيع أبواب الطوارئ	**Fire rating**	**2 ½ -h**

Remarks

- **This result is only valid for the sample delivered to the fire Laboratory.**
- **This report is valid for only one year from issuing date.**
- **The sample was delivered to the laboratory by the entity requesting the test.**
- **The aforementioned data according to what was mentioned in the letter of the body requesting the test without any responsibility on the center.**
- **The attached results apply only to the results are not valid for the approval of any quantitative production / and practices / supplies / as well as export and is not considered as a conformity certificate.**

Tested and report by

Dr. M. M. Ibrahim

Eng. Aya M. Zaki

Reviewed by

Ass. Prof. Hamada Shoukry

Head of Fire Dept.

Prof. Dr. S. S. Shebl

Director of institute

Prof. Dr. M. A. Hassan

Tel : (02) 33356722 / 33356853 / 33357107 / 01120943065
FAX : (02) 33351564
P.O. BOX 1770
87 El-Tahrir St., Dokki, Cairo, Egypt

الممسوحة ضوئيا بـ CamScanner

Housing & Building National Research Center
Vice-Chairman Office
for Research and Studies Affairs

المركز القومي لبحوث الإسكان والبناء
مكتب نائب رئيس مجلس الإدارة
لشئون البحوث والدراسات

مرجعنا : ٢٠٢٣/٠٥/١٣٧
مرجعكم: ٢٠٢٣/٠٤/١٨

الموضوع: اجراء اختبار مقاومة الحريق لباب طوارئ معدني

الجهة الطالبة: شركة سمارت لتصنيع ابواب الطوارئ

تحية طيبة وبعد،،

إيماءً الى خطاب سيادتكم بتاريخ ٢٠٢٣/٠٤/١٨ بخصوص الموضوع عاليه، مرفق طيه التقرير الفني النهائي بالنتائج ، هذا وقد سددت الرسوم المقررة علي دفعتين الدفعة الاولي بالقسيمة رقم ٠٤٧٢١٥٢ بتاريخ ٢٠٢٣/٠٥/٠١ والدفعة الثانية بالقسيمة رقم ٠٤٦٨٩٣٥ بتاريخ ٢٠٢٣/٠٥/١٥.

وتفضلوا بقبول فائق الاحترام،،

مدير المعهد
أستاذ دكتور/
محمود علي حسن

نائب رئيس مجلس الإدارة
لشئون البحوث والدراسات
أستاذ دكتور/
طارق محمد بهاء الدين

87 El-Tahrir St., Dokki, Giza 11511
P.O.Box : 1770 Cairo, EGYPT
E_mail : hbrc@hbrc.edu.eg & www.hbrc.edu.eg
Phone: (+202) 7617102, 7617092 Fax : 3351564, 7628736
٨٧ شارع التحرير الدقى - جيزة
ص.ب. : ١٧٧٠ القاهرة

الممسوحة ضوئيا بـ CamScanner