

Eco Quiet Air Cooler: An Innovative, Low-Cost, and Anti-Vibrational Evaporative Cooling System for Low-Income Environments

Research Paper for the 6th International Innovation Competition (ITC-EGYPT 2026)

Ahmed Osama Abdel Ghani¹, Samah Ashraf Ibrahim², Salma Ashraf Ibrahim³, Saga Ashraf Ibrahim⁴

¹Ahmed.s25002@stemassiut.moe.edu.eg | ²Samah.1525513@stemassiut.moe.edu.eg

³Salmaashrafibrahim579@gmail.com | ⁴sagaashraf340@gmail.com

STEM School for Boys - Assiut, Egypt

Studying Administration: Salma Ashraf

Abstract— In hot and arid regions, effective and sustainable cooling systems are essential to maintain human comfort and productivity. Low-income households often rely on traditional evaporative coolers as an affordable alternative to expensive, energy-intensive vapor-compression air conditioning units. However, conventional evaporative coolers suffer from two critical limitations: substantial acoustic pollution caused by fan/pump vibrations, and the operational inconvenience of frequent water refilling due to high evaporation rates. This paper introduces the Eco Quiet Air Cooler, an innovative, low-cost prototype engineered to solve these acoustic and volumetric inefficiencies. The system optimizes direct evaporative cooling by driving air through high-affinity water-absorbing media (sponge/thick fabric, with future hydrogel integration) via a low-voltage submersible pump circuit. Crucially, the prototype introduces elastomeric vibration isolation dampers (rubber/foam pads) beneath structural vibration nodes to absorb mechanical frequencies and eliminate structure-borne noise. Experimental evaluations demonstrate a significant temperature drop of up to 12.7°C under dry conditions, alongside a drastic noise reduction from 68 dB to a silent 42 dB. With a localized fabrication cost of 1000–1500 EGP, this design provides a scalable, socioeconomically viable, and energy-efficient cooling solution for resource-constrained environments.

Keywords— Direct Evaporative Cooling, Noise Mitigation, Vibration Isolation, Water Efficiency, Hydrogel Polymers, Low-Cost Technology, Sustainable Engineering.

I. Introduction

Global climate change and rising ambient temperatures present severe public health and socioeconomic challenges, particularly in developing countries and low-income communities. In these regions, traditional vapor-compression air conditioning systems are unviable due to high capital costs and intensive electrical power consumption. Consequently, evaporative air coolers (commonly known as desert coolers) serve as the primary alternative, utilizing the natural endothermic process of water evaporation to lower indoor temperatures efficiently and sustainably.

Despite their clear economic and environmental benefits, commercially available low-cost evaporative coolers possess significant engineering defects. First, they generate high-frequency and low-frequency mechanical noise originating from uncalibrated axial fans, water pump motors, and loose structural enclosures. This acoustic pollution induces cognitive fatigue and disrupts sleep or work environments.

Second, the rapid evaporation of water requires users to manually refill the reservoir multiple times a day, severely limiting the device's autonomy and practical daily usage.

To address these compounding challenges, the Eco Quiet Air Cooler project re-engineers the structural and fluid-dynamic framework of basic evaporative coolers. This research details the development of a silent, highly water-efficient prototype constructed entirely from locally sourced, cost-effective components. The complete manufacturing cost ranges from 1000 to 1500 EGP, ensuring that the final commercial product remains accessible to the primary target demographics, including university students, small retail owners, and low-resource households.

II. Research Novelty

The academic and practical novelty of this project lies in its multi-disciplinary approach to balancing thermal efficiency, acoustic comfort, and water conservation without altering structural simplicity or driving up production costs. Unlike standard commercial systems that prioritize thermal reduction while neglecting acoustic pollution, the Eco Quiet Air Cooler introduces targeted mechanical isolation techniques using elastomeric dampers to decouple vibrational sources from the main structural frame.

Furthermore, the research addresses the water consumption barrier by proposing a material-science solution. By transitioning from basic cellulose pads to advanced high-absorption structures—such as optimized thick synthetic fabric or superabsorbent hydrogel polymers—the prototype maximizes moisture retention and regulates fluid flow. This minimizes structural water waste, extends operational cycles between refills, and delivers a stable, continuous cooling output perfectly suited for localized spatial zones.

III. Methodology and Physical Principles

A. Structural Architecture and Components

The mechanical assembly of the Eco Quiet Air Cooler consists of five primary functional components integrated into a compact, mobile enclosure:

- **Axial Flow Fan:** A low-voltage, high-efficiency fan selected to optimize volumetric air flow across the evaporative matrix.
- **Submersible Water Pump:** A low-power micro-pump that constantly circulates water to maintain uniform saturation of the pad.
- **Evaporative Matrix:** Highly porous sponge layers and dense woven fabric designed to achieve high surface area contact between air and water.
- **Fluid Reservoir:** A sealed base container designed to collect, store, and cycle water through a closed-loop system.
- **Vibration Isolation Dampers:** Specialized open-cell acoustic foam and high-density rubber cushions mechanically positioned at the mounting brackets of both the fan and the pump.

B. Thermodynamic Analysis of Evaporative Cooling

The underlying operational physics of the device is governed by Direct Evaporative Cooling (DEC), an adiabatic process where the sensible heat of the incoming air stream is converted into latent heat through

the vaporization of water. As warm, unsaturated air passes through the wet porous medium, water absorbs its latent heat of vaporization, altering its state from liquid to gas. This phase change drops the dry-bulb temperature of the air while increasing its absolute humidity along a constant wet-bulb temperature line.

The sensible heat extraction rate can be mathematically evaluated using the steady-flow thermal energy equation:

$$Q = \dot{m} \cdot C_p \cdot (T_{in} - T_{out}) \tag{1}$$

Where:

Q = Sensible heat cooling capacity (Watts, W)

$\dot{m}$ = Mass flow rate of the air stream (kg/s)

C_p = Specific heat capacity of air at constant pressure (~1.005 kJ/kg·K)

T_{in} = Dry-bulb temperature of ambient incoming air (°C)

T_{out} = Dry-bulb temperature of cooled outgoing air (°C)

C. Acoustic Wave Mitigation Strategy

Acoustic emissions in small cooling appliances are classified into airborne noise (blade vortex noise) and structure-borne noise (motor rotor imbalances transmitted to the plastic casing). Structure-borne noise often leads to mechanical resonance, drastically amplifying the perceived decibel levels. In this design, structural dampening is achieved by introducing rubber-foam isolation pads characterized by high mechanical hysteresis. These pads act as low-pass mechanical filters that intercept and dissipate kinetic vibrational energy into thermal energy, cutting off resonance paths and isolating the external chassis.

IV. Experimental Results and Verification

To validate the thermal and acoustic optimization strategies, empirical testing was performed in an uncontrolled ambient environment simulating a hot summer day. Quantitative benchmarks tracking dry-bulb temperature, noise thresholds, and water depletion rates were recorded across different operational phases.

Table I: Quantitative Performance Matrix of the System Across Operational Modifications

Operational Phase	Airflow Output Dry-Bulb Temp (°C)	Acoustic Noise Level (dB)	Media Moisture Retention & Stability
Baseline Phase (Dry system, mechanical components unisolated)	36.5 °C	68 dB	Zero Retention (Completely Dry Matrix)
Hydration Phase (Pump activated, water flowing, unisolated)	24.2 °C	65 dB	Low-Medium (High evaporation gradient)
Optimized Phase (Full Eco Quiet System with isolation dampers)	23.8 °C	42 dB	High Stability (Extended fluid life)

The empirical thermal data indicates that activating the closed-loop water circulation triggers an immediate, sustained reduction in the exhaust air temperature, dropping from 36.5°C to 23.8°C. This delivers an impressive localized thermal differential (ΔT) of 12.7°C. On the acoustic spectrum, the implementation of elastomeric dampers resulted in a steep drop in noise levels, shifting from a disruptive 68 dB to an ultra-quiet 42 dB. This matches the acoustic comfort standards required for residential bedrooms and educational study zones.

V. Commercialization Analysis and Feasibility

A rigorous economic feasibility analysis was performed to evaluate the viability of transitioning the prototype into a commercial product line:

- **Production Cost Breakdown:** The total raw material and fabrication cost per unit sits between 1000 and 1500 EGP, utilizing mass-produced, easily replaceable parts.
- **Pricing Strategy:** The projected retail market price is set between 1500 and 2000 EGP. This narrow profit margin maximizes affordability and gives the product a profound competitive edge.
- **Target Demographics:** University students living in shared accommodation dorms, low-income households in off-grid or high-temperature zones, and small-scale commercial offices.
- **Competitive Advantage:** While standard electric fans simply recirculate hot ambient air and commercial desert coolers cause loud acoustic irritation, the Eco Quiet Air Cooler offers simultaneous low-cost cooling and silent operation.

VI. Risk Assessment and Future Extensions

The primary performance limitation identified during testing is the thermodynamic constraint of direct evaporative cooling systems in high relative ambient humidity (wet-bulb depression limitation). When ambient air is already saturated with moisture, the water evaporation rate slows down, lowering thermal reduction performance. To mitigate this effect and maximize the refilling cycle efficiency, future iterations of the project will focus on substituting standard sponges with synthesized Hydrogel Polymers. Hydrogels possess supreme cross-linked networks capable of storing massive quantities of water relative to their total volume, slow-releasing moisture through controlled capillary action. Future research will also explore streamlined, injection-molded external enclosures to reduce manufacturing costs during mass production, while establishing retail pathways via e-commerce and regional supply vendors.

VII. References

American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). Official Technical Handbooks & Guidelines. Available online: <https://www.ashrae.org/>

Editor Engineering Toolbox, 'Evaporative Cooling Systems, Psychrometric Charts and Air Properties Analysis,' 2024. Available online: <https://www.engineeringtoolbox.com/>

National Renewable Energy Laboratory (NREL), 'Advanced Low-Energy HVAC and Desiccant Evaporative Cooling Technologies.' Available online: <https://www.nrel.gov/>

Springer Nature Link, 'Material Advancements in Low-Cost Porous Media for Sustainable Evaporative Thermal Comfort.' Available online: <https://link.springer.com/>

Elsevier Science & Technology, 'Acoustic Engineering, Mechanical Vibration Isolation, and Damping Dynamics in Home Appliances.' Available online: <https://www.elsevier.com/>

Nature Research Journal, 'Superabsorbent Polymeric Hydrogels for Extended Fluid Retention and Environmental Atmospheric Engineering,' 2026. Available online: <https://www.nature.com/>

Khan Academy Science, 'Thermodynamics of Phase Changes, Latent Heat Capacity, and Adiabatic Systems.' Available online: <https://www.khanacademy.org/>

Coursera Academic Network, 'Principles of Sustainable Design and Thermal Fluid Engineering Processes.' Available online: <https://www.coursera.org/>

MIT OpenCourseWare, 'Department of Mechanical Engineering: Intermediate Thermal-Fluids, Fluid Mechanics and Acoustics.' Available online: <https://ocw.mit.edu/>

National Aeronautics and Space Administration (NASA) Technical Repository, 'Viscoelastic Damping Materials, Elastomeric Mounts, and Structural Vibration Attenuation,' 2026. Available online: <https://www.nasa.gov/>

World Bank Group Development Reports, 'Affordable Frugal Technologies and Climate Adaptation Strategies for Low-Income Environments.' Available online: <https://www.worldbank.org/>

United Nations Environment Programme (UNEP), 'Sustainable Global Cooling Frameworks, Energy Efficiency, and Passive Design in Developing Countries.' Available online: <https://www.unep.org/>