SOFTWARE FAMILY:
52
IC208CX

SOFTWARE RELEASE: 7.5

PARAMETERS DESCRIPTOR(E2):
7.5

Revision:
0.4 2019/06/05

GENERAL RULES:

CRC calculation: standard modbus RTU CRC

Baudrate	9600
Data Lenght	8
Parity	none
Stop bit	1
Minimum TimeOut	60ms

Reading function code:0x 03
Writing function code: 0x 10

R/W	DEC	REGISTER[hex]	VAR NAME	DESCRIPTION	GROUP	LENGHT	TYPE	GAIN	DEC
R/W	768	0300	St01	Summer Set point	St	word	St02÷St03	[0.1][1]	[1][0]
R/W	769	0301	St02	Summer minimum Set point	St	word	[-50.0÷St01 °C] [-58÷St01 °F]	[0.1][1]	[1][0]
R/W	770	0302	St03	Summer maximum Set point	St	word	[St01÷110 °C] [St01÷230 °F]	[0.1][1]	[1][0]
R/W	771	0303	St04	Winter set point	St	word	St05÷St06	[0.1][1]	[1][0]
R/W	772	0304	St05	Winter minimum Set point	St	word	[-50.0÷St04 °C] [-58÷St04 °F]	[0.1][1]	[1][0]
R/W	773	0305	St06	Winter maximum Set point	St	word	[St04÷110 °C] [St04÷230 °F]	[0.1][1]	[1][0]
R/W	774	0306	St07	Summer regulation band	St	byte	[0.0 ÷ 25.0 °C] [0 ÷ 45 °F]	[0.1][1]	[1][0]
R/W	775	0307	St08	Winter regulation band	St	byte	[0.0 ÷ 25.0 °C] [0 ÷ 45 °F]	[0.1][1]	[1][0]
R/W	776	0308	St09	Probe selection for Summer regulation	St	4bit	0-5	1	0
R/W	777	0309	St10	Probe selection for Winter regulation	St	4bit	0-11	1	0
R/W	778	030A	St11	Regulation: proportional or neutral zone	St	2bit	0-1	1	0
R/W	779	030B	dP01	Upper display visualization	dP	byte	0-16	1	0
R/W	780	030C	dP02	Lower display visualization	dP	byte	0-20	1	0
R/W	781	030D	dP03	Display visualization	dP	2bit	0-3	1	0
R/W	782	030E	dP04	Remore keyboard 1 visualization	dP	1bit	0-1	1	0
R/W	783	030F	dP05	Remore keyboard 2 visualization	dP	1bit	0-1	1	0
R/W	784	0310	dP06	First probe displayed on Visograph	dP	byte	0-35	1	0
R/W	785	0311	dP07	Second probe displayed on Visograph	dP	byte	0-35	1	0
R/W	786	0312	dP08	Third probe displayed on Visograph	dP	byte	0-35	1	0
R/W	787	0313	dP09	Fourth probe displayed on Visograph	dP	byte	0-35	1	0
R/W	788	0314	dP10	Stand-by visualization	dP	2bit	0-2	1	0
R/W	789	0315	CF01	Unit type	CF	2bit	0-2	1	0
R/W	790	0316	CF02	Summer and winter operation mode	CF	2bit	1-3	1	0
R/W	791	0317	CF03	Condensing unit	CF	1bit	No (0) - YES (1)	1	0
R/W	792	0318	CF04	Number of compressors circuit 1	CF	4bit	1-4	1	0
R/W	793	0319	CF05	Number of compressors circuit 2	CF	4bit	0÷3	1	0
R/W	794	031A	CF06	Number of capacity step	CF	4bit	0-3	1	0
R/W	795	031B	CF07	Pressure or temperature condensation	CF	2bit	0-3	1	0
R/W	796	031C	CF08	Pb1 Configuration	CF	byte	0-178	1	0
R/W	797	031D	CF09	Pb2 Configuration	CF	byte	0-178	1	0
R/W	798	031E	CF10	Pb3 Configuration	CF	byte	0-185	1	0
R/W	799	031F	CF11	Pb4 Configuration	CF	byte	0-185	1	0
R/W	800	0320	CF12	Pb5 Configuration	CF	byte	0-178	1	0
R/W	801	0321	CF13	Pb6 Configuration	CF	byte	0-178	1	0
R/W	802	0322	CF14	Pb7 Configuration	CF	byte	0-178	1	0
R/W	803	0323	CF15	Pb8 Configuration	CF	byte	0-178	1	0
R/W	804	0324	CF16	Pb1 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	1	0
R/W	805	0325	CF17	Pb2 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	1	0
R/W	806	0326	CF18	Pb3 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F] [-5,0 ÷ 5,0 bar] [-72 ÷ 72 psi]	1	0
R/W	807	0327	CF19	Pb4 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F] [-5,0 ÷ 5,0 bar] [-72 ÷ 72 psi]	1	0
R/W	808	0328	CF20	Pb5 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	1	0
R/W	809	0329	CF21	Pb6 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	1	0
R/W	810	032A	CF22	Pb7 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	1	0
R/W	811	032B	CF23	Pb8 calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	1	0
R/W	812	032C	CF24	Pb3: minimum pressure value	CF	word	[-1,0÷50.0 bar] [-14÷725 psi]	[0.1][1]	[1][0]
R/W	813	032D	CF25	Pb3: maximum pressure value	CF	word	[-1,0÷50.0 bar] [-14÷725 psi]	[0.1][1]	[1][0]
R/W	814	032E	CF26	Pb4: minimum pressure value	CF	word	[-1,0÷50.0 bar] [-14÷725 psi]	[0.1][1]	[1][0]
R/W	815	032F	CF27	Pb4: maximum pressure value	CF	word	[-1,0÷50.0 bar] [-14÷725 psi]	[0.1][1]	[1][0]
R/W	816	0330	CF28	Pb5: minimum pressure value	CF	word	[-1,0÷50.0 bar] [-14÷725 psi]	[0.1][1]	[1][0]
R/W	817	0331	CF29	Pb5: maximum pressure value	CF	word	[-1,0÷50.0 bar] [-14÷725 psi]	[0.1][1]	[1][0]
R/W	818	0332	CF30	ID1 configuration	CF	byte	0-150	1	0
R/W	819	0333	CF31	ID2 configuration	CF	byte	0-150	1	0
R/W	820	0334	CF32	ID3 configuration	CF	byte	0-150	1	0
R/W	821	0335	CF33	ID4 configuration	CF	byte	0-150	1	0
R/W	822	0336	CF34	ID5 configuration	CF	byte	0-150	1	0
R/W	823	0337	CF35	ID6 configuration	CF	byte	0-150	1	0
R/W	824	0338	CF36	ID7 configuration	CF	byte	0-150	1	0
R/W	825	0339	CF37	ID8 configuration	CF	byte	0-150	1	0
R/W	826	033A	CF38	ID9 configuration	CF	byte	0-150	1	0
R/W	827	033B	CF39	ID10 configuration	CF	byte	0-150	1	0
R/W	828	033C	CF40	ID11 configuration	CF	byte	0-150	1	0
R/W	829	033D	CF41	RL1 configuration	CF	byte	0-148	1	0
R/W	830	033E	CF42	RL2 configuration	CF	byte	0-148	1	0
R/W	831	033F	CF43	RL3 configuration	CF	byte	0-148	1	0
R/W	832	0340	CF44	RL4 configuration	CF	byte	0-148	1	0
R/W	833	0341	CF45	RL5 configuration	CF	byte	0-148	1	0
R/W	834	0342	CF46	RL6 configuration	CF	byte	0-148	1	0
R/W	835	0343	CF47	RL7 configuration	CF	byte	0-148	1	0
R/W	836	0344	CF48	RL8 configuration	CF	byte	0-148	1	0
R/W	837	0345	CF49	0-10V or 4-20mA selection	CF	2bit	0-1	1	0
R/W	838	0346	CF50	OUT 1 configuration	CF	byte	0-109	1	0

R/W	839	0347	CF51	output not available	CF	byte	0-109	1	0
R/W	840	0348	CF52	OUT 2 configuration	CF	byte	0-111	1	0
R/W	841	0349	CF53	OUT 3 configuration	CF	byte	0-111	1	0
R/W	842	034A	CF54	Remote keyboard 1 configuration	CF	4bit	0-2	1	0
R/W	843	034B	CF55	Remote keyboard 2 configuration	CF	4bit	0-2	1	0
R/W	844	034C	CF56	Remote keyboard 1 probe calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	[0.1][1]	[1][0]
R/W	845	034D	CF57	Remote keyboard 2 probe calibration	CF	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	[0.1][1]	[1][0]
R/W	846	034E	CF58	Summer / winter symbol selection	CF	1bit	0-1	1	0
R/W	847	034F	CF59	Summer / winter selection	CF	2bit	0-2	1	0
R/W	848	0350	CF60	Change over setpoint	CF	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	849	0351	CF61	Change over differential	CF	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	850	0352	CF62	°C or °F selection	CF	1bit	0÷1	1	0
R/W	851	0353	CF63	Power supply frequency	CF	2bit	0-2	1	0
R/W	852	0354	CF64	Serial address	CF	byte	1-247	1	0
	853	0355	CF65	Firmware Release	CF	lock			
R	854	0356	CF66	Eeprom parameter map	CF	word	0-999	1	0
R/W	855	0357	CF67	Compressor 1 capacity	CF	byte	0-100	1	0
R/W	856	0358	CF68	Compressor 2 capacity	CF	byte	0-100	1	0
R/W	857	0359	CF69	Compressor 3 capacity	CF	byte	0-100	1	0
R/W	858	035A	CF70	Compressor 4 capacity	CF	byte	0-100	1	0
	859	035B	CF71	NU	CF	byte			
	860	035C	CF72	NU	CF	byte			
R/W	861	035D	CF73	Number of starts per hour of the compressor	CF	byte	0-15	1	0
R/W	862	035E	CF74	Compressor: enabled in winter and/or summer	CF	2bit	0-2	1	0
R/W	863	035F	CF75	Enable hybrid exchangers	CF	1bit	No (0) - YES (1)	1	0
R/W	864	0360	CF76	Buzzer enabled	CF	1bit	No (0) - YES (1)	1	0
R/W	865	0361	CF77	Chiller mode selection	CF	2bit	1-3	1	0
R/W	866	0362	CF78	expansion device presence	CF	1bit	No (0) - YES (1)	1	0
R/W	867	0363	CF79	electronic valve circ 1 presence	CF	1bit	No (0) - YES (1)	1	0
R/W	868	0364	CF80	electronic valve circ 2 presence	CF	1bit	No (0) - YES (1)	1	0
R/W	869	0365	CF81	electronic valve lan address	CF	byte	0-15	1	0
R/W	870	0366	CF82	LP probes on electronic Valve	CF	1bit	No (0) - YES (1)	1	0
R/W	871	0367	CF83	regulation delay after start valve signal	CF	byte	0-250	1	0
R/W	872	0368	CF84	Visograph presence	CF	1bit	No (0) - YES (1)	1	0
R/W	873	0369	EI01	expansion device lan address	EI	byte	0-15	1	0
R/W	874	036A	EI02	expansion device Pb1 Configuration	EI	byte	0-178	1	0
R/W	875	036B	EI03	expansion device Pb2 Configuration	EI	byte	0-178	1	0
R/W	876	036C	EI04	expansion device Pb3 Configuration	EI	byte	0-178	1	0
R/W	877	036D	EI05	expansion device Pb4 Configuration	EI	byte	0-185	1	0
R/W	878	036E	EI06	expansion device Pb5 Configuration	EI	byte	0-185	1	0
R/W	879	036F	EI07	expansion device Pb6 Configuration	EI	byte	0-178	1	0
R/W	880	0370	EI08	expansion device Pb7 Configuration	EI	byte	0-178	1	0
R/W	881	0371	EI09	expansion device Pb8 Configuration	EI	byte	0-178	1	0
R/W	882	0372	EI10	expansion device Pb1 calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	[0.1][1]	[1][0]
R/W	883	0373	EI11	expansion device Pb2calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	[0.1][1]	[1][0]
R/W	884	0374	EI12	expansion device Pb3 calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F] [-5,0 ÷ 5,0 bar] [-72 ÷ 72 psi]	[0.1][1]	[1][0]
R/W	885	0375	EI13	expansion device Pb4 calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F] [-5,0 ÷ 5,0 bar] [-72 ÷ 72 psi]	[0.1][1]	[1][0]
R/W	886	0376	EI14	expansion device Pb5 calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F] [-5,0 ÷ 5,0 bar] [-72 ÷ 72 psi]	[0.1][1]	[1][0]
R/W	887	0377	EI15	expansion device Pb6 calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	[0.1][1]	[1][0]
R/W	888	0378	EI16	expansion device Pb7 calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	[0.1][1]	[1][0]
R/W	889	0379	EI17	expansion device Pb8 calibration	EI	byte	[-12.0 ÷ 12.0 °C] [-21 ÷ 21 °F]	[0.1][1]	[1][0]
R/W	890	037A	EI18	expansion device Pb3: minimum pressure value	EI	word	[-1,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	891	037B	EI19	expansion device Pb3: maximum pressure value	EI	word	[-1,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	892	037C	EI20	expansion device Pb4: minimum pressure value	EI	word	[-1,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	893	037D	EI21	expansion device Pb4: maximum pressure value	EI	word	[-1,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	894	037E	EI22	expansion device Pb5: minimum pressure value	EI	word	[-1,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	895	037F	EI23	expansion device Pb5: maximum pressure value	EI	word	[-1,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	896	0380	EI24	expansion device ID1 configuration	EI	byte	0-150	1	0
R/W	897	0381	EI25	expansion device ID2 configuration	EI	byte	0-150	1	0
R/W	898	0382	EI26	expansion device ID3 configuration	EI	byte	0-150	1	0
R/W	899	0383	EI27	expansion device ID4 configuration	EI	byte	0-150	1	0
R/W	900	0384	EI28	expansion device ID5 configuration	EI	byte	0-150	1	0
R/W	901	0385	EI29	expansion device ID6 configuration	EI	byte	0-150	1	0
R/W	902	0386	EI30	expansion device ID7 configuration	EI	byte	0-150	1	0
R/W	903	0387	EI31	expansion device ID8 configuration	EI	byte	0-150	1	0
R/W	904	0388	EI32	expansion device ID9 configuration	EI	byte	0-150	1	0
R/W	905	0389	EI33	expansion device RL1 configuration	EI	byte	0-148	1	0
R/W	906	038A	EI34	expansion device RL2 configuration	EI	byte	0-148	1	0
R/W	907	038B	EI35	expansion device RL3 configuration	EI	byte	0-148	1	0
R/W	908	038C	EI36	expansion device RL4 configuration	EI	byte	0-148	1	0
R/W	909	038D	EI37	expansion device RL5 configuration	EI	byte	0-148	1	0
R/W	910	038E	EI38	expansion device RL6 configuration	EI	byte	0-148	1	0
R/W	911	038F	EI39	expansion device RL7 configuration	EI	byte	0-148	1	0
R/W	912	0390	EI40	expansion device 0-10V / 4-20mA output selection	EI	1bit	0-1	1	0
R/W	913	0391	EI41	expansion device OUT 1 configuration	EI	byte	0-109	1	0
R/W	914	0392	EI42	expansion device OUT 2 configuration	EI	byte	0-111	1	0
R/W	915	0393	EI43	expansion device OUT 3 configuration	EI	byte	0-111	1	0
R/W	916	0394	Sd01	Dynamic set point: summer offset	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	917	0395	Sd02	Dynamic set point: winter offset	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	918	0396	Sd03	Dynamic set point: summer outside temperature	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	919	0397	Sd04	Dynamic set point: winter outside temperature	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	920	0398	Sd05	Dynamic set point: summer differential temperature	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	921	0399	Sd06	Dynamic set point: winter differential temperature	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	922	039A	Sd07	Dynamic set point: summer offset analog 1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	923	039B	Sd08	Dynamic set point: winter offset analog 1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	924	039C	Sd09	Summer outside temperature analog 1	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]

R/W	925	039D	Sd10	Winter outside temperature analog 1	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	926	039E	Sd11	Summer outside temperature differential analog 1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	927	039F	Sd12	Winter outside temperature differential analog 1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	928	03A0	Sd13	Dynamic set point: summer offset analog 2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	929	03A1	Sd14	Dynamic set point: winter offset analog 2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	930	03A2	Sd15	Summer outside temperature analog 2	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	931	03A3	Sd16	Winter outside temperature analog 2	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	932	03A4	Sd17	Summer outside temperature differential analog 2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	933	03A5	Sd18	Winter outside temperature differential analog 2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	934	03A6	Sd19	Dynamic set point: summer offset relay AUX1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	935	03A7	Sd20	Dynamic set point: winter offset relay AUX1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	936	03A8	Sd21	Summer outside temperature relay AUX1	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	937	03A9	Sd22	Winter outside temperature relay AUX1	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	938	03AA	Sd23	Summer temperature differential relay AUX1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	939	03AB	Sd24	Winter temperature differential relay AUX1	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	940	03AC	Sd25	Dynamic set point: summer offset relay AUX2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	941	03AD	Sd26	Dynamic set point: winter offset relay AUX2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	942	03AE	Sd27	Summer outside temperature relay AUX2	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	943	03AF	Sd28	Winter outside temperature relay AUX2	Sd	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	944	03B0	Sd29	Summer temperature differential relay AUX2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	945	03B1	Sd30	Winter temperature differential relay AUX2	Sd	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	946	03B2	ES01	First band programming: start time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	947	03B3	ES02	First band programming: end time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	948	03B4	ES03	Second band programming: start time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	949	03B5	ES04	Second band programming: end time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	950	03B6	ES05	Third band programming: start time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	951	03B7	ES06	Third band programming: end time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	952	03B8	ES07	Monday	ES	byte	0-0 (0) - 7-7 (63)	1	0
R/W	953	03B9	ES08	Tuesday	ES	byte	0-0 (0) - 7-7 (63)	1	0
R/W	954	03BA	ES09	Wednesday	ES	byte	0-0 (0) - 7-7 (63)	1	0
R/W	955	03BB	ES10	Thursday	ES	byte	0-0 (0) - 7-7 (63)	1	0
R/W	956	03BC	ES11	Friday	ES	byte	0-0 (0) - 7-7 (63)	1	0
R/W	957	03BD	ES12	Saturday	ES	byte	0-0 (0) - 7-7 (63)	1	0
R/W	958	03BE	ES13	Sunday	ES	byte	0-0 (0) - 7-7 (63)	1	0
R/W	959	03BF	ES14	Energy Saving: offset in summer mode	ES	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	960	03C0	ES15	Energy Saving: differential in summer mode	ES	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	961	03C1	ES16	Energy Saving: offset in winter mode	ES	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	962	03C2	ES17	Energy Saving: differential in winter mode	ES	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	963	03C3	ES18	Operation time when machine ON by keyboard	ES	byte	1-250	1	0
R/W	964	03C4	ES19	Sanitary water first band programming: start time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	965	03C5	ES20	Sanitary water first band programming: end time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	966	03C6	ES21	Sanitary water second band programming: start time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	967	03C7	ES22	Sanitary water second band programming: end time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	968	03C8	ES23	Sanitary water third band programming: start time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	969	03C9	ES24	Sanitary water third band programming: end time	ES	byte	0:00 (0) - 24,00 (144)	1	0
R/W	970	03CA	ES25	Sanitary water on Monday	ES	4bit	0-7	1	0
R/W	971	03CB	ES26	Sanitary water on Tuesday	ES	4bit	0-7	1	0
R/W	972	03CC	ES27	Sanitary water on Wednesday	ES	4bit	0-7	1	0
R/W	973	03CD	ES28	Sanitary water on Thursday	ES	4bit	0-7	1	0
R/W	974	03CE	ES29	Sanitary water on Friday	ES	4bit	0-7	1	0
R/W	975	03CF	ES30	Sanitary water on Saturday	ES	4bit	0-7	1	0
R/W	976	03D0	ES31	Sanitary water on Sunday	ES	4bit	0-7	1	0
R/W	977	03D1	ES32	Sanitary water offset	ES	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	978	03D2	ES33	Sanitary water differential	ES	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	979	03D3	Cr01	Compressor rack operation mode	Cr	2bit	0-2	1	0
R/W	980	03D4	Cr02	Set point if regulation by suction probe	Cr	word	Cr03-Cr04	1	0
R/W	981	03D5	Cr03	Compressor rack minimum set point	Cr	word	0- Cr02	[0.1][1]	[1][0]
R/W	982	03D6	Cr04	Compressor rack maximum set point	Cr	word	Cr02- (50.0 bar - 725 PSI)	1	0
R/W	983	03D7	Cr05	Compressor rack regulation band	Cr	byte	[0,1 ÷ 14.0 bar] [1÷ 203 PSI]	[0.1][1]	[1][0]
R/W	984	03D8	Cr06	Compressor rack energy saving set point	Cr	byte	[0,0 ÷ 14.0 bar] [0÷ 203 PSI]	[0.1][1]	[1][0]
R/W	985	03D9	Cr07	Compressor rack energy saving differential	Cr	byte	[0,1 ÷ 14.0 bar] [1÷ 203 PSI]	[0.1][1]	[1][0]
R/W	986	03DA	Cr08	Compressors in ON in case of probe failure	Cr	4bit	0-6	1	0
R/W	987	03DB	Cr09	Fan On in case of probe failure	Cr	4bit	0-4	1	0
R/W	988	03DC	CO01	Minimum ON time of the compressor	CO	byte	0-250 (x10 sec)	1	0
R/W	989	03DD	CO02	Minimum OFF time of the compressor	CO	byte	0-250 (x10 sec)	1	0
R/W	990	03DE	CO03	Switch on delay between two compressors	CO	byte	1-250 (sec)	1	0
R/W	991	03DF	CO04	Switch OFF delay between two compressors	CO	byte	0-250 (sec)	1	0
R/W	992	03E0	CO05	Stand-by time after the power supply	CO	byte	0-250 (x10 sec)	1	0
R/W	993	03E1	CO06	Capacity step operation mode	CO	2bit	0-3	1	0
R/W	994	03E2	CO07	First capacity step operation mode	CO	2bit	0-3	1	0
R/W	995	03E3	CO08	ON time of the solenoid valve intermittent	CO	byte	0-250 (sec)	1	0
R/W	996	03E4	CO09	OFF time of the solenoid valve intermittent	CO	byte	0-250 (sec)	1	0
R/W	997	03E5	CO10	Compressor start-up operation mode	CO	2bit	0-1	1	0
R/W	998	03E6	CO11	Part - winding start-up time	CO	byte	0-100 (0,1 sec)	1	0
R/W	999	03E7	CO12	Star-delta delay time	CO	byte	0-50 (0,1 sec)	1	0
R/W	1000	03E8	CO13	By-pass gas valve start-up time	CO	byte	0÷250(sec.)	1	0
R/W	1001	03E9	CO14	Compressors start up logic activation	CO	2bit	0-2	1	0
R/W	1002	03EA	CO15	Circuit balancing	CO	1bit	No (0) - YES (1)	1	0

R/W	1003	03EB	CO16	Evaporator pump/supply fan operation mode	CO	2bit	0-2	1	0
R/W	1004	03EC	CO17	Delay between pump and comp. activation	CO	byte	1-250 (x10 sec)	1	0
R/W	1005	03ED	CO18	Switching OFF delay of the evaporator pump	CO	byte	0÷250 (min)	1	0
R/W	1006	03EE	CO19	Working hours before evaporator pump rotation	CO	word	0-999 (x 10h)	1	0
R/W	1007	03EF	CO20	Transition time during evaporator pump rotation	CO	byte	0÷250(sec.)	1	0
R/W	1008	03F0	CO21	Condenser pump operation mode	CO	2bit	0-2	1	0
R/W	1009	03F1	CO22	Not used	CO	1bit			
R/W	1010	03F2	CO23	Switching OFF delay of the condenser pump	CO	byte	0÷250(min)	1	0
R/W	1011	03F3	CO24	Working hours before condenser pump rotation	CO	word	0-999 (x 10h)	1	0
R/W	1012	03F4	CO25	Transition time during condenser pump rotation	CO	byte	0÷250(sec)	1	0
R/W	1013	03F5	CO26	Compressor 1 timer	CO	word	0-999 (x 10h)	1	0
R/W	1014	03F6	CO27	Compressor 2 timer	CO	word	0-999 (x 10h)	1	0
R/W	1015	03F7	CO28	Compressor 3 timer	CO	word	0-999 (x 10h)	1	0
R/W	1016	03F8	CO29	Compressor 4 timer	CO	word	0-999 (x 10h)	1	0
R/W	1017	03F9	CO30	Compressor 5 timer	CO	word	0-999 (x 10h)	1	0
R/W	1018	03FA	CO31	Compressor 6 timer	CO	word	0-999 (x 10h)	1	0
R/W	1019	03FB	CO32	Evaporator pump/supply fan timer	CO	word	0-999 (x 10h)	1	0
R/W	1020	03FC	CO33	2nd evaporator pump timer	CO	word	0-999 (x 10h)	1	0
R/W	1021	03FD	CO34	Condenser pump timer	CO	word	0-999 (x 10h)	1	0
R/W	1022	03FE	CO35	2nd Condenser pump timer	CO	word	0-999 (x 10h)	1	0
R/W	1023	03FF	CO36	Pump down operating mode	CO	4bit	0-4	1	0
R/W	33024	8100	CO37	Pump-down pressure setpoint	CO	word	[0÷50.0 bar] [0÷725 psi]	[0.1][1]	[1][0]
R/W	33025	8101	CO38	Pump-down pressure differential	CO	byte	[0,1÷12.0 bar] [1÷174 psi]	[0.1][1]	[1][0]
R/W	33026	8102	CO39	Pump-down maximum time	CO	byte	0÷250(sec.)	1	0
R/W	33027	8103	CO40	Unloading: evaporator inlet set point	CO	word	[-50.0 ÷ 110.0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33028	8104	CO41	Unloading: evaporator inlet differential	CO	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33029	8105	CO42	Delay to enable the unloading	CO	byte	1-250 (x10 sec)	1	0
R/W	33030	8106	CO43	Unloading maximum time (evapor. inlet)	CO	byte	0÷250(min.)	1	0
R/W	33031	8107	CO44	Unloading: condenser press/temp set point	CO	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33032	8108	CO45	Unloading: condenser pres/temp differential	CO	byte	[0,1 ÷ 25.0 °C] [1 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33033	8109	CO46	Unloading: evaporator press/temp set point	CO	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [-14 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33034	810A	CO47	Unloading: evaporat. pres/temp differential	CO	byte	[0,1 ÷ 25.0 °C] [1 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33035	810B	CO48	Unloading maximum time (temper./pressure)	CO	byte	1÷250(min)	1	0
R/W	33036	810C	CO49	Compressors enabled during unloading	CO	4bit	1-3	1	0
R/W	33037	810D	CO50	Unloading minimum time	CO	byte	0÷250(sec.)	1	0
R/W	33038	810E	CO51	Liquid injection valve set point	CO	word	[0.0 ÷ 150.0 °C] [32 ÷ 302 °F]	[0.1][1]	[1][0]
R/W	33039	810F	CO52	Liquid injection valve differential	CO	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33040	8110	CO53	Time in neutral zone to insert resource	CO	byte	0÷250(x 10 min)	1	0
R/W	33041	8111	CO54	Time in neutral zone without rotation	CO	word	0-999 (h)	1	0
R/W	33042	8112	CO55	Unloading: set point evaporator water temperature	CO	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33043	8113	CO56	Unloading differential evaporat. water temp	CO	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33044	8114	CO57	Unloading max time (evaporator water temp)	CO	byte	0÷250(min)	1	0
R/W	33045	8115	CO58	Pump down: time during the switching on	CO	byte	0÷250(sec)	1	0
R/W	33046	8116	CO59	Pump down: time during the switching OFF	CO	byte	0÷250(sec)	1	0
R/W	33047	8117	CO60	Compressor inverter: time at max capacity	CO	byte	0÷250(sec)	1	0
R/W	33048	8118	CO61	Compressor inverter: capacity start-up	CO	byte	0-100	1	0
R/W	33049	8119	CO62	Delay capacity variation at start-up	CO	byte	0÷250(sec)	1	0
R/W	33050	811A	CO63	Capacity to starting counting CO64 time	CO	byte	0-100 (%)	1	0
R/W	33051	811B	CO64	Maximum working time under CO63 capacity	CO	byte	0÷250(x 10 min)	1	0
R/W	33052	811C	CO65	Forcing time at the maximum capacity	CO	byte	0÷250(sec)	1	0
R/W	33053	811D	CO66	Compressor inverter: maximum ON time	CO	word	0-999 (h)	1	0
R/W	33054	811E	CO67	Minimum capacity of the compressor 1	CO	byte	1-CO68 (%)	1	0
R/W	33055	811F	CO68	Maximum capacity of the compressor 1	CO	byte	CO67-100 (%)	1	0
R/W	33056	8120	CO69	Minimum capacity of the compressor 2	CO	byte	1-CO70 (%)	1	0
R/W	33057	8121	CO70	Maximum capacity of the compressor 2	CO	byte	CO69-100 (%)	1	0
R/W	33058	8122	CO71	Delay capacity variation	CO	byte	1÷250(sec)	1	0
R/W	33059	8123	CO72	Working time of the compressor for rotation	CO	byte	0÷250(min)	1	0
R/W	33060	8124	CO73	Sanitary water pump timer	CO	word	0-999 (X 10 h)	1	0
R/W	33061	8125	CO74	Solar panel water pump timer	CO	word	0-999 (X 10 h)	1	0
R/W	33062	8126	CO75	Reversing valve switching time	CO	byte	0÷250(sec)	1	0
R/W	33063	8127	CO76	Chiller maximum number of steps	CO	4bit	1-15	1	0
R/W	33064	8128	CO77	Winter maximum number of steps	CO	4bit	1-15	1	0
R/W	33065	8129	CO78	Sanitary water maximum number of steps	CO	4bit	1-15	1	0
R/W	33066	812A	CO79	Compressor inverter chiller maximum capacity	CO	byte	1-100 (%)	1	0
R/W	33067	812B	CO80	Compressor inverter winter maximum capacity	CO	byte	1-100 (%)	1	0
R/W	33068	812C	CO81	Compressor inverter sanitary water maximum capacity	CO	byte	1-100 (%)	1	0
R/W	33069	812D	CO82	Winter outside temperature to reduce compressor inverter capacity	CO	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33070	812E	CO83	Winter outside differential to reduce compressor inverter capacity	CO	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33071	812F	CO84	Compressor inverter maximun reduced capacity	CO	byte	0-100 (%)	1	0
R/W	33072	8130	CO85	OFF time evaporator pump at set point condition	CO	byte	0÷250(x 10 min)	1	0
R/W	33073	8131	CO86	OFF time evaporator pump in off state	CO	byte	0÷250(x 10 ore)	1	0

Procedura per la lettura e scrittura dei parametri con indirizzo uguale o maggiore di 33024:

1) Abilitare la scrittura estesa dei parametri: all'indirizzo 1795 scrivere il valore 1

2) Leggere o modificare il valore del parametro

3) Se non sono previste scritture successive, disabilitare la scrittura estesa dei parametri: all'indirizzo 1795 scrivere il valore 0

R/W	33074	8132	CO87	ON time evaporator pump	CO	byte	0÷250(x 10 sec)	1	0
R/W	33075	8133	CO88	OFF time condenser pump at set point condition	CO	byte	0÷250(x 10 min)	1	0
R/W	33076	8134	CO89	OFF time condenser pump in off state	CO	byte	0÷250(x 10 ore)	1	0
R/W	33077	8135	CO90	ON time condenser pump	CO	byte	0÷250(x 10 sec)	1	0
R/W	33078	8136	CO91	Compressor ON ON delay time	CO	byte	0÷250(x 10 sec)	1	0
R/W	33079	8137	CO92	solenoid valve on - compressor on delay	CO	byte	0÷250(sec)	1	0
R/W	33080	8138	CO93	compressor OFF- solenoid valve OFF delay	CO	byte	0÷250(sec)	1	0
R/W	33081	8139	CO94	Compressor inverter defrost maximum capacity	CO	byte	1-100 (%)	1	0
R/W	33082	813A	CO95	FC pump timer	CO	word	0-999 (X 10 h)	1	0
R/W	33083	813B	CO96	Compressor inverter unloading maximum capacity	CO	byte	0-100 (%)	1	0
R/W	33084	813C	US01	Auxiliary relay 1 operating mode	uS	4bit	0-4	1	0
R/W	33085	813D	US02	Auxiliary relay 1 probe selection	uS	byte	1-20	1	0
R/W	33086	813E	US03	Auxiliary relay 1 summer minimum set point	uS	word	[-50.0 ÷ US05 °C] [-58 ÷ US05 °F] [0,0 ÷ US05 bar] [0÷ US05 psi]	[0.1][1]	[1][0]
R/W	33087	813F	US04	Auxiliary relay 1 summer maximum set point	uS	word	[US05 ÷ 110,0 °C] [US05 ÷ 230 °F] [US05 ÷ 50,0 bar] [US05 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33088	8140	US05	Auxiliary relay 1 summer set point	uS	word	US03 - US04	[0.1][1]	[1][0]
R/W	33089	8141	US06	Auxiliary relay 1 winter minimum set point	uS	word	[-50.0 ÷ US08 °C] [-58 ÷ US08 °F] [0,0 ÷ US08 bar] [0÷ US08 psi]	[0.1][1]	[1][0]
R/W	33090	8142	US07	Auxiliary relay 1 winter maximum set point	uS	word	[US08 ÷ 110,0 °C] [US08 ÷ 230 °F] [US08 ÷ 50,0 bar] [US08 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33091	8143	US08	Auxiliary relay 1 winter set point	uS	word	US06-US07	[0.1][1]	[1][0]
R/W	33092	8144	US09	Auxiliary relay 1 summer differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33093	8145	US10	Auxiliary relay 1 winter differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33094	8146	US11	Auxiliary relay 2 operating mode	uS	4bit	0-4	1	0
R/W	33095	8147	US12	Auxiliary relay 2 probe selection	uS	byte	1-20	1	0
R/W	33096	8148	US13	Auxiliary relay 2 summer minimum set point	uS	word	[-50.0 ÷ US15 °C] [-58 ÷ US15 °F] [0,0 ÷ US15 bar] [0÷ US15 psi]	[0.1][1]	[1][0]
R/W	33097	8149	US14	Auxiliary relay 2 summer maximum set point	uS	word	[US15 ÷ 110,0 °C] [US15 ÷ 230 °F] [US15 ÷ 50,0 bar] [US15 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33098	814A	US15	Auxiliary relay 2 summer set point	uS	word	US13 - US14	[0.1][1]	[1][0]
R/W	33099	814B	US16	Auxiliary relay 2 winter minimum set point	uS	word	[-50.0 ÷ US18 °C] [-58 ÷ US18 °F] [0,0 ÷ US18 bar] [0÷ US18 psi]	[0.1][1]	[1][0]
R/W	33100	814C	US17	Auxiliary relay 2 winter maximum set point	uS	word	[US18 ÷ 110,0 °C] [US18 ÷ 230 °F] [US18 ÷ 50,0 bar] [US18 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33101	814D	US18	Auxiliary relay 2 winter set point	uS	word	US16-US17	[0.1][1]	[1][0]
R/W	33102	814E	US19	Auxiliary relay 2 summer differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33103	814F	US20	Auxiliary relay 2 winter differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33104	8150	US21	Maximum operating time of auxiliary realys	uS	byte	0-250 (min)	1	0
R/W	33105	8151	US22	Analog output 1 operating mode	uS	4bit	0-4	1	0
R/W	33106	8152	US23	Analog output 1 probe selection	uS	byte	1-20	1	0
R/W	33107	8153	US24	Analog output 1 summer minimum set point	uS	word	[-50.0 ÷ US26 °C] [-58 ÷ US26 °F] [0,0 ÷ US26 bar] [0÷ US26 psi]	[0.1][1]	[1][0]
R/W	33108	8154	US25	Analog output 1 summer maximum set point	uS	word	[US26 ÷ 110,0 °C] [US26 ÷ 230 °F] [US26 ÷ 50,0 bar] [US26 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33109	8155	US26	Analog output 1 summer set point	uS	word	US24 - US25	[0.1][1]	[1][0]
R/W	33110	8156	US27	Analog output 1 winter minimum set point	uS	word	[-50.0 ÷ US28 °C] [-58 ÷ US28 °F] [0,0 ÷ US28 bar] [0÷ US28 psi]	[0.1][1]	[1][0]
R/W	33111	8157	US28	Analog output 1 winter maximum set point	uS	word	[US28 ÷ 110,0 °C] [US28 ÷ 230 °F] [US28 ÷ 50,0 bar] [US28 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33112	8158	US29	Analog output 1 winter set point	uS	word	US27-US28	[0.1][1]	[1][0]
R/W	33113	8159	US30	Analog output 1 summer differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33114	815A	US31	Analog output 1 winter differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33115	815B	US32	Analog output 1 minimum value	uS	byte	0-US33 (%)	1	0
R/W	33116	815C	US33	Analog output 1 maximum value	uS	byte	US32 - 100 (%)	1	0
R/W	33117	815D	US34	Analog output 2 operating mode	uS	4bit	0-4	1	0
R/W	33118	815E	US35	Analog output 2 probe selection	uS	byte	1-20	1	0
R/W	33119	815F	US36	Analog output 2 summer minimum set point	uS	word	[-50.0 ÷ US38 °C] [-58 ÷ US38 °F] [0,0 ÷ US38 bar] [0÷ US38 psi]	[0.1][1]	[1][0]
R/W	33120	8160	US37	Analog output 2 summer maximum set point	uS	word	[US38 ÷ 110,0 °C] [US38 ÷ 230 °F] [US38 ÷ 50,0 bar] [US38 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33121	8161	US38	Analog output 2 summer set point	uS	word	US36-US37	[0.1][1]	[1][0]
R/W	33122	8162	US39	Analog output 2 winter minimum set point	uS	word	[-50.0 ÷ US41 °C] [-58 ÷ US41 °F] [0,0 ÷ US41 bar] [0÷ US41 psi]	[0.1][1]	[1][0]
R/W	33123	8163	US40	Analog output 2 winter maximum set point	uS	word	[US41 ÷ 110,0 °C] [US41 ÷ 230 °F] [US41 ÷ 50,0 bar] [US41 ÷ 725 psi]	[0.1][1]	[1][0]
R/W	33124	8164	US41	Analog output 2 winter set point	uS	word	US39-US40	[0.1][1]	[1][0]
R/W	33125	8165	US42	Analog output 2 summer differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33126	8166	US43	Analog output 2 winter differential	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33127	8167	US44	Analog output 2 minimum value	uS	byte	0-US45 (%)	1	0
R/W	33128	8168	US45	Analog output 2 maximum value	uS	byte	US44 - 100 (%)	1	0
R/W	33129	8169	US46	Analog output 0 under minimum value	uS	1bit	No (0) - YES (1)	1	0
R/W	33130	816A	US47	Summer modulating pump probe 1	uS	byte	0-20	1	0
R/W	33131	816B	US48	Summer modulating pump probe 2	uS	byte	0-20	1	0
R/W	33132	816C	US49	Summer modulating pump maximum output set point	uS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33133	816D	US50	Summer modulating pump band	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33134	816E	US51	Summer modulating pump minimum output	uS	byte	0-US52 (%)	1	0
R/W	33135	816F	US52	Summer modulating pump maximum output	uS	byte	US51 - 100 (%)	1	0
R/W	33136	8170	US53	Winter modulating pump probe 1	uS	byte	0-20	1	0
R/W	33137	8171	US54	Winter modulating pump probe 2	uS	byte	0-20	1	0
R/W	33138	8172	US55	Winter modulating pump maximum output set point	uS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33139	8173	US56	Winter modulating pump band	uS	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33140	8174	US57	Winter modulating pump minimum output	uS	byte	0-US58 (%)	1	0
R/W	33141	8175	US58	Winter modulating pump maximum output	uS	byte	US57 - 100 (%)	1	0
R/W	33142	8176	US59	Modulating pump FC output	uS	byte	0-100 (%)	1	0
R/W	33143	8177	US60	Compressor OFF modulating pump output	uS	byte	0-100 (%)	1	0
R/W	33144	8178	US61	Auxiliary relay 1 enabling	uS	2bit	1-3	1	0
R/W	33145	8179	US62	Auxiliary relay 2 enabling	uS	2bit	1-3	1	0
R/W	33146	817A	US63	Auxiliary analog output 1 enabling	uS	2bit	1-3	1	0
R/W	33147	817B	US64	Auxiliary analog output 2 enabling	uS	2bit	1-3	1	0
R/W	33148	817C	FA01	Condenser fan configuration	FA	4bit	0-4	1	0

R/W	33149	817D	FA02	Condenser fan indipendent from compressor	FA	1bit	No (0) - YES (1)	1	0
R/W	33150	817E	FA03	Time at maximum speed of the condenser fan	FA	byte	0-250 (SEC)	1	0
R/W	33151	817F	FA04	Triac pulse length	FA	byte	0-8 (uSec)	1	0
R/W	33152	8180	FA05	Separate ventilation	FA	1bit	No (0) - YES (1)	1	0
R/W	33153	8181	FA06	Summer pre-ventilation time	FA	byte	0-250 (SEC)	1	0
R/W	33154	8182	FA07	Condenser fan: minimum speed in summer mode	FA	byte	0-100 (%)	1	0
R/W	33155	8183	FA08	Condenser fan: maximum speed in summer mode	FA	byte	0-100 (%)	1	0
R/W	33156	8184	FA09	Temperature/pressure for min speed in chiller mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33157	8185	FA10	Temperature/pressure for max speed in chiller mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33158	8186	FA11	Proportional band in chiller mode	FA	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33159	8187	FA12	Cut-OFF differential in chiller mode	FA	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33160	8188	FA13	Cut-OFF override in chiller mode	FA	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33161	8189	FA14	Cut-OFF time delay	FA	byte	0-250 (SEC)	1	0
R/W	33162	818A	FA15	Night speed in chiller mode	FA	byte	0-100 (%)	1	0
R/W	33163	818B	FA16	Minimum speed in winter mode	FA	byte	0-100 (%)	1	0
R/W	33164	818C	FA17	Maximum speed in winter mode	FA	byte	0-100 (%)	1	0
R/W	33165	818D	FA18	Temperature/pressure for min speed in winter mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33166	818E	FA19	Temperature/pressure for max speed in winter mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33167	818F	FA20	Proportional band in winter mode	FA	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33168	8190	FA21	Cut-OFF differential in winter mode	FA	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33169	8191	FA22	Cut-OFF override in winter mode	FA	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33170	8192	FA23	Night speed in winter mode	FA	byte	0-100 (%)	1	0
R/W	33171	8193	FA24	Hot start set point	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33172	8194	FA25	Hot start differential	FA	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33173	8195	FA26	Set point of step 3 in summer mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33174	8196	FA27	Set point of step 4 in summer mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33175	8197	FA28	Set point of step 3 in winter mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33176	8198	FA29	Set point of step 4 in winter mode	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33177	8199	FA30	Winter pre-ventilation time	FA	byte	0-250 (SEC)	1	0
R/W	33178	819A	FA31	Winter post-ventilation time	FA	byte	0-250 (SEC)	1	0
R/W	33179	819B	FA32	Winter post-ventilation outside temperature	FA	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33180	819C	FA33	Winter post-ventilation speed	FA	byte	0-100 (%)	1	0
R/W	33181	819D	FC01	Free - cooling operation mode	Altro	1bit	0-1	1	0
R/W	33182	819E	Ar01	Anti-freeze heater set point in summer mode	Ar	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33183	819F	Ar02	Anti-freeze heater band for in summer mode	Ar	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33184	81A0	Ar03	Anti-freeze heater set point in winter mode	Ar	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33185	81A1	Ar04	Anti-freeze heater band in winter mode	Ar	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33186	81A2	Ar05	Anti-freeze heater enabled during the defrost	Ar	1bit	No (0) - YES (1)	1	0
R/W	33187	81A3	Ar06	Anti-freeze probe selection in summer mode	Ar	4bit	0-4	1	0
R/W	33188	81A4	Ar07	Anti-freeze probe selection in summer mode	Ar	4bit	0-4	1	0
R/W	33189	81A5	Ar08	Anti-freeze condenser probe selection	Ar	4bit	0-5	1	0
R/W	33190	81A6	Ar09	Anti-freeze heater/water pump enabled in OFF/Std-by	Ar	1bit	No (0) - YES (1)	1	0
R/W	33191	81A7	Ar10	Anti-freeze heaters enabled in case of faulty probe	Ar	1bit	No (0) - YES (1)	1	0
R/W	33192	81A8	Ar11	Boiler function operation mode	Ar	2bit	0-2	1	0
R/W	33193	81A9	Ar12	Outside temperature to enable boiler heater	Ar	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33194	81AA	Ar13	Outside temperature differential for boiler	Ar	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33195	81AB	Ar14	Delay to enable the boiler heater	Ar	byte	0-250 (min)	1	0
R/W	33196	81AC	Ar15	Boiler heaters set point in summer mode	Ar	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33197	81AD	Ar16	Boiler heaters differential in summer mode	Ar	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33198	81AE	Ar17	Boiler heaters set point in winter mode	Ar	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33199	81AF	Ar18	Boiler heaters differential in winter mode	Ar	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33200	81B0	Ar19	Outside temperature to stop the compressor	Ar	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33201	81B1	Ar20	Outside temperature differential to switch on comp	Ar	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33202	81B2	Ar21	Anti-freeze alarm probe selection in summer	Ar	4bit	0-4	1	0
R/W	33203	81B3	Ar22	Anti-freeze alarm probe selection in winter	Ar	4bit	0-4	1	0
R/W	33204	81B4	Ar23	Anti-freeze alarm probe for the condenser	Ar	4bit	0-5	1	0
R/W	33205	81B5	Ar24	Water pump/antifreeze alarm enabled in OFF/Std-by	Ar	1bit	No (0) - YES (1)	1	0
R/W	33206	81B6	Ar25	Water pump probe selection for antifreeze	Ar	4bit	0-4	1	0
R/W	33207	81B7	Ar26	Anti-freeze temperature to enable water pump	Ar	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33208	81B8	Ar27	Anti-freeze differ. to disable water pump	Ar	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33209	81B9	dF01	Defrost configuration	dF	4bit	0-5	1	0
R/W	33210	81BA	dF02	Set point temperature/pressure start defrost	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33211	81BB	dF03	Set point temperature/pressure end defrost	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33212	81BC	dF04	Minimum duration of a defrost cycle	dF	byte	0-250 (SEC)	1	0
R/W	33213	81BD	dF05	Maximum duration of a defrost cycle	dF	byte	0-250 (min)	1	0
R/W	33214	81BE	dF06	Defrosting delay between two circuits	dF	byte	0-250 (min)	1	0
R/W	33215	81BF	dF07	Compressor switch-OFF time before defrost	dF	byte	0-250 (SEC)	1	0
R/W	33216	81C0	dF08	Compressor switch-OFF time after defrost	dF	byte	0-250 (SEC)	1	0
R/W	33217	81C1	dF09	Delay time between two defrost same circ.	dF	byte	1-99 (min)	1	0
R/W	33218	81C2	dF10	Combined defrost I circ: temperature to start	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33219	81C3	dF11	Combined defrost I circ: temperature to end	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]

R/W	33220	81C4	dF12	Combined defrost II circ: temperature to start	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33221	81C5	dF13	Combined defrost II circ: temperature to end	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33222	81C6	dF14	All compressors ON if defrost I circuit	dF	1bit	No (0) - YES (1)	1	0
R/W	33223	81C7	dF15	All compressors ON if defrost II circuit	dF	1bit	No (0) - YES (1)	1	0
R/W	33224	81C8	dF16	Delay between compressor activation in defrost	dF	byte	0-250 (sec)	1	0
R/W	33225	81C9	dF17	Condenser fan operation mode in defrost	dF	2bit	0-2	1	0
R/W	33226	81CA	dF18	Pressure/temperature to enable fan during defrost	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33227	81CB	dF19	Time delay before a forced defrost	dF	byte	0-250 (SEC)	1	0
R/W	33228	81CC	dF20	Forced defrost set point	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33229	81CD	dF21	Forced defrost differential	dF	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33230	81CE	dF22	Start defrost procedure in unit 2 circuits	dF	2bit	0-2	1	0
R/W	33231	81CF	dF23	End defrost procedure in unit 2 circuits	dF	2bit	0-2	1	0
R/W	33232	81D0	dF24	Start / stop defrost probe	dF	2bit	0-3	1	0
R/W	33233	81D1	dF25	Supply fan off during defrost	dF	1bit	No (0) - YES (1)	1	0
R/W	33234	81D2	dF26	Condenser fan defrost set point	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33235	81D3	dF27	Hybrid exchangers summer set point 1	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33236	81D4	dF28	Hybrid exchangers summer set point 2	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33237	81D5	dF29	Hybrid exchangers summer differential 1	dF	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33238	81D6	dF30	Hybrid exchangers summer differential 2	dF	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33239	81D7	dF31	Hybrid exchangers winter set point 1	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33240	81D8	dF32	Hybrid exchangers winter set point 2	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33241	81D9	dF33	Hybrid exchangers winter differential 1	dF	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33242	81DA	dF34	Hybrid exchangers winter differential 2	dF	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33243	81DB	dF35	Hybrid exchangers probe	dF	1bit	0-1	1	0
R/W	33244	81DC	dF36	Summer split coil on time at compressor start up	dF	byte	0-250 (SEC)	1	0
R/W	33245	81DD	dF37	Defrost dynamic set offset	dF	word	[-30.0 ÷ 30,0 °C] [-54 ÷ 54 °F] [-14,0 ÷ 14,0 bar] [-203÷203 psi]	[0.1][1]	[1][0]
R/W	33246	81DE	dF38	Defrost dynamic set outside temperature	dF	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33247	81DF	dF39	Defrost dynamic set outside temperature differential	dF	word	[-30,0 ÷ 30,0 °C] [-54 ÷ 54 °F]	[0.1][1]	[1][0]
R/W	33248	81E0	rC01	Recovery function operation mode	rC	2bit	0-2	1	0
R/W	33249	81E1	rC02	Delay time recovery valve	rC	byte	0-250 (SEC)	1	0
R/W	33250	81E2	rC03	Delay time after recovery valve activation	rC	byte	0-250 (SEC)	1	0
R/W	33251	81E3	rC04	Minimum working time of recovery function	rC	byte	0-250 (min)	1	0
R/W	33252	81E4	rC05	Delay between two recovery cycles	rC	byte	0-250 (min)	1	0
R/W	33253	81E5	rC06	Temperature to disable the recovery	rC	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33254	81E6	rC07	Temperature differential to enable recovery	rC	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33255	81E7	rC08	Maximum time with recovery disabled	rC	byte	0-250 (min)	1	0
R/W	33256	81E8	rC09	Condenser fan off in recovery mode	rC	1bit	No (0) - YES (1)	1	0
R/W	33257	81E9	FS01	Sanitary water regulation mode	FS	4bit	0-2	1	0
R/W	33258	81EA	FS02	Sanitary water priority	FS	2bit	0-2	1	0
R/W	33259	81EB	FS03	Sanitary water set point	FS	word	FS05 - FS06	[0.1][1]	[1][0]
R/W	33260	81EC	FS04	Sanitary water proportional band	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33261	81ED	FS05	Sanitary water minimum set point	FS	word	[-50.0÷FS03 °C] [-58÷FS03 °F]	[0.1][1]	[1][0]
R/W	33262	81EE	FS06	Sanitary water maximum set point	FS	word	[FS03÷110 °C] [FS03÷230 °F]	[0.1][1]	[1][0]
R/W	33263	81EF	FS07	Sanitary water: all compr/heaters forced ON	FS	1bit	0-1	1	0
R/W	33264	81F0	FS08	Sanitary water: heaters enabled	FS	1bit	No (0) - YES (1)	1	0
R/W	33265	81F1	FS09	Sanitary water: delay heaters activation	FS	byte	0-250 (min)	1	0
R/W	33266	81F2	FS10	Delay between solenoid valves switching	FS	word	0-999 (SEC)	1	0
R/W	33267	81F3	FS11	Sanitary water: delay of the 4 way valve	FS	word	0-999 (SEC)	1	0
R/W	33268	81F4	FS12	Antilegionella cycle operating mode	FS	2bit	0-2	1	0
R/W	33269	81F5	FS13	Delay between two Antilegionella cycles	FS	byte	0-250 (ore)	1	0
R/W	33270	81F6	FS14	Antilegionella Set point	FS	word	FS15-FS16	[0.1][1]	[1][0]
R/W	33271	81F7	FS15	Min. value of the Antilegionella set point	FS	word	[-50.0÷FS14 °C] [-58÷FS14 °F]	[0.1][1]	[1][0]
R/W	33272	81F8	FS16	Max. value of the Antilegionella set point	FS	word	[FS14÷110 °C] [FS14÷230 °F]	[0.1][1]	[1][0]
R/W	33273	81F9	FS17	Antilegionella cycle: start time	FS	byte	0:00 (0) - 24,00 (144)	1	0
R/W	33274	81FA	FS18	Antilegionella cycle: day of the week	FS	4bit	0-7	1	0
R/W	33275	81FB	FS19	Antilegionella cycle: minimum working time	FS	byte	1-250 (min)	1	0
R/W	33276	81FC	FS20	Antilegionella cycle: heaters proport. band	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33277	81FD	FS21	Differential to enable freecooling function	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33278	81FE	FS22	Differential for free cooling regulation	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33279	81FF	FS23	Solar panel set point	FS	word	FS25-FS26	[0.1][1]	[1][0]
R/W	33280	8200	FS24	Solar panel differential	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33281	8201	FS25	Solar panel minimum set point	FS	word	[-50.0÷FS23 °C] [-58÷FS23 °F]	[0.1][1]	[1][0]
R/W	33282	8202	FS26	Solar panel maximum set point	FS	word	[FS23÷110 °C] [FS23÷230 °F]	[0.1][1]	[1][0]
R/W	33283	8203	FS27	Delay sanitary water valve / water pump	FS	byte	0-250 (SEC)	1	0
R/W	33284	8204	FS28	Delay sanitary water pump / water valve	FS	byte	0-250 (SEC)	1	0
R/W	33285	8205	FS29	Antilegionella cycle: max. operating time	FS	byte	0-250 (SEC)	1	0
R/W	33286	8206	FS30	Sanitary water: security set point	FS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33287	8207	FS31	Sanitary water: security differential	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33288	8208	FS32	Sanitary water: minimum interruption time	FS	byte	0-250 (min)	1	0
R/W	33289	8209	FS33	Sanitary water pump on	FS	1bit	No (0) - YES (1)	1	0
R/W	33290	820A	FS34	FC OFF time	FS	byte	0-250 (min)	1	0
R/W	33291	820B	FS35	FC On time	FS	byte	0-250 (SEC)	1	0
R/W	33292	820C	FS36	FC maximum duration	FS	byte	0-250 (min)	1	0
R/W	33293	820D	FS37	FC set point	FS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33294	820E	FS38	FC band	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33295	820F	FS39	FC valve minimum value	FS	byte	0- FS40 (%)	1	0

R/W	33296	8210	FS40	FC valve maximum value	FS	byte	FS40 - 100 (%)	1	0
R/W	33297	8211	FS41	FC probe 1	FS	byte	0-20	1	0
R/W	33298	8212	FS42	FC probe 2	FS	byte	0-20	1	0
R/W	33299	8213	FS43	FC condensing fan maximum speed outside temperature set point	FS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33300	8214	FS44	FC condensing fan maximum speed outside temperature differential	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33301	8215	FS45	FC condensing fan delay	FS	byte	0-250 (min)	1	0
R/W	33302	8216	FS46	Antilegionella cycle selection	FS	2bit	0-3	1	0
R/W	33303	8217	FS47	Sanitary water evaporator pump disabling	FS	1bit	No (0) - YES (1)	1	0
R/W	33304	8218	FS48	Sanitary water stop probe	FS	byte	0-20	1	0
R/W	33305	8219	FS49	Sanitary water beginning when first step requested	FS	1bit	No (0) - YES (1)	1	0
R/W	33306	821A	FS50	Antilegionella compressor OFF set point	FS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33307	821B	FS51	Antilegionella compressor security time enabled	FS	1bit	No (0) - YES (1)	1	0
R/W	33308	821C	FS52	Low temperature sanitary water set point	FS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33309	821D	FS53	Low temperature sanitary water band	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33310	821E	FS54	Low temperature sanitary water probe	FS	byte	0-20	1	0
R/W	33311	821F	FS55	Solar panel in sanitary water production	FS	2bit	0-2	1	0
R/W	33312	8220	FS56	Solar panel in winter	FS	2bit	0-2	1	0
R/W	33313	8221	FS57	Solar panel in sanitary water production probe	FS	byte	0-20	1	0
R/W	33314	8222	FS58	Solar panel in winter probe	FS	byte	0-20	1	0
R/W	33315	8223	FS59	Solar panel in sanitary water production differential	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33316	8224	FS60	Solar panel in winter differential	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33317	8225	FS61	Solar panel maximum working time	FS	byte	0-250 (min)	1	0
R/W	33318	8226	FS62	FC low temperature stop probe	FS	byte	0-250 (x 10 sec)	1	0
R/W	33319	8227	FS63	FC low temperature stop set point	FS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33320	8228	FS64	FC low temperature stop differential	FS	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33321	8229	AL01	Low pressure alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33322	822A	AL02	Low pressure alarm delay during pump down	AL	byte	0-250 (x 10 sec)	1	0
R/W	33323	822B	AL03	Low pressure alarm set point	AL	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33324	822C	AL04	Low pressure alarm differential	AL	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33325	822D	AL05	Number of low pressure alarm for manual reset	AL	byte	0-16	1	0
R/W	33326	822E	AL06	Low temperature/pressure alarm enabled during defrost	AL	1bit	No (0) - YES (1)	1	0
R/W	33327	822F	AL07	Low temperature/pressure alarm delay during defrost	AL	byte	0-250 (SEC)	1	0
R/W	33328	8230	AL08	Low temperature/pressure alarm enabled in OFF/Std-by	AL	1bit	No (0) - YES (1)	1	0
R/W	33329	8231	AL09	High temperature/pressure alarm set point	AL	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F] [0,0 ÷ 50,0 bar] [0÷ 725 psi]	[0.1][1]	[1][0]
R/W	33330	8232	AL10	High temperature/pressure alarm differential	AL	byte	[0,1 ÷ 25.0 °C] [0 ÷ 45 °F] [0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33331	8233	AL11	Low oil level / low pressure alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33332	8234	AL12	Low oil level alarm delay in normal operat.	AL	byte	0-250 (SEC)	1	0
R/W	33333	8235	AL13	Max number of low oil level / LP alarm	AL	byte	0-16	1	0
R/W	33334	8236	AL14	Evaporator flow switch alarm configuration	AL	2bit	0-3	1	0
R/W	33335	8237	AL15	Evaporator flow switch/supply fan overload delay	AL	byte	0-250 (SEC)	1	0
R/W	33336	8238	AL16	Evaporator flow switch delay to stop water pump	AL	byte	0-250 (SEC)	1	0
R/W	33337	8239	AL17	Evaporator flow switch activation time	AL	byte	0-250 (SEC)	1	0
R/W	33338	823A	AL18	Evaporator flow switch de-activation time	AL	byte	0-250 (SEC)	1	0
R/W	33339	823B	AL19	Compressor overload alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33340	823C	AL20	Maximum number of compressor overload alarm	AL	byte	0-16	1	0
R/W	33341	823D	AL21	Max number of pump down alarm (switch-OFF)	AL	byte	0-16	1	0
R/W	33342	823E	AL22	Max number of pump down alarm (switch-on)	AL	byte	0-16	1	0
R/W	33343	823F	AL23	Pump down on alarm manual reset	AL	1bit	No (0) - YES (1)	1	0
R/W	33344	8240	AL24	Antifreeze minimum setpoint in summer	AL	word	[-50.0÷AL26 °C] [-58÷AL26 °F]	[0.1][1]	[1][0]
R/W	33345	8241	AL25	Antifreeze maximum setpoint in summer	AL	word	[AL26÷110 °C] [AL26÷230 °F]	[0.1][1]	[1][0]
R/W	33346	8242	AL26	Antifreeze setpoint in summer	AL	word	AL24-AL25	[0.1][1]	[1][0]
R/W	33347	8243	AL27	Antifreeze differential in summer	AL	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33348	8244	AL28	Anti-freeze alarm delay in summer	AL	byte	0-250 (SEC)	1	0
R/W	33349	8245	AL29	Max number of antifreeze alarm	AL	byte	0-16	1	0
R/W	33350	8246	AL30	Antifreeze alarm operation mode in summer	AL	1bit	0-1	1	0
R/W	33351	8247	AL31	Antifreeze minimum setpoint in winter	AL	word	[-50.0÷AL33 °C] [-58÷AL33 °F]	[0.1][1]	[1][0]
R/W	33352	8248	AL32	Antifreeze maximum setpoint in winter	AL	word	[AL26÷110 °C] [AL26÷230 °F]	[0.1][1]	[1][0]
R/W	33353	8249	AL33	Antifreeze setpoint in winter	AL	word	AL31-AL32	[0.1][1]	[1][0]
R/W	33354	824A	AL34	Antifreeze differential in winter	AL	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33355	824B	AL35	Antifreeze alarm delay in winter	AL	byte	0-250 (SEC)	1	0
R/W	33356	824C	AL36	Antifreeze delay in normal condition winter	AL	byte	0-250 (SEC)	1	0
R/W	33357	824D	AL37	Max number of antifreeze alarm in winter	AL	byte	0-16	1	0
R/W	33358	824E	AL38	Antifreeze alarm configuration in winter	AL	1bit	0-1	1	0
R/W	33359	824F	AL39	High compressor discharge temperature setpoint	AL	word	[0,0 - 150 °C] [0÷ 302 °F]	[0.1][1]	[1][0]
R/W	33360	8250	AL40	High compressor discharge temperature differential	AL	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33361	8251	AL41	Max number of high compressor discharge temperature	AL	byte	0-16	1	0
R/W	33362	8252	AL42	Max number of generic alarm	AL	byte	0-16	1	0
R/W	33363	8253	AL43	Activation time of generic alarm	AL	byte	0-250 (SEC)	1	0
R/W	33364	8254	AL44	De-activation time of generic alarm	AL	byte	0-250 (x 10 sec)	1	0
R/W	33365	8255	AL45	Alarm relay disabled in OFF/std-by	AL	1bit	No (0) - YES (1)	1	0
R/W	33366	8256	AL46	Password reset alarm log/comp. overload alarm	AL	word	0-999	1	0
R/W	33367	8257	AL47	Compressor overload stops circuit	AL	1bit	No (0) - YES (1)	1	0
R/W	33368	8258	AL48	Compressor overload alarm enabled if compressor OFF	AL	1bit	No (0) - YES (1)	1	0
R/W	33369	8259	AL49	Oil level alarm enabled if compressor OFF	AL	1bit	No (0) - YES (1)	1	0
R/W	33370	825A	AL50	Generic alarm 2 operation mode	AL	1bit	0-1	1	0
R/W	33371	825B	AL51	Max number of generic alarm 2	AL	byte	0-16	1	0

R/W	33372	825C	AL52	Activation time of generic alarm 2	AL	byte	0-250 (SEC)	1	0
R/W	33373	825D	AL53	De-activation time of generic alarm 2	AL	byte	0-250 (x 10 sec)	1	0
R/W	33374	825E	AL54	Max number of condenser HP/ HT alarms	AL	byte	0-16	1	0
R/W	33375	825F	AL55	Condenser flow switch alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33376	8260	AL56	Condenser flow switch delay to stop pump	AL	byte	0-250 (SEC)	1	0
R/W	33377	8261	AL57	Condenser flow switch activation time	AL	byte	0-250 (SEC)	1	0
R/W	33378	8262	AL58	Condenser flow switch de-activation time	AL	byte	0-250 (SEC)	1	0
R/W	33379	8263	AL59	Max number of high water inlet temperature	AL	byte	0-16	1	0
R/W	33380	8264	AL60	High water inlet temperature alarm delay	AL	byte	0-250 (x 10 sec)	1	0
R/W	33381	8265	AL61	Set point high water inlet temperature	AL	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33382	8266	AL62	Differential high water inlet temperature	AL	byte	[0,1 ÷ 25.0 °C] [1÷ 45 °F]	[0.1][1]	[1][0]
R/W	33383	8267	AL63	High water inlet temperature selec. probe	AL	byte	0-20	1	0
R/W	33384	8268	AL64	Low pressure alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33385	8269	AL65	Sanitary water flow switch alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33386	826A	AL66	Sanitary water flow switch delay to stop pump	AL	byte	0-250 (SEC)	1	0
R/W	33387	826B	AL67	Sanitary water flow switch activation time	AL	byte	0-250 (SEC)	1	0
R/W	33388	826C	AL68	Sanitary water flow switch de-activation time	AL	byte	0-250 (SEC)	1	0
R/W	33389	826D	AL69	Solar panel flow switch alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33390	826E	AL70	Solar panel flow switch delay to stop pump	AL	byte	0-250 (SEC)	1	0
R/W	33391	826F	AL71	Solar panel flow switch activation time	AL	byte	0-250 (SEC)	1	0
R/W	33392	8270	AL72	Solar panel flow switch de-activation time	AL	byte	0-250 (SEC)	1	0
R/W	33393	8271	AL73	Max number of sanitary water heaters overload	AL	byte	0-16	1	0
R/W	33394	8272	AL74	Antifreeze alarm reset by password	AL	1bit	No (0) - YES (1)	1	0
R/W	33395	8273	AL75	Max number of sanitary water pump overload	AL	byte	0-16	1	0
R/W	33396	8274	AL76	Compressor oil warning	AL	1bit	No (0) - YES (1)	1	0
R/W	33397	8275	AL77	Automatic reset compressor overload	AL	1bit	No (0) - YES (1)	1	0
R/W	33398	8276	AL78	Compressor oil alarm set	AL	byte	[0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33399	8277	AL79	Compressor oil alarm differential	AL	byte	[0,1 ÷ 14,0 bar] [1 ÷ 203 psi]	[0.1][1]	[1][0]
R/W	33400	8278	AL80	Max number of compressor oil alarm	AL	byte	0-16	1	0
R/W	33401	8279	AL81	Compressor oil alarm enabling	AL	2bit	0-2	1	0
R/W	33402	827A	AL82	FC pump flow switch alarm delay	AL	byte	0-250 (SEC)	1	0
R/W	33403	827B	AL83	FC pump flow switch delay to stop FC pump	AL	byte	0-250 (SEC)	1	0
R/W	33404	827C	AL84	FC pump switch activation time	AL	byte	0-250 (SEC)	1	0
R/W	33405	827D	AL85	FC pump switch de-activation time	AL	byte	0-250 (SEC)	1	0
R/W	33406	827E	AL86	Pump stop time in flow switch alarm condition	AL	byte	0-250 (min)	1	0
R/W	33407	827F	AL87	Evaporator / sanitary pump flow switch delay after Out1 or Out2 switching	AL	byte	0-250 (SEC)	1	0
R/W	33408	8280	LS01	Enable laser funciton	LS	1bit	No (0) - YES (1)	1	0
R/W	33409	8281	LS02	Set point laser	LS	word	[-50.0 ÷ 110,0 °C] [-58 ÷ 230 °F]	[0.1][1]	[1][0]
R/W	33410	8282	LS03	Delta tempertaure	LS	byte	[0.0÷25.0] [0÷45]	[0.1][1]	[1][0]
R/W	33411	8283	LS04	Delay time to apply the laser set point offset	LS	byte	0÷250	1	0
R/W	33412	8284	LS05	Laser set point offset	LS	byte	[-12.0÷12.0] [-21÷21]	[0.1][1]	[1][0]
R/W	33413	8285	LS06	T1 probe selection for Dt calculation	LS	byte	0÷20	1	0
R/W	33414	8286	LS07	T2 probe selection for Dt calculation	LS	byte	0÷20	1	0
R/W	33415	8287	LS08	Analog output operation mode in laser function	LS	byte	0÷10	1	0
R/W	33416	8288	LS09	Proportional component laser funciton	LS	byte	[0.0÷25.0] [0÷45]	[0.1][1]	[1][0]
R/W	33417	8289	LS10	Integral component laser funciton	LS	byte	0÷250	1	0
R/W	33418	828A	LS11	Derivative component laser funciton	LS	byte	0÷250	1	0
R/W	33419	828B	LS12	Period of PID laser funciton	LS	byte	2÷20	1	0
R/W	33420	828C	LS13	T2 minimum time	LS	byte	1÷10	1	0
R/W	33421	828D	LS14	T3 minimum time	LS	byte	1÷10	1	0
R/W	33422	828E	LS15	Sample time of derivative (Sr)	LS	byte	1÷10	1	0
R/W	33423	828F	LS16	Band adjusting (rS)	LS	byte	[-12.0÷12.0] [-21÷21]	[0.1][1]	[1][0]
R/W	33424	8290	LS17	Integral band limitation (Ar)	LS	byte	[0.0÷25.0] [0÷45]	[0.1][1]	[1][0]
R/W	33425	8291	Pr1	User level password	PASS	word	0-999	1	0
R/W	33426	8292	Pr2	Service level password	PASS	word	0-999	1	0
R/W	33427	8293	Pr3	Master password	PASS	word	0-999	1	0