

APPENDIX A MATHEMATICAL DERIVATIONS AND WORKED EXAMPLE

This appendix consolidates all formal derivations, iterative procedures, and supporting mathematics referenced in the main body of the VCH Sizing Framework. Sections [A](#) and [B](#) establish foundational procedures used across multiple steps of the design framework. Sections [C](#) through [J](#) follow the step numbering of the framework itself. All equation numbers within this appendix are self-contained and cross-referenced from the main body by the labels shown in each section heading.

A. Linear Interpolation for Thermophysical Property Lookup

Thermophysical properties — density ρ , dynamic viscosity μ , specific heat capacity c_p , thermal conductivity k_f , and volumetric thermal expansion coefficient β — are evaluated at local fluid temperatures by linear interpolation over a discrete property table. This procedure is referenced in Steps 2, 5, 6, and 9 of the main framework.

Procedure: Let $\{T_j, \phi_j\}_{j=1}^M$ denote a tabulated property pair where T_j are monotonically increasing temperature nodes and ϕ_j are the corresponding property values. For a query temperature T^* satisfying $T_j \leq T^* \leq T_{j+1}$, the interpolated property is:

$$\phi(T^*) = \phi_j + \frac{T^* - T_j}{T_{j+1} - T_j} (\phi_{j+1} - \phi_j). \quad (1)$$

The bounding index j is located by a bisection search on the sorted temperature array in $O(\log M)$ comparisons. Extrapolation beyond the table range ($T^* < T_1$ or $T^* > T_M$) must be flagged as an error; the calculation should be aborted and the user required to supply data at the relevant temperature.

Validity and Accuracy Bounds: Equation [\(1\)](#) is valid provided:

- 1) T^* lies within the tabulated range: $T_1 \leq T^* \leq T_M$.
- 2) The property ϕ varies smoothly and without phase change across the interval $[T_j, T_{j+1}]$.
- 3) The node spacing $\Delta T_j = T_{j+1} - T_j$ is sufficiently small that the linear approximation introduces negligible error relative to the physical property variation.

For water and common heat-transfer fluids over industrial operating ranges, linear interpolation between nodes spaced at 10 K or less introduces errors below 0.5% for ρ , c_p , and k_f , and below 2% for μ away from the saturation boundary [\(1\)](#).

Dynamic viscosity μ exhibits the strongest nonlinearity with temperature, particularly for viscous fluids at low temperatures. Where high accuracy is required for μ , a log-linear interpolation of the form $\ln[\mu(T)]$ is recommended in place of [\(1\)](#).

B. Worked Numerical Example

The following end-to-end calculation traces a single representative industrial scenario through all eleven steps of the design framework. All intermediate values are stated explicitly so that a practising engineer may use this section as a verification reference when implementing the framework for the first time. All fluid properties are obtained via [\(1\)](#) applied to the tables in Appendix B.

Design Scenario:

- **Working fluid:** Water at coil inlet $T_{in} = 80^\circ\text{C}$, mass flow rate $\dot{m} = 0.5 \text{ kg s}^{-1}$.
- **Tank fluid:** Water at bulk temperature $T_\infty = 20^\circ\text{C}$.
- **Design duty:** $Q_{design} = 25 \text{ kW}$.
- **Vessel aspect ratio:** $\lambda = 1.5$, hemispherical heads.
- **Tube geometry:** $d_i = 25 \text{ mm}$, $d_o = 28 \text{ mm}$, $k_w = 16 \text{ W m}^{-1} \text{ K}^{-1}$ (austenitic stainless steel).
- **Coil centreline diameter:** $D_c = 0.30 \text{ m}$.
- **Insulation:** $t_{ins} = 50 \text{ mm}$, $k_{ins} = 0.04 \text{ W m}^{-1} \text{ K}^{-1}$ (mineral wool).

Step 1 — Fluid Properties (via Section [A](#)): At film temperature $T_f = (80 + 20)/2 = 50^\circ\text{C}$: $\rho = 988 \text{ kg m}^{-3}$, $\mu = 5.47 \times 10^{-4} \text{ Pa s}$, $k_f = 0.644 \text{ W m}^{-1} \text{ K}^{-1}$, $c_p = 4181 \text{ J kg}^{-1} \text{ K}^{-1}$, $Pr = 3.55$.

Step 2 — Reynolds Number (Section [E1](#)):

$$Re = \frac{4\dot{m}}{\pi d_i \mu} = \frac{4 \times 0.5}{\pi \times 0.025 \times 5.47 \times 10^{-4}} = 46,400 \quad (\text{turbulent}).$$

Step 3 — Inner Nusselt Number (Section [F2](#)): Petukhov friction factor: $f = (0.790 \ln 46400 - 1.64)^{-2} = 0.02093$.

$$Nu_{straight} = \frac{(0.02093/8)(46400 - 1000) \times 3.55}{1 + 12.7\sqrt{0.02093/8}(3.55^{2/3} - 1)} = 183.4.$$

Curvature ratio $\delta = 0.028/0.30 = 0.0933$. Correction: $C_{curv} = 1 + 3.6(1 - 0.0933)(0.0933)^{0.8} = 1.252$.

$$Nu_{coil} = 183.4 \times 1.252 = 229.6, \quad h_i = \frac{229.6 \times 0.644}{0.025} = 5916 \text{ W m}^{-2} \text{ K}^{-1}.$$

Step 4 — Outer Natural Convection (Section -F5): At $\Delta T = 60$ K and film properties of water at 50°C : $Ra_{d_o} = g\beta\Delta T d_o^3/(\nu\alpha) = 4.27 \times 10^4$.

$$Nu_{\text{outer}} = \left[0.60 + \frac{0.387 \times (4.27 \times 10^4)^{1/6}}{[1 + (0.559/3.55)^{9/16}]^{8/27}} \right]^2 = 9.87, \quad h_o = \frac{9.87 \times 0.644}{0.028} = 226.8 \text{ W m}^{-2} \text{ K}^{-1}.$$

Step 5 — Overall U (Section -F1):

$$\begin{aligned} \frac{1}{U} &= \frac{r_o}{h_i r_i} + \frac{r_o \ln(r_o/r_i)}{k_w} + \frac{1}{h_o} \\ &= \frac{0.014}{5916 \times 0.0125} + \frac{0.014 \ln(1.120)}{16} + \frac{1}{226.8} \\ &= 1.890 \times 10^{-4} + 9.83 \times 10^{-5} + 4.409 \times 10^{-3} = 4.726 \times 10^{-3} \text{ m}^2 \text{ K W}^{-1}, \\ U &= 211.6 \text{ W m}^{-2} \text{ K}^{-1}. \end{aligned}$$

Step 6 — NTU_{req} (Section -G1): $C_{\min} = 0.5 \times 4181 = 2090.5 \text{ W K}^{-1}$.

$$\varepsilon_{\text{target}} = \frac{25000}{2090.5 \times 60} = 0.1994, \quad NTU_{\text{req}} = -\ln(1 - 0.1994) = 0.2228.$$

Step 7 — Required Area and Coil Length (Sections -G2 and -G3):

$$A_{o,\text{req}} = \frac{0.2228 \times 2090.5}{211.6} = 2.202 \text{ m}^2, \quad L_{\text{coil}} = \frac{2.202}{\pi \times 0.028} = 25.02 \text{ m}.$$

Step 8 — Coil Pitch and Turn Count (Sections -G4 and -G5): With $h_1 = 0.80$ m and $D_c = 0.30$ m, the closed-form pitch from (71):

$$p_{\text{coil}} = \frac{\pi \times 0.30 \times 0.80}{\sqrt{25.02^2 - 0.80^2}} = \frac{0.7540}{25.01} = 30.1 \text{ mm}.$$

Turn arc length: $\ell = \sqrt{(\pi \times 0.30)^2 + 0.0301^2} = 0.9426$ m. $N_t = \lceil 25.02/0.9426 \rceil = 27$ turns. Winding height: $h_{\text{wind}} = 27 \times 0.0301 = 0.813$ m.

Since $h_{\text{wind}} > h_1 = 0.80$ m, D_c must be increased marginally and the Newton–Raphson procedure of Algorithm -G4 applied. This confirms the iterative procedure is required in general.

Step 9 — Displacement Compensation (Section -H1):

$$V_{\text{disp}} = \frac{\pi \times 0.028^2}{4} \times 25.02 = 0.01541 \text{ m}^3 = 15.4 \text{ L}.$$

Step 10 — Steady-State Heat Loss (Section -I5): With $t_w = 3$ mm, $k_s = 16 \text{ W m}^{-1} \text{ K}^{-1}$, $D_i = 0.50$ m, $L_s = 0.80$ m:

$$R_{\text{wall}} = \frac{\ln(1.012)}{2\pi \times 16 \times 0.80} = 1.47 \times 10^{-4} \text{ K W}^{-1}, \quad R_{\text{ins}} = \frac{\ln(1.20)}{2\pi \times 0.04 \times 0.80} = 0.7272 \text{ K W}^{-1}.$$

Neglecting inner and outer convective resistances (small relative to insulation): $R_{\text{tot}} \approx 0.7274 \text{ K W}^{-1}$, $\dot{Q}_{\text{loss}} = (80 - 20)/0.7274 = 82.5 \text{ W}$.

Step 11 — Thermal Battery Sizing (Section -J5): $\dot{Q}_{\text{total}} = 82.5 + 25000 = 25083 \text{ W}$, $t_{\text{batch}} = 3600$ s, $\Delta T_{\text{store}} = T_{\text{max}} - T_{\text{min}} = 10$ K:

$$V_{\text{max}} = \frac{25083 \times 3600}{988 \times 4181 \times 10} = 2.189 \text{ m}^3 = 2189 \text{ L}.$$

Thermal time constant: $\tau_{\text{th}} = 988 \times 2.189 \times 4181 \times 0.7274 = 6.574 \times 10^6 \text{ s} \approx 76$ days, confirming excellent thermal autonomy for this vessel size.

C. Vessel Geometry Derivations (Step 3)

1) Algebraic Solution for Vessel Dimensions — Conical-Capped Vessel:

Geometry Definition: The vessel comprises a vertical cylinder of internal diameter d and cylindrical wall height h_2 , capped at the base by a right circular cone of half-angle θ . The aspect ratio is defined as:

$$\alpha = \frac{h_2}{d}, \quad \alpha > 0. \quad (2)$$

The conical cap height follows from the half-angle:

$$h_c = \frac{d}{2} \tan \theta. \quad (3)$$

TABLE I
WORKED EXAMPLE — SUMMARY OF KEY RESULTS

Step	Quantity	Symbol	Value
2	Reynolds number	Re	46 400
3	Inner heat transfer coeff.	h_i	$5916 \text{ W m}^{-2} \text{ K}^{-1}$
4	Outer heat transfer coeff.	h_o	$226.8 \text{ W m}^{-2} \text{ K}^{-1}$
5	Overall heat transfer coeff.	U	$211.6 \text{ W m}^{-2} \text{ K}^{-1}$
6	Required NTU	NTU_{req}	0.2228
7	Required coil length	L_{coil}	25.02 m
8	Helix pitch	p_{coil}	30.1 mm
9	Coil displacement volume	V_{disp}	15.4 L
10	Steady-state heat loss	$\dot{Q}_{\text{loss}}$	82.5 W
11	Thermal battery max. volume	V_{max}	2189 L

Volume Formula and Cubic Solution: The total internal volume is the sum of the cylindrical and conical contributions:

$$V = \frac{\pi d^2}{4} h_2 + \frac{\pi d^2}{12} h_c. \quad (4)$$

Substituting (2) and (3) into (4) and collecting terms:

$$V = \frac{\pi d^3}{24} (6\alpha + \tan \theta). \quad (5)$$

Setting $V = V_{\text{target}}$ and solving for d :

$$d = \left(\frac{24 V_{\text{target}}}{\pi (6\alpha + \tan \theta)} \right)^{1/3}. \quad (6)$$

The cylindrical wall height and conical cap height follow immediately:

$$h_2 = \alpha d, \quad (7)$$

$$h_c = \frac{d}{2} \tan \theta. \quad (8)$$

Equation (6) is a closed-form cube root — no iterative solution is required for the conical-capped geometry. This distinguishes it from the hemi-ellipsoidal case in Section C2 where the cap volume coefficient differs.

2) *Algebraic Solution for Vessel Dimensions — Hemi-Ellipsoidal-Capped Vessel:*

Geometry Definition: The base cap is a hemi-ellipsoid with equatorial radius $d/2$ and polar semi-axis b . The ratio $\beta = 2b/d$ defines the cap slenderness. A standard shallow (2:1 ellipsoidal) cap uses $\beta = 0.25$; a hemisphere corresponds to $\beta = 1$.

Volume Formula and Cubic Solution: The volume of a hemi-ellipsoid of equatorial radius $d/2$ and polar semi-axis $b = \beta d/2$ is:

$$V_{\text{cap}} = \frac{\pi d^3 \beta}{12}. \quad (9)$$

Total vessel volume:

$$V = \frac{\pi d^2}{4} (\alpha d) + \frac{\pi d^3 \beta}{12} = \frac{\pi d^3}{12} (3\alpha + \beta). \quad (10)$$

Explicit solution for d :

$$d = \left(\frac{12 V_{\text{target}}}{\pi (3\alpha + \beta)} \right)^{1/3}, \quad (11)$$

with $h_2 = \alpha d$ and cap polar semi-axis $b = \beta d/2$.

3) *Conical Cap Lateral Surface Area from First Principles:* A right circular cone of base radius $r = d/2$ and half-angle θ has slant height:

$$\ell_s = \frac{r}{\sin \theta} = \frac{d}{2 \sin \theta}. \quad (12)$$

The lateral surface area is obtained by unrolling the cone into a flat sector of radius ℓ_s and arc length $2\pi r$:

$$A_{\text{cone}} = \pi r \ell_s = \frac{\pi d^2}{4 \sin \theta}. \quad (13)$$

Equation (13) excludes the base circle area πr^2 , which is not an external surface in a closed vessel. The cylindrical wall lateral area is $A_{\text{cyl}} = \pi d h_2$.

4) *Hemi-Ellipsoidal Cap Surface Area and Working Approximation:*

Exact Formula via Elliptic Integral: For a hemi-ellipsoid with equatorial radius $a = d/2$ and polar semi-axis b , defining eccentricity $e = \sqrt{1 - (b/a)^2}$ for the oblate case ($b < a$):

$$A_{\text{hemi,exact}} = 2\pi a^2 \left(1 + \frac{1 - e^2}{e} \operatorname{arctanh}(e) \right). \quad (14)$$

For the prolate case ($b > a$), with $e = \sqrt{1 - (a/b)^2}$:

$$A_{\text{hemi,prolate}} = 2\pi a^2 \left(1 + \frac{b}{ae} \arcsin(e) \right). \quad (15)$$

Knud Thomsen Working Approximation: For engineering calculations the Knud Thomsen approximation is used with $p = 1.6075$ [12]:

$$A_{\text{hemi,approx}} \approx 2\pi \left(\frac{2(d/2)^p b^p + (d/2)^{2p}}{3} \right)^{1/p}. \quad (16)$$

This approximation has a maximum relative error of 1.061% across all ellipsoid axis ratios [12], well within the fabrication tolerance of industrial pressure vessels (typically $\pm 1.5\%$ on wall thickness).

D. NPS Selection and Maximum Coil Configuration (Step 4)

1) *Target Volumetric Flow Rate from Thermal Demand:* The heating fluid must deliver thermal power $\dot{Q}_{\text{design}}$ to the process. For a single-phase fluid with no phase change, the sensible heat equation is:

$$\dot{Q}_{\text{design}} = \dot{m}_{\text{hot}} c_{p,\text{hot}} \Delta T_{\text{coil}}, \quad (17)$$

where $\Delta T_{\text{coil}} = T_{\text{hot,in}} - T_{\text{hot,out}}$ is the hot-side temperature drop. Solving for mass flow rate and converting to volumetric flow rate using density ρ_{hot} at the mean coil temperature:

$$\dot{V} = \frac{\dot{m}_{\text{hot}}}{\rho_{\text{hot}}} = \frac{\dot{Q}_{\text{design}}}{\rho_{\text{hot}} c_{p,\text{hot}} \Delta T_{\text{coil}}}. \quad (18)$$

All fluid properties are evaluated at $T_{\text{mean}} = (T_{\text{hot,in}} + T_{\text{hot,out}})/2$ using [1].

2) *Minimum Internal Flow Area from Velocity Ceiling Constraint:* The continuity equation relates volumetric flow rate to mean velocity u :

$$\dot{V} = u \frac{\pi d_i^2}{4}. \quad (19)$$

Enforcing $u \leq u_{\text{max}}$, the minimum required internal flow area is:

$$A_{\text{flow,min}} = \frac{\dot{V}}{u_{\text{max}}}, \quad (20)$$

and the corresponding minimum internal diameter:

$$d_{i,\text{min}} = \sqrt{\frac{4 \dot{V}}{\pi u_{\text{max}}}}. \quad (21)$$

The NPS schedule is selected as the smallest standard size with $d_i \geq d_{i,\text{min}}$. The actual mean velocity is back-calculated as:

$$u = \frac{4 \dot{V}}{\pi d_i^2} \leq u_{\text{max}}. \quad (22)$$

3) *Helical Coil Arc Length from Parametric Integration:*

Parametric Definition: A helical coil of N turns, centreline diameter D_c , and axial pitch p is described by:

$$x(\varphi) = \frac{D_c}{2} \cos \varphi, \quad (23)$$

$$y(\varphi) = \frac{D_c}{2} \sin \varphi, \quad (24)$$

$$z(\varphi) = \frac{p}{2\pi} \varphi, \quad (25)$$

where $\varphi \in [0, 2\pi N]$ is the azimuthal parameter.

Arc Length Integration: The arc length element is:

$$ds = \sqrt{\left(\frac{dx}{d\varphi}\right)^2 + \left(\frac{dy}{d\varphi}\right)^2 + \left(\frac{dz}{d\varphi}\right)^2} d\varphi. \quad (26)$$

Substituting the derivatives of (23)–(25) and applying $\sin^2 \varphi + \cos^2 \varphi = 1$:

$$ds = \sqrt{\frac{D_c^2}{4} + \frac{p^2}{4\pi^2}} d\varphi. \quad (27)$$

Since the integrand is constant in φ , integrating over N complete turns:

$$L_{\text{coil}} = N \sqrt{(\pi D_c)^2 + p^2}. \quad (28)$$

Equation (28) uses the coil *centreline* diameter $D_c = d_{\text{tank}} - 0.200 - d_o$ where the 0.200 m term accounts for the mandatory 100 mm radial clearance on each side. All dimensions must be in consistent units of metres.

4) *Compound Packing Efficiency and Practical Coil Length:* The geometric maximum coil length from (28) assumes ideal continuous winding with no manufacturing or operational constraints. The practical maximum is obtained by applying the compound packing efficiency factor η_{pack} , which is the product of five independent sub-factors, each addressing a distinct physical constraint:

$$\eta_{\text{pack}} = \eta_f \cdot \eta_s \cdot \eta_w \cdot \eta_t \cdot \eta_d. \quad (29)$$

Reference values for each sub-factor are tabulated in the main framework (Step 4, Tables 1 through 5). Typical compound values across standard industrial coil designs fall in the range $\eta_{\text{pack}} \in [0.55, 0.75]$.

The practical maximum coil length is:

$$L_{\text{practical}} = L_{\text{max}} \times \eta_{\text{pack}}, \quad (30)$$

where L_{max} is evaluated from (28) at the minimum structural pitch $p_{\text{min}} = 2d_o$ and maximum number of turns $N_{\text{max}} = \lfloor h_1/p_{\text{min}} \rfloor$.

E. Hydraulic Resistance and Pump Selection (Step 5)

1) *Reynolds Number for Internal Pipe Flow:*

$$Re = \frac{\rho u d_i}{\mu} = \frac{4 \dot{m}}{\pi d_i \mu}. \quad (31)$$

All fluid properties are evaluated at bulk mean temperature via (11). Flow regime classification for straight pipe: $Re < 2300$ laminar; $2300 \leq Re \leq 4000$ transitional; $Re > 4000$ turbulent. These boundaries are modified for helical geometry by the Dean number (Section E3).

2) *Colebrook-White Equation and Newton-Raphson Solution:*

Colebrook-White Equation: For turbulent flow in a pipe of internal roughness ε :

$$\frac{1}{\sqrt{f_s}} = -2 \log_{10} \left(\frac{\varepsilon/d_i}{3.7} + \frac{2.51}{Re \sqrt{f_s}} \right), \quad (32)$$

where f_s denotes the straight-pipe Darcy friction factor. For laminar flow ($Re < 2300$):

$$f_s = \frac{64}{Re}. \quad (33)$$

Haaland Seed Estimate:

$$f_0 = \left(-1.8 \log_{10} \left[\left(\frac{\varepsilon/d_i}{3.7} \right)^{1.11} + \frac{6.9}{Re} \right] \right)^{-2}. \quad (34)$$

Newton-Raphson Iterative Procedure: Define $x = f_s^{-1/2}$ and the residual function $F(x) = 0$:

$$F(x) = x + 2 \log_{10} \left(\frac{\varepsilon/d_i}{3.7} + \frac{2.51}{Re x} \right), \quad (35)$$

with derivative:

$$F'(x) = 1 + \frac{2}{\ln 10} \cdot \frac{2.51/Re}{\frac{\varepsilon/d_i}{3.7} + \frac{2.51}{Re x}}. \quad (36)$$

The Newton-Raphson update at iteration k :

$$x^{(k+1)} = x^{(k)} - \frac{F(x^{(k)})}{F'(x^{(k)})}. \quad (37)$$

Initialise with $x^{(0)} = f_0^{-1/2}$ from (34). Terminate when $|x^{(k+1)} - x^{(k)}| < 10^{-8}$. Recover friction factor: $f_s = 1/(x^{(k+1)})^2$. Convergence is achieved in three or fewer iterations across the full turbulent regime [7].

3) *Dean Number Definition and Flow Regime Classification:* The Dean number quantifies the ratio of centrifugal to viscous forces in helical pipe flow [8]:

$$De = Re \sqrt{\frac{d_i}{D_c}}. \quad (38)$$

Curvature stabilises the boundary layer, delaying the laminar-to-turbulent transition. The critical Dean number below which flow remains laminar despite $Re > 2300$ is $De_{crit} = 11.6$ [9], corresponding to:

$$Re_{crit,coil} = 11.6 \sqrt{\frac{D_c}{d_i}}. \quad (39)$$

Flow regime classification for helical coils:

- $De < 11.6$: laminar — use Sieder-Tate (Section F3).
- $11.6 \leq De \leq 100$: transitional — interpolate between laminar and turbulent Ito correlations.
- $De > 100$: turbulent — use Gnielinski modified (Section F2).

4) *Ito's Helical Friction Factor Correlations:*

Laminar Regime ($De < 11.6$):

$$f_{hel,lam} = \frac{64}{Re} \left[1 + 0.033 (\log_{10} De)^4 \right]. \quad (40)$$

Turbulent Regime ($De > 100$):

$$f_{hel,turb} = 0.304 Re^{-0.25} \left(\frac{D_c}{d_i} \right)^{-0.1}. \quad (41)$$

Transitional Regime ($11.6 \leq De \leq 100$): Linear interpolation in De :

$$f_{hel,trans} = f_{hel,lam}|_{De=11.6} + \frac{De - 11.6}{88.4} (f_{hel,turb}|_{De=100} - f_{hel,lam}|_{De=11.6}). \quad (42)$$

5) *Darcy-Weisbach Major Loss Applied to Helical Coil Geometry:*

$$\Delta P_{major} = f_{hel} \frac{L_{coil}}{d_i} \frac{\rho u^2}{2}, \quad (43)$$

where f_{hel} is the appropriate Ito friction factor from Section E4 and L_{coil} is from (28).

6) *Minor Losses, Total System Resistance, and Head Conversion:*

K-Factor Method for Minor Losses: Each fitting contributes:

$$\Delta P_{minor,j} = K_j \frac{\rho u^2}{2}. \quad (44)$$

Total system pressure drop:

$$\Delta P_{system} = \left(f_{hel} \frac{L_{coil}}{d_i} + \sum_{j=1}^M K_j \right) \frac{\rho u^2}{2}. \quad (45)$$

Conversion to Equivalent Head:

$$H_{system} = \frac{\Delta P_{system}}{\rho g}, \quad (46)$$

where $g = 9.81 \text{ m s}^{-2}$.

7) *Pump Affinity Laws and VFD Frequency Scaling:* For a geometrically similar pump operating at rotational speed n , the affinity laws follow from invariance of the dimensionless flow, head, and power coefficients [3]:

$$\frac{\dot{V}_2}{\dot{V}_1} = \frac{n_2}{n_1}, \quad (47)$$

$$\frac{H_2}{H_1} = \left(\frac{n_2}{n_1} \right)^2, \quad (48)$$

$$\frac{P_2}{P_1} = \left(\frac{n_2}{n_1} \right)^3. \quad (49)$$

A Variable Frequency Drive (VFD) scales pump speed proportionally to supply frequency f_{VFD} . The target VFD frequency required to achieve velocity-compliant flow rate $\dot{V}_{design}$ is:

$$f_{VFD} = f_{rated} \frac{\dot{V}_{design}}{\dot{V}_{rated}}. \quad (50)$$

The scaled duty head is verified as:

$$H_{\text{duty}} = H_{\text{rated}} \left(\frac{f_{\text{VFD}}}{f_{\text{rated}}} \right)^2 \geq H_{\text{system}}. \quad (51)$$

If (51) is not satisfied, a larger NPS or pump frame is selected and the procedure repeats from Section D2.

F. Thermal Performance Evaluation (Step 6)

1) *Series Thermal Resistance Network and Overall Heat Transfer Coefficient:* For a helical coil of inner radius r_i , outer radius r_o , wall conductivity k_w , and length L , the overall heat transfer coefficient referred to the outer surface is obtained from the series resistance network (inner convection, cylindrical wall conduction, outer convection):

$$\frac{1}{U} = \frac{r_o}{h_i r_i} + \frac{r_o \ln(r_o/r_i)}{k_w} + \frac{1}{h_o}. \quad (52)$$

Including fouling resistances $R_{f,i}$ and $R_{f,o}$ on the inner and outer surfaces respectively:

$$\frac{1}{U} = \frac{r_o}{h_i r_i} + R_{f,i} \frac{r_o}{r_i} + \frac{r_o \ln(r_o/r_i)}{k_w} + R_{f,o} + \frac{1}{h_o}. \quad (53)$$

2) *Gnielinski Correlation Modified for Helical Coil Turbulent Flow:* The Gnielinski correlation for a straight tube ($3000 \lesssim Re \lesssim 5 \times 10^6$, $0.5 \lesssim Pr \lesssim 2000$) is:

$$Nu_{\text{straight}} = \frac{(f/8)(Re - 1000)Pr}{1 + 12.7\sqrt{f/8}(Pr^{2/3} - 1)}, \quad (54)$$

where f is from the Petukhov relation $f = (0.790 \ln Re - 1.64)^{-2}$.

For a helical coil with curvature ratio $\delta = d_i/D_c$, the Manlapaz-Churchill curvature correction [10] gives:

$$Nu_{\text{coil}} = Nu_{\text{straight}} \left[1 + 3.6 \left(1 - \frac{d_i}{D_c} \right) \left(\frac{d_i}{D_c} \right)^{0.8} \right], \quad (55)$$

and $h_i = Nu_{\text{coil}} k_f / d_i$.

3) *Sieder-Tate Correlation for Laminar and Transitional Helical Coil Flow:* For laminar and transitional flow, substituting the Dean number for Re to account for secondary-flow enhancement [10]:

$$Nu_{\text{coil}} = 1.86 \left(\frac{De Pr d_i}{L_{\text{coil}}} \right)^{1/3} \left(\frac{\mu_b}{\mu_w} \right)^{0.14}, \quad (56)$$

valid for Graetz number $Gz = Re Pr d_i / L_{\text{coil}} > 10$ and $De < 11.6$. Here μ_b and μ_w are the dynamic viscosities at bulk and wall temperatures respectively.

4) *Prandtl Number Definition and Role in Convective Correlations:*

$$Pr = \frac{\mu c_p}{k_f} = \frac{\nu}{\alpha_{\text{th}}}, \quad (57)$$

where $\nu = \mu/\rho$ is kinematic viscosity and $\alpha_{\text{th}} = k_f/(\rho c_p)$ is thermal diffusivity. The Prandtl number governs the relative thickness of the hydrodynamic and thermal boundary layers: $\delta_{\text{th}}/\delta_{\text{hydro}} \approx Pr^{-1/3}$.

5) *Churchill-Chu Natural Convection Correlation for a Horizontal Cylinder:* Treating each coil turn as a long horizontal cylinder of outer diameter d_o submerged in the bulk tank fluid [11]:

$$\overline{Nu}_{d_o} = \left\{ 0.60 + \frac{0.387 Ra_{d_o}^{1/6}}{[1 + (0.559/Pr)^{9/16}]^{8/27}} \right\}^2, \quad (58)$$

valid for $Ra_{d_o} \lesssim 10^{12}$. The Rayleigh number, with all fluid properties evaluated at the film temperature $T_f = (T_{\text{wall}} + T_{\infty})/2$:

$$Ra_{d_o} = \frac{g \beta \Delta T d_o^3}{\nu \alpha_{\text{th}}}, \quad (59)$$

and $h_o = \overline{Nu}_{d_o} k_f / d_o$.

6) *Logarithmic Mean Temperature Difference — Derivation and Arithmetic Mean Approximation:*

Derivation: For a coil immersed in a well-mixed tank at constant temperature T_{∞} , the energy balance on a differential element $dA = \pi d_o dx$ gives $d\theta/\theta = -(U \pi d_o / \dot{m} c_p) dx$, where $\theta = T_f - T_{\infty}$. Integrating over the full coil length:

$$q = U A_o \Delta T_{\text{lm}}, \quad \Delta T_{\text{lm}} = \frac{\Delta T_1 - \Delta T_2}{\ln(\Delta T_1 / \Delta T_2)}, \quad (60)$$

where $\Delta T_1 = T_{\text{in}} - T_{\infty}$ and $\Delta T_2 = T_{\text{out}} - T_{\infty}$.

Arithmetic Mean Approximation Validity: The arithmetic mean $\Delta T_{\text{am}} = (\Delta T_1 + \Delta T_2)/2$ approximates ΔT_{lm} within 5% when the ratio $R = \Delta T_1 / \Delta T_2$ satisfies $0.54 \lesssim R \lesssim 1.86$, i.e. when the two endpoint temperature differences differ by less than a factor of approximately 1.86.

7) *Effectiveness-NTU Method: Full Derivation for $C_r = 0$:* For a submerged coil in a large well-mixed tank, the tank thermal capacity rate $C_{\text{tank}} \rightarrow \infty$, giving capacity ratio $C_r = C_{\text{min}}/C_{\text{max}} = 0$. The energy balance on the coil stream reduces to the ODE $d\theta/dA = -(U/C_{\text{min}})\theta$, where $\theta = T_{\text{min}} - T_{\infty}$. Integrating:

$$\ln\left(\frac{\theta_{\text{out}}}{\theta_{\text{in}}}\right) = -NTU, \quad NTU = \frac{UA_o}{C_{\text{min}}}. \quad (61)$$

The heat exchanger effectiveness:

$$\varepsilon = \frac{q}{q_{\text{max}}} = \frac{C_{\text{min}}(T_{\text{min,out}} - T_{\text{min,in}})}{C_{\text{min}}(T_{\infty} - T_{\text{min,in}})}, \quad (62)$$

simplifies, after substituting the integrated ODE result, to:

$$\boxed{\varepsilon = 1 - e^{-NTU}, \quad (C_r = 0).} \quad (63)$$

8) *Maximum Transmissible Thermal Power:*

$$q_{\text{max}} = C_{\text{min}} (T_{h,\text{in}} - T_{\infty}) = \dot{m} c_p (T_{\text{in}} - T_{\infty}). \quad (64)$$

Combining with (63):

$$\boxed{q = (1 - e^{-UA_o/C_{\text{min}}}) C_{\text{min}} (T_{\text{in}} - T_{\infty}).} \quad (65)$$

This expression encapsulates coil geometry (through A_o), thermal resistances (through U from (52) or (53)), flow conditions (through C_{min}), and driving potential (through $T_{\text{in}} - T_{\infty}$). It is evaluated twice in Step 6: once using U_{steady} for nominal performance, and once using U_{cold} (worst-case cold-start viscosity) for conservative sizing.

G. Coil Geometry Optimisation (Step 7)

1) *Target Effectiveness and NTU Back-Calculation from Q_{design} :*

$$\varepsilon_{\text{target}} = \frac{Q_{\text{design}}}{q_{\text{max}}} = \frac{Q_{\text{design}}}{C_{\text{min}} (T_{\text{in}} - T_{\infty})}, \quad (66)$$

with $0 < \varepsilon_{\text{target}} < 1$ required for physical validity. From (63):

$$\boxed{NTU_{\text{req}} = -\ln(1 - \varepsilon_{\text{target}}).} \quad (67)$$

2) *Required Surface Area from NTU_{req} and U_{cold} :* From $NTU = UA_o/C_{\text{min}}$:

$$\boxed{A_{o,\text{req}} = \frac{NTU_{\text{req}} C_{\text{min}}}{U_{\text{cold}}}.} \quad (68)$$

U_{cold} is computed from (53) using fluid properties evaluated at the cold-start temperature (worst-case viscosity from Step 2).

3) *Optimised Coil Length from Required Surface Area:*

$$\boxed{L_{\text{coil}} = \frac{A_{o,\text{req}}}{\pi d_o}.} \quad (69)$$

This must satisfy $L_{\text{coil}} \leq L_{\text{practical}}$ from (30). If this constraint is violated, the NPS is incremented upward and Steps 4 through 7 are repeated.

4) *Helical Pitch Inversion — Transcendental Equation and Newton-Raphson Solution:*

Closed-Form Solution: Given total coil length L_{coil} , coil centreline diameter D_c , and winding height h_1 , the helical geometry relation (28) with $N = h_1/p$ gives:

$$\frac{h_1}{p} \sqrt{(\pi D_c)^2 + p^2} = L_{\text{coil}}. \quad (70)$$

Squaring and solving algebraically:

$$\boxed{p_{\text{coil}} = \frac{\pi D_c h_1}{\sqrt{L_{\text{coil}}^2 - h_1^2}}}, \quad (71)$$

valid when $L_{\text{coil}} > h_1$. When additional geometric constraints couple p to D_c , the full iterative procedure below is required.

Newton-Raphson Iterative Procedure: Define $F(p)$ as in (70). Its derivative is:

$$F'(p) = \frac{-h_1 (\pi D_c)^2}{p^2 \sqrt{(\pi D_c)^2 + p^2}}. \quad (72)$$

[H] $D_c, h_1, L_{\text{coil}}, d_o, \delta_{\text{min}}$ (min gap), $\tau = 10^{-6} \text{ m}$ $p_{\text{coil}} \leftarrow p \leftarrow d_o(1 + \delta_{\text{min}})$ *minimum admissible pitch $|\Delta p| < \tau$ $F \leftarrow (h_1/p) \sqrt{(\pi D_c)^2 + p^2} - L_{\text{coil}}$ $F' \leftarrow -h_1 (\pi D_c)^2 / [p^2 \sqrt{(\pi D_c)^2 + p^2}]$ $\Delta p \leftarrow -F/F'$ $p \leftarrow p + \Delta p$ $p < d_o(1 + \delta_{\text{min}})$ $p \leftarrow d_o(1 + \delta_{\text{min}})$ *enforce lower bound $p_{\text{coil}} \leftarrow p$ Newton-Raphson solver for helical coil pitch

Convergence is quadratic, typically requiring fewer than ten iterations. If $F'(p) \rightarrow 0$ near $p = \pi D_c$, switch to bisection on $[d_o(1 + \delta_{\text{min}}), h_1/2]$.

Pitch Sanity Bounds: The back-calculated pitch must satisfy:

$$p_{\min} = 2 d_o \leq p_{\text{coil}} \leq \frac{h_1}{3}. \quad (73)$$

If $p_{\text{coil}} < p_{\min}$, the coil is already at maximum density and cannot be reduced further without mechanical clashing (see Step 7, Section 7.4.1 of the main framework). If $p_{\text{coil}} > h_1/3$, fewer than three turns result and the helical flow assumption is no longer valid.

5) *Turn Count, Winding Height, and End Clearance Formulations:* Turn arc length: $\ell_{\text{turn}} = \sqrt{(\pi D_c)^2 + p_{\text{coil}}^2}$.

Number of turns (rounded down to ensure the coil fits within h_1):

$$N_t = \left\lfloor \frac{h_1}{p_{\text{coil}}} \right\rfloor. \quad (74)$$

Actual winding height:

$$h_{\text{wind}} = N_t p_{\text{coil}}. \quad (75)$$

End clearance at each extremity:

$$h_{\text{clearance}} = h_1 - h_{\text{wind}} \geq 50 \text{ mm}. \quad (76)$$

If (76) is violated, N_t is reduced by one and the thermal adequacy check of Step 7 is repeated with the reduced surface area.

H. Volumetric Displacement Compensation (Step 8)

1) *Primary Coil Pipe Displacement Volume:* The coil displaces volume equal to the full external cross-section of the tube, since the tube interior (thermofluid) is inaccessible to the process fluid. Using the *external* diameter d_o :

$$V_{\text{disp}} = \frac{\pi d_o^2}{4} L_{\text{coil}}. \quad (77)$$

Using d_i instead of d_o would underestimate the displacement by the tube wall volume and is incorrect.

2) *Gross Fabrication Volume Target:*

$$V_{\text{gross}} = V_{\text{target}} + V_{\text{disp}} + V_{\text{ancillary}}, \quad (78)$$

where $V_{\text{ancillary}} = k_{\text{anc}} \times V_{\text{disp}}$ with k_{anc} from the support complexity table in Step 8.

3) *Option A — Additional Shell Height for Vertical Extension:* With vessel diameter d held constant, the additional cylindrical height required to recover $V_{\text{gross}} - V_{\text{target}}$:

$$\Delta h = \frac{4(V_{\text{disp}} + V_{\text{ancillary}})}{\pi d^2}, \quad h_{1,\text{final}} = h_1 + \Delta h. \quad (79)$$

4) *Option B — Adjusted Vessel Diameter for Radial Expansion:* With shell height h_1 held constant, the adjusted diameter is obtained by substituting V_{gross} for V_{target} in the Step 3 cubic solution. For the conical-capped case from (6):

$$d_{\text{new}} = \left(\frac{24 V_{\text{gross}}}{\pi(6\alpha + \tan \theta)} \right)^{1/3}. \quad (80)$$

For the hemi-ellipsoidal case, substitute V_{gross} into (11).

5) *Updated External Surface Area After Dimensional Adjustment:*

Option A (diameter d fixed, new height $h_{1,\text{final}}$):

$$A_{\text{shell,A}} = \pi d h_{1,\text{final}}, \quad A_{\text{total,A}} = A_{\text{shell,A}} + A_{\text{caps}}. \quad (81)$$

A_{caps} is evaluated using (13) or (16) as appropriate and is unchanged from Step 3.

Option B (height h_1 fixed, new diameter d_{new}): Both shell and cap areas must be recomputed with d_{new} in place of d , using the same surface area formulas from Section C3 or C4.

I. Thermal Driver Sizing (Step 9)

1) *Internal Natural Convection Resistance at the Vessel Boundary:* The inner vessel wall is treated as a vertical flat plate or large-diameter horizontal cylinder. Applying the Churchill-Chu correlation (58) with characteristic length equal to the vessel inner diameter D_i and $\Delta T = T_{\text{bulk}} - T_{\text{wall,i}}$:

$$h_{\text{nc,i}} = \frac{Nu_{D_i} k_f}{D_i}, \quad (82)$$

and the corresponding resistance referred to inner surface area A_i :

$$R_{\text{conv,i}} = \frac{1}{h_{\text{nc,i}} A_i}. \quad (83)$$

For conservative preliminary estimation, $h_{\text{nc,i}}$ may be taken as $50\text{--}200 \text{ W m}^{-2} \text{ K}^{-1}$ for low-to-moderate viscosity process fluids and $10\text{--}50 \text{ W m}^{-2} \text{ K}^{-1}$ for high-viscosity organic fluids.

2) Vessel Wall Conductive Resistance — Flat Wall and Cylindrical Formulations:

Cylindrical Formulation:

$$R_{\text{wall,cyl}} = \frac{\ln(r_o/r_i)}{2\pi k_s L_s}. \quad (84)$$

Flat Wall Approximation:

$$R_{\text{wall,flat}} = \frac{t_w}{k_s A_{\text{wall}}}. \quad (85)$$

The flat-wall approximation introduces less than 5% error when $t_w/r_i < 0.1$ (thin-walled condition).

3) Insulation Conductive Resistance — Flat Wall and Cylindrical Formulations:

Cylindrical Formulation:

$$R_{\text{ins,cyl}} = \frac{\ln(r_{\text{ins}}/r_o)}{2\pi k_{\text{ins}} L_s}, \quad (86)$$

where $r_{\text{ins}} = r_o + t_{\text{ins}}$.

Flat Wall Approximation:

$$R_{\text{ins,flat}} = \frac{t_{\text{ins}}}{k_{\text{ins}} A_{\text{ext}}}, \quad (87)$$

where A_{ext} is from Section H5. The cylindrical form should be preferred when insulation thickness is not negligible relative to the vessel radius.

4) External Convective Resistance Formulation:

$$R_{\text{conv,o}} = \frac{1}{h_{\text{ext}} A_{\text{ins}}}, \quad (88)$$

where A_{ins} is the outer insulation surface area and h_{ext} is estimated from the Churchill-Chu correlation applied to the outer insulation geometry, or taken from the reference values in Step 9, Section 9.2.4 of the main framework.

5) Total Series Resistance Network and Steady-State Heat Loss Rate:

$$R_{\text{tot}} = R_{\text{conv,i}} + R_{\text{wall}} + R_{\text{ins}} + R_{\text{conv,o}}. \quad (89)$$

$$\dot{Q}_{\text{loss}} = \frac{T_{\text{bulk}} - T_{\text{worst,amb}}}{R_{\text{tot}}}. \quad (90)$$

$T_{\text{worst,amb}}$ is the worst-case ambient temperature established in Step 1 — coldest recorded for heating applications, hottest for cooling.

6) Multi-Vessel Total Thermal Driver Capacity: For N_v vessels, each with heat loss $\dot{Q}_{\text{loss},j}$ and process heat demand $Q_{\text{design},j}$:

$$\dot{Q}_{\text{driver,total}} = \sum_{j=1}^{N_v} (\dot{Q}_{\text{loss},j} + Q_{\text{design},j}). \quad (91)$$

A diversity factor $f_d \leq 1$ may be applied if simultaneous peak demand across all vessels is not required by the operating schedule.

7) Driver Turndown Ratio and Heating Element Count Formulations: Minimum number of elements to cover peak demand at rated output per element $\dot{Q}_{\text{rated}}$:

$$N_{e,\text{max}} = \left\lceil \frac{\dot{Q}_{\text{driver,total}}}{\dot{Q}_{\text{rated}}} \right\rceil. \quad (92)$$

Minimum number of elements to sustain standing losses without cycling:

$$N_{e,\text{min}} = \left\lceil \frac{\sum_{j=1}^{N_v} \dot{Q}_{\text{loss},j}}{\dot{Q}_{\text{rated}}} \right\rceil. \quad (93)$$

If the minimum stable driver output at turndown exceeds $\sum_j \dot{Q}_{\text{loss},j}$, the driver will cycle at low demand; $N_{e,\text{max}}$ should be increased or a smaller modulating element added.

J. Thermal Battery Sizing (Step 10)

1) Hydronic Priming Volume:

$$V_{\text{prime}} = V_{\text{pipe}} + V_{\text{coil,int}} + V_{\text{exp}}, \quad (94)$$

where, using the *internal* pipe diameter d_i :

$$V_{\text{coil,int}} = \frac{\pi d_i^2}{4} L_{\text{coil}}, \quad (95)$$

$$V_{\text{pipe}} = \sum_{k=1}^m \frac{\pi d_{i,k}^2}{4} \ell_k, \quad (96)$$

$$V_{\text{exp}} = f_{\text{exp}} (V_{\text{pipe}} + V_{\text{coil,int}}), \quad f_{\text{exp}} \approx 0.04\text{--}0.08. \quad (97)$$

Note the use of d_i here, in contrast to the d_o used in the displacement calculation (77). This is correct: the priming volume is the fluid payload inside the loop, not the volume it displaces.

2) Electric Element Flux Buffer Volume Formulation:

$$V_{\text{buffer,e}} = V_{\text{clearance}} + V_{\text{flux}}, \quad V_{\text{flux}} = \frac{\dot{Q}_e}{\rho c_p (dT/dt)_{\text{limit}}}, \quad (98)$$

where $(dT/dt)_{\text{limit}}$ is the maximum allowable temperature ramp rate that the SCR or VFD control system can track without triggering element high-temperature safety interlocks (K/s), and $V_{\text{clearance}}$ is the volume required to keep all active elements fully submerged at all times including at minimum standby fluid level.

3) *Fired Heater Minimum Volume from Burner Turndown Constraints:* To prevent the fluid temperature from rising through the controller deadband ΔT_{db} faster than the burner can throttle down during its minimum runtime $t_{\text{min,run}}$ at minimum stable output $\dot{Q}_{\text{min}} = \dot{Q}_{\text{rated}}/TR$:

$$V_{\text{min,fired}} = \frac{\dot{Q}_{\text{min}} t_{\text{min,run}}}{\rho c_p \Delta T_{\text{db}}}. \quad (99)$$

4) *Chiller Minimum Volume from Compressor Anti-Recycle Constraints:* The fluid temperature must not exceed $T_{\text{set}} + \Delta T_{\text{db}}$ during the compressor anti-recycle lockout period τ_{arc} :

$$V_{\text{min,chiller}} = \frac{\dot{Q}_{\text{loss}} \tau_{\text{arc}}}{\rho c_p \Delta T_{\text{db}}}. \quad (100)$$

5) Maximum Volume Derivation from First-Law Transient Energy Balance:

Governing ODE: Applying the first law to a well-mixed thermal battery of volume V with no driver input ($\dot{Q}_{\text{source}} = 0$):

$$\rho V c_p \frac{dT}{dt} = -\dot{Q}_{\text{loss}}(T) - \dot{Q}_{\text{proc}}, \quad (101)$$

where $\dot{Q}_{\text{loss}}(T) = (T - T_{\text{worst,amb}})/R_{\text{tot}}$ and $\dot{Q}_{\text{proc}} = Q_{\text{design}}/t_{\text{batch}}$ (constant peak extraction rate).

Integration and Autonomy Boundary: Under the conservative assumption $T \approx T_{\text{set}}$ (small temperature variation relative to absolute temperature), the total energy extracted during one batch cycle t_{batch} is:

$$\Delta E = (\dot{Q}_{\text{loss}} + \dot{Q}_{\text{proc}}) t_{\text{batch}}. \quad (102)$$

This must be provided entirely by cooling the battery through the allowable temperature drawdown $\Delta T_{\text{allow}} = T_{\text{max}} - T_{\text{min}}$:

$$\Delta E = \rho V c_p \Delta T_{\text{allow}}. \quad (103)$$

Equating (102) and (103):

$$V_{\text{max}} = \frac{(\dot{Q}_{\text{loss}} + \dot{Q}_{\text{proc}}) t_{\text{batch}}}{\rho c_p \Delta T_{\text{allow}} \eta_{\text{usable}}}, \quad (104)$$

where $\eta_{\text{usable}} = 0.80$ is the usable thermal fraction accounting for stratification and standing losses.

6) *Thermal Time Constant Formulation:* Setting $\dot{Q}_{\text{proc}} = 0$ in (101) and linearising the loss term, the natural cooling response is exponential with time constant:

$$\tau_{\text{th}} = \rho V c_p R_{\text{tot}}. \quad (105)$$

Equivalently, $\tau_{\text{th}} = (\rho V c_p)/\dot{Q}_{\text{loss}} \times (T_{\text{set}} - T_{\text{worst,amb}})$, confirming that a larger volume, better insulation (higher R_{tot}), and higher fluid thermal mass all increase autonomy as expected.

7) *Thermal Battery Tank Geometric Dimensioning Procedure*: The selected volume $V_{\text{batt}} \in [V_{\text{min}}, V_{\text{max}}]$ is converted to physical dimensions by applying the Step 3 cubic solution with V_{batt} in place of V_{target} and the same aspect ratio α and cap profile selected for the process vessel.

For the conical-capped case from (6):

$$d_{\text{batt}} = \left(\frac{24 V_{\text{batt}}}{\pi(6\alpha + \tan \theta)} \right)^{1/3}, \quad h_{2,\text{batt}} = \alpha d_{\text{batt}}. \quad (106)$$

For the hemi-ellipsoidal case, substitute into (11). The aspect ratio sanity bounds of Step 3 Section 3.2.1 apply: $h_{\text{total,batt}}/d_{\text{batt}} \in [0.8, 4.0]$. A minimum internal diameter of 400 mm is recommended for thermal battery tanks to ensure adequate element submersion and maintenance access.

REFERENCES

- [1] T. L. Bergman, A. S. Lavine, F. P. Incropera, and D. P. DeWitt, *Fundamentals of Heat and Mass Transfer*, 7th ed. Hoboken, NJ: John Wiley & Sons, 2011.
- [2] Y. A. Çengel and A. J. Ghajar, *Heat and Mass Transfer: Fundamentals and Applications*, 5th ed. New York, NY: McGraw-Hill Education, 2015.
- [3] F. M. White, *Fluid Mechanics*, 8th ed. New York, NY: McGraw-Hill Education, 2016.
- [4] D. W. Green and M. Z. Southard, Eds., *Perry's Chemical Engineers' Handbook*, 9th ed. New York, NY: McGraw-Hill Education, 2018.
- [5] C. F. Colebrook, "Turbulent flow in pipes, with particular reference to the transition region between smooth and rough pipe laws," *J. Inst. Civil Eng.*, vol. 11, no. 4, pp. 133–156, 1939.
- [6] S. E. Haaland, "Simple and explicit formulas for the friction factor in turbulent pipe flow," *J. Fluids Eng.*, vol. 105, no. 1, pp. 89–90, 1983.
- [7] L. F. Moody, "Friction factors for pipe flow," *Trans. ASME*, vol. 66, pp. 671–684, 1944.
- [8] W. R. Dean, "Note on the motion of fluid in a curved pipe," *Philos. Mag.*, vol. 4, no. 20, pp. 208–223, 1927.
- [9] H. Ito, "Friction factors for turbulent flow in curved pipes," *J. Basic Eng.*, vol. 81, no. 2, pp. 123–134, 1959.
- [10] R. L. Manlapaz and S. W. Churchill, "Fully developed laminar flow in a helically coiled tube of finite pitch," *Chem. Eng. Commun.*, vol. 7, no. 1–3, pp. 57–78, 1980.
- [11] S. W. Churchill and H. H. S. Chu, "Correlating equations for laminar and turbulent free convection from a horizontal cylinder," *Int. J. Heat Mass Transfer*, vol. 18, no. 9, pp. 1049–1053, 1975.
- [12] K. Thomsen, "Approximate formula for the surface area of an ellipsoid," [Online]. Available: <https://mathworld.wolfram.com/Ellipsoid.html> [Accessed: 2025].
- [13] Spirax Sarco, *The Steam and Condensate Loop*, Book 2. Cheltenham, UK: Spirax-Sarco Ltd., 2008.
- [14] ASME B36.10M-2022, *Welded and Seamless Wrought Steel Pipe*. New York, NY: The American Society of Mechanical Engineers, 2022.
- [15] ASME B36.19M-2022, *Stainless Steel Pipe*. New York, NY: The American Society of Mechanical Engineers, 2022.
- [16] I. J. Karassik, J. P. Messina, P. Cooper, and C. C. Heald, *Pump Handbook*, 3rd ed. New York, NY: McGraw-Hill Education, 2001.

APPENDIX B

THERMOPHYSICAL PROPERTY DATASETS AND REFERENCE MATERIAL

This appendix consolidates all baseline thermodynamic matrices, geometric line profiles, and lifecycle safety tolerances referenced across the core design framework. The tabulated data blocks listed herein provide the explicit property pairs required to execute the first-order linear interpolation algorithms detailed in Section A.A. Sections B.A through B.D serve as the unified data bank for optimizing calculations in Steps 2, 4, 5, 6, 8, and 9.

K. Aqueous and Industrial Transport Fluid Data Matrices

The following datasets represent the baseline thermodynamic properties of standard process and hydronic heat-transfer fluids. Designers must look up parameters at local bulk mean temperatures using first-order linear splines. All property values are evaluated at atmospheric pressure unless otherwise stated. For pressurised closed-loop systems, minor corrections to density and specific heat may be applied per the fluid manufacturer's pressurised property charts; however, for the operating envelopes covered by this framework, the atmospheric-baseline values introduce negligible error for sizing purposes.

1) *Pure Water Base Fluid (Process/Utility Standard)*: Table III indexes properties for distilled/purified water lines across atmospheric heating intervals, primarily utilised for process batch calculations and clean utility runs. Extended to 100°C at atmospheric pressure; pressurised systems may use water as a transport fluid beyond this limit with appropriate saturation-margin analysis.

TABLE II
THERMOPHYSICAL PROPERTIES OF PURE WATER (0°C TO 100°C)

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
0	999.8	4217	1.787	1.787	0.561	13.44
20	998.2	4182	1.002	1.004	0.598	7.01
40	992.2	4179	0.653	0.658	0.631	4.32
60	983.2	4185	0.467	0.475	0.654	2.99
80	971.8	4196	0.354	0.364	0.670	2.22
100	958.4	4216	0.282	0.294	0.679	1.75

2) *30% Propylene Glycol Aqueous Solution (Closed Loop Anti-Freeze Option)*: Table III provides metrics for commercial-grade inhibited propylene glycol mixtures at 30% by volume. Freeze point approximately −13°C. This fluid profile is common in HVAC and industrial process loops due to its low toxicity and GRAS (Generally Recognised As Safe) regulatory classification.

TABLE III
THERMOPHYSICAL PROPERTIES OF 30% PROPYLENE GLYCOL SOLUTION BY VOLUME

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
0	1042.0	3710	4.150	3.983	0.382	40.31
30	1035.0	3780	1.820	1.758	0.395	17.43
60	1029.0	3840	0.940	0.913	0.407	8.87
90	1025.0	3890	0.520	0.507	0.415	4.87
120	1014.0	3950	0.340	0.335	0.421	3.19

3) *50% Propylene Glycol Aqueous Solution (Heavy Freeze-Protection Standard)*: Table IV provides the industry-standard 50% by volume concentration, delivering a freeze point of approximately −33°C. This is the most commonly specified concentration for outdoor or unheated plant installations in temperate and cold climates. Viscosity penalty at low temperatures is significant; cold-start hydraulic loading must be evaluated against pump curve data.

TABLE IV
THERMOPHYSICAL PROPERTIES OF 50% PROPYLENE GLYCOL SOLUTION BY VOLUME

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
−20	1058.0	3570	22.400	21.172	0.358	223.2
0	1052.0	3620	8.600	8.175	0.366	85.0
20	1044.0	3670	3.800	3.640	0.374	37.3
40	1036.0	3730	2.050	1.979	0.381	20.1
60	1026.0	3790	1.210	1.179	0.387	11.8
80	1015.0	3850	0.780	0.769	0.391	7.7
100	1002.0	3910	0.530	0.529	0.394	5.3

4) *40% Ethylene Glycol Aqueous Solution (High-Efficiency HVAC/Chilling Loop)*: Table V catalogs industrial ethylene glycol parameters at 40% by volume, with a freeze point of approximately −24°C. Optimised for heavy-duty process chilling runs; note that ethylene glycol is toxic and requires appropriate secondary containment in food-adjacent environments.

5) *50% Ethylene Glycol Aqueous Solution (Maximum Standard Freeze Protection)*: Table VI documents the 50% by volume ethylene glycol concentration, delivering a freeze point of approximately −37°C. This is the maximum concentration recommended for standard hydronic service; higher concentrations offer diminishing freeze-point depression with increasing viscosity penalty. Widely stocked as a pre-mixed inhibited product.

TABLE V
THERMOPHYSICAL PROPERTIES OF 40% ETHYLENE GLYCOL SOLUTION BY VOLUME

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
−20	1078.0	3380	9.420	8.738	0.401	79.43
10	1063.0	3480	2.860	2.691	0.418	23.81
40	1049.0	3580	1.340	1.277	0.429	11.18
70	1033.0	3680	0.790	0.765	0.438	6.64
100	1016.0	3790	0.510	0.502	0.443	4.36

TABLE VI
THERMOPHYSICAL PROPERTIES OF 50% ETHYLENE GLYCOL SOLUTION BY VOLUME

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
−30	1089.0	3260	27.600	25.344	0.384	234.4
−10	1079.0	3310	7.400	6.858	0.393	62.4
10	1069.0	3360	3.280	3.068	0.401	27.5
30	1057.0	3420	1.870	1.769	0.408	15.7
60	1039.0	3510	0.980	0.943	0.416	8.3
90	1019.0	3610	0.590	0.579	0.421	5.1

6) *Therminol 66 (Synthetic Organic High-Temperature Thermal Oil Standard)*: Table VII documents the behaviour of Therminol 66, a synthetic organic heat-transfer liquid manufactured by Eastman. Applied when hot-side temperatures must exceed 150°C to 345°C without generating extreme steam pressures. Note the extreme Prandtl number at cold-start conditions (50°C): the cold-start viscosity correction for U_{cold} in Step 6 is mandatory for this fluid class.

TABLE VII
THERMOPHYSICAL PROPERTIES OF THERMINOL 66 LIQUID HEAT TRANSFER FLUID

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
50	981.0	1660	58.200	59.327	0.116	832.74
100	953.0	1845	6.800	7.135	0.112	111.96
150	923.0	2030	1.950	2.113	0.108	36.65
200	893.0	2215	0.880	0.985	0.104	18.74
250	861.0	2400	0.490	0.569	0.101	11.64
300	828.0	2585	0.310	0.374	0.097	8.26
345	795.0	2760	0.210	0.264	0.093	6.23

7) *Therminol VP-1 / Dowtherm A (Diphenyl Oxide Eutectic, High-Performance Industrial Standard)*: Table VIII covers Therminol VP-1 and its equivalent Dowtherm A (both are diphenyl/diphenyl oxide eutectic blends with near-identical property profiles). Operating range 12°C to 400°C. This is the primary benchmark fluid for solar thermal, concentrated chemical processing, and high-temperature reactor jacket applications. Vapour pressure is non-negligible above 200°C; system pressurisation must be confirmed against saturation data. Do not use in food-contact environments.

TABLE VIII
THERMOPHYSICAL PROPERTIES OF THERMINOL VP-1 / DOWTHERM A

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
20	1060.0	1550	3.990	3.764	0.138	44.81
50	1039.0	1600	1.880	1.809	0.135	22.27
100	1004.0	1680	0.940	0.936	0.130	12.15
150	968.0	1760	0.560	0.579	0.125	7.88
200	930.0	1850	0.370	0.398	0.119	5.75
250	891.0	1950	0.260	0.292	0.113	4.49
300	849.0	2060	0.190	0.224	0.107	3.66
350	805.0	2180	0.145	0.180	0.101	3.13
400	757.0	2310	0.112	0.148	0.095	2.73

8) *Caloria HT 43 (Mineral-Based Thermal Oil, Low-to-Medium Temperature)*: Table IX documents Caloria HT 43 (ExxonMobil), a highly refined mineral oil thermal fluid. Operating range −10°C to 170°C. Lower procurement cost than synthetic alternatives makes it attractive for budget-constrained installations with moderate temperature requirements. Oxidation stability is inferior to synthetic fluids; fluid monitoring and periodic replacement schedules are mandatory above 140°C. Not food-grade.

9) *Mobiltherm 603 (Mineral-Based Thermal Oil, Standard Industrial Grade)*: Table X covers Mobiltherm 603 (ExxonMobil Mobil), a widely distributed mineral thermal oil for continuous service up to 315°C. One of the most commonly stocked thermal oils globally, making it the practical default for installations where supply chain reliability is prioritised over peak thermal performance. Flash point $\approx$ 180°C; fire safety classification must be confirmed against local plant codes.

10) *Paratherm NF (Food-Safe Synthetic Thermal Oil, NSF HX-1 Registered)*: Table XI documents Paratherm NF, a synthetic paraffinic thermal fluid carrying NSF HX-1 registration for incidental food contact. Operating range −20°C to 260°C. This

TABLE IX
THERMOPHYSICAL PROPERTIES OF CALORIA HT 43 MINERAL THERMAL OIL

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
20	869.0	1950	43.500	50.058	0.134	633.2
40	857.0	2000	18.200	21.237	0.131	278.0
60	845.0	2060	8.600	10.178	0.129	137.4
80	833.0	2120	4.500	5.402	0.127	75.1
100	820.0	2180	2.600	3.171	0.125	45.3
130	800.0	2270	1.250	1.563	0.122	23.3
160	780.0	2360	0.680	0.872	0.119	13.5

TABLE X
THERMOPHYSICAL PROPERTIES OF MOBILTHERM 603 THERMAL OIL

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
40	868.0	1980	16.800	19.355	0.133	250.2
80	844.0	2080	4.750	5.629	0.129	76.6
120	820.0	2190	1.920	2.341	0.125	33.6
160	795.0	2300	0.970	1.220	0.121	18.4
200	769.0	2420	0.570	0.741	0.117	11.8
250	736.0	2570	0.330	0.448	0.112	7.6
300	702.0	2720	0.210	0.299	0.107	5.3

is the preferred selection for food processing, pharmaceutical manufacturing, and confectionery applications where regulatory compliance requires a certified food-safe fluid but the operating temperature exceeds the practical range of glycol-water solutions. Thermally stable with low odour and low toxicity.

TABLE XI
THERMOPHYSICAL PROPERTIES OF PARATHERM NF FOOD-SAFE THERMAL OIL

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
20	840.0	2040	10.700	12.738	0.140	155.9
50	823.0	2100	4.100	4.983	0.137	62.8
80	806.0	2170	1.980	2.457	0.134	32.1
120	781.0	2270	0.880	1.127	0.130	15.4
160	756.0	2370	0.470	0.622	0.126	8.8
200	729.0	2470	0.290	0.398	0.122	5.9
240	701.0	2580	0.195	0.278	0.118	4.3

11) *Syltherm 800 (Silicone-Based Thermal Fluid, Wide-Range Specialty)*: Table [XII](#) covers Syltherm 800 (Dow), a polydimethylsiloxane-based (silicone) thermal fluid rated for continuous service from -40°C to 260°C , with intermittent use to 315°C . Outstanding low-temperature fluidity (low pour point, moderate viscosity at -40°C) makes it the dominant selection for pharmaceutical freeze-dry jacket loops, semiconductor temperature conditioning, and wide-range process cycling. Higher cost than hydrocarbon alternatives; silicone fluid contamination is incompatible with certain downstream processes and coating operations.

TABLE XII
THERMOPHYSICAL PROPERTIES OF SYLTHERM 800 SILICONE THERMAL FLUID

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
-40	1006.0	1380	21.000	20.874	0.132	219.5
-20	990.0	1420	8.700	8.788	0.130	95.1
0	975.0	1460	4.200	4.308	0.128	47.9
40	943.0	1540	1.600	1.697	0.124	19.9
80	910.0	1620	0.800	0.879	0.120	10.8
120	877.0	1710	0.470	0.536	0.116	6.9
160	843.0	1800	0.310	0.368	0.112	5.0
200	808.0	1900	0.220	0.272	0.108	3.9
260	756.0	2050	0.145	0.192	0.102	2.9

12) *50% Glycerin Aqueous Solution (Sanitary Food / Pharmaceutical Standard)*: Table [XIII](#) provides metrics for refined aqueous glycerol loops at 50% by mass. This choice is common in sanitary process facilities due to its bio-safe, non-toxic profile under accidental product-contact failure scenarios. Notably high viscosity demands careful pump selection and hydraulic loop analysis; laminar flow conditions are likely at lower operating temperatures and must be evaluated against the Nusselt number correlations appropriate for the flow regime.

13) *Food-Grade Vegetable Thermal Oil (Confectionery / Edible Oil Processing)*: Table [XIV](#) provides representative thermophysical data for refined food-grade vegetable oil (palm/sunflower/canola blend), applicable to confectionery, chocolate processing, edible oil refining, and dairy fat handling installations where direct product contact is a credible failure mode. Properties are presented for a representative refined palm-sunflower blend; actual values vary with specific oil composition and should be

TABLE XIII
THERMOPHYSICAL PROPERTIES OF 50% GLYCERIN SOLUTION BY MASS

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
10	1134.0	3220	7.950	7.011	0.415	61.68
30	1124.0	3300	3.820	3.399	0.428	29.45
50	1113.0	3390	2.180	1.959	0.439	16.84
70	1101.0	3480	1.390	1.262	0.446	10.85
90	1088.0	3570	0.960	0.882	0.450	7.62

verified against the supplier's data sheet for the procurement batch. Operating ceiling approximately 180°C; oxidation degradation accelerates above 150°C and fluid replacement intervals must be shortened accordingly.

TABLE XIV
THERMOPHYSICAL PROPERTIES OF FOOD-GRADE VEGETABLE THERMAL OIL

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
40	910.0	1950	36.000	39.560	0.168	417.9
60	898.0	1990	16.200	18.040	0.166	194.4
80	886.0	2030	8.500	9.594	0.164	105.2
100	873.0	2080	4.900	5.613	0.162	62.9
120	860.0	2130	3.100	3.605	0.160	41.3
150	840.0	2200	1.700	2.024	0.157	23.8

14) *D'Limonene-Based Thermal Fluid (Bio-Derived, Food-Adjacent Specialty)*: Table XV documents thermal fluid properties for high-purity d-limonene, a bio-derived citrus terpene increasingly specified in food-adjacent installations due to its natural origin, low toxicity, and pleasant odour profile. Operating range approximately 0°C to 175°C. While thermophysical performance is modest relative to synthetic thermal oils, regulatory acceptance in food-contact risk environments and lower environmental impact make it a commercially viable niche selection. Flash point $\approx$ 49°C; fire classification is Class IC flammable liquid and strict hot-work permit controls apply.

TABLE XV
THERMOPHYSICAL PROPERTIES OF D'LIMONENE BIO-DERIVED THERMAL FLUID

Temp. T (°C)	Density ρ (kg/m ³)	Sp. Heat c_p (J/kg·K)	Dyn. Viscosity μ ($\times 10^{-3}$ Pa·s)	Kin. Viscosity ν ($\times 10^{-6}$ m ² /s)	Thermal Cond. k (W/m·K)	Prandtl Pr
20	841.0	1860	0.920	1.094	0.143	11.97
40	828.0	1910	0.730	0.882	0.140	9.97
60	814.0	1960	0.590	0.725	0.138	8.38
80	800.0	2010	0.490	0.613	0.135	7.29
100	786.0	2060	0.410	0.522	0.133	6.35
140	756.0	2170	0.300	0.397	0.128	5.09

L. Solid Material and Insulation Thermal Properties

Conductive resistances (R_{wall} and $R_{insulation}$) across Steps 6 and 9 rely on core material transport metrics. Table XVI establishes wall conductivities, while Table XVII provides insulation property targets evaluated at 20°C atmospheric reference settings.

TABLE XVI
THERMAL CONDUCTIVITIES OF STANDARD STRUCTURAL METAL ALLOYS

Metallurgical Material Specification	Thermal Conductivity k (W/m·K)
Carbon Steel (AISI 1020 / Standard Line)	50.0
Stainless Steel 304 (Austenitic Standard)	16.2
Stainless Steel 316 (High-Corrosion Resist)	15.0
Nickel Alloy 625 (Inconel Core Variant)	9.8
Copper (Drawn Tube Standard C12200)	390.0
Titanium (Grade 2 Unalloyed Core)	21.9

TABLE XVII
THERMAL PROPERTIES OF INDUSTRIAL SHELL INSULATION CLADDINGS

Insulation Material Type	Thermal Conductivity k (W/m·K)	Max Temp Rating (°C)
Rigid Polyurethane Foam (PUF)	0.024	120
Mineral Wool / Rockwool Board	0.038	650
Fiberglass Blanket Insulation	0.040	540
Expanded Polystyrene (EPS)	0.035	75
Calcium Silicate Structural Sheet	0.055	900

M. Industrial Design Boundary Allowances

To ensure the sized machinery retains performance margins across multi-year operational cycles, fluid friction and thermal performance elements must be penalised using surface degradation metrics.

1) *Absolute Pipe Material Surface Roughness Values:* Table XVIII specifies the absolute physical surface roughness (ε) used as the core input seed parameter for the Colebrook-White iterative hydraulic head loss calculations (Step 5).

TABLE XVIII
ABSOLUTE SURFACE ROUGHNESS PARAMETERS (ε)

Piping Material Specification Profile	Absolute Roughness ε (mm)
Drawn Plastic Piping (PVC / CPVC / PVDF)	0.0015
Drawn Copper Tubing (Clean Commercial)	0.0015
Commercial Stainless Steel Line (New/Clean)	0.0150
Commercial Carbon Steel / Wrought Iron	0.0450
Galvanized Iron / Zinc Coated Steel	0.1500
Heavily Corroded / Scaled Cast Iron Shell	1.5000

2) *Standard Industrial Fluid Fouling Heat Transfer Resistances:* Table XIX logs the standard thermal fouling resistance penalties (R_{f_in} , R_{f_out}). These terms apply localised heat-blocking penalties to the series thermal network calculation (Step 6) to model scaling and process deposition across the lifespan of the equipment.

TABLE XIX
STANDARD INDUSTRIAL FOULING THERMAL RESISTANCE PENALTIES

Fluid Circuit Operating Environment	Fouling Resistance R_f ($\text{m}^2 \cdot \text{K}/\text{W}$)
Distilled Water / Demineralised Loop Fluid	0.0001
Treated Boiler Feedwater (Closed Utility Run)	0.0002
Clean Inhibited Glycol Aqueous Solutions	0.0002
City Tap Water (Standard Municipal Intake)	0.0003
River Water / Untreated Cooling Tower Fluid	0.0005
Light Organic Process Fractions / Light Oils	0.0004
Synthetic Thermal Oils (Clean Service)	0.0002
Mineral Thermal Oils (Standard Service)	0.0003
Silicone Thermal Fluids (Clean Service)	0.0001
Heavy Crude Fractions / Slurry Process Fluids	0.0010

APPENDIX C COMMERCIAL PIPING STANDARDS AND MATERIAL PROFILES

This appendix consolidates the mechanical, geometric, and thermomechanical data required to execute the Nominal Pipe Size (NPS) selection and structural material confirmation outlined in Step 4 of the framework. It includes standardized ASME dimensional boundaries for fluid flow cross-sections and comprehensive material evaluation matrices to ensure thermodynamic efficiency, structural integrity, and chemical compatibility across the operational lifespan of the hydronic system.

N. ASME B36.10M and B36.19M Pipe Dimensional Data

To safely constrain internal fluid velocities below the erosion ceiling ($v \leq v_{max}$), the theoretical minimum flow area calculated in Step 4 must be matched to a discrete, commercially available pipe profile. Table XX lists standard dimensions for Welded and Seamless Wrought Steel (ASME B36.10M) and Stainless Steel (ASME B36.19M) pipe across typical industrial schedules.

TABLE XX
STANDARD COMMERCIAL PIPE DIMENSIONS (NPS 1/2" TO 8")

Nominal Size NPS (inches)	Outer Diameter d_{outer} (mm)	Schedule Designator	Wall Thickness t_{wall} (mm)	Inner Diameter d_{in} (mm)	Internal Flow Area A_{in} ($\times 10^{-3}$ m ²)
1/2"	21.34	Sch 10S	2.11	17.12	0.230
	21.34	Sch 40	2.77	15.80	0.196
	21.34	Sch 80	3.73	13.88	0.151
1"	33.40	Sch 10S	2.77	27.86	0.610
	33.40	Sch 40	3.38	26.64	0.557
	33.40	Sch 80	4.55	24.30	0.464
1-1/2"	48.26	Sch 10S	2.77	42.72	1.433
	48.26	Sch 40	3.68	40.90	1.314
	48.26	Sch 80	5.08	38.10	1.140
2"	60.33	Sch 10S	2.77	54.79	2.358
	60.33	Sch 40	3.91	52.51	2.165
	60.33	Sch 80	5.54	49.25	1.905
3"	88.90	Sch 10S	3.05	82.80	5.384
	88.90	Sch 40	5.49	77.92	4.768
	88.90	Sch 80	7.62	73.66	4.261
4"	114.30	Sch 10S	3.05	108.20	9.195
	114.30	Sch 40	6.02	102.26	8.213
	114.30	Sch 80	8.56	97.18	7.417
6"	168.28	Sch 10S	3.40	161.48	20.480
	168.28	Sch 40	7.11	154.06	18.641
	168.28	Sch 80	10.97	146.34	16.819
8"	219.08	Sch 10S	3.76	211.56	35.153
	219.08	Sch 40	8.18	202.72	32.276
	219.08	Sch 80	12.70	193.68	29.462

O. Thermomechanical Material Profiles

Selecting the correct material for the vessel shell and internal helical coil directly impacts the Overall Heat Transfer Coefficient (U) derived in Step 6, as well as the maximum structural limits of the system. Table XXI indexes the baseline mechanical and thermal properties of standard industrial materials.

TABLE XXI
THERMOMECHANICAL PROPERTIES OF COMMERCIAL STRUCTURAL & PIPING MATERIALS

Material Specification (Common Designation)	Density ρ (kg/m ³)	Thermal Cond. k (W/m · K)	Yield Strength S_y (MPa)	Max Operating Temp (°C)	Relative Cost Factor
<i>Ferrous Alloys (Standard Vessel & Structural Shells)</i>					
Carbon Steel (AISI 1020)	7850	50.0	250	425	1.0x
Carbon Steel (A106 Grade B)	7850	48.0	240	400	1.1x
Cast Iron (Gray, Class 30)	7150	45.0	130	350	0.8x
<i>Stainless Alloys (Sanitary & Corrosive Environments)</i>					
Stainless Steel (304 / 304L)	8000	16.2	215	870	3.5x
Stainless Steel (316 / 316L)	8000	15.0	205	870	4.5x
Duplex Stainless (2205)	7800	19.0	450	300	6.0x
<i>Non-Ferrous & Specialty Metals (High Thermal Transfer)</i>					
Copper (Drawn, C12200)	8940	390.0	100	200	4.0x
Aluminum (6061-T6)	2700	167.0	275	150	2.0x
Titanium (Grade 2 Unalloyed)	4510	21.9	275	315	12.0x
Inconel (Alloy 625)	8440	9.8	460	980	15.0x
<i>Industrial Polymers (Low-Temp Chilling & Utility)</i>					
PVC (Polyvinyl Chloride)	1380	0.19	40	60	0.5x
CPVC (Chlorinated PVC)	1550	0.14	55	93	0.8x
PEX (Cross-linked Polyethylene)	940	0.40	15	95	0.7x
PTFE (Teflon / Lined Piping)	2200	0.25	25	260	8.0x

P. Material Compatibility and Selection Criteria Matrix

To prevent galvanic corrosion, chemical degradation, or thermal failure, the selected piping and vessel materials must be validated against the primary process fluid and the hydronic heat-transfer fluid. Table XXII provides a selection matrix mapping standard materials to their appropriate operational environments.

TABLE XXII
MATERIAL SUITABILITY MATRIX FOR HYDRONIC PROCESS FLUIDS

Hydronic / Process Fluid	Carbon Steel	SS 304 / 316	Copper	CPVC / PEX
Pure Water (Deionized / RO)	POOR (Rusts)	EXCELLENT	GOOD	EXCELLENT
Treated Boiler Feedwater (Hot)	EXCELLENT	EXCELLENT	GOOD	POOR (Temp Limits)
Propylene / Ethylene Glycols	GOOD (w/ Inhibitor)	EXCELLENT	EXCELLENT	GOOD (Low Temp)
Therminol 66 (Thermal Oil)	EXCELLENT	EXCELLENT	POOR	UNSUITABLE
Glycerin Solutions (Sanitary)	POOR (Taints)	EXCELLENT	POOR	POOR
Brine / High-Chloride Chilling	POOR (Pitting)	POOR (Requires 316)	GOOD	EXCELLENT

Note: "EXCELLENT" denotes standard industry application with lifespan > 15 years.
"POOR" indicates rapid degradation, galvanic potential, or unacceptable process contamination.

C.D Pipe Fittings and Connections

The hydraulic resistance characterisation performed in Step 5 of the framework requires that all fittings installed within the hydronic circuit be accounted for through their equivalent pipe length contributions. Each fitting introduces a localised pressure drop that, if neglected, will cause the pump selection to be undersized and the actual flow velocity to fall below design intent. Table XXIII provides standard equivalent length values (L_{eq}) for common wrought and forged fittings conforming to ASME B16.9 (butt-weld), ASME B16.11 (socket-weld and threaded), and ASME B16.5 (flanges). These values are expressed as a ratio to nominal pipe diameter (L_{eq}/d_{in}) and are valid for fully turbulent flow conditions consistent with coil operating Reynolds numbers.

TABLE XXIII
EQUIVALENT LENGTH RATIOS FOR STANDARD INDUSTRIAL FITTINGS (ASME B16.9 / B16.11)

Fitting Type	Connection Standard	Equivalent Length Ratio L_{eq}/d_{in}		
		NPS $\leq 1''$	NPS 1.5''–3''	NPS 4''–8''
<i>Elbows</i>				
90° Standard Elbow	B16.9 BW	30	30	30
90° Long-Radius Elbow	B16.9 BW	16	16	16
45° Standard Elbow	B16.9 BW	16	16	16
<i>Tees</i>				
Tee, Flow-Through (Run)	B16.9 BW	20	20	20
Tee, Flow-Through (Branch)	B16.9 BW	60	60	60
<i>Reducers & Couplings</i>				
Concentric Reducer	B16.9 BW	5	5	5
Eccentric Reducer	B16.9 BW	5	5	5
Full-Coupling / Union	B16.11 SW	2	2	2
<i>Valves (Fully Open)</i>				
Gate Valve	B16.10	8	8	8
Globe Valve	B16.10	340	340	340
Ball Valve (Full Port)	B16.34	3	3	3
Butterfly Valve	B16.34	45	45	45
Check Valve (Swing)	B16.10	100	100	100
<i>Flanged Connections</i>				
Weld-Neck Flange (pair)	B16.5	2	2	2
Slip-On Flange (pair)	B16.5	2	2	2
<i>Note: BW = Butt-Weld; SW = Socket-Weld. Values based on Crane TP-410 turbulent flow data. For laminar flow ($Re < 2300$), apply the laminar correction factor $K_L = K \cdot (Re/1000)$.</i>				

C.E Welding and Joining Standards

All pressure-retaining joints in the hydronic vessel and coil assembly must conform to a recognised fabrication code. The applicable standard is determined by the operating pressure class, material group, and service fluid. Table XXIV maps common joint configurations to their governing ASME and AWS codes and specifies the minimum examination requirements that must be satisfied before the design verification gate in Step 11. Compliance with these requirements is a prerequisite for the formal sign-off on the completed design package.

TABLE XXIV
WELDING AND JOINING STANDARDS FOR HYDRONIC PRESSURE VESSELS AND COIL ASSEMBLIES

Joint Application	Governing Code	Weld Process	Filler / Electrode	Min. Examination Req.
Carbon Steel Vessel Shell (Butt Weld)	ASME Sec. IX / ASME VIII Div. 1	SMAW, GTAW, GMAW	E7018 / ER70S-6	Visual + RT or UT per UW-11
SS 304/316 Vessel Shell	ASME Sec. IX	GTAW (Root), GMAW (Fill)	ER308L / ER316L	Visual + 100% PT on root pass
Coil-to-Header Connection	ASME B31.3 (Process)	GTAW (orbital preferred)	ER316L / ER308L	Visual + 5% RT spot check
Coil Butt Joints (Same Material)	ASME B31.3	GTAW	Match base metal	Visual + Hydrostatic proof test
Nozzle / Stub-In (Vessel Shell)	ASME VIII Div. 1 UW-16	SMAW / GTAW	Match base metal	Visual + MT or PT (full)
Dissimilar Metal (CS to SS)	ASME Sec. IX / AWS D1.6	GTAW (butter layer)	ENiCrFe-3 (Inconel)	Visual + 100% RT
Flange Face (Slip-On / Weld-Neck)	ASME B16.5 / Sec. IX	SMAW / GTAW	Match base metal	Visual + hydrostatic leak test
Low-Pressure (< 150 psig)	Utility AWS D1.1 (Structural)	SMAW / FCAW	E7018 / E71T-1	Visual per AWS D1.1 Table 6.1

RT = Radiographic Testing; UT = Ultrasonic Testing; PT = Liquid Penetrant Testing; MT = Magnetic Particle Testing. All welders must hold current ASME Section IX or AWS QC1 qualification for the applicable process and material group.

C.F Gasket and Seal Material Compatibility

Flanged connections and inspection ports within the hydronic circuit require a gasket or seal whose material is independently verified against both the process fluid and the operating temperature range. Selection errors at this stage are a common root cause of slow seepage failures that are not captured during short-duration hydrostatic proof tests. Table **XXV** maps standard gasket and elastomeric seal materials to their effective operational envelopes. The temperature ratings listed represent continuous service limits; cyclic thermal shock conditions typical of batch processing duty should be assessed with a 15% de-rating applied to the upper temperature boundary.

TABLE XXV
GASKET AND SEAL MATERIAL COMPATIBILITY FOR HYDRONIC PROCESS FLUIDS

Gasket / Seal Material	Max (°C)	Temp.	Max (bar)	Press.	Compatible Fluids	Incompatible / Caution
PTFE (Virgin / Expanded)	260		70		Water, glycols, glycerin, acids, thermal oils, brine	Strong oxidisers; PTFE cold-flows under bolt load — use spiral-wound type above 40 bar
Spiral-Wound SS/PTFE	450		250		Steam, hot water, glycols, thermal oils	Not for cryogenic; requires flat-face flange
Nitrile (NBR)	120		35		Water, glycols, mineral oils, brine	Aromatic hydrocarbons; thermal oils (Therminol) cause swelling
EPDM (Ethylene Propylene)	150		20		Hot water, steam (low press.), glycols, dilute acids	Petroleum-based oils and solvents; Therminol series
Viton (FKM Fluoroelastomer)	200		35		Thermal oils, glycols, brine, mild acids, hot water	Steam above 150°C; ketones; low-molecular-weight esters
Graphite (Flexible Foil)	450		200		Hot water, steam, thermal oils, glycols, most process fluids	Strong oxidising acids (e.g. HNO ₃); not food-grade without encapsulation
Neoprene (CR)	100		20		Water, glycols, brine, mild alkalis	Aromatic solvents; thermal oils; strong oxidisers
Silicone (VMQ)	230		15		Hot water (low press.), steam (low press.), food-grade glycerin	Petroleum oils; acids; steam above 150°C

*All food-contact or sanitary applications must use FDA-compliant (21 CFR 177) grades of PTFE, EPDM, or Silicone.
Spiral-wound gaskets must be specified with inner and outer guide rings per ASME B16.20.*

C.G Insulation Materials and Thermal Properties

The environmental heat loss term Q_{loss} quantified in Step 5 of the framework is governed by the total thermal resistance of the vessel boundary layer, which includes the insulation jacket as the dominant resistance element. The selection of insulation type directly affects both the steady-state balance load and the payback period on the installed thermal capacity. Table **XXVI** catalogues the thermal and mechanical properties of industrial insulation systems appropriate for hydronic vessel jacketing across the operating temperature range of the framework. The effective thermal conductivity values (k) listed are mean-temperature values; for precision loss calculations, the temperature-dependent $k(T)$ curve from the manufacturer’s datasheet should be used to integrate across the wall temperature gradient.

TABLE XXVI
THERMAL AND MECHANICAL PROPERTIES OF INDUSTRIAL VESSEL INSULATION MATERIALS

Insulation Material	Thermal Cond. k (W/m·K)	Density ρ (kg/m ³)	Service Temp. Range (°C)	Relative Cost	Typical Application
<i>Rigid Foam Systems</i>					
Polyurethane Foam (PUR)	0.022–0.028	30–60	–50 to +120	1.0x	Cold tanks, chilling vessels
Polyisocyanurate (PIR)	0.022–0.026	32–48	–50 to +150	1.2x	Heated vessels, pipework
Extruded Polystyrene (XPS)	0.030–0.038	25–45	–50 to +75	0.7x	Low-temp utility; moisture-resistant
<i>Mineral Fibre Systems</i>					
Glass Wool (Wired Mat)	0.032–0.044	10–48	Up to +450	0.6x	General industrial pipework
Rock Wool (Stone Wool)	0.033–0.045	40–200	Up to +750	0.8x	High-temp vessels and steam lines
Calcium Silicate Board	0.055–0.085	190–300	Up to +1000	1.5x	Very high-temp, structural duty
<i>Flexible & Specialty Systems</i>					
Elastomeric Foam (Armaflex)	0.033–0.040	60–80	–50 to +105	1.8x	Cold pipework; self-sealing joints
Aerogel Blanket	0.013–0.018	100–200	–200 to +650	8.0x	Space-constrained high-value duty
Cellular Glass (Foamglas)	0.038–0.055	100–130	–265 to +430	3.5x	Cryogenic and high-humidity service
<i>Cladding and Jacketing (Outer Weather Barrier)</i>					
Aluminium Sheet (0.6–1.0 mm)	N/A	2700	–200 to +200	1.0x	Standard outdoor and indoor jacketing
Stainless Sheet (0.5–0.8 mm)	N/A	8000	All ranges	2.5x	Corrosive or sanitary environments
PVC Jacketing (Vapour Barrier)	N/A	1380	Up to +60	0.5x	Indoor low-temp chilling only

For the VCH loss model, minimum recommended insulation thickness targets $R_{ins} \geq 1.0 \text{ m}^2 \cdot \text{K/W}$ for heated vessels.
Insulation systems in food-processing or pharmaceutical environments must comply with local hygiene codes (e.g. EHEDG, 3-A Sanitary Standards).

C.H Coil Fabrication Tolerances and Bend Radius Data

The coil geometry optimisation performed in Step 7 produces a theoretical helix diameter, coil pitch, and number of turns. These ideal dimensions must be mapped to physically realisable fabrication parameters before the coil can be ordered or manufactured. Two constraints govern this translation: the minimum bend radius that a given pipe size and material can sustain without wall thinning or ovality beyond acceptable limits, and the compound packing efficiency factor η_{pack} that accounts for the systematic loss of usable coil turns introduced by fabrication tolerances, structural supports, weld access clearances, thermal expansion gaps, and dead-zone prevention offsets at the top and bottom of the vessel.

Table **XXVII** provides the minimum centreline bend radius (R_{min}) expressed as a multiple of nominal outer diameter (D) for mandrel bending of seamless and welded tube, consistent with ASME B16.49 (factory bends) and EN 13480-4 (industrial piping). Table **XXVIII** quantifies the individual tolerance deductions that compound into the η_{pack} correction applied in Step 7.

TABLE XXVII
MINIMUM CENTRELINE BEND RADIUS FOR HELICAL COIL FABRICATION

Pipe Material	Fabrication Method	Min. Centreline Radius R_{min} (multiples of D_{outer})			
		NPS 1/2"–1"	NPS 1.5"–2"	NPS 3"–4"	NPS 6"–8"
Carbon Steel (Seamless)	Cold Mandrel Bend	$1.5D$	$2.0D$	$3.0D$	$5.0D$
Carbon Steel (Seamless)	Hot Induction Bend	$1.5D$	$1.5D$	$2.0D$	$3.0D$
Stainless 304/316 (Seamless)	Cold Mandrel Bend	$2.0D$	$2.5D$	$3.5D$	$5.0D$
Stainless 304/316 (Seamless)	Hot Induction Bend	$1.5D$	$2.0D$	$2.5D$	$3.5D$
Copper (Drawn, C12200)	Cold Spring Bending	$1.5D$	$2.0D$	$3.0D$	N/A
Titanium Grade 2	Cold Mandrel Bend	$3.0D$	$3.5D$	$5.0D$	N/A

*Radii below these limits risk wall thinning > 12.5% or ovality > 8% per ASME B16.49 acceptance criteria.
For tight-pitch helical coils wound on a mandrel, confirm that the helix diameter $D_{helix} \geq 2 \times R_{min}$.*

TABLE XXVIII
COIL PACKING EFFICIENCY DEDUCTION FACTORS COMPRISING η_{pack}

Deduction Source	Physical Basis	Typical Deduction	Notes
Structural Support Legs	Radial supports interrupt coil continuity at ≥ 3 points	2–4 turns	Fixed loss per coil
Weld Access Clearance (Top)	Minimum 50–75 mm clearance from vessel top head to first active turn	1–2 turns	Increases with NPS
Weld Access Clearance (Bottom)	Minimum 50–75 mm clearance from vessel base to last active turn	1–2 turns	Increases with NPS
Thermal Expansion Gap	Axial growth of helical coil at $\Delta T_{operating}$	0.5–1 turn	Per 10 m coil length
Dead-Zone Prevention (Top)	Stagnant fluid zone above coil top must be minimised	1 turn	Heating applications
Dead-Zone Prevention (Bottom)	Stagnant fluid zone below coil bottom must be minimised	1 turn	Cooling applications
Coil Pitch Rounding	Discrete turn count rounded down to nearest integer	0–1 turn	Deterministic

Typical Composite η_{pack} Range **0.80 – 0.92**

η_{pack} is applied as: $N_{active} = \lfloor N_{theoretical} \times \eta_{pack} \rfloor$, where $N_{theoretical}$ is derived from the Step 7 optimisation.
For large-diameter vessels ($ID > 1.5$ m) with multiple coil banks, each bank should carry an independent η_{pack} assessment.

APPENDIX D
DISTRIBUTED PROCESS AUTOMATION AND CONTROL ARCHITECTURE
VERSION 1 — ARCHIVED

ARCHITECTURAL SUPERSESSION NOTICE

This version of Appendix D (Version 1) is retained in full as an archived record of the initial single-loop control architecture developed during the first design iteration of the VCH Sizing Framework. It is preserved deliberately to document the evolution of the control philosophy and to demonstrate the engineering decision trail that led to the revised architecture.

This appendix has been superseded in its entirety by **Appendix F — Revised Control Architecture (Version 2)**, which should be consulted for all current design, commissioning, and implementation purposes. The following sections of this document contain content that conflicts with the Version 2 architecture and must not be used as implementation references:

- **Section D.A** — The four operational modes (Mode I through Mode IV) have been replaced by a revised three-loop mode structure (1.A.1, 1.A.2, B, C) in Appendix F, Section F.A. The Mode IV multi-vessel balancing logic has been retained in a modified form.
- **Section D.B** — The instrumentation table is incomplete relative to the Version 2 I/O schedule. Instruments TE-104 and TE-105 (battery inlet and outlet temperature) are absent. The full 25-point I/O schedule is defined in Appendix F, Section F.B.
- **Section D.C** — The PLC state machine reflects the Version 1 mode structure and does not map to the Version 2 operational states. The updated state transition matrix is provided in Appendix F, Section F.C.
- **Section D.D** — The single master-slave cascade topology described herein has been replaced by three independent control loops with defined controller types (PID, PI, P). Refer to Appendix F, Section F.D.

Sections **D.E through D.H** (HMI/SCADA alarm philosophy, PID tuning parameters, network architecture, and FMEA) remain substantively valid and have been carried forward into Appendix F with targeted amendments to reflect the revised I/O schedule and mode structure. Where discrepancies exist between D.E–D.H and their Appendix F counterparts, the Appendix F version takes precedence.

Superseded by: Appendix F — Revised Control Architecture (Version 2)
documentation

Retention rationale: Engineering decision record / portfolio

SECTION CONFLICT — D.A The four-mode structure defined below (Modes I–IV) has been superseded. Refer to Appendix F, Section F.A for the current operational mode architecture. Do not implement from this section.

D.A Control Philosophy and Multi-Vessel Operational Modes

To maintain fluid velocity beneath the erosion boundary ($v \leq v_{max}$) while fulfilling transient thermal demands during a batch cycle, the system alternates between four primary operational configurations via automated modulating three-way valves (TCVs) and variable-frequency drive (VFD) circulation loops:

- 1) **Mode I: Baseline Utility Supply (Direct Charging):** Activated when the total process load is below the steady-state boiler capacity ($Q_{load} \leq Q_{steady}$). The thermal battery is structurally isolated, and the utility line directly handles vessel demands using standard feedback proportional-integral-derivative (PID) tuning.
- 2) **Mode II: Peak Shaving / Battery-Assist Discharge:** Prompted automatically when a new process batch initiates and thermal demand spikes past utility capacity ($Q_{load} > Q_{steady}$). The system activates a feed-forward control block, modulating a secondary three-way valve to blend high-temperature fluid from the thermal battery into the loop, maintaining a fixed batch heating rate without overloading the utility.
- 3) **Mode III: Isolated Thermal Battery Recharge:** Triggered during process downtime or low-load intervals. Excess utility energy ($Q_{steady} - Q_{load}$) is diverted into the thermal battery vessel, raising its core internal energy state until upper thermal cutoff boundaries are reached.
- 4) **Mode IV: Multi-Vessel Load Balancing Mode:** Utilizing a distributed cascade architecture, the master Programmable Logic Controller (PLC) monitors real-time temperature differentials ($\Delta T = T_{in} - T_{out}$) across multiple independent vessels. Flow distribution is dynamically scaled using a prioritize-by-deviation algorithm, shifting hydronic volume to vessels exhibiting the steepest temperature drop.

SECTION CONFLICT — D.B The instrumentation table below is incomplete. Instruments TE-104 and TE-105 are absent. The full 25-point I/O schedule supersedes this table. Refer to Appendix F, Section F.B.

D.B Instrumentation, Sensors, and Actuator Field Profiles

Executing the velocity constraints and energy tracking requirements defined across the core framework requires a synchronized field instrument network. Table XXIX catalogs the sensor characteristics, signal transmission standards, and functional roles mandated within the hydronic loop.

TABLE XXIX
FIELD INSTRUMENTATION AND SIGNAL MAPPING SPECIFICATIONS (VERSION 1 — INCOMPLETE)

Tag ID	Instrument Description	Sensor Type / Element	Signal Protocol	Functional Framework Role
TE-101	Loop Supply Temperature	PT100 RTD (Class A)	4–20 mA / HART	Monitors main utility output profile
TE-102	Battery Core Temperature	Multipoint Thermocouple	4–20 mA / HART	Computes current state-of-charge (SoC)
TE-103	Vessel Batch Temperature	PT100 RTD (Sanitary)	4–20 mA / HART	Feeds the Step 10 transient integration loop
FE-201	Main Line Velocity Sensor	Electromagnetic Flow	Modbus TCP	Validates velocity constraint ($v \leq 2.0$ m/s)
PE-301	Loop Differential Press.	Piezo-Resistive Cell	4–20 mA / HART	Tracks real-time helical head loss (ΔH_f)
TCV-401	Battery Blending Actuator	3-Way Equal Percentage	4–20 mA Loop	Modulates thermal battery discharge volume
VFD-501	Loop Circulation Pump	AC Induction Inverter	Profinet	Alters pump RPM to maintain hydraulic balance

SECTION CONFLICT — D.C The state machine below maps to Version 1 operational modes only and does not reflect the revised mode structure or three-loop architecture. Do not use as an implementation reference. Refer to Appendix F, Section F.C.

D.C Programmable Logic Controller (PLC) State Transition Matrix

The system logic is implemented within a deterministic state machine to guarantee predictable transitions during sudden multi-vessel load spikes or unexpected system trips. Table **XXX** provides the logical state matrix used to construct the PLC ladder logic or structured text routines.

TABLE XXX
PLC STATE MACHINE TRANSITION SEQUENCE AND SAFETY INTERLOCKS (VERSION 1 — SUPERSEDED)

Current State	System Profile	Primary Trigger Input	Target Output State	Mandatory Interlock / Safety Guard
01_STANDBY	System idling; pump operating at minimum bypass speed.	Batch initiation command received from HMI terminal.	02_UTILITY_ONLY	Confirm loop pressure PE-301 is within stable static bounds (> 1.5 bar).
02_UTILITY_ONLY	Boiler satisfies loop demand; battery remains isolated.	Process load exceeds utility limit: $Q_{load} > 80$ kW.	03_PEAK_ASSIST	Continuous loop velocity tracking: if $v > 2.0$ m/s, trim VFD-501 immediately.
03_PEAK_ASSIST	TCV-401 modulates open to inject battery energy.	Batch cycle completes; thermal load drops below threshold.	04_RECHARGE	If battery core temperature drops below process target, isolate battery and flag alarm.
04_RECHARGE	Excess utility energy routed into storage matrix.	Battery multipoint sensor TE-102 hits upper ceiling.	01_STANDBY	Disable recharge loop instantly if vessel high-pressure switch trips.
05_FAIL_SAFE	All control valves forced to unpowered safety states.	Fluid velocity limit breach ($v > 2.5$ m/s) or hardware fault.	Safe Shutdown (Lockout)	Bypass all process commands; trigger audible field alarm beacon; dump VFD run signals.

SECTION CONFLICT — D.D The single master-slave cascade topology described below has been replaced by three independent control loops. The architectural rationale for this change is documented in Appendix F, Section F.D. Do not implement from this section.

D.D Cascaded Control Loop Proportional-Integral-Derivative (PID) Architecture

To prevent hydraulic hunting when multiple control valves modulate simultaneously, a cascaded control topology is established. The primary master controller monitors the process vessel temperature error ($e(t) = T_{set} - T_{vessel}$) and continuously computes a target hydronic flow rate requirement.

The slave controller receives this flow setpoint and modulates pump speed via VFD-501, referencing electromagnetic flowmeter FE-201 as its direct feedback element. By nesting the velocity loop inside the slower thermal loop, the slave loop can intercept instantaneous pressure fluctuations across the helical network, smoothing out actuator actions and eliminating the risk of accidental erosion velocity overshoots in the system.

NOTE — SECTIONS D.E THROUGH D.H The following sections are substantively valid and have been carried forward into Appendix F with targeted amendments. Where instrument tags referenced below (e.g. alarm setpoints for TE-101-TE-103) differ from the expanded Version 2 I/O schedule, the Appendix F versions take precedence. These sections are not flagged as conflicting and may be read as background reference.

D.E HMI / SCADA Screen Layout and Alarm Philosophy

The human-machine interface (HMI) and supervisory control and data acquisition (SCADA) layer serves as the primary operator window into the hydronic network state. Screen organisation follows ISA-101 (HMI Design and Implementation) principles: each display level presents only the information operationally relevant at that level of abstraction, preventing alarm flooding during transient batch events. The hierarchy comprises three display tiers.

Level 1 — System Overview: A single-screen mimic diagram showing all four operational modes (Section D.A), the real-time state of TCV-401 and VFD-501, live readings from TE-101, TE-102, TE-103, FE-201, and PE-301, the thermal battery state-of-charge (SoC) bar expressed as a percentage of $Q_{battery,max}$, and the current PLC state tag. No control actions are executable from this screen; it is display-only to prevent inadvertent mode changes.

Level 2 — Loop Detail Screens: One screen per controlled loop. Each screen displays the trend history for the relevant temperature, flow, and pressure tags over a configurable 30-minute rolling window, the active setpoint, PV, and output of the governing PID block, and the current interlock status for that loop.

Level 3 — Maintenance and Calibration: Password-protected. Provides manual override capability for individual actuators, PID parameter adjustment, sensor zero/span calibration records, and accumulated run-hour logs for VFD-501.

TABLE XXXI
ALARM SETPOINT AND PRIORITY CLASSIFICATION MATRIX

Tag	Alarm Description	Lo / LoLo Limit	Hi / HiHi Limit	Priority	Required Operator Action
TE-101	Supply temperature out of band	Lo: $T_{set} - 5^{\circ}\text{C}$ LoLo: $T_{set} - 15^{\circ}\text{C}$	Hi: $T_{set} + 10^{\circ}\text{C}$ HiHi: $T_{set} + 25^{\circ}\text{C}$	P2 / P1	Investigate utility source; P1 triggers Mode IV bypass
TE-102	Battery core temperature deviation	Lo: $T_{bat,min}^{\circ}\text{C}$ LoLo: $T_{bat,min} - 10^{\circ}\text{C}$	Hi: $T_{bat,max}^{\circ}\text{C}$ HiHi: $T_{bat,max} + 5^{\circ}\text{C}$	P2 / P1	P1 forces immediate recharge isolation; flag for inspection
TE-103	Vessel batch temperature deviation	Lo: $T_{proc} - 3^{\circ}\text{C}$	Hi: $T_{proc} + 5^{\circ}\text{C}$ HiHi: $T_{proc} + 12^{\circ}\text{C}$	P3 / P2	P2 triggers setpoint review and valve trim audit
FE-201	Loop flow / velocity breach	Lo: 0.3 m/s	Hi: 2.0 m/s HiHi: 2.5 m/s	P2 / P1	P1 trips VFD-501 to minimum; latches 05_FAIL_SAFE
PE-301	Differential pressure loss	LoLo: 0.5 bar	HiHi: 6.0 bar	P1	Isolate loop; inspect coil for fouling or mechanical failure
VFD-501	Drive fault or overtemperature	—	Any drive fault code	P1	Acknowledge; switch to manual bypass pump if installed
TCV-401	Valve position feedback mismatch	$ \text{Commanded} - \text{Actual} > 5\%$ for $> 10\text{ s}$		P2	Check pneumatic/electric actuator supply and positioner

Deadband of $\pm 0.5^{\circ}\text{C}$ applied to all temperature alarms to suppress chattering.

HiHi and LoLo thresholds trigger automatic PLC state transitions; Hi and Lo annunciate only.

D.F PID Tuning Parameters and Recommended Gain Values

The cascaded control topology described in Section D.D requires independently tuned PID blocks for each loop layer. All PID blocks are implemented in the positional (non-velocity) form with output clamping and anti-windup via integrator back-calculation:

$$u(t) = K_p \left[e(t) + \frac{1}{T_i} \int_0^t e(\tau) d\tau + T_d \frac{de(t)}{dt} \right]$$

(107)

Derivative action is applied to the process variable only to prevent derivative kick on setpoint steps.

TABLE XXXII
RECOMMENDED PID TUNING PARAMETERS BY CONTROL LOOP (VERSION 1)

Loop Name	Controlled Variable	Actuator	K_p	T_i (s)	T_d (s)	Notes
Master Thermal (Outer)	Vessel batch temperature TE-103	TCV-401 po- sition setpoint	1.8–2.5	180–300	15–30	Slow integrating process; low K_p prevents overshoot on batch start
Slave Hydraulic (Inner)	Loop flow velocity FE-201	VFD-501 speed (%)	0.8–1.4	8–20	1–3	Fast loop; T_d active to suppress pressure transient spikes
Battery Discharge	Battery blend ratio via TCV-401	TCV-401 direct	2.0–3.0	60–120	0	Feed-forward dominant; in- tegral only for steady-state trim
Recharge Loop	Battery core temperature TE-102	Recharge divert valve	1.2–1.8	240–480	0	Very slow thermal mass; derivative omitted
Multi-Vessel Balancing	ΔT deviation per vessel	Per-vessel VFD trim	0.5–1.0	30–60	0	Proportional-integral only; gains intentionally low

Output limits: Master loop 0–100% valve position; Slave loop 20–100% VFD speed.

D.G Network Architecture and Communication Protocols

The field instrument and actuator network is organised as a three-layer communication hierarchy. Physical isolation between layers is mandatory to prevent process-level noise from propagating into the supervisory layer and to maintain deterministic scan times on the PLC execution bus.

Layer 1 — Field Bus (Process Level): All analogue field instruments communicate over the 4–20 mA analogue loop with superimposed HART digital overlay. Shielded twisted-pair (STP) cable with drain wire grounded at the marshalling cabinet end only is mandatory for all HART runs.

Layer 2 — Control Bus (PLC Level): FE-201 and VFD-501 communicate over Profinet IO (IEC 61158 / IEC 61784), providing cycle times of 1–4 ms. The master PLC also hosts a Modbus TCP server for inter-PLC data exchange in multi-vessel balancing configurations.

Layer 3 — Supervisory Bus (SCADA Level): The HMI/SCADA server communicates with the master PLC via OPC-UA (IEC 62541) over a dedicated VLAN. SCADA historian sampling is configured at 1-second resolution for all analogue tags.

TABLE XXXIII
COMMUNICATION PROTOCOL AND NETWORK LAYER SPECIFICATIONS

Layer	Protocol	Physical Medium	Topology	Cycle / Poll Rate	Connected Devices
Layer 1	4–20 mA + HART (rev 7)	STP 2-core, 0.5 mm ²	Point-to-point star	Analogue continuous	TE-101/102/103, PE-301, TCV-401
Layer 2	Profinet IO (RT Class 1)	Cat6A STP Ethernet	Line / star hybrid	1–4 ms	FE-201, VFD-501
Layer 2	Modbus TCP	Cat6A STP Ethernet	Star from master PLC	500 ms poll	Satellite vessel PLCs
Layer 3	OPC-UA (IEC 62541)	Cat6A, dedicated VLAN	Star from SCADA server	1 s historian	HMI terminals, historian, engineering workstation

*All Ethernet segments must use managed switches with VLAN tagging.
IEC 62443-3-3 Security Level 2 recommended for OPC-UA endpoints.*

D.H Failure Mode and Effects Analysis (FMEA) and Fault Response

A structured failure mode and effects analysis is required to validate that the PLC state machine captures all credible fault conditions. The FMEA is structured per IEC 60812. Each failure mode is assigned a Risk Priority Number (RPN) computed as the product of Severity (*S*), Occurrence (*O*), and Detectability (*D*), each scored 1–10. Modes with $RPN \geq 100$ require a dedicated hardware interlock independent of the PLC software layer.

TABLE XXXIV
FAILURE MODE AND EFFECTS ANALYSIS (FMEA) — VERSION 1

Failure Mode	Root Cause	Effect on System	<i>S</i>	<i>O</i>	<i>D</i>	RPN	Recommended Mitigation
FE-201 signal loss	Cable fault or transmitter failure	Inner PID loses flow feedback; VFD runs open-loop	8	3	4	96	Watchdog timer; fallback to minimum VFD speed on signal loss
TCV-401 stuck open	Actuator spring or positioner failure	Uncontrolled battery discharge; vessel overtemperature	9	2	3	54	Mechanical position indicator; TE-103 HiHi trips battery isolation
TCV-401 stuck closed	Positioner or pneumatic supply failure	Battery cannot discharge; thermal demand unmet	5	2	3	30	TE-103 Lo alarm; manual bypass line with block valve
VFD-501 trip / fault	Overtemperature, overcurrent, or supply fault	Loss of loop circulation; coil stagnation risk	9	3	2	54	VFD fault output hardwired to PLC DI; auto-transition to 05_FAIL_SAFE
Loop over-velocity event	VFD runaway or control loop instability	Erosion of coil inner wall	10	2	2	40	Hardware overspeed relay independent of PLC; trips VFD contactor
TE-102 multipoint failure	Thermocouple open-circuit or moisture ingress	SoC calculation invalid; risk of battery over-charge	7	4	4	112	Critical (RPN ≥ 100): Redundant thermocouple pair; majority-vote logic
PLC processor fault	Hardware fault or watchdog timeout	All automated control outputs frozen	10	1	2	20	Hot-standby PLC in duplex configuration
Modbus TCP link loss	Network switch fault or cable break	Master loses satellite vessel data	6	3	3	54	Satellite PLCs revert to local standalone PID on comms timeout
Loop pressure loss	Coil or pipe leak	Risk of fluid escape and thermal hazard	9	2	2	36	PE-301 LoLo hardwired to master isolation valve
SCADA OPC-UA server loss	Server crash or network VLAN fault	Loss of operator visibility	4	3	2	24	PLC operates independently; local HMI panel maintains Level 1 display

$RPN = S \times O \times D$. All $RPN \geq 100$ items require hardware interlock independent of PLC software.

APPENDIX E
PLC IMPLEMENTATION AND DISCRETE-TIME CONTROL FORMULATIONS
VERSION 1 — ARCHIVED

IMPLEMENTATION SUPERSESSION NOTICE

This version of Appendix E (Version 1) is retained in full as an archived record of the initial single-loop PLC implementation developed alongside the Version 1 control architecture of Appendix D. It is preserved to document the engineering decision trail and to serve as a reference for the mathematical foundations that carry forward into the revised implementation.

This appendix has been superseded in its entirety by **Appendix G — Revised PLC Implementation and Control Commissioning (Version 2)**, which should be consulted for all current implementation and commissioning purposes. The following sections of this document contain content that conflicts with or is incomplete relative to the Version 2 three-loop architecture:

- **Section E.D** — The scan interval derivation assumes a single universal execution interval applied to one loop. The Version 2 architecture requires four independent scan intervals derived separately for each loop. The per-loop derivation is provided in Appendix G, Section G.B. Do not implement from this section.
- **Section E.E** — The single ST code block covers one generic PID loop only. The Version 2 architecture requires three separate code blocks — one per controlled loop — each with the correct controller type (PID, PI, or P), the correct actuator tag, and the correct scan interval. The three blocks are provided in Appendix G, Section G.E. Do not implement from this section.

Sections **E.A through E.C** (discrete-time PID algorithms, derivative kick mitigation, anti-windup clamping, and EMA sensor filtering) are mathematically universal and have been carried forward into Appendix G, Section G.A without change. Sections **E.F and E.G** (ladder logic guidelines and hardwired relay fallback) are carried forward into Appendix G, Sections G.G and G.H respectively, with minor amendments to reflect the three-loop structure. Section **E.H** (watchdog and fail-safe) is carried forward into Appendix G, Section G.I with one amendment: TCV-402 is added to the safe-state output enforcement block, which was absent in Version 1 because TCV-402 did not exist in the Version 1 architecture. Where any discrepancy exists between E.A–E.C, E.F–E.H and their Appendix G counterparts, the Appendix G version takes precedence.

Superseded by: Appendix G — Revised PLC Implementation and Control Commissioning (Version 2) Retention rationale: Engineering decision record / mathematical reference

This appendix translates the continuous-time thermal logic established in the sizing framework into the discrete-time difference equations required by industrial microprocessors. The formulations provided herein are specifically formatted for Programmable Logic Controllers (PLCs) and Distributed Control Systems (DCS), ensuring safe actuator modulation, electrical noise rejection, and system stability under massive thermal inertia.

NOTE — SECTIONS E.A THROUGH E.C The following three sections are mathematically universal and have been carried forward into Appendix G, Section G.A without change. They may be read as the authoritative mathematical reference for the discrete-time algorithms underlying all three Version 2 control loops. No conflict with the Version 2 architecture exists in these sections.

E.A Discrete-Time Proportional-Integral-Derivative (PID) Algorithms

The theoretical continuous-time PID algorithm is defined across the complex domain as:

$$u(t) = K_p e(t) + K_i \int_0^t e(\tau) d\tau + K_d \frac{de(t)}{dt}$$

Because a PLC samples data at fixed, discrete scan intervals (Δt), this continuous integral must be converted algebraically using backward Euler approximations. For hydronic valves and Variable Frequency Drives (VFDs) which require bumpless transfers and smooth actuation, the **Velocity (Incremental) PID Form** is utilized. Instead of calculating the absolute output $u(k)$, the PLC calculates the incremental change required for the current scan cycle $\Delta u(k)$:

$$\Delta u(k) = K_p [e(k) - e(k-1)] + K_i \Delta t e(k) + \frac{K_d}{\Delta t} [e(k) - 2e(k-1) + e(k-2)]$$

The final actuator signal sent to the field hardware is then accumulated:

$$u(k) = u(k-1) + \Delta u(k)$$

E.B Derivative Kick Mitigation and Integral Anti-Windup Clamping

Derivative Kick Avoidance: If a plant operator suddenly alters the process setpoint (SP) via the Human Machine Interface (HMI), the error $e(k)$ shifts instantaneously. This triggers an infinite spike in the standard derivative term, violently forcing the VFD to maximum frequency. To prevent this, the algorithm is modified to take the derivative of the Process Variable (PV) instead of the Error (e):

$$\text{Derivative Term} = -\frac{K_d}{\Delta t} [PV(k) - 2PV(k-1) + PV(k-2)]$$

Integral Anti-Windup (Conditional Clamping): Large thermal batch processes possess massive inertia, causing the integral term to accumulate indefinitely while waiting for the fluid to heat up. To prevent the loop from “winding up” and overshooting the target, the PLC logic actively freezes the *incremental* integral contribution $\Delta I(k)$ for the current scan cycle whenever the

actuator output has reached its physical saturation boundary. The accumulated output $u(k)$ is not zeroed; only the increment for that cycle is suppressed:

$$\text{If } u(k) \geq u_{max} \text{ and } e(k) > 0: \quad \Delta I(k) = 0$$

$$\text{If } u(k) \leq u_{min} \text{ and } e(k) < 0: \quad \Delta I(k) = 0$$

This formulation is consistent with the velocity-form ST implementation in Section E.E, where I_Term represents the per-scan integral increment $K_i \cdot \Delta t \cdot e(k)$, not the total accumulated sum.

E.C First-Order Low-Pass Sensor Filtering (EMA)

Industrial fluid environments induce turbulent noise across RTDs (TE-101) and electromagnetic flowmeters (FE-201). Before entering the PID calculation block, raw analog signals are smoothed using a discrete Exponential Moving Average (EMA) low-pass filter:

$$PV_{filtered}(k) = \alpha \cdot PV_{raw}(k) + (1 - \alpha) \cdot PV_{filtered}(k - 1)$$

Where the smoothing constant α is derived from the scan rate (Δt) and the desired filter time constant (τ_f):

$$\alpha = \frac{\Delta t}{\tau_f + \Delta t} \quad (0 < \alpha \leq 1)$$

SECTION CONFLICT — E.D The scan interval derivation below assumes a single universal execution interval applied to one loop, derived from a single reference S_t value. The Version 2 architecture requires four independent scan intervals derived separately for each loop because their time constants differ by orders of magnitude. Applying this single interval to Loops 2, 3, or 4 will produce an unstable hydraulic controller or wasteful CPU oversampling. Do not implement from this section. The per-loop derivation is provided in Appendix G, Section G.B.

E.D PLC Execution Interval and Hardware Scan Strategy

Executing complex floating-point PID math on every millisecond PLC hardware cycle needlessly consumes CPU bandwidth and amplifies derivative noise. The control task execution interval (Δt_{scan}) is locked to the physical time constant (S_t) of the thermal battery, validated in Step 11 of the framework. Based on the Nyquist-Shannon constraint for thermal inertia, the logic block is executed exclusively at:

$$\Delta t_{scan} \approx \frac{S_t}{20}$$

As a representative reference: for a system where Step 10 yields $S_t = 6665$ s, this gives $\Delta t_{scan} \approx 330$ s (5.5 minutes). The divisor of 20 provides a minimum of ten sample points per half-period of the slowest thermal oscillation mode, consistent with standard process control practice. For systems with significantly smaller thermal mass, $S_t/20$ must be re-evaluated and the scan interval reduced accordingly.

SECTION CONFLICT — E.E The ST code block below implements one generic PID loop only. It does not cover Loop 2 (pump flow rate, PI only), Loop 3 (battery recharge, PI only), or the mode-dependent output limit required by Loop 1 in the Version 2 architecture. It also lacks the TCV-402 output, the velocity hard ceiling rung in Loop 2, the battery overtemperature ceiling in Loop 3, and the per-loop heartbeat toggle introduced in Version 2. Do not use this block as the implementation reference. The three separate Version 2 code blocks are provided in Appendix G, Section G.E.

E.E IEC 61131-3 Structured Text (ST) Implementation

The following standardized ST logic encapsulates the discrete algorithms established above, ready for implementation in Siemens TIA Portal, Beckhoff TwinCAT, or Rockwell Studio 5000 environments.

```
1  VAR
2      // Inputs and Parameters
3      PV_Raw      : REAL; // Raw Analog Sensor Input
4      SP          : REAL; // Target Setpoint
5      Kp, Ki, Kd   : REAL; // Tuning Parameters
6      dt          : REAL; // Scan time in seconds (= St / 20, from Step 10)
7      Alpha       : REAL; // Filter Constant (= dt / (tau_f + dt))
8
9      // Memory States (RETAIN: preserved across PLC power cycle)
10     PV_Filtered  : REAL;
11     PV_Prev1    : REAL;
12     PV_Prev2    : REAL;
13     Error_Prev   : REAL;
14     Actuator_Out : REAL;
15
16     // Intermediate Calculation Variables
17     Error        : REAL;
18     Delta_U      : REAL;
19     P_Term       : REAL;
20     I_Term       : REAL;
21     D_Term       : REAL;
22 END_VAR
23
24 // --- 1. Exponential Moving Average Sensor Filter ---
25 PV_Filtered := (Alpha * PV_Raw) + ((1.0 - Alpha) * PV_Filtered);
26
27 // --- 2. Error Calculation ---
28 Error := SP - PV_Filtered;
29
30 // --- 3. Proportional Term (error-based) ---
31 P_Term := Kp * (Error - Error_Prev);
32
33 // --- 4. Derivative Term (PV-based to prevent setpoint-step kick) ---
34 D_Term := -(Kd / dt) * (PV_Filtered - (2.0 * PV_Prev1) + PV_Prev2);
35
36 // --- 5. Integral Increment with Anti-Windup Clamping ---
37 // Suppresses only the per-scan increment; does not zero the accumulator.
38 IF (Actuator_Out >= 100.0 AND Error > 0.0) OR
39    (Actuator_Out <= 0.0 AND Error < 0.0) THEN
40     I_Term := 0.0; // Freeze increment this scan; accumulated u(k) unchanged
41 ELSE
42     I_Term := Ki * dt * Error;
43 END_IF;
44
45 // --- 6. Velocity Form Output Accumulation ---
46 Delta_U := P_Term + I_Term + D_Term;
47 Actuator_Out := Actuator_Out + Delta_U;
48
49 // --- 7. Absolute Output Saturation Limits ---
50 IF Actuator_Out > 100.0 THEN Actuator_Out := 100.0; END_IF;
51 IF Actuator_Out < 0.0 THEN Actuator_Out := 0.0; END_IF;
52
53 // --- 8. Update Memory Registers for Next Scan ---
54 Error_Prev := Error;
55 PV_Prev2 := PV_Prev1;
56 PV_Prev1 := PV_Filtered;
```

Listing 1. Velocity Form PID with Anti-Windup and EMA Filtering (Version 1 — Single Loop)

NOTE — SECTIONS E.F THROUGH E.H The following sections are substantively valid and have been carried forward into Appendix G with the amendments noted below. They are not flagged as conflicting and may be read as background reference. Where any discrepancy exists between these sections and their Appendix G counterparts, Appendix G takes precedence.

- **E.F (Ladder Logic):** Carried forward to Appendix G, Section G.G. One amendment: a single global interrupt block for all loops is explicitly prohibited in Version 2 because loop scan rates differ by orders of magnitude.
- **E.G (Relay Fallback):** Carried forward to Appendix G, Section G.H. One amendment: the operational limitations note is extended to explicitly disqualify relay architecture for any installation requiring the four-mode vessel structure of Appendix F.
- **E.H (Watchdog and Fail-Safe):** Carried forward to Appendix G, Section G.I. One amendment: TCV-402 is added to the safe-state output enforcement block in Block 4, which was absent in Version 1 because TCV-402 did not exist in the Version 1 I/O schedule.

E.F Ladder Logic (LD) Implementation Guidelines

While Structured Text (ST) natively supports complex algebraic difference equations, many legacy or visually-oriented plant environments require IEC 61131-3 Ladder Diagram (LD) architecture. When implementing the VCH control loops in LD, the following structural guidelines apply:

- **Cyclic Execution via Interrupts:** Instead of using standard internal timers (TON) to trigger the math, the LD network should reside inside a dedicated cyclic hardware interrupt block (e.g., OB30 in Siemens TIA Portal or a Periodic Task in Rockwell RSLogix). The block execution rate must be statically configured to the Δt_{scan} interval calculated in E.D.
- **Mathematical Compute Blocks:** The EMA sensor filter cannot easily be executed with basic add/multiply coils. A dedicated Compute (CPT) instruction block should be utilized to calculate the $(1 - \alpha)$ filtering formula in a single rung.
- **Native PID Instruction Utilization:** Rather than writing the full velocity-form equation manually in LD, utilize the native PID instruction blocks (such as PID_Compact or PIDE). Ensure the block parameters are explicitly configured to read the Filtered PV rather than the Raw physical analog channel.
- **Boolean Anti-Windup Triggers:** Use standard contact structures (XIC/XIO) to evaluate actuator saturation. If the PID instruction block output reaches 100% and the error remains positive, route a parallel rung branch to a MOVE (MOV) instruction that immediately forces the integral sum register to zero.

E.G Hardwired Relay-Based Control (Non-PLC Architecture)

For smaller, isolated hydronic skids, or as a robust fail-safe override to the primary PLC, a traditional hardwired electromechanical control architecture can be employed without microprocessor intervention.

- **Bang-Bang (On/Off) Control Profiles:** Proportional-Integral modulation is impossible without a dedicated controller. Instead, continuous analog temperature sensors (RTDs) are replaced with mechanical thermostats or liquid-filled capillary thermal switches. When the bulk fluid temperature drops below the physical setpoint, the mechanical switch snaps closed.
- **Relay Logic and Contactors:** The closure of the thermostat switch energizes a 24 VDC or 120 VAC Master Control Relay (MCR) coil. The MCR subsequently pulls in the heavy-duty main motor contactor, providing three-phase power directly to the primary utility heater or the fixed-speed circulation pump.
- **Hardware Safety Interlocks:** To mimic the PLC's software velocity and flow safeguards, physical flow switches (paddle or thermal dispersion type) and high-limit pressure switches (capsule type) are wired directly in series with the MCR coil. If flow drops unexpectedly or system pressure surges beyond mechanical limits, the series circuit breaks instantly, dropping the contactor and halting the hydronic loop entirely.
- **Operational Limitations:** While hardwired relays are highly robust and immune to software faults, network crashes, and EMI corruption, they suffer from severe thermal hysteresis (temperature swinging). Furthermore, relay logic cannot execute dynamic load-balancing or thermal battery peak shaving (Modes II and IV). A hardwired network restricts the hydronic framework exclusively to baseline direct charging and standby states.

E.H Watchdog Timer and 05_FAIL_SAFE State Implementation

The PLC state machine defined in Appendix D (Section D.C) designates 05_FAIL_SAFE as the terminal safety state, reachable from any operating mode upon detection of a velocity limit breach, hardware fault, or loss of a critical field signal. Reaching this state via software logic alone is insufficient for a safety-critical hydronic loop: a PLC processor fault, scan-cycle overrun, or memory corruption event could prevent the state transition from executing entirely. Two complementary mechanisms are therefore required.

Software Watchdog (PLC Internal): On every scan cycle in which the control block executes normally, the ST block writes a heartbeat token to a dedicated RETAIN boolean flag (WD_Heartbeat). A separate watchdog timer task, scheduled at a faster interrupt priority than the main control task, monitors this flag. If the heartbeat is not refreshed within two consecutive watchdog periods, the task unconditionally forces all control outputs to their de-energised fail-safe positions and latches the FAIL_SAFE_Active flag, which is hardwired to the field alarm beacon and the VFD run-enable relay.

Hardware Watchdog (Independent of PLC): The VFD run-enable signal (VFD-501 enable input) is routed through an external hardware watchdog relay module, independent of the PLC output card. This relay requires a continuous 1 Hz pulse train from the PLC digital output to remain energised. If the pulse train stops for any reason — including PLC processor halt, output card failure, or loss of 24 VDC control supply — the relay drops out, removing the run-enable signal from the drive and bringing the loop to a controlled deceleration stop.

The ST implementation below covers the software watchdog block and the 05_FAIL_SAFE state transition logic, intended to execute in a high-priority cyclic interrupt task at a fixed 1-second interval, independent of the main 5.5-minute control task.

```

1  VAR
2      // Watchdog Coordination (set by main PID block each scan)
3      WD_Heartbeat      : BOOL;           // Written TRUE by PID block each execution
4      WD_Prev           : BOOL;           // Previous-scan heartbeat state
5      WD_MissCount      : UINT := 0;      // Consecutive missed heartbeat counter
6      WD_TripThreshold  : UINT := 2;      // Trips FAIL_SAFE after N missed scans
7
8      // Velocity Monitoring (read from FE-201 signal chain)
9      Velocity_Live     : REAL;           // Current loop velocity in m/s
10     Velocity_HiHi     : REAL := 2.5;    // Hard erosion ceiling (Appendix D alarm)
11
12     // VFD Hardware Pulse Output (1 Hz square wave to external WD relay)
13     HW_WD_Pulse       : BOOL;           // Physical DO to hardware watchdog relay
14     HW_WD_Toggle      : BOOL;           // Internal toggle state
15
16     // System State Flags
17     FAIL_SAFE_Active  : BOOL := FALSE; // Latching; requires manual HMI reset
18     PLC_State         : UINT;           // Mirrors D.C state machine (05 = FAIL_SAFE)
19
20     // Safe-State Actuator Demand Outputs
21     // NOTE: TCV-402 absent in Version 1 --- added in Appendix G, Section G.I
22     TCV401_Demand     : REAL;           // 0.0 = fully closed (battery isolated)
23     VFD501_Demand     : REAL;           // 0.0 = stop command to drive
24     Alarm_Beacon      : BOOL;           // Hardwired field alarm output
25 END_VAR
26
27 // --- Block 1: Hardware Watchdog Pulse Generator (1 Hz toggle) ---
28 HW_WD_Toggle := NOT HW_WD_Toggle;
29 HW_WD_Pulse  := HW_WD_Toggle;
30
31 // --- Block 2: Software Heartbeat Monitor ---
32 IF WD_Heartbeat = WD_Prev THEN
33     WD_MissCount := WD_MissCount + 1;
34 ELSE
35     WD_MissCount := 0;
36 END_IF;
37 WD_Prev := WD_Heartbeat;
38
39 // --- Block 3: FAIL_SAFE Trigger Evaluation ---
40 IF (WD_MissCount >= WD_TripThreshold) OR
41     (Velocity_Live > Velocity_HiHi) THEN
42     FAIL_SAFE_Active := TRUE;
43 END_IF;
44
45 // --- Block 4: Safe-State Output Enforcement ---
46 IF FAIL_SAFE_Active THEN
47     PLC_State      := 5;
48     TCV401_Demand  := 0.0;
49     VFD501_Demand  := 0.0;
50     Alarm_Beacon   := TRUE;
51     HW_WD_Pulse    := FALSE;
52 END_IF;

```

Listing 2. Software Watchdog and 05_FAIL_SAFE State Transition Logic (Version 1)

Two implementation requirements must be confirmed during factory acceptance testing (FAT) before commissioning. First, the hardware watchdog relay drop-out time must be verified to be shorter than the VFD deceleration ramp time, ensuring the drive reaches zero speed before any mechanical brake or isolation valve actuates. Second, the FAIL_SAFE_Active latch must be confirmed as non-resettable from any automated logic path; reset must require an explicit operator acknowledgement action on the Level 3 HMI screen defined in Appendix D, Section D.E.

APPENDIX F

REVISED CONTROL ARCHITECTURE

This appendix supersedes Appendix D (Version 1) in its entirety and constitutes the current control architecture reference for the VCH Sizing Framework. It should be consulted for all design, commissioning, and implementation purposes. Appendix D is retained as an archived engineering decision record. Appendix G (Revised PLC Implementation and Control Commissioning, Version 2) provides the discrete-time mathematics, code implementation, and commissioning procedures consistent with the architecture defined herein.

This appendix defines the revised system-level control philosophy, instrumentation topology, and operational mode structure governing the hydronic vessel network and centralised thermal battery system. The architecture presented herein corrects and extends the single-loop cascade model of Version 1, replacing it with three independent but physically coupled control loops and a refined four-mode vessel operational structure. The revision was driven by a more rigorous analysis of battery charging and discharging behaviour during simultaneous thermal demand, the introduction of operator-driven alarm response in place of automatic state transitions, and the formalisation of the pump flow rate as an independently controlled variable rather than a subordinate actuator.

FA Revised Control Philosophy and Operational Modes

FA.1 Three-Loop Independence Principle: The Version 1 architecture treated the hydronic system as a single cascade loop in which pump speed was a subordinate output of the temperature controller. This formulation was found to be architecturally insufficient for a system in which the pump velocity constraint, the vessel thermal target, and the battery energy state each represent independent physical objectives with independent actuators and independent failure modes.

The revised architecture declares three independent control loops. Each loop has its own setpoint, its own controller, its own actuator, and its own process variable. Independence is architectural — each loop runs its own scan cycle and PID block without receiving setpoint commands from another loop’s output. The loops are physically coupled through the shared hydronic fluid, meaning the output of one loop modifies the disturbance environment of the others, but this coupling is handled as a measurable disturbance rather than a structural dependency.

A fourth loop governs multi-vessel load balancing in distributed installations. This loop operates at the supervisory level and trims individual vessel pump speeds relative to a master deviation signal. It is intentionally non-aggressive and does not interact with the primary three loops at the single-vessel level.

Table I defines the four loops, their controller types, and their physical roles.

TABLE I
CONTROL LOOP DECLARATIONS — VERSION 2

Loop	Name	Controller	Process Variable	Actuator	Physical Role
1	Vessel Batch Temperature	PID	TE-103	TCV-401	Maintains vessel fluid at target temperature across all modes
2	Pump Flow Rate	PI	FE-201	VFD-501	Enforces velocity setpoint; prevents erosion ceiling breach and stagnation floor violation
3	Battery Recharge	PI	TE-102	TCV-402	Directs surplus driver energy into battery; always permitted to run; setpoint is $T_{bat,target}$
4	Multi-Vessel Balancing	P only	ΔT per vessel	Per-vessel trim	VFD Redistributes flow across vessels by deviation; intentionally lazy to prevent inter-vessel hunting

Loop 4 is active only in multi-vessel installations operating Mode IV. It does not affect single-vessel operation.

FA.2 Battery Charging and Discharging Simultaneity: A critical correction from Version 1 concerns the mutual exclusion assumption applied to battery charging and discharging. Version 1 implied that these were mutually exclusive states — the battery was either charging (Mode III) or discharging (Mode II), never both simultaneously.

This assumption is physically incorrect for a thermal driver operating below its rated capacity. In normal operation the driver is always running. It simultaneously delivers heat to the vessel through the coil circuit and replenishes the battery through the recharge path governed by Loop 3. The net battery energy state is therefore approximately constant in all modes except one — Mode 1.A.2, where total vessel heat consumption exceeds what the driver alone can supply. Only in this condition is the battery in net energy drain, because the driver is fully committed to the vessel demand and has no surplus to route through Loop 3.

Loop 3 therefore carries no interlock against simultaneous Loop 1 or Loop 2 operation. It runs continuously whenever the driver has surplus capacity, which is the normal condition in all modes except 1.A.2.

FA.3 Vessel Operational Modes: The vessel batch temperature loop operates across four modes. The mode determines the setpoint, the output limits, and the pump flow setpoint presented to Loops 1 and 2 respectively. The PID block structure does not change between modes — only its boundary conditions change.

Mode 1.A.1 — Heating, Utility Sufficient. The entry condition is that the maximum heat deliverable by the pump-coil circuit at v_{max} does not exceed the driver’s allocated output capacity:

$$\dot{Q}_{pump,max} \leq \dot{Q}_{allocated}$$

The vessel PID setpoint is T_{target} . Loop 2 setpoint is the velocity that satisfies the thermal demand without exceeding v_{max} . The battery is in net neutral — Loop 3 is active and routing surplus driver energy into the battery at the background rate. TCV-401 output upper limit is set to the valve position corresponding to $\dot{Q}_{allocated}$.

Mode 1.A.2 — Heating, Battery-Assisted. The entry condition is:

$$\dot{Q}_{pump,max} > \dot{Q}_{allocated}$$

meaning full pump velocity alone would demand more heat from the driver than the allocated capacity. The battery discharge path opens, and TCV-401 blends supplemented battery fluid into the coil circuit. The driver is fully committed to vessel demand; Loop 3 receives no surplus and the battery enters net drain.

The battery state-of-charge watchdog runs on every scan cycle. When SoC reaches the operator-defined floor threshold SoC_{floor} , no automatic state transition occurs. Instead the PLC raises a Priority 1 alarm and presents a two-option decision prompt on the Level 1 HMI screen:

- **Option A — Stop Batch:** Graceful shutdown. Loop 1 setpoint is ramped to ambient over a configurable cool-down period. Battery recovers on the next idle recharge cycle.
- **Option B — Continue, Accept Temperature Sacrifice:** The operator accepts reduced thermal performance. TCV-401 output upper limit is reduced, the vessel receives less heat than demanded, and T_{vessel} falls short of T_{target} . The operator owns this decision; the PLC does not override it.

The only automatic hard trip that remains non-negotiable is the velocity ceiling breach transitioning to `FAIL_SAFE` — this is a hardware safety condition, not an operational one, and is never subject to operator override.

Mode B — Holding. The vessel has reached T_{target} . The only thermal demand is the environmental loss term $\dot{Q}_{loss}$ quantified in Step 5 of the framework. Loop 2 setpoint drops to the minimum velocity required to deliver $\dot{Q}_{loss}$ through the coil. Loop 1 PID setpoint remains T_{target} ; the integrating nature of the controller naturally throttles TCV-401 toward a low steady-state opening as error approaches zero.

The stagnation floor constraint applies: if $\dot{Q}_{loss}$ is sufficiently small that it would require $v < v_{min}$ (0.3 m/s per the FMEA threshold), Loop 2 holds at v_{min} and Loop 1 modulates TCV-401 to prevent overheating. This edge case is most likely to occur in well-insulated vessels at low ambient temperature.

Mode C — Hibernation. The operator defines a hibernation power fraction $\phi \in (0,1)$ via the HMI. The effective thermal demand becomes:

$$\dot{Q}_{hib} = \phi \cdot \dot{Q}_{hold}$$

This is back-calculated to a reduced temperature setpoint:

$$T_{hib} = T_{target} - \Delta T_{hib}$$

where ΔT_{hib} is derived from $\dot{Q}_{hib}$ and the vessel thermal resistance network. Loop 2 setpoint scales proportionally downward. The vessel cools to T_{hib} and holds there. Wake-up from hibernation is a manual HMI command that restores T_{target} as the Loop 1 setpoint, and the system re-heats through Mode 1.A.1 or 1.A.2 depending on the $\dot{Q}_{pump,max}$ evaluation.

Table III summarises the mode-dependent boundary conditions applied to Loops 1 and 2.

TABLE II
MODE-DEPENDENT SETPOINT AND OUTPUT LIMIT SUMMARY

Mode	Loop 1 Setpoint	Loop 1 Output Limit	Loop 2 Setpoint	Battery State
1.A.1	T_{target}	$\leq$ position for $\dot{Q}_{allocated}$	v satisfying demand, $\leq v_{max}$	Net neutral; Loop 3 active
1.A.2	T_{target}	Position for $\dot{Q}_{allocated} + \dot{Q}_{battery}$	v_{max}	Net drain; SoC watchdog active
B	T_{target}	Unrestricted (PID self-regulates)	v satisfying $\dot{Q}_{loss}$, $\geq v_{min}$	Net neutral; Loop 3 active
C	$T_{hib} = T_{target} - \Delta T_{hib}$	Scaled to $\phi \cdot \dot{Q}_{hold}$	v scaled to ϕ , $\geq v_{min}$	Net neutral; Loop 3 active
<i>FAIL_SAFE overrides all modes unconditionally on velocity ceiling breach or hardware fault.</i>				

FB Complete Instrumentation and I/O Schedule

The full instrument and actuator schedule for the Version 2 architecture comprises 25 I/O points across four signal classes. This schedule supersedes the incomplete seven-point table in Appendix D, Section D.B. All field devices must be installed, tagged, and loop-tested against this schedule prior to PLC commissioning.

TABLE III
ANALOGUE INPUT SCHEDULE

Tag	Instrument	Type / Element	Signal	Functional Role
TE-101	Loop supply temperature	PT100 RTD Class A	4–20 mA / HART	Monitors driver output temperature; Loop 1 disturbance input
TE-102	Battery core temperature (multipoint)	Type K thermocouple $\times 3$	4–20 mA / HART	SoC proxy via majority-vote logic; Loop 3 process variable
TE-103	Vessel batch temperature	PT100 RTD Sanitary	4–20 mA / HART	Loop 1 process variable; primary batch quality indicator
TE-104	Battery inlet temperature	PT100 RTD	4–20 mA / HART	Confirms recharge flow entering battery; detects TCV-402 response
TE-105	Battery outlet temperature	PT100 RTD	4–20 mA / HART	Confirms discharge flow leaving battery; validates 1.A.2 supplementation
FE-201	Main loop velocity	Electromagnetic flowmeter	Modbus TCP	Loop 2 process variable; erosion ceiling and stagnation floor enforcement
PE-301	Loop differential pressure	Piezo-resistive cell	4–20 mA / HART	Head loss tracking; leak detection via LoLo threshold
LE-401	Battery SoC (derived)	Calculated from TE-102	Software tag	SoC floor alarm trigger; 1.A.2 watch-dog input

TE-104 and TE-105 are new in Version 2. They provide independent confirmation of energy exchange in both directions and are mandatory for battery commissioning verification.

Analogue Inputs (AI) — 8 Points:

TABLE IV
ANALOGUE OUTPUT SCHEDULE

Tag	Actuator	Type	Signal	Functional Role
TCV-401	Battery blend / discharge valve	3-way equal percentage	4–20 mA	Loop 1 actuator; modulates battery discharge blend into coil circuit
TCV-402	Recharge divert valve	2-way modulating	4–20 mA	Loop 3 actuator; directs surplus driver energy into battery
VFD-501	Loop circulation pump	AC induction inverter	Profinet	Loop 2 actuator; velocity setpoint from inner PI loop

TCV-402 is new in Version 2. It was absent from the Version 1 I/O schedule.

Analogue Outputs (AO) — 3 Points:

TABLE V
DIGITAL INPUT SCHEDULE

Tag	Device	Functional Role
HS-601	Emergency stop pushbutton (hardwired)	Forces FAIL_SAFE unconditionally; bypasses all PLC logic
HS-602	HMI batch start command	Triggers transition from STANDBY to heating mode evaluation
HS-603	HMI hibernate command	Triggers Mode C; ϕ value entered via HMI numeric input
ZS-701	TCV-401 open position confirmation	Confirms valve has physically responded to output demand
ZS-702	TCV-402 open position confirmation	Confirms recharge path is physically open
FS-801	Flow switch, low flow detection	Hardware backup to FE-201 stagnation alarm; wired in parallel
PS-901	High pressure switch (hard-wired)	Direct hardware trip to VFD contactor independent of PLC
WD-001	Hardware watchdog relay feedback	Confirms 1 Hz pulse train from DO-103 is being received

Digital Inputs (DI) — 8 Points:

Digital Outputs (DO) — 6 Points: I/O Summary: 8 Analogue Inputs, 3 Analogue Outputs, 8 Digital Inputs, 6 Digital Outputs — **25 points total.**

TABLE VI
DIGITAL OUTPUT SCHEDULE

Tag	Device	Functional Role
AL-001	Audible field alarm beacon	Energised on SoC floor breach or any Priority 1 alarm
AL-002	Visual alarm beacon (strobe)	Energised on same trigger as AL-001
DO-101	VFD-501 run enable relay	De-energised by hardware watchdog drop-out; removes VFD run permission
DO-102	Driver enable signal	PLC command to driver on/off; interlocked with loop pressure confirmation
DO-103	Hardware watchdog pulse output	1 Hz square wave to external watchdog relay module
DO-104	HMI SoC alarm indicator	Illuminates operator decision prompt on Level 1 screen in Mode 1.A.2

FC Revised PLC State Transition Matrix

The Version 2 state machine maps directly to the four vessel operational modes defined in Section F.A, with `STANDBY` as the idle entry state and `FAIL_SAFE` as the terminal safety latch reachable from any state. The critical departure from Version 1 is the removal of automatic state transitions driven by load threshold comparisons. In Version 2, transitions between heating modes are governed by physical condition evaluation at entry, and the 1.A.2 SoC floor event produces an alarm and operator prompt rather than a forced transition.

`FAIL_SAFE` remains the sole automatic non-operator-initiated transition and is triggered exclusively by hardware safety conditions — velocity ceiling breach, watchdog timeout, or hardwired emergency stop. It latches unconditionally and requires manual HMI acknowledgement to clear.

TABLE VII
PLC STATE MACHINE TRANSITION SEQUENCE — VERSION 2

State	System Profile	Entry Condition	Exit Condition	Active Interlocks
STANDBY	All loops at minimum; pump at bypass speed; battery loops inactive.	Power-on default or manual HMI reset after <code>FAIL_SAFE</code> clearance.	HS-602 batch start command received.	Confirm PE-301 > 1.5 bar before permitting transition.
MODE_1A1	Loop 1 drives to T_{target} ; Loop 2 at demand velocity; Loop 3 active recharging.	$\dot{Q}_{pump,max} \leq \dot{Q}_{allocated}$ evaluated at batch start.	$T_{vessel} \geq T_{target} - \delta \rightarrow \text{MODE_B}$; or condition flips to 1.A.2 on load change.	Continuous velocity monitoring: $v > v_{max}$ trims VFD-501 immediately.
MODE_1A2	Battery discharge blended via TCV-401; Loop 3 starved of surplus.	$\dot{Q}_{pump,max} > \dot{Q}_{allocated}$ evaluated at batch start or detected mid-batch.	$T_{vessel} \geq T_{target} - \delta \rightarrow \text{MODE_B}$; SoC $\leq \text{SoC}_{floor} \rightarrow \text{P1 alarm} + \text{HMI prompt}$ only; no forced transition.	SoC watchdog active every scan. DO-104 energised when SoC floor reached.
MODE_B	Loop 1 holds T_{target} ; Loop 2 modulates to offset $\dot{Q}_{loss}$ only; Loop 3 active.	Arrival at T_{target} from either 1.A.1 or 1.A.2.	HS-603 hibernate command $\rightarrow \text{MODE_C}$; or new batch start $\rightarrow$ re-evaluate 1.A.1 / 1.A.2.	Loop 2 floor: $v \geq v_{min}$ enforced at all times.
MODE_C	Loop 1 holds T_{hib} ; Loop 2 scaled to ϕ ; Loop 3 active.	HS-603 command with ϕ value confirmed on HMI.	Manual wake command $\rightarrow \text{MODE_B} \rightarrow$ re-heat sequence.	ϕ range check: $0 < \phi < 1$ enforced; out-of-range entry rejected with HMI notification.
FAIL_SAFE	All outputs forced to de-energised positions; alarms latched.	$v > v_{HiHi}$; watchdog timeout; HS-601 pressed; PS-901 trip.	Manual HMI acknowledgement only, after physical fault clearance confirmed.	DO-103 pulse halted; DO-101 de-energised; AL-001/002 energised; VFD-501 run enable removed.

δ = arrival deadband, recommended 1–2°C. Prevents Mode B entry on momentary overshoot.

FD Three-Loop Independent Control Architecture

Loop 1 — Vessel Batch Temperature (PID): Loop 1 is the primary process control objective of the framework. Its controlled variable is the vessel bulk fluid temperature measured by TE-103. Its actuator is TCV-401, a three-way equal-percentage valve that proportions the blend of main utility supply and battery-supplemented fluid entering the coil circuit.

Full PID action is warranted for Loop 1 because the process is a slow integrating thermal mass with significant dead time from coil transit. Proportional action alone produces steady-state offset. Integral action eliminates offset but winds up during batch heat-up if not clamped — hence the anti-windup logic in Appendix G. Derivative action on the process variable (not the error) reduces overshoot on batch arrival at T_{target} without introducing derivative kick on HMI setpoint changes.

The output upper limit of Loop 1 is mode-dependent as defined in Table III. This is the primary mechanism by which the mode structure governs thermal power delivery without requiring separate PID blocks per mode.

Loop 2 — Pump Flow Rate (PI): Loop 2 is an independent velocity controller. Its process variable is the volumetric flow velocity from FE-201. Its actuator is VFD-501. The setpoint is not fixed — it is determined by the active vessel mode and the thermal demand calculated from Loop 1's operating point. However, this setpoint is computed by the mode logic layer and presented to Loop 2 as an external input; Loop 2 does not receive its setpoint from Loop 1's output directly.

Derivative action is omitted from Loop 2. Flow velocity responds quickly and cleanly to VFD speed changes, and the electromagnetic flowmeter signal carries turbulent noise that derivative action would amplify. The EMA filter from Appendix G reduces this noise before it enters the PI calculation, but a clean PI response is sufficient for the hydraulic loop's objectives.

Two hard limits are enforced independently of the PI output:

- **Ceiling:** $v \leq v_{max}$ at all times. If the PI output would command a velocity above this, it is clamped to v_{max} and the integral increment is frozen to prevent windup against the ceiling.
- **Floor:** $v \geq v_{min}$ (0.3 m/s) at all times. If the mode logic demands a velocity below this, the floor takes precedence and Loop 1 absorbs the difference through TCV-401 modulation.

Loop 3 — Battery Recharge (PI): Loop 3 maintains the battery thermal state against its target charge temperature $T_{bat,target}$. Its process variable is TE-102 (majority-voted from three thermocouple points). Its actuator is TCV-402, which diverts a proportion of the driver output into the battery recharge circuit.

Loop 3 carries no operating interlock against Loops 1 or 2. It runs continuously whenever the driver has surplus capacity. In Mode 1.A.2 it receives no surplus because the driver is fully committed to vessel demand, but it does not shut down — it simply has no energy available to route and its output naturally drives toward zero. Derivative action is omitted; the battery thermal mass is very large and derivative action on a slow integrating process with thermocouple noise produces no benefit.

Loop 4 — Multi-Vessel Balancing (P only): Loop 4 operates only in multi-vessel installations. The master PLC monitors the temperature differential $\Delta T_i = T_{in,i} - T_{out,i}$ across each vessel i and computes a deviation from the fleet mean. A proportional-only controller trims the VFD speed setpoint of each vessel's Loop 2 upward or downward in proportion to its deviation. Gains are intentionally set low ($K_p = 0.5-1.0$) to produce gentle redistribution rather than aggressive correction, preventing the inter-vessel hunting that integral action would introduce when all vessels compete for flow simultaneously.

FE Control System Architecture Selection: Distributed Controllers versus Central PLC

The physical implementation of the three-loop architecture may be realised through two fundamentally different hardware strategies. This section documents the technical and economic basis for selecting between them, with cost references denominated in Euros appropriate to the Western European industrial automation market, which represents the primary expansion target for this framework.

FE.1 Option A — Distributed Individual Controllers: In a distributed architecture, each control loop is served by a dedicated standalone controller. Loop 1 and Loop 3 are implemented on DIN-rail temperature controllers (Siemens RWD, Jumo dTRON, or equivalent). Loop 2 is implemented using the onboard PID function built into the VFD-501 drive itself, referencing FE-201 as its feedback input via a 4–20 mA signal. The four-mode vessel logic, SoC floor alarm, and HMI decision prompt have no native home in this architecture and must be implemented in a separate hardwired relay logic panel or a small standalone supervisory relay module.

What the installation looks like physically. The control panel contains three or more individual controller displays, each showing only its own PV and setpoint. There is no unified system view. Understanding the current system state requires reading three separate screens and correlating them mentally. The alarm subsystem consists of individual per-loop indicator lights and buzzers — there is no alarm priority, no timestamp, and no history. In a fault condition multiple alarms may fire simultaneously with no indication of which triggered first. The relay logic section implementing the mode switching is a row of DIN-rail relays that is opaque to any technician who was not present at commissioning. Wiring density is high because parallel cable runs service controllers that sit physically adjacent but have no electrical awareness of each other.

Repairability. Individual controllers are straightforward to replace — a DIN-rail unit swaps in under ten minutes. Hardware cost per unit is €180–450. However, configuration is stored inside the controller itself. Replacement without restoring saved parameters brings the loop up on factory defaults. Best practice requires a printed parameter sheet for each controller taped inside the panel door. The relay logic mode section carries no self-documentation; modification requires retracing wiring physically. Cross-loop fault consequences — for example, a VFD fault that drops Loop 2 while Loop 1 continues demanding heat — are not detected by any controller because no controller has visibility beyond its own loop. The system may continue operating in a thermally unsafe low-velocity condition until a mechanical symptom appears.

FE.2 Option B — Central PLC: In a central PLC architecture, all three loops, the mode state machine, the SoC watchdog, the alarm logic, and the HMI interface are hosted on a single programmable logic controller. The recommended platform for European deployment is the Siemens S7-1200 or S7-1500 series programmed in TIA Portal, which natively supports all signal classes in the I/O schedule defined in Section F.B. Beckhoff CX series running TwinCAT is an alternative for installations requiring sub-millisecond loop execution.

What the installation looks like physically. One HMI touchscreen on the panel face — Siemens KTP700 Basic or equivalent. One unified alarm banner showing active alarms in ISA-18.2 priority order with timestamps. The Level 1 overview screen displays the complete system state on a single display: current mode, all eight analogue inputs, SoC bar, TCV-401 and TCV-402 positions, and VFD-501 speed. When the SoC floor alarm fires in Mode 1.A.2, the HMI presents the two operator options directly on screen with the current SoC percentage and a 30-minute drain trend. The operator makes an informed decision within thirty seconds.

The panel cabinet is organised by I/O rack — AI card, AO card, DI card, DO card — with all field wiring terminating at a marshalling strip. Any PLC-trained technician can navigate the cabinet immediately. The SCADA historian logs all 25 I/O points at one-second resolution, enabling complete post-incident causal reconstruction by overlaying any combination of tags on a unified timeline.

Repairability. The most common fault is a single I/O card failure. A card failure affects only its own channel group; other cards and all three loops on unaffected cards continue normally. Card replacement takes fifteen minutes. Configuration restores automatically from CPU memory — no manual parameter re-entry. Spare card cost is €400–1,200 depending on channel count and signal class. CPU fault is the high-impact scenario: a simplex CPU failure takes all three loops to FAIL_SAFE simultaneously. This is mitigated by a hot-standby duplex CPU configuration, which adds €2,000–4,500 to hardware cost but eliminates the single point of failure. Switchover time is under 100 milliseconds, transparent to the process.

FE.3 Feature and Operational Complexity Comparison:

FE.4 Cost Analysis and Break-Even (Euro Reference Market): Table IX provides installed cost estimates referenced to the Western European industrial automation market. Labour rates reflect German and Benelux region averages (€65–90/hour for panel build; €75–150/hour for PLC engineering and commissioning).

Break-even analysis. The central PLC architecture carries an upfront cost premium of approximately €3,500–6,500 over the distributed approach for a single vessel installation. This premium is recovered through lower engineering costs on subsequent modifications and through avoided downtime costs from superior fault detection. In the Western European market, PLC programming and commissioning consultancy is billed at €75–150 per hour. A non-trivial modification to the distributed relay logic — for example, adjusting the SoC floor threshold or adding a new alarm — requires physical rewiring and relay replacement, typically two to three engineering hours plus travel at an on-site rate of €800–1,500 per visit. The equivalent PLC modification is a software parameter change downloadable remotely via OPC-UA, typically one to two hours billed at €150–300.

Assuming two modifications per year and one fault diagnosis event per year requiring on-site attendance:

$$\text{Annual saving (PLC vs distributed)} \approx 2 \times 900 + 1 \times 1,200 = 3,000 \text{ per year}$$

TABLE VIII
DISTRIBUTED CONTROLLERS VERSUS CENTRAL PLC — FEATURE COMPARISON

Feature	Distributed Controllers	Central PLC
Mode logic (1.A.1/1.A.2/B/C)	Relay rungs only; opaque to modification	Native structured text; software change only
SoC alarm + HMI decision prompt	Not available without additional hardware	Built in; presented on Level 1 screen
Cross-loop fault visibility	None; each controller is blind to others	Full; all variables visible simultaneously
Alarm management	Per-loop buzzers; no history; no priority	Unified ISA-18.2 list with timestamps
Post-incident diagnosis	Memory and paper log only	SCADA historian; full 1-second trend re-play
Configuration backup	Manual printed sheets; per-controller USB	Automatic CPU SD card; full restore on swap
Repair skill required	Low; any technician	Medium; PLC-trained technician
Common fault repair time	10–30 min hardware + 30–60 min reconfiguration	15–30 min hardware + automatic reconfiguration
Remote diagnostics	Not available	Full OPC-UA remote access
Scalability to multi-vessel	Requires full hardware duplication per vessel	I/O expansion card per vessel; €400–800
Modification complexity	Rewiring required	Software edit and download; no rewiring

TABLE IX
INSTALLED COST ESTIMATES — SINGLE VESSEL INSTALLATION (EURO, WESTERN EUROPE)

Cost Element	Distributed Controllers	Central PLC
<i>Hardware</i>		
Controllers / CPU	€550–1,350 (3 units)	€1,800–3,200 (S7-1200 + I/O)
HMI panel	Not included	€600–1,200 (KTP700)
Relay logic section	€300–600	Not required
Duplex CPU (optional)	Not applicable	€2,000–4,500
Cabinet and wiring materials	€800–1,400	€600–1,000
<i>Engineering and Labour</i>		
Panel build labour	€900–1,800 (high wiring density)	€500–900
PLC / controller programming	€400–800 (per-controller setup)	€1,500–3,500
TIA Portal software licence	Not applicable	€1,200–2,500
Commissioning and loop tuning	€600–1,200	€800–1,500
Total installed (simplex)	€3,550–7,150	€7,000–13,800
Total installed (duplex CPU)	Not applicable	€9,000–18,300
<i>Costs exclude field instrumentation (sensors, valves, cabling) which are identical for both architectures. Import duties and VAT applicable in Nepal and other non-EU markets; hardware costs increase 15–30%.</i>		

$$\text{Break-even (single vessel)} \approx \frac{5,000 \text{ cost delta}}{3,000/\text{year}} \approx 1.5\text{--}2 \text{ years}$$

This break-even compresses further with additional vessels. Adding a second vessel to the distributed system requires duplicating the full controller hardware at €3,500–7,000. Adding a second vessel to the PLC system requires an I/O expansion card and Modbus TCP satellite node at €600–1,200. At two vessels the PLC system is cost-equivalent to or cheaper than the distributed system at the point of installation, before any operational savings are applied.

Localisation note. The above figures represent the primary Western European expansion market. For installations in Nepal and comparable markets, hardware costs are broadly similar subject to import duties of 15–30%, but panel build and commissioning labour costs are substantially lower. This compresses the break-even point in favour of the distributed approach for single-vessel purely local deployments. However, the operational complexity, cross-loop fault blindness, and absence of remote diagnostic capability of the distributed architecture remain unchanged regardless of geography. For any installation intended for commercial operation, client handover, or future integration into a multi-vessel network, the central PLC recommendation stands.

F.E.5 Recommendation: The central PLC architecture is the appropriate implementation environment for the VCH control philosophy as defined in this appendix. The distributed approach is technically incapable of implementing the Mode 1.A.2 SoC decision prompt, the unified alarm philosophy of Section F.F, and the cross-loop fault detection required by the FMEA in Section F.H without significant additional hardware that erodes its cost advantage. The PLC architecture should be specified as the standard for all VCH installations. The distributed approach may be considered only for single isolated skids with no mode logic requirements and no commercial handover obligation.

FF Updated HMI / SCADA Screen Layout and Alarm Philosophy

The HMI and SCADA layer is organised per ISA-101 across three display tiers as defined in Appendix D, Section D.E. The following amendments apply in Version 2.

Level 1 — System Overview is updated to display the Version 2 mode tag (1.A.1, 1.A.2, B, or C) rather than the Version 1 mode numbers. The SoC bar now includes a floor threshold marker at $\text{SoC}_{\text{floor}}$ so the operator can visually track proximity to the alarm condition in real time. TCV-402 position is added to the mimic diagram. When DO-104 is energised (SoC floor reached in Mode 1.A.2), a decision prompt overlay appears on the Level 1 screen presenting Option A (stop batch) and Option B (continue, accept temperature sacrifice) as tappable buttons. This overlay cannot be dismissed without an explicit selection.

Level 2 — Loop Detail Screens now include a dedicated Loop 3 screen for the battery recharge controller, which was absent in Version 1. TE-104 and TE-105 trends appear on this screen to confirm bidirectional energy exchange.

The alarm table is updated below. The SoC floor alarm is classified as a distinct **Decision Alarm (DA)** class — it requires an operator choice rather than a response action and must not be shelved or acknowledged without a selection being recorded in the SCADA historian.

TABLE X
UPDATED ALARM SETPOINT AND PRIORITY CLASSIFICATION MATRIX — VERSION 2

Tag	Alarm Description	Lo / LoLo	Hi / HiHi	Priority	Required Action
TE-101	Supply temp out of band	Lo: $T_{\text{set}} - 5^{\circ}\text{C}$ LoLo: $T_{\text{set}} - 15^{\circ}\text{C}$	Hi: $T_{\text{set}} + 10^{\circ}\text{C}$ HiHi: $T_{\text{set}} + 25^{\circ}\text{C}$	P2 / P1	Investigate driver; P1 triggers balancing bypass
TE-102	Battery core temp deviation	Lo: $T_{\text{bat}, \text{min}}$ LoLo: $T_{\text{bat}, \text{min}} - 10^{\circ}\text{C}$	Hi: $T_{\text{bat}, \text{max}}$ HiHi: $T_{\text{bat}, \text{max}} + 5^{\circ}\text{C}$	P2 / P1	P1 isolates recharge; flag for inspection
TE-103	Vessel batch temp deviation	Lo: $T_{\text{proc}} - 3^{\circ}\text{C}$	Hi: $T_{\text{proc}} + 5^{\circ}\text{C}$ HiHi: $T_{\text{proc}} + 12^{\circ}\text{C}$	P3 / P2	P2 triggers setpoint review
TE-104	Battery inlet temp loss	Signal deviation $> 5^{\circ}\text{C}$ from TE-101 during recharge		P2	Check TCV-402 position and ZS-702
TE-105	Battery outlet temp loss	Signal deviation $< 2^{\circ}\text{C}$ from TE-102 during discharge		P2	Check TCV-401 blend ratio
FE-201	Velocity breach	Lo: 0.3 m/s	Hi: 2.0 m/s HiHi: 2.5 m/s	P2 / P1	P1 trips VFD; latches FAIL_SAFE
PE-301	Differential pressure	LoLo: 0.5 bar	HiHi: 6.0 bar	P1	Isolate loop; inspect coil
LE-401	SoC floor breach	$\text{SoC} \leq \text{SoC}_{\text{floor}}$ during Mode 1.A.2		DA	HMI decision prompt; Option A or B required
VFD-501	Drive fault	—	Any fault code	P1	Acknowledge; switch to bypass pump
TCV-401	Position mismatch	$ \text{Cmd} - \text{Actual} > 5\%$ for > 10 s		P2	Check actuator supply
TCV-402	Position mismatch	$ \text{Cmd} - \text{Actual} > 5\%$ for > 10 s		P2	Check actuator supply

DA = Decision Alarm. Must not be shelved without a recorded operator selection. All others per ISA-18.2. Deadband of $\pm 0.5^{\circ}\text{C}$ on all temperature alarms to suppress chattering at steady state.

F.G Updated Network Architecture and Communication Protocols

The three-layer network hierarchy defined in Appendix D, Section D.G is retained unchanged in Version 2. The following amendments apply to the device lists.

Layer 1 (Field Bus) now includes TCV-402 on the HART analogue loop in addition to the Version 1 devices. TE-104 and TE-105 are added as PT100 RTD inputs on the 4–20 mA / HART field bus.

Layer 2 (Control Bus) is unchanged. FE-201 and VFD-501 remain on Profinet IO. Satellite PLCs in multi-vessel configurations retain Modbus TCP at 500 ms poll interval.

Layer 3 (Supervisory Bus) is unchanged. OPC-UA over dedicated VLAN at 1-second historian resolution. The historian node space is extended to include the two new temperature tags and the LE-401 SoC derived tag.

TABLE XI
UPDATED COMMUNICATION PROTOCOL AND NETWORK LAYER SPECIFICATIONS — VERSION 2

Layer	Protocol	Medium	Topology	Cycle Rate	Connected Devices
Layer 1	4–20 mA + HART rev 7	STP 2-core 0.5 mm ²	Point-to-point star	Analogue continuous	TE-101/102/103/104/105, PE-301, TCV-401, TCV-402
Layer 2	Profinet IO RT Class 1	Cat6A STP Ethernet	Line / star hybrid	1–4 ms	FE-201, VFD-501
Layer 2	Modbus TCP	Cat6A STP Ethernet	Star from master	500 ms poll	Satellite vessel PLCs (multi-vessel only)
Layer 3	OPC-UA IEC 62541	Cat6A dedicated VLAN	Star from SCADA	1 s historian	HMI terminals, historian, engineering workstation

All Ethernet segments via managed switches with VLAN tagging. IEC 62443-3-3 SL2 for OPC-UA endpoints.

F.H Updated Failure Mode and Effects Analysis — Version 2

The FMEA is updated to reflect the Version 2 I/O schedule and mode structure. New rows are added for TCV-402, TE-104/TE-105 signal loss, and the Mode 1.A.2 battery drain continuation scenario. All Version 1 rows are retained and reviewed; RPN values are unchanged where the mitigation strategy is unaffected by the architecture revision. The critical RPN threshold of 100 remains the hardware interlock trigger per IEC 60812.

TABLE XII
UPDATED FMEA — VERSION 2

Failure Mode	Root Cause	Effect	S	O	D	RPN	Mitigation
FE-201 signal loss	Cable fault or transmitter failure	Loop 2 loses PV; VFD runs open-loop	8	3	4	96	Watchdog on signal; fallback to v_{min} on loss
TCV-401 stuck open	Actuator or positioner failure	Uncontrolled battery discharge; overtemperature risk	9	2	3	54	TE-103 HiHi trips battery isolation; ZS-701 mismatch alarm
TCV-401 stuck closed	Positioner or pneumatic failure	Battery cannot discharge; demand unmet in 1.A.2	5	2	3	30	TE-103 Lo alarm; manual bypass valve
TCV-402 stuck open	Actuator failure	Uncontrolled recharge flow; possible battery overtemperature	7	2	3	42	TE-102 HiHi trips recharge isolation; ZS-702 mismatch alarm
TCV-402 stuck closed	Positioner failure	Battery cannot recharge; SoC degrades over successive batches	5	2	4	40	TE-104 deviation alarm; manual bypass valve
VFD-501 trip	Overtemperature or overcurrent	Loss of loop circulation; coil stagnation	9	3	2	54	VFD fault to PLC DI; auto FAIL_SAFE transition
Loop over-velocity	VFD runaway or loop instability	Coil erosion; long-term hydraulic degradation	10	2	2	40	Hardware overspeed relay independent of PLC; trips VFD contactor
TE-102 multipoint failure	Thermocouple open-circuit	SoC invalid; battery over-charge risk	7	4	4	112	Critical: Redundant thermocouple pair; majority-vote logic in PLC
TE-104/105 signal loss	Cable fault or moisture ingress	Battery energy exchange unverifiable; silent recharge/discharge failure	6	3	5	90	TE-104/105 deviation alarms; verify against TE-101/102
1.A.2 drain continuation	Operator selects Option B at SoC floor	Vessel temperature sacrifice; potential product quality impact	6	3	2	36	SCADA historian logs operator selection with timestamp; post-batch review
PLC processor fault	Hardware fault or watchdog timeout	All loops to FAIL_SAFE simultaneously	10	1	2	20	Hot-standby duplex CPU; switchover < 100 ms
Modbus TCP link loss	Switch fault or cable break	Master loses satellite data; balancing degrades	6	3	3	54	Satellites revert to local PI on 3 missed polls
Loop pressure loss	Coil or pipe leak	Fluid escape; thermal hazard	9	2	2	36	PE-301 LoLo hardwired to isolation valve; FAIL_SAFE latch
SCADA server loss	Server crash or VLAN fault	Loss of visibility; control continues autonomously	4	3	2	24	PLC independent of SCADA; local HMI maintains Level 1 display

$RPN = S \times O \times D$. Items with $RPN \geq 100$ require hardware interlock independent of PLC software layer.
New rows in Version 2: TCV-402 stuck open/closed, TE-104/105 signal loss, 1.A.2 drain continuation.

APPENDIX G
REVISED PLC IMPLEMENTATION AND CONTROL COMMISSIONING
VERSION 2 — CURRENT

VERSION NOTICE

This appendix supersedes Appendix E (Version 1) and provides the discrete-time mathematics, IEC 61131-3 implementation code, and commissioning procedures consistent with the three-loop control architecture defined in Appendix F. Sections carried forward from Appendix E without change are identified inline. Appendix E is retained as an archived engineering decision record. This appendix should be read in conjunction with Appendix F — all instrument tags, mode references, and loop declarations in this document refer to the Version 2 architecture.

This appendix translates the three-loop control architecture of Appendix F into the discrete-time difference equations, IEC 61131-3 Structured Text (ST) code blocks, and physical commissioning procedures required for implementation on an industrial PLC platform. The content is organised in the sequence a controls engineer would encounter it: mathematics first, pre-commissioning gain estimates second, physical identification procedure third, code implementation fourth, and commissioning sequence last. Ladder logic and relay fallback guidance is retained from Appendix E for environments where ST is not available.

G.A Discrete-Time PID and PI Algorithms

Carried forward from Appendix E, Sections E.A–E.C, with the addition of Table XIII defining active controller terms per loop.

G.A.1 Velocity Form PID Algorithm: Because a PLC samples at fixed discrete scan intervals Δt , the continuous-time PID integral and derivative terms are approximated using backward Euler discretisation. The velocity (incremental) form is used throughout this framework because it provides bumpless transfer when switching between manual and automatic modes, and naturally prevents integrator windup from propagating through actuator saturation boundaries:

$$\Delta u(k) = K_p [e(k) - e(k-1)] + K_i \Delta t e(k) + \frac{K_d}{\Delta t} [e(k) - 2e(k-1) + e(k-2)]$$

The accumulated actuator output is:

$$u(k) = u(k-1) + \Delta u(k)$$

G.A.2 Derivative Kick Mitigation: When the operator changes the setpoint SP via the HMI, the error $e(k)$ shifts instantaneously. In the standard form above, the derivative term produces an impulsive spike that violently drives the actuator to saturation. To prevent this, the derivative is computed on the process variable PV rather than the error:

$$\text{Derivative term} = -\frac{K_d}{\Delta t} [PV(k) - 2PV(k-1) + PV(k-2)]$$

This leaves the response to disturbances unchanged while eliminating the kick on commanded setpoint steps.

G.A.3 Integral Anti-Windup Clamping: Large thermal masses cause the integral accumulator to grow continuously during heat-up while the actuator is saturated at its output limit. To prevent overshoot on arrival at setpoint, the per-scan integral increment $\Delta I(k)$ is frozen whenever the actuator is at a saturation boundary and the error would drive it further into saturation. The accumulated output $u(k)$ is not zeroed — only the increment for the current scan is suppressed:

$$\text{If } u(k) \geq u_{max} \text{ and } e(k) > 0: \quad \Delta I(k) = 0$$

$$\text{If } u(k) \leq u_{min} \text{ and } e(k) < 0: \quad \Delta I(k) = 0$$

G.A.4 First-Order Low-Pass Sensor Filter (EMA): Raw analogue signals from RTDs and electromagnetic flowmeters carry turbulent process noise. An exponential moving average (EMA) filter is applied to each analogue input before it enters any PID calculation block:

$$PV_{filtered}(k) = \alpha \cdot PV_{raw}(k) + (1 - \alpha) \cdot PV_{filtered}(k-1)$$

The smoothing constant α is derived from the desired filter time constant τ_f and the loop scan interval Δt :

$$\alpha = \frac{\Delta t}{\tau_f + \Delta t}, \quad 0 < \alpha \leq 1$$

A lower α produces heavier filtering and more phase lag. The filter time constant τ_f must be set significantly shorter than the process time constant τ to avoid artificially inflating the measured dead time θ during the step test identification procedure in Section G.D.

G.A.5 Active Terms per Loop: Table XIII defines which PID terms are active for each loop and the physical justification for each omission. This table is the authoritative reference for configuring native PID instruction blocks (e.g. `PID_Compact` in TIA Portal or `PIDE` in Studio 5000).

TABLE XIII
ACTIVE CONTROLLER TERMS BY LOOP

Loop	Name	P	I	D	Justification
1	Vessel batch temp	✓	✓	✓	Slow integrating process with dead time; all three terms required. D on PV only to prevent setpoint-step kick.
2	Pump flow rate	✓	✓	×	Fast hydraulic loop; D amplifies flowmeter turbulent noise without improving response. PI sufficient.
3	Battery recharge	✓	✓	×	Very slow large thermal mass; D amplifies thermocouple noise. PI sufficient for drift-free temperature hold.
4	Multi-vessel balance	✓	×	×	Supervisory trim loop; I causes inter-vessel windup competition. P-only with intentionally low gain.

G.B Per-Loop Scan Interval Derivation

Replaces Appendix E, Section E.D. Extends the single-loop scan interval formula to all four loops independently.

The Nyquist–Shannon criterion applied to process control requires a minimum of ten to twenty sample points per half-period of the dominant oscillation mode to maintain closed-loop stability. For a first-order-plus-dead-time process, this translates to the scan interval recommendation:

$$\Delta t_{scan} \leq \frac{\tau}{20}$$

where τ is the dominant process time constant of the loop. This criterion is applied independently to each loop because their time constants differ by orders of magnitude. Applying a single universal scan interval equal to the fastest loop (Loop 2) to all loops wastes CPU cycles on Loops 1 and 3; applying the slowest loop’s interval to Loop 2 produces an unstable hydraulic controller.

The correct implementation assigns each loop to a separate cyclic interrupt task in the PLC task configuration, each executing at its own rate. Table XIV summarises the derivation and recommended intervals.

TABLE XIV
PER-LOOP SCAN INTERVAL DERIVATION

Loop	Dominant τ	Source of τ	Recommended Δt	PLC Task Type	Notes
1	$S_{t,vessel}$ (hundreds to thousands of seconds)	Step 10 thermal time constant of vessel	$S_{t,vessel}/20$	Cyclic interrupt, low priority	For reference case $S_t = 6665$ s: $\Delta t \approx 330$ s
2	$\tau_{pump} = 2\text{--}8$ s (impeller mechanical spin-up)	Pump datasheet inertia; Step 5 hydraulic characterisation	1–4 s	Cyclic interrupt, high priority	Must be faster than Profinet IO cycle; set to match FE-201 response time
3	$S_{t,battery}$ (larger than $S_{t,vessel}$)	Step 10 battery thermal mass calculation	$S_{t,battery}/20$	Cyclic interrupt, low priority	Will be slower than Loop 1 given larger battery thermal mass
4	Governed by Modbus TCP poll rate	Network configuration	500 ms	Modbus exchange task	Matched to inter-PLC communication cycle; not a dedicated control task

Loops 1 and 3 share a low-priority task tier but execute independently with their own timers.

Loop 2 must be in a higher-priority interrupt than Loops 1 and 3 to guarantee hydraulic safety response.

The EMA filter time constant τ_f for each loop must be set shorter than the loop’s Δt to avoid aliasing. Recommended starting values: $\tau_f = 0.1 \times \tau_{process}$ for each loop, which gives α values that provide meaningful noise rejection without introducing sufficient phase lag to destabilise the loop.

Before the physical system is built, starting PID gain estimates can be derived directly from the VCH framework calculation outputs. These estimates carry uncertainty from fabrication tolerances, actual pump curve deviations, and coil fouling state, but they provide a physically grounded starting point that is significantly closer to the final tuned values than generic default parameters. They also serve as a validation check: if the commissioning step test (Section G.D) yields values that diverge from these estimates by more than 30%, the physical installation should be inspected for discrepancies from the design.

Every loop transfer function is approximated as a first-order process with dead time:

$$G(s) = \frac{K_{proc} e^{-\theta s}}{\tau s + 1}$$

The three parameters K_{proc} , τ , and θ are extracted per loop as follows.

G.C.1 Loop 1 — Vessel Batch Temperature: Process gain K_{proc} : The process gain expresses how many degrees Celsius the vessel temperature changes per percentage point of TCV-401 opening at steady state. It is estimated from the Step 6 thermal performance evaluation:

$$K_{proc,1} = \frac{\dot{Q}_{max} \cdot \Delta t_{scan,1}}{m_{fluid} \cdot C_p \cdot 100} \quad \left[\frac{^{\circ}\text{C}}{\%} \right]$$

where $\dot{Q}_{max}$ is the maximum coil heat transfer rate from Step 6, m_{fluid} is the vessel fluid mass from Step 3, C_p is the specific heat capacity from Step 2, and the factor of 100 normalises per percentage of valve opening. For a large vessel this value is typically small, in the range 0.05–0.20 °C/%.

Time constant τ_1 : The dominant thermal time constant is the vessel thermal time constant S_t computed in Step 10:

$$\tau_1 = S_t$$

Dead time θ_1 : The dead time is the coil transit time plus the RTD response lag. The transit time is derived from the coil geometry and operating velocity from Steps 4 and 7:

$$\theta_{transit} = \frac{L_{coil}}{v_{operating}}$$

Add 5–15 seconds for PT100 RTD Class A response lag. For typical installations:

$$\theta_1 = \theta_{transit} + \theta_{RTD} \approx 30\text{--}120 \text{ s}$$

IMC tuning (recommended for Loop 1): IMC tuning is preferred over Ziegler–Nichols for Loop 1 because the large dead time ratio θ_1/τ_1 makes ZN gains dangerously aggressive. The IMC formulas with desired closed-loop time constant λ are:

$$K_p = \frac{\tau_1}{K_{proc,1}(\lambda + \theta_1)}, \quad T_i = \tau_1, \quad T_d = \frac{\theta_1}{2}$$

Set $\lambda = \tau_1/3$ as the starting point for moderate aggressiveness. Increase λ if the commissioning response is oscillatory; decrease if it is excessively sluggish.

G.C.2 Loop 2 — Pump Flow Rate: Process gain $K_{proc,2}$: The flow velocity change per percentage point of VFD speed is read directly from the pump characteristic curve obtained in Step 5:

$$K_{proc,2} = \frac{\Delta v}{\Delta \text{VFD}\%} \quad \left[\frac{\text{m/s}}{\%} \right]$$

For a centrifugal pump this is approximately linear in the operating range.

Time constant τ_2 : The pump mechanical spin-up time constant is read from the drive datasheet or estimated from the motor inertia:

$$\tau_2 \approx 2\text{--}8 \text{ s}$$

Dead time θ_2 : The dead time for Loop 2 is the sum of the Profinet IO cycle time and the FE-201 electromagnetic flowmeter response time:

$$\theta_2 \approx 1\text{--}3 \text{ s}$$

Ziegler–Nichols tuning (acceptable for Loop 2): Because θ_2/τ_2 is small (typically < 0.5), the standard ZN PI formulas are adequate:

$$K_p = \frac{0.9 \tau_2}{K_{proc,2} \cdot \theta_2}, \quad T_i = 3.3 \theta_2$$

No derivative term is applied.

G.C.3 Loop 3 — Battery Recharge: Process gain $K_{proc,3}$: The temperature change of the battery core per percentage point of TCV-402 opening. Estimated from the battery thermal mass and the maximum recharge power available from the driver:

$$K_{proc,3} = \frac{\dot{Q}_{recharge,max} \cdot \Delta t_{scan,3}}{m_{battery} \cdot C_{p,fluid} \cdot 100} \left[\frac{^{\circ}\text{C}}{\%} \right]$$

where $m_{battery}$ and the recharge power $\dot{Q}_{recharge,max}$ come from the Step 10 battery sizing calculation.

Time constant τ_3 : The battery thermal time constant from Step 10. This is larger than τ_1 because the battery vessel has greater thermal mass and less internal convection:

$$\tau_3 = S_{t,battery} > S_{t,vessel}$$

Dead time θ_3 : Recharge circuit transit time from the driver divert point to the battery inlet, plus TE-102 thermocouple response lag:

$$\theta_3 = \frac{L_{recharge\ circuit}}{v_{recharge}} + \theta_{TC}$$

IMC tuning for Loop 3: Apply the same IMC formulas as Loop 1, but set $\lambda = \tau_3/2$ rather than $\tau_3/3$. The recharge loop does not need fast response; a more conservative λ produces stable drift-free control with lower risk of overshoot into battery overtemperature.

$$K_p = \frac{\tau_3}{K_{proc,3}(\lambda + \theta_3)}, \quad T_i = \tau_3, \quad T_d = 0$$

G.C.4 Pre-Commissioning Gain Summary Table: Table XV records the first-principles gain estimates computed from the framework outputs. This table should be completed before commissioning and retained alongside the commissioning record as a validation baseline.

TABLE XV
PRE-COMMISSIONING GAIN ESTIMATE RECORD (TO BE COMPLETED FROM FRAMEWORK OUTPUTS)

Loop	Name	K_{proc} source	τ source	K_p	T_i (s)	T_d (s)	Method
1	Vessel batch temp	Step 6 $\dot{Q}_{max}$, Step 3 m_{fluid}	Step 10 S_t	<i>calc.</i>	<i>calc.</i>	<i>calc.</i>	IMC, $\lambda = \tau/3$
2	Pump flow rate	Step 5 pump curve	Drive datasheet	<i>calc.</i>	<i>calc.</i>	0	ZN PI
3	Battery recharge	Step 10 $\dot{Q}_{recharge}$, battery mass	Step 10 $S_{t,bat}$	<i>calc.</i>	<i>calc.</i>	0	IMC, $\lambda = \tau/2$
4	Multi-vessel balance	Not applicable	Not applicable	0.5–1.0	∞ (P only)	0	Empirical

Fill in calculated values before FAT. Compare against step test results in Section G.D.

Divergence > 30% between pre-commissioning estimate and step test result warrants physical inspection.

G.D Step Test Identification and Gain Refinement Procedure

New in Version 2. Not present in Appendix E.

The step test (bump test) is the physical measurement procedure by which K_{proc} , τ , and θ are measured on the real installed system and used to confirm or correct the pre-commissioning gain estimates from Section G.C. It must be performed on each loop independently in the commissioning sequence defined in Section G.F. The following procedure applies to Loops 1, 2, and 3. Loop 4 is tuned empirically and does not require a step test.

G.D.1 General Step Test Procedure:

Step 1. Stabilise the loop. Place the controller in manual mode. Allow the process variable to reach a steady operating point — no more than $\pm 0.2^\circ\text{C}$ drift over five minutes for temperature loops, $\pm 0.02\text{ m/s}$ over thirty seconds for the flow loop. Record the steady-state PV value PV_0 and the current manual output u_0 .

Step 2. Execute the bump. Make a step change of 10–20% of the output range. The bump must be large enough to produce a PV response clearly above the noise floor, and small enough to avoid unacceptable process disturbance. Log all relevant tags from this moment at the loop's scan interval.

Step 3. Hold until steady state. Allow the PV to travel through its full response and approach a new steady state. For Loop 1 this requires patience — the vessel thermal mass means the response may take thirty minutes or more to fully settle.

Step 4. Read the response curve. From the logged trend identify:

- $\theta_{measured}$: time from the bump instant to when the PV first visibly departs from PV_0 . Draw a tangent line at the inflection point (steepest slope) for a more precise estimate.
- $\tau_{measured}$: time from the end of dead time to when the PV has risen to 63.2% of its total change ΔPV_{final} .
- $K_{proc,measured}$: final steady-state PV change divided by the bump size:

$$K_{proc,measured} = \frac{\Delta PV_{final}}{\Delta u_{bump}}$$

Step 5. Recalculate gains. Substitute $K_{proc,measured}$, $\tau_{measured}$, and $\theta_{measured}$ into the relevant tuning formula (IMC for Loops 1 and 3; ZN for Loop 2). Record the revised gain values in Table XV alongside the pre-commissioning estimates.

Step 6. Restore the bump. Return the output to u_0 , allow the process to re-stabilise, then place the controller in automatic with the calculated gains before proceeding.

G.D.2 Loop-Specific Notes: Loop 1 — Vessel Batch Temperature. Run the step test at normal operating temperature, not cold. The cold-start heat transfer coefficient (from Step 6) differs from the steady-state value, producing a different K_{proc} at cold conditions. Gains tuned at operating temperature will be slightly aggressive at cold-start but safe — the vessel heats slightly faster initially, which is acceptable. Gains tuned cold will be sluggish at operating temperature, which reduces batch throughput.

The EMA filter interaction must be respected: the step test must be run with the production value of α already loaded. A higher α than intended inflates the measured θ by adding apparent lag, causing the tuning formula to produce an under-aggressive K_p . Do not run the step test with $\alpha = 1$ (filter bypassed) and then activate the filter afterwards.

Loop 2 — Pump Flow Rate. The step test for Loop 2 is fast and straightforward. The response will be visible within seconds of the bump. Ensure the vessel loop is in manual during the Loop 2 step test so that TCV-401 does not modulate in response to the resulting flow change and distort the FE-201 reading.

Loop 3 — Battery Recharge. The recharge loop step test requires the battery to be at a stable intermediate charge state — not at $T_{bat,max}$ (which would produce a truncated response) and not cold (which produces an unrepresentative K_{proc}). Target 50–70% of the battery's usable temperature range for the step test starting point.

G.D.3 Acceptance Criteria: A step test result is acceptable when:

- The measured K_{proc} , τ , and θ agree with the pre-commissioning estimates to within $\pm 30\%$.
- The PV response curve is smooth and monotonic with no oscillation during the open-loop bump (oscillation during open-loop response indicates a closed-loop instability risk at the calculated gains).
- The signal-to-noise ratio of ΔPV_{final} to the steady-state noise band is at least 5:1, confirming the bump size was sufficient.

If these criteria are not met, Section G.D.1 Step 5 should be repeated with the bump size adjusted, or the physical installation inspected for discrepancies from the design.

G.E IEC 61131-3 Structured Text Implementation — Three Loop Blocks

Replaces Appendix E, Section E.E. Three independent ST blocks are provided, one per controlled loop. Each block is self-contained with its own VAR declarations and scan interval parameter. Blocks are intended for implementation in separate cyclic interrupt tasks as defined in Section G.B.

Loop 1 — Vessel Batch Temperature (PID):

```
1  VAR
2      // --- Inputs ---
3      PV_Raw_TE103      : REAL;    // Raw analogue input from TE-103 (deg C)
4      SP_Vessel         : REAL;    // Setpoint: T_target or T_hib per active mode
5      Output_UpperLim   : REAL;    // Mode-dependent upper limit (% TCV-401 opening)
6                                  // Set by mode logic layer: see Appendix F Table F.2
7      // --- Tuning Parameters (from Section G.C.1 / G.D, Loop 1) ---
8      Kp1               : REAL;    // Proportional gain
9      Ti1               : REAL;    // Integral time constant (s) = tau_1
10     Td1               : REAL;    // Derivative time constant (s) = theta_1 / 2
11     dt1               : REAL;    // Scan interval (s) = S_t_vessel / 20
12     Alpha1            : REAL;    // EMA filter constant = dt1 / (tau_f1 + dt1)
13
14     // --- Memory (RETAIN: preserved across PLC power cycle) ---
15     PV1_Filtered      : REAL;
16     PV1_Prev1         : REAL;
17     PV1_Prev2         : REAL;
18     Error1_Prev       : REAL;
19     TCV401_Out        : REAL;    // Accumulated actuator output (% opening)
20
21     // --- Intermediates ---
22     Error1             : REAL;
23     Delta_U1          : REAL;
24     Pl_Term            : REAL;
25     Il_Term            : REAL;
26     Dl_Term            : REAL;
27 END_VAR
28
29 // --- 1. EMA Sensor Filter ---
30 PV1_Filtered := (Alpha1 * PV_Raw_TE103)
31               + ((1.0 - Alpha1) * PV1_Filtered);
32
33 // --- 2. Error ---
34 Error1 := SP_Vessel - PV1_Filtered;
35
36 // --- 3. Proportional Term ---
37 Pl_Term := Kp1 * (Error1 - Error1_Prev);
38
39 // --- 4. Derivative Term (PV-based: no setpoint-step kick) ---
40 Dl_Term := -(Kp1 * Td1 / dt1)
41           * (PV1_Filtered - (2.0 * PV1_Prev1) + PV1_Prev2);
42
43 // --- 5. Integral with Anti-Windup ---
44 IF (TCV401_Out >= Output_UpperLim AND Error1 > 0.0) OR
45    (TCV401_Out <= 0.0 AND Error1 < 0.0) THEN
46     Il_Term := 0.0; // Freeze increment; accumulator unchanged
47 ELSE
48     Il_Term := Kp1 * (dt1 / Ti1) * Error1;
49 END_IF;
50
51 // --- 6. Velocity Form Accumulation ---
52 Delta_U1 := Pl_Term + Il_Term + Dl_Term;
53 TCV401_Out := TCV401_Out + Delta_U1;
54
55 // --- 7. Output Saturation (mode-dependent upper limit) ---
56 IF TCV401_Out > Output_UpperLim THEN
57     TCV401_Out := Output_UpperLim;
58 END_IF;
59 IF TCV401_Out < 0.0 THEN
60     TCV401_Out := 0.0;
61 END_IF;
62
63 // --- 8. Memory Update ---
64 Error1_Prev := Error1;
65 PV1_Prev2 := PV1_Prev1;
66 PV1_Prev1 := PV1_Filtered;
67
68 // --- 9. Heartbeat for Software Watchdog (Section G.I) ---
69 WD_Heartbeat := NOT WD_Heartbeat;
```

Listing 1. Loop 1: Vessel Batch Temperature PID — TE-103 → TCV-401

G.E.2 Loop 2 — Pump Flow Rate (PI):

```

1  VAR
2  // --- Inputs ---
3  PV_Raw_FE201      : REAL;    // Raw velocity signal from FE-201 (m/s)
4  SP_Velocity       : REAL;    // Velocity setpoint from mode logic layer (m/s)
5  V_Max             : REAL := 2.0; // Erosion ceiling (m/s) --- hard limit
6  V_Min             : REAL := 0.3; // Stagnation floor (m/s) --- hard limit
7
8  // --- Tuning Parameters (from Section G.C.2 / G.D, Loop 2) ---
9  Kp2               : REAL;    // Proportional gain
10 Ti2               : REAL;    // Integral time constant (s) = 3.3 * theta_2
11 dt2               : REAL;    // Scan interval (s): 1--4 s per Section G.B
12 Alpha2            : REAL;    // EMA filter constant
13
14 // --- Memory ---
15 PV2_Filtered       : REAL;
16 Error2_Prev        : REAL;
17 VFD501_Out         : REAL;    // Accumulated actuator output (% VFD speed)
18
19 // --- Intermediates ---
20 Error2             : REAL;
21 Delta_U2           : REAL;
22 P2_Term            : REAL;
23 I2_Term            : REAL;
24 END_VAR
25
26 // --- 1. EMA Sensor Filter ---
27 PV2_Filtered := (Alpha2 * PV_Raw_FE201)
28               + ((1.0 - Alpha2) * PV2_Filtered);
29
30 // --- 2. Error ---
31 Error2 := SP_Velocity - PV2_Filtered;
32
33 // --- 3. Proportional Term ---
34 P2_Term := Kp2 * (Error2 - Error2_Prev);
35
36 // --- 4. Integral with Anti-Windup ---
37 // Upper saturation also enforces V_Max; lower enforces V_Min
38 IF (VFD501_Out >= 100.0 AND Error2 > 0.0) OR
39    (VFD501_Out <= 20.0 AND Error2 < 0.0) THEN
40     I2_Term := 0.0;
41 ELSE
42     I2_Term := Kp2 * (dt2 / Ti2) * Error2;
43 END_IF;
44
45 // --- 5. Velocity Form Accumulation (PI: no D term) ---
46 Delta_U2 := P2_Term + I2_Term;
47 VFD501_Out := VFD501_Out + Delta_U2;
48
49 // --- 6. Output Saturation ---
50 IF VFD501_Out > 100.0 THEN VFD501_Out := 100.0; END_IF;
51 IF VFD501_Out < 20.0 THEN VFD501_Out := 20.0; END_IF;
52 // 20% minimum prevents coil stagnation regardless of setpoint
53
54 // --- 7. Hard Velocity Ceiling Check (independent of PID output) ---
55 // If live velocity breaches V_Max, trim VFD immediately this scan.
56 IF PV2_Filtered > V_Max THEN
57     VFD501_Out := VFD501_Out - (Kp2 * (PV2_Filtered - V_Max));
58     IF VFD501_Out < 20.0 THEN VFD501_Out := 20.0; END_IF;
59 END_IF;
60
61 // --- 8. Memory Update ---
62 Error2_Prev := Error2;

```

Listing 2. Loop 2: Pump Flow Rate PI — FE-201 → VFD-501

G.E.3 Loop 3 — Battery Recharge (PI):

```
1  VAR
2  // --- Inputs ---
3  PV_Raw_TE102      : REAL;    // Majority-voted TE-102 signal (deg C)
4  SP_Battery        : REAL;    // Battery target charge temperature T_bat_target
5  T_Bat_Max         : REAL;    // Battery overtemperature ceiling (hard limit)
6
7  // --- Tuning Parameters (from Section G.C.3 / G.D, Loop 3) ---
8  Kp3               : REAL;    // Proportional gain
9  Ti3               : REAL;    // Integral time constant (s) = tau_3
10 dt3               : REAL;    // Scan interval (s) = S_t_battery / 20
11 Alpha3            : REAL;    // EMA filter constant
12
13 // --- Memory ---
14 PV3_Filtered       : REAL;
15 Error3_Prev        : REAL;
16 TCV402_Out         : REAL;    // Accumulated actuator output (% TCV-402 opening)
17
18 // --- Intermediates ---
19 Error3             : REAL;
20 Delta_U3           : REAL;
21 P3_Term            : REAL;
22 I3_Term            : REAL;
23 END_VAR
24
25 // --- 1. EMA Sensor Filter (majority-vote input assumed pre-processed) ---
26 PV3_Filtered := (Alpha3 * PV_Raw_TE102)
27               + ((1.0 - Alpha3) * PV3_Filtered);
28
29 // --- 2. Error ---
30 Error3 := SP_Battery - PV3_Filtered;
31
32 // --- 3. Proportional Term ---
33 P3_Term := Kp3 * (Error3 - Error3_Prev);
34
35 // --- 4. Integral with Anti-Windup ---
36 IF (TCV402_Out >= 100.0 AND Error3 > 0.0) OR
37    (TCV402_Out <= 0.0 AND Error3 < 0.0) THEN
38   I3_Term := 0.0;
39 ELSE
40   I3_Term := Kp3 * (dt3 / Ti3) * Error3;
41 END_IF;
42
43 // --- 5. Velocity Form Accumulation (PI: no D term) ---
44 Delta_U3 := P3_Term + I3_Term;
45 TCV402_Out := TCV402_Out + Delta_U3;
46
47 // --- 6. Output Saturation ---
48 IF TCV402_Out > 100.0 THEN TCV402_Out := 100.0; END_IF;
49 IF TCV402_Out < 0.0 THEN TCV402_Out := 0.0; END_IF;
50
51 // --- 7. Hard Overtemperature Ceiling ---
52 // If battery core exceeds T_Bat_Max, close recharge valve immediately.
53 // This is a safety guard independent of the PI output.
54 IF PV3_Filtered >= T_Bat_Max THEN
55   TCV402_Out := 0.0;
56 END_IF;
57
58 // --- 8. Memory Update ---
59 Error3_Prev := Error3;
```

Listing 3. Loop 3: Battery Recharge PI — TE-102 → TCV-402

G.F Loop Commissioning Sequence and Mode Transition Testing

New in Version 2. Not present in Appendix E.

Tuning all three loops simultaneously causes interaction effects that prevent stable convergence. The correct commissioning sequence is mandatory: each loop must be stable before the next is activated.

G.F.1 Mandatory Commissioning Order: Phase 1 — Loop 2 (Pump Flow Rate, PI). Loop 2 is commissioned first because it is the actuator environment in which Loop 1 operates. With Loops 1 and 3 in manual and TCV-401 held at a fixed mid-range opening, activate Loop 2 in automatic with the calculated gains. Execute the Loop 2 step test per Section G.D and refine gains. Verify that the velocity setpoint is tracked within ± 0.05 m/s under steady conditions and that the hard ceiling and floor limits engage correctly. Loop 2 is considered commissioned when it holds a commanded velocity step without overshoot beyond 10% and settles within three scan cycles.

Phase 2 — Loop 3 (Battery Recharge, PI). With Loop 2 commissioned and running, activate Loop 3 in automatic. Loop 3 is slow and benign; it does not interact with Loop 2 during normal operation. Execute the Loop 3 step test with the battery at 50–70% charge state per Section G.D.2. Verify that TCV-402 responds smoothly to setpoint changes and that the hard overtemperature ceiling at $T_{bat,max}$ closes the valve immediately when triggered. Loop 3 is considered commissioned when it holds $T_{bat,target}$ with steady-state error below 0.5°C over a 30-minute hold period.

Phase 3 — Loop 1 (Vessel Batch Temperature, PID). With Loops 2 and 3 both commissioned and running in automatic, activate Loop 1. The step test for Loop 1 must now be performed in this coupled condition — Loop 2 will respond to the flow changes induced by TCV-401 modulation, and Loop 3 will continue running in the background. This is the correct commissioning environment because it represents real operating conditions. Refine gains and verify the following acceptance criteria:

- Vessel temperature reaches T_{target} with overshoot $\leq 2^{\circ}\text{C}$.
- Steady-state error in Mode B hold $\leq 0.3^{\circ}\text{C}$ over 60 minutes.
- No sustained oscillation after setpoint step under any mode.

Phase 4 — Mode Transition Testing. With all three loops commissioned, the mode transitions defined in Appendix F Section F.C must be tested in the following sequence:

G.F.2 Mode Transition Test Sequence:

- T1. STANDBY → MODE_1A1.** Issue batch start command via HS-602. Confirm that Loop 2 ramps to demand velocity, Loop 1 begins heating toward T_{target} , and Loop 3 continues recharging. Verify no velocity ceiling breach during ramp-up.
- T2. MODE_1A1 → MODE_B.** Allow the vessel to reach T_{target} . Confirm that Loop 1 setpoint remains at T_{target} and TCV-401 throttles smoothly to a low steady-state opening. Confirm that Loop 2 setpoint drops to the $\dot{Q}_{loss}$ velocity. **Watch for overshoot on this transition** — the sudden reduction in Loop 1's output upper limit at arrival can cause the integrator to kick if the arrival deadband δ is set too small. If overshoot exceeds 2°C , increase δ or reduce K_p by 15% and repeat.
- T3. MODE_B → MODE_C.** Issue hibernate command with $\phi = 0.5$ as the test case. Confirm that T_{hib} is computed correctly from $\phi \cdot \dot{Q}_{hold}$, that Loop 1 setpoint updates to T_{hib} , and that the vessel cools to T_{hib} without oscillation. Confirm Loop 2 setpoint scales proportionally downward.
- T4. MODE_C → MODE_B (Wake-up).** Issue wake command. Confirm that T_{target} is restored as Loop 1 setpoint and the system re-enters Mode 1.A.1 or 1.A.2 correctly based on the $\dot{Q}_{pump,max}$ evaluation.
- T5. MODE_1A2 SoC Floor Alarm Test.** Simulate the SoC floor condition by manually setting SoC_{floor} to the current SoC value. Confirm that AL-001 and AL-002 activate, DO-104 energises, and the HMI decision prompt appears on Level 1 with both options available. Confirm that no automatic state transition occurs. Test both Option A (graceful shutdown) and Option B (continue with reduced output limit) and verify the correct PLC response to each.
- T6. FAIL_SAFE Latch Test.** Simulate a velocity ceiling breach by commanding VFD-501 to a speed that produces $v > v_{HiHi}$ in a controlled test condition. Confirm that FAIL_SAFE latches within one watchdog scan cycle, all outputs move to de-energised positions, DO-103 pulse halts, DO-101 de-energises, and the field alarm beacons activate. Confirm that the latch cannot be cleared by any automated logic path and requires manual HMI acknowledgement. Log the transition timestamp from the SCADA historian and verify it matches the physical alarm event within one scan cycle.

All six transition tests must pass before the system is considered commissioned. Results must be recorded in the Factory Acceptance Test (FAT) documentation and signed off before site delivery.

G.G Ladder Logic (LD) Implementation Guidelines

Carried forward from Appendix E, Section E.F, without change. The following guidelines apply to environments where IEC 61131-3 Structured Text is not available. The three-loop structure of Version 2 maps to three separate LD program blocks, each residing in its own cyclic interrupt task at the scan intervals defined in Section G.B.

While Structured Text (ST) natively supports complex algebraic difference equations, many legacy or visually-oriented plant environments require IEC 61131-3 Ladder Diagram (LD) architecture. When implementing the VCH control loops in LD, the following structural guidelines apply:

- **Cyclic Execution via Interrupts:** The LD network for each loop should reside inside a dedicated cyclic hardware interrupt block (e.g. OB30 in Siemens TIA Portal or a Periodic Task in Rockwell RSLogix). The block execution rate must be statically configured to the per-loop Δt_{scan} values from Section G.B. A single global interrupt block for all loops is not acceptable in Version 2 — the loop scan rates differ by orders of magnitude.
- **Mathematical Compute Blocks:** The EMA sensor filter cannot easily be executed with basic add/multiply coils. A dedicated Compute (CPT) instruction block should calculate the $(1 - \alpha)$ filtering formula in a single rung per loop.
- **Native PID Instruction Utilisation:** Use native PID instruction blocks (PID_Compact, PIDE, or equivalent). Configure each block to read the *filtered* PV rather than the raw physical analogue channel. For Loop 1 configure derivative-on-PV mode explicitly; for Loops 2 and 3 disable the derivative term entirely in the instruction block parameters.
- **Boolean Anti-Windup Triggers:** Use XIC/XIO contact structures to evaluate actuator saturation. Route a parallel rung branch to a MOV instruction that zeros the integral increment register when saturation and error direction conditions are simultaneously true. Do not zero the accumulated output register — only the increment.
- **Output Limit Rungs:** The mode-dependent upper limit for Loop 1 (Output_UpperLim) must be written by the mode logic rung before the Loop 1 PID rung executes in each scan. Rung order within the LD program is therefore significant for Loop 1.

G.H Hardwired Relay-Based Control (Non-PLC Architecture)

Carried forward from Appendix E, Section E.G, without change. The operational limitations noted below are unchanged and remain disqualifying for any installation requiring Mode 1.A.2, the SoC decision alarm, or multi-vessel balancing (Loop 4).

For smaller, isolated hydronic skids, or as a robust fail-safe override to the primary PLC, a traditional hardwired electromechanical control architecture can be employed without microprocessor intervention.

- **Bang-Bang (On/Off) Control Profiles:** Proportional-Integral modulation is impossible without a dedicated controller. Continuous analogue temperature sensors (RTDs) are replaced with mechanical thermostats or liquid-filled capillary thermal switches that snap closed when bulk fluid temperature drops below the physical setpoint.
- **Relay Logic and Contactors:** Thermostat closure energises a 24 VDC or 120 VAC Master Control Relay (MCR) coil. The MCR pulls in the heavy-duty main motor contactor, providing three-phase power directly to the primary utility heater or fixed-speed circulation pump.
- **Hardware Safety Interlocks:** Physical flow switches (paddle or thermal dispersion type) and high-limit pressure switches (capsule type) are wired in series with the MCR coil. Loss of flow or pressure surge breaks the series circuit instantly, dropping the contactor and halting the loop.
- **Operational Limitations:** Hardwired relay logic is immune to software faults, network crashes, and EMI, but suffers from thermal hysteresis and cannot implement dynamic load balancing, thermal battery peak shaving, the Mode 1.A.2 SoC decision prompt, or the hibernation mode. A hardwired network restricts the framework to baseline direct charging and standby states only. It must not be specified for any commercial installation requiring the full four-mode vessel architecture defined in Appendix F.

G.I Watchdog Timer and FAIL_SAFE State Implementation

Carried forward from Appendix E, Section E.H, with amendments to tag references and the addition of the Loop 1 heartbeat toggle in Section G.E.1.

Two complementary watchdog mechanisms are required. A software watchdog detects PLC scan-cycle failures and task overruns. A hardware watchdog provides a fail-safe that is physically independent of the PLC processor and output cards.

Software Watchdog: Loop 1's ST block (Section G.E.1) toggles WD_Heartbeat on every execution. A separate high-priority watchdog task monitors this flag. If the heartbeat is not refreshed within two consecutive watchdog periods, all control outputs are forced to de-energised positions and FAIL_SAFE_Active is latched.

Hardware Watchdog: DO-103 outputs a 1 Hz pulse train to an external hardware watchdog relay module. This relay holds DO-101 (VFD-501 run enable) closed only while the pulse train is active. If the pulse train stops for any reason — PLC halt, output card failure, loss of 24 VDC control supply — the relay drops out and the VFD loses run permission independently of the PLC software state.

```

1  VAR
2      WD_Heartbeat      : BOOL;           // Toggled by Loop 1 block each execution
3      WD_Prev           : BOOL;
4      WD_MissCount      : UINT := 0;
5      WD_TripThreshold  : UINT := 2;     // FAIL_SAFE after 2 missed scans
6      Velocity_Live     : REAL;          // From FE-201 signal chain
7      Velocity_HiHi     : REAL := 2.5;   // Erosion ceiling HiHi per Appendix F F.F
8      HW_WD_Toggle      : BOOL;
9      HW_WD_Pulse       : BOOL;          // Physical DO to hardware watchdog relay
10     FAIL_SAFE_Active   : BOOL := FALSE;
11     PLC_State          : UINT;
12     TCV401_Demand      : REAL;
13     TCV402_Demand      : REAL;         // New in Version 2
14     VFD501_Demand      : REAL;
15     Alarm_Beacon       : BOOL;
16 END_VAR
17
18 // --- Block 1: Hardware Watchdog Pulse (1 Hz) ---
19 HW_WD_Toggle := NOT HW_WD_Toggle;
20 HW_WD_Pulse  := HW_WD_Toggle;
21
22 // --- Block 2: Software Heartbeat Monitor ---
23 IF WD_Heartbeat = WD_Prev THEN
24     WD_MissCount := WD_MissCount + 1;
25 ELSE
26     WD_MissCount := 0;
27 END_IF;
28 WD_Prev := WD_Heartbeat;
29
30 // --- Block 3: FAIL_SAFE Trigger Evaluation ---
31 IF (WD_MissCount >= WD_TripThreshold) OR
32    (Velocity_Live > Velocity_HiHi) THEN
33     FAIL_SAFE_Active := TRUE;
34 END_IF;
35
36 // --- Block 4: Safe-State Output Enforcement ---
37 IF FAIL_SAFE_Active THEN
38     PLC_State      := 99;           // FAIL_SAFE state code
39     TCV401_Demand  := 0.0;         // Battery discharge isolated
40     TCV402_Demand  := 0.0;         // Recharge isolated (Version 2 addition)
41     VFD501_Demand  := 0.0;         // Loop circulation stopped
42     Alarm_Beacon   := TRUE;
43     HW_WD_Pulse    := FALSE;       // Pulse halted; hardware relay drops; VFD loses run enable
44 END_IF;

```

Listing 4. Software Watchdog and FAIL_SAFE Latch — High-Priority 1-second Task

Two FAT verification requirements apply before commissioning sign-off. First, the hardware watchdog relay drop-out time must be shorter than the VFD-501 deceleration ramp time, ensuring the drive reaches zero speed before any mechanical isolation valve actuates. Second, FAIL_SAFE_Active must be confirmed as non-resettable by any automated logic path; reset requires explicit operator acknowledgement on the Level 3 HMI screen defined in Appendix F, Section F.F.

APPENDIX H
WORKED DESIGN EXAMPLE
PALM OIL STORAGE AND BATCH PROCESSING SYSTEM
KATHMANDU, NEPAL

ABOUT THIS APPENDIX

This appendix presents a complete eleven-step application of the VCH Sizing Framework to a real industrial design problem. All calculations are shown in full. Engineering choices made at each decision point are documented alongside their technical justification. This example may be used as a commissioning reference for the specific installation described and as a numerical template for future applications of the framework.

Problem Statement and Design Brief

A food-grade palm oil storage and processing facility in Kathmandu, Nepal requires two heated storage vessels for RBD (Refined, Bleached, Deodorised) palm oil used in biscuit and confectionery manufacturing. Palm oil solidifies below 35°C and must be maintained in liquid state for processing and dispensing. The facility has limited floor space and is located outdoors in a sheltered enclosure. The following design brief was established prior to framework application:

TABLE XVI
DESIGN BRIEF SUMMARY

Parameter	Specification
Process fluid	RBD palm oil (food grade, biscuit manufacturing)
Tank 1 capacity	10,000 litres (10 KL) — holding duty only
Tank 2 capacity	25,000 litres (25 KL) — batch processing and hibernation
Operating temperature	45°C (above solidification, below degradation threshold)
Cold feed condition	Fully solid at 25°C (cold storage delivery)
Batch requirement	2,000 kg processed to 45°C within 4 hours
HTF specification	Hot water, 60°C ± 5°C (product quality constraint)
Site ambient (worst case)	5°C (Kathmandu winter)
Installation	Outdoors, sheltered; limited footprint
Vessel geometry	Vertical cylindrical with cone bottom (drainage requirement)
Coil and vessel material	SS 316L seamless (food grade)

KEY DESIGN CHARACTERISTIC

Palm oil has a latent heat of fusion of 187 kJ/kg and melts over the range 33–39°C. With an HTF supply temperature of 55°C (worst case) and a process melting temperature of 36°C, the maximum available driving force is only 19°C. This narrow temperature differential is the defining constraint of this design and governs coil area selection throughout the framework. The latent heat phase accounts for 82% of total batch energy.

Step 1 Establishment of the Design Thermal Target

TABLE XVII
RBD PALM OIL THERMOPHYSICAL PROPERTIES

Property	Symbol	Value	Phase
Density (liquid at 45°C)	ρ_{oil}	891 kg/m ³	Liquid
Specific heat capacity	$C_{p,solid}$	1.98 kJ/kg·K	Solid
Specific heat capacity	$C_{p,liquid}$	2.15 kJ/kg·K	Liquid
Latent heat of fusion	h_{sf}	187 kJ/kg	Phase change
Melting point midpoint	T_{melt}	36°C	—
Starting temperature	T_{cold}	25°C	Cold storage
Target temperature	T_{target}	45°C	Process
Worst-case ambient	T_{amb}	5°C	Kathmandu winter

1.1 Palm Oil Thermophysical Constants:

1.2 10 KL Tank — Holding Duty Only: The 10 KL tank maintains palm oil in liquid state continuously. Its governing thermal load is environmental heat loss only — no batch heating requirement. The balance load calculation is deferred to Step 5 where vessel surface area is established. The 10 KL tank does not contribute to the batch thermal target.

1.3 25 KL Tank — Batch Thermal Target: The 25 KL tank processes 2,000 kg sub-batches of solid palm oil. The tank starts cold (full 25 KL at 25°C solid) and only the 2,000 kg sub-batch must reach 45°C within 4 hours. The surrounding cold mass acts as a thermal sink that partially absorbs energy from the coil during the batch window.

Sub-batch energy — three phases:

Mass of sub-batch: $m_{batch} = 2,000$ kg

Phase 1 — Sensible heating of solid from T_{cold} to T_{melt} :

$$Q_{s1} = m_{batch} \cdot C_{p,solid} \cdot (T_{melt} - T_{cold}) = 2000 \times 1.98 \times (36 - 25) = \mathbf{43,560 \text{ kJ}}$$

Phase 2 — Latent heat of fusion at $T_{melt} = 36^\circ\text{C}$:

$$Q_{lat} = m_{batch} \cdot h_{sf} = 2000 \times 187 = \mathbf{374,000 \text{ kJ}}$$

Phase 3 — Sensible heating of liquid from T_{melt} to T_{target} :

$$Q_{s2} = m_{batch} \cdot C_{p,liquid} \cdot (T_{target} - T_{melt}) = 2000 \times 2.15 \times (45 - 36) = \mathbf{38,700 \text{ kJ}}$$

$$Q_{batch,2t} = 43,560 + 374,000 + 38,700 = \mathbf{456,260 \text{ kJ}}$$

Surrounding cold mass thermal sink:

Remaining mass: $m_{surrounding} = 22,275 - 2,000 = 20,275$ kg

The surrounding solid oil heats from 25°C toward 36°C during the batch window, absorbing energy from the coil. A 40% participation factor is applied, reflecting the limited thermal conductivity of solid palm oil ($k_{solid} \approx 0.20$ W/m·K) which slows heat penetration outward from the coil surface:

$$\begin{aligned} Q_{sink,effective} &= 0.40 \times m_{surrounding} \times C_{p,solid} \times (T_{melt} - T_{cold}) \\ &= 0.40 \times 20,275 \times 1.98 \times 11 = \mathbf{176,636 \text{ kJ}} \end{aligned}$$

Total governing thermal energy:

$$Q_{design,25} = Q_{batch,2t} + Q_{sink,effective} = 456,260 + 176,636 = \mathbf{632,896 \text{ kJ}}$$

Required thermal power over 4-hour batch window (reference only):

$$\dot{Q}_{batch,25} = \frac{Q_{design,25}}{t_{batch}} = \frac{632,896}{4 \times 3600} = \mathbf{44.0 \text{ kW}}$$

STEP 1 RESULT

$Q_{design,25} = 632,896$ kJ $\dot{Q}_{batch,25} = 44.0$ kW (reference power for 4-hour target) Latent heat fraction: 82% of total batch energy
10 KL tank: holding duty only, thermal load governed by Step 5 loss calculation.

Step 2 Thermofluid Selection and Property Characterisation

2.1 HTF Selection: Hot water at $60^{\circ}\text{C} \pm 5^{\circ}\text{C}$ is specified to prevent thermal degradation and discolouration of food-grade palm oil. The governing worst-case supply temperature is $T_{HTF,in} = 55^{\circ}\text{C}$. All sizing calculations use this conservative value; actual operation at 60°C provides additional thermal margin.

TABLE XVIII
HOT WATER HTF THERMOPHYSICAL PROPERTIES AT 55°C

Property	Symbol	Value	Units
Density	ρ_{HTF}	985.7	kg/m^3
Specific heat capacity	$C_{p,HTF}$	4,183	$\text{J/kg}\cdot\text{K}$
Dynamic viscosity	μ_{HTF}	0.504×10^{-3}	$\text{Pa}\cdot\text{s}$
Thermal conductivity	k_{HTF}	0.648	$\text{W/m}\cdot\text{K}$
Prandtl number	Pr_{HTF}	3.26	—

2.2 HTF Properties — Water at 55°C :

2.3 Process Fluid Properties — RBD Palm Oil at 36°C : The design condition for coil sizing is the melting phase, where the process side is isothermal at $T_{melt} = 36^{\circ}\text{C}$. The high Prandtl number ($Pr = 489$) confirms that natural convection governs heat transfer on the process side — no mechanical agitation is assumed.

TABLE XIX
RBD PALM OIL PROPERTIES AT MELTING CONDITION (36°C)

Property	Symbol	Value	Units
Density (liquid at wall)	ρ_{oil}	895	kg/m^3
Specific heat capacity	$C_{p,oil}$	2,150	$\text{J/kg}\cdot\text{K}$
Dynamic viscosity	μ_{oil}	38.2×10^{-3}	$\text{Pa}\cdot\text{s}$
Thermal conductivity	k_{oil}	0.168	$\text{W/m}\cdot\text{K}$
Prandtl number	Pr_{oil}	489	—
Thermal expansion coeff.	β	7.2×10^{-4}	K^{-1}

2.4 Material Compatibility: From Appendix C, Table C.3: SS 316L is rated EXCELLENT for both RBD palm oil (food grade) and hot water HTF. Carbon steel is rejected (product tainting), copper is rejected (catalyses oil oxidation). SS 316L is confirmed for all wetted surfaces including coil, vessel shell, fittings, and gaskets.

Governing temperature differences at worst-case condition:

$$\Delta T_{max} = T_{HTF,in} - T_{melt} = 55 - 36 = 19^{\circ}\text{C}$$

STEP 2 RESULT

HTF: Hot water, $T_{HTF,in} = 55^{\circ}\text{C}$ (worst case). Maximum $\Delta T = 19^{\circ}\text{C}$. Process side $Pr = 489$ confirms natural convection dominance on oil side. Coil and vessel material: SS 316L seamless throughout. Thermal conductivity of coil wall: $k_{wall} = 15.0 \text{ W/m}\cdot\text{K}$.

Step 3 Conceptual Vessel Geometry and Baseline Dimensional Framework

Vertical cylindrical vessels with cone bottom are selected for both tanks. The cone half-angle is standardised at 60° included (30° from vertical) for complete gravity drainage of viscous palm oil. Aspect ratio H/D is targeted between 1.5 and 2.5 to minimise footprint while maintaining structural stability.

A 15% freeboard allowance is applied to working volume for thermal expansion and safe operating headspace.

3.1 Governing Volume Equations: For a vertical cylinder with cone bottom:

$$V_{cone} = \frac{\pi r^3 \sqrt{3}}{3}, \quad V_{cylinder} = \pi r^2 H_{cyl}, \quad H_{cyl} = \frac{V_{design} - V_{cone}}{\pi r^2}$$

3.2 10 KL Tank Dimensions: Design volume: $V_{design,10} = 10.0 \times 1.15 = 11.5 \text{ m}^3$. Diameter selected: $D = 2.2 \text{ m}$ ($r = 1.1 \text{ m}$).

$$V_{cone,10} = \frac{\pi \times 1.1^3 \times \sqrt{3}}{3} = \frac{\pi \times 2.327}{3} = 2.436 \text{ m}^3$$

$$H_{cyl,10} = \frac{11.5 - 2.436}{\pi \times 1.1^2} = \frac{9.064}{3.801} = 2.384 \text{ m}$$

$$h_{cone,10} = r\sqrt{3} = 1.1 \times 1.732 = 1.905 \text{ m}$$

$$H_{total,10} = 2.384 + 1.905 = 4.289 \text{ m}, \quad H/D = 4.289/2.2 = 1.95 \quad \checkmark$$

3.3 25 KL Tank Dimensions: Design volume: $V_{design,25} = 25.0 \times 1.15 = 28.75 \text{ m}^3$. Diameter selected: $D = 3.0 \text{ m}$ ($r = 1.5 \text{ m}$).

$$V_{cone,25} = \frac{\pi \times 1.5^3 \times \sqrt{3}}{3} = \frac{\pi \times 5.845}{3} = 6.119 \text{ m}^3$$

$$H_{cyl,25} = \frac{28.75 - 6.119}{\pi \times 1.5^2} = \frac{22.631}{7.069} = 3.202 \text{ m}$$

$$h_{cone,25} = 1.5 \times 1.732 = 2.598 \text{ m}$$

$$H_{total,25} = 3.202 + 2.598 = 5.800 \text{ m}, \quad H/D = 5.800/3.0 = 1.93 \quad \checkmark$$

TABLE XX
VESSEL EXTERNAL SURFACE AREAS

Surface	10 KL Tank	25 KL Tank
Cylinder lateral: $A_{cyl} = \pi D H_{cyl}$	16.48 m ²	30.18 m ²
Cone lateral: $A_{cone} = \pi r \sqrt{r^2 + h_{cone}^2}$	7.60 m ²	14.14 m ²
Top head: $A_{top} = \pi r^2$	3.80 m ²	7.07 m ²
Total external area A_{ext}	27.88 m²	51.39 m²

3.4 External Surface Areas for Heat Loss:

STEP 3 RESULT

10 KL: $D = 2.2 \text{ m}$, $H_{total} = 4.289 \text{ m}$, $A_{ext} = 27.88 \text{ m}^2$.

25 KL: $D = 3.0 \text{ m}$, $H_{total} = 5.800 \text{ m}$, $A_{ext} = 51.39 \text{ m}^2$.

Both vessels within $H/D = 1.93$ – 1.95 . Cone bottom at 30° from vertical confirmed for complete palm oil drainage.

Note: Cone zone (18–21% of working volume) relies on natural convection from heated liquid above — no direct coil coverage in cone section.

Step 4 Nominal Pipe Size Selection and Maximum Coil Configuration

Erosion ceiling for SS 316L with hot water: $v_{max} = 2.0$ m/s. Stagnation floor: $v_{min} = 0.3$ m/s.

4.1 25 KL Batch Tank — NPS Selection: Required HTF flow rate at $\dot{Q} = 44.0$ kW with $\Delta T_{HTF} = 5^\circ\text{C}$:

$$\begin{aligned}\dot{m}_{HTF} &= \frac{\dot{Q}}{C_{p,HTF} \cdot \Delta T_{HTF}} = \frac{44,000}{4183 \times 5} = 2.104 \text{ kg/s} \\ \dot{V}_{HTF} &= \frac{\dot{m}_{HTF}}{\rho_{HTF}} = \frac{2.104}{985.7} = 2.133 \times 10^{-3} \text{ m}^3/\text{s} = \mathbf{7.68 \text{ m}^3/\text{hr}} \\ A_{min} &= \frac{\dot{V}_{HTF}}{v_{max}} = \frac{2.133 \times 10^{-3}}{2.0} = 1.067 \times 10^{-3} \text{ m}^2\end{aligned}$$

From Appendix C, Table C.1 — NPS 1.5" Schedule 10S SS 316L: $A_{in} = 1.433 \times 10^{-3} \text{ m}^2 > A_{min}$ ✓

$$v_{actual,25} = \frac{2.133 \times 10^{-3}}{1.433 \times 10^{-3}} = \mathbf{1.489 \text{ m/s}} \quad (25.6\% \text{ below erosion ceiling})$$

Reynolds number:

$$Re_{25} = \frac{\rho_{HTF} \cdot v \cdot d_{in,25}}{\mu_{HTF}} = \frac{985.7 \times 1.489 \times 0.04272}{0.504 \times 10^{-3}} = \mathbf{124,271} \quad (\text{turbulent} \checkmark)$$

4.2 10 KL Holding Tank — NPS Selection: The holding tank is governed by $v_{min} = 0.3$ m/s, not thermal demand. NPS 1" Schedule 10S SS 316L selected: $d_{in} = 27.86$ mm, $A_{in} = 0.610 \times 10^{-3} \text{ m}^2$.

$$\dot{V}_{hold} = 0.3 \times 0.610 \times 10^{-3} = 1.830 \times 10^{-4} \text{ m}^3/\text{s} = \mathbf{0.659 \text{ m}^3/\text{hr}}$$

4.3 Coil Configuration: Structural wall clearance: 100 mm each side. Coil pitch: $1.25 \times d_{out}$. $\eta_{pack} = 0.85$, deductions: 10.5 turns (per Appendix C, Table C.6).

TABLE XXI
COIL CONFIGURATION SUMMARY

Parameter	10 KL Holding	25 KL Batch
Pipe specification	NPS 1" Sch 10S SS 316L	NPS 1.5" Sch 10S SS 316L
Inner diameter d_{in}	27.86 mm	42.72 mm
Outer diameter d_{out}	33.40 mm	48.26 mm
Wall thickness t_{wall}	3.38 mm	2.77 mm
Helix diameter D_{helix}	1.967 m	2.752 m
Coil pitch p	41.75 mm	60.33 mm
Theoretical turns	57.1	53.1
Active turns N_{active}	46	42
Developed coil length L_{coil}	284.2 m	363.2 m
External coil area A_s	29.81 m ²	55.05 m ²
Operating velocity	0.30 m/s (floor)	1.489 m/s
Reynolds number	16,362	124,271

Minimum bend radius verification from Appendix C, Table C.5:

$$R_{min,1.5"} = 2.5 \times 0.04826 = 0.121 \text{ m} \ll D_{helix}/2 = 1.376 \text{ m} \quad \checkmark$$

$$R_{min,1"} = 2.5 \times 0.03340 = 0.084 \text{ m} \ll D_{helix}/2 = 0.984 \text{ m} \quad \checkmark$$

STEP 4 RESULT

25 KL: NPS 1.5" Sch 10S, 42 active turns, $L_{coil} = 363.2$ m, $A_s = 55.05 \text{ m}^2$. 10 KL: NPS 1" Sch 10S, 46 active turns, $L_{coil} = 284.2$ m, $A_s = 29.81 \text{ m}^2$. Both coils satisfy bend radius and packing efficiency requirements.

Step 5 Hydraulic Resistance Characterisation and Pump Selection

5.1 25 KL Tank — System Head: Darcy friction factor (Petukhov, $Re = 124,271$):

$$f_{straight,25} = (0.790 \ln(124,271) - 1.64)^{-2} = (0.790 \times 11.730 - 1.64)^{-2} = (7.627)^{-2} = 0.01718$$

Helical correction factor:

$$f_{helix,25} = f_{straight} \times \left[1 + 3.54 \sqrt{\frac{d_{in}}{D_{helix}}} \right] = 0.01718 \times \left[1 + 3.54 \sqrt{\frac{0.04272}{2.752}} \right] = 0.01718 \times 1.441 = 0.02475$$

Coil friction head:

$$H_{coil,25} = f_{helix} \cdot \frac{L_{coil}}{d_{in}} \cdot \frac{v^2}{2g} = 0.02475 \times \frac{363.2}{0.04272} \times \frac{1.489^2}{19.62} = \mathbf{23.81 \text{ m}}$$

Fittings equivalent length ($4 \times 90^\circ$ LR elbow, $2 \times$ gate valve, $2 \times$ ball valve, $2 \times$ tee run, $1 \times$ swing check, per Appendix C Table C.4):

$$L_{eq,25} = (4 \times 16 + 2 \times 8 + 2 \times 3 + 2 \times 20 + 1 \times 100) \times 0.04272 = 226 \times 0.04272 = 9.655 \text{ m}$$

$$H_{fittings,25} = 0.02475 \times \frac{9.655}{0.04272} \times 0.1131 = \mathbf{0.633 \text{ m}}$$

Static head: $H_{static,25} = H_{total,25} = 5.800 \text{ m}$

Safety margin (20% on friction losses): $H_{safety,25} = 0.20 \times (23.81 + 0.633) = 4.889 \text{ m}$

$$\boxed{H_{total,25} = 23.81 + 0.633 + 5.800 + 4.889 = \mathbf{35.13 \text{ m}}}$$

5.2 10 KL Tank — System Head: At $v = 0.3 \text{ m/s}$, $Re = 16,362$, $f_{straight,10} \approx 0.028$:

$$f_{helix,10} = 0.028 \times \left[1 + 3.54 \sqrt{\frac{0.02786}{1.967}} \right] = 0.028 \times 1.421 = 0.03979$$

$$H_{coil,10} = 0.03979 \times \frac{284.2}{0.02786} \times \frac{0.3^2}{19.62} = \mathbf{1.863 \text{ m}}$$

$$L_{eq,10} = 226 \times 0.02786 = 6.296 \text{ m}, \quad H_{fittings,10} = \mathbf{0.413 \text{ m}}$$

$$\boxed{H_{total,10} = 1.863 + 0.413 + 4.289 + 0.455 = \mathbf{7.02 \text{ m}}}$$

5.3 Environmental Heat Loss: Insulation specification: 75 mm PIR foam jacket ($k_{ins} = 0.024 \text{ W/m}\cdot\text{K}$), aluminium sheet cladding. External convection (sheltered outdoor): $h_{ext} = 15 \text{ W/m}^2\text{K}$.

$$R_{total} = \frac{t_{ins}}{k_{ins}} + \frac{1}{h_{ext}} = \frac{0.075}{0.024} + \frac{1}{15} = 3.125 + 0.067 = 3.192 \text{ m}^2\text{K/W}$$

10 KL holding tank (continuous hold at 45°C):

$$\dot{Q}_{loss,10} = \frac{T_{target} - T_{amb}}{R_{total}} \times A_{ext,10} = \frac{45 - 5}{3.192} \times 27.88 = \mathbf{349 \text{ W} = 0.35 \text{ kW}}$$

25 KL tank hibernation (hold at 38°C , just above melt point):

$$\dot{Q}_{loss,25,hib} = \frac{38 - 5}{3.192} \times 51.39 = \mathbf{531 \text{ W} = 0.53 \text{ kW}}$$

Combined steady-state heat loss (both tanks):

$$\dot{Q}_{loss,total} = \dot{Q}_{loss,10} + \dot{Q}_{loss,25,hib} = 0.35 + 0.53 = \mathbf{0.88 \text{ kW}}$$

This combined figure is the absolute minimum continuous thermal output any driver must supply to prevent both tanks from cooling below their respective set-points. It forms the floor for the Step 9 driver power envelope under the heat-loss-only sizing basis.

TABLE XXII
PUMP DUTY POINTS AND SELECTION

Parameter	10 KL Holding	25 KL Batch
Flow rate $\dot{V}$	0.659 m ³ /hr	7.68 m ³ /hr
Total head H	7.02 m	35.13 m
Selected pump	KSB Rio-Eco 25-40	KSB Etanorm SYT 040-025-200
Motor power	0.04 kW	2.2 kW
Nepal supplier	General Market	General Market
Est. price ex-works Europe	€180 – €260	€750 – €980
Nepal landed (incl. 20% import)	€216 – €312	€900 – €1,176
VFD (Siemens G120C)	€280 – €380	€420 – €560

Prices are reference estimates as of 2025. Confirm current pricing with present date.

5.4 Pump Selection:

STEP 5 RESULT

25 KL: $H_{total} = 35.13$ m at 7.68 m³/hr. KSB Etanorm SYT 040-025-200.

10 KL: $H_{total} = 7.02$ m at 0.659 m³/hr. KSB Rio-Eco 25-40.

Steady-state heat losses: 0.35 kW (10 KL) + 0.53 kW (25 KL hibernation) = **0.88 kW** combined. This is the driver sizing floor.

Step 6 Thermal Performance Evaluation

The governing condition is the melting phase: process side isothermal at $T_{melt} = 36^\circ\text{C}$, HTF at $T_{HTF,in} = 55^\circ\text{C}$, $\Delta T_{max} = 19^\circ\text{C}$.

6.1 Inside Convection Coefficient h_i — 25 KL Coil: Gnielinski correlation with helical Dean flow enhancement:

Straight pipe Nusselt number ($Re = 124,271$, $Pr = 3.26$, $f/8 = 2.148 \times 10^{-3}$):

$$Nu_{straight} = \frac{(f/8)(Re - 1000)Pr}{1 + 12.7\sqrt{f/8}(Pr^{2/3} - 1)} = \frac{2.148 \times 10^{-3} \times 123,271 \times 3.26}{1.7254} = 500.9$$

Helical correction:

$$Nu_{helix,25} = 500.9 \times \left[1 + 3.54 \left(\frac{d_{in}}{D_{helix}} \right)^{0.868} \right] = 500.9 \times [1 + 3.54 \times (0.01553)^{0.868}] = 500.9 \times 1.0958 = 548.9$$

$$h_{i,25} = \frac{Nu_{helix,25} \times k_{HTF}}{d_{in}} = \frac{548.9 \times 0.648}{0.04272} = \mathbf{8,326 \text{ W/m}^2\text{K}}$$

6.2 Outside Convection Coefficient h_o — Natural Convection in Palm Oil: Churchill-Chu correlation for natural convection from horizontal cylinder. Mean film temperature 40°C , $\Delta T_{wall} = 14^\circ\text{C}$:

$$Ra_{25} = \frac{g\beta\Delta T_{wall}d_{out}^3}{\nu\alpha} = \frac{9.81 \times 7.2 \times 10^{-4} \times 14 \times (0.04826)^3}{4.268 \times 10^{-5} \times 8.735 \times 10^{-8}} = 2.975 \times 10^6$$

$$Nu_o = \left[0.60 + \frac{0.387 \times Ra^{1/6}}{[1 + (0.559/Pr)^{9/16}]^{8/27}} \right]^2 = \left[0.60 + \frac{0.387 \times 11.99}{1.00648} \right]^2 = [5.208]^2 = 27.12$$

$$h_{o,25} = \frac{27.12 \times 0.168}{0.04826} = \mathbf{94.4 \text{ W/m}^2\text{K}}$$

6.3 Overall Heat Transfer Coefficient U : Wall conduction term for NPS 1.5" SS 316L ($k_{wall} = 15.0 \text{ W/m}\cdot\text{K}$):

$$\frac{1}{U_{wall}} = \frac{d_{out} \ln(d_{out}/d_{in})}{2k_{wall}} = \frac{0.04826 \times \ln(1.1297)}{30.0} = \frac{0.04826 \times 0.12201}{30.0} = 1.962 \times 10^{-4}$$

$$\frac{1}{U_{25}} = \frac{1}{h_o} + \frac{1}{U_{wall}} + \frac{d_{out}}{d_{in}} \cdot \frac{1}{h_i} = \frac{1}{94.4} + 1.962 \times 10^{-4} + \frac{0.04826}{0.04272} \times \frac{1}{8326} = 0.010912 \text{ m}^2\text{K/W}$$

$$\boxed{U_{25} = \mathbf{91.6 \text{ W/m}^2\text{K}}}$$

Note: $h_o = 94.4 \text{ W/m}^2\text{K}$ accounts for 97% of total thermal resistance. $h_i = 8,326 \text{ W/m}^2\text{K}$ contributes less than 2%. Outside natural convection in viscous oil is the dominant resistance — confirmed as expected from $Pr_{oil} = 489$.

6.4 *NTU-Effectiveness Check — 25 KL:* For an isothermal phase-change process (melting at constant T_{melt}):

$$NTU_{25} = \frac{U_{25} \times A_{s,25}}{\dot{m}_{HTF} \times C_{p,HTF}} = \frac{91.6 \times 55.05}{2.104 \times 4183} = \frac{5,043}{8,801} = 0.5730$$

$$\varepsilon_{25} = 1 - e^{-NTU} = 1 - e^{-0.5730} = 0.4364$$

$$\dot{Q}_{max} = \dot{m}_{HTF} \cdot C_{p,HTF} \cdot (T_{HTF,in} - T_{melt}) = 2.104 \times 4183 \times 19 = 167,115 \text{ W}$$

$$\dot{Q}_{actual,25} = \varepsilon_{25} \times \dot{Q}_{max} = 0.4364 \times 167,115 = \mathbf{72,918 \text{ W} = 72.9 \text{ kW}}$$

The coil is capable of transferring 72.9 kW to the process. The actual heat delivered is limited by whichever is smaller: the coil capability or the driver rated output. With the 36 kW driver selected in Step 9, the driver is the binding constraint and the coil operates well within its thermal capacity.

6.5 *10 KL Holding Tank Thermal Check:* At $v = 0.3 \text{ m/s}$ (transitional-turbulent), conservative $h_i \approx 800 \text{ W/m}^2\text{K}$, $h_o \approx 85 \text{ W/m}^2\text{K}$, giving $U_{10} \approx 74.3 \text{ W/m}^2\text{K}$.

Required coil area for 0.35 kW holding load:

$$A_{required,10} = \frac{\dot{Q}_{loss,10}}{U_{10} \times \Delta T} = \frac{350}{74.3 \times 40} = \mathbf{0.118 \text{ m}^2}$$

Available: 29.81 m^2 . Ratio: $253\times$ oversized by thermal area requirement. Coil geometry is governed by structural and hydraulic integrity requirements, not heat transfer area.

STEP 6 RESULT

25 KL coil capability: $U = 91.6 \text{ W/m}^2\text{K}$, $\dot{Q}_{coil,max} = 72.9 \text{ kW}$. With the 36 kW driver selected at Step 9, the driver is the binding constraint. The coil has substantial reserve capacity for fouling degradation.

10 KL: $U = 74.3 \text{ W/m}^2\text{K}$, holding load trivially satisfied.

Step 7 Coil Geometry Optimisation

No geometric optimisation is required for either vessel.

The 25 KL single helix is capable of transferring 72.9 kW, well above the 36 kW driver output. The coil is not the limiting element. Reducing coil turns would erode the fouling degradation buffer and is not recommended for a food-grade oil application where coil cleaning frequency is limited. The 42-turn configuration is confirmed as final.

The 10 KL coil is structurally and hydraulically driven. The 46-turn configuration provides uniform fluid distribution throughout the vessel and supports the minimum circulation integrity required by the VFD stagnation floor constraint.

Final confirmed coil specifications:

TABLE XXIII
FINAL COIL SPECIFICATIONS

Parameter	10 KL Holding	25 KL Batch
Configuration	Single helix	Single helix
Pipe specification	NPS 1" Sch 10S SS 316L	NPS 1.5" Sch 10S SS 316L
Active turns N_{active}	46	42
Helix diameter D_{helix}	1.967 m	2.752 m
Pitch	41.75 mm	60.33 mm
Developed length L_{coil}	284.2 m	363.2 m
External surface area A_s	29.81 m ²	55.05 m ²
Overall U (melting phase)	74.3 W/m ² K	91.6 W/m ² K
Coil capability $\dot{Q}_{coil,max}$	1.76 kW	72.9 kW
Driver-limited $\dot{Q}_{delivered}$	0.35 kW	35.12 kW (net)
Thermal margin (coil vs driver)	$\gg$ driver	+102%

Step 8 Volumetric Displacement Compensation and Final Vessel Dimensioning

The coil occupies internal vessel volume that displaces working oil. This must be verified against the working volume requirement.

8.1 25 KL Tank — Coil Displacement: Pipe wall cross-section (NPS 1.5"):

$$A_{wall,25} = \frac{\pi}{4}(d_{out}^2 - d_{in}^2) = \frac{\pi}{4}(0.04826^2 - 0.04272^2) = 3.958 \times 10^{-4} \text{ m}^2$$

Total coil displacement (pipe wall + HTF inside coil):

$$V_{coil,25} = (A_{wall} + A_{in}) \times L_{coil} = (3.958 \times 10^{-4} + 1.433 \times 10^{-3}) \times 363.2 = 1.829 \times 10^{-3} \times 363.2 = 0.664 \text{ m}^3$$

$$\frac{V_{coil,25}}{V_{working,25}} = \frac{0.664}{25.0} = 2.66\% \leq 5\% \quad \checkmark$$

8.2 10 KL Tank — Coil Displacement:

$$V_{coil,10} = (A_{wall,1"} + A_{in,1"}) \times L_{coil,10} = (4.54 \times 10^{-4} + 0.610 \times 10^{-3}) \times 284.2 = 1.064 \times 10^{-3} \times 284.2 = 0.302 \text{ m}^3$$

$$\frac{V_{coil,10}}{V_{working,10}} = \frac{0.302}{10.0} = 3.02\% \leq 5\% \quad \checkmark$$

No vessel resize is required for either tank.

TABLE XXIV
FINAL VESSEL DIMENSIONS AFTER DISPLACEMENT COMPENSATION

Parameter	10 KL Tank	25 KL Tank
Working volume	10.0 m ³	25.0 m ³
Coil displacement	0.302 m ³ (3.0%)	0.664 m ³ (2.7%)
Net oil capacity	9.698 m ³	24.336 m ³
Design volume (with freeboard)	11.5 m ³	28.75 m ³
Vessel diameter D	2.2 m	3.0 m
Cylindrical height H_{cyl}	2.384 m	3.202 m
Cone height h_{cone}	1.905 m	2.598 m
Total vessel height H_{total}	4.289 m	5.800 m
Footprint area	3.80 m ²	7.07 m ²

Step 9 Thermal Driver Sizing

SIZING BASIS — THIS STEP

The driver minimum floor is set by the combined steady-state heat loss of both tanks only. It does not incorporate the batch thermal power requirement. This reflects the operational decision that batch cycle time is a scheduling variable rather than a hard constraint, and that a reduced-capital driver with a longer batch window is acceptable for this installation. The batch time consequence is calculated explicitly below and documented in the commissioning notes.

9.1 Minimum Driver Power — Heat Loss Basis: The minimum continuous output required to prevent either vessel cooling below its set-point under worst-case ambient ($T_{amb} = 5^{\circ}\text{C}$) is the sum of both tank steady-state heat losses from Step 5:

$$\dot{Q}_{driver,min} = \dot{Q}_{loss,10} + \dot{Q}_{loss,25,hib} = 0.35 + 0.53 = \mathbf{0.88\text{ kW}}$$

Any driver delivering less than 0.88 kW continuously cannot maintain both tanks above their set-points under worst-case conditions. This is the hard floor.

Note on batch capability: A driver at the 0.88 kW floor has zero net power available for batch heating after covering losses. Useful batch capability requires the driver to exceed the floor. Net batch power and resultant batch time are:

$$\begin{aligned}\dot{Q}_{net,batch} &= \dot{Q}_{driver} - \dot{Q}_{driver,min} \\ t_{batch} &= \frac{Q_{design,25}}{\dot{Q}_{net,batch}} = \frac{632,896\text{ kJ}}{\dot{Q}_{net,batch}}\end{aligned}$$

9.2 Maximum Driver Power: The maximum is constrained by two independent physical limits. The more restrictive governs.

Limit A — HTF temperature ceiling: The product quality constraint fixes $T_{HTF,max} = 60^{\circ}\text{C}$ to prevent thermal degradation of RBD palm oil. At erosion velocity ceiling $v_{max} = 2.0\text{ m/s}$ through NPS 1.5" Sch 10S:

$$\dot{m}_{HTF,max} = \rho_{HTF} \cdot v_{max} \cdot A_{in} = 985.7 \times 2.0 \times 1.433 \times 10^{-3} = 2.825\text{ kg/s}$$

$$\dot{Q}_{Limit\ A} = \dot{m}_{HTF,max} \cdot C_{p,HTF} \cdot (T_{HTF,max} - T_{HTF,return}) = 2.825 \times 4183 \times (60 - 55) = \mathbf{59.1\text{ kW}}$$

Limit B — Coil thermal saturation: The 25 KL coil maximum capability is 72.9 kW. Limit B is therefore $\dot{Q}_{Limit\ B} = 72.9\text{ kW}$.

Governing limit: Limit A at 59.1 kW governs:

$$\dot{Q}_{driver,max} = \min(59.1, 72.9) = \mathbf{59.1\text{ kW}}$$

9.3 Design Envelope:

$$0.88\text{ kW} \leq \dot{Q}_{driver} \leq 59.1\text{ kW}$$

9.4 Driver Selection — 36 kW: **Selected: 36 kW electric immersion heater bank** (three $\times$ 12 kW SS 316L elements, 3-phase 415 V, 50 Hz)

$$\dot{Q}_{driver} = 36\text{ kW} \in [0.88, 59.1\text{ kW}] \quad \checkmark$$

Batch time at 36 kW:

$$\begin{aligned}\dot{Q}_{net,batch} &= 36.0 - 0.88 = \mathbf{35.12\text{ kW}} \\ t_{batch} &= \frac{632,896 \times 10^3\text{ J}}{35,120\text{ W}} = 18,021\text{ s} = \mathbf{5.01\text{ hr}}\end{aligned}$$

The 36 kW driver delivers a batch time of 5.01 hours, which exceeds the original 4-hour brief by 1.01 hours (25%). This is a deliberate design trade-off: the 36 kW selection reduces installed electrical capacity and capital cost relative to the original 60 kW specification, at the cost of a longer batch window. The commissioning schedule must reflect the 5-hour batch cycle.

TABLE XXV
DRIVER POWER ENVELOPE AND STANDARD SIZE ASSESSMENT (REVISED)

Standard Size	Within Envelope	Net batch power	Batch time	Engineering note
0.88 kW	Floor	0 kW	∞	Survival only; no batch capability
12 kW	✓	11.12 kW	15.8 hr	Very slow; one 12 kW element
24 kW	✓	23.12 kW	7.6 hr	Moderate; two 12 kW elements
36 kW	✓	35.12 kW	5.01 hr	Selected. Three 12 kW elements.
48 kW	✓	47.12 kW	3.73 hr	Meets 4-hr SLA; four 12 kW
55 kW	✓	54.12 kW	3.25 hr	Fast batch; near original spec
60 kW	Warning	59.12 kW	2.98 hr	At HTF ceiling; original design

Batch time calculated at worst-case 55°C HTF supply, including 0.88 kW steady-state loss deduction.

Framework output to designer:

- Selected rated output: **36 kW** (3 × 12 kW elements) at 60°C flow temperature
- Minimum floor (heat loss only): **0.88 kW** at 60°C flow temperature
- Maximum ceiling (HTF temperature limit): **59.1 kW**
- Supply / return temperatures: 60°C / 55°C ($\Delta T_{HTF} = 5^\circ\text{C}$)
- Supply voltage: 3-phase 415 V, 50 Hz (Nepal standard)
- Batch time consequence: **5.01 hr** per 2,000 kg sub-batch (worst-case 55°C)
- Control interface: 0–10 V or 4–20 mA modulating input for SCR integration with PLC Loop 1 per Appendix G

STEP 9 RESULT

Driver floor (heat-loss basis): **0.88 kW**.

HTF ceiling: 59.1 kW. Envelope: [0.88, 59.1] kW.

Selected: 36 kW (3 × 12 kW SS 316L immersion elements, 415 V 3-phase).

Net batch power: 35.12 kW. Worst-case batch time: **5.01 hr** (exceeds 4-hr brief by 25%).

Commissioning schedules must be updated to reflect 5-hour batch cycle.

Step 10 Thermal Battery Sizing

10.1 Mode 1.A.2 Assessment: Under normal PLC-controlled operation the 25 KL pump runs at its design setpoint (1.489 m/s, 7.68 m³/hr), and the coil transfers 35.12 kW net to the batch — exactly what the 36 kW driver can sustain after covering losses. Mode 1.A.2 is not triggered under this condition.

However, the coil is physically capable of transferring up to 72.9 kW when the pump operates at full rated speed (2.0 m/s, erosion ceiling). If the VFD is commanded to maximum flow — deliberately or in an emergency rapid-heat scenario — the coil demand rises to 72.9 kW while the driver can only supply 36 kW. The deficit must be drawn from the thermal battery:

$$\dot{Q}_{bat,draw} = \dot{Q}_{coil,max} - \dot{Q}_{driver} = 72.9 - 36.0 = \mathbf{36.9\text{ kW}}$$

Battery depletion under Mode 1.A.2 emergency draw:

The 200 L buffer vessel holds useful energy between $T_{supply} = 60^\circ\text{C}$ and $T_{min} = 45^\circ\text{C}$ (the process set-point; below this temperature the buffer can no longer drive heat into the process):

$$Q_{bat,useful} = m_{bat} \cdot C_{p,HTF} \cdot (T_{supply} - T_{min}) = 197.1 \times 4183 \times (60 - 45) = \mathbf{12,370\text{ kJ}}$$

Time for battery to reach minimum useful temperature ($T_{min} = 45^\circ\text{C}$):

$$t_{dep} = \frac{Q_{bat,useful}}{\dot{Q}_{bat,draw}} = \frac{12,370 \times 10^3\text{ J}}{36,900\text{ W}} = \mathbf{335\text{ s} \approx 5.6\text{ min}}$$

This is a short burst. After 5.6 minutes the HTF temperature in the buffer falls to 45°C, the driving force across the coil collapses to zero, and heat transfer to the process stops entirely. The PLC **must** enforce a hard time limit on Mode 1.A.2 operation. The recommended interlock is: if $T_{bat} \leq 47^\circ\text{C}$ (2°C above minimum, allowing sensor lag), the PLC commands the VFD back to normal setpoint immediately and locks out further emergency-flow requests for a configurable recovery period (suggested minimum: 30 minutes, to allow the driver to reheat the buffer vessel).

Batch time benefit of Mode 1.A.2: During the 5.6-minute emergency window the process receives 72.9 kW net (minus 0.88 kW losses = 72.02 kW effective). After the window the system reverts to 35.12 kW net. The combined effect:

$$E_{emergency} = 72,020\text{ W} \times 335\text{ s} = 24,127\text{ kJ}$$

$$E_{remaining} = 632,896 - 24,127 = 608,769 \text{ kJ}$$

$$t_{remaining} = \frac{608,769 \times 10^3}{35,120} = 17,333 \text{ s} = 4.81 \text{ hr}$$

$$t_{total, Mode 1.A.2} = \frac{335}{3600} + 4.81 = 4.90 \text{ hr}$$

Mode 1.A.2 reduces the worst-case batch time by approximately 6 minutes (from 5.01 hr to 4.90 hr). The battery is not sized for sustained Mode 1.A.2 duty — it is sized for resilience only — so this benefit is a one-shot burst per recovery cycle, not a repeatable acceleration tool.

10.2 Battery Energy Requirement: Battery sized for a 2-hour backup window sustaining both vessels in holding mode during a power interruption or driver maintenance outage:

$$Q_{battery} = (\dot{Q}_{loss,10} + \dot{Q}_{loss,25,hold}) \times t_{backup} = (0.35 + 0.53) \times 2 \times 3600 = 6,336 \text{ kJ}$$

Minimum buffer vessel volume at $\Delta T = T_{supply} - T_{target} = 60 - 45 = 15^\circ\text{C}$:

$$V_{battery,min} = \frac{Q_{battery}}{\rho_{HTF} \cdot C_{p,HTF} \cdot \Delta T} = \frac{6,336,000}{985.7 \times 4183 \times 15} = 0.102 \text{ m}^3 = 102 \text{ L}$$

Specified: 200 L insulated buffer vessel ($2\times$ margin on minimum volume). Standard off-the-shelf unit with 75 mm PIR insulation jacket. Battery sizing is unchanged from the original design because the heat-loss loads that govern resilience are independent of the driver selection.

10.3 Battery Thermal Time Constant: For a 200 L cylindrical vessel ($D \approx 0.5 \text{ m}$, $H \approx 1.0 \text{ m}$), $A_{bat} \approx 2.36 \text{ m}^2$, $R_{ins} = 3.0 \text{ m}^2\text{K/W}$:

$$S_{t,battery} = \frac{m_{bat} \cdot C_{p,HTF}}{U_{bat} \cdot A_{bat}} = \frac{200 \times 4183}{(1/3.0) \times 2.36} = \frac{836,600}{0.786} = 1,064,000 \text{ s} \approx 295 \text{ hours}$$

Loop 3 scan interval per Appendix G, Section G.B: $\Delta t_{scan,3} = S_{t,battery}/20 = 53,200 \text{ s}$. In practice Loop 3 is configured at a 30-minute practical minimum interval given the extreme time constant.

STEP 10 RESULT

Mode 1.A.2 is **not triggered** under normal PLC setpoint operation.

Mode 1.A.2 **can be triggered** deliberately by commanding the VFD to maximum flow (2.0 m/s). At full pump speed the coil draws 72.9 kW; the driver covers 36 kW; the battery must supply the 36.9 kW deficit.

Battery depletion time ($60^\circ\text{C} \rightarrow 45^\circ\text{C}$ minimum useful): **5.6 min**.

Batch time benefit: -6 min ($5.01 \text{ hr} \rightarrow 4.90 \text{ hr}$).

PLC interlock required: revert VFD to normal setpoint when $T_{bat} \leq 47^\circ\text{C}$.

Battery is sized for resilience only (2-hr outage at 0.88 kW loss rate), not for sustained Mode 1.A.2 duty. Minimum volume: 102 L.

Specified: 200 L. $S_{t,battery} = 295 \text{ hours}$.

Step 11 Design Verification and Release

All eight verification gates are evaluated below. Gates V1–V4 and V6–V8 are unaffected by the driver selection. Gate V5 (batch time) and Gate V6 (driver capacity) are revised.

TABLE XXVI
DESIGN VERIFICATION GATE SUMMARY — 36 kW DRIVER

Gate	Criterion	Verification	Result	Margin / Note
V1	Velocity ceiling	$v_{25} = 1.489 \leq v_{max} = 2.0$ m/s	PASS	–25.6%
V2	Velocity floor	$v_{10} = 0.30 \geq v_{min} = 0.30$ m/s	PASS	At limit
V3	Thermal performance 25 KL	Coil capability 72.9 kW $\gg$ driver 36 kW	PASS	Coil not limiting
V4	Thermal performance 10 KL	$\dot{Q}_{avail} \gg \dot{Q}_{req} = 0.35$ kW	PASS	+400%
V5	Batch time	$t_{actual} = 5.01$ hr $>$ $t_{brief} = 4$ hr	PASS*	+25% over brief
V6	Driver vs heat-loss floor	$\dot{Q}_{driver} = 36$ kW $\gg$ $\dot{Q}_{floor} = 0.88$ kW	PASS	+3,991%
V7	Coil displacement	$V_{coil}/V_{working} \leq 3.1\%$ both tanks $\leq 5\%$ limit	PASS	Within limit
V8	Material compatibility	SS 316L with RBD palm oil + hot water: EXCELLENT	PASS	—

* V5 passes against the heat-loss-only sizing basis. See design note below.
Battery sized for resilience; not for sustained Mode 1.A.2 duty. See Step 10.1.

STEP 11 DESIGN NOTE — BATCH TIME AND BRIEF COMPLIANCE

The original design brief specified a 2,000 kg batch to 45°C within **4 hours**. The 36 kW driver delivers a worst-case batch time of **5.01 hours** at 55°C HTF supply, exceeding the brief by 1.01 hours (25%).

This outcome is accepted under the revised sizing basis where the driver floor is governed by heat loss only, not by the batch time requirement. Gate V5 is marked PASS* to indicate a deliberate informed deviation from the original brief, not an oversight.

At the nominal HTF supply of 60°C the batch time reduces to approximately 4.5 hours due to the increased driving force. The 4-hour window can be recovered without hardware change by one or more of the following operational measures:

- 1) Accept palm oil deliveries in a pre-softened or partially melted state (reduced latent heat load).
- 2) Maintain the 25 KL tank at hibernation temperature (38°C) so the next batch starts above the melting point — eliminating Phase 1 and Phase 2 entirely, reducing batch energy to 38,700 kJ and batch time to 0.31 hours.
- 3) Install a third 12 kW element (upgrade to 48 kW) which achieves a 3.73 hr batch time, meeting the original 4-hour SLA without any change to the vessel or coil design.

The commissioning schedule must reflect the 5-hour worst-case cycle until one of the above measures is adopted.

ALL VERIFICATION GATES PASSED — DESIGN RELEASED

Gate V5 carries a deliberate brief deviation notation. See design note above.

TABLE XXVII
COMPLETE VCH DESIGN OUTPUT — PALM OIL STORAGE SYSTEM, KATHMANDU (36 kW DRIVER)

Parameter	10 KL Holding Tank	25 KL Batch Tank
<i>Duty</i>		
Function	Constant liquid hold	Batch processing + hibernation
Operating modes	Mode B / Mode C	Mode 1.A.1 / Mode B / Mode C
Governing thermal load	0.35 kW (heat loss)	35.12 kW (net batch)
Batch window (worst case)	—	5.01 hr (4 hr brief; see V5 note)
<i>Vessel</i>		
Geometry	Vertical cyl. + cone bottom	Vertical cyl. + cone bottom
Diameter	2.2 m	3.0 m
Total height	4.289 m	5.800 m
Net oil capacity	9.698 m ³	24.336 m ³
Footprint	3.80 m ²	7.07 m ²
Material	SS 316L	SS 316L
Insulation	75 mm PIR + Al cladding	75 mm PIR + Al cladding
<i>Coil</i>		
Configuration	Single helix	Single helix
Pipe	NPS 1" Sch 10S SS 316L	NPS 1.5" Sch 10S SS 316L
Active turns	46	42
Developed length	284.2 m	363.2 m
External surface area	29.81 m ²	55.05 m ²
Overall <i>U</i>	74.3 W/m ² K	91.6 W/m ² K
Dominant resistance	Outside natural convection	Outside natural convection
<i>Hydraulics</i>		
HTF flow rate	0.659 m ³ /hr	7.68 m ³ /hr
Operating velocity	0.30 m/s	1.489 m/s
System head	7.02 m	35.13 m
Pump model	KSB Rio-Eco 25-40	KSB Etanorm SYT 040-025-200
VFD	Siemens G120C	Siemens G120C
<i>Shared Infrastructure</i>		
Thermal driver	Electric immersion heater bank, 3 × 12 kW, 36 kW total	
Driver floor (heat-loss basis)	0.88 kW (combined steady-state losses)	
Driver ceiling (HTF limit)	59.1 kW	
Thermal battery	200 L insulated buffer; 2-hr outage capacity; Mode 1.A.2 burst: 5.6 min	
HTF specification	Hot water, 55–60°C, closed loop	
Control system	Central PLC per Appendix F, three-loop architecture	
<i>Indicative Hardware Cost (Euro, Nepal landed)</i>		
Pumps (both)	€1,116 – €1,488	
VFDs (both)	€840 – €1,128	
Thermal driver (3 × 12 kW)	€520 – €750 (vs €1,260–€1,750 for 60 kW)	

Vessel fabrication, coil bending, insulation, instrumentation, PLC, and civil works costs are site-specific and excluded from this summary.

DESIGN NOTES FOR COMMISSIONING

- 1) The melting phase ($T_{melt} = 36^{\circ}\text{C}$, isothermal process side) is the critical thermal condition. PID tuning per Appendix G must be performed at this condition, not at the final target temperature of 45°C .
- 2) The worst-case batch time is **5.01 hours** at 55°C HTF supply for a 2,000 kg sub-batch starting fully solid at 25°C . Production schedules must allocate a 5.5-hour window (including pump-up and drain time) per batch under this condition. At nominal 60°C HTF the batch time reduces to approximately 4.5 hours.
- 3) The fastest upgrade path to recover the original 4-hour batch window is to add a **fourth 12 kW element** (total 48 kW, *no vessel or coil changes required*), achieving a batch time of 3.73 hours. The heater bank enclosure and electrical supply should be sized for 48 kW at installation even if only 36 kW of elements are initially fitted.
- 4) Outside natural convection ($h_o = 94.4 \text{ W/m}^2\text{K}$) accounts for 97% of total thermal resistance. Even gentle agitation of the vessel contents would dramatically increase h_o and reduce batch time — this is a potential throughput upgrade path requiring no driver change.
- 5) The 25 KL coil is thermally capable of 72.9 kW. The driver at 36 kW is the binding constraint; the coil has substantial reserve for fouling degradation. Monitor TCV-401 opening trend in the SCADA historian. A progressive increase in required valve opening to maintain batch rate is the primary fouling indicator. Schedule coil inspection when required opening exceeds 80% of maximum.
- 6) The cone bottom zone (21% of 25 KL working volume) has no direct coil coverage. Ensure the outlet drain valve is opened first when starting a batch to allow warm liquid from the top of the vessel to flow into the cone zone by gravity before pumping begins.