

Thesis Report – Graduation Internship

Quantum Imaging with Undetected Photons: Enhanced Image processing & User Interface

Author: Samer Saftawi
Study program: Bachelor Applied Computer Science
Student number: 541642

Supervisor: Dr. D. Polishchuk
Study Coach: Dr. A. Khan
Research group: Applied Nanotechnology
Project: Quantum Delta NL
Institution: Saxion University of Applied Sciences

Internship period: 02.02.2026 – 03.07.2026

Foreword

As a student at Saxion – University of Applied Sciences, this project will be a graduation internship that serves as the final step in completing the Bachelor of Applied Computer Science program.

Quantum Photonics is an emerging field that explores the quantum properties of light and their applications in various technologies, including quantum imaging. Quantum Imaging with Undetected Photons (QIUP) is an advanced technique that allows for imaging objects without directly detecting the photons that interact with them, leveraging quantum entanglement and interference effects.

The Applied Nanotechnology (ANT) research group at Saxion is actively involved in advancing quantum photonics technologies, including QIUP. This project will focus on enhancing the image processing and developing a user-friendly interface for the QIUP system, aiming to improve the quality of the images produced and make the technology more accessible to researchers and practitioners in the field.

Summary

The aim of this report is to make Quantum technologies more accessible to a wider audience by contributing to the advancement of quantum imaging technology. Fast Fourier Transform (FFT), an advanced image processing method, was used to enhance the quality of images produced by QIUP. Additionally, a user-friendly interface was developed to allow researchers and practitioners to easily interact with the QIUP system, facilitating the adoption and application of this cutting-edge technology in various fields.

— **TO DO** —: Results, Conclusions, and Recommendations.

Contents

1	Introduction	6
1.1	Background of the Assignment	6
1.2	The Setup	6
1.3	Problem Definition and Objectives	8
1.4	Scope of Work	9
1.5	Approach & Methodology	10
1.6	Outline of the Report	11
2	Analysis / Specifications	13
2.1	Physical Specifications	13
2.2	Hardware Specifications	14
2.2.1	Piezoelectric Stage	14
2.2.2	CMOS Camera	15
2.3	Software Specifications	15
2.4	Requirements	15
3	Functional Design	16
4	Technical Design	17
5	Realisation	18
6	Testing	19
7	Conclusions and Recommendations	20
7.1	Conclusions	20
7.2	Recommendations	20

Abbreviations

QIUP Quantum Imaging with Undetected Photons

ANT Applied Nanotechnology

FFT Fast Fourier Transform

TLC Talent & Learning Center

PPLN Periodically Poled Lithium Niobate

CMOS Complementary Metal-Oxide-Semiconductor

SPDC Spontaneous Parametric Down-Conversion

CCD Charged Coupled Device

GUI Graphical User Interface

KPZ101 KCube Piezo Controller

KSG101 KCube Strain Gauge Meter

List of Figures and Tables

List of Figures

1	Demonstrational Setup and Schematic.	7
2	Old Showcase of the QIUP Setup.	8

List of Tables

1 Introduction

This chapter provides an introduction to the project, explains the background and context of the assignment and also describes the setup of the demonstrational platform for QIUP at the Talent & Learning Center (TLC) lab within the ANT research group.

1.1 Background of the Assignment

As part of the Quantum Delta program, this project aims to accelerate the development and adoption of quantum technologies [1]. A primary challenge in this field is the non-intuitive nature of quantum properties such as entanglement and indistinguishability, which is being leveraged in QIUP to enable imaging without directly interacting with the photon that detects the sample.


The demonstrational setup for QIUP at the TLC lab within the ANT research group provides a platform for exploring and enhancing this technology.

1.2 The Setup


The experimental implementation of the quantum imager is shown in Figure 1. The system consists of:

- Continuous-wave pump laser
- Periodically Poled Lithium Niobate (PPLN) nonlinear crystal
- Dichroic beam splitter
- Piezoelectric-stage connected with a mirror
- Thorlabs Zelux Complementary Metal-Oxide-Semiconductor (CMOS) camera

Inside the PPLN crystal, Spontaneous Parametric Down-Conversion (SPDC) splits pump photons from a continuous-wave laser with frequency of 532 nm into signal (visible) photons with a frequency of 810 nm and idler (infrared) photons with a frequency of 1550 nm (telecommunication). The idler interacts with the object, while the signal does not. Upon recombination, interference occurs and is recorded by the CMOS camera.



(a) Top-Down view on demonstrational setup at Saxion.



(b) Schematic of demonstrational setups functionality.

Figure 1: Demonstrational Setup and Schematic.

The system relies on the principle of induced coherence, utilizing a nonlinear interferometer.

As detailed in the schematic (Figure 1b), a continuous wave pump laser is directed into a nonlinear crystal specifically, a PPLN crystal. Through SPDC, the pump photon splits into a signal photon (visible spectrum) and an idler photon (infrared). A dichroic beam splitter separates these paths: the visible signal is reflected by a reference mirror (Mirror 1), while the infrared idler interacts with the target object before being reflected by Mirror 2. The idler photons that pass through the object contain spatial information about its absorption or phase profile. When the idler and signal beams recombine at the

crystal, quantum interference modulates the intensity of the signal beam based on the idler's path information. Consequently, the image of the object which was only "seen" by the infrared light is transferred to the visible spectrum and detected by the Charged Coupled Device (CCD) camera. The physical realization of this schematic is shown in Figure 1a. The setup is constructed on an optical breadboard to ensure stability. The pump source directs the beam through conditioning optics towards the central crystal mount. The detection module utilizes a Thorlabs Zelux CMOS camera to capture the interference patterns.

1.3 Problem Definition and Objectives

Problem Definition

The experimental setup for QIUP serves as a powerful proof-of-concept for mid-infrared imaging. However, the current setup has limitations in terms of image quality and user accessibility. There are two main software tools by Thorlabs that are used to control the setup and process the images, Thorcam [2] (left part of the figure 2) and Kinesis [3] (right part of the figure 2), which are used for camera and piezoelectric actuator control, but they are not optimized for QIUP applications or any image processing. Using this approach is rather unintuitive and requires a lot of manual work to only get gray scale images, which do not have the best quality as illustrated in Figure 2.




Figure 2: Old Showcase of the QIUP Setup.

Objectives

The main objective of this project is to transform the current laboratory setup into a robust, automated, and user-friendly demonstrator platform for QIUP technology demon-

stration, which can be divided into the following sub-objectives:

1. **Advanced Image Processing:** Captured images will be processed using advanced techniques, such as FFT, to enhance image quality and extract more detailed information like visibility, contrast and phase from the raw data.
2. **Hardware Automation System:** The current use of multiple software tools for controlling the hardware components will be streamlined into a single, cohesive automation system that can manage all aspects of the QIUP setup, including camera control, piezoelectric actuators, data acquisition and image processing.
3. **User Interface Development:** A user-friendly interface will be developed to allow researchers and practitioners to easily interact with the QIUP system, facilitating the adoption and application of this cutting-edge technology in various fields. The interface will provide intuitive controls for operating the hardware, visualizing the processed images, and accessing the key metrics visibility and contrast phase.

1.4 Scope of Work

To consider this project successful, the expected technical results have been categorized using the MoSCoW method:

Must Have:

- **Hardware Automation System:** A robust Python-based control script capable of communicating with and reliably driving both the Thorlabs CMOS camera and the piezoelectric stage.
- **Image Processing Core:** A functional FFT-based algorithm capable of near real-time reconstruction of visibility, contrast, and phase images from the raw sensor data.

Should Have:

- **Functional Graphical User Interface (GUI):** An intuitive graphical user interface that allows the operator to control the hardware, acquire live images, and display the reconstructed quantum interference patterns.
- **Performance Optimization:** Validated and optimized code execution that ensures the imaging performance is fast and smooth enough for live audience demonstrations.

- **Advanced camera settings:** The ability to adjust camera settings such as exposure time, gain, and frame rate through the software interface to optimize image quality under different conditions.

Could Have:

- **Advanced GUI Capabilities:** Additional features in the software, such as one-click calibration presets, advanced data visualization tweaks, or the ability to export/upload acquired data.
- **New Samples:** For demonstration purposes, new samples (transparent or opaque) with creative visualizations could be introduced to better showcase the capabilities of QIUP technology .

Won't Have:

- **Hardware Upgrades:** The physical integration of new hardware components not present in the current setup.

1.5 Approach & Methodology

This project combines software development with experimental physics validation. To manage the iterative nature of development alongside research and hardware integration, the project utilizes the Scrum framework. This allows for flexibility while ensuring continuous delivery of features and frequent validation against the physical setup.

Development Process

The project is divided into sprints lasting 1–4 weeks. This duration provides a balance between sufficient development time and frequent feedback loops. At the end of each sprint, the results are reviewed and the subsequent sprint is adjusted based on the progress of the QIUP system integration.

System Architecture and Tools

The software is developed as a modular system using the following tools:

- **Language & IDE:** Python is used for the entire system development within the Visual Studio Code environment.

- **Hardware Control:** Integration with the Thorlabs piezoelectric stage with corresponding Strain Gauge Meter (KPZ101/KSG101) and CMOS camera is handled via the Kinesis .NET API and ThorCam SDK.
- **Data Management:** Project assets are saved in a secure directory on the ANT internal network, ensuring compliance, data integrity, and unified access.

FFT-Based Image Processing

For a QIUP demonstrator, the most important information is not found in a single static image, but rather in how the image changes. Because the system utilizes an interferometer with a scanning piezoelectric stage, we expect a very specific physical effect: as the optical path length changes, the light intensity at any given point will oscillate sinusoidally, creating moving interference fringes. [4]

To capture and translate these interferometric effects into a clear image, this project implements a pixel-wise FFT approach. Rather than analyzing the spatial patterns of a single frame, the software treats every individual pixel on the camera as an independent sensor. It tracks how the brightness of each pixel changes over a sequence of phase-shifted frames, creating a time-domain signal.

1.6 Outline of the Report

1. **Introduction:** Provides background on quantum imaging technology, defines the problem statement, outlines project objectives, and presents the methodology and scope of work.
2. **Analysis / Specifications:** Details the requirements analysis, system specifications, and constraints for the enhanced image processing and user interface development.
3. **Functional Design:** Describes the functional architecture, user workflows, and feature specifications for the image processing algorithms and UI components.
4. **Technical Design:** Presents the technical implementation approach, software architecture, technology stack, and design patterns used for the project.
5. **Realisation:** Documents the actual implementation of the system, including code development, integration, and deployment of the quantum imaging software.
6. **Testing:** Covers testing strategies, test cases, results, and validation of the image processing quality and user interface functionality.

7. **Conclusions & Recommendations:** Summarizes key findings, evaluates achievement of objectives, and provides recommendations for future improvements and research directions.

2 Analysis / Specifications

In this chapter, the requirements for the QIUP project will be analyzed. Additionally to the requirements, the constraints will be discussed and specified

2.1 Physical Specifications

To grasp how this demonstrational setup works, it is crucial to understand the underlying physical principles and components that enable QIUP technology.

Nonlinear Interferometry

To understand how QIUP works, it is essential to first understand what's behind it: the nonlinear interferometer. In classical optics, a standard interferometer uses mirrors and beam splitters to divide a single beam of light, send the halves along different paths, and recombine them to measure interference patterns. A nonlinear interferometer, however, replaces standard beam splitters with nonlinear crystals to exploit the quantum properties of light [5].

Spontaneous Parametric Down-Conversion

The core of this system is a quantum optical process called SPDC [6]. When a high-energy laser (the laser pump) illuminates a specialized nonlinear crystal in our case the PPLN crystal, a photon will spontaneously split into a pair of photons at different wavelengths [5]. These two newly created photons are called the signal photon and the idler photon. In the context of this demonstrator, the signal photon is in the visible spectrum (detected by the CMOS camera), while the idler photon is in the infrared spectrum (which will interact with the object).

Induced Coherence and "Which-Way" Information

The foundational principle behind QIUP is a phenomenon known as "induced coherence without induced emission" [5]. Imagine an optical setup configured so that a signal-idler photon pair could be created in a first crystal or a second identical crystal. The system is precisely aligned so that the path of the idler photon from the first crystal overlaps perfectly with the emission path of the idler from the second crystal.

Indistinguishability and Interference: Quantum interference is observed at the camera only if the path taken by the photon is fundamentally unknown [5, 6]. In QIUP, the alternating fringe pattern extracted via FFT exists because the signal photon's origin is undefined. By perfectly overlapping the infrared idler and signal beams, the setup intentionally erases the "which-way" (or *welcher-weg*) information regarding where the photon pair was generated [6, 5]. This forced spatial indistinguishability induces coherence between the visible signal photons, enabling them to interfere even though they never interacted with the sample [7, 5].

Extracting the Image

To turn this quantum phenomenon into an imaging system, the sample is placed in the path of the idler photon. The transmission and phase properties of the object directly control the visibility of the interference fringes seen in the signal beam [5]. The infrared idler photon gathers the physical information about the object, but it is entirely discarded and never reaches a detector [6]. Meanwhile, the visible signal photon never interacts with the object, yet its interference pattern, captured by the CMOS camera and processed via FFT, contains the complete image [8, 7].

2.2 Hardware Specifications

The demonstrational setup has several programmable hardware components that are essential for the operation of the QIUP system.

2.2.1 Piezoelectric Stage

To utilize the principle of induced coherence, the setup relies on a piezoelectric stage to precisely control the optical path length of the signal beam in μm . This is necessary to create the phase shifts required for the interference pattern to emerge and be captured by the camera.

The piezoelectric stage consists of two components:

- **KCube Piezo Controller (KPZ101):**
With the KPZ101 we are able to control the position of the piezoelectric stage with high precision, allowing for accurate phase scanning and modulation of the interference pattern. This is possible by applying voltage to the piezoelectric actuator, which causes it to expand or contract, thus changing the optical path length of the signal beam.
- **KCube Strain Gauge Meter (KSG101)**
The KSG101 is a strain gauge meter that provides feedback on the position of the piezoelectric stage, ensuring precise control and stability during the phase scanning process, which is needed because we need to have exactly one phase cycle otherwise we encounter spectral leakage.

Open & Closed loop mode

The piezoelectric stage can operate in both open-loop and closed-loop modes. In open-loop mode, the position of the stage is controlled solely by the input voltage, without any feedback. In closed-loop mode, the system uses feedback from the KSG101 to adjust the

voltage and maintain a precise position, which is crucial for achieving stable and accurate phase modulation in the QIUP setup.

2.2.2 CMOS Camera

The Thorlabs Zelux CMOS camera is used as the detector in the QIUP setup to capture signal photons, which contain the image information retrieved by the idler photons.

2.3 Software Specifications

Programming Language

Software Development Kits

Libraries

2.4 Requirements

User Requirements

System Requirements

3 Functional Design

4 Technical Design

5 Realisation

6 Testing

7 Conclusions and Recommendations

7.1 Conclusions

7.2 Recommendations

References

- [1] Quantum Delta NL, “Quantum delta NL,” 2024.
- [2] Thorlabs, Inc., “ThorCam™ Software User Guide,” 2024. Accessed: 2026-04-15.
- [3] Thorlabs, Inc., “Kinesis® Software and API,” 2024. Accessed: 2026-04-15.
- [4] Z. Xie, Y. Tang, Y. Zhou, and Q. Deng, “Surface and thickness measurement of transparent thin-film layers utilizing modulation-based structured-illumination microscopy,” *Optics Express*, 2018.
- [5] J. Fuenzalida, E. Giese, and M. Gräfe, “Nonlinear interferometry: A new approach for imaging and sensing,” *Advanced Quantum Technologies*, 2024.
- [6] G. B. Lemos, V. Borish, G. D. Cole, S. Ramelow, R. Lapkiewicz, and A. Zeilinger, “Quantum imaging and metrology with undetected photons,” *Nature*, 2014.
- [7] E. Pearce, N. R. Gemmell, J. Flórez, J. Ding, R. F. Oulton, A. S. Clark, and C. C. Phillips, “Practical quantum imaging with undetected photons,” *Optics Continuum*, 2023.
- [8] M. Kutas, B. Haase, J. Klier, D. Molter, and G. von Freymann, “Quantum-inspired terahertz spectroscopy with visible photons,” *Optica*, 2021.

Appendices