



AIR CONDITIONING CONTROL
PANEL WITH ZONE CONTROL

BULKHEAD

EXHAUST DISCHARGE LOUVRES
0.02m² FREE AREA MINIMUM (TYPICAL)

OUTSIDE AIR INTAKES WITH
ACOUSTIC BOOT, BALANCING
DAMPER AND BACK DRAFT DAMPER

ISSUED FOR CONSTRUCTION

2	23/09/16	CONSTRUCTION ISSUE	DH	RR
1	07/04/16	NON-REQUIRED EXHAUST REMOVED	DH	RR
0	15/02/16	TENDER ISSUE	DH	RR
REV.	DATE	DESCRIPTION	DRN	CHKD

ARCHITECT
HAYES ANDERSON LYNCH
ARCHITECTS PTY LTD

CONSULTANTS
BCA CONSULTANTS
CONSULTING ENGINEERS : MECHANICAL
ELECTRICAL FIRE LIFTS HYDRAULICS
LEVEL 1, 20 CAMBRIDGE ST, (PO BOX 288)
COORPAROO QUEENSLAND 4151
Tel: (617)3240 3200 Fax: (617)3240 3299
Email : bca@bcoconsultants.com.au
ACN No. 070 353 249

PROJECT
**45 WELLINGTON ROAD
EAST BRISBANE**

DRAWING
**MECHANICAL SERVICES
LEVELS 7 & 8
AIR CONDITIONING AND
VENTILATION LAYOUT**

NORTH POINT	CHECKED RR	DRG SCALE 1:100
DESIGNED DH		SHEET SIZE A1
DRAWN DH		No IN SET 7 of 10

PROJECT No. 7103	DATE 17/09/2015	FILE NAME 7103-M106.dwg
JOB No. 7103	DRAWING No. M106	REV. 2

This drawing is copyright and must not be retained, copied or used without the authority of BCA CONSULTANTS. This drawing should be read in conjunction with all relevant contracts, specifications and drawings.