


Typical
The condensate sensors at the take off for the first chilled beam served or adjacent to the take off if space is not permitted. Expose the CHW pipe insulation for 100mm and strap the sensor. To be installed as per the condensate sensor manufacturers specification.



LEVEL 12 CONDENSATE SENSOR MARKUP
AGC-8532-SK-LEVEL 12 CONDENSATE SENSOR
MARKUP-161020
Rev 1 - NM - 05/10/2016
Rev 2 - NM