



- PARTITION LEGEND:**
- ELECTRICAL DOORS TO CONTAIN NON-COMBUSTIBLE LINING
  - ALL PENETRATIONS THROUGH FLOOR ARE TO BE FIRE SEALED
  - RETAIL SEPARATED INTO ZONES: TO DELETE REQUIREMENT FOR SMOKE EXHAUST, ENSURE COMMERCIAL KITCHENS CAN BE CONTAINED
  - NO COMMERCIAL KITCHEN PERMITTED IN ATRIUM FIRE COMPARTMENT (SMOKE ZONE)
  - THIS DRAWING IS TO BE PRINTED IN COLOUR
  - THESE DRAWINGS TO BE READ IN CONJUNCTION WITH AND SHALL COMPLY WITH THE REQUIREMENTS OF ACOUSTIC REPORT BY WOOD & GREVE ENGINEERS INCLUDING APPENDIX PARTITION MARK-UP DRAWINGS
  - REFER DRY WALL PARTITION DETAILS A3305 & A3306 FOR DRY WALL DETAILS ONLY (IE. THERMAL AND FIRE RATINGS FOR MASONRY/CONCRETE ON GENERAL PARTITIONS)
  - FOR RELATIVE CEILING HEIGHTS REFER TO A2400 SERIES
  - FOR FIRE RATING OF DRY WALL PARTITIONS REFER TO DETAIL SHEETS A3305 & A3306
  - FOR FIRE RATING OF MASONRY REFER MASONRY TYPES AND GENERAL PARTITION PLANS
  - ACOUSTIC RATINGS NOTED ON WALL TYPES ON A3305 & A3306
  - READ IN CONJUNCTION WITH FIRE COMPARTMENT PLAN
  - READ IN CONJUNCTION WITH A1700 THERMAL INSULATION
  - FOR EXTENT OF TILING ON WET AREA LININGS REFER A4000 SERIES
  - WHERE FLOOR FINISHES NOTED AS SCHEDULED, REFER TO A2000 SERIES FOR TYPE & EXTENT
  - FOR DETAILED TOILET PARTITION SETOUT REFER A2000 WET AREA DRAWINGS

- LEGEND:**
- SMOKE RATED CONSTRUCTION  
200 C FOR 30MINS
  - CORE FILLED
  - THERMAL INSULATION LINE
  - APPROVED MANIFESTATION ON GLASS TO STANDARDS  
TO BE SHOWN ON SHOP DRAWINGS  
REFER TO PD PARTITION SCHEDULE FOR SPECS AND DETAILS
  - PD:XX  
DENOTES DOOR REFERENCE CODE.  
REFER DOOR SCHEDULE AND MATRIX FOR SPECS. AND DETAILS
  - PLAN DETAIL MARKER
  - ELEVATION MARKER
  - WALLS WITH INTEGRATED SEAT  
FRAMING WITHIN WALL  
ADDITIONAL TO BOX.  
REFER TO A7000 SERIES.
- BLOCKWORK LEGEND**
- 120/120/120 STRUCTURAL FRL
  - 120/120/120 SUBJECT TO FIRE SAFETY ENGINEERING
  - 180/180/180 STRUCTURAL FRL  
SUBSTATION OR SUBSTATION EGRESS
  - 240/240/240 STRUCTURAL FRL  
DIESEL (DANGEROUS GOODS)  
SLAB LEVEL MAY BE 180/180/180
  - 120/120 FIRE WALL
  - NON-FIRE RATED BLOCKWORK
  - FUTURE TENANCY WALL NON-FIRE RATED  
SUBJECT TO CONFIRMATION OF FINAL LOCATION
  - TMV THERMOSTATIC MIXING VALVE  
ACCESS PANEL IN WALL
  - WM WATER METER  
ACCESS PANEL IN WALL
  - WS-X DENOTES WALL STIFFENER
  - RN-03 CEMENT RENDER WITH 4mm SAWCUT JOINTS. PAINTED FINISH
  - RN-04 CEMENT RENDER
- REFER TO STRUCTURAL DRAWINGS S300701 AND S300702 FOR WALL STIFFENER TYPES AND DETAILS  
ALL STIFFENERS TO BE 300mm FROM END OF WALLS
- CONCRETE BLOCK WORK - WALL TYPES**
- MA-01 90mm. Non-fire rated
  - MA-02 140mm. Non-fire rated
  - MA-03 90mm. Non-fire rated
  - MA-04 90mm. Two hour (120) fire rated
  - MA-05 140mm. Two hour (120) fire rated
  - MA-06 190mm. Two hour (120) fire rated
  - MA-07 190mm. Three hour (180) fire rated
  - MA-08 190mm. Four hour (240) fire rated

Refer 0339 MA: Masonry Schedule for detail description  
Refer Structural Engineer Masonry Specification  
Refer Architectural 0331 Brick and Block Construction

- Refer drawings for overall level of fire rated construction that the blockwork wall shall achieve (i.e: 120/120/120, -120/120).

- Refer drawings for nominated minimum acoustic rating (including acoustic sealing / sealant) for blockwork walls (i.e: Rw 43, Rw 55)

- Refer drawings for nominated minimum thermal insulation rating i.e. R1.8

- Refer Structural Engineer Drawings for details of Wall Stiffener Types WS1, WS2, WS3, WS4 and WS5, blockwork deflection head details, construction joints and wall ties.

- All work to include building-in of blockwork into associated fire and acoustic rated door frames.

Recent revision history			Notes & Legend Consultant must verify all dimensions on site before commencing work or preparing shop drawings. Do not scale drawings.
#	Status	Description	
1	FOR CONSTRUCTION	06/04/16	
2	FOR CONSTRUCTION	25/05/16	
3	FOR CONSTRUCTION	22/07/16	
4	FOR CONSTRUCTION	20/12/16	

Notes & Legend  
Consultant must verify all dimensions on site before commencing work or preparing shop drawings. Do not scale drawings.

Date generated: 20-12-16 10:12:19 AM C:\My Documents\Autodesk\Revit\2016\161018\_DarlingSquare\_Building\_161018\_spld.rvt



Project  
DARLING SQUARE NW PLOT

Client  
LEND LEASE

Woods Bagot

Project number  
120605

Checked  
Approved

Size check  
25mm

Scale  
1:100

Sheet title  
PARTITIONS PLAN - LEVEL 2

Sheet number  
A2302

Revision  
4