

**400/220/110/66 kV TRANSMISSION OUTAGES FROM 09.02.2021 TO 15.02.2021**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	9-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
2	9-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
3	9-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
4	9-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
5	9-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
6	9-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
7	9-Feb-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
8	9-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
9	9-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
10	9-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
11	9-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
12	9-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
13	9-Feb-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN:LINE CLEAR AVAILED
14	9-Feb-21	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN:LINE CLEAR AVAILED
15	9-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
16	9-Feb-21	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
17	9-Feb-21	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
18	9-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVAILED
19	9-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
20	9-Feb-21	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	8:18 (08.02.2021)	17:42 (09.02.2021)	33:20HRS	TRANSFORMER CHARGED
21	9-Feb-21	BAGALKOT	110	BELLATTI-ENERCON 2	BELLATTI_110 (STATION NOT AFFECTED)	11:46	19:31	7:45	LINE CLEAR AVAILED
22	9-Feb-21	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110 (STATION NOT AFFECTED)	23:57 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
23	9-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
24	9-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
25	9-Feb-21	BAGALKOT	220	GHATAPRABHA-NARENDRA 2	GHATAPRABHA_220	10:10	19:00	8:50	NFBC ISSUED
26	9-Feb-21	BAGALKOT	110	GADAG - LAXMESHWAR	STATION NOT AFFECTED LAXMESHWAR_110	11:20	18:01	6:41	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
27	9-Feb-21	BAGALKOT	110	110/11KV,HV4	GHATAPRABHA_110	08:23	08:46	0:23	HAND TRIPPED
28	9-Feb-21	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	08:20	08:35	0:15	TRANSFORMER FAULT
29	9-Feb-21	BAGALKOT	110	110/33KV,HV2	HUNGUND_110, AMINGAD_33, KARADI_33	15:16	15:22	0:06	TRANSFORMER FAULT
30	9-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
31	9-Feb-21	BAGALKOT	220	HUBLI-NAGJHARI1	HUBLI_220	13:33	17:16	3:43	LINE FAULT
32	9-Feb-21	BAGALKOT	110	110/33KV, HV1	HUBLI_220, SAUSHI_33, VRL_33	09:06	15:08	6:02	LINE CLEAR AVAILED
33	9-Feb-21	BAGALKOT	110	110/33KV, HV1	HUBLI_220, SAUSHI_33, VRL_33	09:16	15:21	6:05	LINE CLEAR AVAILED
34	9-Feb-21	BAGALKOT	110	SOUDATTI220- SOUDATTI2	STATION NOT AFFECTED SOUDATTI_110	10:57	14:07	3:10	LINE CLEAR AVAILED
35	9-Feb-21	BAGALKOT	110	SOUDATTI220- RAMDURGA2	STATION NOT AFFECTED RAMDURGA_110	10:59	14:09	3:10	LINE CLEAR AVAILED
36	9-Feb-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
37	9-Feb-21	BAGALKOT	110	110/11KV, HV3	SOUDATTI_110	11:22	13:07	1:45	LINE CLEAR AVAILED
38	9-Feb-21	BAGALKOT	110	110/11KV, HV2	SIRSI_110	11:17	11:24	0:07	LINE CLEAR AVAILED
39	9-Feb-21	BAGALKOT	110	110/11KV, HV1	SHIRGOAN_110	11:17	13:47	2:30	LINE CLEAR AVAILED
40	9-Feb-21	BAGALKOT	220	KUDACHI- MAHALINGAPUR2	MAHALINGAPUR_220	12:43	16:29	3:46	LINE CLEAR AVAILED
41	9-Feb-21	BENGALURU	66	B STATION - EDC 220	B STATION	10:05	14:40	04:35	LINE CLEAR AVAILED
42	9-Feb-21	BENGALURU	66	HV1	KADUBISANAHALLI	08:50	09:00	00:10	LINE CLEAR AVAILED
43	9-Feb-21	BENGALURU	66	HV2	KADUBISANAHALLI	14:00	14:40	00:40	LINE CLEAR AVAILED
44	9-Feb-21	BENGALURU	66	KADUBISANAHALLI - HAL 220	KADUBISANAHALLI, EXORA	14:00	14:40	00:40	LINE CLEAR AVAILED
45	9-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:44	13:05	00:21	LINE FAULT
46	9-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	12:44	13:05	00:21	LINE FAULT
47	9-Feb-21	BENGALURU	220	HV2	T K HALLI 220	12:44	13:05	00:21	TRANSFORMER FAULT
48	9-Feb-21	BENGALURU	220	HV1	T K HALLI 220	15:56	16:00	00:04	TRANSFORMER FAULT
49	9-Feb-21	BENGALURU	66	T K HALLI 220 - BWSSB 1	BWSSB 1	15:56	16:04	00:08	LINE CLEAR AVAILED
50	9-Feb-21	BENGALURU	66	T K HALLI 220 - BWSSB 2	BWSSB 2	15:56	16:11	00:15	LINE CLEAR AVAILED
51	9-Feb-21	BENGALURU	66	T K HALLI 220 - BWSSB 3	BWSSB 2	15:56	16:11	00:15	LINE CLEAR AVAILED
52	9-Feb-21	BENGALURU	66	T K HALLI 220 - BWSSB 4	BWSSB 2	15:56	16:40	00:44	LINE CLEAR AVAILED
53	9-Feb-21	BENGALURU	66	SURYANAGAR - YERANDANAHALLI	SURYANAGAR	15:56	16:01	00:04	LOAD CHANGE OVER
54	9-Feb-21	BENGALURU	66	SURYANAGAR - ANEKAL	ANEKAL	18:07	18:11	00:03	LOAD CHANGE OVER
55	9-Feb-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	09:37	09:46	00:08	LINE FAULT
56	9-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	08:10	08:22	00:12	LINE FAULT
57	9-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	10:32	10:50	00:18	LOAD CURTAILMENT
58	9-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:55	13:05	00:10	LOAD CURTAILMENT
59	9-Feb-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	08:15	08:24	00:09	LINE FAULT
60	9-Feb-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	09:11	09:25	00:14	LOAD CURTAILMENT
61	9-Feb-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	12:10	12:30	00:20	LOAD CURTAILMENT
62	9-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:04	10:30	00:26	LOAD CURTAILMENT
63	9-Feb-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	13:24	13:33	00:09	LINE CLEAR AVAILED
64	9-Feb-21	BENGALURU	66	HV1	KONDASPURA	12:55	13:13	00:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
65	9-Feb-21	BENGALURU	66	HV2	MAASTHI	15:34	15:40	00:05	LINE CLEAR AVAILED
66	9-Feb-21	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	9:45(08.02.2021)	12:32(09.02.2021)	26:47 HRS	LINE CHARGED
67	9-Feb-21	GULBARGA	220	MALLAT-RTPS	RTPS_220	03:59	04:42	00:43	LINE FAULT
68	9-Feb-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	04:58	05:15	00:17	LINE FAULT
69	9-Feb-21	GULBARGA	220	HV2	SHAHAPUR_220	15:40	16:05	00:25	LINE CLEAR AVAILED
70	9-Feb-21	GULBARGA	220	RTPS-MALLAT	MALLAT_220	03:59	04:42	00:43	LINE FAULT
71	9-Feb-21	GULBARGA	220	MALLAT-LINGSUGUR	MALLAT_220	04:58	05:15	00:17	LINE FAULT
72	9-Feb-21	GULBARGA	110	HV1	KADAGANCHI_110	11:25	11:30	00:05	TRANSFORMER FAULT
73	9-Feb-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	13:40	13:55	00:15	LINE CLEAR AVAILED
74	9-Feb-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	03:50	04:20	00:30	MAIN SUPPLY FAILURE
75	9-Feb-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	02:20	02:45	00:25	MAIN SUPPLY FAILURE
76	9-Feb-21	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	06:00	06:30	00:30	MAIN SUPPLY FAILURE
77	9-Feb-21	GULBARGA	110	HV1	SHAHAPUR_220	11:52	13:28	01:36	LINE CLEAR AVAILED
78	9-Feb-21	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	04:55	05:13	00:18	LINE FAULT
79	9-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADALAPURA_110,KU RDICROSS_110	06:18	06:28	00:10	LINE FAULT
80	9-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	21:50	22:02	00:12	LINE FAULT
81	9-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	22:05	22:15	00:10	LINE FAULT
82	9-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	22:35	23:42	01:07	LINE FAULT
83	9-Feb-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	14:03	14:40	00:37	LINE CLEAR AVAILED
84	9-Feb-21	GULBARGA	110	HV1	GABUR_110	16:30	18:25	01:55	TRANSFORMER FAULT
85	9-Feb-21	GULBARGA	110	HV1	GABUR_110	19:55	22:00	02:05	LINE CLEAR AVAILED
86	9-Feb-21	GULBARGA	110	HV1	GABUR_110	22:32	22:55	00:23	LINE CLEAR AVAILED
87	9-Feb-21	GULBARGA	66	HV1	MAGALA_66	12:15	12:20	00:05	TRANSFORMER FAULT
88	9-Feb-21	GULBARGA	66	HV1	MAGALA_66	12:25	12:30	00:05	TRANSFORMER FAULT
89	9-Feb-21	GULBARGA	66	HV1	MAGALA_66	12:35	12:40	00:05	TRANSFORMER FAULT
90	9-Feb-21	GULBARGA	66	HV1	MAGALA_66	13:35	13:50	00:15	TRANSFORMER FAULT
91	9-Feb-21	GULBARGA	66	HV1	MAGALA_66	14:00	14:10	00:10	TRANSFORMER FAULT
92	9-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
93	9-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
94	9-Feb-21	HASSAN	110	HV2	PUTTUR_110	10:17(26.1.2021)	12:46(9.2.2021)	338:28 hrs	TRANSFORMER CHARGED
95	9-Feb-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	02:27	07:05	04:38	LINE CLEAR AVAILED
96	9-Feb-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	14:37	16:05	01:28	LINE CLEAR AVAILED
97	9-Feb-21	HASSAN	220	MRSSHIM-SHARAVATHY1	MRSMSG_220	14:37	16:06	01:29	LINE CLEAR AVAILED
98	9-Feb-21	HASSAN	220	MRSSHIM-VARAH12	MRSMSG_220	10:41	13:29	02:48	LINE CLEAR AVAILED
99	9-Feb-21	HASSAN	110	HV1	MRSMSG_220	09:07	13:15	04:08	LINE CLEAR AVAILED
100	9-Feb-21	HASSAN	220	HV1	MSEZ_220	16:14	18:11	01:57	LINE CLEAR AVAILED
101	9-Feb-21	HASSAN	220	HV2	MSEZ_220	09:45	16:11	06:26	LINE CLEAR AVAILED
102	9-Feb-21	HASSAN	110	LV1	MSEZ_220	16:13	18:11	01:58	LINE CLEAR AVAILED
103	9-Feb-21	HASSAN	110	LV2	MSEZ_220	09:45	16:12	06:27	LINE CLEAR AVAILED
104	9-Feb-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	10:42	13:29	02:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
105	9-Feb-21	HASSAN	110	HV1	NITTUR_110	09:40	11:33	01:53	LINE CLEAR AVAILED
106	9-Feb-21	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	11:20	14:02	02:42	LINE CLEAR AVAILED
107	9-Feb-21	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	15:35	16:01	00:26	LINE CLEAR AVAILED
108	9-Feb-21	HASSAN	110	NITUR11-MANIPAL	NITTUR_110	17:11	17:30	00:19	LINE CLEAR AVAILED
109	9-Feb-21	HASSAN	110	HV1	BANAVARA_110	12:04	13:08	01:04	LINE CLEAR AVAILED
110	9-Feb-21	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	09:16	17:07	07:51	LINE CLEAR AVAILED
111	9-Feb-21	HASSAN	110	GURUPUR-MDBDRE	GURUPURA_110	17:58	18:03	00:05	LINE FAULT
112	9-Feb-21	HASSAN	110	HV2	GURUVAYANAKERE_110	11:32	12:11	00:39	LINE CLEAR AVAILED
113	9-Feb-21	HASSAN	110	HV1	JAVAGAL_110	12:50	13:45	00:55	LINE CLEAR AVAILED
114	9-Feb-21	HASSAN	110	HV2	JAVAGAL_110	13:35	14:35	01:00	LINE CLEAR AVAILED
115	9-Feb-21	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	09:12	17:08	07:56	LINE CLEAR AVAILED
116	9-Feb-21	HASSAN	110	HV1	MOODABIDRE_110	09:12	17:17	08:05	LINE CLEAR AVAILED
117	9-Feb-21	HASSAN	110	HV1	MOODABIDRE_110	17:56	18:03	00:07	TRANSFORMER FAULT
118	9-Feb-21	HASSAN	110	HV2	MOODABIDRE_110	09:13	17:16	08:03	LINE CLEAR AVAILED
119	9-Feb-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	09:12	17:18	08:06	LINE CLEAR AVAILED
120	9-Feb-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	09:12	17:18	08:06	LINE CLEAR AVAILED
121	9-Feb-21	HASSAN	66	HV1	BALEHONNUR_66	13:57	16:12	02:15	LINE CLEAR AVAILED
122	9-Feb-21	HASSAN	66	HV1	MAGGE_66	11:37	12:43	01:06	LINE CLEAR AVAILED
123	9-Feb-21	HASSAN	66	HV2	KIADBHASSAN_66	11:41	12:39	00:58	LINE CLEAR AVAILED
124	9-Feb-21	HASSAN	66	HV2	BASAVAGHATTA_66	16:33	16:46	00:13	LINE CLEAR AVAILED
125	9-Feb-21	MYSORE	66	HV1	ARAKERE_66	8:48	8:57	0:09	TRANSFORMER FAULT
126	9-Feb-21	MYSORE	66	DATAGALLY-RK NAGARA	NO STATION EFFECTED	14:48	15:25	0:36	HAND TRIPPED
127	9-Feb-21	MYSORE	66	HOOTAGALLY-BOGADHI	NO STATION EFFECTED	9:38	12:08	2:29	LINE CLEAR AVAILED
128	9-Feb-21	MYSORE	66	HV2	HOOTAGALLY_220	14:05	14:14	0:08	LINE CLEAR AVAILED
129	9-Feb-21	MYSORE	220	HOOTAGALLY-KADAKOLA	NO STATION EFFECTED	10:17	18:21	8:03	LINE CLEAR AVAILED
130	9-Feb-21	MYSORE	66	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66	6:20	8:34	2:14	LINE FAULT
131	9-Feb-21	MYSORE	66	KM DODDI-MANDYA	KOLKARANADODDI_66 KMDODDI_66 K_HONNALGERE_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	18:33	18:50	0:16	HAND TRIPPED
132	9-Feb-21	MYSORE	66	KM DODDI-TK HALLI	KOLKARANADODDI_66 KMDODDI_66 K_HONNALGERE_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	12:59	18:50	5:50	LINE CLEAR AVAILED
133	9-Feb-21	MYSORE	66	HV1	KRNAGARA_66	15:30	15:34	0:04	TRANSFORMER FAULT
134	9-Feb-21	MYSORE	66	HV2	KRNAGARA_66	15:30	15:32	0:02	TRANSFORMER FAULT
135	9-Feb-21	MYSORE	66	HV2	MALAVALLI_66	13:34	14:01	0:27	LINE CLEAR AVAILED
136	9-Feb-21	MYSORE	66	HV1	MYSORESOUTH_66	9:51	12:30	2:39	LINE CLEAR AVAILED
137	9-Feb-21	MYSORE	66	HV2	MYSORESOUTH_66	12:30	19:45	7:14	LINE CLEAR AVAILED
138	9-Feb-21	MYSORE	66	PERIYAPATNA-HUNSUR	NO STATION EFFECTED	11:59	17:49	5:49	LINE CLEAR AVAILED
139	9-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	7:51	8:05	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
140	9-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	10:47	12:01	1:13	NFBC ISSUED
141	9-Feb-21	MYSORE	66	SFC SIVA-PGL	NO STATION EFFECTED	7:50	7:58	0:07	LINE FAULT
142	9-Feb-21	MYSORE	66	SFC SIVA-5 MW	NO STATION EFFECTED	7:50	7:55	0:05	LINE FAULT
143	9-Feb-21	MYSORE	66	SFC SIVA-10 MW	NO STATION EFFECTED	7:50	7:57	0:07	LINE FAULT
144	9-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	12:04	12:59	0:55	NFBC ISSUED
145	9-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	7:51	8:10	0:19	LINE FAULT
146	9-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 7	NO STATION EFFECTED	9:20	10:46	1:26	NFBC ISSUED
147	9-Feb-21	MYSORE	66	TUBINAKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	7:45	7:52	0:07	LINE FAULT
148	9-Feb-21	MYSORE	66	TUBINAKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	10:19	10:24	0:04	LINE FAULT
149	9-Feb-21	MYSORE	66	TUBINAKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	11:01	11:05	0:03	LINE FAULT
150	9-Feb-21	MYSORE	66	K HONNALAGERE-IGLOOR	NO STATION EFFECTED	13:06 (17/01/2021)	7:12 (09/02/2021)	546:06 HRS	LINE CHARGED
151	9-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN:LINE CLEAR AVAILED
152	9-Feb-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
153	9-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
154	9-Feb-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
155	9-Feb-21	TUMKUR	220	THALLAK 220kv-HIRIYUR	THALLAKK_220	7:02	8:30	1:27	LINE CLEAR AVAILED
156	9-Feb-21	TUMKUR	110	TR-2	KADABA_110	15:17	16:59	1:42	LINE CLEAR AVAILED
157	9-Feb-21	TUMKUR	110	TR-2	KADABA_110	17:01	18:22	1:20	LINE CLEAR AVAILED
158	9-Feb-21	TUMKUR	110	TR-1	TANDAGA_110	14:48	16:05	1:16	LINE CLEAR AVAILED
159	9-Feb-21	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	10:53	12:08	1:14	LINE CLEAR AVAILED
160	9-Feb-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:22	17:35	0:13	LINE FAULT
161	9-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	19:06	19:16	0:10	LINE FAULT
162	9-Feb-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	8:57	9:36	0:39	LINE CLEAR AVAILED
163	9-Feb-21	TUMKUR	66	TR-2	HONNNUDIKE_66	15:59	16:30	0:30	LINE CLEAR AVAILED
164	9-Feb-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:07	10:18	0:10	LINE FAULT
165	9-Feb-21	TUMKUR	66	TR-2	KUKKAWADA_66	11:02	13:30	2:28	LINE CLEAR AVAILED
166	9-Feb-21	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	4:01	4:08	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
167	9-Feb-21	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	10:49	11:24	0:34	HAND TRIPPED
168	9-Feb-21	TUMKUR	66	TR-2	SANIKERE_66	10:18	10:22	0:04	TRANSFORMER FAULT
169	10-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
170	10-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVOIDED
171	10-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOIDED
172	10-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
173	10-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
174	10-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVOIDED
175	10-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
176	10-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
177	10-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
178	10-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
179	10-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
180	10-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
181	10-Feb-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
182	10-Feb-21	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
183	10-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
184	10-Feb-21	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
185	10-Feb-21	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
186	10-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
187	10-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
188	10-Feb-21	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110 (STATION NOT AFFECTED)	23:57 (9.2.2021)	3:52 (10.02.2021)	3:55hrs	LINE CHARGED
189	10-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVOIDED
190	10-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVOIDED
191	10-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
192	10-Feb-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
193	10-Feb-21	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	STATION NOT AFFECTED SIDDAPUR_110	9:23 (10.02.2021)			LINE OPEN:LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
194	10-Feb-21	BAGALKOT	110	SIRSI-JOG2(JOG)	STATION NOT AFFECTED SIRSI_110	09:23	09:32	0:09	HAND TRIPPED
195	10-Feb-21	BAGALKOT	110	110/11KV, HV2	SHIRGOAN_110	11:23	11:45	0:22	LINE CLEAR AVAILED
196	10-Feb-21	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	15:39	16:32	0:53	LINE CLEAR AVAILED
197	10-Feb-21	BAGALKOT	220	NAGJHARI1- HUBLI	STATION NOT AFFECTED HUBLI_220	12:54	13:42	0:48	LINE CLEAR AVAILED
198	10-Feb-21	BAGALKOT	110	110/11KV, HV1	MUDUGANUR_110	17:44	17:50	0:06	LOAD CURTAILMENT
199	10-Feb-21	BAGALKOT	110	110/11KV, HV1	MUDUGANUR_110	17:51	18:00	0:09	LOAD CURTAILMENT
200	10-Feb-21	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	STATION NOT AFFECTED MALGHAN(S)_110	23:47 (10.02.2021)			LINE OPEN: LINE FAULT
201	10-Feb-21	BAGALKOT	110	MRUTHYUNJAY NAGAR- GOPPANAKOPPA2	STATION NOT AFFECTED MRUTHYUNJAY NAGAR_110	16:20	17:57	1:37	LINE FAULT
202	10-Feb-21	BAGALKOT	110	110/11KV, HV1	KUDALSANGAM_110	17:46	18:34	0:48	TRANSFORMER FAULT
203	10-Feb-21	BAGALKOT	110	110/11KV, HV2	KADANKOPPA_110	12:17	12:26	0:09	TRANSFORMER FAULT
204	10-Feb-21	BAGALKOT	110	BPCL- ITANAL	STATION NOT AFFECTED ITANAL_110	12:29	12:34	0:05	LINE CLEAR AVAILED
205	10-Feb-21	BAGALKOT	110	110/11KV, HV3	HIREKERUR_110	15:26	18:51	3:25	LINE CLEAR AVAILED
206	10-Feb-21	BAGALKOT	110	110/11KV, HV4	GAJENDRAGAD_110	17:46	17:55	0:09	LOAD CURTAILMENT
207	10-Feb-21	BAGALKOT	110	110/11KV, HV1	GADAG_110	10:18	19:00	8:42	LINE CLEAR AVAILED
208	10-Feb-21	BAGALKOT	110	110/33KV, HV4	GADAG_110, LAKKUNDI_33, HULKOTI_33	10:29	19:02	8:33	LINE CLEAR AVAILED
209	10-Feb-21	BAGALKOT	110	110/33KV, HV3	GADAG_110, LAKKUNDI_33, HULKOTI_33	10:29	19:02	8:33	LINE CLEAR AVAILED
210	10-Feb-21	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	6:32	19:00	12:28	LINE FAULT
211	10-Feb-21	BAGALKOT	110	110/11KV.HV 2	AINAPUR_110	17:46	17:53	0:07	LOAD CURTAILMENT
212	10-Feb-21	BENGALURU	66	HV2	AMAR JYOTHI	10:55	11:09	00:14	LINE CLEAR AVAILED
213	10-Feb-21	BENGALURU	66	HV2	AMAR JYOTHI	13:24	13:30	00:06	LINE CLEAR AVAILED
214	10-Feb-21	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	18:40	19:05	00:25	LINE FAULT
215	10-Feb-21	BENGALURU	66	HV1	BRIGADE METROPOLIS	21:23	21:27	00:04	TRANSFORMER FAULT
216	10-Feb-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	15:20	15:27	00:07	LOAD CHANGEOVER
217	10-Feb-21	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	13:18	13:21	00:03	TRANSFORMER FAULT
218	10-Feb-21	BENGALURU	220	HOODY 220 - MALUR 220	NO STATION AFFECTED	06:18	13:36	07:18	LINE FAULT
219	10-Feb-21	BENGALURU	66	KODIGEHALI - T G HALLI	TAVAREKERE, T G HALLI	16:32	16:46	00:14	LINE FAULT
220	10-Feb-21	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	09:05	14:16	05:11	LINE CLEAR AVAILED
221	10-Feb-21	BENGALURU	66	HV1	MEI LAYOUT	10:58	11:00	00:02	LINE CLEAR AVAILED
222	10-Feb-21	BENGALURU	66	HV2	MEI LAYOUT	12:08	13:43	01:35	LINE CLEAR AVAILED
223	10-Feb-21	BENGALURU	66	SRS PEENYA 220 - DG 1	NO STATION AFFECTED	04:25	07:45	03:20	LINE FAULT
224	10-Feb-21	BENGALURU	66	GURUVINAPURA - SOMANAHALLI 220	GURUVINAPURA, B V HALLI	18:38	18:42	00:04	LOAD CHANGEOVER
225	10-Feb-21	BENGALURU	220	VIKAS TECH PARK - SARJAPURA 220	VIKAS TECH PARK 220	14:02	15:14	01:12	MAIN SUPPLY FAILURE
226	10-Feb-21	BENGALURU	220	VIKAS TECH PARK - HSR LAYOUT 220	VIKAS TECH PARK 220	18:53	19:08	00:15	LOAD CHANGEOVER
227	10-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	06:03	09:58	03:55	LINE FAULT
228	10-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:44	16:48	00:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
229	10-Feb-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:05	14:45	00:40	LINE FAULT
230	10-Feb-21	BENGALURU	220	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	14:46	15:40	00:53	LINE FAULT
231	10-Feb-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:02	15:40	01:38	MAIN SUPPLY FAILURE
232	10-Feb-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	14:02	15:35	01:33	MAIN SUPPLY FAILURE
233	10-Feb-21	BENGALURU	66	HV1	BANGARPET	16:45	16:50	00:04	TRANSFORMER FAULT
234	10-Feb-21	BENGALURU	66	HV2	DODDABELAVANGALA	11:36	11:49	00:13	TRANSFORMER FAULT
235	10-Feb-21	BENGALURU	66	HV2	DOMMASANDRA	18:15	18:29	00:14	LINE CLEAR AVAILED
236	10-Feb-21	BENGALURU	66	HV1	HUKUNDA	05:10	05:20	00:09	TRANSFORMER FAULT
237	10-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	04:02	04:13	00:10	TRANSFORMER FAULT
238	10-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	05:31	05:36	00:05	TRANSFORMER FAULT
239	10-Feb-21	BENGALURU	66	HV2	RANGANDODDI	14:17	14:31	00:13	LINE CLEAR AVAILED
240	10-Feb-21	BENGALURU	66	HV1	SARJAPURA 220	14:02	18:59	04:57	MAIN SUPPLY FAILURE
241	10-Feb-21	BENGALURU	66	HV2	SARJAPURA 220	18:54	19:02	00:08	LOAD CHANGE OVER
242	10-Feb-21	BENGALURU	66	HV2	SARJAPURA 220	14:02	15:20	01:18	MAIN SUPPLY FAILURE
243	10-Feb-21	BENGALURU	66	HV2	MAASTHI	00:47	00:51	00:03	TRANSFORMER FAULT
244	10-Feb-21	BENGALURU	66	HV2	MAASTHI	02:10	02:13	00:02	TRANSFORMER FAULT
245	10-Feb-21	BENGALURU	66	HV2	MAASTHI	10:43	10:50	00:06	TRANSFORMER FAULT
246	10-Feb-21	BENGALURU	66	SOMANAHALLI 220 - RANGANDODDI	RANGANDODDI	10:45	11:30	00:45	LINE FAULT
247	10-Feb-21	GULBARGA	400	JSVWL-BPS2	BPS_400	10:04	13:55	03:51	LINE CLEAR AVAILED
248	10-Feb-21	GULBARGA	220	RTPS-LINGSUGUR2	LINGSUGUR_220	9:32(10.02.2021)			LINE OPEN: LINE CLEAR AVAILED
249	10-Feb-21	GULBARGA	220	HV2	ITTAGI_110	11:43	11:50	00:07	TRANSFORMER FAULT
250	10-Feb-21	GULBARGA	220	RTPS-LINGSUGUR3	LINGSUGUR_220	06:06	06:21	00:15	LINE FAULT
251	10-Feb-21	GULBARGA	110	HALBARGA-CHIDRI	CHIDRI_110	16:27			LINE OPEN: LINE FAULT
252	10-Feb-21	GULBARGA	110	KAPANOOR-MADIYAL	MADIYAL_110	01:54	02:07	00:13	LINE FAULT
253	10-Feb-21	GULBARGA	110	KUSTAGI-ILKAL	ILKAL_110	04:43	04:48	00:05	LINE FAULT
254	10-Feb-21	GULBARGA	110	PDHALLI-JANAKI	JANAKI_IPP	06:45	08:05	01:20	LINE FAULT
255	10-Feb-21	GULBARGA	110	PDHALLI-CLEAN MAX	CLEAN MAX_IPP	06:45	08:05	01:20	LINE FAULT
256	10-Feb-21	GULBARGA	110	PDHALLI- CLEAN SOLAR	CLEAN SOLAR_IPP	06:45	08:05	01:20	LINE FAULT
257	10-Feb-21	GULBARGA	110	PDHALLI-BASAI	BASAI_IPP	06:45	08:05	01:20	LINE FAULT
258	10-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	05:30	05:37	00:07	LINE FAULT
259	10-Feb-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	05:20	05:25	00:05	LINE FAULT
260	10-Feb-21	GULBARGA	110	SHAHAPUR-SHAHABAD1	SHAHAPUR_110	06:20	07:10	00:50	LINE FAULT
261	10-Feb-21	GULBARGA	110	SHAHAPUR-SHAHABAD1	SHAHAPUR_110	07:10	09:30	02:20	LINE CLEAR AVAILED
262	10-Feb-21	GULBARGA	110	BISIHALLI-ALLIPUR	BISIHALLI_110	07:20	08:05	00:45	LINE FAULT
263	10-Feb-21	GULBARGA	110	BISIHALLI-ALLIPUR	BISIHALLI_110	09:54	10:00	00:06	LINE FAULT
264	10-Feb-21	GULBARGA	110	HV2	BISIHALLI_110	09:54	10:00	00:06	TRANSFORMER FAULT
265	10-Feb-21	GULBARGA	110	HV2	BISIHALLI_110	12:58	13:04	00:06	TRANSFORMER FAULT
266	10-Feb-21	GULBARGA	110	HUMNABAD-MANEKHALI	MANEKHALI_110	19:10	19:20	00:10	LINE FAULT
267	10-Feb-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	18:00(10.02.2021)			LINE OPEN: LINE FAULT
268	10-Feb-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	18:00(10.02.2021)	2:38(11.02.2021)	8:38HRS	LINE FAULT
269	10-Feb-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	06:40	07:31	00:51	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
270	10-Feb-21	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	10:30	11:30	01:00	LINE CLEAR AVAILED
271	10-Feb-21	GULBARGA	110	SIDHNOOR-NIRLOOPI_IPP	SINDHANOOR_220	11:02	18:30	07:28	LINE CLEAR AVAILED
272	10-Feb-21	GULBARGA	66	HV1	ITTAGI_110	10:40	10:46	00:06	TRANSFORMER FAULT
273	10-Feb-21	GULBARGA	66	HV1	HANASI_66	16:35	17:40	01:05	LINE CLEAR AVAILED
274	10-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
275	10-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
276	10-Feb-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	11:01(10.2.2021)			LINE OPEN:LINE CLEAR AVAILED
277	10-Feb-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:35	18:51	00:16	HAND TRIPPED
278	10-Feb-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	15:59	18:43	02:44	LINE FAULT
279	10-Feb-21	HASSAN	110	HV1	MRSMSG_220	11:52	12:02	00:10	HAND TRIPPED
280	10-Feb-21	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	15:59	18:43	02:44	LINE FAULT
281	10-Feb-21	HASSAN	220	HV2	SHIRALKOPPA_220	15:02	16:02	01:00	LINE CLEAR AVAILED
282	10-Feb-21	HASSAN	110	LV2	SHIRALKOPPA_220	15:02	16:02	01:00	LINE CLEAR AVAILED
283	10-Feb-21	HASSAN	110	HV1	HALADY_110	17:44	18:03	00:19	TRANSFORMER FAULT
284	10-Feb-21	HASSAN	110	HV2	GANDASI_110	17:44	17:55	00:11	LOAD CURTAILMENT
285	10-Feb-21	HASSAN	110	HV2	GERUMARA_110	17:51	19:04	01:13	LOAD CURTAILMENT
286	10-Feb-21	HASSAN	110	HV1	GURUPURA_110	10:19	11:49	01:30	LINE CLEAR AVAILED
287	10-Feb-21	HASSAN	220	HV1	KADUR_220	09:20	10:21	01:01	TRANSFORMER FAULT
288	10-Feb-21	HASSAN	220	HV2	KADUR_220	09:20	10:24	01:04	TRANSFORMER FAULT
289	10-Feb-21	HASSAN	110	HV2	KADUR_220	09:20	10:31	01:11	TRANSFORMER FAULT
290	10-Feb-21	HASSAN	110	LV1	KADUR_220	09:20	10:21	01:01	TRANSFORMER FAULT
291	10-Feb-21	HASSAN	110	LV2	KADUR_220	09:20	10:24	01:04	TRANSFORMER FAULT
292	10-Feb-21	HASSAN	110	KADUR-NERELEKERE	KADUR_220	09:20	10:27	01:07	LINE FAULT
293	10-Feb-21	HASSAN	110	KADUR-NGNHL	KADUR_220	09:20	10:27	01:07	LINE FAULT
294	10-Feb-21	HASSAN	110	KADUR-TNGL	KADUR_220	09:20	10:27	01:07	LINE FAULT
295	10-Feb-21	HASSAN	110	KADUR-YGTI	KADUR_220	09:20	10:27	01:07	LINE FAULT
296	10-Feb-21	HASSAN	110	HV1	KALLUSADARAHALLY_110	11:07	11:11	00:04	HAND TRIPPED
297	10-Feb-21	HASSAN	110	HV1	KALLUSADARAHALLY_110	12:15	12:34	00:19	LINE CLEAR AVAILED
298	10-Feb-21	HASSAN	110	HV1	KONAJE_110	09:53	17:24	07:31	LINE CLEAR AVAILED
299	10-Feb-21	HASSAN	110	HV1	SHIVAPUR_110	09:38	09:57	00:19	MAIN SUPPLY FAILURE
300	10-Feb-21	HASSAN	66	HASN22-HN PURA	HASSAN_220	12:40	12:59	00:19	HAND TRIPPED
301	10-Feb-21	HASSAN	66	HV1	BALEHONNUR_66	12:56	13:18	00:22	LINE CLEAR AVAILED
302	10-Feb-21	HASSAN	66	HV1	RAMESHWARNAGAR_66	11:37	13:59	02:22	LINE CLEAR AVAILED
303	10-Feb-21	HASSAN	66	HV2	RAMESHWARNAGAR_66	10:37	12:02	01:25	LINE CLEAR AVAILED
304	10-Feb-21	HASSAN	66	HV2	RAMESHWARNAGAR_66	17:45	18:10	00:25	LOAD CURTAILMENT
305	10-Feb-21	HASSAN	66	HV2	SALAGAME_66	17:45	19:03	01:18	LOAD CURTAILMENT
306	10-Feb-21	HASSAN	66	HV2	SINGAPURA_66	17:45	18:12	00:27	LOAD CURTAILMENT
307	10-Feb-21	HASSAN	66	HV2	BASAVAGHATTA_66	17:51	18:03	00:12	LOAD CURTAILMENT
308	10-Feb-21	MYSORE	66	HV2	ADDIHALLI_66	17:50	17:53	0:02	LOAD CURTAILMENT
309	10-Feb-21	MYSORE	66	HV2	AKKIHEBBAL_66	17:45	17:51	0:06	LOAD CURTAILMENT
310	10-Feb-21	MYSORE	66	HV1	BGPURA_66	11:57	12:45	0:47	LINE CLEAR AVAILED
311	10-Feb-21	MYSORE	66	HV1	BGPURA_66	17:50	18:00	0:10	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
312	10-Feb-21	MYSORE	66	HV1	BILIKERE_66	17:51	18:01	0:10	LOAD CURTAILMENT
313	10-Feb-21	MYSORE	66	HV2	BILIKERE_66	13:30	14:02	0:32	LINE CLEAR AVAILED
314	10-Feb-21	MYSORE	66	HV1	BOOKANAKERE_66	9:34	15:03	5:29	LINE CLEAR AVAILED
315	10-Feb-21	MYSORE	66	HV2	BOOKANAKERE_66	9:34	15:03	5:29	LINE CLEAR AVAILED
316	10-Feb-21	MYSORE	66	HV2	BOOKANAKERE_66	17:40	17:51	0:11	LOAD CURTAILMENT
317	10-Feb-21	MYSORE	66	HV2	CHINAKURALI_66	17:43	17:54	0:11	LOAD CURTAILMENT
318	10-Feb-21	MYSORE	66	HV1	CHANDAKAVADI_66	13:37	13:56	0:19	LINE CLEAR AVAILED
319	10-Feb-21	MYSORE	66	HV1	DATTAGALLY_66	6:25 (10/02/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
320	10-Feb-21	MYSORE	66	HV1	DODDINADUVADI_66	17:51	18:01	0:09	LOAD CURTAILMENT
321	10-Feb-21	MYSORE	66	HV2	DODDARAYAPET_66	17:51	18:10	0:18	LOAD CURTAILMENT
322	10-Feb-21	MYSORE	66	HV1	HAMPAPURA_66	11:01	11:36	0:34	LINE CLEAR AVAILED
323	10-Feb-21	MYSORE	66	HANAGODU-PONNAMPETE	NO STATION EFFECTED	18:30 (10/02/2021)			LINE OPEN:LINE CLEAR AVAILED
324	10-Feb-21	MYSORE	220	HOOTAGALLY-BASTIPURA-1	NO STATION EFFECTED	10:43	15:47	5:04	NFBC ISSUED
325	10-Feb-21	MYSORE	66	HOOTAGALLY-ELAWALA	NO STATION EFFECTED	10:16	16:34	6:18	LINE CLEAR AVAILED
326	10-Feb-21	MYSORE	66	HOOTAGALLY-HUNSUR	NO STATION EFFECTED	10:15	16:33	6:17	LINE CLEAR AVAILED
327	10-Feb-21	MYSORE	66	HOOTAGALLY-BELAGOLA	NO STATION EFFECTED	9:45	16:35	6:50	LINE CLEAR AVAILED
328	10-Feb-21	MYSORE	66	HOOTAGALLY-KHB	NO STATION EFFECTED	10:01	16:25	6:24	LINE CLEAR AVAILED
329	10-Feb-21	MYSORE	66	HOOTAGALLY-DODDAKADNUR	NO STATION EFFECTED	9:48	16:38	6:50	LINE CLEAR AVAILED
330	10-Feb-21	MYSORE	220	HV3	HOOTAGALLY_220	10:17	14:38	4:20	LINE CLEAR AVAILED
331	10-Feb-21	MYSORE	66	HV1	HULLAHALLI_66	11:54	13:36	1:41	LINE CLEAR AVAILED
332	10-Feb-21	MYSORE	66	HV2	HULLAHALLI_66	12:29	13:54	1:24	LINE CLEAR AVAILED
333	10-Feb-21	MYSORE	66	HV2	KMDODDI_66	17:45	18:13	0:28	LOAD CURTAILMENT
334	10-Feb-21	MYSORE	66	KR NAGARA-MYSORE-1	MIRLE_66	17:05	17:53	0:48	LINE FAULT
335	10-Feb-21	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	17:11	17:15	0:04	LINE FAULT
336	10-Feb-21	MYSORE	66	MADHUVANAHALLY-HANNUR 1	NO STATION EFFECTED	18:31	18:38	0:06	LINE FAULT
337	10-Feb-21	MYSORE	66	HV2	MALAVALLI_66	10:24	16:35	6:11	LINE CLEAR AVAILED
338	10-Feb-21	MYSORE	66	HV2	MALAVALLI_66	17:46	18:00	0:14	LOAD CURTAILMENT
339	10-Feb-21	MYSORE	66	HV1	NAGAMANGALA_66	17:51	17:58	0:07	LOAD CURTAILMENT
340	10-Feb-21	MYSORE	66	HV1	PANDAVAPURA_66	17:47	17:56	0:09	LOAD CURTAILMENT
341	10-Feb-21	MYSORE	66	HV2	PANDAVAPURA_66	7:18	7:50	0:32	TRANSFORMER FAULT
342	10-Feb-21	MYSORE	66	HV1	PERIYAPATNA_66	11:22	17:14	5:52	LINE CLEAR AVAILED
343	10-Feb-21	MYSORE	66	HV2	PERIYAPATNA_66	17:12	19:00	1:47	LINE CLEAR AVAILED
344	10-Feb-21	MYSORE	66	HV1	SATHEGALA_66	17:45	17:55	0:10	LOAD CURTAILMENT
345	10-Feb-21	MYSORE	66	HV2	SANTHEMARAHALLI_66	17:45	18:01	0:16	LOAD CURTAILMENT
346	10-Feb-21	MYSORE	66	HV2	THALAKADU_66	17:45	0:00	6:15	LOAD CURTAILMENT
347	10-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN:LINE CLEAR AVAILED
348	10-Feb-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
349	10-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
350	10-Feb-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)			LINE OPEN:LINE CLEAR AVAILED
351	10-Feb-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	0:28	17:20	16:51	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
352	10-Feb-21	TUMKUR	110	NITTUR 220kv- AMMASANDRA	AMMASANDRA_110, HEIDELBERGCEMENT_EHT_110, SAMPIGE_110, DODDAGUNI_110	17:29	18:14	0:44	HAND TRIPPED
353	10-Feb-21	TUMKUR	110	TR-1	SHETYKERE_110	7:20	7:30	0:10	LINE CLEAR AVAILED
354	10-Feb-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPAHALLI	KEMPAHALLI_66, AGALKOTE_66	14:35	14:51	0:16	HAND TRIPPED
355	10-Feb-21	TUMKUR	66	TR-2	BEVINAHALLI_66	12:55	13:38	0:43	LINE CLEAR AVAILED
356	10-Feb-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	8:58	19:17	10:19	LINE CLEAR AVAILED
357	10-Feb-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHIT RAHALI_66	8:58	19:15	10:17	LINE CLEAR AVAILED
358	10-Feb-21	TUMKUR	66	TR-3	HARIYABBE_66	17:42	18:04	0:21	TRANSFORMER FAULT
359	10-Feb-21	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	7:18	7:29	0:11	LINE FAULT
360	10-Feb-21	TUMKUR	66	TR-2	HONNUDIKE_66	12:18	12:31	0:13	LINE CLEAR AVAILED
361	10-Feb-21	TUMKUR	66	NEELAGUNDA 220kv- HARAPANAHALLI-1	HARAPANAHALLI_66	18:42	19:06	0:24	LINE FAULT
362	10-Feb-21	TUMKUR	66	SIRA- MADHUGIRI OLD( BADAVANAHALLI)	SIRA_66	11:26	11:28	0:02	LINE CLEAR AVAILED
363	10-Feb-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	3:04	3:08	0:04	TRANSFORMER FAULT
364	10-Feb-21	TUMKUR	66	TR-2	URDIGERE_66	15:01	17:38	2:36	LINE CLEAR AVAILED
365	11-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
366	11-Feb-21	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	13:01	13:25	0:24	TRANSFORMER FAULT
367	11-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
368	11-Feb-21	BAGALKOT	110	110/11KV, HV2	HANAGAL_110	00:12	00:20	0:08	TRANSFORMER FAULT
369	11-Feb-21	BAGALKOT	110	110/11KV, HV2	HANAGAL_110	08:57	09:05	0:08	TRANSFORMER FAULT
370	11-Feb-21	BAGALKOT	110	110/11KV, HV3	MUNDARGI_110	14:15	14:25	0:10	TRANSFORMER FAULT
371	11-Feb-21	BAGALKOT	110	ANKOLA-ARGA(L1)	ANKOLA_110 (STATION NOT AFFECTED)	12:30	14:38	2:08	LINE CLEAR AVAILED
372	11-Feb-21	BAGALKOT	110	BANAHATTI-JAMAKHANDI (NAVALAGI)	NAVALAGI_110	15:53	17:02	1:09	LINE CLEAR AVAILED
373	11-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN: LINE CLEAR AVAILED
374	11-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN: LINE CLEAR AVAILED
375	11-Feb-21	BAGALKOT	110	GAJENDRAGAD1- RON	RON_110	20:11 (11.02.2021)			LINE OPEN: LINE CLEAR AVAILED
376	11-Feb-21	BAGALKOT	110	GAJENDRAGAD-RON 1	RON_110	19:11	19:43	0:32	LINE FAULT
377	11-Feb-21	BAGALKOT	110	GAJENDRAGAD-RON 2	RON_110	19:11			LINE OPEN: LINE FAULT
378	11-Feb-21	BAGALKOT	110	GAMESH- RON	RON_110	19:10	20:16	1:06	LINE CLEAR AVAILED
379	11-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
380	11-Feb-21	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
381	11-Feb-21	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
382	11-Feb-21	BAGALKOT	110	ITANAL- RAIBAG2	ITANAL_110	18:16 (11.02.2021)			LINE OPEN: LINE FAULT
383	11-Feb-21	BAGALKOT	110	JAMKHANDI- MAHALINGAPUR (NAVALGI)	NAVALAGI_110	16:28	16:35	0:07	HAND TRIPPED
384	11-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
385	11-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
386	11-Feb-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMATA_110	19:03 (01.02.2021)	12:29 (11.02.2021)	233:26 hrs	LINE CHARGED
387	11-Feb-21	BAGALKOT	110	KUMTA-SIRSI2	STATION NOT AFFECTED KUMATA_110	19:01 (01.02.2021)	12:29 (11.02.2021)	233:28 hrs	LINE CHARGED
388	11-Feb-21	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	19:31	19:37	0:06	HAND TRIPPED
389	11-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
390	11-Feb-21	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	STATION NOT AFFECTED MALGHAN(S)_110	23:47 (10.02.2021)	00:10 (11.02.2021)	0:23 hrs	LINE CHARGED
391	11-Feb-21	BAGALKOT	110	NAREGAL- RON	RON_110	19:45	20:11	0:26	HAND TRIPPED
392	11-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
393	11-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
394	11-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
395	11-Feb-21	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	19:10	20:15	1:05	LINE FAULT
396	11-Feb-21	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	STATION NOT AFFECTED SIDDAPUR_110	9:23 (10.02.2021)	18:57 (11.02.2021)	33:34 hrs	LINE CHARGED
397	11-Feb-21	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MKHUBLI_220	11:31	12:56	1:25	LINE CLEAR AVAILED
398	11-Feb-21	BAGALKOT	220	220/110KV,HV2&LV2	STATION NOT AFFECTED GADAG_220	12:30	18:36	6:06	LINE CLEAR AVAILED
399	11-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVAILED
400	11-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
401	11-Feb-21	BAGALKOT	220	BIJAPUR-VAISHALI 1&2	STATION NOT AFFECTED BIJAPUR_220	12:17	18:05	5:48	LINE CLEAR AVAILED
402	11-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
403	11-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
404	11-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
405	11-Feb-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
406	11-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
407	11-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
408	11-Feb-21	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	10:55	11:01	00:06	LINE CLEAR AVAILED
409	11-Feb-21	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI	10:55	11:28	00:33	LINE CLEAR AVAILED
410	11-Feb-21	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	14:58	15:30	00:32	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
411	11-Feb-21	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN	10:55	12:10	01:15	LINE CLEAR AVAILED
412	11-Feb-21	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	13:37	13:42	00:05	LOAD CHANGE OVER
413	11-Feb-21	BENGALURU	66	BMTC - EDC 220	BMTC	10:55	11:55	01:00	LINE CLEAR AVAILED
414	11-Feb-21	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	08:42	08:51	00:09	LINE FAULT
415	11-Feb-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	05:26	05:33	00:06	LINE FAULT
416	11-Feb-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	05:34	09:18	03:43	LINE FAULT
417	11-Feb-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	09:19	09:21	00:02	LINE FAULT
418	11-Feb-21	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	09:40	10:10	00:30	LOAD CHANGE OVER
419	11-Feb-21	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	18:00	18:10	00:10	LOAD CHANGE OVER
420	11-Feb-21	BENGALURU	66	DOMMASANDRA - SARJAPURA 220	DOMMASANDRA	10:35	10:40	00:05	LOAD CHANGE OVER
421	11-Feb-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	13:16	13:21	00:05	LOAD CHANGE OVER
422	11-Feb-21	BENGALURU	66	GUDIBANDE - GOWRIBIDANUR 220	GUDIBANDE	14:10	14:31	00:21	LINE CLEAR AVAILED
423	11-Feb-21	BENGALURU	66	HAL 220 - ADUGODI 1	LEELA VENTURE	10:55	13:08	02:13	LINE CLEAR AVAILED
424	11-Feb-21	BENGALURU	66	HAL 220 - ADUGODI 2	AMAR JYOTHI	10:55	13:08	02:13	LINE CLEAR AVAILED
425	11-Feb-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	10:55	13:08	02:13	LINE CLEAR AVAILED
426	11-Feb-21	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	10:55	13:08	02:13	LINE CLEAR AVAILED
427	11-Feb-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	12:25	12:30	00:05	LOAD CHANGE OVER
428	11-Feb-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	14:50	14:51	01:00	LOAD CHANGE OVER
429	11-Feb-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	13:45	13:50	00:05	LOAD CHANGE OVER
430	11-Feb-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	15:50	15:55	00:05	LOAD CHANGE OVER
431	11-Feb-21	BENGALURU	66	HV1	EDC 220	10:55	11:18	00:23	LINE CLEAR AVAILED
432	11-Feb-21	BENGALURU	66	HV1	NAGANATHPURA 220	10:55	10:59	00:04	TRANSFORMER FAULT
433	11-Feb-21	BENGALURU	66	HV1	ATTUR YELAHANKA	14:43	15:04	00:21	LINE CLEAR AVAILED
434	11-Feb-21	BENGALURU	66	HV1	SARJAPURA 220	14:56	15:05	00:09	TRANSFORMER FAULT
435	11-Feb-21	BENGALURU	66	HV1	TEKAL	12:45	13:30	00:45	LINE CLEAR AVAILED
436	11-Feb-21	BENGALURU	66	HV1	MALUR 66	11:10	11:30	00:20	LINE CLEAR AVAILED
437	11-Feb-21	BENGALURU	66	HV1	MAASTHI	11:08	11:31	00:22	LINE CLEAR AVAILED
438	11-Feb-21	BENGALURU	66	HV2	EDC 220	10:55	11:18	00:23	LINE CLEAR AVAILED
439	11-Feb-21	BENGALURU	66	HV2	SRIGANDA KAVALU	12:21	12:25	00:04	LINE CLEAR AVAILED
440	11-Feb-21	BENGALURU	66	HV2	L R BANDE	11:00	11:05	00:05	LINE CLEAR AVAILED
441	11-Feb-21	BENGALURU	66	HV2	ATTUR YELAHANKA	14:27	14:42	00:15	LINE CLEAR AVAILED
442	11-Feb-21	BENGALURU	66	HV2	MALUR 66	10:40	10:45	00:05	TRANSFORMER FAULT
443	11-Feb-21	BENGALURU	66	HV2	MAASTHI	07:33	07:50	00:17	TRANSFORMER FAULT
444	11-Feb-21	BENGALURU	66	HV3	CB PURA I/A	12:20	12:26	00:06	TRANSFORMER FAULT
445	11-Feb-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA	08:45	08:55	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
446	11-Feb-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:05	11:29	00:24	LINE FAULT
447	11-Feb-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	12:10	12:27	00:17	LINE FAULT
448	11-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	18:08	18:18	00:10	LINE FAULT
449	11-Feb-21	BENGALURU	66	KORAMANGALA 220 - HAL 2	K & C VALLEY, GOLF LINKS	13:15	13:50	00:35	LINE FAULT
450	11-Feb-21	BENGALURU	66	KYALANUR - TALAGWARA	NO STATION AFFECTED	06:07	06:22	00:14	LINE FAULT
451	11-Feb-21	BENGALURU	66	KYALANUR - VEMGAL	KYALANUR	06:07	06:21	00:14	LINE FAULT
452	11-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	17:34	17:39	00:05	LINE FAULT
453	11-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	10:43	10:48	00:04	LINE FAULT
454	11-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	15:20	16:53	01:33	LINE FAULT
455	11-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	17:58	18:08	00:10	LINE FAULT
456	11-Feb-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	15:39	16:27	00:47	LINE CLEAR AVAILED
457	11-Feb-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	12:45	12:54	00:09	LINE CLEAR AVAILED
458	11-Feb-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	11:43	12:04	00:21	LINE FAULT
459	11-Feb-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	13:16	16:15	02:59	LINE CLEAR AVAILED
460	11-Feb-21	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	10:55	10:59	00:04	LINE FAULT
461	11-Feb-21	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	10:56	11:28	00:32	LINE CLEAR AVAILED
462	11-Feb-21	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	10:55	11:28	00:33	LINE CLEAR AVAILED
463	11-Feb-21	BENGALURU	66	NIMHANS 220 - NATIONAL COLLEGE	NATIONAL COLLEGE	10:56	12:30	01:34	LINE CLEAR AVAILED
464	11-Feb-21	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	10:53	11:10	00:17	MAIN SUPPLY FAILURE
465	11-Feb-21	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	15:14	15:18	00:04	LOAD CHANGEOVER
466	11-Feb-21	BENGALURU	66	PALLICHERLU - GANJIGUNTE	PALLICHERLU	08:42	08:52	00:10	MAIN SUPPLY FAILURE
467	11-Feb-21	BENGALURU	66	PERESANDRA - MANDIKAL	PERESANDRA	14:55	15:00	00:05	LOAD CHANGEOVER
468	11-Feb-21	BENGALURU	66	PERESANDRA - MITTEMARI 220	PERESANDRA	10:00	11:10	00:10	LOAD CHANGEOVER
469	11-Feb-21	BENGALURU	66	REMCO - SUBRAMANYAPURA	NO STATION AFFECTED	08:13	12:22	04:09	LINE CLEAR AVAILED
470	11-Feb-21	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	08:13	08:41	00:28	MAIN SUPPLY FAILURE
471	11-Feb-21	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	12:26	12:36	00:10	LOAD CHANGEOVER
472	11-Feb-21	BENGALURU	66	SADLI- JULLUPALYA	SADLI, DIBBURAHALLI	07:34	07:46	00:11	LINE FAULT
473	11-Feb-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	19:59	21:09	01:10	LINE FAULT
474	11-Feb-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT), RR NAGAR	08:13	08:41	00:28	LINE FAULT
475	11-Feb-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	14:15	15:20	01:05	LINE CLEAR AVAILED
476	11-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:15	15:20	01:05	LINE CLEAR AVAILED
477	11-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:15	15:20	01:05	LINE CLEAR AVAILED
478	11-Feb-21	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 1	HALAGUR	14:15	15:20	01:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
479	11-Feb-21	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	13:32	13:35	00:03	LOAD CHANGEVER
480	11-Feb-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	17:30	17:35	00:05	LOAD CHANGEVER
481	11-Feb-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	01:40	02:01	00:21	LINE FAULT
482	11-Feb-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	NO STATION AFFECTED	05:03	07:40	02:37	LINE CLEAR AVAILED
483	11-Feb-21	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	NO STATION AFFECTED	07:40	12:55	05:15	LINE FAULT
484	11-Feb-21	BENGALURU	220	EDC 220 - HAL 220	EDC 220	10:55	11:17	00:22	MAIN SUPPLY FAILURE
485	11-Feb-21	BENGALURU	220	EDC 220 - NIMHANS 220	NIMHANS 220	10:55	11:28	00:33	MAIN SUPPLY FAILURE
486	11-Feb-21	BENGALURU	220	HAL 220 - HOODY 1	HAL 220	10:55	12:38	01:43	MAIN SUPPLY FAILURE
487	11-Feb-21	BENGALURU	220	HAL 220 - HOODY 2	HAL 220	10:55	13:06	02:11	LINE FAULT
488	11-Feb-21	BENGALURU	220	HOODY 400 - HAL 1	HAL 1	10:55	12:11	01:16	LINE FAULT
489	11-Feb-21	BENGALURU	220	HOODY 400 - HAL 2	HAL 2	10:55	13:06	02:11	LINE FAULT
490	11-Feb-21	BENGALURU	220	HV1	EDC 220	10:55	11:28	00:33	MAIN SUPPLY FAILURE
491	11-Feb-21	BENGALURU	220	HV1	NIMHANS 220	10:55	11:28	00:33	LINE CLEAR AVAILED
492	11-Feb-21	BENGALURU	220	HV1	T K HALLI 220	14:15	15:18	01:03	LINE CLEAR AVAILED
493	11-Feb-21	BENGALURU	220	HV2	EDC 220	10:55	11:28	00:33	MAIN SUPPLY FAILURE
494	11-Feb-21	BENGALURU	220	HV2	NIMHANS 220	10:55	11:28	00:33	LINE CLEAR AVAILED
495	11-Feb-21	BENGALURU	220	HV2	T K HALLI 220	14:15	15:18	01:03	LINE CLEAR AVAILED
496	11-Feb-21	BENGALURU	220	MAGADI 220 - NELAMANGALA 400	MAGADI 220	05:34	06:17	00:42	LINE FAULT
497	11-Feb-21	BENGALURU	220	NIMHANS 220 - EDC 220	NIMHANS 220	10:55	11:28	00:33	MAIN SUPPLY FAILURE
498	11-Feb-21	BENGALURU	220	TK HALLI 220 - VAJAMANGALA 220	T K HALLI 220	14:15	15:18	01:03	MAIN SUPPLY FAILURE
499	11-Feb-21	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	11:45	11:53	00:08	LINE FAULT
500	11-Feb-21	GULBARGA	110	GULBARGA UNIVERSITY-GULBARGA NORTH2	GULBARGA UNIVERSITY_110	13:25	13:30	00:05	MAIN SUPPLY FAILURE
501	11-Feb-21	GULBARGA	110	HALBARGA-CHIDRI	CHIDRI_110	16:27(10.02.2021)	13:32(11.02.2021)	21:05HRS	LINE CHARGED
502	11-Feb-21	GULBARGA	110	HV1	KURKUNTA_110	10:30	13:30	03:00	LINE CLEAR AVAILED
503	11-Feb-21	GULBARGA	110	HV1	CHINCHOLLI_110	09:20	10:00	00:40	LINE CLEAR AVAILED
504	11-Feb-21	GULBARGA	110	HV1	CHINCHOLLI_110	17:50	18:48	00:58	LINE CLEAR AVAILED
505	11-Feb-21	GULBARGA	110	HV2	BISIHALLI_110	10:30	11:00	00:30	LINE CLEAR AVAILED
506	11-Feb-21	GULBARGA	110	HV2	SINDHANOOR_110	09:15	09:25	00:10	TRANSFORMER FAULT
507	11-Feb-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	18:00(10.02.2021)	2:38(11.02.2021)	8:38 hrs	LINE CHARGED
508	11-Feb-21	GULBARGA	110	KUSHTAGI-KUSHTAGISOLAR_IPP	KUSHTAGI_220	06:40	07:31	00:51	LINE FAULT
509	11-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	20:33	20:42	00:09	LINE FAULT
510	11-Feb-21	GULBARGA	110	SHAHAPUR-WARDHASOLAR_IPP	SHAHAPUR_220	19:24	22:10	02:46	LINE FAULT
511	11-Feb-21	GULBARGA	220	RTPS-LINGSUGUR2	LINGSUGUR_220	9:32:00 AM(10.02.2021)	16:46(11.02.2021)	31:14HRS	NFBC ISSUED
512	11-Feb-21	HASSAN	66	HASSN220-R R NAGAR	HASSAN_220	17:12	17:15	00:03	HAND TRIPPED
513	11-Feb-21	HASSAN	66	HV1	BALLUPETE_66	13:43	14:00	00:17	HAND TRIPPED
514	11-Feb-21	HASSAN	66	HV1	HAGARE_66	13:37	13:43	00:06	LINE CLEAR AVAILED
515	11-Feb-21	HASSAN	66	HV1	HALEBEEDU_66	10:10	10:15	00:05	HAND TRIPPED
516	11-Feb-21	HASSAN	66	HV1	HANGARANAHALLY_66	12:30	14:20	01:50	LINE CLEAR AVAILED
517	11-Feb-21	HASSAN	66	HV1	KIADB_66	11:30	12:45	01:15	LINE CLEAR AVAILED
518	11-Feb-21	HASSAN	66	HV2	CHIKMAGALUR_66	16:30	18:10	01:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
519	11-Feb-21	HASSAN	66	HV2	HALEBEEDU_66	10:10	10:15	00:05	HAND TRIPPED
520	11-Feb-21	HASSAN	66	HV2	KIADB_66	10:30	11:40	01:10	LINE CLEAR AVAILED
521	11-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	08:53	09:02	00:09	TRANSFORMER FAULT
522	11-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
523	11-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
524	11-Feb-21	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	13:41	14:41	01:00	LINE FAULT
525	11-Feb-21	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	09:54	13:41	03:47	LINE CLEAR AVAILED
526	11-Feb-21	HASSAN	220	VARAH1-SHMG3	varahi_gen	13:41	14:41	01:00	LINE CLEAR AVAILED
527	11-Feb-21	HASSAN	220	VARAH1-SHMG3	varahi_gen	09:54	13:41	03:47	LINE FAULT
528	11-Feb-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	11:01(10.2.2021)			LINE OPEN:LINE CLEAR AVAILED
529	11-Feb-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:01 (11.02.2021)			LINE OPEN: LINE FAULT
530	11-Feb-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:43	21:00	03:17	LINE FAULT
531	11-Feb-21	MYSORE	66	BANNUR-MALIYUR	MALIYURU_66	7:27	7:41	0:14	LINE FAULT
532	11-Feb-21	MYSORE	66	HANAGODU-PONNAMPETE	NO STATION EFFECTED	18:30 (10/02/2021)	9:10 (11/02/2021)	14:40 HRS	LINE CHARGED
533	11-Feb-21	MYSORE	66	HANNUR-KOTTHANUR	NO STATION EFFECTED	14:23	14:36	0:12	LINE FAULT
534	11-Feb-21	MYSORE	66	HD KOTE-TARAKA	ANTHARSANTHE_66	15:30	15:45	0:15	HAND TRIPPED
535	11-Feb-21	MYSORE	66	HUNSUR-HANAGODU	NO STATION EFFECTED	9:18	15:49	6:30	LINE CLEAR AVAILED
536	11-Feb-21	MYSORE	66	HV1	ADDIHALLI_66	12:05	12:19	0:14	TRANSFORMER FAULT
537	11-Feb-21	MYSORE	66	HV1	DATTAGALLY_66	19:31	21:40	2:09	LINE CLEAR AVAILED
538	11-Feb-21	MYSORE	66	HV1	DATTAGALLY_66	6:25 (10/02/2021)	19:15 (11/02/2021)	36:50 HRS	TRANSFORMER CHARGED
539	11-Feb-21	MYSORE	66	HV2	DATTAGALLY_66	19:22	21:10	1:47	TRANSFORMER FAULT
540	11-Feb-21	MYSORE	66	HV2	PERIYAPATNA_66	12:18	18:25	6:06	LINE CLEAR AVAILED
541	11-Feb-21	MYSORE	66	KADAKOLA-SARAGUR 1	ANTHARSANTHE_66 B MATKERE_66 CHANDRAVADI_66 HDKOTE_66 HAMPAPURA(K)_66 DOORA_66 HURA_66 HULLAHALLI_66 JAIPUR_66 SANTHESARAGUR_66	15:00	15:12	0:12	LINE FAULT
542	11-Feb-21	MYSORE	66	KADAKOLA-SARAGUR 2	ANTHARSANTHE_66 B MATKERE_66 CHANDRAVADI_66 HDKOTE_66 HAMPAPURA(K)_66 DOORA_66 HURA_66 HULLAHALLI_66 JAIPUR_66 SANTHESARAGUR_66	15:00	15:12	0:12	LINE FAULT
543	11-Feb-21	MYSORE	66	KIRUGAVLU-MALIYUR	MALIYURU_66	7:26	7:44	0:18	LINE FAULT
544	11-Feb-21	MYSORE	66	KIRUGAVLU-MALIYUR	MALIYURU_66	15:42	16:40	0:57	LINE FAULT
545	11-Feb-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
546	11-Feb-21	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66	14:00	14:05	0:05	LINE FAULT
547	11-Feb-21	MYSORE	66	PERIYAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	16:15	17:25	1:09	LINE CLEAR AVAILED
548	11-Feb-21	MYSORE	66	PERIYAPATNA-HUNSUR	NO STATION EFFECTED	15:04	18:05	3:00	LINE CLEAR AVAILED
549	11-Feb-21	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 1	NO STATION EFFECTED	14:55	16:25	1:30	LINE CLEAR AVAILED
550	11-Feb-21	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 1	NO STATION EFFECTED	17:20	17:25	0:05	HAND TRIPPED
551	11-Feb-21	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 2	NO STATION EFFECTED	16:20	18:05	1:45	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
552	11-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN:LINE CLEAR AVAILED
553	11-Feb-21	MYSORE	66	TALAKADU-ADANI	THALAKADU_66	10:02	16:14	6:11	LINE CLEAR AVAILED
554	11-Feb-21	MYSORE	66	TALAKADU-ADANI	NO STATION EFFECTED	18:40	19:47	1:07	LINE CLEAR AVAILED
555	11-Feb-21	MYSORE	66	TALAKADU-CHANDHALLY	THALAKADU_66	10:00	16:00	6:00	LINE CLEAR AVAILED
556	11-Feb-21	MYSORE	66	TALAKADU-PARINAMIPURA	THALAKADU_66	10:02	16:00	5:57	LINE CLEAR AVAILED
557	11-Feb-21	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	12:15	12:20	0:05	LINE FAULT
558	11-Feb-21	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	12:30	12:35	0:05	LINE FAULT
559	11-Feb-21	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	11:36	11:42	0:06	LINE FAULT
560	11-Feb-21	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	16:51	0:00	7:08	LINE FAULT
561	11-Feb-21	MYSORE	220	BEGUR 220-CR NAGARA 1	CRNAGAR_220 ATTIGULIPURA_66 BADANAGUPPE_66 BHARGI_66 BOMMALAPURA_66 CHANDAKAVADI_66 DODDARAYAPET_66 GUNDULPET_66 HANGLA_66 HARVEY_66 HONNALLY_MYS_66 KABHALLY_66 TERAkanAMBE_66 YELANDUR_66	15:00	15:15	0:15	HAND TRIPPED
562	11-Feb-21	MYSORE	220	BEGUR 220-CR NAGARA 2	CRNAGAR_220 ATTIGULIPURA_66 BADANAGUPPE_66 BHARGI_66 BOMMALAPURA_66 CHANDAKAVADI_66 DODDARAYAPET_66 GUNDULPET_66 HANGLA_66 HARVEY_66 HONNALLY_MYS_66 KABHALLY_66 TERAkanAMBE_66 YELANDUR_66	15:00	15:15	0:15	HAND TRIPPED
563	11-Feb-21	MYSORE	220	HOOTAGALLY-KADAKOLA	NO STATION EFFECTED	11:47	18:26	6:38	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
564	11-Feb-21	MYSORE	220	HOOTAGALLY-VAJAMANGALA	VAJAMANGALA_220 AYRALI_66 BANNUR_66 BGPURA_66 CHIDRAVALI_66 DEVANOORMYS_66 DKMAIDANA_66 GARGESHWARI_66 JYOTHINAGARA_66 MALIYURU_66 MARADIHUNDI_66 MEGALAPURA_66 RAJEEVNAGARA_66 SFCSHIVA_66 THUMBLA_66 THUMBLA_66 VADKEPURA_66 VYASRAJPURA_66	15:00	16:07	1:07	LINE FAULT
565	11-Feb-21	MYSORE	220	KADAKOLA-BEGUR 1	BEGUR_220 BEGUR_66 NANJANGUDU_66 SINDHUVALI_66	15:00	15:11	0:11	LINE FAULT
566	11-Feb-21	MYSORE	220	KADAKOLA-BEGUR 2	BEGUR_220 BEGUR_66 NANJANGUDU_66 SINDHUVALI_66	15:00	15:12	0:12	LINE FAULT
567	11-Feb-21	MYSORE	220	KUSHALANAGARA 220-BASTIPURA-1	NO STATION EFFECTED	10:33	13:21	2:48	NFBC ISSUED
568	11-Feb-21	MYSORE	220	MADHUVANAHALLI-CR NAGARA 1	MADHUVANAHALLI_220 AJJIPURA_66 CHANDALLI_66 COWDALLI_66 DODDINADUVADI_66 HANNUR_66 JANNUR_66 KOLLEGALA_66 KOTTANUR_66 KUNTHUR_66 MAMBALLI_66 MUGUR_66 PARINAMIPURA_66 PGPALYA_66 RAMAPURA_MYS_66 SANTHEMARAHALLI_66 SATHEGALA_66 THALAKADU_66 THAYURU_66 TNARASIPURA_66	15:05	15:18	0:13	HAND TRIPPED
569	11-Feb-21	MYSORE	220	MADHUVANAHALLI-CR NAGARA 2	MADHUVANAHALLI_220 AJJIPURA_66 CHANDALLI_66 COWDALLI_66 DODDINADUVADI_66 HANNUR_66 JANNUR_66 KOLLEGALA_66 KOTTANUR_66 KUNTHUR_66 MAMBALLI_66 MUGUR_66 PARINAMIPURA_66 PGPALYA_66 RAMAPURA_MYS_66 SANTHEMARAHALLI_66 SATHEGALA_66 THALAKADU_66 THAYURU_66 TNARASIPURA_66	15:05	15:18	0:13	HAND TRIPPED
570	11-Feb-21	MYSORE	220	MADHUVANAHALLI-HEBBANI 1	HEBBANI_220	15:07	15:36	0:28	HAND TRIPPED
571	11-Feb-21	MYSORE	220	MADHUVANAHALLI-HEBBANI 2	HEBBANI_220	15:07	15:25	0:17	HAND TRIPPED
572	11-Feb-21	MYSORE	220	MADHUVANAHALLI-WARDA SOLAR	NO STATION EFFECTED	15:08	15:18	0:10	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
573	11-Feb-21	MYSORE	220	VAJMANGALA-TK HALLI	TK HALLI_220 K_HONNALGERE_66 KIADBMANDYA_66 KMDODDI_66 KOLKARANADODDI_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	15:05	16:18	1:13	LINE CLEAR AVAILED
574	11-Feb-21	TUMKUR	66	BADAVANAHALLI-MADHUGIRI	BADAVANAHALLI_66	09:01	09:12	0:10	LINE FAULT
575	11-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	06:50	07:06	0:15	LINE FAULT
576	11-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:24	15:29	0:04	LINE FAULT
577	11-Feb-21	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	18:44	18:58	0:14	MAIN SUPPLY FAILURE
578	11-Feb-21	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	18:43	18:59	0:16	MAIN SUPPLY FAILURE
579	11-Feb-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	06:49	07:02	0:12	LINE FAULT
580	11-Feb-21	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	07:28	07:31	0:03	LINE FAULT
581	11-Feb-21	TUMKUR	66	LINGADHALLI-SHIMOGA	LINGDHALLI_66	08:57	09:30	0:32	LINE FAULT
582	11-Feb-21	TUMKUR	66	TR-1	HANAGAL_66	18:43	18:58	0:15	MAIN SUPPLY FAILURE
583	11-Feb-21	TUMKUR	66	TR-2	HANAGAL_66	18:43	18:58	0:15	MAIN SUPPLY FAILURE
584	11-Feb-21	TUMKUR	66	TR-2	HONNUDIKE_66	10:03	12:00	1:56	LINE CLEAR AVAILED
585	11-Feb-21	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	07:04	07:36	0:32	LOAD CURTAILMENT
586	11-Feb-21	TUMKUR	110	TR-1	KBCROSS_220	11:57	12:01	0:04	HAND TRIPPED
587	11-Feb-21	TUMKUR	110	TR-2	NITTUR_220	16:43	17:48	1:04	LINE CLEAR AVAILED
588	11-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	10:10:07 AM(31.12.2020)	3:09:00 PM(11.02.2021)		LINE OPEN:LINE CLEAR AVAILED
589	11-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	3:11:29 PM(11.02.2021)			LINE OPEN: LINE FAULT
590	11-Feb-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:11:32 AM(31.12.2020)	3:11:04 PM(11.02.2021)		LINE OPEN:LINE CLEAR AVAILED
591	11-Feb-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	3:12:29 PM(11.02.2021)			LINE OPEN: LINE FAULT
592	11-Feb-21	TUMKUR	220	MADHUGIRI 220kV- GOWRIBIDANUR220	MADHUGIRI 220kV	15:45	16:19	0:34	LINE FAULT
593	12-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
594	12-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
595	12-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
596	12-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
597	12-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
598	12-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
599	12-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
600	12-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
601	12-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
602	12-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
603	12-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
604	12-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
605	12-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
606	12-Feb-21	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
607	12-Feb-21	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
608	12-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVAILED
609	12-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
610	12-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
611	12-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
612	12-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
613	12-Feb-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
614	12-Feb-21	BAGALKOT	110	GAJENDRAGAD- RON 2	RON_110	19:11 (11.02.2021)	13:02 (12.02.2021)	17:35HRS	LINE CHARGED
615	12-Feb-21	BAGALKOT	110	GAJENDRAGAD1- RON	RON_110	20:11 (11.02.2021)	12:59 (12.02.2021)	16:48HRS	LOAD CHANGE OVER
616	12-Feb-21	BAGALKOT	110	ITANAL- RAIBAG2	ITANAL_110	18:16 (11.02.2021)	0:18 (12.02.2021)	6:02HRS	LINE CHARGED
617	12-Feb-21	BAGALKOT	110	BANAHATTI-JAMAKHANDI(NAVALAGI)	STATION NOT AFFECTED BANAHATTI_110	11:15	12:47	1:32	LINE CLEAR AVAILED
618	12-Feb-21	BAGALKOT	110	110/33KV,HV1	BELGAUM_110,RM2_33,FORT_33,S ADASHIVANAGAR_33,KLE_33,SHRI NAGA GIS_33	09:09	10:03	0:54	TRANSFORMER FAULT
619	12-Feb-21	BAGALKOT	110	110/33KV,HV2	BELGAUM_110	9:09	18:56	9:47	TRANSFORMER FAULT
620	12-Feb-21	BAGALKOT	110	DAMBAL-MUNDARGI1&2	MUNDARGI_110	16:22	16:30	0:08	HAND TRIPPED
621	12-Feb-21	BAGALKOT	110	DAMBAL-GADAG1	DAMBAL_110	15:55	16:22	0:27	LINE FAULT
622	12-Feb-21	BAGALKOT	110	DAMBAL-SUZLON1&2	DAMBAL_110	15:55	16:24	0:29	HAND TRIPPED
623	12-Feb-21	BAGALKOT	110	DAMBAL-ENERCON1&2	DAMBAL_110	15:55	16:22	0:27	HAND TRIPPED
624	12-Feb-21	BAGALKOT	110	DAMBAL-GADAG1	DAMBAL_110	19:10	20:42	1:32	LINE CLEAR AVAILED
625	12-Feb-21	BAGALKOT	110	DAMBAL-SUZLON1&2	DAMBAL_110	19:10	20:45	1:35	LINE CLEAR AVAILED
626	12-Feb-21	BAGALKOT	110	DAMBAL-ENERCON1&2	DAMBAL_110	19:10	20:45	1:35	LINE CLEAR AVAILED
627	12-Feb-21	BAGALKOT	110	110/11KV,HV1&HV2	KULIGERI CROSS_110	8:28	9:05	0:37	LINE CLEAR AVAILED
628	12-Feb-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	9:13	13:56	4:43	NFBC ISSUED
629	12-Feb-21	BAGALKOT	110	RAIBAG-CHIKKODI1	STATION NOT AFFECTED RAIBAG_110	10:27	12:07	1:40	LINE CLEAR AVAILED
630	12-Feb-21	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	12:25	16:59	4:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
631	12-Feb-21	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	12:50 (12.02.2021)			LINE OPEN:LINE CLEAR AVAILED
632	12-Feb-21	BAGALKOT	110	BELAGAUM220-VADAGAON	VADAGAON_110	09:15	09:18	0:03	LINE CLEAR AVAILED
633	12-Feb-21	BAGALKOT	110	BELAGAUM220-VADAGAON	STATION NOT AFFECTED VADAGAON_110	19:34	20:34	1:00	HAND TRIPPED
634	12-Feb-21	BAGALKOT	110	BELAGAUM220-VADAGAON	STATION NOT AFFECTED VADAGAON_110	20:35 (12.02.2021)			LINE OPEN:LINE CLEAR AVAILED
635	12-Feb-21	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	9:00	17:11	8:11	LINE CLEAR AVAILED
636	12-Feb-21	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED SOUDATTI_220	11:08	17:33	6:25	LINE CLEAR AVAILED
637	12-Feb-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED SOUDATTI_220	11:03	17:33	6:30	LINE CLEAR AVAILED
638	12-Feb-21	BAGALKOT	110	SAMBAPUR ROAD-DAMBAL	STATION NOT AFFECTED DAMBAL_110	12:05	15:39	3:34	NFBC ISSUED
639	12-Feb-21	BAGALKOT	110	SAMBAPUR ROAD-DAMBAL	STATION NOT AFFECTED DAMBAL_110	18:35	20:35	2:00	NFBC ISSUED
640	12-Feb-21	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	13:21	13:47	00:26	MAIN SUPPLY FAILURE
641	12-Feb-21	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	17:39	17:41	00:02	LOAD CHANGEOVER
642	12-Feb-21	BENGALURU	66	HV2	BIDADI	15:06	19:36	04:30	LINE CLEAR AVAILED
643	12-Feb-21	BENGALURU	66	HV1	CHANDRA LAYOUT	10:40	10:42	00:02	LINE CLEAR AVAILED
644	12-Feb-21	BENGALURU	66	CHANDRA LAYOUT - VRISHBHAVATHI 220	CHANDRA LAYOUT	13:21	14:12	00:51	MAIN SUPPLY FAILURE
645	12-Feb-21	BENGALURU	66	EPIP 220 - DIVYASHREE TECH PARK	DIVYASHREE TECH PARK	11:38	15:25	03:47	LINE CLEAR AVAILED
646	12-Feb-21	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	11:00	14:23	03:23	LINE CLEAR AVAILED
647	12-Feb-21	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	02:00	02:19	00:19	LINE FAULT
648	12-Feb-21	BENGALURU	66	BANASWADI - ITI 220	BANASWADI	02:53	02:57	00:04	LOAD CHANGEOVER
649	12-Feb-21	BENGALURU	66	IISC - HEBBAL 220	IISC	10:29	10:33	00:04	LOAD CHANGEOVER
650	12-Feb-21	BENGALURU	66	IISC - NRS 220	IISC	15:46	15:51	00:05	LOAD CHANGEOVER
651	12-Feb-21	BENGALURU	66	HV1	KADUGODI	14:23	16:45	02:22	LINE CLEAR AVAILED
652	12-Feb-21	BENGALURU	66	HV2	KADUGODI	14:23	17:10	02:47	LINE CLEAR AVAILED
653	12-Feb-21	BENGALURU	66	PLATINUM CITY - DG4	PLATINUM CITY	12:00	14:05	02:05	LINE CLEAR AVAILED
654	12-Feb-21	BENGALURU	66	REMCO - VRISHABHAVATHI 220	REMCO	13:22	14:19	00:57	MAIN SUPPLY FAILURE
655	12-Feb-21	BENGALURU	220	SOMANAHALLI 220 - VRISHABHAVATHI	VRISHABHAVATHI	13:21	13:45	00:24	LINE FAULT
656	12-Feb-21	BENGALURU	66	HV1	VIJAYANAGARA	13:23	13:35	00:12	MAIN SUPPLY FAILURE
657	12-Feb-21	BENGALURU	220	VRISHABHAVATHI - SOMANAHALLI 220	VRISHABHAVATHI	13:21	14:01	00:40	MAIN SUPPLY FAILURE
658	12-Feb-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	05:33	05:46	00:12	LINE FAULT
659	12-Feb-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	05:47	05:52	00:05	LINE FAULT
660	12-Feb-21	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	19:35	19:42	00:07	LOAD CHANGEOVER
661	12-Feb-21	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	12:31	13:40	01:09	LINE FAULT
662	12-Feb-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	18:48	18:52	00:03	LOAD CHANGEOVER
663	12-Feb-21	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA, KACHMARANAHALLI	12:31	14:10	01:39	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
664	12-Feb-21	BENGALURU	66	SARIAPURA 220 - DOMMASANDRA	DOMMASANDRA, KACHMARANAHALLI	18:50	18:51	00:01	LOAD CHANGEOVER
665	12-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	11:45	12:04	00:19	LOAD CHANGEOVER
666	12-Feb-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:45	12:03	00:18	LOAD CHANGEOVER
667	12-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:45	12:17	00:32	LOAD CHANGEOVER
668	12-Feb-21	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TECH PARK 220	13:07	14:27	01:20	LINE FAULT
669	12-Feb-21	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	15:12	15:25	00:13	LOAD CHANGEOVER
670	12-Feb-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	15:18	15:38	00:20	LOAD CHANGEOVER
671	12-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	15:18	15:25	00:07	LOAD CHANGEOVER
672	12-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:46	16:08	00:22	LINE FAULT
673	12-Feb-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	15:46	15:53	00:07	LINE FAULT
674	12-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	07:43	12:58	05:15	LINE CLEAR AVAILED
675	12-Feb-21	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	14:35	14:45	00:10	LOAD CHANGEOVER
676	12-Feb-21	BENGALURU	66	KONDASPURA - HOSKOTE 220	KONDASPURA	14:35	14:45	00:10	LOAD CHANGEOVER
677	12-Feb-21	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	14:46	14:52	00:06	LOAD CHANGEOVER
678	12-Feb-21	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:52	11:02	00:10	LOAD CHANGEOVER
679	12-Feb-21	BENGALURU	66	KACHMARANAHALLI - SHAMRAJ TECH PARK	KACHMARANAHALLI	11:29	11:40	00:10	LOAD CHANGEOVER
680	12-Feb-21	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	14:46	14:52	00:06	LOAD CHANGEOVER
681	12-Feb-21	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	10:52	11:02	00:10	LOAD CHANGEOVER
682	12-Feb-21	BENGALURU	66	KACHMARANAHALLI - SHAMRAJ TECH PARK	KACHMARANAHALLI	11:29	11:40	00:10	LOAD CHANGEOVER
683	12-Feb-21	BENGALURU	66	KACHMARANAHALLI - DOMMASANDRA	KACHMARANAHALLI	11:29	11:39	00:09	MAIN SUPPLY FAILURE
684	12-Feb-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	13:46	15:25	01:39	LOAD CURTAILMENT
685	12-Feb-21	BENGALURU	66	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	12:31	13:07	00:36	LINE FAULT
686	12-Feb-21	BENGALURU	66	MALUR 220 - SARJAPURA 220	SARJAPURA 220, VIKAS TECH PARK 220	13:07	18:40	05:33	LINE FAULT
687	12-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	19:49	19:54	00:05	LINE FAULT
688	12-Feb-21	BENGALURU	66	HV2	DODDABELAVANGALA	18:19	18:30	00:10	TRANSFORMER FAULT
689	12-Feb-21	BENGALURU	66	DG2	DB PURA 220	18:19	18:30	00:10	LINE FAULT
690	12-Feb-21	BENGALURU	66	HV2	SARJAPURA 220	12:31	13:41	01:10	MAIN SUPPLY FAILURE
691	12-Feb-21	BENGALURU	66	HV2	SARJAPURA 220	18:42	18:52	00:10	LOAD CHANGEOVER
692	12-Feb-21	BENGALURU	66	HV2	MAASTHI	19:23	19:33	00:09	LINE CLEAR AVAILED
693	12-Feb-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	12:31	13:40	01:09	MAIN SUPPLY FAILURE
694	12-Feb-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:42	18:52	00:10	LOAD CHANGEOVER
695	12-Feb-21	GULBARGA	110	SANKLAPUR-TORANGALU	TORANGALU_110	09:49	09:53	00:04	LINE CLEAR AVAILED
696	12-Feb-21	GULBARGA	110	HV3	KEREHALI_110	10:30	10:35	00:05	TRANSFORMER FAULT
697	12-Feb-21	GULBARGA	110	HV3	KEREHALI_110	10:50	11:00	00:10	TRANSFORMER FAULT
698	12-Feb-21	GULBARGA	110	HV3	KEREHALI_110	11:10	11:20	00:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
699	12-Feb-21	GULBARGA	110	HV3	KEREHALLI_110	15:53	16:03	00:10	TRANSFORMER FAULT
700	12-Feb-21	GULBARGA	110	SANKLAPUR-TORANGALU	TORANGALU_110	09:49	09:53	00:04	LINE CLEAR AVAILED
701	12-Feb-21	GULBARGA	110	HV3	KEREHALLI_110	10:30	10:35	00:05	TRANSFORMER FAULT
702	12-Feb-21	GULBARGA	110	HV3	KEREHALLI_110	10:50	11:00	00:10	TRANSFORMER FAULT
703	12-Feb-21	GULBARGA	110	HV3	KEREHALLI_110	11:10	11:20	00:10	TRANSFORMER FAULT
704	12-Feb-21	GULBARGA	110	HV3	KEREHALLI_110	15:53	16:03	00:10	TRANSFORMER FAULT
705	12-Feb-21	GULBARGA	110	HV2	GINIGERA_110	07:40	12:00	04:20	TRANSFORMER FAULT
706	12-Feb-21	GULBARGA	110	HV2	GINIGERA_110	16:40	19:05	02:25	LINE CLEAR AVAILED
707	12-Feb-21	GULBARGA	66	HV1	CHORNOOR_66	17:20	18:00	00:40	LINE CLEAR AVAILED
708	12-Feb-21	GULBARGA	66	HV2	CHORNOOR_66	17:40	18:08	00:28	LINE CLEAR AVAILED
709	12-Feb-21	GULBARGA	66	KOTTUR-SUZLON1	KOTTUR_66	13:05	18:54	05:49	NFBC ISSUED
710	12-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
711	12-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
712	12-Feb-21	HASSAN	400	TALAGU-HSN400#1	TALAGUPPA_400	11:01(10.2.2021)	16:21(12.02.2021)	53:19 hrs	LINE CHARGED
713	12-Feb-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:01 (11.02.2021)	13:31(15.02.2021)	88:29 hrs	LINE CHARGED
714	12-Feb-21	HASSAN	220	VARAHI-SHMG3	varahi_gen	13:31	14:53	01:22	LINE FAULT
715	12-Feb-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	10:40	12:13	01:33	NFBC ISSUED
716	12-Feb-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:39	12:12	01:33	LINE CLEAR AVAILED
717	12-Feb-21	HASSAN	110	MRS-ANDPR	KUMSI_110	10:09	16:05	05:56	LINE CLEAR AVAILED
718	12-Feb-21	HASSAN	110	HV1	SORABA_110	10:40	11:29	00:49	LINE CLEAR AVAILED
719	12-Feb-21	HASSAN	110	HV1	SORABA_110	11:41	16:57	05:16	LINE CLEAR AVAILED
720	12-Feb-21	HASSAN	110	HV4	MRSMSG_220	11:18	14:24	03:06	LINE CLEAR AVAILED
721	12-Feb-21	HASSAN	66	LV4	MRSMSG_220	11:18	14:24	03:06	LINE CLEAR AVAILED
722	12-Feb-21	HASSAN	66	HV1	CHIKKAKONDAGOLA_6	11:40	13:40	02:00	LINE CLEAR AVAILED
723	12-Feb-21	HASSAN	66	HV2	CHIKKAKONDAGOLA_6	10:55	12:40	01:45	LINE CLEAR AVAILED
724	12-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	09:08	09:12	00:04	TRANSFORMER FAULT
725	12-Feb-21	MYSORE	66	HV1	DATTAGALLY_66	14:50	19:30	4:39	TRANSFORMER CHARGED
726	12-Feb-21	MYSORE	66	DR PETE-CR NAGARA 2	NO STATION EFFECTED	17:00	17:10	0:10	LINE FAULT
727	12-Feb-21	MYSORE	66	HV1	DEVANOORMYS_66	8:23	8:50	0:26	TRANSFORMER FAULT
728	12-Feb-21	MYSORE	66	HV2	ELAVALA_66	8:55	9:12	0:17	TRANSFORMER FAULT
729	12-Feb-21	MYSORE	66	HOOTAGALLI-FTS 1	NO STATION EFFECTED	18:14	18:23	0:08	LINE FAULT
730	12-Feb-21	MYSORE	220	HOOTAGALLI-KADAKOLA	NO STATION EFFECTED	15:26	17:26	1:59	LINE CLEAR AVAILED
731	12-Feb-21	MYSORE	66	HV1	MADESWARAPURA_66	10:55	14:59	4:04	LINE CLEAR AVAILED
732	12-Feb-21	MYSORE	66	HV2	MADHUVANAHALLI_220	11:18	13:39	2:21	LINE CLEAR AVAILED
733	12-Feb-21	MYSORE	66	MEGHALAPURA-HEBBANI	BGPURA_66 CHIDRAVALLI_66 GARGESHWARI_66 THUMBLA_66 VYASRAJPURA_66	2:58	3:15	0:16	LINE FAULT
734	12-Feb-21	MYSORE	66	HV1	NAGAMANGALA_66	10:25	14:45	4:20	LINE CLEAR AVAILED
735	12-Feb-21	MYSORE	66	HV2	NAGAMANGALA_66	10:25	14:45	4:20	LINE CLEAR AVAILED
736	12-Feb-21	MYSORE	66	HV1	NAGAMANGALA_66	15:40	18:00	2:19	LINE CLEAR AVAILED
737	12-Feb-21	MYSORE	66	HV2	NAGAMANGALA_66	15:41	18:00	2:18	LINE CLEAR AVAILED
738	12-Feb-21	MYSORE	66	HV1	PERIYAPATNA_66	12:35	17:30	4:55	LINE CLEAR AVAILED
739	12-Feb-21	MYSORE	66	HV2	PERIYAPATNA_66	17:30	18:45	1:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
740	12-Feb-21	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	17:05	17:10	0:04	LINE FAULT
741	12-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN:LINE CLEAR AVAILED
742	12-Feb-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
743	12-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	15:11:29(11.02.2021)	11:34:16 (12.02.2021)	20:34hrs	LINE CHARGED
744	12-Feb-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	15:12:29 (11.02.2021)	11:34:23 (12.02.2021)	20:33hrs	LINE CHARGED
745	12-Feb-21	TUMKUR	220	TR-2	KBCROSS_220	22:09	22:15	0:06	HAND TRIPPED
746	12-Feb-21	TUMKUR	110	TR-2	KBCROSS_220	12:12	12:16	0:04	HAND TRIPPED
747	12-Feb-21	TUMKUR	66	TR-2	BELLAVI_66	11:00	11:26	0:26	LINE CLEAR AVAILED
748	12-Feb-21	TUMKUR	66	BEVINAHALLI-JAVAGONDANAHALLI	BEVINAHALLI_66	10:41	10:48	0:06	LINE FAULT
749	12-Feb-21	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	14:12	14:21	0:08	LINE CLEAR AVAILED
750	12-Feb-21	TUMKUR	66	TR-1	CHIKKATOTLUKERE_66	14:53	15:44	0:51	LINE CLEAR AVAILED
751	12-Feb-21	TUMKUR	66	TR-2	DAVANAGERE_66	10:11	11:27	1:15	LINE CLEAR AVAILED
752	12-Feb-21	TUMKUR	66	TR-2	DAVANAGERE_66	14:56	14:58	0:01	HAND TRIPPED
753	12-Feb-21	TUMKUR	66	HIRIYURKV 220kV- SUZLON 2	SUZLON2_IPP_66	12:23	15:06	2:43	LINE CLEAR AVAILED
754	12-Feb-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	8:27	13:44	5:16	LINE CLEAR AVAILED
755	12-Feb-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	13:40	14:21	0:41	LINE FAULT
756	12-Feb-21	TUMKUR	66	TR-1	MAVINAKATTE_66	17:03	17:07	0:03	TRANSFORMER FAULT
757	13-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
758	13-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
759	13-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
760	13-Feb-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
761	13-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
762	13-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
763	13-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
764	13-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
765	13-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
766	13-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
767	13-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
768	13-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
769	13-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
770	13-Feb-21	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
771	13-Feb-21	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
772	13-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVAILED
773	13-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
774	13-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
775	13-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
776	13-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
777	13-Feb-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
778	13-Feb-21	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	12:50 (12.02.2021)			LINE OPEN:LINE CLEAR AVAILED
779	13-Feb-21	BAGALKOT	110	BELAGAUM220-VADAGAON	STATION NOT AFFECTED VADAGAON_110	20:35 (12.02.2021)	8:46 (13.02.2021)	12:11hrs	LINE CHARGED
780	13-Feb-21	BAGALKOT	110	CHIKKODI-ANKALI	ANKALI_110	10:57	12:17	1:20	LINE CLEAR AVAILED
781	13-Feb-21	BAGALKOT	110	GADAG-DAMBAL2	STATION NOT AFFECTED GADAG_220	6:30	11:13	4:43	LINE FAULT
782	13-Feb-21	BAGALKOT	110	GHATAPRABHA220-KABBUR	KABBUR_110	1:03	1:18	0:15	LINE FAULT
783	13-Feb-21	BAGALKOT	110	GHATAPRABHA220-KABBUR	KABBUR_110	3:14	3:22	0:08	LINE FAULT
784	13-Feb-21	BAGALKOT	110	GHATAPRABHA220- SURYODAYA SOLAR	STATION NOT AFFECTED GHATAPRABHA_220	0:52	4:34	3:42	LINE CLEAR AVAILED
785	13-Feb-21	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALI_110	10:20	19:34	9:14	LINE CLEAR AVAILED
786	13-Feb-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:45 (13.02.2021)			LINE OPEN:LINE CLEAR AVAILED
787	13-Feb-21	BAGALKOT	110	BAGEWADI-MATTIHAL	MATTIHAL_110	7:40	7:59	0:19	LINE FAULT
788	13-Feb-21	BAGALKOT	110	MK HUBLI-KHANAPUR	KHANAPUR_110	9:59	16:10	6:11	LINE CLEAR AVAILED
789	13-Feb-21	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	8:10	8:17	0:07	TRANSFORMER FAULT
790	13-Feb-21	BAGALKOT	110	110/33KV,HV1	SADALAGA_110	10:18	18:05	7:47	LINE CLEAR AVAILED
791	13-Feb-21	BAGALKOT	110	110/11KV,HV1	SADALAGA_110	11:00	18:35	7:35	LINE CLEAR AVAILED
792	13-Feb-21	BAGALKOT	110	110/11KV, HV1	TILUVALLI_110	10:45	19:37	8:52	LINE CLEAR AVAILED
793	13-Feb-21	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	10:45	19:41	8:56	LINE CLEAR AVAILED
794	13-Feb-21	BAGALKOT	110	110/33KV, HV3	TILUVALLI_110, KALAKERI_33, SHESHGIRI_33 & KNNL LIS_33	10:45	19:43	8:58	LINE CLEAR AVAILED
795	13-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIDDAPUR_110	9:59	12:25	2:26	LINE CLEAR AVAILED
796	13-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIDDAPUR_110	17:57	18:05	0:08	TRANSFORMER FAULT
797	13-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIDDAPUR_110	18:37	18:52	0:15	TRANSFORMER FAULT
798	13-Feb-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	11:31	12:07	00:36	LINE FAULT
799	13-Feb-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA	12:25	12:27	00:02	LINE FAULT
800	13-Feb-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	DODDALAHALLI, HONNIGANAHALLI, HALAGUR	12:48	12:59	00:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
801	13-Feb-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU	10:57	14:10	03:13	LINE CLEAR AVAILED
802	13-Feb-21	BENGALURU	220	KOTIPURA 220 - TUBINAKERE	KOTIPURA 220	14:16	14:47	00:31	MAIN SUPPLY FAILURE
803	13-Feb-21	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	14:16	14:48	00:32	LINE CLEAR AVAILED
804	13-Feb-21	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTHNAGAR	12:27	12:32	00:05	LINE FAULT
805	13-Feb-21	BENGALURU	66	DEVANAHALLI - DB PURA 1	DEVANAHALLI	13:08	13:12	00:04	LINE FAULT
806	13-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:21	09:47	00:26	LOAD CURTAILMENT
807	13-Feb-21	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	10:04	11:20	01:16	LINE CLEAR AVAILED
808	13-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:51	16:01	00:10	LINE FAULT
809	13-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:05	18:30	02:25	LINE CLEAR AVAILED
810	13-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	18:50	19:05	00:15	LINE CLEAR AVAILED
811	13-Feb-21	BENGALURU	66	HV1	HOSKOTE 66	16:34	16:45	00:10	TRANSFORMER FAULT
812	13-Feb-21	BENGALURU	66	HV2	MAASTHI	14:00	14:05	00:05	TRANSFORMER FAULT
813	13-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	13:33	13:37	00:04	TRANSFORMER FAULT
814	13-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	01:18	01:25	00:07	LINE FAULT
815	13-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	11:40	12:01	00:21	LINE FAULT
816	13-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	12:46	13:08	00:22	LINE FAULT
817	13-Feb-21	GULBARGA	110	BISIHALLI-ALIPUR	BISIHALLI_110	16:25	17:15	00:50	MAIN SUPPLY FAILURE
818	13-Feb-21	GULBARGA	110	HV2	BISIHALLI_110	09:45	09:53	00:08	TRANSFORMER FAULT
819	13-Feb-21	GULBARGA	110	HV3	KAMPLI_GLB_110	11:48	13:34	01:46	LINE CLEAR AVAILED
820	13-Feb-21	GULBARGA	110	SINDHANOOR-SIRAGUPPA	SIRAGUPPA_110,DHADESUGUR_11 0,TEKKALKOTE_110,NSL SUGAR IPP	00:20	00:30	00:10	LINE FAULT
821	13-Feb-21	GULBARGA	110	SINDHANOOR-SIRAGUPPA	SIRAGUPPA_110,DHADESUGUR_11 0,TEKKALKOTE_110,NSL SUGAR IPP	05:10	05:25	00:15	LINE FAULT
822	13-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KURD I CROSS_110	05:40	05:50	00:10	LINE FAULT
823	13-Feb-21	GULBARGA	110	SINDHANOOR-NIRLOOTI	NIRLOOTI_IPP	10:00	19:15	09:15	LINE CLEAR AVAILED
824	13-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	02:50	02:55	00:05	LINE FAULT
825	13-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	04:57	05:07	00:10	LINE FAULT
826	13-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	05:31	05:38	00:07	LINE FAULT
827	13-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	12:45	13:15	00:30	LINE FAULT
828	13-Feb-21	GULBARGA	66	ITTAGI-RENEW SOLAR1	RENEW SOLAR_IPP	14:33	14:44	00:11	LINE FAULT
829	13-Feb-21	GULBARGA	66	ITTAGI-HIREHADAGALI1	HIREHADAGALI_66	21:48	21:58	00:10	LINE FAULT
830	13-Feb-21	GULBARGA	66	HV1	CHORNOOR_66	15:15	15:20	00:05	TRANSFORMER FAULT
831	13-Feb-21	GULBARGA	66	HV2	TAMBRAHALLI_66	13:02	13:34	00:32	LINE CLEAR AVAILED
832	13-Feb-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
833	13-Feb-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
834	13-Feb-21	HASSAN	220	CRPATNA-HSN400	CRPATNA_220	14:17	15:27	01:10	LINE FAULT
835	13-Feb-21	HASSAN	220	SHRVTY-TALAGUPPA1	sharavathy_gen	09:07	14:06	04:59	LINE FAULT
836	13-Feb-21	HASSAN	220	TALGUPPA1-SGS1	TALAGUPPA_400	14:37	19:36	04:59	LINE FAULT
837	13-Feb-21	HASSAN	220	MRSSTM-SHRVTY	MRSMG_220	05:51	11:11	05:20	LINE FAULT
838	13-Feb-21	HASSAN	110	HV1	ESSUR_110	07:40	07:50	00:10	TRANSFORMER FAULT
839	13-Feb-21	HASSAN	110	HV1	JAVAGAL_110	01:09	10:59	09:50	TRANSFORMER FAULT
840	13-Feb-21	HASSAN	110	HV1	JAVAGAL_110	11:04	11:57	00:53	LINE CLEAR AVAILED
841	13-Feb-21	HASSAN	110	HV1	KONAJE_110	09:42	09:46	00:04	HAND TRIPPED
842	13-Feb-21	HASSAN	110	HV2	KONAJE_110	12:41	12:43	00:02	HAND TRIPPED
843	13-Feb-21	HASSAN	110	HV3	KONAJE_110	12:44	12:46	00:02	HAND TRIPPED
844	13-Feb-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	13:05	14:57	01:52	LINE CLEAR AVAILED
845	13-Feb-21	HASSAN	110	HV1	MOODABIDRE_110	21:51	22:00	00:09	TRANSFORMER FAULT
846	13-Feb-21	HASSAN	110	HV1	SAGARA_110	10:00	17:25	07:25	LINE CLEAR AVAILED
847	13-Feb-21	HASSAN	110	HV2	SAGARA_110	10:00	17:25	07:25	LINE CLEAR AVAILED
848	13-Feb-21	HASSAN	110	HV3	SAGARA_110	14:30	16:55	02:25	LINE CLEAR AVAILED
849	13-Feb-21	HASSAN	110	HV1	MRSMG_220	09:17	12:11	02:54	LINE CLEAR AVAILED
850	13-Feb-21	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	09:56	12:35	02:39	LINE CLEAR AVAILED
851	13-Feb-21	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	01:44	02:00	00:16	LINE FAULT
852	13-Feb-21	HASSAN	66	CRPATNA-CRPTNA1	CRPATNA_220	14:15	15:35	01:20	LINE CLEAR AVAILED
853	13-Feb-21	HASSAN	66	CRPATNA-CRPTNA2	CRPATNA_220	14:15	15:35	01:20	LINE CLEAR AVAILED
854	13-Feb-21	HASSAN	66	CRPATNA-HNPURA	CRPATNA_220	14:15	15:35	01:20	LINE CLEAR AVAILED
855	13-Feb-21	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	14:15	15:35	01:20	LINE CLEAR AVAILED
856	13-Feb-21	HASSAN	66	CRPATNA-SBELAGOLA	CRPATNA_220	14:15	15:35	01:20	LINE CLEAR AVAILED
857	13-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	11:39	11:42	00:03	TRANSFORMER FAULT
858	13-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	11:42	12:12	00:30	TRANSFORMER FAULT
859	13-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	12:58	13:05	00:07	TRANSFORMER FAULT
860	13-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	16:30	16:34	00:04	TRANSFORMER FAULT
861	13-Feb-21	MYSORE	66	HV1	CHANDAKAVADI_66	9:30	17:40	8:10	LINE CLEAR AVAILED
862	13-Feb-21	MYSORE	66	HV2	CHANDAKAVADI_66	9:30	17:41	8:11	LINE CLEAR AVAILED
863	13-Feb-21	MYSORE	66	GUNDLUPETE-BOMMALAPURA	BOMMALAPURA_66	10:15	16:31	6:16	LINE CLEAR AVAILED
864	13-Feb-21	MYSORE	66	GUNDLUPETE-CR NAGARA 2	TERAKANAMBE_66	15:57	17:30	1:33	NFBC ISSUED
865	13-Feb-21	MYSORE	66	HV1	GUNDULPET_66	9:16	17:40	8:23	LINE CLEAR AVAILED
866	13-Feb-21	MYSORE	66	HV2	GUNDULPET_66	9:15	17:40	8:25	LINE CLEAR AVAILED
867	13-Feb-21	MYSORE	66	HV1	HANGLA_66	9:30	16:28	6:58	LINE CLEAR AVAILED
868	13-Feb-21	MYSORE	66	HV1	HANGLA_66	9:30	16:30	7:00	LINE CLEAR AVAILED
869	13-Feb-21	MYSORE	66	HV1	HARVEY_66	7:45	13:38	5:53	LINE CLEAR AVAILED
870	13-Feb-21	MYSORE	66	HV2	HARVEY_66	7:45	13:38	5:53	LINE CLEAR AVAILED
871	13-Feb-21	MYSORE	66	KOLLEGALA-PARINAMIPURA	CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	6:34	6:38	0:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
872	13-Feb-21	MYSORE	220	KR PETE 220-YACHANAHALLI	KRPET_220 AKKIEBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATAMPLE_66 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66	14:46	15:16	0:30	HAND TRIPPED
873	13-Feb-21	MYSORE	66	PERIYAPATNA-HANAGODU	HANAGODU_66 PONNAMPET_66 VIRAJPET_66	10:20	11:13	0:53	LINE CLEAR AVAILED
874	13-Feb-21	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 1	PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66	15:50	15:55	0:05	HAND TRIPPED
875	13-Feb-21	MYSORE	66	PERIYAPATNA-KUSHALANAGARA 2	PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66	15:50	17:15	1:25	LINE CLEAR AVAILED
876	13-Feb-21	MYSORE	66	PERIYAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	15:50	15:52	0:02	HAND TRIPPED
877	13-Feb-21	MYSORE	66	PERIYAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	15:58	16:10	0:11	LINE FAULT
878	13-Feb-21	MYSORE	66	PERIYAPATNA-HANAGODU	PONNAMPET_66 VIRAJPET_66	16:20	16:30	0:10	LINE FAULT
879	13-Feb-21	MYSORE	66	HV1	PERIYAPATNA_66	15:52	15:55	0:02	HAND TRIPPED
880	13-Feb-21	MYSORE	66	HV1	PERIYAPATNA_66	16:30	16:35	0:05	HAND TRIPPED
881	13-Feb-21	MYSORE	66	HV2	PERIYAPATNA_66	12:45	17:43	4:58	LINE CLEAR AVAILED
882	13-Feb-21	MYSORE	220	TUBINAKERE-HUYGONAHALLI	KRPET_220 AKKIEBBAL_66 ANEGOLAL_66 BANANGADI_66 BOGADHI MANDYA_66 BOOKANAKERE_66 CHINAKURALI_66 G MALLIGERE_66 GANJIGERE_66 GUDDENAHALLI_66 HARIYALDAMMATAMPLE_66 JAKKANAHALLY_66 KIKKERI_66 KRISHNAPURA_66 KRPET_66 MADESWARAPURA_66 NAGAMANGALA_66 SANTHEBACHALLI_66 SHEELUNERE_66	14:15	14:51	0:36	HAND TRIPPED
883	13-Feb-21	MYSORE	220	TUBINAKERE-KOTHIPURA	NO STATION EFFECTED	14:15	14:43	0:28	HAND TRIPPED
884	13-Feb-21	MYSORE	220	HV2	TUBINAKERE_220	14:15	14:39	0:24	HAND TRIPPED
885	13-Feb-21	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66 ADDIHALLI_66	10:21	10:26	0:05	LINE FAULT
886	13-Feb-21	MYSORE	66	TUBINAKERE-NAGAMANGALA 1	HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	12:35	12:40	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
887	13-Feb-21	MYSORE	66	TK HALLI-MANDYA-1	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	0:02	0:07	0:05	LINE FAULT
888	13-Feb-21	MYSORE	66	TK HALLI-MANDYA-2	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	0:02	0:07	0:05	LINE FAULT
889	13-Feb-21	MYSORE	66	TK HALLI-MANDYA-1	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	0:15	0:23	0:08	LINE FAULT
890	13-Feb-21	MYSORE	66	TK HALLI-MANDYA-2	NO STATION EFFECTED	0:40	0:50	0:10	LINE FAULT
891	13-Feb-21	MYSORE	66	TK HALLI-MANDYA-1	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	3:05	3:15	0:10	LINE FAULT
892	13-Feb-21	MYSORE	66	TK HALLI-MANDYA-1	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K_HONNALGERE_66	4:50	5:30	0:40	LINE FAULT
893	13-Feb-21	MYSORE	66	TK HALLI-MANDYA-2	NO STATION EFFECTED	6:51	8:13	1:22	LINE CLEAR AVAILED
894	13-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN:LINE CLEAR AVAILED
895	13-Feb-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
896	13-Feb-21	TUMKUR	220	HIRIYUR 220KV- AZURE POWER SOLAR_IPP_66	AZURE POWER SOLAR_IPP_66	18:09	18:13	0:03	LINE FAULT
897	13-Feb-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	10:18	19:34	9:15	TRANSFORMER FAULT
898	13-Feb-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	19:56	20:04	0:08	HAND TRIPPED
899	13-Feb-21	TUMKUR	66	TR-2	BEVINAHALLI_66	9:16	11:41	2:25	TRANSFORMER FAULT
900	13-Feb-21	TUMKUR	66	TR-1	DAVANAGERE_66	11:13	15:24	4:11	LINE CLEAR AVAILED
901	13-Feb-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	13:24	13:37	0:13	LINE FAULT
902	13-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:13	20:24	0:11	LINE FAULT
903	13-Feb-21	TUMKUR	66	TR-2	HOLALKERE_66	10:14	10:17	0:03	TRANSFORMER FAULT
904	13-Feb-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	15:25	15:34	0:08	HAND TRIPPED
905	13-Feb-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	16:09	16:13	0:03	HAND TRIPPED
906	13-Feb-21	TUMKUR	66	TR-2	HOSADURGA_66	12:29	12:34	0:04	TRANSFORMER FAULT
907	13-Feb-21	TUMKUR	66	TR-1	RANGANATHAPURA_66	7:45	8:16	0:30	HAND TRIPPED
908	13-Feb-21	TUMKUR	66	TR-1	SASALUHALLA_66	2:16	2:20	0:04	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
909	14-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
910	14-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
911	14-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
912	14-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
913	14-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
914	14-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
915	14-Feb-21	BAGALKOT	110	KANABARGI LAYOUT-NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
916	14-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
917	14-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
918	14-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
919	14-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
920	14-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
921	14-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
922	14-Feb-21	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
923	14-Feb-21	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)			LINE OPEN:LINE CLEAR AVAILED
924	14-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVAILED
925	14-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
926	14-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
927	14-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
928	14-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
929	14-Feb-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:13 (09.02.2021)			LINE OPEN: LINE FAULT
930	14-Feb-21	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	12:50 (12.02.2021)			LINE OPEN:LINE CLEAR AVAILED
931	14-Feb-21	BAGALKOT	110	MACHE-UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:45 (13.02.2021)	16:12 (14.02.2021)	31:27hrs	LINE CHARGED
932	14-Feb-21	BAGALKOT	110	110/11KV,HV3(HV1)	BAILHONGAL_110	18:35	22:52	4:17	TRANSFORMER FAULT
933	14-Feb-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	12:07	17:04	4:57	LINE CLEAR AVAILED
934	14-Feb-21	BAGALKOT	110	BANAHATTI-JAMAKHANDI(NAVALAGI)	STATION NOT AFFECTED BANAHATTI_110	09:38	09:50	0:12	HAND TRIPPED
935	14-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:11	20:17	10:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
936	14-Feb-21	BAGALKOT	220	220/110KV,HV1,LV1	STATION NOT AFFECTED BELGAUM_220	10:06	14:37	4:31	LINE CLEAR AVOIDED
937	14-Feb-21	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED BELGAUM_220	10:06	14:37	4:31	LINE CLEAR AVOIDED
938	14-Feb-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	10:10	14:33	4:23	LINE CLEAR AVOIDED
939	14-Feb-21	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	10:10	14:33	4:23	LINE CLEAR AVOIDED
940	14-Feb-21	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	KANABARGI LAYOUT_110	10:00	17:23	7:23	LINE CLEAR AVOIDED
941	14-Feb-21	BAGALKOT	110	BELGAUM-HONAGA(HUKKERI)	STATION NOT AFFECTED BELGAUM_220	10:02	14:57	4:55	LINE CLEAR AVOIDED
942	14-Feb-21	BAGALKOT	110	BELGAUM- BELGAUM(NEHARUNAGAR)	STATION NOT AFFECTED BELGAUM_220	10:04	10:21	0:17	HAND TRIPPED
943	14-Feb-21	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	10:11	20:16	10:05	LINE CLEAR AVOIDED
944	14-Feb-21	BAGALKOT	110	HUKKERI-HATTARAGI	STATION NOT AFFECTED HATTARAGI_110	8:50 (14.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
945	14-Feb-21	BAGALKOT	110	110/11KV,HV2	HATTARAGI_110	8:49	8:51	0:02	TRANSFORMER FAULT
946	14-Feb-21	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110,ALAGAWADI_33	10:09	18:32	8:23	LINE CLEAR AVOIDED
947	14-Feb-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,MYT RA SOLAR_33	10:09	18:32	8:23	LINE CLEAR AVOIDED
948	14-Feb-21	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	15:09	15:10	0:01	HAND TRIPPED
949	14-Feb-21	BAGALKOT	110	MAHALINGAPUR220-HIDIKAL	HIDIKAL_110	15:15	16:26	1:11	LINE CLEAR AVOIDED
950	14-Feb-21	BAGALKOT	110	BELGAUM220-HUDALI	STATION NOT AFFECTED HUDALI_110	14:45 (14.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
951	14-Feb-21	BAGALKOT	110	110/11KV,HV2	HUNAGUND_110,AMINAGAD_33,K ARADI_33,MYTRA SOLAR_33	14:56	15:02	0:06	TRANSFORMER FAULT
952	14-Feb-21	BAGALKOT	110	MAHALINGAPUR220(NAVALAGI)- JAMAKHANDI	STATION NOT AFFECTED JAMAKHANDI_110	9:44	22:16	12:32	LINE CLEAR AVOIDED
953	14-Feb-21	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	12:08 (14.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
954	14-Feb-21	BAGALKOT	110	110/11KV,HV1	MK HUBLI_220	10:23	11:01	0:38	LINE CLEAR AVOIDED
955	14-Feb-21	BAGALKOT	110	110/11KV,HV1	MK HUBLI_220	11:18	14:15	2:57	LINE CLEAR AVOIDED
956	14-Feb-21	BAGALKOT	110	NARAGUND-BPCL	STATION NOT AFFECTED NARGUND_110	3:36	9:35	5:59	LINE FAULT
957	14-Feb-21	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	MAHALINGAPUR_220	11:04	16:34	5:30	LINE CLEAR AVOIDED
958	14-Feb-21	BAGALKOT	110	VAJJRAMATTI220-KATARAKI	KATARKI_110	12:50	13:14	0:24	LINE FAULT
959	14-Feb-21	BAGALKOT	110	110/11KV, HV1	VADAGAON_110	09:47	16:26	6:39	LINE CLEAR AVOIDED
960	14-Feb-21	BAGALKOT	110	110/11KV, HV2	VADAGAON_110	10:03	18:42	8:39	LINE CLEAR AVOIDED
961	14-Feb-21	BAGALKOT	110	110/33KV, HV3	VADAGAON_110, RM1_33	09:30	16:28	6:58	LINE CLEAR AVOIDED
962	14-Feb-21	BAGALKOT	110	110/33KV, HV4	VADAGAON_110, FORT_33	09:30	16:28	6:58	LINE CLEAR AVOIDED
963	14-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED TIKOTA_110	9:01	9:02	0:01	TRANSFORMER FAULT
964	14-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIRGAON_110	10:05	11:04	0:59	LINE CLEAR AVOIDED
965	14-Feb-21	BAGALKOT	110	110/11KV, HV1	TUMMINAKATTI_110	6:54	7:30	0:36	TRANSFORMER FAULT
966	14-Feb-21	BENGALURU	66	A STATION 220 - A STATION 66	A STATION 66	18:52	18:54	00:02	LOAD CHANGEOVER
967	14-Feb-21	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	13:34	13:38	00:04	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
968	14-Feb-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	20:34	20:38	00:04	LOAD CHANGEOVER
969	14-Feb-21	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	08:40	08:50	00:10	LOAD CHANGEOVER
970	14-Feb-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	12:50	12:55	00:05	LOAD CHANGEOVER
971	14-Feb-21	BENGALURU	66	RAJANKUNTE - YELAHANKA 220	RAJANKUNTE	15:00	15:05	00:05	LOAD CHANGEOVER
972	14-Feb-21	BENGALURU	66	RAJANKUNTE - DB PURA 220	RAJANAKUNTE	16:00	16:05	00:05	LOAD CHANGEOVER
973	14-Feb-21	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	12:07	12:14	00:07	LOAD CHANGEOVER
974	14-Feb-21	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	14:45	14:50	00:05	LOAD CHANGEOVER
975	14-Feb-21	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	11:05	11:10	00:05	LOAD CHANGEOVER
976	14-Feb-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	15:20	15:26	00:06	LOAD CHANGEOVER
977	14-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE3	ESCORTS ( EHT ), MANYATHA TECH PARK, ABBIGERE, ATTUR YELAHANKA	12:28	13:14	00:45	LINE CLEAR AVAILED
978	14-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, RAILWAYS (EHT)	10:13	12:06	01:53	LINE CLEAR AVAILED
979	14-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE5	KHB	16:14	16:57	00:43	LINE CLEAR AVAILED
980	14-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	15:25	16:26	01:01	LINE CLEAR AVAILED
981	14-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	14:55	15:57	01:01	LINE CLEAR AVAILED
982	14-Feb-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	11:07	12:29	01:22	LINE CLEAR AVAILED
983	14-Feb-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	11:07	12:29	01:22	LINE CLEAR AVAILED
984	14-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:21	09:29	00:07	LINE FAULT
985	14-Feb-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	09:30	12:28	02:58	LINE CLEAR AVAILED
986	14-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	11:07	12:29	01:22	LINE CLEAR AVAILED
987	14-Feb-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	07:17	07:26	00:08	LINE FAULT
988	14-Feb-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	11:07	12:29	01:22	LINE CLEAR AVAILED
989	14-Feb-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	07:17	07:26	00:08	LINE FAULT
990	14-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	09:40	09:42	00:02	LOAD CHANGEOVER
991	14-Feb-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	16:45	16:53	00:08	LOAD CHANGEOVER
992	14-Feb-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	09:40	09:42	00:02	LOAD CHANGEOVER
993	14-Feb-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	16:45	16:53	00:08	LOAD CHANGEOVER
994	14-Feb-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	09:40	09:42	00:02	LOAD CHANGEOVER
995	14-Feb-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	16:45	16:53	00:08	LOAD CHANGEOVER
996	14-Feb-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	16:49	16:53	00:04	LOAD CHANGEOVER
997	14-Feb-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	16:49	16:53	00:04	LOAD CHANGEOVER
998	14-Feb-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	09:13	18:10	08:57	LINE CLEAR AVAILED
999	14-Feb-21	BENGALURU	66	HV2	JIGANI LINK ROAD	09:50	17:25	07:35	LINE CLEAR AVAILED
1000	14-Feb-21	BENGALURU	66	HV1	JIGANI LINK ROAD	10:10	17:40	07:30	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1001	14-Feb-21	BENGALURU	66	HV3	JIGANI LINK ROAD	10:00	20:35	10:35	LINE CLEAR AVAILED
1002	14-Feb-21	BENGALURU	66	HV1	WEL CAST STEEL	08:45	08:50	00:04	LINE CLEAR AVAILED
1003	14-Feb-21	BENGALURU	66	HV1	MITTEMARI 220	16:57	17:06	00:09	TRANSFORMER FAULT
1004	14-Feb-21	BENGALURU	66	HV2	AGALAKOTE	18:20	19:15	00:55	TRANSFORMER FAULT
1005	14-Feb-21	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	23:20(14.02.2021)			LINE OPEN: LINE FAULT
1006	14-Feb-21	GULBARGA	220	SEDAM-RTPS1	RTPS_220	11:06	12:30	01:24	LINE CLEAR AVAILED
1007	14-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	05:05	05:15	00:10	LINE FAULT
1008	14-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	22:20	22:30	00:10	LINE FAULT
1009	14-Feb-21	GULBARGA	110	MALLAT-KAVITHAL GAMESH	KAVITHAL GAMESH_IPP	03:01	03:11	00:10	LINE FAULT
1010	14-Feb-21	GULBARGA	110	SEDAM-KURUKUNTA	KURUKUNTA_110	13:05	15:40	02:35	MAIN SUPPLY FAILURE
1011	14-Feb-21	GULBARGA	110	SANKLAPUR-TORANGALU	TORANGALU_110	10:30	10:35	00:05	LINE CLEAR AVAILED
1012	14-Feb-21	GULBARGA	110	SANKLAPUR-TORANGALU	TORANGALU_110	16:33	16:38	00:05	LINE CLEAR AVAILED
1013	14-Feb-21	GULBARGA	110	GURUMTAKAL-SEDAM	GURUMITAKAL_110	13:30	14:35	01:05	LINE CLEAR AVAILED
1014	14-Feb-21	GULBARGA	110	GURUMTAKAL-SEDAM	GURUMITAKAL_110	23:35(14.02.2021)			LINE OPEN: LINE FAULT
1015	14-Feb-21	GULBARGA	110	SINDHANOOR-SINDHANOOR	SINDHANOOR_110	06:10	07:25	01:15	MAIN SUPPLY FAILURE
1016	14-Feb-21	GULBARGA	110	SINDHANOOR-SINDHANOOR	SINDHANOOR_110	07:45	07:55	02:15	MAIN SUPPLY FAILURE
1017	14-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	06:10	06:35	00:25	MAIN SUPPLY FAILURE
1018	14-Feb-21	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	22:20	22:25	00:05	MAIN SUPPLY FAILURE
1019	14-Feb-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	11:45	15:15	03:30	NFBC ISSUED
1020	14-Feb-21	GULBARGA	110	HV1	SINDHANOOR_220	06:20	07:05	00:45	TRANSFORMER FAULT
1021	14-Feb-21	GULBARGA	110	HV2	SINDHANOOR_220	06:20	12:20	06:00	TRANSFORMER FAULT
1022	14-Feb-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKKUNDA_110,KAMPLI_110,YERADONA_110,SRNAGAR_110,MALLAPURA_110	12:55	13:05	00:10	LINE FAULT
1023	14-Feb-21	GULBARGA	110	SEDAM-KURUKUNTA	KURUKUNTA_110	13:13	15:50	02:37	LINE CLEAR AVAILED
1024	14-Feb-21	GULBARGA	110	SEDAM-GURMITKAL	GURUMITAKAL_110	13:51	14:36	00:45	LINE CLEAR AVAILED
1025	14-Feb-21	GULBARGA	110	ALLIPUR-MUNIRBAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATHVAHANA_IPP,AGRAWAL_1PP,SUZLON_IPP,KAMALAPUR_110,MATRI_110,RBNS FACTORY	07:46	07:54	00:08	LINE FAULT
1026	14-Feb-21	GULBARGA	66	HV2	TAMBRAHALLI_66	09:28	09:45	00:17	LINE CLEAR AVAILED
1027	14-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1028	14-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1029	14-Feb-21	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	13:38	14:17	00:39	LINE FAULT
1030	14-Feb-21	HASSAN	110	HV4	BAIKAMPADY_110	09:03	18:40	09:37	LINE CLEAR AVAILED
1031	14-Feb-21	HASSAN	110	HV2	MOODABIDRE_110	22:15	23:30	01:15	LINE CLEAR AVAILED
1032	14-Feb-21	HASSAN	66	HV1	MAGGE_66	13:15	14:14	00:59	TRANSFORMER FAULT
1033	14-Feb-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	03:40	03:46	00:06	LINE FAULT
1034	14-Feb-21	HASSAN	66	HV2	UDAYAPURA_66	09:40	09:45	00:05	TRANSFORMER FAULT
1035	14-Feb-21	MYSORE	66	CR NAGARA-KOLLEGALA	KOLLEGALA_66	10:24	16:53	6:29	NFBC ISSUED
1036	14-Feb-21	MYSORE	66	DR PETE-CR NAGARA 1	NO STATION EFFECTED	11:19	11:28	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1037	14-Feb-21	MYSORE	66	DR PETE-CR NAGARA 1	NO STATION EFFECTED	11:28	11:33	0:04	LINE FAULT
1038	14-Feb-21	MYSORE	66	DR PETE-CR NAGARA 1	NO STATION EFFECTED	11:33	12:25	0:51	LINE FAULT
1039	14-Feb-21	MYSORE	66	DR PETE-CR NAGARA 1	NO STATION EFFECTED	13:14 (14/02/2021)			LINE OPEN:LINE CLEAR AVAILED
1040	14-Feb-21	MYSORE	66	DR PETE-CR NAGARA 2	NO STATION EFFECTED	10:53	10:57	0:03	LINE FAULT
1041	14-Feb-21	MYSORE	66	HANNUR-KOTTHANUR	KOTTANUR_66	11:30	14:31	3:00	LINE CLEAR AVAILED
1042	14-Feb-21	MYSORE	66	HV2	HEBBAL_66	23:01 (14/02/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1043	14-Feb-21	MYSORE	66	KIRUGAVLU-MALIYUR	KIRUGAVLU_66 VADKEPURA_66	7:25	7:31	0:05	LINE FAULT
1044	14-Feb-21	MYSORE	66	HV1	MADHUVANAHALLI_220	11:08	14:05	2:57	LINE CLEAR AVAILED
1045	14-Feb-21	MYSORE	66	MADHUVANAHALLY-DODDINDUVADI	DODDINADUVADI_66	9:46	18:35	8:49	NFBC ISSUED
1046	14-Feb-21	MYSORE	66	MADHUVANAHALLY-KOLLEGALA 1	KOLLEGALA_66	10:35	16:52	6:17	NFBC ISSUED
1047	14-Feb-21	MYSORE	66	MADHUVANAHALLY-PG PALYA	PGPALYA_66	10:19	16:15	5:56	NFBC ISSUED
1048	14-Feb-21	MYSORE	66	MADHUVANAHALLY-HEBBANI	NO STATION EFFECTED	15:00	15:06	0:06	LINE FAULT
1049	14-Feb-21	MYSORE	66	HV1	METAGALLY_66	9:40	17:06	7:25	LINE CLEAR AVAILED
1050	14-Feb-21	MYSORE	66	HV1	SATHEGALA_66	10:53	13:50	2:56	LINE CLEAR AVAILED
1051	14-Feb-21	MYSORE	66	HV2	SATHEGALA_66	11:19	15:05	3:45	LINE CLEAR AVAILED
1052	14-Feb-21	MYSORE	66	SATHEGALA-BPCL	NO STATION EFFECTED	10:10	15:30	5:20	LINE CLEAR AVAILED
1053	14-Feb-21	MYSORE	66	SATHEGALA-HEBBANI	NO STATION EFFECTED	4:54	13:50	8:55	LOAD CURTAILMENT
1054	14-Feb-21	MYSORE	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	10:10	17:08	6:58	LINE CLEAR AVAILED
1055	14-Feb-21	MYSORE	66	HV1	SANIVARASANTHE_66	12:08	12:13	0:05	TRANSFORMER FAULT
1056	14-Feb-21	MYSORE	66	SFC SIVA-PGL	NO STATION EFFECTED	7:25	7:32	0:06	LINE FAULT
1057	14-Feb-21	MYSORE	66	SFC SIVA-PGL	NO STATION EFFECTED	11:53	11:59	0:05	LINE FAULT
1058	14-Feb-21	MYSORE	66	SFC SIVA-5 MW	NO STATION EFFECTED	7:25	7:32	0:07	LINE FAULT
1059	14-Feb-21	MYSORE	66	SFC SIVA-10 MW	NO STATION EFFECTED	7:25	7:35	0:10	LINE FAULT
1060	14-Feb-21	MYSORE	66	SFC SIVA-5 MW	NO STATION EFFECTED	11:53	11:59	0:06	LINE FAULT
1061	14-Feb-21	MYSORE	66	SFC SIVA-10 MW	NO STATION EFFECTED	11:53	11:58	0:05	LINE FAULT
1062	14-Feb-21	MYSORE	66	SFC SIVA-PPCL	NO STATION EFFECTED	11:53	14:07	2:13	LINE FAULT
1063	14-Feb-21	MYSORE	66	HV1	SHIVALLY_66	7:30	8:20	0:49	LINE CLEAR AVAILED
1064	14-Feb-21	MYSORE	66	HV1	YELANDUR_66	10:10	15:40	5:30	LINE CLEAR AVAILED
1065	14-Feb-21	MYSORE	66	HV2	YELANDUR_66	10:04	15:40	5:35	LINE CLEAR AVAILED
1066	14-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)			LINE OPEN:LINE CLEAR AVAILED
1067	14-Feb-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1068	14-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	19:02	19:23	0:21	HAND TRIPPED
1069	14-Feb-21	TUMKUR	220	TR-1	PAVAGADA_220	12:13	13:23	1:10	LINE CLEAR AVAILED
1070	14-Feb-21	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR IPP 66	ADAN SOLAR_IPP_110	18:53	22:44	3:50	LINE CLEAR AVAILED
1071	14-Feb-21	TUMKUR	66	ANCHEPALYA 220KV- VIJAYA STEEL	ANCHEPALYA_220	10:28	17:33	7:05	LINE CLEAR AVAILED
1072	14-Feb-21	TUMKUR	66	ANCHEPALYA 220KV- YEDIYUR(BG NAGAR)	YEDIYUR_66	9:01	14:48	5:46	LINE CLEAR AVAILED
1073	14-Feb-21	TUMKUR	66	ANTHRASANAHALI 220KV- KOLALA ( dabaspete)	KOLALA_66, URDIGERE_66	10:16	11:00	0:44	LINE FAULT
1074	14-Feb-21	TUMKUR	66	TR-2	BEVINAHALLI_66	7:44	7:59	0:14	TRANSFORMER FAULT
1075	14-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	20:37	20:45	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1076	14-Feb-21	TUMKUR	66	TR-1	GARAGA_66	5:38	16:08	10:29	LINE CLEAR AVAILED
1077	14-Feb-21	TUMKUR	66	TR-2	GARAGA_66	5:38	16:08	10:29	LINE CLEAR AVAILED
1078	14-Feb-21	TUMKUR	66	GARAGA-MTHD-PNCHLI	GARAGA_66	5:38	16:07	10:28	LINE CLEAR AVAILED
1079	14-Feb-21	TUMKUR	66	H D PURA- SUZLON	SUZLON-IPP	19:22	21:18	1:56	LINE CLEAR AVAILED
1080	14-Feb-21	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	19:25	21:23	1:57	LINE CLEAR AVAILED
1081	14-Feb-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:26	10:35	0:08	LINE FAULT
1082	14-Feb-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	16:27	16:38	0:11	LINE FAULT
1083	14-Feb-21	TUMKUR	66	TR-2	LINGDHALLI_66	9:31	9:35	0:04	TRANSFORMER FAULT
1084	14-Feb-21	TUMKUR	66	TR-2	LINGDHALLI_66	9:50	9:55	0:04	TRANSFORMER FAULT
1085	14-Feb-21	TUMKUR	66	TR-1	PAVAGADA_220	12:13	13:23	1:10	LINE CLEAR AVAILED
1086	14-Feb-21	TUMKUR	66	TR-2	SIRA_66	17:08	18:39	1:30	LINE CLEAR AVAILED
1087	14-Feb-21	TUMKUR	66	TR-2	URDIGERE_66	10:20	11:03	0:42	MAIN SUPPLY FAILURE
1088	14-Feb-21	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE_66	10:20	11:01	0:41	MAIN SUPPLY FAILURE
1089	14-Feb-21	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	10:20	11:02	0:42	MAIN SUPPLY FAILURE
1090	15-Feb-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
1091	15-Feb-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIDDAPUR_110	10:23	11:05	0:42	LINE CLEAR AVAILED
1092	15-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SIRSI_110	13:54 (15.02.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1093	15-Feb-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIROL_110	18:08	18:19	0:11	LINE CLEAR AVAILED
1094	15-Feb-21	BAGALKOT	110	110/11KV, HV4	STATION NOT AFFECTED BELGAUM_110	1:05 (27.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
1095	15-Feb-21	BAGALKOT	110	110/11KV,HV3	BAILHONGAL_110	20:33	21:04	0:31	TRANSFORMER FAULT
1096	15-Feb-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, NIVARAGI_33, DULAKHED_33, HALASANGI_33	09:02	09:11	0:09	TRANSFORMER FAULT
1097	15-Feb-21	BAGALKOT	110	AMBEWADI-KAVALWADA(NK2)	STATION NOT AFFECTED AMBEWADI_220	15:02	19:39	4:37	LINE CLEAR AVAILED
1098	15-Feb-21	BAGALKOT	110	AMBEWADI-XELDOM	STATION NOT AFFECTED AMBEWADI_220	09:39	18:26	8:47	LINE CLEAR AVAILED
1099	15-Feb-21	BAGALKOT	110	BAGALKOT220-BAGALKOT2	STATION NOT AFFECTED BAGALKOT_220	07:41	07:55	0:14	LINE FAULT
1100	15-Feb-21	BAGALKOT	110	BAGALKOT220-BAGALKOT2	STATION NOT AFFECTED BAGALKOT_220	09:20	12:58	3:38	LINE CLEAR AVAILED
1101	15-Feb-21	BAGALKOT	110	BELGAUM220-HUDALI	STATION NOT AFFECTED HUDALI_110	14:45 (14.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1102	15-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1103	15-Feb-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	7:13 (07.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1104	15-Feb-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
1105	15-Feb-21	BAGALKOT	110	HAVERI-HANAGAL(TILUVALI)	STATION NOT AFFECTED HAVERI_220	09:46	09:57	0:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1106	15-Feb-21	BAGALKOT	110	HUKKERI-HATTARAGI	STATION NOT AFFECTED HATTARAGI_110	8:50 (14.02.2021)	9:41 (14.02.2021)	0:51 hrs	LINE CHARGED
1107	15-Feb-21	BAGALKOT	110	HUKKERI-HATTARAGI	HATTARAGI_110	9:03 (15.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1108	15-Feb-21	BAGALKOT	110	HUNGUND-ILKAL1	STATION NOT AFFECTED HUNGUND_110	18:49 (05.02.2021)	9:06 (15.02.2021)	230:17 hrs	LINE CHARGED
1109	15-Feb-21	BAGALKOT	110	HUNGUND-ILKAL2	STATION NOT AFFECTED HUNGUND_110	09:03 (05.02.2021)	9:06 (15.02.2021)	240:03 hrs	LINE CHARGED
1110	15-Feb-21	BAGALKOT	110	KANABARGI LAYOUT- NEHRUNAGAR(BELGAUM)	STATION NOT AFFECTED KANABARGI LAYOUT_110	9:16 (03.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1111	15-Feb-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
1112	15-Feb-21	BAGALKOT	110	KULIGERE CROSS-MRN SUGAR	KULIGERI CROSS_110	07:41	07:46	0:05	LINE FAULT
1113	15-Feb-21	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	GAJENDRAGAD_110	12:50 (12.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1114	15-Feb-21	BAGALKOT	110	MAHALINGAPUR- RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	12:49 (18.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1115	15-Feb-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	14:32 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1116	15-Feb-21	BAGALKOT	110	RAIBAG-ITNAL1&2 (ITNAL)	STATION NOT AFFECTED RAIBAG_110	17:42 (04.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1117	15-Feb-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
1118	15-Feb-21	BAGALKOT	110	SAVANUR-ASIAN SOLAR FEBTECH	SAVANUR_110 ASIAN SOLAR FEBTECH_110	21:29	21:33	0:04	LINE FAULT
1119	15-Feb-21	BAGALKOT	110	SIGIKERI-ACHANUR	STATION NOT AFFECTED ACHANUR_110	09:08	13:40	4:32	LINE FAULT
1120	15-Feb-21	BAGALKOT	220	AMBEWADI -NARENDRA 1	AMBEWADI_220	21:05 (31.01.2021)			LINE OPEN:LINE CLEAR AVAILED
1121	15-Feb-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:47 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
1122	15-Feb-21	BAGALKOT	220	CHIKKODI -BELGAUM 1	CHIKKODI_220	10:47:00 (9.2.2021)			LINE OPEN:LINE CLEAR AVAILED
1123	15-Feb-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
1124	15-Feb-21	BAGALKOT	220	HAVERI-NARENDRA	STATION NOT AFFECTED HAVERI_220	21:29	22:24	0:55	LINE FAULT
1125	15-Feb-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	13:13 (09.02.2021)	18:49 (15.02.2021)	29:36 hrs	LINE CHARGED
1126	15-Feb-21	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	12:33	14:58	2:25	LINE CLEAR AVAILED
1127	15-Feb-21	BAGALKOT	220	MAHALINGAPUR-NARENDRA1	STATION NOT AFFECTED MAHALINGAPUR_220	12:14	14:21	2:07	LINE FAULT
1128	15-Feb-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	12:14	13:07	0:53	LINE FAULT
1129	15-Feb-21	BAGALKOT	220	NARENDRA- HUBLI1	NARENDRA_220	13:13 (09.02.2021)	18:49 (15.02.2021)	29:36 hrs	LINE CHARGED
1130	15-Feb-21	BAGALKOT	220	NARENDRA-AMBEWADI1	STATION NOT AFFECTED NARENDRA_220	12:08 (14.02.2021)	12:53 (15.02.2021)	24:45 hrs	NFBC ISSUED
1131	15-Feb-21	BAGALKOT	220	RANEENNUR- SHIRALKOPPA(BELLIGAVI)	STATION NOT AFFECTED RANEENNUR_220	23:40 (14.02.2021)	18:15 (15.02.2021)	18:35 hrs	HAND TRIPPED
1132	15-Feb-21	BAGALKOT	220	RANEENNUR- SHIRALKOPPA(BELLIGAVI)	STATION NOT AFFECTED RANEENNUR_220	23:41 (15.02.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1133	15-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	13:34 (30.01.2021)			LOAD CURTAILMENT
1134	15-Feb-21	BAGALKOT	220	SIRSI-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	4:30 (30.01.2021)			LOAD CURTAILMENT
1135	15-Feb-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	12:12	12:19	0:07	LINE FAULT
1136	15-Feb-21	BENGALURU	66	A STATION 220 - A STATION 1	A STATION 66	23:21	23:43	00:22	LINE FAULT
1137	15-Feb-21	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	11:12	11:22	00:10	LOAD CHANGEOVER
1138	15-Feb-21	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	12:15	12:28	00:13	LOAD CHANGEOVER
1139	15-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:12	11:22	00:10	LOAD CHANGEOVER
1140	15-Feb-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	12:15	12:28	00:13	LOAD CHANGEOVER
1141	15-Feb-21	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	11:12	11:22	00:10	LOAD CHANGEOVER
1142	15-Feb-21	BENGALURU	66	DB PURA 220 - TUBUGERE	TUBUGERE	12:15	12:28	00:13	LOAD CHANGEOVER
1143	15-Feb-21	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	17:11	17:16	00:05	LOAD CHANGEOVER
1144	15-Feb-21	BENGALURU	66	HOSKOTE 220 - HBR LAYOUT	HBR LAYOUT	16:18	16:30	00:12	LINE FAULT
1145	15-Feb-21	BENGALURU	66	HV1	YELAHANKA 220	11:36	12:36	01:00	LINE CLEAR AVAILED
1146	15-Feb-21	BENGALURU	66	HV2	DODDABELAVANGALA	11:39	11:50	00:11	TRANSFORMER FAULT
1147	15-Feb-21	BENGALURU	66	HV2	YELAHANKA 220	12:43	16:36	03:52	LINE CLEAR AVAILED
1148	15-Feb-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, YEDUMADU	17:55	18:10	00:15	LINE FAULT
1149	15-Feb-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	06:20	06:30	00:10	LINE FAULT
1150	15-Feb-21	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:30	10:47	00:17	LINE CLEAR AVAILED
1151	15-Feb-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	01:32	01:55	00:23	LINE FAULT
1152	15-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:09	17:48	03:39	LINE CLEAR AVAILED
1153	15-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	14:09	14:36	00:27	LINE CLEAR AVAILED
1154	15-Feb-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:43	17:49	00:06	LINE CLEAR AVAILED
1155	15-Feb-21	BENGALURU	66	VIJAYAPURA - D B PURA 220	VIJAYAPURA, JANGAMKOTE	11:20	11:30	00:10	LOAD CHANGEOVER
1156	15-Feb-21	BENGALURU	66	VIJAYAPURA - MELUR	VIJAYAPURA, JANGAMKOTE	12:30	12:35	00:05	LOAD CHANGEOVER
1157	15-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE2	NO STATION AFFECTED	15:54	16:33	00:38	LINE CLEAR AVAILED
1158	15-Feb-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	10:51	11:55	01:03	LINE CLEAR AVAILED
1159	15-Feb-21	GULBARGA	110	CHIDRI-HALBARGA	CHIDRI_110	14:10	14:35	00:25	NFBC ISSUED
1160	15-Feb-21	GULBARGA	110	GURUMTAKAL-SEDAM	GURUMITAKAL_110	23:35(14.02.2021)	00:30(15.2.2021)	0:55 HRS	LINE CHARGED
1161	15-Feb-21	GULBARGA	110	GURUMTAKAL-SEDAM	GURUMITAKAL_110	03:00	12:20	09:20	LINE CLEAR AVAILED
1162	15-Feb-21	GULBARGA	110	HUMNABAD-MANEKHALLI	MANEKHALLI_110	17:30	20:35	03:05	LINE FAULT
1163	15-Feb-21	GULBARGA	110	HV1	NIRNA_110	12:40	12:45	00:05	TRANSFORMER FAULT
1164	15-Feb-21	GULBARGA	110	HV1	SHAHAPUR_110	22:15	22:32	00:17	TRANSFORMER FAULT
1165	15-Feb-21	GULBARGA	110	HV2	HATTI_110	15:23	15:50	00:27	LINE CLEAR AVAILED
1166	15-Feb-21	GULBARGA	110	HV2	HATTI_110	16:07	16:18	00:11	LINE CLEAR AVAILED
1167	15-Feb-21	GULBARGA	110	HV2	TAMBRAHALLI_110	13:15	16:25	03:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1168	15-Feb-21	GULBARGA	110	HV2	MYLAR_110	15:25	21:30	06:05	TRANSFORMER FAULT
1169	15-Feb-21	GULBARGA	110	KUSHTAGI-INR_SLR	KUSHTAGI_220	07:20	23:05	15:45	LINE FAULT
1170	15-Feb-21	GULBARGA	110	KUSHTAGI-KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	10:00	14:45	04:45	LINE CLEAR AVAILED
1171	15-Feb-21	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	06:28	07:45	01:17	LINE CLEAR AVAILED
1172	15-Feb-21	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	08:00	13:30	05:30	LINE CLEAR AVAILED
1173	15-Feb-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	14:07	14:20	00:13	LINE FAULT
1174	15-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT1	BYAGAWAT_110,VALKAMDINNI_110	16:05	17:05	01:00	LINE CLEAR AVAILED
1175	15-Feb-21	GULBARGA	110	MALLAT-BYAGAWAT2	MADLAPUR_110,MANVI_110	15:55	17:05	01:10	LINE CLEAR AVAILED
1176	15-Feb-21	GULBARGA	110	NALWAR-CLNSOLAR_IPP	NALWAR_110	11:30	11:45	00:15	LINE FAULT
1177	15-Feb-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR-110	17:10	17:24	00:14	LOAD CHANGEOVER
1178	15-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	02:40	02:45	00:05	LINE FAULT
1179	15-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	06:15	06:30	00:15	LINE FAULT
1180	15-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	06:45	06:50	00:05	LINE FAULT
1181	15-Feb-21	GULBARGA	110	RAICHUR-SINDHANOOR2	MANVI_110,MADLAPUR_110, KURDICROSS_110	07:20	07:30	00:10	LINE FAULT
1182	15-Feb-21	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITAKAL_110	03:00	12:20	09:20	LINE CLEAR AVAILED
1183	15-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	04:56	05:03	00:07	LINE FAULT
1184	15-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	06:40	06:44	00:04	LINE FAULT
1185	15-Feb-21	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,UGARSUGAR_IPP	20:46	20:53	00:07	LINE FAULT
1186	15-Feb-21	GULBARGA	110	SHAHAPUR-SHAHABAD1	SHAHAPUR_110	11:34	17:46	06:12	LINE CLEAR AVAILED
1187	15-Feb-21	GULBARGA	110	SHAHAPUR-SHAHABAD1	SHAHAPUR_110	11:34	17:47	06:13	LINE CLEAR AVAILED
1188	15-Feb-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	15:49	16:04	00:15	LINE CLEAR AVAILED
1189	15-Feb-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	22:12	22:18	00:06	LINE FAULT
1190	15-Feb-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	16:06	16:19	00:13	LINE CLEAR AVAILED
1191	15-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR1	MASKI_110,MUDDAPUR_110	15:30(14.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1192	15-Feb-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADAVIAMARESHWAR_110	15:05(14.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1193	15-Feb-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	14:15(15.2.2021)			LINE OPEN:LINE CLEAR AVAILED
1194	15-Feb-21	GULBARGA	220	HV1	HUMNABAD_220	17:30	18:02	00:32	TRANSFORMER FAULT
1195	15-Feb-21	GULBARGA	220	HV1	SHAHAPUR_110	22:15	22:32	00:17	TRANSFORMER FAULT
1196	15-Feb-21	GULBARGA	220	HV1	KUSHTAGI_220	07:16	07:20	00:04	TRANSFORMER FAULT
1197	15-Feb-21	GULBARGA	220	HV1 & HV2	KUSHTAGI_220	06:28	07:09	00:41	TRANSFORMER FAULT
1198	15-Feb-21	GULBARGA	220	HV2	SEDAM_220	02:06	02:27	00:21	TRANSFORMER FAULT
1199	15-Feb-21	GULBARGA	220	HV2	SEDAM_220	16:09	16:19	00:10	TRANSFORMER FAULT
1200	15-Feb-21	GULBARGA	220	HV2	SEDAM_220	17:37	18:01	00:24	TRANSFORMER FAULT
1201	15-Feb-21	GULBARGA	220	KAPNOOR-SHAHABAD	SHAHABAD_220	13:50	14:20	00:30	LINE CLEAR AVAILED
1202	15-Feb-21	GULBARGA	220	KAPNOOR-SHAHAPUR	SHAHAPUR_220	11:55	13:15	01:20	LINE CLEAR AVAILED
1203	15-Feb-21	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	05:05	08:33	03:28	LINE FAULT
1204	15-Feb-21	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	23:20(14.02.2021)	08:35(15.02.2021)	9:15HRS	LINE CHARGED
1205	15-Feb-21	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	17:37	19:34	01:57	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1206	15-Feb-21	GULBARGA	220	SEDAM-RTPS1,2	SEDAM_220,HUMNABAD_220,TAN DUR_220,SHAHAPUR_220	02:06	02:38	00:32	LINE FAULT
1207	15-Feb-21	GULBARGA	220	SEDAM-RTPS1,2	SEDAM_220,TANDUR_220,SHAHAP UR_220	17:37	18:54	01:17	LINE FAULT
1208	15-Feb-21	GULBARGA	220	SEDAM-TANDUR	SEDAM_220	23:20(14.02.2021)	08:15(15.02.2021)	09:00HRS	LINE CHARGED
1209	15-Feb-21	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	14:07	14:57	00:50	LINE CLEAR AVAILED
1210	15-Feb-21	GULBARGA	400	JSWVL-GUTTUR	GUTTUR_400	09:30	22:45	13:15	NFBC ISSUED
1211	15-Feb-21	HASSAN	66	CHANNARA-MALLALI	CHANNARAYAPATNA_66	13:55	14:10	00:15	LINE FAULT
1212	15-Feb-21	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	13:55	14:10	00:15	LINE FAULT
1213	15-Feb-21	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	13:59	14:18	00:19	MAIN SUPPLY FAILURE
1214	15-Feb-21	HASSAN	66	HV1	RAMPURA_66	07:25	07:34	00:09	TRANSFORMER FAULT
1215	15-Feb-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1216	15-Feb-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1217	15-Feb-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	13:55	14:20	00:25	LINE FAULT
1218	15-Feb-21	HASSAN	110	ARSK2-ARSKR	ARASIKERE_220	12:57	15:09	02:12	MAIN SUPPLY FAILURE
1219	15-Feb-21	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	12:57	15:11	02:14	MAIN SUPPLY FAILURE
1220	15-Feb-21	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	12:57	15:16	02:19	MAIN SUPPLY FAILURE
1221	15-Feb-21	HASSAN	110	HV1	MRSMSG_220	16:30	16:37	00:07	HAND TRIPPED
1222	15-Feb-21	HASSAN	110	HV1	SAGARA_110	11:33	14:18	02:45	LINE CLEAR AVAILED
1223	15-Feb-21	HASSAN	110	HV2	BANAVARA_110	12:57	15:41	02:44	MAIN SUPPLY FAILURE
1224	15-Feb-21	HASSAN	110	HV2	PUTTUR_110	09:39	16:38	06:59	LINE CLEAR AVAILED
1225	15-Feb-21	HASSAN	110	HV4	MRSMSG_220	16:17	16:29	00:12	HAND TRIPPED
1226	15-Feb-21	HASSAN	110	HV4	MRSMSG_220	16:30	16:37	00:07	LINE CLEAR AVAILED
1227	15-Feb-21	HASSAN	110	HV4	MRSMSG_220	16:45	17:00	00:15	HAND TRIPPED
1228	15-Feb-21	HASSAN	110	LV1	MSEZ_220	09:41	14:05	04:24	LINE CLEAR AVAILED
1229	15-Feb-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	11:04	13:14	02:10	LINE CLEAR AVAILED
1230	15-Feb-21	HASSAN	220	ARSK2-SHMG	ARASIKERE_220	12:57	14:03	01:06	MAIN SUPPLY FAILURE
1231	15-Feb-21	HASSAN	220	HV1	MSEZ_220	09:42	14:15	04:33	LINE CLEAR AVAILED
1232	15-Feb-21	HASSAN	220	MRSSH-HASSAN	MRSMSG_220	12:57	14:52	01:55	LINE FAULT
1233	15-Feb-21	MYSORE	66	BOOKANAKERE-CHINKURALI	CHINAKURALI_66, BANNANGADI_66	6:03	6:09	0:05	LINE FAULT
1234	15-Feb-21	MYSORE	66	CR NAGARA-DR PETE 1	NO STATION EFFECTED	10:49	16:14	5:25	NFBC ISSUED
1235	15-Feb-21	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATION EFFECTED	15:09	15:18	0:09	LINE FAULT
1236	15-Feb-21	MYSORE	66	DR PETE-CR NAGARA 1	NO STATION EFFECTED	13:14 (14/02/2021)	16:13 (15/02/2021)	26:58 HRS	NFBC ISSUED
1237	15-Feb-21	MYSORE	66	HV1	CHIKKA_MANDYA_66	16:46	18:06	1:20	LINE CLEAR AVAILED
1238	15-Feb-21	MYSORE	66	HV1	DATTAGALLY_66	12:36	13:46	1:09	LINE CLEAR AVAILED
1239	15-Feb-21	MYSORE	66	HV1	JAKKANAHALLY_66	10:47 (15/02/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1240	15-Feb-21	MYSORE	66	HV1	K_HONNALGERE_66	1:32	2:01	0:28	HAND TRIPPED
1241	15-Feb-21	MYSORE	66	HV1	KMDODDI_66	14:04	18:00	3:56	LINE CLEAR AVAILED
1242	15-Feb-21	MYSORE	66	HV1	NAGAMANGALA_66	9:35	15:53	6:17	LINE CLEAR AVAILED
1243	15-Feb-21	MYSORE	66	HV1	NAGAMANGALA_66	17:41	18:27	0:46	HAND TRIPPED
1244	15-Feb-21	MYSORE	66	HV1	SFCSHIVA_66	18:07	18:39	0:31	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1245	15-Feb-21	MYSORE	66	HV1	SFCSHIVA_66	19:04	19:08	0:04	HAND TRIPPED
1246	15-Feb-21	MYSORE	66	HV1	SHIVALLY_66	15:50	16:18	0:28	LINE CLEAR AVAILED
1247	15-Feb-21	MYSORE	66	HV1	SRIRANGAPATNA_66	10:58	12:54	1:55	TRANSFORMER FAULT
1248	15-Feb-21	MYSORE	66	HV2	CHANDAKAVADI_66	10:50	11:55	1:04	LINE CLEAR AVAILED
1249	15-Feb-21	MYSORE	66	HV2	DATTAGALLY_66	10:54	11:27	0:33	LINE CLEAR AVAILED
1250	15-Feb-21	MYSORE	66	HV2	DATTAGALLY_66	12:08	12:31	0:23	LINE CLEAR AVAILED
1251	15-Feb-21	MYSORE	66	HV2	KADAKOLA_220	11:02	11:25	0:23	LINE CLEAR AVAILED
1252	15-Feb-21	MYSORE	66	HV2	K_HONNALGERE_66	1:32	2:01	0:28	HAND TRIPPED
1253	15-Feb-21	MYSORE	66	HV2	KMDODDI_66	14:06	18:00	3:54	LINE CLEAR AVAILED
1254	15-Feb-21	MYSORE	66	HV2	NAGAMANGALA_66	9:35	17:17	7:41	LINE CLEAR AVAILED
1255	15-Feb-21	MYSORE	66	HV2	NAGAMANGALA_66	3:26	3:30	0:03	TRANSFORMER FAULT
1256	15-Feb-21	MYSORE	66	HV2	NAGAMANGALA_66	18:07	18:27	0:20	HAND TRIPPED
1257	15-Feb-21	MYSORE	66	HV2	SFCSHIVA_66	18:08	18:39	0:31	HAND TRIPPED
1258	15-Feb-21	MYSORE	66	HV2	SFCSHIVA_66	19:04	19:08	0:04	HAND TRIPPED
1259	15-Feb-21	MYSORE	66	HV2	SHIVALLY_66	9:45	15:56	6:10	LINE CLEAR AVAILED
1260	15-Feb-21	MYSORE	66	HV2	SRIRANGAPATNA_66	10:58	11:08	0:09	TRANSFORMER FAULT
1261	15-Feb-21	MYSORE	66	HV2	HEBBAL_66	23:01 (14/02/2021)	2:48 (15/02/2021)	3:46 HRS	TRANSFORMER CHARGED
1262	15-Feb-21	MYSORE	66	HV3	SFCSHIVA_66	18:08	18:39	0:31	HAND TRIPPED
1263	15-Feb-21	MYSORE	66	HV3	SFCSHIVA_66	19:03	19:08	0:04	HAND TRIPPED
1264	15-Feb-21	MYSORE	66	HV4	SFCSHIVA_66	18:08	18:39	0:31	HAND TRIPPED
1265	15-Feb-21	MYSORE	66	HV4	SFCSHIVA_66	19:03	19:08	0:04	HAND TRIPPED
1266	15-Feb-21	MYSORE	66	KM DODDI-MANDYA	KIADBMANDYA_66 KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	14:16	14:47	0:31	LINE CLEAR AVAILED
1267	15-Feb-21	MYSORE	66	KM DODDI-MANDYA	KIADBMANDYA_66 KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	17:42	17:55	0:13	LINE CLEAR AVAILED
1268	15-Feb-21	MYSORE	66	KM DODDI-SCSL	NO STATION EFFECTED	14:16	14:47	0:31	LINE CLEAR AVAILED
1269	15-Feb-21	MYSORE	66	KM DODDI-SCSL	NO STATION EFFECTED	17:42	17:56	0:14	LINE CLEAR AVAILED
1270	15-Feb-21	MYSORE	66	KM DODDI-TK HALI	KMDODDI_66	14:15	17:53	3:38	LINE CLEAR AVAILED
1271	15-Feb-21	MYSORE	66	KR NAGARA-BHERYA	NO STATION EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1272	15-Feb-21	MYSORE	66	KR PETE 220-BOOKANAKERE	BANANGADI_66 BOOKANAKERE_66 CHINAKURALI_66 GANJIGERE_66 SHEELUNERE_66	12:56	13:03	0:06	LINE FAULT
1273	15-Feb-21	MYSORE	66	MADHUVANAHALLY-DODDINDUVADI	DODDINADUVADI_66	16:05	16:54	0:48	NFBC ISSUED
1274	15-Feb-21	MYSORE	66	SFC SIVA-5 MW	NO STATION EFFECTED	18:07	18:42	0:35	HAND TRIPPED
1275	15-Feb-21	MYSORE	66	SFC SIVA-5 MW	NO STATION EFFECTED	19:07	19:25	0:18	HAND TRIPPED
1276	15-Feb-21	MYSORE	66	SFC SIVA-ATRIA	NO STATION EFFECTED	18:07	18:40	0:33	HAND TRIPPED
1277	15-Feb-21	MYSORE	66	SFC SIVA-ATRIA	NO STATION EFFECTED	19:07	19:17	0:10	HAND TRIPPED
1278	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	17:51	17:53	0:01	HAND TRIPPED
1279	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	18:10	18:39	0:28	HAND TRIPPED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1280	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	19:03	19:08	0:05	HAND TRIPPED
1281	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 1	NO STATION EFFECTED	14:33 (06/02/2021)	17:47 (15/02/2021)	219:14 HRS	LINE CHARGED
1282	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	18:10	18:39	0:29	HAND TRIPPED
1283	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 2	NO STATION EFFECTED	19:03	19:08	0:05	HAND TRIPPED
1284	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	18:09	18:39	0:30	HAND TRIPPED
1285	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	19:03	19:08	0:05	HAND TRIPPED
1286	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 6	NO STATION EFFECTED	11:45	11:47	0:01	HAND TRIPPED
1287	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 7	NO STATION EFFECTED	18:09	18:39	0:29	HAND TRIPPED
1288	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 7	NO STATION EFFECTED	19:03	19:08	0:04	HAND TRIPPED
1289	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 7	NO STATION EFFECTED	11:47	11:50	0:02	HAND TRIPPED
1290	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	18:10	18:39	0:29	HAND TRIPPED
1291	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 8	NO STATION EFFECTED	19:03	19:08	0:05	HAND TRIPPED
1292	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	18:10	18:39	0:29	HAND TRIPPED
1293	15-Feb-21	MYSORE	66	SFC SIVA-HEBBANI 9	NO STATION EFFECTED	19:03	19:08	0:05	HAND TRIPPED
1294	15-Feb-21	MYSORE	66	SFC SIVA-PGL	NO STATION EFFECTED	18:08	18:44	0:35	HAND TRIPPED
1295	15-Feb-21	MYSORE	66	SFC SIVA-PGL	NO STATION EFFECTED	19:08	19:10	1:00	LINE CLEAR AVAILED
1296	15-Feb-21	MYSORE	66	SFC SIVA-PPCL	NO STATION EFFECTED	18:08	18:46	0:38	HAND TRIPPED
1297	15-Feb-21	MYSORE	66	SFC SIVA-PPCL	NO STATION EFFECTED	19:08	19:10	1:00	LINE CLEAR AVAILED
1298	15-Feb-21	MYSORE	66	SR PATNA-G UKKADA	SRIRANGAPATNA_66	10:57	11:04	0:07	LINE FAULT
1299	15-Feb-21	MYSORE	66	SR PATNA-METAGALLY	SRIRANGAPATNA_66	10:57	11:04	0:07	LINE FAULT
1300	15-Feb-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	07:41	07:51	0:09	LINE FAULT
1301	15-Feb-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	09:13	09:24	0:11	LINE FAULT
1302	15-Feb-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:47	11:57	0:10	LINE FAULT
1303	15-Feb-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	15:03	15:05	0:02	TRANSFORMER FAULT
1304	15-Feb-21	TUMKUR	66	TR-1	TAVAREKERE(C)_66	07:01	07:04	0:03	TRANSFORMER FAULT
1305	15-Feb-21	TUMKUR	66	TR-1	THOVINAKERE_66	12:37	15:09	2:32	LINE CLEAR AVAILED
1306	15-Feb-21	TUMKUR	66	TR-1	THOVINAKERE_66	15:30	17:04	1:34	LINE CLEAR AVAILED
1307	15-Feb-21	TUMKUR	66	TR-2	BRAHMASANDRA_66	22:10	22:38	0:27	TRANSFORMER FAULT
1308	15-Feb-21	TUMKUR	66	TR-2	PAVAGADA_66	08:53	09:00	0:07	TRANSFORMER FAULT
1309	15-Feb-21	TUMKUR	66	TR-2	SANIKERE_66	14:48	14:57	0:09	TRANSFORMER FAULT
1310	15-Feb-21	TUMKUR	66	TR-2	SANIKERE_66	16:19	16:27	0:07	TRANSFORMER FAULT
1311	15-Feb-21	TUMKUR	110	HONNAVALI 110-ADAN SOLAR IPP 66	ADAN SOLAR_IPP_110	7:03:43 PM(15.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1312	15-Feb-21	TUMKUR	110	NITTUR 220kV- KADABA	KADABA_110	15:06	15:08	0:01	HAND TRIPPED
1313	15-Feb-21	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	12:09	15:19	3:09	LINE CLEAR AVAILED
1314	15-Feb-21	TUMKUR	110	NITTUR 220kV- KG TEMPLE	KGTEMPLE_110, UNGRA_110	12:12	15:10	2:58	LINE CLEAR AVAILED
1315	15-Feb-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:39	12:26	0:47	HAND TRIPPED
1316	15-Feb-21	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	15:48	18:20	2:32	LINE CLEAR AVAILED
1317	15-Feb-21	TUMKUR	220	KB CROSS 220kV- NELAMANGALA	KBCROSS_220	10:57	10:59	0:01	HAND TRIPPED
1318	15-Feb-21	TUMKUR	220	NEELAGUNDA220kV- GUTTUR 220kV	NEELAGUNDA_220	11:03	19:52	8:48	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1319	15-Feb-21	TUMKUR	220	NITTUR 220kv- ARASIKERE	NITTUR_220	15:06	15:23	0:17	MAIN SUPPLY FAILURE
1320	15-Feb-21	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	12:09	15:06	2:57	LINE CLEAR AVAILED