400/220/110/66 kV TRANSMISSION OUTAGES FROM:20.12.21 TO 27.12.2021

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
1	21-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
2	21-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
3	21-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
4	21-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
5	21-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
6	21-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
7	21-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
8	21-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN, LINE CLEAR AVAILED
9	21-Dec-2021	BAGALKOT	110	ummachagi - Kiruvatti	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN,LINE FAULT
10	21-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
11	21-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
12	21-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
13	21-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
14	21-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN, LINE CLEAR AVAILED
15	21-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE FAULT
16	21-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
17	21-Dec-2021	BAGALKOT	66	66/33,HV3	HARIHAR HOSPET_66	13:23 (20.12.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
18	21-Dec-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:01	9:06	0:05	TRANSFORMER FAULT
19	21-Dec-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	15:37	15:45	0:08	TRANSFORMER FAULT
20	21-Dec-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	17:09	17:35	0:26	LINE CLEAR AVAILED
21	21-Dec-2021	BAGALKOT	110	ANKOLA-ARGA(L1)	ARGA_110	9:07	9:20	0:13	NFBC ISSUED
22	21-Dec-2021	BAGALKOT	110	GADAG-DAMBAL	DAMBAL_110	5:28	11:32	6:04	LINE FAULT
23	21-Dec-2021	BAGALKOT	110	110/11KV,HV1	GADAG_110	11:28	17:06	5:38	LINE CLEAR AVAILED
24	21-Dec-2021	BAGALKOT	110	HUNGUND-KUDAL SANGAM	KUDALSANGAM_110	4:54	5:20	0:26	LINE FAULT
25	21-Dec-2021	BAGALKOT	110	110/11KV,HV1	ISLAMPUR_110	10:48	11:00	0:12	LINE CLEAR AVAILED
26	21-Dec-2021	BAGALKOT	110	110/33KV,HV3	MACHE_110	22:56	22:58	0:02	HAND TRIPPED
27	21-Dec-2021	BAGALKOT	110	110/11KV, HV1	TILUVALLI_110	4:21	10:41	6:20	TRANSFORMER FAULT
28	21-Dec-2021	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	16:10	16:18	0:08	TRANSFORMER FAULT
29	21-Dec-2021	BAGALKOT	110	110/11KV, HV1	MANTUR(G)_110	7:37	7:52	0:15	TRANSFORMER FAULT
30	21-Dec-2021	BAGALKOT	110	110/11KV, HV2	MANTUR(G)_110	7:37	7:52	0:15	TRANSFORMER FAULT
31	21-Dec-2021	BAGALKOT	110	110/11KV, HV2	MANTUR(G)_110	6:40	6:46	0:06	TRANSFORMER FAULT
32	21-Dec-2021	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	9:23	11:40	2:17	LINE CLEAR AVAILED
33	21-Dec-2021	BAGALKOT	110	GADAG220-DAMBAL	GADAG_220	6:30	11:02	4:32	LINE FAULT
34	21-Dec-2021	BAGALKOT	110	AMBEWADI-NK-2	AMBEWADI_220	21:59	22:04	0:05	HAND TRIPPED
35	21-Dec-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI 220	9:48	19:04	9:16	LINE FAULT
36	21-Dec-2021	BAGALKOT	110	110/33KV, HV2	HUBLI 220	10:29	18:41	8:12	LINE CLEAR AVAILED
37	21-Dec-2021	BAGALKOT	110	110/11KV,HV4	HUBLI 220	16:20	18:56	2:36	LINE CLEAR AVAILED
<u> </u>				. ,	· - ·				

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
38	21-Dec-2021	BAGALKOT	110	KARWAR220- ARGA	KARWAR_220	9:10	12:24	3:14	LINE CLEAR AVAILED
39	21-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAHPUR(TALANDAGE)	CHIKKODI_220	9:43	18:36	8:53	LINE CLEAR AVAILED
40	21-Dec-2021	BAGALKOT	110	VAJRAMATTI220- MANTUR1	VAJRAMATTI_220	6:48	7:12	0:24	LINE FAULT
41	21-Dec-2021	BAGALKOT	220	RANEBENNUR- GUTTUR	RANEBENNUR_220	18:06 (20.12.2021)	10:16 (21.12.2021)	16:10hrs	LINE CHARGED
42	21-Dec-2021	BAGALKOT	110	GADAG220-DAMBAL	GADAG_220	13:22	13:40	0:18	HAND TRIPPED
43	21-Dec-2021	BAGALKOT	110	110/11KV, HV1	ITANAL_110	7:50	8:10	0:20	TRANSFORMER FAULT
44	21-Dec-2021	BAGALKOT	110	BAGALKOT- KERUR	BAGALKOT_220	14:20	14:35	0:15	LINE FAULT
45	21-Dec-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	9:48	19:04	9:16	LINE FAULT
46	21-Dec-2021	BAGALKOT	110	HUBLI- KALGHATAGI	HUBLI_220	21:39 (21.12.2021)			LINE OPEN,LINE FAULT
47	21-Dec-2021	BENGALURU	66	BRIGADE MEADOWS - SOMANAHALLI 220	BRIGADE MEADOWS	10:45	10:46	0:01	LOAD CHANGE OVER
48	21-Dec-2021	BENGALURU	66	BRIGADE MEADOWS - SUBRAMANYAPURA 220	BRIGADE MEADOWS	16:35	16:36	0:01	LOAD CHANGE OVER
49	21-Dec-2021	BENGALURU	66	HV1	BANASAWADI	12:46	12:57	0:11	MAIN SUPPLY FAILURE
50	21-Dec-2021	BENGALURU	66	HV3	BANASAWADI	12:46	12:57	0:11	MAIN SUPPLY FAILURE
51	21-Dec-2021	BENGALURU	66	HV1	BANASAWADI	13:32	13:36	0:04	LOAD CHANGE OVER
52	21-Dec-2021	BENGALURU	66	HV3	BANASAWADI	13:32	13:36	0:04	LOAD CHANGE OVER
53	21-Dec-2021	BENGALURU	66	ELITE PROMENEDE - RBI	ELITE PROMENEDE	12:12	12:20	0:08	LOAD CHANGE OVER
54	21-Dec-2021	BENGALURU	66	ELITE PROMENEDE - KHODAYS 220	ELITE PROMENEDE	15:48	15:53	0:05	LOAD CHANGE OVER
55	21-Dec-2021	BENGALURU	66	HEBBALA 220 - BANASAWADI	BANASAWADI	12:46	12:57	0:11	LINE FAULT
56	21-Dec-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	7:40	7:44	0:04	LOAD CHANGE OVER
57	21-Dec-2021	BENGALURU	66	SAHAKARI NAGAR - MANYATHA TECH PARK 220	SAHAKARI NAGAR	15:50	15:55	0:05	LOAD CHANGE OVER
58	21-Dec-2021	BENGALURU	66	HV2	NRS 220	11:43	11:45	0:02	HAND TRIPPED
59	21-Dec-2021	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	13:34	13:35	0:01	LOAD CHANGE OVER
60	21-Dec-2021	BENGALURU	66	RBI - KHODAYS 220	RBI	15:40	15:42	0:02	LOAD CHANGE OVER
61	21-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD	6:19	6:33	0:14	LINE FAULT
62	21-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	7:09	7:26	0:17	LINE FAULT
63	21-Dec-2021	BENGALURU	66	SHOBHA FOREST - SOMANAHALLI 220	SHOBHA FOREST	10:43	10:54	0:11	LOAD CHANGE OVER
64	21-Dec-2021	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	16:42	16:47	0:05	LOAD CHANGE OVER
65	21-Dec-2021	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	6:19	6:33	0:14	LINE FAULT
66	21-Dec-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	NO STATION AFFECTED	6:19	6:42	0:23	LINE FAULT
67	21-Dec-2021	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	16:01	16:08	0:07	LOAD CHANGE OVER
68	21-Dec-2021	BENGALURU	66	HV1	KYALANUR	11:46	12:45	0:58	LINE CLEAR AVAILED
69	21-Dec-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	6:48	7:01	0:13	LINE FAULT
70	21-Dec-2021	BENGALURU	66	HV2	YEDUMADU	11:40	11:50	0:10	LINE CLEAR AVAILED
71	21-Dec-2021	BENGALURU	220	HV3	KOLAR 220	11:59	20:15	8:16	LINE CLEAR AVAILED
72	21-Dec-2021	BENGALURU	220	LV3	KOLAR 220	11:59	20:28	8:29	LINE CLEAR AVAILED
73	21-Dec-2021	BENGALURU	66	KOLAR 220 - BANGARPET 1	NO STATION AFFECTED	11:50	12:11	0:21	LINE CLEAR AVAILED
74	21-Dec-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	NO STATION AFFECTED	11:50	12:11	0:21	LINE CLEAR AVAILED
75	21-Dec-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	11:51	12:11	0:20	LINE CLEAR AVAILED
76	21-Dec-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	11:53	12:13	0:20	LINE CLEAR AVAILED
77	21-Dec-2021	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	11:53	12:13	0:20	LINE CLEAR AVAILED
78	21-Dec-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	11:53	12:14	0:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
79	21-Dec-2021	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	11:53	12:14	0:21	LINE CLEAR AVAILED
80	21-Dec-2021	BENGALURU	66	HV1	KOLAR 220	11:54	12:11	0:17	LINE CLEAR AVAILED
81	21-Dec-2021	BENGALURU	66	HV2	KOLAR 220	11:58	12:11	0:13	LINE CLEAR AVAILED
	21-Dec-2021	DENICALLIBLE	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR,	44.54	12:12	0.10	LINE CLEAR AVAILED
82	24.5. 2024	BENGALURU		WOLAR 220 NANGALI	YELDUR	11:54	12:13	0:19	MAIN CURRING FAILURE
83	21-Dec-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	17:50	18:50	1:00	MAIN SUPPLY FAILURE
84	21-Dec-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	17:53	19:05	1:12	MAIN SUPPLY FAILURE
85	21-Dec-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	18:50	19:07	0:17	MAIN SUPPLY FAILURE
86	21-Dec-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	20:20	20:30	0:10	LINE CLEAR AVAILED
87	21-Dec-2021	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	20:20	20:30	0:10	LINE CLEAR AVAILED
88	21-Dec-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	20:20	20:30	0:10	LINE CLEAR AVAILED
89	21-Dec-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	20:20	20:30	0:10	LINE CLEAR AVAILED
90	21-Dec-2021	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	20:20	20:30	0:10	LINE CLEAR AVAILED
91	21-Dec-2021	BENGALURU	66	HV1	KOLAR 220	20:25	20:30	0:05	HAND TRIPPED
92	21-Dec-2021	BENGALURU	66	HV2	KOLAR 220	20:25	20:30	0:05	HAND TRIPPED
93	21-Dec-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	14:10	14:18	0:08	MAIN SUPPLY FAILURE
94	21-Dec-2021	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	14:10	14:18	0:08	MAIN SUPPLY FAILURE
95	21-Dec-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	14:10	14:18	0:08	MAIN SUPPLY FAILURE
96	21-Dec-2021	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	14:10	14:18	0:08	MAIN SUPPLY FAILURE
97	21-Dec-2021	BENGALURU	66	KOLAR 220 - THAYLUR	TAMAKA	14:10	14:18	0:08	MAIN SUPPLY FAILURE
98	21-Dec-2021	BENGALURU	66	HV1	KOLAR 220	14:10	14:18	0:08	MAIN SUPPLY FAILURE
99	21-Dec-2021	BENGALURU	66	HV2	KOLAR 220	14:10	14:18	0:08	MAIN SUPPLY FAILURE
100	21-Dec-2021	BENGALURU	66	HV1	DALSANUR	12:00	12:45	0:45	LINE CLEAR AVAILED
101	21-Dec-2021	BENGALURU	66	HV2	CHANDAPURA	15:23	15:30	0:06	LINE CLEAR AVAILED
102	21-Dec-2021	BENGALURU	66	RAMANAGARA - BEVOOR	BEVVOR, SANKALGERE, DASHAVARA	10:15	15:30	5:15	LINE CLEAR AVAILED
103	21-Dec-2021	BENGALURU	220	BEGUR 220 - HOODY 220	NO STATION AFFECTED	10:42	14:16	3:34	LINE CLEAR AVAILED
104	21-Dec-2021	BENGALURU	66	HV2	HONNIGANANHALLI	15:39(21-12-2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
105	21-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
106	21-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
107	21-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
108	21-Dec-2021	GULBARGA	220	HV2	HUMNABAD_220	10:49	20:40	9:51	LINE CLEAR AVAILED
109	21-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	1:05	7:02	5:57	LINE CLEAR AVAILED
110	21-Dec-2021	GULBARGA	110	LV2	HUMNABAD_220	10:49			TRANSFORMER OPEN,LINE CLEAR AVAILED
111	21-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:313(19.12.2021)			LINE OPEN, LINE CLEAR AVAILED
112	21-Dec-2021	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGAWEST_110	7:50(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
113	21-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN, LINE CLEAR AVAILED
114	21-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
115	21-Dec-2021	GULBARGA	110	HUMNABAD-HALLIKHED	HALLIKHED_110	10:49			LINE OPEN, LINE CLEAR AVAILED
116	21-Dec-2021	GULBARGA	110	HV2	HANUMNAL_110	10:55	11:40	0:45	LINE CLEAR AVAILED
117	21-Dec-2021	GULBARGA	110	HV1	GOOGLE_110	11:10	11:15	0:05	TRANSFORMER FAULT
118	21-Dec-2021	GULBARGA	110	SHAHPUR-KBJNL	KBJNL_110	4:34	4:40	0:06	LINE FAULT
119	21-Dec-2021	GULBARGA	110	SINDHANOOR-ADAVI AMARESHWAR	ADAVI AMARESHWAR_110	7:36	7:46	0:10	LINE FAULT
120	21-Dec-2021	GULBARGA	110	MASKI-RENEWSOLAR	MASKI_110	18:25(21.12.2021)	1:46(22.12.2 021)	7:21hrs	LINE CHARGED
121	21-Dec-2021	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	3:00	3:05	0:05	MAIN SUPPLY FAILURE
122	21-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	3:00	6:05	3:05	LINE FAULT
123	21-Dec-2021	GULBARGA	110	CHINCHOLI-SEDAM1	CHINCHOLI_110	15:42	16:40	0:58	LINE CLEAR AVAILED
124	21-Dec-2021	GULBARGA	110	CHINCHOLI-MANEKHELI	CHINCHOLI_110	15:42	16:45	1:03	LINE CLEAR AVAILED
125	21-Dec-2021	GULBARGA	110	CHINCHOLI-CHETTINAD_IPP	CHINCHOLI_110	15:42	16:46	1:04	LINE CLEAR AVAILED
126	21-Dec-2021	GULBARGA	110	CHINCHOLI-RENEWSOLAR_IPP	CHINCHOLI_110	15:42	16:45	1:03	LINE CLEAR AVAILED
127	21-Dec-2021	GULBARGA	110	JAWALGERA-SINDHNOOR	JAWALGERA_110	7:35	7:45	0:10	MAIN SUPPLY FAILURE
128	21-Dec-2021	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	19:28	19:35	0:07	MAIN SUPPLY FAILURE
129	21-Dec-2021	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	15:50	16:43	0:53	LINE CLEAR AVAILED
130	21-Dec-2021	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	3:00	3:05	0:05	LINE FAULT
131	21-Dec-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	GANDHINAGAR_110,THUR VIHAL_110	10:50	17:55	7:05	LINE CLEAR AVAILED
132	21-Dec-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_1 10,KEREHALLI_110,MALLA PUR_110	13:50	13:59	0:09	LINE FAULT
133	21-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	18:46	18:57	0:11	LINE FAULT
134	21-Dec-2021	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	21:25	21:45	0:20	LINE FAULT
135	21-Dec-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	9:25	13:00	3:35	TRANSFORMER FAULT
136	21-Dec-2021	GULBARGA	66	HV1	TAMBRAHALLI_66	16:23	16:25	0:02	HAND TRIPPED
137	21-Dec-2021	GULBARGA	66	HV2	TAMBRAHALLI_66	16:25	16:30	0:05	HAND TRIPPED
138	21-Dec-2021	GULBARGA	66	TAMBRAHALLI-ITTAGGI	TAMBRAHALLI_66	9:40	12:50	3:10	LINE CLEAR AVAILED
139	21-Dec-2021	GULBARGA	66	HALAVAGALU-HARVI	HARVI_66	9:10	9:15	0:05	LINE FAULT
140	21-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)	18:00 (21.12.2021)	743:47 HRS	TRANSFORMER CHARGED
141	21-Dec-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:07(20.12.2021)	6:56 (21.2.2021)	10:48 hrs	LINE CHARGED
142	21-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:14(20.12.2021)	8:48(21.12.2 021)	14:33 hrs	LINE CHARGED
143	21-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:41(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
144	21-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
145	21-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
146	21-Dec-2021	HASSAN	110	HV1	MADHUVANA_110	10:05(21.12.2021			TRANSFORMER OPEN,LINE CLEAR AVAILED
147	21-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	13:27	16:37	3:10	LINE FAULT
148	21-Dec-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	11:21	12:56	1:35	LINE CLEAR AVAILED
149	21-Dec-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	17:50	22:08	4:18	LINE FAULT
150	21-Dec-2021	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	13:36	18:21	4:45	LINE FAULT
151	21-Dec-2021	HASSAN	220	MRSSHM-VARAHI2	MRSMG_220	16:08	19:28	3:20	LINE FAULT
152	21-Dec-2021	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	10:59	12:50	1:51	LINE CLEAR AVAILED
153	21-Dec-2021	HASSAN	110	MRSSHM-BADRAVATY2	MRSMG_220	13:03	15:43	2:40	LINE CLEAR AVAILED
154	21-Dec-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:07	16:56	6:49	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
155	21-Dec-2021	HASSAN	220	SHRAVTY-TALAGUPPA1	sharavathy_gen	11:21	12:56	1:35	LINE CLEAR AVAILED
156	21-Dec-2021	HASSAN	220	UPCL-KEMAR1	upcl_gen	9:13	21:24	12:11	LINE CLEAR AVAILED
157	21-Dec-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	17:49	22:08	4:19	LINE FAULT
158	21-Dec-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	13:36	18:21	4:45	LINE FAULT
159	21-Dec-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	14:10	14:41	0:31	LINE FAULT
160	21-Dec-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	16:08	19:28	3:20	LINE FAULT
161	21-Dec-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	14:10	14:44	0:34	LINE FAULT
162	21-Dec-2021	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	14:10	14:16	0:06	LINE FAULT
163	21-Dec-2021	HASSAN	110	HV1	HOSANGADI_110	10:37	15:12	4:35	LINE CLEAR AVAILED
164	21-Dec-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	8:50	18:39	9:49	LINE CLEAR AVAILED
165	21-Dec-2021	HASSAN	66	BYACHAN-HNPURA	BYACHANAHALLI_66	10:39	16:53	6:14	LINE CLEAR AVAILED
166	21-Dec-2021	HASSAN	66	HV1	BYACHANAHALLI_66	10:31	16:54	6:23	LINE CLEAR AVAILED
167	21-Dec-2021	HASSAN	66	GANGUR-HASSAN	GANGUR_66	10:10	16:01	5:51	LINE CLEAR AVAILED
168	21-Dec-2021	HASSAN	66	HV1	GANGUR_66	10:11	16:02	5:51	LINE CLEAR AVAILED
169	21-Dec-2021	HASSAN	66	HV1	HALEBEEDU_66	10:10	15:13	5:03	LINE CLEAR AVAILED
170	21-Dec-2021	HASSAN	66	HV2	HALEBEEDU_66	10:10	15:13	5:03	LINE CLEAR AVAILED
171	21-Dec-2021	HASSAN	66	HNPR2-HASS1	HOLENARASIPURA_220	9:59	15:58	5:59	LINE CLEAR AVAILED
172	21-Dec-2021	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	12:15	12:41	0:26	LINE CLEAR AVAILED
173	21-Dec-2021	HASSAN	66	HV1	HOLENARASIPURA_220	10:26	17:37	7:11	LINE CLEAR AVAILED
174	21-Dec-2021	HASSAN	66	HV1	KANDLI_66	10:27	17:45	7:18	LINE CLEAR AVAILED
175	21-Dec-2021	HASSAN	66	HV2	KANDLI_66	10:27	17:45	7:18	LINE CLEAR AVAILED
176	21-Dec-2021	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	12:21	12:42	0:21	NFBC ISSUED
177	21-Dec-2021	HASSAN	66	HV1	MOSALEHOSAHALLI_66	12:21	12:42	0:21	NFBC ISSUED
178	21-Dec-2021	HASSAN	66	HV1	SAKLESHPURA_66	11:24	11:36	0:12	HAND TRIPPED
179	21-Dec-2021	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	9:43	10:21	0:38	LINE CLEAR AVAILED
180	21-Dec-2021	MYSURU	66	HV1	HULLAHALLI_66	13:00	14:10	1:10	LINE CLEAR AVAILED
181	21-Dec-2021	MYSURU	66	HV2	HULLAHALLI_66	11:54	13:21	1:27	LINE CLEAR AVAILED
182	21-Dec-2021	MYSURU	66	HUNSUR-HOOTGALLI	BANNIKUPPE_66 HOSURGATE_66 HUNSUR 66	10:04	18:09	8:04	NFBC ISSUED
183	21-Dec-2021	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	10:45	14:28	3:43	NFBC ISSUED
184	21-Dec-2021	MYSURU	66	KR NAGARA-BILIKERE	NO STATIONS EFFECTED	11:28	15:44	4:15	LINE CLEAR AVAILED
185	21-Dec-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	17:07	17:13	0:06	LINE FAULT
186	21-Dec-2021	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	16:48	16:57	0:08	LINE FAULT
187	21-Dec-2021	MYSURU	66	HV2	MADIKERI_66	11:16	15:24	4:07	LINE CLEAR AVAILED
188	21-Dec-2021	MYSURU	66	MEGHALAPURA-HEBBANI	BG PURA_66 CHIDRAWALLI_66 THUMBLA_66	3:17	3:30	0:12	LINE FAULT
189	21-Dec-2021	MYSURU	66	PERIAPATNA-HANGUD	PONNAMPET_66VIRAJPET _66 HANGOD_66	11:54	12:25	0:31	LINE CLEAR AVAILED
190	21-Dec-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	10:57	15:10	4:12	LINE CLEAR AVAILED
191	21-Dec-2021	MYSURU	66	TN PURA-THAYUR	TNARASIPURA_66	10:00	17:20	7:20	LINE CLEAR AVAILED
192	21-Dec-2021	MYSURU	66	VAJMANGLA-KADAKOLAL1	MARADIHUNDI_66 AYRALLI_66	1:17	1:28	0:11	LINE FAULT
193	21-Dec-2021	MYSURU	220	HV1	HEBBANI_220	8:51	10:56	2:05	LINE CLEAR AVAILED
194	21-Dec-2021	MYSURU	220	HV2	HEBBANI_220	11:04	12:45	1:41	LINE CLEAR AVAILED
195	21-Dec-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	18:11:07(21.12.2021)			LINE OPEN,LINE FAULT
196	21-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
197	21-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
198	21-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN, LINE CLEAR AVAILED
199	21-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01(30.10.2021)			LINE OPEN, LINE CLEAR AVAILED
200	21-Dec-2021	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 2(MAGADI)	ANCHEPALYA_220	12:04	14:07	2:03	LINE CLEAR AVAILED
201	21-Dec-2021	TUMKUR	220	TR-2	DAVANGERE_SRS_220	9:27	18:07	8:39	LINE CLEAR AVAILED
202	21-Dec-2021	TUMKUR	220	TR-2	HIRIYUR_220	4:23	4:40	0:17	TRANSFORMER FAULT
203	21-Dec-2021	TUMKUR	220	TR-3	HIRIYUR_220	4:23	4:40	0:17	TRANSFORMER FAULT
204	21-Dec-2021	TUMKUR	220	TR-1	MADHUGIRI_220	13:03	13:30	0:26	LINE CLEAR AVAILED
205	21-Dec-2021	TUMKUR	220	TR-3	THALLAK_220	15:22	17:57	2:35	LINE CLEAR AVAILED
206	21-Dec-2021	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	16:04	17:44	1:39	LINE CLEAR AVAILED
207	21-Dec-2021	TUMKUR	66	TR-2(HV-2)	CHANNAGIRI_66	16:46	16:57	0:10	TRANSFORMER FAULT
208	21-Dec-2021	TUMKUR	66	TR-3	CHITRADURGA_220	10:27	16:37	6:09	LINE CLEAR AVAILED
209	21-Dec-2021	TUMKUR	66	TR-4	CHITRADURGA_220	10:27	16:28	6:00	LINE CLEAR AVAILED
210	21-Dec-2021	TUMKUR	66	DAVANGERE SRS- CHITRADURGA2	CHITRADURGA_220	14:50	15:15	0:25	LINE FAULT
211	21-Dec-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	13:23	15:50	2:26	LINE CLEAR AVAILED
212	21-Dec-2021	TUMKUR	66	TR-1	GARAGA_66	10:43	17:39	6:55	LINE CLEAR AVAILED
213	21-Dec-2021	TUMKUR	66	TR-2	GARAGA_66	10:43	17:39	6:55	LINE CLEAR AVAILED
214	21-Dec-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	4:35	4:46	0:11	LINE FAULT
215	21-Dec-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	4:33	4:48	0:15	LINE FAULT
216	21-Dec-2021	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	4:32	4:46	0:14	LINE FAULT
217	21-Dec-2021	TUMKUR	66	HIRIYUR220kV-BEVINAHALLI	JAVAGONDANAHALLI_66, BEVINAHALLI_66	4:32	4:46	0:14	LINE FAULT
218	21-Dec-2021	TUMKUR	66	HIRIYUR 220KV- MATHOD	MATHOD_66	4:32	4:46	0:14	LINE FAULT
219	21-Dec-2021	TUMKUR	66	TR-2	HONNUDIKE_66	13:48	13:52	0:03	TRANSFORMER FAULT
220	21-Dec-2021	TUMKUR	66	TR-1(HV-1)	MADHUGIRI_220	13:03	13:38	0:35	HAND TRIPPED
221	21-Dec-2021	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA(SIRA2)	KALLAMBELLA_66, SIRA_66	13:02	13:38	0:35	HAND TRIPPED
222	21-Dec-2021	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66	13:02	13:38	0:35	HAND TRIPPED
223	21-Dec-2021	TUMKUR	66	TR-1(LV-1)	MADHUGIRI_220	13:02	13:36	0:33	HAND TRIPPED
224	21-Dec-2021	TUMKUR	66	MADHUGIRI 220kV- PULLAMAGATTA	PULLAMGATTA_66	13:00	13:26	0:25	HAND TRIPPED
225	21-Dec-2021	TUMKUR	66	MADHUGIRI 220kV- SIRA	GULIGENAHALLI_66,	13:01	13:38	0:36	HAND TRIPPED
226	21-Dec-2021	TUMKUR	66	TR-1	MADADKERE_66	10:31	16:11	5:39	LINE CLEAR AVAILED
227	21-Dec-2021	TUMKUR	66	TR-2	MADADKERE_66	10:31	16:11	5:39	LINE CLEAR AVAILED
228	21-Dec-2021	TUMKUR	66	TR-1	PAVAGADA_66	2:51	2:59	0:07	TRANSFORMER FAULT
229	21-Dec-2021	TUMKUR	66	TR-1	PAVAGADA_66	7:47	7:52	0:04	TRANSFORMER FAULT
230	21-Dec-2021	TUMKUR	66	TR-1	PAVAGADA_66	12:15	12:39	0:23	TRANSFORMER FAULT
231	21-Dec-2021	TUMKUR	66	TR-1	PAVAGADA_66	14:36	14:47	0:10	TRANSFORMER FAULT
232	21-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	9:49	9:55	0:06	TRANSFORMER FAULT
233	21-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	10:51	11:00	0:08	TRANSFORMER FAULT
234	21-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	12:02	16:00	3:57	LINE CLEAR AVAILED
235	21-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	12:50	12:58	0:07	LINE FAULT
236	21-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	14:21	14:27	0:06	LINE FAULT
237	21-Dec-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	16:28	16:42	0:13	LINE CLEAR AVAILED
238	22-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
239	22-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
240	22-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
241	22-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
242	22-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
243	22-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
244	22-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
245	22-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN, LINE CLEAR AVAILED
246	22-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN,LINE FAULT
247	22-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)	14:22 (22.12.2021)	220:04hrs	LINE CHARGED
248	22-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
249	22-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
250	22-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
251	22-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN, LINE CLEAR AVAILED
252	22-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE FAULT
253	22-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
254	22-Dec-2021	BAGALKOT	66	66/33,HV3	HARIHAR HOSPET_66	13:23 (20.12.2021)	16:56 (22.12.2021)	51:33hrs	TRANSFORMER CHARGED
255	22-Dec-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:49	15:48	2:59	LINE CLEAR AVAILED
256	22-Dec-2021	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	19:49	19:56	0:07	LINE FAULT
257	22-Dec-2021	BAGALKOT	110	ALMEL-KPR I SUGARS	ALMEL_110	19:49	19:55	0:06	LINE FAULT
258	22-Dec-2021	BAGALKOT	110	GADG ROAD -NW RAILWAY(BIDNAL)	GADAG ROAD_110	18:34	19:01	0:27	LINE FAULT
259	22-Dec-2021	BAGALKOT	110	110/11KV,HV1&2	HANAGAL_110	10:10	17:54	7:44	LINE CLEAR AVAILED
260	22-Dec-2021	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	2:03	2:10	0:07	TRANSFORMER FAULT
261	22-Dec-2021	BAGALKOT	110	110/33KV,HV3	MACHE_110	21:36	21:37	0:01	HAND TRIPPED
262	22-Dec-2021	BAGALKOT	110	110/11KV,HV2	MUNDAGOD_110	17:50	17:55	0:05	HAND TRIPPED
263	22-Dec-2021	BAGALKOT	110	BIDNAL-PH COMPUND	PH COMPOUND_110	14:23	16:46	2:23	LOAD CHANGE OVER
264	22-Dec-2021	BAGALKOT	110	RON-GAMESH	RON_110	17:04	17:13	0:09	HAND TRIPPED
265	22-Dec-2021	BAGALKOT	110	110/11KV,HV3	SAVALAGI_110	15:24	17:05	1:41	TRANSFORMER FAULT
266	22-Dec-2021	BAGALKOT	110	VAJRAMATTI220- BILAGI(SHIRGUPPI)	VAJRAMATTI_220	19:51	20:03	0:12	LINE FAULT
267	22-Dec-2021	BAGALKOT	220	GHATAPRABHA220- KABBUR	GHATAPRABHA_220	14:13	15:53	1:40	LINE CLEAR AVAILED
268	22-Dec-2021	BAGALKOT	110	HAVERI220- TILUVALLI(HANGAL)	HAVERI_220	10:02	16:34	6:32	LINE CLEAR AVAILED
269	22-Dec-2021	BAGALKOT	220	BIDNAL- TADAS1(HIREBENDIGERI1)	BIDNAL_220	10:09	17:54	7:45	LINE CLEAR AVAILED
270	22-Dec-2021	BAGALKOT	220	BIDNAL- TADAS2(HIREBENDIGERI2)	BIDNAL_220	10:10	17:57	7:47	LINE CLEAR AVAILED
	22-Dec-2021	BAGALKOT		220/110KV, HV1&LV1	KUDACHI_220, TERDAL_110, AINAPUR_110, KUDACHI_110, UGARKHUD_110,	12:40	12:47	0:07	TRANSFORMER FAULT
271			220		YELPARHATTI 110				

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
272	22-Dec-2021	BAGALKOT	220	220/110KV, HV2&LV2	KUDACHI_220, TERDAL_110, AINAPUR_110, KUDACHI_110, UGARKHUD_110, YELPARHATTI 110	12:40	12:46	0:06	TRANSFORMER FAULT
273	22-Dec-2021	BAGALKOT	110	KUDACHI220- UGARKHUD(KUDACHI110)	KUDACHI_220	12:40	13:34	0:54	LINE FAULT
274	22-Dec-2021	BAGALKOT	110	HUBLI- KALGHATAGI	HUBLI_220	21:39 (21.12.2021)	16:05 (22.12.2021)	18:26hrs	LINE CHARGED
275	22-Dec-2021	BAGALKOT	110	VAJRAMATTI220- SHIRGUPPI	SHIRAGUPPI_110	19:55	20:05	0:10	LINE FAULT
276	22-Dec-2021	BAGALKOT	110	SHIRAGUPPI- BILAGI	BILAGI_110,GIRISAGAR_11 0,BISNAL_110,TOLAMATTI _110	19:55	20:05	0:10	MAIN SUPPLY FAILURE
277	22-Dec-2021	BAGALKOT	110	110/33KV, HV4	ANKALI_110	3:05	3:45	0:40	TRANSFORMER FAULT
278	22-Dec-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	12:37	16:29	3:52	LINE FAULT
279	22-Dec-2021	BAGALKOT	110	110/11KV, HV1	HUBLI_220	9.25	10:33	4:33	LINE CLEAR AVAILED
280	22-Dec-2021	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	0:30	0:41	0:11	LOAD CHANGE OVER
281	22-Dec-2021	BENGALURU	66	HV2	KENGERI SATELLITE TOWN	11:42	11:44	0:02	HAND TRIPPED
282	22-Dec-2021	BENGALURU	66	HV1	RR NAGAR	12:45	12:50	0:05	HAND TRIPPED
283	22-Dec-2021	BENGALURU	66	HV2	RR NAGAR	14:10	14:13	0:03	HAND TRIPPED
284	22-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON	0:30	0:41	0:11	LINE FAULT
285	22-Dec-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, D CROSS	7:42	7:51	0:09	LINE FAULT
286	22-Dec-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, D CROSS	8:07	8:32	0:25	LINE FAULT
287	22-Dec-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA, D CROSS	17:23	17:29	0:05	LOAD CHANGE OVER
288	22-Dec-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	15:46	17:07	1:20	LINE CLEAR AVAILED
289	22-Dec-2021	BENGALURU	66	T G HALLY - ANCHEPALYA 220	T G HALLY	6:45	7:14	0:29	MAIN SUPPLY FAILURE
290	22-Dec-2021	BENGALURU	66	HV1	MANCHENAHALLI	15:14	15:48	0:34	LINE CLEAR AVAILED
291	22-Dec-2021	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	14:00	14:24	0:24	LINE FAULT
292	22-Dec-2021	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	13:39	13:52	0:12	LINE CLEAR AVAILED
293	22-Dec-2021	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	10:00	12:00	2:00	LINE CLEAR AVAILED
294	22-Dec-2021	BENGALURU	66	KIADB DB PURA 220 - HIMAT SINGHA FACTORY (EHT)	HIMAT SINGHA FACTORY (EHT)	15:11	15:49	0:37	LINE CLEAR AVAILED
295	22-Dec-2021	BENGALURU	220	HV1	KIADB DB PURA 220	12:24	17:21	4:57	LINE CLEAR AVAILED
296	22-Dec-2021	BENGALURU	66	HV2	AVANI	11:55	13:00	1:05	LINE CLEAR AVAILED
297	22-Dec-2021	BENGALURU	66	HV1	AVANI	13:00	14:20	1:20	LINE CLEAR AVAILED
298	22-Dec-2021	BENGALURU	66	AVANI - MULBAGALU	MULBAGALU	13:30	14:20	0:50	LINE CLEAR AVAILED
299	22-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)	11:30(22-12-		LINE OPEN,LINE FAULT
300	22-Dec-2021	BENGALURU	66	HV2	HONNIGANANHALLI	15:39(21-12-2021)	2021)	19:50hrs	TRANSFORMER CHARGED
301	22-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
302	22-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
303	22-Dec-2021	GULBARGA	220	HV2,LV2	HALBARGA_220	2:50	2:56	0:06	TRANSFORMER FAULT
304	22-Dec-2021	GULBARGA	220	KAPNOOR-SHAHAPUR	SHAHAPUR_220	12:30	15:36	3:06	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
305	22-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
306	22-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN, LINE CLEAR AVAILED
307	22-Dec-2021	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGAWEST_110	7:50(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
308	22-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:09 (22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
309	22-Dec-2021	GULBARGA	110	HV1	SREERAMANAGAR 110	16:25	16:35	0:10	LINE CLEAR AVAILED
310	22-Dec-2021	GULBARGA	110	HV1	SREERAMANAGAR 110	20:00	20:05	0:05	HAND TRIPPED
311	22-Dec-2021	GULBARGA	110	HV1	GHATTARGA 110	16:20	16:23	0:03	HAND TRIPPED
312	22-Dec-2021	GULBARGA	110	HV2	GHATTARGA 110	17:30	17:33	0:03	HAND TRIPPED
313	22-Dec-2021	GULBARGA	110	HV3	KEREHALLI 110	14:25	14:40	0:15	TRANSFORMER FAULT
314	22-Dec-2021	GULBARGA	110	HV1	LADHA 110	13:05	13:35	0:30	TRANSFORMER FAULT
315	22-Dec-2021	GULBARGA	110	HV1	HUMNABAD 110	11:33	11:42	0:09	TRANSFORMER FAULT
313	22-Dec-2021	GOLBANGA	110	1101	HOWINABAD_110	11.33	11.42	0.03	TRANSFORMILE FAULT
316	22-Dec-2021	GULBARGA	110	LV2	HUMNABAD_220	10:49 (21.12.2021)	18:36 (22.12.2021)	31:47 HRS	TRANSFORMER CHARGED
317	22-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:31(19.12.2021)	13:05 (22.12.2021)	65:34 HRS	LINE CHARGED
318	22-Dec-2021	GULBARGA	110	MASKI-RENEWSOLAR	MASKI_110	18:25(21.12.2021)	1:46(22.12.2 021)	7:21hrs	LINE CHARGED
319	22-Dec-2021	GULBARGA	110	ITTAGI-HUVINAHADGALI	HUVINAHADGALI_66,HOL AGUNDI_66	10:50	17:35	6:45	LINE CLEAR AVAILED
320	22-Dec-2021	GULBARGA	110	RAJESHWAR-WARDA	RAJESHWAR_110	18:12	20:18	2:06	LINE CLEAR AVAILED
321	22-Dec-2021	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	20:15	20:25	0:10	LINE FAULT
322	22-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	17:30	17:33	0:03	HAND TRIPPED
323	22-Dec-2021	GULBARGA	110	GHATTARGA-AFZALPUR	AFZALPUR 110	17:30	17:33	0:03	HAND TRIPPED
324	22-Dec-2021	GULBARGA	110	CHITGUPPA-NIRNA	NIRNA 110	11:55	12:00	0:05	MAIN SUPPLY FAILURE
325	22-Dec-2021	GULBARGA	110	GABBUR-BPSLR	GABBUR 110	18:00	21:10	3:10	LINE CLEAR AVAILED
					GURMITKAL_110,KONKAL				
326	22-Dec-2021	GULBARGA	110	SEDAM GURMITKAL	110	8:58	9:10	0:12	LINE FAULT
327	22-Dec-2021	GULBARGA	110	SEDAM-CHITTAPUR	CHITTAPUR_110,KORWAR TEMPLE 110	11:00	16:32	5:32	LINE CLEAR AVAILED
328	22-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPU R_110,WADGERA_110,SA NNATHI_110,CORE GREEN SUGUR IPP	21:42	21:50	0:08	LINE FAULT
329	22-Dec-2021	GULBARGA	110	HUMNABAD-MANEKHELLI	MANEKHELLI_110	11:33	11:43	0:10	LINE FAULT
330	22-Dec-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110,NIRNA_1 10	11:33	11:42	0:09	LINE FAULT
331	22-Dec-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BHALKI SUGAR IPP	2:50	2:58	0:08	LINE FAULT
332	22-Dec-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITAL_110	21:11	21:20	0:09	LINE FAULT
333	22-Dec-2021	GULBARGA	110	KAPNOOR-MAHAGAON	MAHAGAON_110,MARAG UTTI_110	14:50	14:59	0:09	LINE CLEAR AVAILED
334	22-Dec-2021	GULBARGA	66	HV1	PUNABGHATA_66	13:10	13:15	0:05	TRANSFORMER FAULT
335	22-Dec-2021	GULBARGA	66	HV1	CHORNOOR_66	8:45	9:25	0:40	LINE CLEAR AVAILED
336	22-Dec-2021	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI 66	19:20	19:50	0:30	LINE FAULT
337	22-Dec-2021	GULBARGA	66	TELAGI-NEELAGUNDA	TELAGI 66	23:00	23:15	0:15	LINE FAULT
338	22-Dec-2021	GULBARGA	66	NEELGUNDA-TELAGI	TELAGI_66,KURBAHALLI_6 6,YEREGUNTA_66	19:21	19:43	0:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
339	22-Dec-2021	GULBARGA	66	NEELGUNDA-TELAGI	TELAGI_66,KURBAHALLI_6 6,YEREGUNTA 66	22:56	23:08	0:12	LINE FAULT
340	22-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
341	22-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
342	22-Dec-2021	HASSAN	110	HV1	MADHUVANA_110	10:05(21.12.2021			TRANSFORMER OPEN,LINE CLEAR AVAILED
343	22-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:41(21.12.2021)	11:03(22.12. 2021)	16:22HRS	LINE CHARGED
344	22-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	15:53 (22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
345	22-Dec-2021	HASSAN	66	HV1	HANBALU_66	20:59 (22.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
346	22-Dec-2021	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	20:59 (22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
347	22-Dec-2021	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	8:47(22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
348	22-Dec-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	8:31(22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
349	22-Dec-2021	HASSAN	220	HSN	ARASIKERE_220	10:50	18:00	7:10	LINE CLEAR AVAILED
350	22-Dec-2021	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	15:15	18:53	3:38	LINE FAULT
351	22-Dec-2021	HASSAN	220	MRSSHM-VARAHI3	MRSMG 220	0:08	8:50	8:42	LINE FAULT
352	22-Dec-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	15:15	18:53	3:38	LINE FAULT
353	22-Dec-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	0:08	8:50	8:42	LINE FAULT
354	22-Dec-2021	HASSAN	110	HOSNGD-VTRG1	HOSANGADI 110	11:17	13:33	2:16	LINE CLEAR AVAILED
355	22-Dec-2021	HASSAN	110	HV2	HULICAL 110	11:25	17:38	6:13	LINE CLEAR AVAILED
356	22-Dec-2021	HASSAN	110	HV2	KARAYA_110	9:53	11:53	2:00	LINE CLEAR AVAILED
357	22-Dec-2021	HASSAN	110	KEMAR-BELMAN	KEMAR 220	10:10	13:16	3:06	LINE CLEAR AVAILED
358	22-Dec-2021	HASSAN	110	KEMAR-KARKALA	KEMAR 220	14:29	15:47	1:18	LINE CLEAR AVAILED
359	22-Dec-2021	HASSAN	110	KEMAR-MOODAB	KEMAR 220	14:19	15:49	1:30	LINE CLEAR AVAILED
360	22-Dec-2021	HASSAN	110	HV1	KEMAR 220	11:11	15:18	4:07	LINE CLEAR AVAILED
361	22-Dec-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE 110	11:00	15:51	4:51	LINE CLEAR AVAILED
362	22-Dec-2021	HASSAN	110	PUTTUR-PUTUR 2	PUTTUR 220	10:20	13:36	3:16	NFBC ISSUED
363	22-Dec-2021 22-Dec-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR 110	9:49	15:16	5:27	NFBC ISSUED
364	22-Dec-2021 22-Dec-2021	HASSAN	110	HV1	SHIRALKOPPA_220	12:58	14:30	1:32	LINE CLEAR AVAILED
365	22-Dec-2021 22-Dec-2021	HASSAN	110	VITTAL-PUTR SLTUR	VITLA 110	9:50	15:16	5:26	LINE CLEAR AVAILED
366	22-Dec-2021 22-Dec-2021	HASSAN	66	HV1	AREHALLI 66	10:15	18:55	8:40	LINE CLEAR AVAILED
367	22-Dec-2021 22-Dec-2021	HASSAN	66	HV1	BALLUPETE 66	10:16	15:20	5:04	LINE CLEAR AVAILED
368	22-Dec-2021 22-Dec-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	10:08	18:41	8:33	LINE CLEAR AVAILED
369	22-Dec-2021 22-Dec-2021	HASSAN	66	HV1	BANDISHETTIHALLY 66	7:05	7:13	0:08	MAIN SUPPLY FAILURE
-	22-Dec-2021 22-Dec-2021	HASSAN	66	HV1		9:57	18:58	9:01	
370		HASSAN	66		HANBALU_66	9:57	18:58	9:01	LINE CLEAR AVAILED LINE CLEAR AVAILED
371	22-Dec-2021	ļ	66	HANUBAL-SAKLESPUR	HANBALU_66	0:30	0:40	0:10	
372	22-Dec-2021	HASSAN	66	HASSN220-HN PURA	HASSAN_220		1		LINE FAULT
373	22-Dec-2021	HASSAN	+ +	HASSN220-SAKLESH2	HASSAN_220	10:28	15:00	4:32	NFBC ISSUED
374	22-Dec-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	8:44	850	15:16	LINE FAULT
375	22-Dec-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	7:03	7:10	0:07	LINE FAULT
376	22-Dec-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	9:51	18:54	9:03	NFBC ISSUED
377	22-Dec-2021	HASSAN	66	HV1	MAGGE_66	10:03	18:40	8:37	LINE CLEAR AVAILED
378	22-Dec-2021	HASSAN	66	HV2	MAGGE_66	10:03	18:40	8:37	LINE CLEAR AVAILED
379	22-Dec-2021	HASSAN	66	HV2	RAMNATHPURA_66	14:22	14:56	0:34	LINE CLEAR AVAILED
380	22-Dec-2021	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	9:51	18:54	9:03	LINE CLEAR AVAILED
381	22-Dec-2021	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	21:47	22:10	0:23	HAND TRIPPED
382	22-Dec-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	9:51	18:54	9:03	LINE CLEAR AVAILED
383	22-Dec-2021	HASSAN	66	HV1	SAKLESHPURA_66	9:51	18:54	9:03	LINE CLEAR AVAILED
384	22-Dec-2021	HASSAN	66	HV1	SAKLESHPURA_66	18:54	18:56	0:02	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
385	22-Dec-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	9:51	18:54	9:03	LINE CLEAR AVAILED
386	22-Dec-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	9:51	18:54	9:03	LINE CLEAR AVAILED
387	22-Dec-2021	HASSAN	66	SALAGAM-HIREMANGLUR	SALGAME_66	10:19	16:39	6:20	LINE CLEAR AVAILED
388	22-Dec-2021	HASSAN	66	HV1	SALGAME_66	10:17	16:42	6:25	LINE CLEAR AVAILED
389	22-Dec-2021	HASSAN	66	HV2	SALGAME_66	10:17	16:42	6:25	LINE CLEAR AVAILED
390	22-Dec-2021	HASSAN	66	SALAGAM-UDURKOPPLU	SALGAME_66	10:19	16:39	6:20	LINE CLEAR AVAILED
391	22-Dec-2021	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	10:24	16:35	6:11	LINE CLEAR AVAILED
392	22-Dec-2021	MYSURU	66	HV1	CHUNCHUNKATTE_66	7:54	8:27	0:33	TRANSFORMER FAULT
393	22-Dec-2021	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	NO STATIONS EFFECTED	9:39	11:15	1:35	LINE CLEAR AVAILED
394	22-Dec-2021	MYSURU	66	HV2	MADIKERI_66	9:25	19:33	10:07	LINE CLEAR AVAILED
395	22-Dec-2021	MYSURU	66	HV1	MANDGERE_66	12:20	13:45	1:25	LINE CLEAR AVAILED
396	22-Dec-2021	MYSURU	66	HV1	MANDGERE_66	14:00	14:10	0:10	LINE CLEAR AVAILED
397	22-Dec-2021	MYSURU	66	MYSORE SOUTH-GIS	MYSORESOUTH_66	10:35	16:54	6:18	LINE CLEAR AVAILED
398	22-Dec-2021	MYSURU	66	MYSORE SOUTH-KADAKOLA	MYSORESOUTH_66	10:35	16:57	6:22	LINE CLEAR AVAILED
399	22-Dec-2021	MYSURU	220	TUBINKERE-BASPTIPURA	NO STATIONS EFFECTED	11:12	11:33	0:21	LINE FAULT
400	22-Dec-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	18:11:07 (21.12.2021)	13:05:00 (22.12.2021)	18:53hrs	LINE CHARGED
401	22-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
402	22-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16(8.12.2021)			LINE OPEN, LINE CLEAR AVAILED
403	22-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN, LINE CLEAR AVAILED
404	22-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN, LINE CLEAR AVAILED
405	22-Dec-2021	TUMKUR	220	TR-2(HV SDE)	ANCHEPALYA_220	9:30	13:51	4:20	LINE CLEAR AVAILED
406	22-Dec-2021	TUMKUR	220	NITTUR 220-ARASIKERE	NITTUR_220	10:50	17:59	7:08	LINE CLEAR AVAILED
407	22-Dec-2021	TUMKUR	220	TR-1(HV SDE)	NITTUR_220	10:39	18:28	7:49	LINE CLEAR AVAILED
408	22-Dec-2021	TUMKUR	220	TR-2(HV SIDE)	NITTUR_220	10:39	18:48	8:09	LINE CLEAR AVAILED
409	22-Dec-2021	TUMKUR	220	NITTUR 220-NELAMANGALA	NITTUR_220	10:46	17:58	7:12	LINE CLEAR AVAILED
410	22-Dec-2021	TUMKUR	110	TR-3	GUBBI_110	10:25	18:40	8:15	LINE CLEAR AVAILED
411	22-Dec-2021	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	10:08	18:43	8:34	LINE CLEAR AVAILED
412	22-Dec-2021	TUMKUR	110	NITTUR 220-AMMASANDRA110	AMMASANDRA_110,SAM PIGE_110	10:07	18:40	8:33	LINE CLEAR AVAILED
413	22-Dec-2021	TUMKUR	110	TR-2	NITTUR_220	10:30	18:56	8:26	LINE CLEAR AVAILED
414	22-Dec-2021	TUMKUR	110	TR-1	NITTUR_220	10:30	18:30	7:59	LINE CLEAR AVAILED
415	22-Dec-2021	TUMKUR	110	NITTUR 220-KADABA	KADABA_110	10:38	18:37	7:58	LINE CLEAR AVAILED
416	22-Dec-2021	TUMKUR	110	NITTUR 220-KALLUR	KALLUR_110	0:10	3:29	3:19	LINE CLEAR AVAILED
417	22-Dec-2021	TUMKUR	110	NITTUR 220-KALLUR	KALLUR_110	10:07	18:38	8:31	LINE CLEAR AVAILED
418	22-Dec-2021	TUMKUR	110	NITTUR 220-K G TEMPLE	KGTEMPLE_110	10:14	18:47	8:32	LINE CLEAR AVAILED
419	22-Dec-2021	TUMKUR	110	TR-(LV SIDE)	NITTUR_220	10:39	18:29	7:50	LINE CLEAR AVAILED
420	22-Dec-2021	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	10:38	18:48	8:09	LINE CLEAR AVAILED
421	22-Dec-2021	TUMKUR	110	SOMLAPURA 110-NITTUR220	SOMLAPURA_110	10:23	18:54	8:30	LINE CLEAR AVAILED
422	22-Dec-2021	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENAHALLI_66,SRI GIRI PURA	6:46	7:15	0:29	LINE FAULT
423	22-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	6:46	7:14	0:27	LINE FAULT
424	22-Dec-2021	TUMKUR	66	TR-1(LV SIDE)	ANCHEPALYA_220	9:30	13:52	4:22	TRANSFORMER FAULT
425	22-Dec-2021	TUMKUR	66	TR-2((LV SIDE)	ANCHEPALYA_220	13:53	17:52	3:59	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
426	22-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, BRAHMASANDRA_66,THO VINAKERE_66,ANKASAND RA 66	11:39	12:20	0:40	LINE FAULT
427	22-Dec-2021	TUMKUR	66	CHITRADURGA 220kV- TURUVANUR	MADANAYAKANAHALLI_6 6, TURUVANUR_66, BIDARKERE_66, JAGALUR 66, SOKKE 66	10:04	15:43	5:38	LINE CLEAR AVAILED
428	22-Dec-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	12:21	12:45	0:23	LINE FAULT
429	22-Dec-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR 66	8:51	9:00	0:09	LINE FAULT
430	22-Dec-2021	TUMKUR	66	TR-2	HIRIYUR_66	13:51	14:52	1:01	LINE CLEAR AVAILED
431	22-Dec-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNA GIRI_66	10:27	10:34	0:06	HAND TRIPPED
432	22-Dec-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66, NEELAGUNDA_66	10:04	17:09	7:04	LINE CLEAR AVAILED
433	22-Dec-2021	TUMKUR	66	TR-1	JIDDIGERE_66	12:40	13:03	0:23	LINE CLEAR AVAILED
434	22-Dec-2021	TUMKUR	66	MADANAYAKANAHALLI66-TURUVANUR66	MADANAYAKANAHALLI_6 6	9:59	16:43	6:43	LINE CLEAR AVAILED
435	22-Dec-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	10:23	10:49	0:25	LINE CLEAR AVAILED
436	22-Dec-2021	TUMKUR	66	TR-2	TAVAREKERE(H)_66	11:25	12:28	1:03	LINE CLEAR AVAILED
437	22-Dec-2021	TUMKUR	66	TR-1	PANDARAHALLI_66	11:13	11:43	0:29	LINE CLEAR AVAILED
438	22-Dec-2021	TUMKUR	66	MADANAYAKANAHALLI66-TURUVANUR66	MADANAYAKANAHALLI_6 6	9:59	16:43	6:43	LINE CLEAR AVAILED
439	22-Dec-2021	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	12:23	12:26	0:02	MAIN SUPPLY FAILURE
440	22-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV- KUNIGAL66	YEDIYUR_66,THIPPUR_,JID DEGERE_66	6:44	7:15	0:31	LINE FAULT
441	22-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	6:44	7:15	0:31	LINE FAULT
442	22-Dec-2021	TUMKUR	66	ANCHEPALYA 66kV-HEBBUR66	HEBBUR_66,THIMMASAN DRA_66,HONNENAHALLI_ 66	6:44	7:15	0:31	LINE FAULT
443	23-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
444	23-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
445	23-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
446	23-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
447	23-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
448	23-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
449	23-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
450	23-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN, LINE CLEAR AVAILED
451	23-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN,LINE FAULT
452	23-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
453	23-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
454	23-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
455	23-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN, LINE CLEAR AVAILED
456	23-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE FAULT
457	23-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
458	23-Dec-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	13:54	14:24	0:30	HAND TRIPPED
459	23-Dec-2021	BAGALKOT	110	ANLOLA -KUMATA(L2)	ANKOLA_110	13:08	13:14	0:06	HAND TRIPPED
460	23-Dec-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:36	17:22	6:46	LINE CLEAR AVAILED
461	23-Dec-2021	BAGALKOT	220	BIDNAL-TADAS2	BIDNAL_220	10:41	16:10	5:29	LINE CLEAR AVAILED
462	23-Dec-2021	BAGALKOT	110	110/11KV,HV2	GUTTAL 110	14:04	14:40	0:36	LINE CLEAR AVAILED
463	23-Dec-2021	BAGALKOT	110	110/33KV,HV2	HANAGALL_110 & PALA &LAXMIPUR_33	10:54	11:09	0:15	TRANSFORMER FAULT
464	23-Dec-2021	BAGALKOT	110	110/11KV,HV2	HEBBALLI_110	11:19	14:19	3:00	LINE CLEAR AVAILED
465	23-Dec-2021	BAGALKOT	110	ISLAMPUR-ANKALAGI	ANKALAGI_110	11:59	12:02	0:03	HAND TRIPPED
466	23-Dec-2021	BAGALKOT	110	110/11KV,HV1	KALADAGI_110	18:46	19:09	0:23	TRANSFORMER FAULT
467	23-Dec-2021	BAGALKOT	110	KUMATA-SIRS 1	KUMATA 110	8:32	18:25	9:53	NFBC ISSUED
468	23-Dec-2021	BAGALKOT	110	110/11KV,HV2	SAVANUR 110	10:33	18:09	7:36	LINE CLEAR AVAILED
469	23-Dec-2021	BAGALKOT	110	SAVANUR-RAMANAKOPPA 110	SAVANUR 110	18:09	18:45	0:36	LINE CLEAR AVAILED
470	23-Dec-2021	BAGALKOT	110	SHIGGOAN -SAVANUR	SAVANUR 110	15:05	18:10	3:05	LINE CLEAR AVAILED
471	23-Dec-2021	BAGALKOT	110	SIRS-KUMATA2	SIRSI 110	8:33	18:25	9:52	NFBC ISSUED
472	23-Dec-2021	BAGALKOT	110	JOG2-SIRSI	SIRSI 110	9:30	18:24	8:54	NFBC ISSUED
473	23-Dec-2021	BAGALKOT	110	110/11KV,HV1	ZALKI 110	16:24	16:26	0:02	TRANSFORMER FAULT
474	23-Dec-2021	BAGALKOT	110	INDI-ZALKI	ZALKI_110	16:09	16:12	0:03	HAND TRIPPED
475	23-Dec-2021	BAGALKOT	110	TARIHAL-TADSNKP(KIADB GAMANGHATTI)	TARIHAL_110	11:44 (23.12.2021)	-		LINE OPEN, LINE CLEAR AVAILED
476	23-Dec-2021	BAGALKOT	110	SIRSI220- SIRSI1&2	SIRSI_220	9:25	19:29	10:04	NFBC ISSUED
477	23-Dec-2021	BAGALKOT	110	HAVERI220- SAVANUR	HAVERI_220	13:35	15:10	1:35	LINE CLEAR AVAILED
478	23-Dec-2021	BAGALKOT	110	110/11KV, HV1	SHIROL_110	17:55	18:10	0:15	LINE CLEAR AVAILED
479	23-Dec-2021	BAGALKOT	220	BALLIGAVI- RANEBENNUR	RANEBENNUR_220	14:36 (23.12.2021)			LINE OPEN,LINE FAULT
480	23-Dec-2021	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	6:26	6:50	0:24	LINE FAULT
481	23-Dec-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	6:26	7:02	0:36	LINE FAULT
482	23-Dec-2021	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	12:01	12:16	0:15	LINE CLEAR AVAILED
483	23-Dec-2021	BENGALURU	66	HV1	CHATRA	15:21	15:29	0:08	TRANSFORMER FAULT
484	23-Dec-2021	BENGALURU	66	HV1	EXORA	13:10	13:15	0:05	LINE CLEAR AVAILED
485	23-Dec-2021	BENGALURU	66	HV2	EXORA	10:50	10:55	0:05	HAND TRIPPED
486	23-Dec-2021	BENGALURU	66	HV1	HANUMANTHNAGARA	13:31	15:37	2:06	LINE CLEAR AVAILED
487	23-Dec-2021	BENGALURU	66	HV2	HANUMANTHNAGARA	14:23	15:38	1:15	LINE CLEAR AVAILED
488	23-Dec-2021	BENGALURU	66	SHOBHA CITY - MANYATHA TECH PARK 220	SHOBHA CITY	17:30	18:15	0:45	MAIN SUPPLY FAILURE
489	23-Dec-2021	BENGALURU	66	SHOBHA CITY - HENNUR CROSS	SHOBHA CITY	20:56	20:59	0:03	LOAD CHANGE OVER
490	23-Dec-2021	BENGALURU	220	HOODY 220 - RAILWAYS 2 (EHT)	RAILWAYS 2 (EHT)	15:53	16:29	0:36	LINE FAULT
491	23-Dec-2021	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	7:02	7:07	0:05	LOAD CHANGE OVER
492	23-Dec-2021	BENGALURU	66	MANYATHA TECH PARK 220 - HOSKOTE 2	SHOBHA CITY	17:30	18:15	0:45	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
493	23-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	6:26	6:49	0:23	LINE FAULT
494	23-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
495	23-Dec-2021	GULBARGA	400	BTPSG-RTPS	RTPS_400	3:45	14:16	10:31	LINE FAULT
496	23-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
497	23-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
498	23-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:44 (23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
499	23-Dec-2021	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	12:20	14:55	2:35	LINE CLEAR AVAILED
500	23-Dec-2021	GULBARGA	220	SHAHAPUR-RTPS2	RTPS2	14:25	14:36	0:11	LINE FAULT
501	23-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
502	23-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:09 (22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
503	23-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN, LINE CLEAR AVAILED
504	23-Dec-2021	GULBARGA	110	MASKI-RNEWSOLAR_IPP	MASKI_110	18:25(23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
505	23-Dec-2021	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGAWEST_110	7:50(21.12.2021)	21:15(23.12. 2021)	13:25HRS	LINE CHARGED
506	23-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_1 10,YERDONA_110,SRNAG AR_110,MALLAPURA_110	9:05	9:10	0:05	HAND TRIPPED
507	23-Dec-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	7:57	17:29	9:32	LINE CLEAR AVAILED
508	23-Dec-2021	GULBARGA	110	KAPNOOR-GULBARGAWEST	GULBARGAWEST_110,GUL BARGA SOUTH_110	10:01	14:35	4:34	LINE CLEAR AVAILED
509	23-Dec-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAP UR_110,NSL SUGARS FACTORY	1:43	1:50	0:07	LINE FAULT
510	23-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPU R_110,WADGERA_110,SA NNATHI_110,CORE GREEN SUGUR IPP	20:54	21:00	0:06	LINE FAULT
511	23-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPU R_110,WADGERA_110,SA NNATHI_110,CORE GREEN SUGUR IPP	21:26	21:33	0:07	LINE FAULT
512	23-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPU R_110,WADGERA_110,SA NNATHI_110,CORE GREEN SUGUR IPP	23:34	23:39	0:05	LINE FAULT
513	23-Dec-2021	GULBARGA	110	HUMNABAD-HUMNABAD1	MANEKHELLI_110	19:21	19:52	0:31	LINE CLEAR AVAILED
514	23-Dec-2021	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGANORTH2	GULBARGANORTH_110	13:30	17:55	4:25	LINE CLEAR AVAILED
515	23-Dec-2021	GULBARGA	110	MASKI-RNEWSOLAR_IPP	MASKI_110	18:25(23.12.2021)	2:03(24.12.2 021)	7:38HRS	LINE CHARGED
516	23-Dec-2021	GULBARGA	110	MALLAPURA-MUNIRABAD	MALLAPURA_110	8:25	18:45	10:20	MAIN SUPPLY FAILURE
517	23-Dec-2021	GULBARGA	110	HV2	SREERAMANAGAR_110	9:57	11:15	1:18	LINE CLEAR AVAILED
518	23-Dec-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	8:15	8:40	0:25	MAIN SUPPLY FAILURE
519	23-Dec-2021	GULBARGA	110	NAVALI-KANAKAGIRI	NAVALI_110	13:45	14:05	0:20	MAIN SUPPLY FAILURE
520	23-Dec-2021	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	6:16	6:21	0:05	LINE FAULT
521	23-Dec-2021	GULBARGA	110	GANDHINAGAR-TURVIHAL	TURVIHAL_110	9:50	9:55	0:05	LINE FAULT
522	23-Dec-2021	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	6:20	7:00	0:40	MAIN SUPPLY FAILURE
523	23-Dec-2021	GULBARGA	110	HV1	BAYYAPURA_110	11:00	17:30	6:30	LINE CLEAR AVAILED
524	23-Dec-2021	GULBARGA	110	HV2	BAYYAPURA_110	11:00	17:30	6:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
525	23-Dec-2021	GULBARGA	110	MUDGAL-BAYYAPURA	BAYYAPURA_110	15:05	17:25	2:20	LINE CLEAR AVAILED
526	23-Dec-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	20:25	20:30	0:05	MAIN SUPPLY FAILURE
527	23-Dec-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	9:05	9:20	0:15	MAIN SUPPLY FAILURE
528	23-Dec-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	18:30	18:40	0:10	MAIN SUPPLY FAILURE
529	23-Dec-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGA VATHI_110,DR NAGAR_110,KARATAGI_11 0	8:10	17:55	9:45	LINE CLEAR AVAILED
530	23-Dec-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_1 10,KEREHALLI_110,MALLA PUR 110	8:26	18:46	10:20	LINE CLEAR AVAILED
531	23-Dec-2021	GULBARGA	110	MUNIRABAD-VYSANKERE2	STAR METALLIC _IPP	8:22	17:23	9:01	LINE CLEAR AVAILED
532	23-Dec-2021	GULBARGA	110	MUNIRABAD-VYSANAKERE1	DONIMALAI_110	9:05	17:15	8:10	LINE CLEAR AVAILED
533	23-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_1 10,YERDONA_110,SRNAG AR_110,MALLAPURA_110	18:26	18:36	0:10	LINE CLEAR AVAILED
534	23-Dec-2021	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI _110	12:42	12:56	0:14	LINE CLEAR AVAILED
535	23-Dec-2021	GULBARGA	110	SHAHABAD-WADI	WADI_110	10:25	17:05	6:40	LINE CLEAR AVAILED
536	23-Dec-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	0:05	0:15	0:10	LINE FAULT
537	23-Dec-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKA MDINNI_110	22:42	22:52	0:10	LINE FAULT
538	23-Dec-2021	GULBARGA	66	HPHALLI-NEELAGUNDA	HARAPANAHALLI_66	3:00	3:05	0:05	LINE FAULT
539	23-Dec-2021	GULBARGA	66	ITTAGI-HUVINAHADGALI	HUVINAHADGALI_66,HOL AGUNDI_66	0:48	0:55	0:07	LINE FAULT
540	23-Dec-2021	GULBARGA	66	ITTAGI-HUVINAHADGALI	HUVINAHADGALI_66,HOL AGUNDI 66	8:40	8:52	0:12	LINE FAULT
541	23-Dec-2021	GULBARGA	66	ITTAGI-HIREHADGALI2	HIREHADGALI_66,GIRIYAP UR_66,MAGALA_66,SOVE NHALLI_66,TUNGA BHADRA IPP	5:10	5:25	0:15	LINE FAULT
542	23-Dec-2021	GULBARGA	66	HV2	ITTAGI_220	10:55	15:15	4:20	LINE CLEAR AVAILED
543	23-Dec-2021	GULBARGA	66	HV1	ITTAGI_220	11:00	18:35	7:35	LINE CLEAR AVAILED
544	23-Dec-2021	GULBARGA	66	HV1	ITTAGI_220	18:45	19:11	0:26	LINE CLEAR AVAILED
545	23-Dec-2021	GULBARGA	66	HV2	HALAVAGALU_66	12:40	12:45	0:05	TRANSFORMER FAULT
546	23-Dec-2021	GULBARGA	66	HV2	HALAVAGALU_66	12:50	12:55	0:05	TRANSFORMER FAULT
547	23-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
548	23-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
549	23-Dec-2021	HASSAN	110	HV1	MADHUVANA_110	10:05(21.12.2021			TRANSFORMER OPEN,LINE CLEAR AVAILED
550	23-Dec-2021	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	8:47(22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
551	23-Dec-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	8:31(22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
552	23-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	15:53 (22.12.2021)	10:08(23.12. 2021)	18:15hrs	LINE CHARGED
553	23-Dec-2021	HASSAN	66	HV1	HANBALU_66	20:59 (22.12.2021)	13:31(23.12. 2021)	16:32hrs	TRANSFORMER CHARGED
554	23-Dec-2021	HASSAN	66	HANUBAL-SAKLESPUR	HANBALU_66	20:59 (22.12.2021)	13:27(23.12. 2021)	16:28hrs	LINE CHARGED
555	23-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:29(23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
556	23-Dec-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	19:45(23.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
557	23-Dec-2021	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	9:13	9:39	0:26	LINE FAULT
558	23-Dec-2021	HASSAN	220	GERSOPA-TALGUPPA	gerusoppa_gen	9:13	9:38	0:25	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
559	23-Dec-2021	HASSAN	220	HV1	HOLENARASIPURA_220	11:14	13:16	2:02	LINE CLEAR AVAILED
560	23-Dec-2021	HASSAN	66	Lv1	HOLENARASIPURA_220	11:13	13:17	2:04	LINE CLEAR AVAILED
561	23-Dec-2021	HASSAN	110	HOSNGD-VTRG2	HOSANGADI_110	14:32	15:35	1:03	LINE CLEAR AVAILED
562	23-Dec-2021	HASSAN	110	HV1	JAVAGAL_110	15:03	16:00	0:57	LINE CLEAR AVAILED
563	23-Dec-2021	HASSAN	110	JOG-NK2	mghejog_gen	9:39	18:24	8:45	LINE CLEAR AVAILED
564	23-Dec-2021	HASSAN	110	HV1	KAVOOR_220	9:34	16:52	7:18	LINE CLEAR AVAILED
565	23-Dec-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:10	18:27	8:17	LINE CLEAR AVAILED
566	23-Dec-2021	HASSAN	110	HV2	NERALAKERE_110	16:07	16:51	0:44	LINE CLEAR AVAILED
567	23-Dec-2021	HASSAN	66	HV1	AREHALLI_66	10:48	13:40	2:52	LINE CLEAR AVAILED
568	23-Dec-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	10:50	19:45	8:55	LINE CLEAR AVAILED
569	23-Dec-2021	HASSAN	66	HV2	CHIKKAKONDAGOLA_66	10:35	16:05	5:30	LINE CLEAR AVAILED
570	23-Dec-2021	HASSAN	66	SAKALE-HANBAL	SAKLESHPURA_66	10:46	13:24	2:38	NFBC ISSUED
571	23-Dec-2021	MYSURU	66	GUNDLUPETE-KABBALLI	NO STATIONS EFFECTED	17:45	19:36	1:50	LINE CLEAR AVAILED
572	23-Dec-2021	MYSURU	66	HAMPAPURA-CHIKKA MANDYA	NO STATIONS EFFECTED	15:17	17:30	2:13	LINE CLEAR AVAILED
573	23-Dec-2021	MYSURU	66	HV2	KIRUGAVALU_66	10:12	16:13	6:00	LINE CLEAR AVAILED
574	23-Dec-2021	MYSURU	66	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66DMG_HALLI_6 6	6:36	6:44	0:07	LINE FAULT
575	23-Dec-2021	MYSURU	66	HV1	MADDUR_66	7:18	7:26	0:08	HAND TRIPPED
576	23-Dec-2021	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_ 66	6:17	6:35	0:18	LINE FAULT
577	23-Dec-2021	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_ 66	15:26	15:36	0:09	LINE FAULT
578	23-Dec-2021	MYSURU	66	HV2	SANTHEBACHALLI_66	13:38	16:31	2:52	LINE CLEAR AVAILED
579	23-Dec-2021	MYSURU	66	HV1	SANTHEBACHALLI_66	16:00	17:15	1:15	LINE CLEAR AVAILED
580	23-Dec-2021	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	6:17	6:25	0:08	LINE FAULT
581	23-Dec-2021	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	6:17	7:01	0:44	LINE FAULT
582	23-Dec-2021	MYSURU	66	SFC SIVA-5MW	NO STATIONS EFFECTED	14:35	14:39	0:04	LINE FAULT
583	23-Dec-2021	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	14:35	14:39	0:04	LINE FAULT
584	23-Dec-2021	MYSURU	66	HV1	SUTTUR_66	18:21	18:39	0:17	HAND TRIPPED
585	23-Dec-2021	MYSURU	66	TUBINKERE-MANDYA 2	HAMPAPURA_66 BASARALU_66 BESAGARAHALLI_66 KOPPA_66 CHIKKA_MANDYA_66MAN DYA_66KADKOTHANAHAL LI_66MALAVALLI_66 HAMPAPURA_66	10:08	10:20	0:11	LINE FAULT
586	23-Dec-2021	MYSURU	66	TUBINKERE-MANDYA 4	BASARALU_66 BESAGARAHALLI_66 KOPPA_66 CHIKKA_MANDYA_66MAN DYA_66KADKOTHANAHAL LI 66MALAVALLI 66	10:08	10:16	0:07	LINE FAULT
587	23-Dec-2021	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	8:52	9:02	0:10	LINE FAULT
588	23-Dec-2021	MYSURU	66	HOOTAGALLI-BARC-1	NO STATIONS EFFECTED	12:58	13:13	0:15	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
589	23-Dec-2021	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	14:20:00 (23.12.2021)			LINE OPEN,LINE FAULT
590	23-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
591	23-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN, LINE CLEAR AVAILED
592	23-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN, LINE CLEAR AVAILED
593	23-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01(30.10.2021)			LINE OPEN, LINE CLEAR AVAILED
594	23-Dec-2021	TUMKUR	400	ICT 1(TR-1) (HV SIDE)	JAGLUR_400	10:38	16:18	5:39	LINE CLEAR AVAILED
595	23-Dec-2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	12:19	15:17	2:58	LINE CLEAR AVAILED
596	23-Dec-2021	TUMKUR	220	ICT 1(TR-1) (LV SIDE)	JAGLUR_400	10:38	16:19	5:40	LINE CLEAR AVAILED
597	23-Dec-2021	TUMKUR	110	TR-1	TURUVEKERE_110	11:12	11:24	0:11	TRANSFORMER FAULT
598	23-Dec-2021	TUMKUR	110	NITTUR 220-KALLUR	KALLUR_110	5:56	6:21	0:25	LINE FAULT
599	23-Dec-2021	TUMKUR	110	TR1	SAMPIGE_110	10:01	15:53	5:52	LINE CLEAR AVAILED
600	23-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR _66	YEDIYUR_66,THIPPUR_66, JIDDEGERE_66	18:06	18:18	0:11	LINE FAULT
601	23-Dec-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	10:35	10:57	0:22	LINE FAULT
602	23-Dec-2021	TUMKUR	66	HIRIYURKV 220kV- SUZLON 2	SUZLON2_IPP_66	6:50	7:10	0:20	LINE FAULT
603	23-Dec-2021	TUMKUR	66	HIRIYURKV 220kV- SUZLON 2	SUZLON2_IPP_66	7:25	7:40	0:15	LINE FAULT
604	23-Dec-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNA GIRI_66	10:17	10:26	0:09	LINE FAULT
605	23-Dec-2021	TUMKUR	66	TR-2	KADDAJJI_66	9:56	10:06	0:10	TRANSFORMER FAULT
606	23-Dec-2021	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	14:15	14:43	0:28	LINE CLEAR AVAILED
607	23-Dec-2021	TUMKUR	66	TR-2	NAYAKANHATTI_66	11:54	12:04	0:09	LINE CLEAR AVAILED
608	23-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	13:33	15:34	2:01	LINE CLEAR AVAILED
609	23-Dec-2021	TUMKUR	66	PAVAGADA220-NAGALAMADIKE66	PAVAGADA_220	6:26	6:34	0:07	LINE FAULT
610	23-Dec-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	18:33	23:14	4:41	LINE CLEAR AVAILED
611	23-Dec-2021	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	18:33	23:14	4:41	LINE CLEAR AVAILED
612	23-Dec-2021	TUMKUR	66	BRAHMASANDRA- SIRA(ANKASANDRA)	BRAHMASANDRA_66	6:38	6:46	0:08	LINE FAULT
613	23-Dec-2021	TUMKUR	66	TR-2	LINGADAHALLI_66	11:13	11:16	0:03	HAND TRIPPED
614	23-Dec-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	7:56	8:14	0:17	LINE FAULT
615	24-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
616	24-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
617	24-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
618	24-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
619	24-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
620	24-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
621	24-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
622	24-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN, LINE CLEAR AVAILED
623	24-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN,LINE FAULT
624	24-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
625	24-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
626	24-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
627	24-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN, LINE CLEAR AVAILED
628	24-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE FAULT
629	24-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
630	24-Dec-2021	BAGALKOT	110	TARIHAL-TADSNKP(KIADB GAMANGHATTI)	TARIHAL_110	11:44 (23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
631	24-Dec-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_220	13:00	16:28	3:28	LINE CLEAR AVAILED
632	24-Dec-2021	BAGALKOT	220	KARWAR- KADARA1	KARWAR_220	10:36	13:40	3:04	LINE CLEAR AVAILED
633	24-Dec-2021	BAGALKOT	110	HUBLI- RAMANKOPPA	HUBLI_220	10:02	16:54	6:52	LINE CLEAR AVAILED
634	24-Dec-2021	BAGALKOT	220	GUTTUR1- HAVERI	HAVERI_220	12:20	16:30	4:10	LINE CLEAR AVAILED
635	24-Dec-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	10:28	16:03	5:35	LINE CLEAR AVAILED
636	24-Dec-2021	BAGALKOT	220	SIRSI- SHARAVATHY1&2	SIRSI_220	10:28	15:52	5:24	LINE CLEAR AVAILED
637	24-Dec-2021	BAGALKOT	110	VAJRAMATTI-BILAGI(SHIRGUPPI)	VAJRAMATTI_220, BILAGI_110, TOLAMATTI_110,GIRISAG AR 110, BISNAL 110	4:18	4:29	0:11	LINE FAULT
638	24-Dec-2021	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	12:18	12:25	0:07	HAND TRIPPED
639	24-Dec-2021	BAGALKOT	110	SIRSI- HUBLI1(ESALE1)	SIRSI_110	15:52 (24.12.2021)			LINE OPEN, LINE CLEAR AVAILED
640	24-Dec-2021	BAGALKOT	110	SIRSI- KAVALWADA(ESALE1)	SIRSI_110	15:52 (24.12.2021)			LINE OPEN, LINE CLEAR AVAILED
641	24-Dec-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:03	9:26	0:23	HAND TRIPPED
642	24-Dec-2021	BAGALKOT	110	110/11KV,HV2	ALMEL_110	16:24	16:25	0:01	TRANSFORMER FAULT
643	24-Dec-2021	BAGALKOT	110	110/11KV,HV2	AIGALI_110	8:00	8:11	0:11	TRANSFORMER FAULT
644	24-Dec-2021	BAGALKOT	110	BGWDI-MAMADAPUR 1(LINE 2)	MAMADAPUR_110	2:46	2:58	0:12	LINE FAULT
645	24-Dec-2021	BAGALKOT	110	BGWDI-MAMADAPUR 1(LINE 2)	MAMADAPUR_110	4:16	4:25	0:09	LINE FAULT
646	24-Dec-2021	BAGALKOT	220	BGWDI-FORFIVE1,FORFIVE2,	BAGEWADI_220, FORFIVE_IPP	7:23	14:31	7:08	LINE CLEAR AVAILED
647	24-Dec-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	9:35	17:40	8:05	LINE CLEAR AVAILED
648	24-Dec-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL DAM_110 &BELGAUM W/S_33	12:32	16:23	3:51	LINE CLEAR AVAILED
649	24-Dec-2021	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	7:27 (24.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
650	24-Dec-2021	BAGALKOT	110	SRS-RAMANAKOPPA	RAMANAKOPPA_110	10:01	15:38	5:37	NFBC ISSUED
651	24-Dec-2021	BAGALKOT	110	110/11KV,HV2	RON_110	11:11	15:24	4:13	LINE CLEAR AVAILED
652	24-Dec-2021	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	16:28	16:40	0:12	LINE CLEAR AVAILED
653	24-Dec-2021	BAGALKOT	110	SOUDATTI220(NARAGUND)- SOUDATTI	SOUDATTI_110	13:01	16:28	3:27	LINE CLEAR AVAILED
654	24-Dec-2021	BAGALKOT	220	BALLIGAVI- RANEBENNUR	RANEBENNUR_220	14:36 (23.12.2021)			LINE OPEN,LINE FAULT
655	24-Dec-2021	BAGALKOT	110	110/11KV,HV1	UMMACHAGI_110	15:55	16:35	0:40	TRANSFORMER FAULT
656	24-Dec-2021	BAGALKOT	110	110/11KV,HV1	UMMACHAGI_110	17:35	18:15	0:40	LINE CLEAR AVAILED
657	24-Dec-2021	BAGALKOT	110	CHIKKODI220- SADALAGA	SADALAGA_110	16:30	16:40	0:10	LINE FAULT
658	24-Dec-2021	BAGALKOT	110	SIRSI220- UMMACHAGI	SIRSI_220	16:00	16:30	0:30	HAND TRIPPED
659	24-Dec-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	10:28	16:03	5:35	LINE CLEAR AVAILED
660	24-Dec-2021	BAGALKOT	110	SHIRAGUPPI-VAJRAMATTI	SHIRAGUPPI_110	4:20	4:30	0:10	LINE FAULT
661	24-Dec-2021	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110, TOLAMATTI_110,GIRISAG AR_110,BISNAL_110	4:20	4:30	0:10	LINE FAULT
662	24-Dec-2021	BAGALKOT	110	SHIRAGUPPI-BILAGI	BILAGI_110, TOLAMATTI_110,GIRISAG AR_110, BISNAL_110	4:20	4:30	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
663	24-Dec-2021	BAGALKOT	220	220/110KV, HV1	SIRSI_220	10:29	15:53	5:24	LINE CLEAR AVAILED
664	24-Dec-2021	BENGALURU	66	HV1	AMAR JYOTHI	14:19	14:52	0:33	MAIN SUPPLY FAILURE
665	24-Dec-2021	BENGALURU	66	HV1	AMAR JYOTHI	15:12	15:45	0:33	LOAD CHANGE OVER
666	24-Dec-2021	BENGALURU	66	HV1	AMAR JYOTHI	18:50	18:55	0:05	LOAD CHANGE OVER
667	24-Dec-2021	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	14:40	14:46	0:06	LOAD CHANGE OVER
668	24-Dec-2021	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	14:50	15:08	0:18	MAIN SUPPLY FAILURE
669	24-Dec-2021	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	15:29	15:35	0:06	MAIN SUPPLY FAILURE
670	24-Dec-2021	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	18:44	18:50	0:06	MAIN SUPPLY FAILURE
671	24-Dec-2021	BENGALURU	66	BMTC - EAST DIVISION COMPOUND 220	BMTC	16:25	16:30	0:05	LOAD CHANGE OVER
672	24-Dec-2021	BENGALURU	66	BMTC - NATIONAL COLLEGE	BMTC	18:50	18:54	0:04	LOAD CHANGE OVER
673	24-Dec-2021	BENGALURU	66	HV2	BRIGADE MEADOWS	12:41	12:51	0:10	LINE CLEAR AVAILED
674	24-Dec-2021	BENGALURU	66	HV1	BRIGADE MEADOWS	12:34	12:36	0:02	TRANSFORMER FAULT
675	24-Dec-2021	BENGALURU	66	BYDRAHALLI - SRS PEENYA 220	BYDRAHALLI, SRIGANDA KAVALU	19:45	22:25	2:40	LINE FAULT
676	24-Dec-2021	BENGALURU	66	HV1	CHATRA	11:24	11:31	0:07	TRANSFORMER FAULT
677	24-Dec-2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - HAL 220	EAST DIVISION COMPOUND 220	16:40	18:24	1:44	LINE CLEAR AVAILED
678	24-Dec-2021	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	12:37	13:04	0:27	LINE CLEAR AVAILED
679	24-Dec-2021	BENGALURU	66	HV2	HAL 220	14:29	14:30	0:01	HAND TRIPPED
680	24-Dec-2021	BENGALURU	66	HOODY 220 - MALUR 220	NO STATION AFFECTED	11:14	13:33	2:19	LINE FAULT
681	24-Dec-2021	BENGALURU	66	HSR LAYOUT 220 - AUSTIN TOWN	KORAMANGALA 220	14:50	15:03	0:13	LINE FAULT
682	24-Dec-2021	BENGALURU	66	HSR LAYOUT 220 - AUSTIN TOWN	KORAMANGALA 220	15:29	15:31	0:02	LINE FAULT
683	24-Dec-2021	BENGALURU	66	JAYADEVA - SARAKKI	JAYADEVA	18:50	18:58	0:08	LOAD CHANGE OVER
684	24-Dec-2021	BENGALURU	66	SARAKKI -JAYADEVA	SARAKKI	14:50	14:55	0:05	LOAD CHANGE OVER
685	24-Dec-2021	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	15:06	15:27	0:21	MAIN SUPPLY FAILURE
686	24-Dec-2021	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	18:39	18:46	0:07	MAIN SUPPLY FAILURE
687	24-Dec-2021	BENGALURU	66	JAYANAGARA - NIMHANS 220	JAYANAGARA	14:54	15:00	0:06	MAIN SUPPLY FAILURE
688	24-Dec-2021	BENGALURU	66	KODIGEHALLI - BYDRAHALLI	KODIGEHALLI	19:45	20:02	0:17	MAIN SUPPLY FAILURE
689	24-Dec-2021	BENGALURU	66	KODIGEHALLI - T G HALLI	KODIGEHALLI	22:22	22:34	0:12	LOAD CHANGE OVER
690	24-Dec-2021	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	13:55	14:22	0:27	LINE CLEAR AVAILED
691	24-Dec-2021	BENGALURU	220	KORAMANGALA 220 - HSR LAYOUT 220	KORAMANGALA 220	18:42	18:55	0:13	LOAD CHANGE OVER
692	24-Dec-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	8:52	9:15	0:23	MAIN SUPPLY FAILURE
693	24-Dec-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	10:01	10:05	0:04	LOAD CHANGE OVER
694	24-Dec-2021	BENGALURU	66	HV1	NANDINI LAYOUT	11:23	11:27	0:04	HAND TRIPPED
695	24-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	3:02	3:25	0:23	LINE FAULT
696	24-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	14:26	14:48	0:22	LOAD CHANGE OVER
697	24-Dec-2021	BENGALURU	66	TK HALLI 220 - BWSSB 4 (EHT)	BWSSB 4 (EHT)	7:36	8:02	0:26	LINE FAULT
698	24-Dec-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA	NO STATION AFFECTED	9:21	10:18	0:57	LINE FAULT
699	24-Dec-2021	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	8:52	9:15	0:23	LINE FAULT
700	24-Dec-2021	BENGALURU	66	SOLDEVANAHALLI - SRS PEENYA 220	SOLDEVANAHALLI	8:22	8:30	0:08	LOAD CHANGE OVER
701	24-Dec-2021	BENGALURU	220	MALUR 220 - HOODY 400	NO STATION AFFECTED	12:16	13:43	1:27	LINE FAULT
702	24-Dec-2021	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	12:15	13:28	1:13	LINE CLEAR AVAILED
703	24-Dec-2021	BENGALURU	66	HV2	WEL CAST STEEL	13:19	14:01	0:41	TRANSFORMER FAULT
704	24-Dec-2021	BENGALURU	66	HV2	HUKUNDA	17:32	17:41	0:09	TRANSFORMER FAULT
705	24-Dec-2021	BENGALURU	66	HV1	H GOLLAHALLI	14:05	14:20	0:15	LINE CLEAR AVAILED
706	24-Dec-2021	BENGALURU	66	HV2	H GOLLAHALLI	11:25	11:35	0:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
707	24-Dec-2021	BENGALURU	220	HV1	KIADB DB PURA 220	11:40	12:45	1:05	LINE CLEAR AVAILED
708	24-Dec-2021	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	6:29	6:47	0:18	LINE FAULT
709	24-Dec-2021	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	15:44	17:06	1:22	LINE CLEAR AVAILED
710	24-Dec-2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	7:36	7:42	0:06	LINE FAULT
711	24-Dec-2021	BENGALURU	66	HV2	NIMHANS 220	12:59	13:01	0:02	LOAD CHANGE OVER
712	24-Dec-2021	BENGALURU	66	HV1	NIMHANS 220	15:16	15:23	0:07	LOAD CHANGE OVER
713	24-Dec-2021	BENGALURU	66	HV2	NIMHANS 220	15:16	15:23	0:07	LOAD CHANGE OVER
714	24-Dec-2021	BENGALURU	220	NIMHANS 220 - EDC 220	NIMHANS 220	15:16	15:23	0:07	LOAD CHANGE OVER
715	24-Dec-2021	BENGALURU	66	HV1	NIMHANS 220	18:35	18:42	0:07	LOAD CHANGE OVER
716	24-Dec-2021	BENGALURU	66	HV2	NIMHANS 220	18:35	18:42	0:07	LOAD CHANGE OVER
					JAYANAGAR, NATIONAL				
717	24-Dec-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	COLLEGE	15:06	15:27	0:21	LOAD CHANGE OVER
	24-Dec-2021		66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL				LOAD CURTAILMENT
718	24 DCC 2021	BENGALURU	00	MINITARY 220 SATANAGAN	COLLEGE	14:54	15:00	0:06	LOAD CONTAILMENT
719	24-Dec-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE	18:35	18:46	0:11	LOAD CHANGE OVER
720	24-Dec-2021	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	14:47	14:55	0:08	LOAD CHANGE OVER
721	24-Dec-2021	BENGALURU	66	HV1	HOSKOTE 66	15:45	17:00	1:15	LINE CLEAR AVAILED
722									
722	24-Dec-2021	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	13:56	14:00	0:04	LOAD CHANGE OVER
723	24-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
724	24-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
725	24-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
726	24-Dec-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	19:41			LINE OPEN,LINE FAULT
727	24-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:44 (23.12.2021)	7:21 (24.12.2021)	8:37 HRS	LINE CHARGED
728	24-Dec-2021	GULBARGA	220	MALLAT-RTPS	MALLAT 220	18:35	19:06	0:31	LINE FAULT
729	24-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
730	24-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:09 (22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
731	24-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN, LINE CLEAR AVAILED
732	24-Dec-2021	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPURA_110	3:20	3:32	0:12	LINE FAULT
733	24-Dec-2021	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPURA_110	5:08	5:15	0:07	LINE FAULT
734	24-Dec-2021	GULBARGA	110	MUDDAPURA-SINDHANOOR	MUDDAPURA_110	5:37	5:50	0:13	LINE FAULT
735	24-Dec-2021	GULBARGA	110	HV1	BHALKI_110	8:00	9:00	1:00	TRANSFORMER FAULT
736	24-Dec-2021	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	19:55	20:05	0:10	MAIN SUPPLY FAILURE
737	24-Dec-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	14:30	14:40	0:10	MAIN SUPPLY FAILURE
738	24-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	1:20	1:25	0:05	MAIN SUPPLY FAILURE
739	24-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	3:25	3:30	0:05	MAIN SUPPLY FAILURE
740	24-Dec-2021	GULBARGA	110	HV1	KEREHALLI_110	15:10	15:35	0:25	TRANSFORMER FAULT
741	24-Dec-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	3:20	3:33	0:13	MAIN SUPPLY FAILURE
742	24-Dec-2021	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	3:37	3:52	0:15	MAIN SUPPLY FAILURE
743	24-Dec-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	12:20	12:25	0:05	MAIN SUPPLY FAILURE
744	24-Dec-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE 110	19:05	19:10	0:05	MAIN SUPPLY FAILURE
745	24-Dec-2021	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD 220	12:24	12:36	0:12	LINE FAULT
746	24-Dec-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAP UR_110,NSL SUGAR FACTORY_IPP	1:43	1:50	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
					TEKKALAKOTE_110,				
					SIRIGUPPA_110,DHADESU				
	24-Dec-2021		110	SINDHANOOR-SIRAGUPPA	GUR_110,SIRIGERA				MAIN SUPPLY FAILURE
747		GULBARGA			CROSS_110,NSL SUGAR IPP,VOORA IPP	11:59	12:09	0:10	
, , ,		0025/ 1110/ 1			MUKUNDA 110,YERADON	11.00	12.03	0.20	
	24 D 2024		110	CINIDITANICOD NATINIDADADA	A_110,BENNUR_110,BTPS				LINE CALLET
	24-Dec-2021		110	SINDHANOOR-MUNIRABAD2	WATER				LINE FAULT
748		GULBARGA			WORKS,KAMPLI 110	14:28	14:38	0:10	
					TEKKALAKOTE_110, SIRIGUPPA 110,DHADESU				
	24-Dec-2021		110	SINDHANOOR-SIRAGUPPA	GUR_110,SIRIGERA				MAIN SUPPLY FAILURE
	24-Dec-2021		110	SINDIIANOOK-SINAGOFFA	CROSS 110,NSL				WAIN SOFFLY FAILURE
749		GULBARGA			SUGAR IPP, VOORA IPP	17:52	18:02	0:10	
750	24-Dec-2021	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	1:32	1:42	0:10	LINE FAULT
	24-Dec-2021		110	MALLAT-MADLAPUR	ADAVI				LINE FAULT
751	24-Dec-2021	GULBARGA	110	WALLAT-WADLAFOR	AMARESHWAR_110	21:17	21:25	0:08	LINE FAOLI
752	24-Dec-2021	GULBARGA	110	RAICHUR-MATAMARI	MATAMARI_110	17:59	18:20	0:21	LOAD CURTAILMENT
750	24-Dec-2021	CHIDADCA	110	RAICHUR-SINDHANOOR2	KURDICROSS_110,MADLA	40-24	10.02	0.20	LOAD CURTAILMENT
753		GULBARGA	110		PUR_110,MANVI_110	18:24 12:22	19:03	0:39	LINE FALLE
754	24-Dec-2021	GULBARGA	110	MUNIRABAD-VYSANKERE1	DONIMALAI_110 VENKATAGIRI_110,GANGA	12:22	12:32	0:10	LINE FAULT
					VATHI 110,DR				
	24-Dec-2021		110	MUNIRABAD-SINDHANOOR1	NAGAR 110,KARATAGI 11				LINE FAULT
755		GULBARGA			0	12:22	12:32	0:10	
756	24-Dec-2021	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	12:00	12:10	0:10	LINE FAULT
757	24-Dec-2021	GULBARGA	66	HV1	TELAGI_66	13:45	13:50	0:05	TRANSFORMER FAULT
758	24-Dec-2021	GULBARGA	66	HV1	HARVI_66	14:25	14:30	0:05	TRANSFORMER FAULT
	24-Dec-2021		66	HV1	CHIKKAKONDAGOLA 66		14:01(24.12.		TRANSFORMER CHARGED
759	24 DCC 2021	HASSAN	00	1141	CHIRKAKONDAGCEA_00	19:45(23.12.2021)	2021)	18:15 hrs	THANSI ONWER CHARGED
700	24-Dec-2021	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	0.47/22 12 2021\	18:15(24.12. 2021)	57:27	LINE CHARGED
760		HASSAIN				8:47(22.12.2021)	18:14(24.12.	37.27	
761	24-Dec-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	8:31(22.12.2021)	2021)	57:42 hrs	LINE CHARGED
762	24-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
763	24-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
764	24-Dec-2021	HASSAN	110	HV1	MADHUVANA_110	10:05(21.12.2021			TRANSFORMER OPEN,LINE CLEAR AVAILED
765	24-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:29(23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
766	24-Dec-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:58(24.12.2021)			LINE OPEN,LINE FAULT
767	24-Dec-2021	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	18:18(24.12.2021)			LINE OPEN,LINE FAULT
768	24-Dec-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	18:18(24.12.2021)			LINE OPEN,LINE FAULT
769	24-Dec-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	18:09 (24.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
770	24-Dec-2021	HASSAN	220	HNPR2-GPLPR2	HOLENARASIPURA_220	11:44	14:31	2:47	LINE CLEAR AVAILED
771	24-Dec-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:59	13:21	2:22	NFBC ISSUED
772	24-Dec-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR 220	10:07	12:35	2:28	LINE CLEAR AVAILED
773	24-Dec-2021	HASSAN	220	MRSSHM-VARAHI2	MRSMG_220	17:34	22:27	4:53	LINE FAULT
774	24-Dec-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:59	13:21	2:22	LINE CLEAR AVAILED
775	24-Dec-2021	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	17:34	22:27	4:53	LINE FAULT
776	24-Dec-2021	HASSAN	110	HV1	KARAYA 110	12:45	13:31	0:46	LINE CLEAR AVAILED
777	24-Dec-2021	HASSAN	110	HV1	KAVOOR 220	9:31	13:08	3:37	LINE CLEAR AVAILED
-	24-Dec-2021	HASSAN	66	HASSN22-HN PURA	HASSAN 220	7:08	8:12	1:04	LINE FAULT
778									· · · ·

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
780	24-Dec-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	14:23	18:08	3:45	TRANSFORMER FAULT
781	24-Dec-2021	HASSAN	66	HV2	HASSAN_66	3:56	4:04	0:08	TRANSFORMER FAULT
782	24-Dec-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	17:46	18:17	0:31	HAND TRIPPED
783	24-Dec-2021	HASSAN	66	HV2	SHANTHIGRAMMA_66	8:10	8:20	0:10	TRANSFORMER FAULT
784	24-Dec-2021	HASSAN	66	UDDURKO-SUZLON	UDDURKOPLU_66	11:09	12:01	0:52	LINE CLEAR AVAILED
785	24-Dec-2021	MYSURU	66	HV1	BANNIMANTAPA_66	13:02	13:52	0:49	LINE CLEAR AVAILED
786	24-Dec-2021	MYSURU	66	DUNDANNAHALLI-BESAGARAHALLI	NO STATIONS EFFECTED	20:25	20:40	0:15	HAND TRIPPED
787	24-Dec-2021	MYSURU	66	HV2	DUNDANNAHALLI_66	15:53	16:23	0:29	HAND TRIPPED
788	24-Dec-2021	MYSURU	66	HANAGOD-PONAMPETE	PONNAMPET_66 VIRAJPETE_66	10:26	18:05	7:38	LINE FAULT
789	24-Dec-2021	MYSURU	66	JAKKANAHALLI-NAGMANGLA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA 66	10:00	10:06	0:06	LINE FAULT
790	24-Dec-2021	MYSURU	66	HV1	KIKKERI_66	16:08	18:57	2:49	LINE CLEAR AVAILED
791	24-Dec-2021	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	8:48	8:56	0:07	LINE FAULT
792	24-Dec-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	7:16	7:21	0:04	LINE FAULT
793	24-Dec-2021	MYSURU	66	MADHUVANAHALLI-CR NAGARA 2	NO STATIONS EFFECTED	16:10	17:23	1:13	LINE CLEAR AVAILED
794	24-Dec-2021	MYSURU	66	HV2	MADIKERE_66	10:38	16:45	6:07	LINE CLEAR AVAILED
795	24-Dec-2021	MYSURU	66	MEGHALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_ 66	7:01	7:18	0:17	LINE FAULT
796	24-Dec-2021	MYSURU	66	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	7:00	7:02	0:02	LINE FAULT
797	24-Dec-2021	MYSURU	66	SFCSIVA-PGL	NO STATIONS EFFECTED	9:20	9:28	0:08	LINE FAULT
798	24-Dec-2021	MYSURU	66	SFCSIVA-10MW SOLAR	NO STATIONS EFFECTED	9:20	9:23	0:03	LINE FAULT
799	24-Dec-2021	MYSURU	66	SFCSIVA-5MW SOLAR	NO STATIONS EFFECTED	9:20	9:28	0:08	LINE FAULT
800	24-Dec-2021	MYSURU	66	HV1	TUBINKERE_66	12:43	13:49	1:06	LINE CLEAR AVAILED
801	24-Dec-2021	MYSURU	66	HV2	TUBINKERE_66	10:13	14:02	3:49	LINE CLEAR AVAILED
802	24-Dec-2021	MYSURU	66	HV2	POONAMPETE_66	23:06:14 (24.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
803	24-Dec-2021	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	14:20:00 (23.12.2021)			LINE OPEN,LINE FAULT
804	24-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
805	24-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN, LINE CLEAR AVAILED
806	24-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN, LINE CLEAR AVAILED
807	24-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN, LINE CLEAR AVAILED
808	24-Dec-2021	TUMKUR	220	TR-2	ANTHRASANAHALLI_220	10:32	11:02	0:29	TRANSFORMER FAULT
809	24-Dec-2021	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	10:32	14:23	3:50	TRANSFORMER FAULT
810	24-Dec-2021	TUMKUR	220	TR-3	ANTHRASANAHALLI_220	10:32	11:01	0:28	TRANSFORMER FAULT
811	24-Dec-2021	TUMKUR	220	MADHUGIRI 220kV- VASANTANARASAPURA 2	VASANTANARASAPURA LINE 2	10:33	11:14	0:41	LINE FAULT
812	24-Dec-2021	TUMKUR	220	MADHUGIRI 220kV- VASANTANARASAPURA 2	VASANTANARASAPURA LINE 2	11:14	17:09	5:54	LINE CLEAR AVAILED
813	24-Dec-2021	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	12:19	16:30	4:10	LINE CLEAR AVAILED
814	24-Dec-2021	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	12:19	16:30	4:10	LINE CLEAR AVAILED
815	24-Dec-2021	TUMKUR	110	TR-3	GUBBI_110	12:13	15:56	3:43	LINE CLEAR AVAILED
816	24-Dec-2021	TUMKUR	110	TR-1	SAMPIGE_110	9:12	10:23	1:10	LINE CLEAR AVAILED
817	24-Dec-2021	TUMKUR	110	TR-1	SAMPIGE_110	11:40	14:15	2:34	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
818	24-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	15:35	20:15	4:39	LINE CLEAR AVAILED
819	24-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALVADI 66	10:46	11:16	0:30	HAND TRIPPED
820	24-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	10:45	11:14	0:28	HAND TRIPPED
821	24-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- KORA	KORA_66, THOVINAKERE_66	10:45	11:06	0:21	HAND TRIPPED
822	24-Dec-2021	TUMKUR	66	TR-1(LV-1)	ANTHRASANAHALLI_220	10:32	11:14	0:41	HAND TRIPPED
823	24-Dec-2021	TUMKUR	66	TR-1(LV-1)	ANTHRASANAHALLI_220	11:14	14:24	3:09	LINE CLEAR AVAILED
824	24-Dec-2021	TUMKUR	66	TR-2(LV-2)	ANTHRASANAHALLI_220	10:32	11:03	0:30	HAND TRIPPED
825	24-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI 66	10:45	11:10	0:24	HAND TRIPPED
826	24-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- TUMKUR	TUMKUR_66	10:46	11:03	0:17	HAND TRIPPED
827	24-Dec-2021	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:59	12:40	0:41	HAND TRIPPED
828	24-Dec-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI 66	15:08	15:20	0:11	LINE FAULT
829	24-Dec-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	10:39	10:53	0:13	LINE FAULT
830	24-Dec-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	13:17	13:27	0:09	LINE FAULT
831	24-Dec-2021	TUMKUR	66	TR-2	KADAJJI 66	9:37	9:44	0:06	TRANSFORMER FAULT
832	24-Dec-2021	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE 66	10:32	11:21	0:48	LINE FAULT
833	24-Dec-2021	TUMKUR	66	TR-1	MADHUGIRI_220	12:23	12:38	0:14	LINE CLEAR AVAILED
834	24-Dec-2021	TUMKUR	66	TR-2	MADHUGIRI_220	11:56	12:21	0:24	LINE CLEAR AVAILED
835	24-Dec-2021	TUMKUR	66	TR-2	MATHOD_66	10:15	10:20	0:04	TRANSFORMER FAULT
836	24-Dec-2021	TUMKUR	66	TR-2	MATHOD 66	10:50	10:55	0:05	TRANSFORMER FAULT
837	24-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	12:13	15:10	2:56	LINE CLEAR AVAILED
838	24-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	12:16	12:34	0:18	LINE FAULT
839	24-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	15:10	15:16	0:06	LINE FAULT
840	24-Dec-2021	TUMKUR	66	THALLAK 220kV- CHALLAKERE-2	THALLAK 220kV	18:07	18:19	0:11	LINE FAULT
841	24-Dec-2021	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE 66	12:22	17:42	5:19	LINE CLEAR AVAILED
842	25-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
843	25-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI 220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
844	25-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
845	25-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
846	25-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
847	25-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
848	25-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
849	25-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN, LINE CLEAR AVAILED
850	25-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN,LINE FAULT
851	25-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
852	25-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED

Sec. 2021 BAGALKOT 20	SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
25-be-2021 BAGALKOT 110 GADMG220-SETMERS CADMG_220 (16.322021) LINE OPEN, LINE CERR MAILED 17.12.2021) LINE OPEN, LINE CERR MAILED 15.52 LINE CERR MAILED 15	853	25-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220				LINE OPEN, LINE CLEAR AVAILED
SS 25-De-2021 BAGAIKOT 110 RON-GUENDRAGAD2 RON_SILO 17.22.2021 LINE OPEN, LINE CLEAR AVAILED 10.2037 LINE OPEN, LINE CLEAR AVAILED 10.2037 LINE OPEN, LINE CLEAR AVAILED 11.34.1 LINE OPEN, LINE CLEAR AVAILED 13.34.1 LINE OPEN, LINE CLEAR AVAILED 13.32.1 LINE CLEAR AVAIL	854	25-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	(14.12.2021)			LINE OPEN, LINE CLEAR AVAILED
\$50 25-Dec-2021 BAGALKOT 110 RON-GAIRNORGADI RON_110 (27.12.2021) LINE OPEN, LINE CLEAR AVAILED	855	25-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	(17.12.2021)			LINE OPEN,LINE FAULT
25-Dec-2021 BAGALKOT 110 TARHAL-TADANIP (RADB GAMANGHATI) TARHAL_TID (23.12.2021) LINE OPEN, LINE CLEAR AVAILED (23.12.2021) LINE CREAR AVAILED LINE FAULT LINE	856	25-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	(17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
SSP 25-Dec-2021 BAGALKOT 110 SIRS-HUBLILESNLET) SIRS_110 (24.12.2021) 15-52 11NE OPEN, LINE CLEAR AVAILED 15-52 124.12.2021) 15-52 11NE OPEN, LINE CLEAR AVAILED 15-52 124.12.2021) 15-52 124.12.2021) 15-52 124.12.2021) 15-52 124.12.2021) 15-52 124.12.2021 15-52 124.12.2021) 15-52 124.12.2021 124.12.2021 124.12	857	25-Dec-2021	BAGALKOT	110	TARIHAL-TADSNKP(KIADB GAMANGHATTI)	TARIHAL_110	(23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
25-Dec-2021 BAGALKOT 110 SINS- KANALWADA(ESALEI) SINS_110 (24.12.2021) 18.11 (25.12.2021) 22.44HRS TRANSFORMER CHARGED 18.60 110 110/11KV,HV2 MALGHAN(B]_110 7.27 (24.12.2021) 22.44HRS TRANSFORMER CHARGED 18.60 110 CHIKKODI 200 5.08 9.10 4.02 LINE FAULT 18.61 25.02.2021 BAGALKOT 110 CHIKKODI 200 5.08 9.10 4.02 LINE FAULT 18.61 25.02.2021 BAGALKOT 110 SINS_120 5.08 9.10 4.02 LINE FAULT 18.61 25.02.2021 BAGALKOT 110 MIKHUBILIZO-BARIHONGAL MK.HUBIL 220 9.30 9.55 0.25 HAND TRIPPED 18.63 25.02.2021 BAGALKOT 220 SINS-HUBBII SINS_1220 10.16 18.35 8.19 LINE CLEAR AVAILED 18.65 25.02.201 BAGALKOT 220 SINS-HUBBII SINS_1220 10.16 18.35 8.19 LINE CLEAR AVAILED 18.65 25.02.201 BAGALKOT 220 SINSH-HUBBII SINS_1220 10.16 18.35 8.19 LINE CLEAR AVAILED 18.65 25.02.201 BAGALKOT 220 SINSH-HUBBII SINS_1220 10.16 18.35 8.19 LINE CLEAR AVAILED 18.65 25.02.201 BAGALKOT 110 110/11KV,HV2 HUKKERI_110 12.40 12.45 0.05 TRANSFORMER FAULT 18.65 25.02.201 BAGALKOT 110 110/11KV,HV2 HUKKERI_110 12.40 12.45 0.05 LINE FAULT 18.65 25.02.201 BAGALKOT 110 110/11KV,HV2 NIDAGUNDI_110 9.05 9.13 0.08 TRANSFORMER FAULT 18.65 25.02.201 BAGALKOT 110 110/11KV,HV2 RON_110 13.40 14.17 4.75 0.09 LURE CLEAR AVAILED 18.67 25.02.201 BAGALKOT 110 SUUVARNASOUNA SUGARRI JID 13.40 14.17 0.37 LINE CLEAR AVAILED 18.75 25.02.2021 BAGALKOT 110 SUUVARNASOUNA SUGARRI JID 10.04 10.04 10.05 LINE CLEAR AVAILED 10.05 LINE CLEAR AV	858	25-Dec-2021	BAGALKOT	110	SIRSI- HUBLI1(ESALE1)	SIRSI_110	(24.12.2021)			LINE OPEN, LINE CLEAR AVAILED
Septe-2021 BAGALKOT 110 110/11KV,HY2 MALGHANIB),110 7-27 (24.12.021) (25.12.2021	859	25-Dec-2021	BAGALKOT	110	SIRSI- KAVALWADA(ESALE1)	SIRSI_110				LINE OPEN, LINE CLEAR AVAILED
SEC 25-Dec-2021 BAGALKOT 110 GHATAPABAHA220-GONAK GHATAPABAHA220 7:39 8:04 0.25 LINE FAULT	860	25-Dec-2021	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	7:27 (24.12.2021)		22:44HRS	TRANSFORMER CHARGED
864 25-Dec-2021 BAGALKOT 110 MIKHUBILIZO-BAILHONGAL MIKHUBIL 20 9:30 9:55 0:25 HAND TRIPPED	861	25-Dec-2021	BAGALKOT	110	CHIKKODI220- SADALAGA	CHIKKODI_220	5:08	9:10	4:02	LINE FAULT
25-Dec-2021 BAGALKOT 220 SIRS-HUBLI SIRS_220 10:16 18:35 8:19 LINE CLEAR AVAILED	862	25-Dec-2021	BAGALKOT	110		GHATAPRABHA_220	7:39	8:04	0:25	LINE FAULT
865 25-Dec-2021 BAGALKOT 220 BGWDI-RBRK BAGEWADI_220 16:45 16:59 0:14 LINE FAULT	863	25-Dec-2021	BAGALKOT	110	MKHUBLI220-BAILHONGAL	MK HUBLI_220	9:30	9:55	0:25	HAND TRIPPED
R66 25-Dec-2021 BAGALKOT 110 110/11kV,HV4 HUKKER_110 12-40 12-45 0.05 TRANSFORMER FAULT	864	25-Dec-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	10:16	18:35	8:19	LINE CLEAR AVAILED
RFT 25-Dec-2021 BAGALKOT 110 PG HUNASYAL-NAGANUR NAGANUR_110 4:19 4:24 0:05 LINE FAULT	865	25-Dec-2021	BAGALKOT	220	BGWDI-RBRK	BAGEWADI_220	16:45	16:59	0:14	LINE FAULT
R68 25-Dec-2021	866	25-Dec-2021	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:40	12:45	0:05	TRANSFORMER FAULT
R69 25-Dec-2021	867	25-Dec-2021	BAGALKOT	110	PG HUNASYAL-NAGANUR	NAGANUR_110	4:19	4:24	0:05	LINE FAULT
870 25-Dec-2021 BAGALKOT 110 110/11kV,HV2 RON_110 13:40 14:17 0:37 LINE CLEAR AVAILED	868	25-Dec-2021	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	9:05	9:13	0:08	TRANSFORMER FAULT
ST1 25-Dec-2021 BAGALKOT 110 SOUDATTI-ENERCON SOUDATTI_110 10:25 17:35 7:10 LINE CLEAR AVAILED	869	25-Dec-2021	BAGALKOT	110	PG HUNASYAL-NAGANUR	NAGANUR_110	4:17	4:25	0:08	LINE FAULT
25-Dec-2021 BAGALKOT 110 UGARKHUD-UGAR SUGARS UGARKHUD_110, UGAR SUGARS IPP 14:05 12:13 358:08HRS IINE CHARGED	870	25-Dec-2021	BAGALKOT	110	110/11KV,HV2	RON_110	13:40	14:17	0:37	LINE CLEAR AVAILED
ST2 25-Dec-2021 BAGALKOT 110 SUVARNASOUDHA-MACHEO/G SUVARNASOUDA_110 14:05 (10.12.2021) 358:08HRS LINE CHARGED	871	25-Dec-2021	BAGALKOT	110	SOUDATTI-ENERCON	SOUDATTI_110	10:25	17:35	7:10	LINE CLEAR AVAILED
SUVARNASOUDA_110 (10.12.2021) (25.12.2021) 358:08HRS LINE CHARGED	872	25-Dec-2021	BAGALKOT	110	UGARKHUD-UGAR SUGARS	_	8:10	8:11	0:01	MAIN SUPPLY FAILURE
SUGARS_IPP 7:50 7:55 0:05 MAIN SUPPLY FAILURE	873	25-Dec-2021	BAGALKOT	110	SUVARNASOUDHA-MACHEO/G	_			358:08HRS	LINE CHARGED
876 25-Dec-2021 BAGALKOT 110 MKHUBLI220-BAILHONGAL BAILHONGAL_110 9:35 9:45 0:10 MAIN SUPPLY FAILURE 877 25-Dec-2021 BAGALKOT 110 MKHUBLI220-BAILHONGAL BAILHONGAL_110 9:55 10:05 0:10 HAND TRIPPED 878 25-Dec-2021 BAGALKOT 110 110/11KV,HV2 BAGEWADI_220 10:42 10:46 0:04 TRANSFORMER FAULT 879 25-Dec-2021 BAGALKOT 110 CHIKKODI_220-RAIBAG1 CHIKKODI_220 6:55 10:35 3:40 LINE FAULT 880 25-Dec-2021 BAGALKOT 110 AMBEWADI-SUPA2 AMBEWADI_220 3:14 3:28 0:14 LINE FAULT 881 25-Dec-2021 BAGALKOT 220 SIRSI-BUBLI2 SIRSI_220 10:16 18:35 8:19 LINE FAULT 882 25-Dec-2021 BENGALURU 66 HV1 CHATRA 7:40 7:45 0:05 TRANSFORMER FAULT 883 25-Dec-2021 BENGALURU 66	874	25-Dec-2021	BAGALKOT	110	UGARKHUD-KAGWAD		7:50	7:55	0:05	MAIN SUPPLY FAILURE
877 25-Dec-2021 BAGALKOT 110 MKHUBLI220-BAILHONGAL BAILHONGAL_110 9:55 10:05 0:10 HAND TRIPPED 878 25-Dec-2021 BAGALKOT 110 110/11KV,HV2 BAGEWADI_220 10:42 10:46 0:04 TRANSFORMER FAULT 879 25-Dec-2021 BAGALKOT 110 CHIKKODI220- RAIBAG1 CHIKKODI_220 6:55 10:35 3:40 LINE FAULT 880 25-Dec-2021 BAGALKOT 110 AMBEWADI-SUPA2 AMBEWADI_220 3:14 3:28 0:14 LINE FAULT 881 25-Dec-2021 BAGALKOT 220 SIRSI-HUBLI2 SIRSI_220 10:16 18:35 8:19 LINE CLEAR AVAILED 882 25-Dec-2021 BENGALURU 66 HV1 CHATRA 7:40 7:45 0:05 TRANSFORMER FAULT 883 25-Dec-2021 BENGALURU 66 TK HALLI 220 - MANDYA 2 KIADB MANDYA, 12:55 13:15 0:20 884 25-Dec-2021 BENGALURU 66 TK HALLI 220 - SH	875	25-Dec-2021	BAGALKOT	110	110/11KV,HV2	TUMMINAKATTI_110	13:40	14:40	1:00	TRANSFORMER FAULT
878 25-Dec-2021 BAGALKOT 110 110/11KV,HV2 BAGEWADI_220 10:42 10:46 0:04 TRANSFORMER FAULT 879 25-Dec-2021 BAGALKOT 110 CHIKKODI220-RAIBAG1 CHIKKODI_220 6:55 10:35 3:40 LINE FAULT 880 25-Dec-2021 BAGALKOT 110 AMBEWADI_SUPA2 AMBEWADI_220 3:14 3:28 0:14 LINE FAULT 881 25-Dec-2021 BAGALKOT 220 SIRSI-HUBLI2 SIRSI_220 10:16 18:35 8:19 LINE CLEAR AVAILED 882 25-Dec-2021 BENGALURU 66 HV1 CHATRA 7:40 7:45 0:05 TRANSFORMER FAULT KM DODDI, KK DODDI, KIADB MANDYA, KIADB MANDYA, LINE FAULT LINE FAULT 884 25-Dec-2021 BENGALURU 66 TK HALLI 220 - SHIMSHA NO STATION AFFECTED 12:55 13:31 0:36 LINE FAULT 885 25-Dec-2021 BENGALURU 66 TK HALLI 220 - SHIMSHA NO STATION AFFECTED 13:32 17:39 <td>876</td> <td></td> <td></td> <td>+</td> <td>MKHUBLI220-BAILHONGAL</td> <td>BAILHONGAL_110</td> <td></td> <td></td> <td>0:10</td> <td>MAIN SUPPLY FAILURE</td>	876			+	MKHUBLI220-BAILHONGAL	BAILHONGAL_110			0:10	MAIN SUPPLY FAILURE
STP 25-Dec-2021 BAGALKOT 110 CHIKKODI220-RAIBAG1 CHIKKODI220 6:55 10:35 3:40 LINE FAULT	877		BAGALKOT	110	MKHUBLI220-BAILHONGAL		9:55	10:05	0:10	HAND TRIPPED
S80 25-Dec-2021 BAGALKOT 110 AMBEWADI-SUPA2 AMBEWADI_220 3:14 3:28 0:14 LINE FAULT		25-Dec-2021	BAGALKOT	110				10:46	0:04	TRANSFORMER FAULT
SIRSI 25-Dec-2021 BAGALKOT 220 SIRSI-HUBLI2 SIRSI_220 10:16 18:35 8:19 LINE CLEAR AVAILED	879	25-Dec-2021	BAGALKOT	110		CHIKKODI_220	6:55	1	3:40	LINE FAULT
R82 25-Dec-2021 BENGALURU 66 HV1 CHATRA 7:40 7:45 0:05 TRANSFORMER FAULT					AMBEWADI-SUPA2	-			+	
25-Dec-2021 66	881	25-Dec-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	10:16	18:35	8:19	LINE CLEAR AVAILED
25-Dec-2021 BENGALURU 66 TK HALLI 220 - MANDYA 2 KIADB MANDYA, MADDUR, MANDYA 12:55 13:15 0:20	882	25-Dec-2021	BENGALURU	66	HV1		7:40	7:45	0:05	TRANSFORMER FAULT
884 25-Dec-2021 BENGALURU 66 TK HALLI 220 - SHIMSHA NO STATION AFFECTED 12:55 13:31 0:36 LINE FAULT 885 25-Dec-2021 BENGALURU 66 TK HALLI 220 - SHIMSHA NO STATION AFFECTED 13:32 17:39 4:07 LINE FAULT KM DODDI, KK DO	883	25-Dec-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KIADB MANDYA,	12:55	13:15	0:20	LINE FAULT
885 25-Dec-2021 BENGALURU 66 TK HALLI 220 - SHIMSHA NO STATION AFFECTED 13:32 17:39 4:07 LINE FAULT KM DODDI, KK DODDI, VALUE KIADB MANDYA, KIADB MANDYA, LINE FAULT	884	25-Dec-2021	BENGALURU	66	TK HALLI 220 - SHIMSHA	· · · · · · · · · · · · · · · · · · ·	12:55	13:31	0:36	LINE FAULT
25-Dec-2021 66 TK HALLI 220 - MANDYA 2 KIADB MANDYA, LINE FAULT	885	25-Dec-2021	BENGALURU	66		NO STATION AFFECTED	13:32	17:39	4:07	LINE FAULT
886 BENGALURU MADDUR, MANDYA 13:31 13:56 0:25	886	25-Dec-2021	BENGALURU	66	TK HALLI 220 - MANDYA 2	KIADB MANDYA,	13:31	13:56	0:25	LINE FAULT
887 25-Dec-2021 BENGALURU 66 WELCASTE STEEL - SRS PEENYA 220 WELCASTE STEEL 22:28 22:35 0:07 LOAD CHANGE OVER	-	25-Dec-2021		66	WELCASTE STEEL - SRS PEENYA 220	,		1		LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
888	25-Dec-2021	BENGALURU	66	T G HALLI - ANCHEPALYA 220	T G HALLI	23:14	23:29	0:15	MAIN SUPPLY FAILURE
889	25-Dec-2021	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	AGALKOTE	23:14	23:29	0:15	MAIN SUPPLY FAILURE
890	25-Dec-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	23:14	23:29	0:15	MAIN SUPPLY FAILURE
891	25-Dec-2021	BENGALURU	66	GUDEMARANAHALLI - ANCHEPALYA 220	GUDEMARANAHALLI	23:14	23:29	0:15	MAIN SUPPLY FAILURE
892	25-Dec-2021	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGEREPURA	23:14	23:29	0:15	MAIN SUPPLY FAILURE
893	25-Dec-2021	BENGALURU	220	LV2	SARJAPURA 220	9:49	11:30	1:41	TRANSFORMER FAULT
894	25-Dec-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:49	11:05	1:16	LINE FAULT
895	25-Dec-2021	BENGALURU	66	DOMMASANDRA - KACHMARANAHALLI	DOMMASANDRA	14:50	14:55	0:05	LOAD CHANGE OVER
896	25-Dec-2021	BENGALURU	66	SARJAPUR 220 - ATTIBELE	ATTIBELE	9:49	10:38	0:49	MAIN SUPPLY FAILURE
897	25-Dec-2021	BENGALURU	66	SARJAPUR 220 - ATTIBELE	ATTIBELE	11:27	11:32	0:05	LINE CLEAR AVAILED
898	25-Dec-2021	BENGALURU	66	HV1	SARJAPURA 220	9:49	10:38	0:49	MAIN SUPPLY FAILURE
899	25-Dec-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2(DG3)	HBR LAYOUT, BELL CERAMICS (EHT)	3:34	3:48	0:14	LINE FAULT
900	25-Dec-2021	BENGALURU	66	HBR LAYOUT - HEBBAL 220	HBR LAYOUT, BELL CERAMICS (EHT)	4:04	4:07	0:03	LOAD CHANGE OVER
901	25-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	D PALYA, GUDIBANDE, MANDIKAL, PERESANDRA	9:46	9:55	0:09	LINE FAULT
902	25-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	9:46	9:56	0:10	LINE FAULT
903	25-Dec-2021	BENGALURU	66	HV1	HOSKOTE 66	20:10	20:35	0:25	TRANSFORMER FAULT
904	25-Dec-2021	BENGALURU	66	HV3	HOSKOTE 66	2:40	3:00	0:20	TRANSFORMER FAULT
905	25-Dec-2021	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, GOWNPALLI, SOMAYAJANAHALLI, RAYALPADU	6:28	6:39	0:11	LINE FAULT
906	25-Dec-2021	BENGALURU	66	PADMANABHANAGAR - SUBRAMANYAPURA 220	PADMANABHANAGAR	6:05	6:09	0:04	LOAD CHANGE OVER
907	25-Dec-2021	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	23:11	23:14	0:02	LOAD CHANGE OVER
908	25-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
909	25-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
910	25-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
911	25-Dec-2021	GULBARGA	220	SHAHAPUR-KAPNOOR	SHAHAPUR_220	0:42	1:11	0:29	LINE FAULT
912	25-Dec-2021	GULBARGA	220	ALIPUR-BTPS	ALIPUR_220	7:08	15:38	8:30	LINE CLEAR AVAILED
913	25-Dec-2021	GULBARGA	220	MALLAT-RTPS	MALLAT_220	19:41(24.12.2021)	12:01(25.12. 2021)	16:20HRS	LINE CHARGED
914	25-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN, LINE CLEAR AVAILED
915	25-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
916		GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:09 (22.12.2021)			LINE OPEN, LINE CLEAR AVAILED
917	25-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR	GABBUR_110	22:00(25.12.2021)			LINE OPEN,LINE FAULT
918	25-Dec-2021	GULBARGA	110	GULBARGAUNIVERSITY-GULBARGASOUTH	GULBARGAUNIVERSITY_11 0	10:20	19:10	8:50	NFBC ISSUED
919	25-Dec-2021	GULBARGA	110	STARMETALLIC-MUNIRABAD	MUNIRABAD_220	13:58	14:40	0:42	LINE FAULT
920	25-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	13:49	13:59	0:10	MAIN SUPPLY FAILURE
921	25-Dec-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BHALKI SUGUR_IPP	4:00	4:05	0:05	LINE FAULT
922	25-Dec-2021	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	22:01	22:05	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
923	25-Dec-2021	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_1 10,RBSNS,KAMALAPUR_11 0	14:01	14:10	0:09	LINE FAULT
924	25-Dec-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:58(24.12.2021)	7:03(25.12.2 021)	7:04 hrs	LINE CHARGED
925	25-Dec-2021	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	18:18(24.12.2021)	9:07(25.12.2 021)	16:48 hrs	LINE CHARGED
926	25-Dec-2021	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	18:18(24.12.2021)	11:31(25.12. 2021)	17:16 hrs	LINE CHARGED
927	25-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
928	25-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
929	25-Dec-2021	HASSAN	110	HV1	MADHUVANA_110	10:05(21.12.2021			TRANSFORMER OPEN,LINE CLEAR AVAILED
930	25-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:29(23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
931	25-Dec-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	18:09 (24.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
932	25-Dec-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	13:56	14:04	0:08	LINE FAULT
933	25-Dec-2021	MYSURU	66	HV2	HANNUR_66	11:03	17:40	6:36	LINE CLEAR AVAILED
934	25-Dec-2021	MYSURU	66	HV2	HANNUR_66	17:40	18:00	0:20	TRANSFORMER FAULT
935	25-Dec-2021	MYSURU	66	HV2	HANNUR_66	18:00	19:12	1:12	LINE CLEAR AVAILED
936	25-Dec-2021	MYSURU	66	HV3	KUSHALANAGARA 66	1:33	1:34	0:01	HAND TRIPPED
937	25-Dec-2021	MYSURU	66	HV3	KUSHALANAGARA 66	7:03	8:09	1:06	LINE CLEAR AVAILED
938	25-Dec-2021	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	7:03	7:08	0:05	LINE FAULT
939	25-Dec-2021	MYSURU	66	HOOTGALLY-VIKRANTH	HEBBAL_66 METAGALLY_66	7:16	7:40	0:23	LINE FAULT
940	25-Dec-2021	MYSURU	66	HV2	POONAMPETE_66	23:06:14 (24.12.2021)	13:48:44 (25.12.2021)	14:42HRS	TRANSFORMER CHARGED
941	25-Dec-2021	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	14:20:00 (23.12.2021)			LINE OPEN,LINE FAULT
942	25-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
943	25-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN, LINE CLEAR AVAILED
944	25-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN, LINE CLEAR AVAILED
945	25-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN, LINE CLEAR AVAILED
946	25-Dec-2021	TUMKUR	220	TR-1	KDBVNO_220	17:49	20:20	2:31	TRANSFORMER FAULT
947	25-Dec-2021	TUMKUR	66	TR-1	BHARAMAGIRI_66	3:04	3:06	0:02	TRANSFORMER FAULT
948	25-Dec-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKA TTE_66,KADAJJI_66	6:46	6:58	0:12	LINE FAULT
949	25-Dec-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKA TTE_66,KADAJJI_66	7:54	8:05	0:10	LINE FAULT
950	25-Dec-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKA TTE_66,KADAJJI_66	10:31	11:24	0:52	LINE CLEAR AVAILED
951	25-Dec-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKA TTE_66,KADAJJI_66	18:18	18:32	0:13	LINE FAULT
952	25-Dec-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	6:03	6:07	0:04	HAND TRIPPED
953	25-Dec-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	6:03	6:06	0:02	HAND TRIPPED
954	25-Dec-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI 66	5:57	6:07	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
955	25-Dec-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI 66	6:32	6:42	0:09	LINE FAULT
956	25-Dec-2021	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	16:18	18:16	1:57	LINE CLEAR AVAILED
957	25-Dec-2021	TUMKUR	66	TR-1(LV-1)	KDBVNO_220	17:49	20:21	2:32	TRANSFORMER FAULT
958	25-Dec-2021	TUMKUR	66	TR-2	MALEBENNUR_66	7:03	7:30	0:27	TRANSFORMER FAULT
959	25-Dec-2021	TUMKUR	66	TR-1	MATHOD_66	21:19	21:28	0:09	TRANSFORMER FAULT
960	25-Dec-2021	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_ 66,	8:08	8:28	0:20	LINE FAULT
961	25-Dec-2021	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_ 66,	8:29	8:44	0:14	LINE FAULT
962	25-Dec-2021	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_ 66,	12:12	12:29	0:17	LINE FAULT
963	25-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	12:17	12:26	0:09	TRANSFORMER FAULT
964	25-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	13:24	13:30	0:05	TRANSFORMER FAULT
965	25-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	10:06	10:10	0:03	LINE FAULT
966	25-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	12:26	12:31	0:04	LINE FAULT
967	25-Dec-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	9:52	10:04	0:12	LINE CLEAR AVAILED
968	26-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
969	26-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
970	26-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
971	26-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
972	26-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
973	26-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
974	26-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
975	26-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN, LINE CLEAR AVAILED
976	26-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)			LINE OPEN,LINE FAULT
977	26-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
978	26-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
979	26-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
980	26-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN, LINE CLEAR AVAILED
981	26-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE FAULT
982	26-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
983	26-Dec-2021	BAGALKOT	110	TARIHAL-TADSNKP(KIADB GAMANGHATTI)	TARIHAL_110	11:44 (23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
984	26-Dec-2021	BAGALKOT	110	SIRSI- HUBLI1(ESALE1)	SIRSI_110	15:52 (24.12.2021)			LINE OPEN, LINE CLEAR AVAILED
985	26-Dec-2021	BAGALKOT	110	SIRSI- KAVALWADA(ESALE1)	SIRSI_110	15:52 (24.12.2021)			LINE OPEN, LINE CLEAR AVAILED
986	26-Dec-2021	BAGALKOT	110	KARWAR220- BINAGA	KARWAR_220	9:09	9:48	0:39	HAND TRIPPED
987	26-Dec-2021	BAGALKOT	110	KARWAR220- ARGA	KARWAR_220	9:18	9:58	0:40	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
988	26-Dec-2021	BAGALKOT	110	GHATAPRABHA220- GOKAK	GHATAPRABHA_220	13:40	15:33	1:53	LINE CLEAR AVAILED
989	26-Dec-2021	BAGALKOT	110	CHIKKODI220- SANKESHWAR	CHIKKODI_220	3:11	3:58	0:47	LINE FAULT
990	26-Dec-2021	BAGALKOT	110	220/110KV, LV1	CHIKKODI_220	3:10	3:35	0:25	TRANSFORMER FAULT
991	26-Dec-2021	BAGALKOT	220	220/110KV, HV2&LV2	CHIKKODI_220	3:10	3:35	0:25	TRANSFORMER FAULT
992	26-Dec-2021	BAGALKOT	220	220/110KV, HV3&LV3	CHIKKODI_220	3:10	3:35	0:25	TRANSFORMER FAULT
993	26-Dec-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI1	SOUDATTI_220	10:02	16:23	6:23	LINE CLEAR AVAILED
994	26-Dec-2021	BAGALKOT	110	SOUDATTI220- SOUDATTI2	SOUDATTI_220	10:02	16:24	6:23	LINE CLEAR AVAILED
995	26-Dec-2021	BAGALKOT	110	SOUDATTI220- NARAGUND(RAMDURGA1)	SOUDATTI_220	9:16	13:25	7:06	LINE CLEAR AVAILED
996	26-Dec-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	9:42	18:27	8:45	LINE CLEAR AVAILED
997	26-Dec-2021	BAGALKOT	110	CHIKKODI220- SANKESHWAR	SANKESHWAR_110	3:11	3:55	0:44	LINE FAULT
998	26-Dec-2021	BAGALKOT	110	110/11KV, HV1	SANKESHWAR_110	3:12	3:55	0:43	HAND TRIPPED
999	26-Dec-2021	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	3:11	3:55	0:44	HAND TRIPPED
1000	26-Dec-2021	BAGALKOT	110	110/11KV, HV3	SAVALAGI_110	12:36	12:56	0:20	TRANSFORMER FAULT
1001	26-Dec-2021	BAGALKOT	110	110/11KV,HV1	THORVI_110	11:28	11:30	0:02	TRANSFORMER FAULT
1002	26-Dec-2021	BAGALKOT	110	MAMADAPUR-DEVARGENNUR	DEVARGENNUR_ 110	18:16	18:34	0:18	LINE FAULT
1003	26-Dec-2021	BAGALKOT	110	DEVARGENNUR-SHIRABUR	SHIRABUR_ 110	18:16	18:35	0:19	LINE FAULT
1004	26-Dec-2021	BAGALKOT	110	HALIYAL-ALNAVAR(GMR)	ALNAVAR_110	10:40	15:53	5:13	LINE CLEAR AVAILED
1005	26-Dec-2021	BAGALKOT	110	BAGEWADI-MAMADAPUR(B)	MAMADAPUR_110	18:29	18:40	0:11	LINE FAULT
1006	26-Dec-2021	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	8:33	8:38	0:05	TRANSFORMER FAULT
1007	26-Dec-2021	BAGALKOT	110	CHIKKODI220-ANKALI	ANKALI_110	3:10	3:40	0:30	MAIN SUPPLY FAILURE
1008	26-Dec-2021	BAGALKOT	110	BGWDI-MAMADAPUR 1(LINE 2)	MAMADAPUR_110	18:17	18:26	0:09	LINE FAULT
1009	26-Dec-2021	BAGALKOT	220	KADRA1&2- KARWAR	KARWAR_220	8:57	9:45	0:48	MAIN SUPPLY FAILURE
1010	26-Dec-2021	BAGALKOT	110	SIRSI220- KAVALWADA	SIRSI_220	19:10	19:14	0:04	HAND TRIPPED
1011	26-Dec-2021	BAGALKOT	110	ALNAVAR- HALIYAL	HALIYAL_110	10:25	15:55	5:30	MAIN SUPPLY FAILURE
1012	26-Dec-2021	BAGALKOT	110	RANEBENNUR- HONNATTI	RANEBENNUR_220	3:56	4:06	0:10	LINE FAULT
1013	26-Dec-2021	BAGALKOT	110	SOUDATTI220- RAMDURGA2	SOUDATTI_220	9:16	13:25	7:06	LINE CLEAR AVAILED
1014	26-Dec-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	9:42	18:27	8:45	LINE CLEAR AVAILED
1015	26-Dec-2021	BENGALURU	66	A STATION 220 - NRS 220	A STATION 220	18:12	18:39	0:27	MAIN SUPPLY FAILURE
1016	26-Dec-2021	BENGALURU	66	A STATION 220 - A STATION 1 & 2	A STATION 66	18:12	18:40	0:28	MAIN SUPPLY FAILURE
1017	26-Dec-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	NO STATION AFFECTED	6:51	7:33	0:42	LINE FAULT
1018	26-Dec-2021	BENGALURU	66	BIDADI 220 - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU, KEMPANAHALLI	8:25	8:38	0:13	LINE CLEAR AVAILED
1019	26-Dec-2021	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIGEHALLI, SRIGANDA KAVALU	15:08	15:27	0:19	LINE CLEAR AVAILED
1020	26-Dec-2021	BENGALURU	66	HV1	CHATRA	17:40	18:04	0:24	MAIN SUPPLY FAILURE
1021	26-Dec-2021	BENGALURU	66	HV1	EPIP 220	10:02	12:05	2:03	LINE CLEAR AVAILED
1022	26-Dec-2021	BENGALURU	66	HV2	EPIP 220	14:05	15:11	1:06	LINE CLEAR AVAILED
1023	26-Dec-2021	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	5:40	5:55	0:15	LOAD CHANGE OVER
1024	26-Dec-2021	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	18:01	18:08	0:07	LOAD CHANGE OVER
1025	26-Dec-2021	BENGALURU	66	IISc - HEBBALA 220	IISc	5:19	5:22	0:03	LOAD CHANGE OVER
1026	26-Dec-2021	BENGALURU	66	IISc - NRS 220	IISc	18:13	18:44	0:31	LOAD CHANGE OVER
1027	26-Dec-2021	BENGALURU	66	KANTEERAVA - A STATION 220	KANTEERAVA	18:12	18:42	0:30	MAIN SUPPLY FAILURE

1028		Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
1020	26-Dec-2021	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	7:23	7:42	0:19	MAIN SUPPLY FAILURE
1029	26-Dec-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	5:35	5:40	0:05	LOAD CHANGE OVER
1030	26-Dec-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	18:12	18:48	0:36	MAIN SUPPLY FAILURE
1031	26-Dec-2021	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	5:30	5:35	0:05	LOAD CHANGE OVER
1032	26-Dec-2021	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	21:53	21:58	0:05	LOAD CHANGE OVER
1033	26-Dec-2021	BENGALURU	66	MEI LAYOUT - SRS PEENYA 220	MEI LAYOUT, WIDIA, WIDIA(EHT)	7:00	7:21	0:21	MAIN SUPPLY FAILURE
1034	26-Dec-2021	BENGALURU	66	MEI LAYOUT - SRS PEENYA 220	MEI LAYOUT, WIDIA, WIDIA(EHT)	13:56	14:01	0:05	MAIN SUPPLY FAILURE
1035	26-Dec-2021	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	15:06	15:36	0:30	MAIN SUPPLY FAILURE
1036	26-Dec-2021	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	18:12	18:40	0:28	MAIN SUPPLY FAILURE
1037	26-Dec-2021	BENGALURU	66	HV1	VIJAYANAGARA	18:12	18:48	0:36	MAIN SUPPLY FAILURE
1038	26-Dec-2021	BENGALURU	220	HV4	SRS PEENYA 220	18:15	18:30	0:15	TRANSFORMER FAULT
1039	26-Dec-2021	BENGALURU	220	HV3	SRS PEENYA 220	15:27	15:36	0:09	TRANSFORMER FAULT
1040	26-Dec-2021	BENGALURU	220	HV2	SRS PEENYA 220	6:30	13:32	7:02	LINE CLEAR AVAILED
1041	26-Dec-2021	BENGALURU	220	HV4	SRS PEENYA 220	7:30	17:50	10:20	LINE CLEAR AVAILED
1042	26-Dec-2021	BENGALURU	66	BIEC - SRS PEENYA 220	BIEC	5:50	6:05	0:15	LOAD CHANGE OVER
1043	26-Dec-2021	BENGALURU	66	BIEC - SOLADEVANAHALLI	BIEC	20:12	20:26	0:14	LOAD CHANGE OVER
	26-Dec-2021	BENGALURU	66	T G HALLI - ANCHEPALYA 220	T G HALLI	18:15	18:32	0:17	MAIN SUPPLY FAILURE
\vdash	26-Dec-2021	BENGALURU	66	AGALKOTE - ANCHEPALYA 220	AGALKOTE	18:15	18:32	0:17	MAIN SUPPLY FAILURE
	26-Dec-2021	BENGALURU	66	MAGADI 66 - ANCHEPALYA 220	MAGADI 66	18:15	18:32	0:17	MAIN SUPPLY FAILURE
	26-Dec-2021	BENGALURU	66	GUDEMARANAHALLI - ANCHEPALYA 220	GUDEMARANAHALLI	18:15	18:32	0:17	MAIN SUPPLY FAILURE
1048	26-Dec-2021	BENGALURU	66	HULLENAHALLI - ANCHEPALYA 220	HULLENAHALLI, KUDUR, SIRIGEREPURA	18:15	18:32	0:17	MAIN SUPPLY FAILURE
1049	26-Dec-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	9:17	11:48	2:31	LINE CLEAR AVAILED
1050	26-Dec-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	9:17	11:49	2:32	LINE CLEAR AVAILED
1051	26-Dec-2021	BENGALURU	66	HV2	KOLAR 220	11:50	13:19	1:29	LINE CLEAR AVAILED
1052	26-Dec-2021	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	5:35	5:52	0:17	LOAD CHANGE OVER
1053	26-Dec-2021	BENGALURU	66	HV2	TEMAGONDALU	17:51	18:07	0:16	LINE CLEAR AVAILED
1054	26-Dec-2021	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANUKUNTE	17:40	17:55	0:14	LINE FAULT
1055	26-Dec-2021	BENGALURU	220	NELAMANGALA 400 - NRS 220	NRS 220	18:13	18:42	0:28	LINE FAULT
1056	26-Dec-2021	BENGALURU	66	HV2	SULIBELE	0:30	1:10	0:40	TRANSFORMER FAULT
1057	26-Dec-2021	BENGALURU	66	HV1	HOSKOTE 66	9:05	9:10	0:05	TRANSFORMER FAULT
1058	26-Dec-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	13:36	13:53	0:16	LINE FAULT
1059	26-Dec-2021	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	5:27	5:32	0:05	LOAD CHANGE OVER
1060	26-Dec-2021	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	21:51	21:56	0:05	LOAD CHANGE OVER
1061	26-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
1062	26-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1063	26-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1064	26-Dec-2021	GULBARGA	220	HV2	LINGASUGUR_220	11:24	11:31	0:07	LINE CLEAR AVAILED
1065	26-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	18:16 (26.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1066	26-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1067	26-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
	26-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR	GABBUR_110	20:40(26.12.2021)			LINE OPEN,LINE FAULT

1069 1070 26-D 1071 26-D 1072 26-D 1073 26-D 1074 26-D 1075 26-D 1076 26-D 1077 26-D 1078 26-D 1079 26-D	-Dec-2021 -Dec-2021	GULBARGA	110 110 110 110 110 110 110 110	GABBUR-BPSOLAR BISIHALLI-HALKUNDI BISIHALLI-HALKUNDI BISIHALLI-HALKUNDI HV1 METRI-ALIPUR METRI-ALIPUR METRI-ALIPUR GALAG-MALLAT	GABBUR_110 BISIHALLI_110 BISIHALLI_110 BISIHALLI_110 BISIHALLI_110 KEREHALLI_110 METRI_110 METRI_110	22:00(25.12.2021) 1:45 3:40 9:30 11:43 16:45 7:35	6:30(26.12.2 021) 1:59 4:10 9:43 12:04 17:00	8:30HRS 0:14 0:30 0:13 0:21 0:15	LINE CHARGED MAIN SUPPLY FAILURE MAIN SUPPLY FAILURE MAIN SUPPLY FAILURE MAIN SUPPLY FAILURE
1071 26-D 1072 26-D 1073 26-D 1074 26-D 1075 26-D 1076 26-D 1077 26-D 1078 26-D 1079 26-D	-Dec-2021	GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA	110 110 110 110 110 110 110 110	BISIHALLI-HALKUNDI BISIHALLI-HALKUNDI BISIHALLI-HALKUNDI HV1 METRI-ALIPUR METRI-ALIPUR METRI-ALIPUR	BISIHALLI_110 BISIHALLI_110 BISIHALLI_110 KEREHALLI_110 METRI_110 METRI_110	3:40 9:30 11:43 16:45 7:35	4:10 9:43 12:04	0:30 0:13 0:21	MAIN SUPPLY FAILURE MAIN SUPPLY FAILURE MAIN SUPPLY FAILURE
1072 26-D 1073 26-D 1074 26-D 1075 26-D 1076 26-D 1077 26-D 1078 26-D 1079 26-D	-Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021	GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA	110 110 110 110 110 110 110	BISIHALLI-HALKUNDI BISIHALLI-HALKUNDI HV1 METRI-ALIPUR METRI-ALIPUR METRI-ALIPUR	BISIHALLI_110 BISIHALLI_110 KEREHALLI_110 METRI_110 METRI_110	9:30 11:43 16:45 7:35	9:43 12:04	0:13 0:21	MAIN SUPPLY FAILURE MAIN SUPPLY FAILURE
1073 26-D 1074 26-D 1075 26-D 1076 26-D 1077 26-D 1078 26-D 1079 26-D	-Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021	GULBARGA GULBARGA GULBARGA GULBARGA GULBARGA	110 110 110 110 110 110	BISIHALLI-HALKUNDI HV1 METRI-ALIPUR METRI-ALIPUR METRI-ALIPUR	BISIHALLI_110 KEREHALLI_110 METRI_110 METRI_110	11:43 16:45 7:35	12:04	0:21	MAIN SUPPLY FAILURE
1074 26-D 1075 26-D 1076 26-D 1077 26-D 1078 26-D 1079 26-D	-Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021	GULBARGA GULBARGA GULBARGA GULBARGA	110 110 110 110 110	HV1 METRI-ALIPUR METRI-ALIPUR METRI-ALIPUR	KEREHALLI_110 METRI_110 METRI_110	16:45 7:35	+		
1075 26-D 1076 26-D 1077 26-D 1078 26-D 1079 26-D	-Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021	GULBARGA GULBARGA GULBARGA GULBARGA	110 110 110 110	METRI-ALIPUR METRI-ALIPUR METRI-ALIPUR	METRI_110 METRI_110	7:35	17:00	0:15	
1076 26-D 1077 26-D 1078 26-D 1079 26-D	-Dec-2021 -Dec-2021 -Dec-2021 -Dec-2021	GULBARGA GULBARGA GULBARGA	110 110 110	METRI-ALIPUR METRI-ALIPUR	METRI_110				TRANSFORMER FAULT
1077 26-D 1078 26-D 1079 26-D	-Dec-2021 -Dec-2021 -Dec-2021	GULBARGA GULBARGA	110 110	METRI-ALIPUR			7:45	0:10	MAIN SUPPLY FAILURE
1078 26-D 1079 26-D	-Dec-2021 -Dec-2021	GULBARGA	110		METRI 440	14:01	14:25	0:24	MAIN SUPPLY FAILURE
1079 26-D	-Dec-2021			GALAG-MALLAT	METRI_110	15:55	16:05	0:10	MAIN SUPPLY FAILURE
		GULBARGA	110	OUTUO-INIUTTU I	GALAG_110	8:04	8:10	0:06	MAIN SUPPLY FAILURE
26-D	-Dec-2021		110	HV3	LADHA_110	12:01	12:11	0:10	TRANSFORMER FAULT
1080	DCC 2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:09 (22.12.2021)	12:55 (26.12.2021)	89:46 HRS	LINE CHARGED
1081 26-D	-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	2:36	2:43	0:07	LINE FAULT
1082 26-D	-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	2:36	2:43	0:07	LINE FAULT
1083 26-D	-Dec-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	6:19	6:26	0:07	LINE FAULT
1084 26-D	-Dec-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:09	19:19	0:10	LINE FAULT
26-D	-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPU R_110,WADAGERA_110,S ANNATHI_IPP,COREGREEN SUGARS IPP	20:56	21:05	0:09	LINE FAULT
-	-Dec-2021	GULBARGA	110	ALIPUR-BELLARY NORTH	BELLARY NORTH 110	9:30	9:39	0:09	LINE CLEAR AVAILED
	-Dec-2021	GULBARGA	110	ALIPUR-BELLARY NORTH	BELLARY NORTH 110	9:30	9:39	0:09	LINE CLEAR AVAILED
	-Dec-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BHALKI SUGUR_IPP	1:37	1:44	0:07	LINE FAULT
26-D	-Dec-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BHALKI SUGUR_IPP	2:30	2:35	0:05	LINE FAULT
26-D	-Dec-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,LADHA_110, MGSSK_IPP,BHALKI SUGUR_IPP	4:30	4:35	0:05	LINE FAULT
1091 26-D	-Dec-2021	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	6:35	7:10	0:35	LINE FAULT
1092 26-D	-Dec-2021	GULBARGA	110	HUMNABAD-CHITGUPPA	CHITGUPPA_110,NIRNA_1 10	5:31	5:39	0:08	LINE FAULT
26-D	-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADON A_110,BENNUR_110,BTPS WATER WORKS,KAMPLI 110	23:40	23:50	0:10	LINE FAULT
1094 26-D	-Dec-2021	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	20:40	20:44	0:04	LINE FAULT
26-D	-Dec-2021	GULBARGA	110	RAICHUR-APMC1&2	APMC_110,CHIKKASUGUR _110,SHAKTHINAGA_110	5:24	20:44	15:20	LINE FAULT
1096 26-D	-Dec-2021	GULBARGA	66	HV1	HALVAGALU_66	14:10(26.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1097 26-D	-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1098 26-D	-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1099 26-D	-Dec-2021	HASSAN	110	HV1	MADHUVANA_110	10:05(21.12.2021			TRANSFORMER OPEN,LINE CLEAR AVAILED
1100 26-D	-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:29(23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1101 26-D	-Dec-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	18:09 (24.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
1102	26-Dec-2021	HASSAN	220	HV1	MRSMG_220	9:55(26.12.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1103	26-Dec-2021	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	7:41(26.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1104	26-Dec-2021	HASSAN	110	LV1	MRSMG_220	9:55(26.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1105	26-Dec-2021	HASSAN	110	MRSSHM-BADRAVATY3	MRSMG_220	18:52	18:55	0:03	HAND TRIPPED
1106	26-Dec-2021	HASSAN	110	HV2	MRSMG_220	18:15	18:46	0:31	HAND TRIPPED
1107	26-Dec-2021	HASSAN	110	HV3	MRSMG_220	18:15	18:46	0:31	HAND TRIPPED
1108	26-Dec-2021	HASSAN	110	HV4	MRSMG_220	18:15	18:46	0:31	HAND TRIPPED
1109	26-Dec-2021	HASSAN	66	LV2	MRSMG 220	18:15	18:46	0:31	HAND TRIPPED
1110	26-Dec-2021	HASSAN	66	LV3	MRSMG 220	18:15	18:46	0:31	HAND TRIPPED
1111	26-Dec-2021	HASSAN	66	LV4	MRSMG 220	18:15	18:46	0:31	HAND TRIPPED
1112	26-Dec-2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE 110	8:43	9:22	0:39	LINE FAULT
1113	26-Dec-2021	HASSAN	110	SORABA-SHR220	SORABA 110	8:45	8:52	0:07	HAND TRIPPED
1114	26-Dec-2021	HASSAN	66	HV1	HANGARAHALLI 66	13:15	14:07	0:52	LINE CLEAR AVAILED
1115	26-Dec-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI 66	9:02	9:30	0:28	HAND TRIPPED
1116	26-Dec-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI 66	11:45	11:58	0:13	HAND TRIPPED
1117	26-Dec-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI 66	14:05	14:20	0:15	HAND TRIPPED
1118	26-Dec-2021	MYSURU	66	DEVNUR(N'GUD)-SUTTHUR	SUTTUR 66	6:42	6:49	0:06	LINE FAULT
1110	20-Dec-2021	WITSONO	00	DEVNOR(N GOD)-301 HIGH	_	0.42	0.43	0.00	LINETAGEI
	26-Dec-2021	MYSURU	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66 THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA				LINE FAULT
1119					_66	8:03	8:13	0:09	
1120	26-Dec-2021	MYSURU	66	JAKKANAHALI-NAGMANGLA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA 66	18:12	18:17	0:05	LINE FAULT
1121	26-Dec-2021	MYSURU	66	HV2	HANNUR_66	10:19	11:55	1:35	LINE CLEAR AVAILED
1122	26-Dec-2021	MYSURU	66	KABHALLY-GUNDALPETE	KABHALLY_66	18:18	19:04	0:46	LINE CLEAR AVAILED
1123	26-Dec-2021	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	NO STATIONS EFFECTED	15:07	17:08	2:00	LINE CLEAR AVAILED
1124	26-Dec-2021	MYSURU	66	MADHUVANAHALLI-HANNUR2	NO STATIONS EFFECTED	17:30	17:34	0:04	LINE FAULT
1125	26-Dec-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	PANDAVAPURA_66 DODDABYADARAHALLI_66	14:57	15:02	0:05	LINE FAULT
1126	26-Dec-2021	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	14:20:00 (23.12.2021)			LINE OPEN,LINE FAULT
1127	26-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1128	26-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1129	26-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN, LINE CLEAR AVAILED
1130	26-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN, LINE CLEAR AVAILED
1131	26-Dec-2021	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	15:46	16:15	0:28	LINE FAULT
1132	26-Dec-2021	TUMKUR	66	ANCHEPALYA 66kV- ANCHEPALYA-2	ANCHEPALYA 66kV	18:13	18:32	0:18	LINE FAULT
1133	26-Dec-2021	TUMKUR	66	TR-1	BRAHMASANDRA_66	11:58	13:17	1:19	LINE CLEAR AVAILED
1134	26-Dec-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKA TTE_66,KADAJJI_66	9:11	9:22	0:10	LINE FAULT
1135	26-Dec-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKA TTE_66,KADAJJI_66	11:29	11:36	0:07	LINE FAULT
1136	26-Dec-2021	TUMKUR	66	HINDASGHATTA66-HIRIYUR220KV	HINDASGHATTA_66	10:20	10:23	0:02	LINE FAULT
1137	26-Dec-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	10:20	10:23	0:02	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1138	26-Dec-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI 66	8:09	8:19	0:09	LINE FAULT
1139	26-Dec-2021	TUMKUR	66	TR-1	MATHOD_66	4:19	4:31	0:12	TRANSFORMER FAULT
1140	26-Dec-2021	TUMKUR	66	TR-1	MATHOD_66	6:04	7:55	1:50	TRANSFORMER FAULT
1141	26-Dec-2021	TUMKUR	66	TR-1	PAVAGADA_66	6:06	6:09	0:02	TRANSFORMER FAULT
1142	26-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	11:04	11:14	0:10	TRANSFORMER FAULT
1143	26-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	13:59	14:05	0:06	TRANSFORMER FAULT
1144	26-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	15:13	15:20	0:07	TRANSFORMER FAULT
1145	26-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	14:05	14:10	0:04	LINE FAULT
1146	26-Dec-2021	TUMKUR	66	TR-1	TUMKUR_66	10:10	17:07	6:57	LINE CLEAR AVAILED
1147	26-Dec-2021	TUMKUR	66	TR-2	TUMKUR_66	10:10	16:57	6:47	LINE CLEAR AVAILED
1148	27-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1149	27-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN, LINE CLEAR AVAILED
1150	27-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN,LINE FAULT
1151	27-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN,LINE FAULT
1152	27-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN, LINE CLEAR AVAILED
1153	27-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
1154	27-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN, LINE CLEAR AVAILED
1155	27-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56 (26.11.2021)			LINE OPEN, LINE CLEAR AVAILED
1156	27-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25 (08.12.2021)	18:12 (27.12.2021)	465:37HRS	LINE CHARGED
1157	27-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1158	27-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1159	27-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01 (13.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1160	27-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1161	27-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE FAULT
1162	27-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1163	27-Dec-2021	BAGALKOT	110	TARIHAL-TADSNKP(KIADB GAMANGHATTI)	TARIHAL_110	11:44 (23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1164	27-Dec-2021	BAGALKOT	110	SIRSI- HUBLI1(ESALE1)	SIRSI_110	15:52 (24.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1165	27-Dec-2021	BAGALKOT	110	SIRSI- KAVALWADA(ESALE1)	SIRSI_110	15:52 (24.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1166	27-Dec-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	11:21	11:34	0:13	HAND TRIPPED
1167	27-Dec-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	11:54	12:02	0:08	HAND TRIPPED
1168	27-Dec-2021	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	11:53	12:06	0:13	HAND TRIPPED
1169	27-Dec-2021	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	12:19	12:28	0:09	HAND TRIPPED
1170	27-Dec-2021	BAGALKOT	110	BIDNAL-PH COMPUND	PH COMPOUND_110	12:28	13:07	0:39	HAND TRIPPED
1171	27-Dec-2021	BAGALKOT	110	BIDNAL-PH COMPUND	PH COMPOUND_110	13:23	13:51	0:28	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
1172	27-Dec-2021	BAGALKOT	110	BIDNAL-GADAG	GADAG_110	13:22	13:32	0:10	HAND TRIPPED
1173	27-Dec-2021	BAGALKOT	110	BIDNAL-GADAG	GADAG_110	13:46	14:03	0:17	HAND TRIPPED
1174	27-Dec-2021	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	11:45 (13.12.2021)	11:12 (27.12.2012)	348:15HRS	LINE CHARGED
1175	27-Dec-2021	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	13:34 (27.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1176	27-Dec-2021	BAGALKOT	110	GOPANAKOPPA(BIDNAL)-GADAG ROAD	GADAG ROAD_110	2:05	2:17	0:12	LINE FAULT
1177	27-Dec-2021	BAGALKOT	110	BIDNAL(GOPANAKOPPA)-GADAG ROAD	GADAG ROAD_110	13:22	14:06	0:44	HAND TRIPPED
1178	27-Dec-2021	BAGALKOT	110	CHIKKODI220- SADALAGA	SADALAGA_110	8:02	9:35	1:33	LINE FAULT
1179	27-Dec-2021	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	12:44	19:02	6:18	NFBC ISSUED
1180	27-Dec-2021	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	12:44	19:02	6:18	NFBC ISSUED
1181	27-Dec-2021	BAGALKOT	110	GHATAPRABHA220- SHIRGOAN	GHATAPRABHA_220	7:20	7:36	0:16	LINE FAULT
1182	27-Dec-2021	BAGALKOT	110	VAJRAMATTI-MANTUR(K.D.JAMBAGI)	VAJRAMATTI_220	19:38 (27.12.2021)			LINE OPEN,LINE FAULT
1183	27-Dec-2021	BAGALKOT	110	GADAG220- LAXMESHWAR	GADAG_220	17:51	18:00	0:09	HAND TRIPPED
1184	27-Dec-2021	BAGALKOT	220	AMBEWADI- NAGJHARI2	AMBEWADI_220	10:51	11:16	0:25	LINE CLEAR AVAILED
1185	27-Dec-2021	BAGALKOT	220	AMBEWADI- NAGJHARI1	AMBEWADI_220	10:51	11:22	0:31	LINE CLEAR AVAILED
1186	27-Dec-2021	BAGALKOT	220	AMBEWADI- PONDA1	AMBEWADI_220	10:52	11:52	1:00	LINE CLEAR AVAILED
1187	27-Dec-2021	BAGALKOT	110	AMBEWADI- NK1(KAVALWAD)	AMBEWADI_220	8:39 (27.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1188	27-Dec-2021	BAGALKOT	110	AMBEWADI- NK2(HALIYAL)	AMBEWADI_220	8:39 (27.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1189	27-Dec-2021	BAGALKOT	220	220/110KV, HV2&LV2	AMBEWADI_220	10:53	11:12	0:19	LINE CLEAR AVAILED
1190	27-Dec-2021	BAGALKOT	110	BIDNAL220- NAVALGUND	NAVALGUND_110	12:22 (27.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1191	27-Dec-2021	BAGALKOT	110	NAVALGUND- NOKAR SOLAR	NAVALGUND_110	17:55	22:50	4:55	NFBC ISSUED
1192	27-Dec-2021	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	11:27	11:35	0:08	TRANSFORMER FAULT
1193	27-Dec-2021	BAGALKOT	110	MALGHAN(S)-MANALI SUARS	MALGHAN(S)_110	21:26	21:32	0:06	LINE FAULT
1194	27-Dec-2021	BAGALKOT	110	LAXMESHWAR- GADAG1	LAXMESHWAR_110	17:51	18:00	0:09	HAND TRIPPED
1195	27-Dec-2021	BAGALKOT	110	110/11KV, HV4	KERUR_110	13:36	13:54	0:18	HAND TRIPPED
1196	27-Dec-2021	BAGALKOT	110	HAVERI220- BYADAGI	HAVERI_220	11:15	13:19	2:04	LINE CLEAR AVAILED
1197	27-Dec-2021	BAGALKOT	110	CHIKKODI220- RAIBAG1	CHIKKODI_220	3:16	10:55	7:39	LINE FAULT
1198	27-Dec-2021	BAGALKOT	110	KD JAMBAGI- MUDHOL	MUDHOL_110	19:40	20:15	0:35	MAIN SUPPLY FAILURE
1199	27-Dec-2021	BAGALKOT	110	KD JAMBAGI- HALAKI	HALAKI_110	19:40	20:15	0:35	MAIN SUPPLY FAILURE
1200	27-Dec-2021	BAGALKOT	220	110/11KV, HV1	VAJRAMATTI_220	22:42	22:56	0:14	TRANSFORMER FAULT
1201	27-Dec-2021	BAGALKOT	110	110/33KV, HV3	KONNUR_110	11:50	12:15	0:25	MAIN SUPPLY FAILURE
1202	27-Dec-2021	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	11:50	12:15	0:25	MAIN SUPPLY FAILURE
1203	27-Dec-2021	BAGALKOT	110	110/11KV, HV2	NARAGUND_110	11:50	12:15	0:25	MAIN SUPPLY FAILURE
1204	27-Dec-2021	BAGALKOT	110	110/11KV, HV2	KATAKOL_110	12:35	12:45	0:10	TRANSFORMER FAULT
1205	27-Dec-2021	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	12:28	12:36	0:08	LOAD CHANGE OVER
1206	27-Dec-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	NO STATION AFFECTED	15:30	15:45	0:15	LINE CLEAR AVAILED
1207	27-Dec-2021 27-Dec-2021	BENGALURU	66	HV1 BYADRAHALLI - SRS PEENYA 220	BYDRAHALLI BYADRAHALLI, TAVAREKERE,	7:31	7:39	0:08	TRANSFORMER FAULT LINE CLEAR AVAILED
1208		BENGALURU	66		KODIGEHALLI, SRIGANDA KAVALU	22:30	22:48	0:18	
1209	27-Dec-2021	BENGALURU	66	HV1	CHATRA	11:30	13:25	1:55	LINE CLEAR AVAILED
1210	27-Dec-2021	BENGALURU	66	HV3	EPIP 220	9:59	11:34	1:35	LINE CLEAR AVAILED
1211	27-Dec-2021	BENGALURU	66	EPIP 220 - GITC(EHT)	GITC(EHT)	11:41	12:00	0:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
1212	27-Dec-2021	BENGALURU	220	HV1	KHODAYS 220	10:50	16:34	5:44	LINE CLEAR AVAILED
1213	27-Dec-2021	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	10:12	10:19	0:07	LINE CLEAR AVAILED
1214	27-Dec-2021	BENGALURU	66	HV1	KHODAYS 220	10:12	10:19	0:07	LINE CLEAR AVAILED
1215	27-Dec-2021	BENGALURU	66	HV2	KHODAYS 220	10:12	10:19	0:07	LINE CLEAR AVAILED
1216	27-Dec-2021	BENGALURU	66	HV1	KHODAYS 220	16:48	16:52	0:04	HAND TRIPPED
1217	27-Dec-2021	BENGALURU	66	HV2	KHODAYS 220	16:48	16:52	0:04	HAND TRIPPED
1218	27-Dec-2021	BENGALURU	66	KHODAYS 220 - SOUTH CITY	SOUTH CITY	16:48	16:52	0:04	HAND TRIPPED
1219	27-Dec-2021	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	6:05	6:28	0:23	LOAD CHANGE OVER
1220	27-Dec-2021	BENGALURU	66	HV2	MATHIKERE	10:30	10:35	0:05	LOAD CHANGE OVER
1221	27-Dec-2021	BENGALURU	66	HV1	MATHIKERE	11:02	11:05	0:03	LOAD CHANGE OVER
1222	27-Dec-2021	BENGALURU	66	HV3	NRS 220	17:32	18:10	0:38	LINE CLEAR AVAILED
	27 Dec 2021			10/4	PRESTIGE				LINE CLEAR AVAILED
1223	27-Dec-2021	BENGALURU	66	HV1	SHANTINIKETHAN	14:37	14:56	0:19	LINE CLEAR AVAILED
					BYADRAHALLI,				
	27-Dec-2021			SRS PEENYA 220 - BYADRAHALLI	TAVAREKERE,				HAND TRIPPED
1224		BENGALURU	66		KODIGEHALLI, SRIGANDA KAVALU	5:29	5:32	0:03	
1225	27-Dec-2021	BENGALURU	66	TK HALLI 220 - SIMSHA	NO STATION AFFECTED	13:56	14:00	0:04	LINE FAULT
1226	27-Dec-2021	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	5:50	5:57	0:07	LOAD CHANGE OVER
1227	27-Dec-2021	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	5:40	5:45	0:05	LOAD CHANGE OVER
1228	27-Dec-2021	BENGALURU	66	HV2	HUKUNDA	13:45	13:53	0:07	TRANSFORMER FAULT
1229	27-Dec-2021	BENGALURU	66	HV1	MELUR	9:15	12:18	3:03	LINE CLEAR AVAILED
1225		BENGALONO	00		TEKAL, TORALAKKI,	5.15	12.10	3.03	
1230	27-Dec-2021	BENGALURU	66	TEKAL - MALUR 220	BUDIKOTE	11:40	12:54	1:14	LINE CLEAR AVAILED
1231	27-Dec-2021	BENGALURU	66	HV2	TYAMAGONDLU	12:31	15:05	2:33	LINE CLEAR AVAILED
1232	27-Dec-2021	BENGALURU	66	YELAHANKA 220 - LINE6	SOLDEVANAHALLI	18:22	18:35	0:13	LINE FAULT
1233	27-Dec-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	6:26	6:42	0:15	LINE FAULT
1234	27-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - RVNL 2	NO STATION AFFECTED	12:35	14:38	2:03	LINE CLEAR AVAILED
1235	27-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN,LINE FAULT
1236	27-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN,TRANSFORMER FAULT
1237	27-Dec-2021	GULBARGA	220	HV1	RAICHUR 220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1238	27-Dec-2021	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKKASUGUR _110,SHAKTHINAGA_110	5:58			LINE OPEN,LINE FAULT
1239	27-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA 110	10:40(7.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1240	27-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE 110	14:55(30.07.2021)			LINE OPEN, LINE CLEAR AVAILED
1241	27-Dec-2021	GULBARGA	110	HV1	GALAG_110	14:50	14:53	0:03	TRANSFORMER FAULT
1242	27-Dec-2021	GULBARGA	110	HV2	SREERAMANAGAR 110	17:20	17:25	0:05	LINE CLEAR AVAILED
1243	27-Dec-2021	GULBARGA	110	HV2	SREERAMANAGAR_110	21:40	22:03	0:23	TRANSFORMER FAULT
1244	27-Dec-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR _110,SHAKTHINAGA_110	5:58	6:03	0:05	LINE FAULT
1245	27-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR	GABBUR_110	20:40(26.12.2021)	6:30(27.12.2 021)	9:50HRS	LINE CHARGED
1246	27-Dec-2021	GULBARGA	110	UCHCHANGI DURGA-NEELAGUNDA	UCHCHANGI DURGA_66,BILCHOD_66	9:05	9:15	0:10	MAIN SUPPLY FAILURE
1247	27-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	18:16 (26.12.2021)	1:55 (27.12.2021)	7:39 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
1248	27-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	0:48	0:55	0:07	LINE FAULT
1249	27-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	0:48	0:55	0:07	LINE FAULT
1250	27-Dec-2021	GULBARGA	110	HALBARGA-KOLHAR1,KOLHAR2	KOLHAR_110,JANAWADA_ 110,NSSK SUGAR FACTORY	4:30	4:36	0:06	LINE FAULT
1251	27-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	21:20	21:35	0:15	MAIN SUPPLY FAILURE
1252	27-Dec-2021	GULBARGA	110	HALKUNDI-BELLARY SOUTH	HALKUNDI_110	15:48	15:53	0:05	LINE FAULT
1253	27-Dec-2021	GULBARGA	110	RAICHUR-APMC1	APMC_110,CHIKKASUGUR _110,SHAKTHINAGA_110	21:13	21:19	0:06	LINE CLEAR AVAILED
1254	27-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	20:22	20:32	0:10	LINE FAULT
1255	27-Dec-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	6:35	6:45	0:10	LINE FAULT
1256	27-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_1 10,YERDONA_110,SRNAG AR_110,MALLAPURA_110	0:50	3:05	2:15	LINE FAULT
1257	27-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_1 10,YERDONA_110,SRNAG AR_110,MALLAPURA_110	3:50	4:05	0:15	LINE FAULT
1258	27-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_1 10,YERDONA_110,SRNAG AR_110,MALLAPURA_110	4:35	4:45	0:10	LINE FAULT
1259	27-Dec-2021	GULBARGA	110	SINDHANOOR-SIRGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESU GUR_110,SIRIGERA CROSS_110,NSL SUGAR IPP,VOORA IPP	11:10	11:20	0:10	LINE FAULT
1260	27-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPU R_110,WADGERA_110,SA NNATHI_110,CORE GREEN SUGUR IPP	20:50	20:55	0:05	LINE FAULT
1261	27-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	0:00	0:05	0:05	MAIN SUPPLY FAILURE
1262	27-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	20:30	20:35	0:05	LINE FAULT
1263	27-Dec-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	6:25	6:35	0:10	MAIN SUPPLY FAILURE
1264	27-Dec-2021	GULBARGA	66	HV1	HALVAGALU_66	14:10(26.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1265	27-Dec-2021	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_66	6:30	6:40	0:10	LINE FAULT
1266	27-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	11:36(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1267	27-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	11:34(21.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1268	27-Dec-2021	HASSAN	110	HV1	MADHUVANA_110	10:05(21.12.2021			TRANSFORMER OPEN,LINE CLEAR AVAILED
1269	27-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:29(23.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1270	27-Dec-2021	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	18:09 (24.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1271	27-Dec-2021	HASSAN	220	HV1	MRSMG_220	9:55(26.12.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1272	27-Dec-2021	HASSAN	110	MRSSHM-GAJNUR	MRSMG_220	7:41(26.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1273	27-Dec-2021	HASSAN	110	LV1	MRSMG_220	9:55(26.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1274	27-Dec-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	7:33(27.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1275	27-Dec-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	16:47	17:03	0:16	LINE FAULT
1276	27-Dec-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	16:47	17:03	0:16	LINE FAULT
1277	27-Dec-2021	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	10:36	13:48	3:12	NFBC ISSUED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open _at	Closed_At	Duration	REASON
1278	27-Dec-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	12:52	13:57	1:05	LINE FAULT
1279	27-Dec-2021	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	14:24	16:24	2:00	LINE FAULT
1280	27-Dec-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	7:22	8:28	1:06	LINE FAULT
1281	27-Dec-2021	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	8:54	10:55	2:01	LINE FAULT
1282	27-Dec-2021	HASSAN	110	HV2	HALADY_110	13:33	13:42	0:09	HAND TRIPPED
1283	27-Dec-2021	HASSAN	110	HV3	BANTWAL_110	10:11	12:40	2:29	LINE CLEAR AVAILED
1284	27-Dec-2021	HASSAN	66	HASSN22-BELUR	HASSAN_220	16:56	17:17	0:21	HAND TRIPPED
1285	27-Dec-2021	HASSAN	66	HV2	RAMNATHPURA_66	9:24	10:23	0:59	TRANSFORMER FAULT
1286	27-Dec-2021	MYSURU	66	HV1	ADICHUNCHANAGIRI_66	10:53	14:29	3:36	LINE CLEAR AVAILED
1287	27-Dec-2021	MYSURU	66	HV2	ADICHUNCHANAGIRI_66	14:20	16:50	2:30	LINE CLEAR AVAILED
1288	27-Dec-2021	MYSURU	66	BOOKANAKERE-KR PETE	NO STATIONS EFFECTED	8:59	11:15	2:16	LINE CLEAR AVAILED
1289	27-Dec-2021	MYSURU	66	HV1	HEBBAL_66	9:54	12:46	2:52	TRANSFORMER FAULT
1290	27-Dec-2021	MYSURU	66	HV1	HEBBAL_66	12:49	13:06	0:16	HAND TRIPPED
1291	27-Dec-2021	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	8:39	8:44	0:05	LINE FAULT
1292	27-Dec-2021	MYSURU	66	K HONNALAGERE-IGLOOR	NO STATIONS EFFECTED	11:26	16:18	4:52	LINE CLEAR AVAILED
1293	27-Dec-2021	MYSURU	66	K HONNALAGERE-MADDUR	NO STATIONS EFFECTED	11:23	11:26	0:02	HAND TRIPPED
1294	27-Dec-2021	MYSURU	66	K HONNALAGERE-MADDUR	NO STATIONS EFFECTED	16:18	16:21	0:03	HAND TRIPPED
1295	27-Dec-2021	MYSURU	66	HV1	KRNAGARA_66	16:32	17:15	0:42	LINE CLEAR AVAILED
	27-Dec-2021	MAYCHIDII		ND DETE 220 DOOMANAVEDE	GANJIGERE_66SHEELUNER				LINE CLEAR AVAILED
1296	27-Det-2021	MYSURU	66	KR PETE 220-BOOKANAKERE	E_66	10:01	16:45	6:44	LINE CLEAR AVAILED
1297	27-Dec-2021	MYSURU	66	HV1	SUTTUR_66	8:14	8:21	0:07	HAND TRIPPED
1298	27-Dec-2021	MYSURU	66	TUBINKERE-NAGMANGALA 1	NO STATIONS EFFECTED	20:05	22:19	2:14	LINE CLEAR AVAILED
1299	27-Dec-2021	MYSURU	66	HEBBANI-TK HALLI	NO STATIONS EFFECTED	13:58	14:01	0:03	LINE FAULT
1300	27-Dec-2021	MYSURU	66	BG NAGARA-NAGMANGALA	NO STATIONS EFFECTED ADDIHALLI 66	19:13:16 (27.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1301	27-Dec-2021	MYSURU	66	TUBINKERE-NAGMANGALA 2	HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66SHIVALLY 66 KESLAGERE 66	18:37:49 (27.12.2021)			LINE OPEN,LINE FAULT
1302	27-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN, LINE CLEAR AVAILED
1303	27-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN, LINE CLEAR AVAILED
1304	27-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN, LINE CLEAR AVAILED
1305	27-Dec-2021	TUMKUR	110	TR-1	NITTUR_220	14:02	16:40	2:37	LINE CLEAR AVAILED
1306	27-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	9:12	9:29	0:17	LINE FAULT
1307	27-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	9:36	10:09	0:33	LINE FAULT
1308	27-Dec-2021	TUMKUR	66	TR-2	BHARAMAGIRI_66	10:14	10:18	0:03	TRANSFORMER FAULT
1309	27-Dec-2021	TUMKUR	66	TR-1	DODDASARANGI_66	11:02	13:44	2:41	LINE CLEAR AVAILED
1310	27-Dec-2021	TUMKUR	66	TR-1	GOWRASAMUDRA_66	12:04	13:34	1:29	LINE CLEAR AVAILED
1311	27-Dec-2021	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	13:19	13:22	0:03	LINE FAULT
1312	27-Dec-2021	TUMKUR	66	H D PURA- CHITRADURGA220	H D PURA_66	16:36	16:40	0:04	LINE FAULT
1313	27-Dec-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	19:14	19:20	0:05	TRANSFORMER FAULT
1314	27-Dec-2021	TUMKUR	66	TR-2	KADAJJI_66	15:07	15:13	0:05	TRANSFORMER FAULT
1315	27-Dec-2021	TUMKUR	66	LINGADAHALLI- SHYLAPURA	LINGADAHALLI_TMK2_66	10:58	11:02	0:03	HAND TRIPPED
1316	27-Dec-2021	TUMKUR	66	PDKOTE-CLEAR SOLAR	CLEAR SOLAR	12:12	12:20	0:08	LINE FAULT
1317	27-Dec-2021	TUMKUR	66	TR-1	PDKOTE_66	12:47	12:57	0:09	TRANSFORMER FAULT