

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 16.04.2019 to 22.04.2019**

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	16-Apr-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	20:05	20:11	0:06	TRANSFORMER FAULT
2	16-Apr-19	BAGALKOT	110	HUBLI220-KADANKOPPA	KADANKOPPA_110	10:32	13:58	3:26	LINE CLEAR AVAILED
3	16-Apr-19	BAGALKOT	110	110/11KV,HV1	SHIRGOAN_110	8:10	9:23	1:13	LINE CLEAR AVAILED
4	16-Apr-19	BAGALKOT	110	110/11KV,HV2	MALGHAN(B)_110	21:49	21:59	0:10	TRANSFORMER FAULT
5	16-Apr-19	BAGALKOT	220	220/110KV, HV1&LV1	KARWAR_220	10:31	12:00	1:29	LINE CLEAR AVAILED
6	16-Apr-19	BAGALKOT	110	KARWAR220-BINAGA(LIS)	KARWAR_220	6:00	13:40	7:40	LINE FAULT
7	16-Apr-19	BAGALKOT	110	AMBEWADI-KIRUVATTI	KIRUVATTI_110	13:23	13:28	0:05	HAND TRIPPED
8	16-Apr-19	BAGALKOT	110	AMBEWADI-KADANKOPPA	KADANKOPPA_110	14:11	14:43	0:32	LINE CLEAR AVAILED
9	16-Apr-19	BAGALKOT	110	110/11KV,HV2A	JAMKHANDI_110	16:00	17:11	1:11	LINE CLEAR AVAILED
10	16-Apr-19	BAGALKOT	220	HIREBENDIGERI1&2-BIDNAL	BIDNAL_110	11:31	18:31	7:00	LINE CLEAR AVAILED
11	16-Apr-19	BAGALKOT	220	PONDA2-AMBEWADI	AMBEWADI_220	11:14	15:35	4:21	LINE CLEAR AVAILED
12	16-Apr-19	BENGALURU	66	HAL 220 - HOODY 2	BAGMANE TECH PARK, GTRE (EHT)	12:23	13:05	0:42	LINE CLEAR AVAILED
13	16-Apr-19	BENGALURU	66	SOMANAHALLI 220 - HAROHALLI (EHT)	HAROHALLI (EHT), KANAKAPURA 220	14:08	14:21	0:12	LINE FAULT
14	16-Apr-19	BENGALURU	66	HV5	NRS 220	11:03	11:08	0:05	TRANSFORMER FAULT
15	16-Apr-19	BENGALURU	66	HV1	NIMHANS 220	10:51	10:54	0:02	LINE CLEAR AVAILED
16	16-Apr-19	BENGALURU	66	KANAKAPURA 220 - KANAKAPURA 66	KANAKAPURA 66	14:08	14:21	0:12	MAIN SUPPLY FAILURE
17	16-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	14:08	14:33	0:24	MAIN SUPPLY FAILURE
18	16-Apr-19	BENGALURU	66	KANAKAPURA 220 - TK HALLI 2	HONNIGANAHALLI, HALAGUR	14:08	14:21	0:12	MAIN SUPPLY FAILURE
19	16-Apr-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	14:08	14:33	0:24	MAIN SUPPLY FAILURE
20	16-Apr-19	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	14:08	14:21	0:12	MAIN SUPPLY FAILURE
21	16-Apr-19	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	14:08	14:33	0:24	MAIN SUPPLY FAILURE
22	16-Apr-19	BENGALURU	66	NRS 220 - VIJAY NGR MY1	VIJAYANAGARA	23:05	23:59	0:54	LINE CLEAR AVAILED
23	16-Apr-19	BENGALURU	66	HV2	SUBRAMANYAPURA 66	10:19	10:21	0:02	LINE CLEAR AVAILED
24	16-Apr-19	BENGALURU	220	HV1	KANAKAPURA 220	14:08	14:28	0:19	MAIN SUPPLY FAILURE
25	16-Apr-19	BENGALURU	220	HV2	KANAKAPURA 220	14:08	14:28	0:19	MAIN SUPPLY FAILURE
26	16-Apr-19	BENGALURU	66	HEBBAL 220 - C STATION 1 & 2	C STATION	20:48	21:24	0:35	MAIN SUPPLY FAILURE
27	16-Apr-19	BENGALURU	66	HV1	HEBBAL 220	20:48	21:21	0:33	MAIN SUPPLY FAILURE
28	16-Apr-19	BENGALURU	66	HV2	HEBBAL 220	20:48	21:21	0:32	MAIN SUPPLY FAILURE
29	16-Apr-19	BENGALURU	66	HV3	HEBBAL 220	20:48	21:21	0:32	MAIN SUPPLY FAILURE
30	16-Apr-19	BENGALURU	220	LV1	HEBBAL 220	20:48	23:59	3:10	TRANSFORMER FAULT
31	16-Apr-19	BENGALURU	220	LV2	HEBBAL 220	20:48	21:20	0:32	TRANSFORMER FAULT
32	16-Apr-19	BENGALURU	220	HV1.	HEBBAL 220	20:48	23:59	3:10	TRANSFORMER FAULT
33	16-Apr-19	BENGALURU	220	HV2	HEBBAL 220	20:48	21:20	0:31	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
34	16-Apr-19	GULBARGA	220	ALIPUR-GOOTY	ALIPUR_220	7:27	11:04	3:37	LINE CLEAR AVAILED
35	16-Apr-19	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110, KURUGOD_110, SHATAVANA_IPP, AGARWAL_IPP, SUZLON_IPP, KAMALAPUR_110	12:47	14:03	1:16	LINE CLEAR AVAILED
36	16-Apr-19	GULBARGA	110	HV2	HANUMANAL_110	7:20	8:50	1:30	LINE CLEAR AVAILED
37	16-Apr-19	GULBARGA	110	ALIPUR-KUDITINI	KUDITINI_110	9:30	12:30	3:00	LINE CLEAR AVAILED
38	16-Apr-19	GULBARGA	110	HV1	RAICHUR_220	12:34	12:53	0:19	LINE CLEAR AVAILED
39	16-Apr-19	GULBARGA	220	SEDAM-SHREECEMENT_IPP	SEDAM_220	16:18	16:25	0:07	LINE FAULT
40	16-Apr-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	22:15	22:25	0:10	LINE FAULT
41	16-Apr-19	GULBARGA	66	UPANAYAKANAHALLI-MUNIRABAD	UPANAYAKANAHALLI_66	8:10	8:25	0:15	LINE CLEAR AVAILED
42	16-Apr-19	GULBARGA	66	UPANAYAKANAHALLI-MUNIRABAD	UPANAYAKANAHALLI_66	9:15	11:10	1:55	NFBC ISSUED
43	16-Apr-19	HASSAN	110	HV2	KONDENALU_110	16:51	18:24	1:33	LINE CLEAR AVAILED
44	16-Apr-19	HASSAN	110	HV1	SHIVAPURA_110	13:22	13:30	0:08	LINE CLEAR AVAILED
45	16-Apr-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	14:38	14:45	0:07	LINE FAULT
46	16-Apr-19	HASSAN	66	HV2	HASSAN_66	15:44	15:49	0:05	LINE CLEAR AVAILED
47	16-Apr-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	8:06	15:50	7:44	LINE FAULT
48	16-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	17:54	18:06	0:12	LINE FAULT
49	16-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66,	11:37	16:19	4:42	LINE FAULT
50	16-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66	11:52	23:59	12:07	LINE FAULT
51	16-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66	12:14	16:19	4:05	LINE FAULT
52	16-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66,	17:19	17:20	0:01	LINE FAULT
53	16-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66, HURA_66, HULLAHALLI_66, DOORA_66	17:18	17:20	0:02	LINE FAULT
54	16-Apr-19	MYSORE	66	HV1	K_HONNALGERE_66	8:18	8:27	0:09	MAIN SUPPLY FAILURE
55	16-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	8:18	8:27	0:09	MAIN SUPPLY FAILURE
56	16-Apr-19	MYSORE	66	HV1	K_HONNALGERE_66	11:43	11:55	0:12	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
57	16-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	11:43	11:47	0:04	MAIN SUPPLY FAILURE
58	16-Apr-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	8:15	8:26	0:11	LINE FAULT
59	16-Apr-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66 SOMANAHALLI_66	11:42	11:50	0:08	LINE FAULT
60	16-Apr-19	MYSORE	66	HV1	SANTHESARAGUR_66	0:11	0:16	0:04	TRANSFORMER FAULT
61	16-Apr-19	MYSORE	66	HV5	SFCSHIVA_66	15:10	19:29	4:18	LINE CLEAR AVAILED
62	16-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66	11:57	12:03	0:06	LINE FAULT
63	16-Apr-19	TUMKUR	220	THALLAK 220kV- THALLAK	THALLAK_66	12:37	16:54	4:17	LINE CLEAR AVAILED
64	16-Apr-19	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TANDAGA_110, KADEHALLI_110	21:20	21:31	0:10	LINE CLEAR AVAILED
65	16-Apr-19	TUMKUR	66	TR-1	NAGASAMUDRA_66	13:29	13:35	0:06	TRANSFORMER FAULT
66	16-Apr-19	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	16:04	17:01	0:57	LINE CLEAR AVAILED
67	17-Apr-19	BAGALKOT	220	220/110KV, HV2&LV2	HUBLI_220	10:27	14:37	4:10	LINE CLEAR AVAILED
68	17-Apr-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	21:52	22:42	0:50	TRANSFORMER FAULT
69	17-Apr-19	BAGALKOT	220	HIREBENDIGERI1&2-BIDNAL	BIDNAL_110	9:12	17:54	8:42	LINE CLEAR AVAILED
70	17-Apr-19	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110, WATER SUPPLY_33, KARJOL LIS_33	17:12	21:26	4:14	LINE CLEAR AVAILED
71	17-Apr-19	BENGALURU	66	NRS 220 - VIJAY NGR MY1	VIJAYANAGARA	0:00	0:43	0:43	LINE CLEAR AVAILED
72	17-Apr-19	BENGALURU	66	HV1	TK HALLI 220	19:26	19:28	0:02	TRANSFORMER FAULT
73	17-Apr-19	BENGALURU	66	HV1	TK HALLI 220	15:08	15:12	0:03	TRANSFORMER FAULT
74	17-Apr-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE(EHT)	6:51	9:31	2:39	LINE FAULT
75	17-Apr-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR, GLOBAL VILLAGE (EHT)	6:51	7:04	0:13	MAIN SUPPLY FAILURE
76	17-Apr-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	9:38	9:40	0:01	LOAD CHANGEOR
77	17-Apr-19	BENGALURU	66	HV1	SHOBHA APARTMENT	15:54	16:02	0:07	TRANSFORMER FAULT
78	17-Apr-19	BENGALURU	66	HOODY 220 - POTTERY ROAD	POTTERY ROAD, ITC (EHT)	15:57	17:21	1:23	LINE FAULT
79	17-Apr-19	BENGALURU	66	HV1	ITI	20:32	22:07	1:34	LINE CLEAR AVAILED
80	17-Apr-19	BENGALURU	66	JAYADEVA - NIMHANS 220	JAYADEVA	23:37	23:41	0:03	LINE FAULT
81	17-Apr-19	BENGALURU	66	JAYADEVA - ADUGODI	ADUGODI	23:37	23:59	0:21	LINE FAULT
82	17-Apr-19	BENGALURU	66	HV1	AMARJYOTHI	15:17	15:23	0:06	LOAD CHANGEOR
83	17-Apr-19	BENGALURU	66	HV1	AMARJYOTHI	22:28	22:31	0:03	LOAD CHANGEOR
84	17-Apr-19	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI	ELECTRONIC CITY, INFOSYS (EHT)	17:38	17:46	0:08	LOAD CHANGEOR
85	17-Apr-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	19:19	19:22	0:03	LOAD CHANGEOR
86	17-Apr-19	BENGALURU	66	HV1	BOODIGERE	16:57	17:09	0:11	TRANSFORMER FAULT
87	17-Apr-19	BENGALURU	66	HV3	HEBBAL 220	6:40	7:09	0:28	LINE CLEAR AVAILED
88	17-Apr-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	6:40	7:09	0:28	LINE CLEAR AVAILED
89	17-Apr-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	18:27	18:44	0:17	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
90	17-Apr-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	6:40	7:09	0:28	LINE CLEAR AVAILED
91	17-Apr-19	BENGALURU	66	HEBBAL 220 - LR BANDE	LR BANDE	16:09	16:56	0:46	LINE FAULT
92	17-Apr-19	BENGALURU	66	PADMANABHANAGAR - NATIONAL COLLEGE	PADMANABHANAGAR	15:19	15:31	0:11	LOAD CHANGEOVER
93	17-Apr-19	BENGALURU	220	YERANDANAHALLI 220 - HOSUR	YERANDANAHALLI 220	15:23	21:28	6:05	LINE FAULT
94	17-Apr-19	BENGALURU	66	HV2	YERANDANAHALLI 220	15:23	15:48	0:25	MAIN SUPPLY FAILURE
95	17-Apr-19	GULBARGA	220	SEDAAM-RTPS1	SEDAM_220	17:45	18:28	0:43	LINE FAULT
96	17-Apr-19	GULBARGA	220	SEDAAM-RTPS1	SEDAM_220	17:45	18:38	0:53	LINE FAULT
97	17-Apr-19	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	11:00	23:59	12:59	LINE CLEAR AVAILED
98	17-Apr-19	GULBARGA	110	SINDHANOOR-PGLR_WIND_IPP	SIDHANOOR_220	20:43	21:05	0:22	LINE FAULT
99	17-Apr-19	HASSAN	220	KADUR-SHIMOGA	KADUR_220	10:33	13:10	2:37	LINE CLEAR AVAILED
100	17-Apr-19	HASSAN	220	MRSSHM-KADUR	MRS MG_220	10:32	13:10	2:38	LINE CLEAR AVAILED
101	17-Apr-19	HASSAN	66	HV1	ALDUR_66	6:15	6:40	0:25	LINE CLEAR AVAILED
102	17-Apr-19	HASSAN	66	RAMNAT-KADVINKOTE	RAMNATH PURA_66	20:03	21:58	1:55	MAIN SUPPLY FAILURE
103	17-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	6:50	19:05	12:15	LINE CLEAR AVAILED
104	17-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	6:50	19:05	12:15	LINE CLEAR AVAILED
105	17-Apr-19	HASSAN	66	HV2	SINGAPURA_66	12:25	13:14	0:49	LINE CLEAR AVAILED
106	17-Apr-19	MYSORE	66	HV1	ARAKERE_66	14:05	14:09	0:04	TRANSFORMER FAULT
107	17-Apr-19	MYSORE	66	HV1	GARUDANAUKADDA_66	7:14	23:59	16:44	TRANSFORMER FAULT
108	17-Apr-19	MYSORE	66	HV1	GARUDANAUKADDA_66	7:45	7:50	0:04	TRANSFORMER FAULT
109	17-Apr-19	MYSORE	66	HV2	KRPET_66	20:47	21:12	0:25	HAND TRIPPED
110	17-Apr-19	MYSORE	66	HV2	KRPET_66	21:18	21:38	0:19	HAND TRIPPED
111	17-Apr-19	MYSORE	66	HV3	KUSHALANAGARA_66	15:11	15:15	0:03	TRANSFORMER FAULT
112	17-Apr-19	MYSORE	66	KUSHALANAGARA 220-MYSORE-1	MIRLE_66 KRNAGARA_66 BHERYA_66 BILIKERE_66 GVGUDI_66	17:48	17:57	0:08	LINE FAULT
113	17-Apr-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	17:48	17:57	0:08	LINE FAULT
114	17-Apr-19	MYSORE	66	KUSHALANAGARA 220-BYLKUPPE	BYLUKUPPE_66	18:31	18:37	0:06	LINE FAULT
115	17-Apr-19	MYSORE	220	KUSHALANAGARA 220-HV1	KUSHALNAGARA_220 ITS DOWN STREAM STATIONS INTERRUPTED.	20:15	20:52	0:37	MAIN SUPPLY FAILURE
116	17-Apr-19	MYSORE	220	KUSHALANAGARA 220-HV2	KUSHALANAGARA & ITS DOWN STREAM STATIONS INTERRUPTED.	20:15	20:52	0:37	MAIN SUPPLY FAILURE
117	17-Apr-19	MYSORE	66	KUSHALANAGARA 220-BETTADAPURA	BETTADHAPURA_66 CHUNCHUNKATTE_66 KITTUR_66 RAVANDUR_66	18:30	18:38	0:07	LINE FAULT
118	17-Apr-19	MYSORE	66	HV1	MALAVALLI_66	2:39	3:00	0:20	HAND TRIPPED
119	17-Apr-19	MYSORE	66	HV2	MALAVALLI_66	2:39	3:15	0:35	HAND TRIPPED
120	17-Apr-19	MYSORE	66	HV1	SANTHESARAGUR_66	10:27	10:35	0:07	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
121	17-Apr-19	TUMKUR	220	ANTHRASANAHALLI 220kV- NELAMANGALA	ANTHRASANAHALLI_220	14:13	16:43	2:29	LINE FAULT
122	17-Apr-19	TUMKUR	66	TR-1	CHANNAGIRI_66	18:21	18:45	0:23	TRANSFORMER FAULT
123	17-Apr-19	TUMKUR	66	TR-1	HANAGAL_66	18:33	18:39	0:05	LINE CLEAR AVOIDED
124	17-Apr-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	13:21	13:31	0:10	LINE FAULT
125	18-Apr-19	BAGALKOT	400	DHONI-GUTTUR	DHONI_400	19:03	23:59	4:56	LINE FAULT
126	18-Apr-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI1&2(TADAS1&2)	BIDNAL_220	8:15	18:15	10:00	LINE CLEAR AVOIDED
127	18-Apr-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	11:19	23:59	12:40	LINE FAULT
128	18-Apr-19	BAGALKOT	110	110/11KV,HV-1	GUTTAL_110	15:49	16:01	0:12	TRANSFORMER FAULT
129	18-Apr-19	BAGALKOT	110	110/11KV,HV-1	GUTTAL_110	16:31	16:38	0:07	TRANSFORMER FAULT
130	18-Apr-19	BAGALKOT	110	110/11KV, HV1	YELLAPARHATTI_110	12:11	13:00	0:49	LINE CLEAR AVOIDED
131	18-Apr-19	BAGALKOT	220	HUBLI-SIRS1	HUBLI_220	12:40	13:07	0:27	LINE FAULT
132	18-Apr-19	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	15:47	15:56	0:09	LINE CLEAR AVOIDED
133	18-Apr-19	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	22:13	22:57	0:44	TRANSFORMER FAULT
134	18-Apr-19	BAGALKOT	110	110/33KV, HV2	MATTIHAL_110, WATER SUPPLY_33	10:42	14:03	3:21	LINE CLEAR AVOIDED
135	18-Apr-19	BAGALKOT	220	KUDACHI-GHATAPRABHA	KUDACHI_220	4:04	4:42	0:38	LINE FAULT
136	18-Apr-19	BAGALKOT	110	110/11KV, HV2	KHANAPUR_110	17:46	23:59	6:13	LINE CLEAR AVOIDED
137	18-Apr-19	BENGALURU	66	HV1	YERANDANAHALLI 220	20:30	20:48	0:18	TRANSFORMER FAULT
138	18-Apr-19	BENGALURU	220	YERANDAHALLI 220 - SOMANAHALLI 220	YERANDANAHALLI 220	21:18	21:47	0:29	LINE FAULT
139	18-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ANEKAL 1 & 2	SURYANAGAR, ATTIBELE	21:18	21:57	0:39	MAIN SUPPLY FAILURE
140	18-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	21:18	22:06	0:48	MAIN SUPPLY FAILURE
141	18-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	21:18	22:06	0:48	MAIN SUPPLY FAILURE
142	18-Apr-19	BENGALURU	66	JAYADEVA - ADUGODI	ADUGODI	0:00	0:17	0:17	MAIN SUPPLY FAILURE
143	18-Apr-19	BENGALURU	220	HV2	TK HALLI 220	17:42	18:03	0:21	TRANSFORMER FAULT
144	18-Apr-19	BENGALURU	220	HV2	TK HALLI 220	18:03	18:08	0:04	TRANSFORMER FAULT
145	18-Apr-19	BENGALURU	220	SOMANAHALLI 220 - YARANDANAHALLI 220	YARANDANAHALLI 220, JIGANI 220	21:18	21:42	0:23	LINE FAULT
146	18-Apr-19	BENGALURU	220	HAL 220 - EDC 220	EDC 220	18:56	19:17	0:20	LINE FAULT
147	18-Apr-19	BENGALURU	220	A STATION 220 - EDC 220	A STATION 220	18:56	19:05	0:08	MAIN SUPPLY FAILURE
148	18-Apr-19	BENGALURU	220	HV1	EDC 220	18:56	19:20	0:23	MAIN SUPPLY FAILURE
149	18-Apr-19	BENGALURU	220	HV2	EDC 220	18:56	19:20	0:23	MAIN SUPPLY FAILURE
150	18-Apr-19	BENGALURU	220	YARANDANAHALLI 220 - ELECTRONIC CITY 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	21:18	21:53	0:35	MAIN SUPPLY FAILURE
151	18-Apr-19	BENGALURU	220	HV2	YARANDANAHALLI 220	21:18	21:50	0:32	MAIN SUPPLY FAILURE
152	18-Apr-19	BENGALURU	220	HV3	YARANDANAHALLI 220	21:18	21:50	0:32	MAIN SUPPLY FAILURE
153	18-Apr-19	BENGALURU	66	HV3	YARANDANAHALLI 220	21:18	21:58	0:40	MAIN SUPPLY FAILURE
154	18-Apr-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	17:29	17:33	0:04	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
155	18-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 1 & 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:42	18:10	0:27	MAIN SUPPLY FAILURE
156	18-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:53	22:29	0:36	LINE FAULT
157	18-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:49	19:57	0:07	LINE FAULT
158	18-Apr-19	BENGALURU	66	HV3	ELECTRONIC CITY	18:30	18:40	0:10	TRANSFORMER FAULT
159	18-Apr-19	BENGALURU	66	HV2	TAVAREKERE	18:40	18:57	0:16	TRANSFORMER FAULT
160	18-Apr-19	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	19:15	19:36	0:20	LINE FAULT
161	18-Apr-19	BENGALURU	66	HV1	SIR MV LAYOUT	11:46	11:50	0:03	LINE CLEAR AVAILED
162	18-Apr-19	BENGALURU	66	HV2	CHANDRALAYOUT	18:28	18:56	0:27	TRANSFORMER FAULT
163	18-Apr-19	BENGALURU	66	EDC 220 - AUSTIN TOWN	AUSTIN TOWN, KORMANGALA	18:56	19:23	0:27	MAIN SUPPLY FAILURE
164	18-Apr-19	BENGALURU	66	EDC 220 - B STATION	B STATION	18:56	19:25	0:28	MAIN SUPPLY FAILURE
165	18-Apr-19	BENGALURU	66	HV1	EDC 220	18:56	19:20	0:24	MAIN SUPPLY FAILURE
166	18-Apr-19	BENGALURU	66	HV2	EDC 220	18:56	19:20	0:23	MAIN SUPPLY FAILURE
167	18-Apr-19	BENGALURU	66	ADUGODI - HAL 1	AMARJYOTHI	20:22	20:45	0:22	LINE FAULT
168	18-Apr-19	GULBARGA	220	KUSHTAGI-LINGSUGUR	KUSHTAGI_220	9:40	9:55	0:15	LINE FAULT
169	18-Apr-19	GULBARGA	220	HV2	ALIPUR_220	9:51	10:27	0:36	LINE CLEAR AVAILED
170	18-Apr-19	GULBARGA	220	RTPS-RAICHUR1	RAICHUR_220	15:56	17:40	1:44	LINE CLEAR AVAILED
171	18-Apr-19	GULBARGA	110	HV1	SIRWAR_110	8:57	9:10	0:13	TRANSFORMER FAULT
172	18-Apr-19	GULBARGA	110	KUSHTAGI-YELBURGA	YELBURGA_110	9:40	10:00	0:20	LINE FAULT
173	18-Apr-19	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	9:40	10:23	0:43	LINE FAULT
174	18-Apr-19	GULBARGA	110	KUSHTAGI-ILKAL2	ILKAL_110	9:40	10:30	0:50	LINE FAULT
175	18-Apr-19	GULBARGA	110	KUSHTAGI_KANAKAGIRI	KANAKAGIRI_110,GANADAL_110	9:40	10:25	0:45	LINE FAULT
176	18-Apr-19	GULBARGA	110	HV3	KOLHAR_110	9:10	10:10	1:00	LINE CLEAR AVAILED
177	18-Apr-19	GULBARGA	66	HV1	TAMBRAHALI_66	11:10	11:30	0:20	LINE CLEAR AVAILED
178	18-Apr-19	HASSAN	110	HV1	MRSMG_220	8:50	8:55	0:05	TRANSFORMER FAULT
179	18-Apr-19	HASSAN	110	HV2	MRSMG_220	8:50	8:56	0:06	TRANSFORMER FAULT
180	18-Apr-19	HASSAN	110	HV3	MRSMG_220	8:50	8:57	0:07	TRANSFORMER FAULT
181	18-Apr-19	HASSAN	110	HV4	MRSMG_220	8:50	8:57	0:07	TRANSFORMER FAULT
182	18-Apr-19	HASSAN	66	LV1	MRSMG_220	8:50	8:55	0:05	TRANSFORMER FAULT
183	18-Apr-19	HASSAN	66	LV2	MRSMG_220	8:50	8:56	0:06	TRANSFORMER FAULT
184	18-Apr-19	HASSAN	66	LV3	MRSMG_220	8:50	8:57	0:07	TRANSFORMER FAULT
185	18-Apr-19	HASSAN	66	LV4	MRSMG_220	8:50	8:57	0:07	TRANSFORMER FAULT
186	18-Apr-19	HASSAN	66	MRSSHM-BD-1	MRSMG_220	8:53	8:59	0:06	HAND TRIPPED
187	18-Apr-19	HASSAN	66	MRSSHM-BD-2	MRSMG_220	8:53	8:58	0:05	HAND TRIPPED
188	18-Apr-19	HASSAN	66	MRSSHM-DVG2	MRSMG_220	8:53	8:58	0:05	HAND TRIPPED
189	18-Apr-19	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	8:53	8:58	0:05	HAND TRIPPED
190	18-Apr-19	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	9:07	9:08	0:01	HAND TRIPPED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
191	18-Apr-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	12:21	12:24	0:03	LINE FAULT
192	18-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYARAPURA_66	12:25	12:30	0:05	MAIN SUPPLY FAILURE
193	18-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	6:52	19:37	12:45	LINE CLEAR AVAILED
194	18-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	6:52	19:37	12:45	LINE CLEAR AVAILED
195	18-Apr-19	MYSORE	66	HV1	DEVANOORMYS_66	19:07	23:59	4:51	TRANSFORMER FAULT
196	18-Apr-19	MYSORE	66	HV2	HAMPAPURA_66	19:26	19:50	0:23	TRANSFORMER FAULT
197	18-Apr-19	MYSORE	66	HV1	K_HONNALGERE_66	17:43	18:07	0:23	MAIN SUPPLY FAILURE
198	18-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	17:44	18:06	0:22	MAIN SUPPLY FAILURE
199	18-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	17:34	17:38	0:03	MAIN SUPPLY FAILURE
200	18-Apr-19	MYSORE	66	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66	19:49	19:54	0:05	LINE FAULT
201	18-Apr-19	MYSORE	66	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66	21:54	22:54	1:00	LINE FAULT
202	18-Apr-19	MYSORE	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66 TUMBKERE_66	22:01	22:12	0:11	LINE FAULT
203	18-Apr-19	MYSORE	66	KIADB MANDYA-MADDUR	K_HONNALGERE_66 MADDUR_66 SOMANAHALLI_66	22:54	23:59	1:05	LINE FAULT
204	18-Apr-19	MYSORE	66	KIADB MANDYA-TK HALLI	K_HONNALGERE_66 SOMANAHALLI_66	22:54	22:56	0:02	LINE FAULT
205	18-Apr-19	MYSORE	66	HV1	KIADBMANDYA_66	17:44	18:05	0:21	MAIN SUPPLY FAILURE
206	18-Apr-19	MYSORE	66	HV2	KIADBMANDYA_66	17:44	18:05	0:21	MAIN SUPPLY FAILURE
207	18-Apr-19	MYSORE	66	HV1	KIADBMANDYA_66	18:08	18:10	0:02	MAIN SUPPLY FAILURE
208	18-Apr-19	MYSORE	66	HV2	KIADBMANDYA_66	18:08	18:10	0:02	MAIN SUPPLY FAILURE
209	18-Apr-19	MYSORE	66	HV2	KMDODDI_66	12:17	12:20	0:03	TRANSFORMER FAULT
210	18-Apr-19	MYSORE	66	KR PETE 220-KR PETE 1	AKKIHEBBAL_66 KRPET_66	19:05	19:07	0:02	LINE FAULT
211	18-Apr-19	MYSORE	66	KR PETE 220-KR PETE 2	AKKIHEBBAL_66 KRPET_66	19:05	19:07	0:02	LINE FAULT
212	18-Apr-19	MYSORE	66	HV3	KUSHALANAGARA_66	18:09	19:04	0:54	TRANSFORMER FAULT
213	18-Apr-19	MYSORE	66	KUSHALANAGARA 220-RAMANTHAPURA 1	ALUR SIDDAPUR_66 KANAGAL_66	18:09	0:00	5:50	LINE FAULT
214	18-Apr-19	MYSORE	66	HV2	SALIGRAMA_66	0:39	0:43	0:04	TRANSFORMER FAULT
215	18-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY _66 VADERALLI_66	5:41	5:44	0:03	LINE FAULT
216	18-Apr-19	TUMKUR	66	TR-1	CHANNAGIRI_66	8:05	8:07	0:01	TRANSFORMER FAULT
217	18-Apr-19	TUMKUR	66	TR-2	CHANNAGIRI_66	16:23	16:30	0:07	TRANSFORMER FAULT
218	18-Apr-19	TUMKUR	66	TR-2	DAVANAGERE_66	12:02	12:08	0:05	LINE CLEAR AVAILED
219	18-Apr-19	TUMKUR	66	TR-1	DEVARAHALLI_66	16:10	16:13	0:03	TRANSFORMER FAULT
220	18-Apr-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	10:57	11:53	0:55	LINE CLEAR AVAILED
221	18-Apr-19	TUMKUR	66	TR-1	HALUVAGALU_66	13:06	14:36	1:29	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
222	18-Apr-19	TUMKUR	66	TR-1	HALUVAGALU_66	16:16	17:42	1:25	TRANSFORMER FAULT
223	18-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	10:29	10:37	0:08	LINE FAULT
224	18-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	14:00	14:19	0:19	LINE FAULT
225	18-Apr-19	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:01	16:21	7:20	MAIN SUPPLY FAILURE
226	18-Apr-19	TUMKUR	66	TR-2	MALEBENNUR_66	14:21	14:36	0:15	LINE CLEAR AVAILED
227	18-Apr-19	TUMKUR	66	NAGALAMADIKE- SUNDARRAJASOLAR_IPP_66	SUNDARRAJASOLAR_IPP_66	12:15	12:34	0:19	LINE FAULT
228	18-Apr-19	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANAHALLI_66,HALUVAGALU_66,TELAGI_66	22:06	23:19	1:13	LINE CLEAR AVAILED
229	19-Apr-19	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	0:53	1:13	0:20	LINE FAULT
230	19-Apr-19	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	1:36	10:27	8:51	LINE CLEAR AVAILED
231	19-Apr-19	BAGALKOT	220	BIDNAL-HIREBENDIGERI1&2(TADAS1&2)	BIDNAL_220	8:20	17:45	9:25	LINE CLEAR AVAILED
232	19-Apr-19	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	10:50	11:02	0:12	LINE FAULT
233	19-Apr-19	BAGALKOT	110	110/33KV,HV-2	BELGAUM_110	13:12	14:31	1:19	LINE CLEAR AVAILED
234	19-Apr-19	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	SOUDATTI_220	13:13	17:36	4:23	LINE CLEAR AVAILED
235	19-Apr-19	BAGALKOT	110	SOUDATTI220-MUNVALLY	MUNVALLY_110	7:09	13:40	6:31	LINE CLEAR AVAILED
236	19-Apr-19	BAGALKOT	110	110/11KV, HV1	SALAHALLI_110	13:14	13:58	0:44	LINE CLEAR AVAILED
237	19-Apr-19	BAGALKOT	110	KUMATA-SIRSI1	KUMATA_110	12:31	14:48	2:17	LINE CLEAR AVAILED
238	19-Apr-19	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	0:27	0:43	0:16	TRANSFORMER FAULT
239	19-Apr-19	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	13:09	13:57	0:48	LINE CLEAR AVAILED
240	19-Apr-19	BAGALKOT	110	AMBEWADI-KADANKOPPA	KADANKOPPA_110	7:22	7:38	0:16	LINE FAULT
241	19-Apr-19	BENGALURU	66	HV3	ADUGODI	14:47	14:55	0:08	LOAD CHANGEVER
242	19-Apr-19	BENGALURU	66	HV1	TK HALLI 220	19:38	19:41	0:03	TRANSFORMER FAULT
243	19-Apr-19	BENGALURU	220	HV2	TK HALLI 220	17:14	17:24	0:10	TRANSFORMER FAULT
244	19-Apr-19	BENGALURU	66	HV1	VIJAYANAGARA	5:14	5:20	0:05	LOAD CHANGEVER
245	19-Apr-19	BENGALURU	66	HV2	VIJAYANAGARA	5:08	5:13	0:05	LOAD CHANGEVER
246	19-Apr-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	6:53	7:06	0:12	LINE FAULT
247	19-Apr-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	17:14	17:35	0:21	MAIN SUPPLY FAILURE
248	19-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	17:14	17:25	0:10	MAIN SUPPLY FAILURE
249	19-Apr-19	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	8:28	8:44	0:16	LINE FAULT
250	19-Apr-19	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	12:56	13:17	0:21	LINE FAULT
251	19-Apr-19	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	14:00	16:48	2:47	LINE FAULT
252	19-Apr-19	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	6:43	6:50	0:07	LOAD CHANGEVER
253	19-Apr-19	BENGALURU	66	HV1	AMARJYOTHI	8:10	8:17	0:07	LOAD CHANGEVER
254	19-Apr-19	BENGALURU	66	HV1	AMARJYOTHI	14:45	14:55	0:10	LOAD CHANGEVER



Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
255	19-Apr-19	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	10:53	12:57	2:04	LINE CLEAR AVAILED
256	19-Apr-19	GULBARGA	220	RTPS-LINGASUGUR2	LINGASUGUR_220	13:22	13:38	0:16	LINE FAULT
257	19-Apr-19	GULBARGA	110	HV2	ALIPUR_220	7:02	8:20	1:18	LINE CLEAR AVAILED
258	19-Apr-19	GULBARGA	110	WADAGERA-CLEANSOLAR_IPP	WADAGERA_110	18:00	19:30	1:30	LINE CLEAR AVAILED
259	19-Apr-19	GULBARGA	66	HV2	TAMBRAHALLI_66	4:20	5:00	0:40	LINE CLEAR AVAILED
260	19-Apr-19	HASSAN	110	HV1	MRSMG_220	9:47	9:50	0:03	TRANSFORMER FAULT
261	19-Apr-19	HASSAN	110	HV2	MRSMG_220	9:47	9:50	0:03	TRANSFORMER FAULT
262	19-Apr-19	HASSAN	110	HV3	MRSMG_220	9:47	9:50	0:03	TRANSFORMER FAULT
263	19-Apr-19	HASSAN	110	HV4	MRSMG_220	9:47	9:51	0:04	TRANSFORMER FAULT
264	19-Apr-19	HASSAN	110	SAGARA-ALKLA	SAGARA_!10	19:07	19:25	0:18	HAND TRIPPED
265	19-Apr-19	HASSAN	66	LV1	MRSMG_220	9:47	9:50	0:03	TRANSFORMER FAULT
266	19-Apr-19	HASSAN	66	LV2	MRSMG_220	9:47	9:50	0:03	TRANSFORMER FAULT
267	19-Apr-19	HASSAN	66	LV3	MRSMG_220	9:47	9:51	0:04	TRANSFORMER FAULT
268	19-Apr-19	HASSAN	66	LV4	MRSMG_220	9:47	9:51	0:04	TRANSFORMER FAULT
269	19-Apr-19	HASSAN	66	MRSSHM-BD-1	MRSMG_220	9:47	9:56	0:09	HAND TRIPPED
270	19-Apr-19	HASSAN	66	MRSSHM-BD-2	MRSMG_220	9:47	9:56	0:09	HAND TRIPPED
271	19-Apr-19	HASSAN	66	MRSSHM-DVG2	MRSMG_220	9:47	9:53	0:06	HAND TRIPPED
272	19-Apr-19	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	9:47	12:12	2:25	LINE CLEAR AVAILED
273	19-Apr-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:14	8:25	0:11	LINE FAULT
274	19-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:41	19:20	11:39	LINE CLEAR AVAILED
275	19-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:41	19:20	11:39	LINE CLEAR AVAILED
276	19-Apr-19	MYSORE	66	HV1	ATTIGULIPURA_66	7:09	7:21	0:12	HAND TRIPPED
277	19-Apr-19	MYSORE	66	HV1	DODDABYADARAHALLI_66	9:59	23:59	13:59	LINE CLEAR AVAILED
278	19-Apr-19	MYSORE	66	HV1	K_HONNALGERE_66	17:13	17:26	0:12	MAIN SUPPLY FAILURE
279	19-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	17:13	17:45	0:31	MAIN SUPPLY FAILURE
280	19-Apr-19	MYSORE	66	HV1	KMDODDI_66	17:10	17:20	0:10	MAIN SUPPLY FAILURE
281	19-Apr-19	MYSORE	66	HV2	KMDODDI_66	17:10	17:20	0:10	MAIN SUPPLY FAILURE
282	19-Apr-19	MYSORE	66	KUNTHUR-DR PETE	THAYURU_66 TNARASIPURA_66 SANTHEMARAHALLI_66	2:21	2:29	0:08	LINE FAULT
283	19-Apr-19	MYSORE	66	HV2	MADHUVANAHALLI_220	0:19	2:41	2:22	TRANSFORMER FAULT
284	19-Apr-19	MYSORE	66	HV2	MADHUVANAHALLI_220	7:22	10:42	3:20	LINE CLEAR AVAILED
285	19-Apr-19	MYSORE	66	HV2	MADHUVANAHALLI_220	12:00	16:42	4:42	LINE CLEAR AVAILED
286	19-Apr-19	MYSORE	66	HV1	MADHUVANAHALLI_220	12:00	12:35	0:35	LINE CLEAR AVAILED
287	19-Apr-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	11:27	11:35	0:07	LINE FAULT
288	19-Apr-19	MYSORE	66	PANNIYADAHUNDI-HEMMARGALA	HEMMARGALA_66 KARYA_66	17:27	17:46	0:18	HAND TRIPPED
289	19-Apr-19	MYSORE	66	SANTHE SARAGUR-B MATTGERE	B MATKERE_66	18:33	18:53	0:19	LINE CLEAR AVAILED
290	19-Apr-19	MYSORE	66	HV1	VIRAJPET_66	14:36	14:49	0:12	TRANSFORMER FAULT
291	19-Apr-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	9:01	11:08	2:06	LINE CLEAR AVAILED
292	19-Apr-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	11:16	13:08	1:51	LINE CLEAR AVAILED
293	20-Apr-19	BAGALKOT	110	110/11KV,HV2	ANANDANAGAR_110	12:31	17:25	4:54	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
294	20-Apr-19	BAGALKOT	110	BANAHATTI-JAMKHANDI	JAMKHANDI_110	17:54	18:02	0:08	LINE FAULT
295	20-Apr-19	BAGALKOT	110	KADANAKOPPA-KAVALWADA	KAVALWADA_110	12:42	12:53	0:11	HAND TRIPPED
296	20-Apr-19	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	0:00	12:34	12:34	LINE CLEAR AVAILED
297	20-Apr-19	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	12:34	23:59	11:25	LINE CLEAR AVAILED
298	20-Apr-19	BAGALKOT	110	KUMTA-SIRSI 1	KUMTA_110	12:31	23:59	11:28	LINE CLEAR AVAILED
299	20-Apr-19	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	23:40	23:48	0:08	TRANSFORMER FAULT
300	20-Apr-19	BAGALKOT	110	DAMBAL-MUNDARGI	MUNDARGI_110	10:53	12:25	1:32	NFBC ISSUED
301	20-Apr-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,HEBBL_33KV,KANAGAL_33KV	11:44	11:53	0:09	LINE CLEAR AVAILED
302	20-Apr-19	BENGALURU	66	HV3	ADUGODI	5:40	5:49	0:09	LOAD CHANGEOVER
303	20-Apr-19	BENGALURU	220	HV2	YERANDANAHALLI 220	6:04	6:27	0:23	TRANSFORMER FAULT
304	20-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	6:04	6:29	0:24	LINE FAULT
305	20-Apr-19	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	6:04	6:47	0:42	LINE FAULT
306	20-Apr-19	BENGALURU	220	HV2	TK HALLI 220	19:46	19:56	0:10	TRANSFORMER FAULT
307	20-Apr-19	BENGALURU	66	HV2	TK HALLI 220	7:15	7:17	0:02	TRANSFORMER FAULT
308	20-Apr-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	11:32	11:53	0:20	LINE CLEAR AVAILED
309	20-Apr-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	19:46	19:56	0:10	MAIN SUPPLY FAILURE
310	20-Apr-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	19:46	19:56	0:10	LINE FAULT
311	20-Apr-19	BENGALURU	66	HV2	TAVAREKERE	5:51	5:55	0:03	TRANSFORMER FAULT
312	20-Apr-19	BENGALURU	66	HV1	ITI	12:44	15:45	3:01	LINE CLEAR AVAILED
313	20-Apr-19	BENGALURU	66	HV2	ITI	16:20	16:25	0:05	TRANSFORMER FAULT
314	20-Apr-19	BENGALURU	66	BANGARPET - KOLAR 1	BANGARPET	16:26	17:31	1:04	LINE FAULT
315	20-Apr-19	BENGALURU	66	KOLAR 220 - BANGARPET 1	BANGARPET	16:26	17:31	1:04	LINE FAULT
316	20-Apr-19	BENGALURU	66	HV1	DEVANAHALLI	16:34	16:40	0:05	LINE CLEAR AVAILED
317	20-Apr-19	BENGALURU	66	HV1	DEVANAHALLI	18:43	18:48	0:05	LINE CLEAR AVAILED
318	20-Apr-19	BENGALURU	66	HV1	DEVANAHALLI	19:10	19:20	0:10	TRANSFORMER FAULT
319	20-Apr-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGALI	11:45	12:02	0:16	LINE FAULT
320	20-Apr-19	BENGALURU	66	CHINTAMANI 220 - CHINTAMANI 66	CHINTAMANI 66, SM MANGALA	7:57	8:49	0:52	LINE CLEAR AVAILED
321	20-Apr-19	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	0:58	1:33	0:35	LINE FAULT
322	20-Apr-19	BENGALURU	66	CHANNAPATNA - CHIKKENAHALLI	CHANNAPATNA	18:31	18:38	0:07	LINE CLEAR AVAILED
323	20-Apr-19	BENGALURU	66	HV1	KODIHALLI KANAKAPURA	14:50	15:54	1:04	LINE CLEAR AVAILED
324	20-Apr-19	GULBARGA	220	HV1	KUSTAGI_220	13:25	13:40	0:15	TRANSFORMER FAULT
325	20-Apr-19	GULBARGA	220	HV2	KUSTAGI_220	13:25	13:45	0:20	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
326	20-Apr-19	GULBARGA	220	SEDAM-SHREECEMENT_IPP	SHREECEMENT_IPP	15:48	15:55	0:07	LINE CLEAR AVAILED
327	20-Apr-19	GULBARGA	110	MALLAT-KAVITHAL	KAVITAL_110	20:00	22:55	2:55	LINE FAULT
328	20-Apr-19	GULBARGA	110	ALIPUR-PDHALLI	PD_HALLI_110	13:00	21:08	8:08	LINE CLEAR AVAILED
329	20-Apr-19	GULBARGA	66	HV2	TAMBRAHALLI_66	7:30	7:50	0:20	TRANSFORMER FAULT
330	20-Apr-19	GULBARGA	66	HV1	CHORNOOR_66	11:11	11:40	0:29	LINE CLEAR AVAILED
331	20-Apr-19	GULBARGA	66	HV2	TAMBRAHALLI_66	18:30	18:50	0:20	LINE CLEAR AVAILED
332	20-Apr-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	9:37	13:52	4:15	LINE CLEAR AVAILED
333	20-Apr-19	HASSAN	220	KEMAR-Varahi3	KEMAR_220	12:16	16:45	4:29	LINE FAULT
334	20-Apr-19	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	9:37	13:51	4:14	LINE CLEAR AVAILED
335	20-Apr-19	HASSAN	220	VARAHI-KEMAR3	varahi_gen	12:16	16:40	4:24	LINE FAULT
336	20-Apr-19	HASSAN	110	ARSK2-GANDASI	ARASIKERE_220	13:01	13:06	0:05	HAND TRIPPED
337	20-Apr-19	HASSAN	110	ARSK2-GERUMARA	ARASIKERE_220	13:01	13:06	0:05	HAND TRIPPED
338	20-Apr-19	HASSAN	110	LV1	ARASIKERE_220	13:01	13:05	0:04	HAND TRIPPED
339	20-Apr-19	HASSAN	110	HV2	KADUR_220	11:02	12:27	1:25	LINE CLEAR AVAILED
340	20-Apr-19	HASSAN	110	HV3	MANIPAL_110	10:19	11:29	1:10	LINE CLEAR AVAILED
341	20-Apr-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	12:54	13:01	0:07	LINE FAULT
342	20-Apr-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	13:09	13:16	0:07	LINE FAULT
343	20-Apr-19	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	15:53	16:00	0:07	LINE FAULT
344	20-Apr-19	HASSAN	66	HV2	BELUR_66	9:38	9:44	0:06	TRANSFORMER FAULT
345	20-Apr-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:33	9:40	0:07	LINE FAULT
346	20-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	12:55	13:00	0:05	MAIN SUPPLY FAILURE
347	20-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	13:10	13:15	0:05	MAIN SUPPLY FAILURE
348	20-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	13:25	14:00	0:35	MAIN SUPPLY FAILURE
349	20-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	15:15	15:35	0:20	MAIN SUPPLY FAILURE
350	20-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	15:45	15:55	0:10	MAIN SUPPLY FAILURE
351	20-Apr-19	HASSAN	66	BYARAPU-BAGUR	K_BYRAPURA_66	16:00	16:30	0:30	MAIN SUPPLY FAILURE
352	20-Apr-19	HASSAN	66	GENDEHA-HASSAN	GENDEHALLY_66	14:53	15:02	0:09	HAND TRIPPED
353	20-Apr-19	HASSAN	66	HV1	GENDEHALLY_66	14:53	15:02	0:09	HAND TRIPPED
354	20-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPUA_66	7:39	18:25	10:46	LINE CLEAR AVAILED
355	20-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPUA_66	7:39	18:25	10:46	LINE CLEAR AVAILED
356	20-Apr-19	MYSORE	66	BOOKANAKERE-CHINAKURALI	BANANGADI_66 CHINAKURALI_66	22:01	22:06	0:04	LINE FAULT
357	20-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	11:33	11:54	0:20	MAIN SUPPLY FAILURE
358	20-Apr-19	MYSORE	66	HV1	K_HONNALGERE_66	19:49	20:23	0:34	MAIN SUPPLY FAILURE
359	20-Apr-19	MYSORE	66	HV2	K_HONNALGERE_66	19:49	20:14	0:24	MAIN SUPPLY FAILURE
360	20-Apr-19	MYSORE	66	KM DODDI-TK HALLI	KMDODDI_66 KOLKARANADODDI_66 KIADBMANDYA_66 MADDUR_66 SOMANAHALLI_66 TUMBEKERE_66	19:45	20:13	0:28	MAIN SUPPLY FAILURE
361	20-Apr-19	MYSORE	66	MADHUVANAHALLI-YELANDUR	MAMBALLI_66 YELANDUR_66	18:08	18:17	0:09	LINE FAULT
362	20-Apr-19	MYSORE	66	PANNYADAHUNDI-HEMMARGALA	CHINAKURALI_66	10:21	11:09	0:47	LINE CLEAR AVAILED
363	20-Apr-19	MYSORE	66	RK NAGARA-KADAKOLA	KARYA_66	12:17	12:20	0:02	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
364	20-Apr-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	7:06	8:01	0:55	LINE CLEAR AVAILED
365	20-Apr-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-2	ENERCON1_IPP_66	7:11	8:06	0:55	LINE CLEAR AVAILED
366	20-Apr-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	7:06	8:02	0:56	LINE CLEAR AVAILED
367	20-Apr-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	7:06	8:02	0:56	LINE CLEAR AVAILED
368	20-Apr-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	7:06	8:01	0:55	LINE CLEAR AVAILED
369	20-Apr-19	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	8:28	11:07	2:38	LINE CLEAR AVAILED
370	20-Apr-19	TUMKUR	66	HIRIYUR220-TAVAREKERE (H)	TAVAREKERE(H)_66, PATNAYAKANAHALLI_66	9:46	11:35	1:48	LINE CLEAR AVAILED
371	20-Apr-19	TUMKUR	66	TR-2	THIMMASANDRA_66	6:24	14:02	7:37	LINE CLEAR AVAILED
372	21-Apr-19	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	5:29	5:48	0:19	TRANSFORMER FAULT
373	21-Apr-19	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_66KV	11:00	12:36	1:36	LINE CLEAR AVAILED
374	21-Apr-19	BAGALKOT	110	110/11KV,HV2	KHANAPUR_110	0:00	9:10	9:10	LINE CLEAR AVAILED
375	21-Apr-19	BAGALKOT	110	VAJRAMATTI220-MANTUR1	MANTUR_110	8:18	9:34	1:16	LINE CLEAR AVAILED
376	21-Apr-19	BAGALKOT	110	VAJRAMATTI220-MANTUR2	MANTUR_110	8:18	9:35	1:17	LINE CLEAR AVAILED
377	21-Apr-19	BAGALKOT	110	110/11KV,HV2	UGAR KHUD_110	12:40	12:46	0:06	TRANSFORMER FAULT
378	21-Apr-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	19:26	19:30	0:04	TRANSFORMER FAULT
379	21-Apr-19	BAGALKOT	110	110/11KV,HV2	YARAGATTI_110	23:16	23:19	0:03	TRANSFORMER FAULT
380	21-Apr-19	BAGALKOT	110	110/11KV,HV1	YELLAPARHATTI_110	10:51	11:11	0:20	LINE CLEAR AVAILED
381	21-Apr-19	BAGALKOT	110	110/33KV,HV4	ZALKI_110,NEVARGI_33KV,DHULKED_33 KV	15:12	15:25	0:13	TRANSFORMER FAULT
382	21-Apr-19	BENGALURU	66	BANASHANKARI - VRISHBHAVATHI 220	BANASHANKARI	7:30	7:39	0:08	LOAD CHANGEOVER
383	21-Apr-19	BENGALURU	66	BANASHANKARI - AREHALLI	BANASHANKARI	14:53	14:58	0:05	LOAD CHANGEOVER
384	21-Apr-19	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	15:50	20:01	4:11	LINE FAULT
385	21-Apr-19	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	17:55	20:02	2:06	LINE CLEAR AVAILED
386	21-Apr-19	BENGALURU	66	HSR LAYOUT 220 - KORAMANGALA	K & C VALLEY, NAL (EHT)	17:16	17:46	0:29	LOAD CHANGEOVER
387	21-Apr-19	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	15:46	16:05	0:18	MAIN SUPPLY FAILURE
388	21-Apr-19	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	17:04	17:09	0:05	LOAD CHANGEOVER
389	21-Apr-19	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	15:46	16:05	0:18	MAIN SUPPLY FAILURE
390	21-Apr-19	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	17:15	17:20	0:05	LOAD CHANGEOVER
391	21-Apr-19	BENGALURU	66	GOKULA - MATHIKERE	GOKULA, BEL (EHT)	16:50	17:05	0:15	LOAD CHANGEOVER
392	21-Apr-19	BENGALURU	66	HV2	NGEF	9:24	9:45	0:20	TRANSFORMER FAULT
393	21-Apr-19	BENGALURU	66	RR NAGAR - SUBRAMANYAPURA 220	RR NAGAR	13:22	13:25	0:02	LOAD CHANGEOVER
394	21-Apr-19	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	10:25	10:30	0:05	LOAD CHANGEOVER
395	21-Apr-19	BENGALURU	66	PLATINUM CITY - DG4	PLATINUM CITY	11:30	11:35	0:05	LOAD CHANGEOVER
396	21-Apr-19	BENGALURU	66	RR NAGAR - VRISHBHAVATHI 220	RR NAGAR	14:50	14:54	0:03	LOAD CHANGEOVER
397	21-Apr-19	BENGALURU	66	HV2	RR NAGAR	13:22	13:25	0:02	LOAD CHANGEOVER
398	21-Apr-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, BEL (EHT)	15:46	16:25	0:38	LINE FAULT
399	21-Apr-19	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, BEL (EHT)	15:46	16:25	0:38	LINE FAULT
400	21-Apr-19	BENGALURU	66	HV2	SUBRAMANYAPURA 66	7:52	8:06	0:14	TRANSFORMER FAULT
401	21-Apr-19	BENGALURU	66	SUBRAMANYAPRUA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	10:54	11:24	0:29	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
402	21-Apr-19	BENGALURU	66	HV2	VIJAYANAGARA	13:27	14:56	1:29	LINE CLEAR AVAILED
403	21-Apr-19	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	10:09	10:26	0:17	LINE FAULT
404	21-Apr-19	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	5:47	6:16	0:28	LINE FAULT
405	21-Apr-19	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:11	15:20	0:09	LINE FAULT
406	21-Apr-19	BENGALURU	66	DB PURA 220 - DG 1	DODDABELAVANGALA, AIR (EHT)	7:38	7:53	0:14	LINE FAULT
407	21-Apr-19	BENGALURU	66	HV1	KIADB DB PURA 220	6:25	6:51	0:26	TRANSFORMER FAULT
408	21-Apr-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	6:09	6:14	0:04	LINE FAULT
409	21-Apr-19	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	11:50	12:30	0:40	LINE FAULT
410	21-Apr-19	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	17:00	17:20	0:20	LOAD CHANGEOVER
411	21-Apr-19	GULBARGA	110	HV2	HANUMANAL_110	7:30	9:40	2:10	LINE CLEAR AVAILED
412	21-Apr-19	GULBARGA	110	MALLAT-BYAGAWAT	BYAGAWAT_110	0:15	0:30	0:15	LINE FAULT
413	21-Apr-19	GULBARGA	110	MALLAT-KAVITHAL	KAVITAL_110	10:58	15:55	4:57	LINE FAULT
414	21-Apr-19	HASSAN	66	HV2	BELUR_66	12:16	16:24	4:08	LINE CLEAR AVAILED
415	21-Apr-19	HASSAN	66	HV2	BELUR_66	16:26	16:34	0:08	HAND TRIPPED
416	21-Apr-19	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	8:15	8:19	0:04	MAIN SUPPLY FAILURE
417	21-Apr-19	HASSAN	66	MRSSHM-DVG2	MRS MG_220	8:08	8:15	0:07	LINE FAULT
418	21-Apr-19	HASSAN	66	MRSSHM-HOLUR	MRS MG_220	10:49	10:52	0:03	HAND TRIPPED
419	21-Apr-19	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	7:20	15:10	7:50	LINE CLEAR AVAILED
420	21-Apr-19	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	7:20	15:10	7:50	LINE CLEAR AVAILED
421	21-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 2	HURA_66, HULLAHALLI_66, DOORA_66,	18:00	18:15	0:15	LINE FAULT
422	21-Apr-19	MYSORE	66	KADAKOLA-SARAGUR 1	JAIPUR_66, HAMPAPURA(K)_66, ANTHARSANTHE_66, HDKOTE_66, B MATKERE_66, SANTHESARAGUR_66	18:00	18:09	0:09	LINE FAULT
423	21-Apr-19	MYSORE	66	MADHUVANAHALLI-YELANDUR	MAMBALLI_66 YELANDUR_66	16:50	16:57	0:06	LINE FAULT
424	21-Apr-19	MYSORE	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	15:14	15:29	0:15	LINE FAULT
425	21-Apr-19	MYSORE	66	HV2	SALIGRAMA_66	19:40	19:46	0:06	TRANSFORMER FAULT
426	21-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY _66 VADERALLI_66	4:57	5:03	0:06	LINE FAULT
427	21-Apr-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	6:09	6:27	0:18	LINE FAULT
428	21-Apr-19	TUMKUR	66	TR-1	DEVARAHALLI_66	15:16	15:22	0:05	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
429	21-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:06	9:25	0:19	LINE FAULT
430	21-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:19	12:30	0:10	LINE FAULT
431	21-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:08	23:26	0:17	LINE FAULT
432	21-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	23:27	23:40	0:13	LINE FAULT
433	21-Apr-19	TUMKUR	66	TR-1	IDHALLY_66	13:51	14:05	0:14	TRANSFORMER FAULT
434	21-Apr-19	TUMKUR	66	KUNDUR- SUZLON	SUZLON_IPP_66	11:36	15:09	3:33	LINE CLEAR AVAILED
435	22-Apr-19	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	0:00	11:35	11:35	LINE CLEAR AVAILED
436	22-Apr-19	BAGALKOT	110	110/11KV,HV1	HALIYAL_110	13:59	17:40	3:41	TRANSFORMER FAULT
437	22-Apr-19	BAGALKOT	110	KOTTAWAGI LIS-HUKKERI	HUKKERI_110	21:20	21:55	0:35	LINE FAULT
438	22-Apr-19	BAGALKOT	220	SIRSI-HUBLI 2	SIRSI_220	14:04	14:41	0:37	LINE FAULT
439	22-Apr-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	9:30	9:38	0:08	TRANSFORMER FAULT
440	22-Apr-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	19:14	19:17	0:03	TRANSFORMER FAULT
441	22-Apr-19	BAGALKOT	110	110/11KV,HV2	LAXMESWAR_110	18:35	23:59	5:24	TRANSFORMER FAULT
442	22-Apr-19	BENGALURU	66	HV2	HEBAL 220	1:51	2:50	0:59	LINE CLEAR AVAILED
443	22-Apr-19	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	12:05	12:10	0:05	LOAD CHANGEOVER
444	22-Apr-19	BENGALURU	66	RBI - KHODAYS 220	RBI	16:02	16:08	0:06	LOAD CHANGEOVER
445	22-Apr-19	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	12:22	12:30	0:08	LOAD CHANGEOVER
446	22-Apr-19	BENGALURU	66	SOUTH CITY - KHODAYS 220	SOUTH CITY	16:00	16:05	0:05	LOAD CHANGEOVER
447	22-Apr-19	BENGALURU	66	HV2	SHOBHA APARTMENT	10:32	10:48	0:15	LINE CLEAR AVAILED
448	22-Apr-19	BENGALURU	66	HV2	TAVAREKERE	13:10	13:19	0:09	TRANSFORMER FAULT
449	22-Apr-19	BENGALURU	66	HV1	TELECOM LAYOUT	13:01	13:48	0:46	LINE CLEAR AVAILED
450	22-Apr-19	BENGALURU	66	HV2	TELECOM LAYOUT	11:55	12:54	0:59	LINE CLEAR AVAILED
451	22-Apr-19	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI	17:35	17:54	0:19	LINE FAULT
452	22-Apr-19	HASSAN	220	KEMAR-PUTUR2	KEMAR_220	10:50	17:50	7:00	NFBC ISSUED
453	22-Apr-19	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	10:10	11:35	1:25	LINE CLEAR AVAILED
454	22-Apr-19	HASSAN	110	HV	KITTADAHALLY_110	11:39	12:29	0:50	LINE CLEAR AVAILED
455	22-Apr-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	9:15	9:19	0:04	LINE FAULT
456	22-Apr-19	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	10:57	23:59	13:02	NFBC ISSUED
457	22-Apr-19	HASSAN	66	HV2	RAMESHWARNAGAR_66	11:45	12:30	0:45	LINE CLEAR AVAILED
458	22-Apr-19	MYSORE	66	HV1	BANNUR_66	4:58	5:02	0:03	TRANSFORMER FAULT
459	22-Apr-19	MYSORE	66	HV1	BOOKANAKERE_66	16:03	23:59	7:55	LINE CLEAR AVAILED
460	22-Apr-19	MYSORE	66	HV2	BOOKANAKERE_66	13:00	15:40	2:40	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
461	22-Apr-19	MYSORE	66	HV1	GARUDANAUKADDA_66	7:37	7:45	0:07	TRANSFORMER FAULT
462	22-Apr-19	MYSORE	66	TUBINAKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 BASARALU_66 KESLAGERE_66 SHIVALLY_66 VADERALLI_66	13:08	13:12	0:04	LINE FAULT
463	22-Apr-19	MYSORE	66	VAJAMANGALA-KADAKOLA 1	AYRALLI_66, MARADIHUNDI_66	20:28	21:02	0:34	LINE FAULT
464	22-Apr-19	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	13:10	17:01	3:51	LINE FAULT
465	22-Apr-19	TUMKUR	220	TR-1	HONNALLI_220	13:11	13:24	0:12	HAND TRIPPED
466	22-Apr-19	TUMKUR	220	THALLAK 220-HIRIYUR	HIRIYUR_220	6:35	20:02	13:26	LINE CLEAR AVAILED
467	22-Apr-19	TUMKUR	66	TR-2	BADDIHALLI_66	16:13	18:26	2:12	LINE CLEAR AVAILED
468	22-Apr-19	TUMKUR	66	TR-2	BADDIHALLI_66	18:45	18:47	0:01	LINE CLEAR AVAILED
469	22-Apr-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	9:05	9:11	0:06	LINE FAULT
470	22-Apr-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:05	9:17	0:11	LINE FAULT
471	22-Apr-19	TUMKUR	66	TR-2	HONNALI_66	9:28	10:39	1:11	TRANSFORMER FAULT
472	22-Apr-19	TUMKUR	66	TR-2	HONNALI_66	10:50	11:36	0:45	TRANSFORMER FAULT
473	22-Apr-19	TUMKUR	66	TR-1	LINGDHALLI_66	20:36	20:40	0:03	TRANSFORMER FAULT
474	22-Apr-19	TUMKUR	66	TR-1	MADHUGIRI_220	16:09	17:03	0:53	LINE CLEAR AVAILED
475	22-Apr-19	TUMKUR	66	THALLAK 220kV- CHALLAKERE 1	CHALLAKERE_66, SANIKERE_66	14:57	15:26	0:29	HAND TRIPPED