

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 07.07.2020 TO 13.07.2020**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	7-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
2	7-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
3	7-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
4	7-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
5	7-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
6	7-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
7	7-Jul-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN , LINE CLEAR AVAILED
8	7-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN , LINE CLEAR AVAILED
9	7-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)			LINE OPEN , LINE CLEAR AVAILED
10	7-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN , LINE CLEAR AVAILED
11	7-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
12	7-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
13	7-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
14	7-Jul-2020	BAGALKOT	110	SIRSI 220(ESALE )-UMMACHAGI	STATION NOT AFFECTED	12:25 (03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
15	7-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
16	7-Jul-2020	BAGALKOT	110	110/11KV, HV1	YARGATTI_110	11:48	13:14	1:26	LINE CLEAR AVAILED
17	7-Jul-2020	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	11:48	18:13	6:25	LINE CLEAR AVAILED
18	7-Jul-2020	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	18:27	18:35	0:08	HAND TRIPPED
19	7-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, UGARKHUD_110	20:00	20:06	0:06	TRANSFORMER FAULT
20	7-Jul-2020	BAGALKOT	110	SHIRAGUPPI SUGARS- KAGAWAD	KAGAWAD_110	19:55	20:24	0:29	LINE FAULT
21	7-Jul-2020	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	19:55	20:10	0:15	LINE FAULT
22	7-Jul-2020	BAGALKOT	110	110/11KV, HV1	HIDIKAL DAM_110	4:16	4:20	0:04	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
23	7-Jul-2020	BAGALKOT	110	110/11KV, HV1	HIDIKAL DAM_110	6:29	9:20	2:51	LINE CLEAR AVAILED
24	7-Jul-2020	BAGALKOT	110	HUNGUND-KUDAL SANGAM(BAGEWADI)	KUDAL SANGAM_110	23:15	23:35	0:20	LINE FAULT
25	7-Jul-2020	BENGALURU	66	HV1	MULBAGAL	11:27	12:10	00:43	TRANSFORMER FAULT
26	7-Jul-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	NO STATION AFFECTED	10:40(6-7-2020)			LINE OPEN , LINE CLEAR AVAILED
27	7-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
28	7-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN , LINE FAULT
29	7-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
30	7-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
31	7-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
32	7-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN , LINE FAULT
33	7-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN , LINE FAULT
34	7-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN , LINE FAULT
35	7-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN , LINE CLEAR AVAILED
36	7-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)			LINE OPEN , LINE CLEAR AVAILED
37	7-Jul-2020	GULBARGA	110	HV2	BETAGERA_110	08:40	09:00	00:20	LINE CLEAR AVAILED
38	7-Jul-2020	GULBARGA	110	HV1	SINDHANOOR_110	04:20	04:25	00:05	TRANSFORMER FAULT
39	7-Jul-2020	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	00:40	01:00	00:20	MAIN SUPPLY FAILURE
40	7-Jul-2020	GULBARGA	110	VALKAMDINNI-RAICHUR	VALKAMDINNI_110	09:15	10:15	01:00	MAIN SUPPLY FAILURE
41	7-Jul-2020	GULBARGA	110	MALLAT-BYAGAWAT	BYAGWAT_110	00:40	00:49	00:09	LINE FAULT
42	7-Jul-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	05:35	06:01	00:26	LINE FAULT
43	7-Jul-2020	GULBARGA	220	LINGAPUR-MUNIRABAD2	MUNIRABAD_220	08:56	17:21	08:25	LINE CLEAR AVAILED
44	7-Jul-2020	GULBARGA	110	HV2	MANVI_110	12:45	14:14	01:29	LINE CLEAR AVAILED
45	7-Jul-2020	GULBARGA	110	HV1	MANVI_110	18:29	18:36	00:07	TRANSFORMER FAULT
46	7-Jul-2020	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	22:02 (3.07.2020)			LINE OPEN , LINE CLEAR AVAILED
47	7-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
48	7-Jul-2020	HASSAN	110	HV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN , LINE CLEAR AVAILED
49	7-Jul-2020	HASSAN	66	LV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN , LINE CLEAR AVAILED
50	7-Jul-2020	HASSAN	400	HASSAN40-UPCL1	SHNATHIGRAMA_400	21:49 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
51	7-Jul-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:50 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
52	7-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:44 (7.07.2020)			LINE OPEN , LINE CLEAR AVAILED
53	7-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	01:05	11:35	10:30	HAND TRIPPED
54	7-Jul-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	02:31	06:55	04:24	LINE FAULT
55	7-Jul-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	10:23	10:44	00:21	HAND TRIPPED
56	7-Jul-2020	HASSAN	110	MRSHM-GAJNUR	MRSMSG_220	01:18	02:07	00:49	LINE CLEAR AVAILED
57	7-Jul-2020	HASSAN	110	MRSHM-GAJNUR	MRSMSG_220	10:26	10:41	00:15	HAND TRIPPED
58	7-Jul-2020	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	11:50	12:46	00:56	LINE FAULT
59	7-Jul-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	02:31	06:55	04:24	LINE FAULT
60	7-Jul-2020	HASSAN	220	VARAH1-SHMG3	varahi_gen	10:23	10:44	00:21	HAND TRIPPED
61	7-Jul-2020	HASSAN	110	HV2	ANAVATTI_110	20:19	20:45	00:26	TRANSFORMER FAULT
62	7-Jul-2020	HASSAN	110	HV2	ARASIKERE_110	08:33	15:01	06:28	TRANSFORMER FAULT
63	7-Jul-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	01:30	02:42	01:12	HAND TRIPPED
64	7-Jul-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	10:23	10:51	00:28	HAND TRIPPED
65	7-Jul-2020	HASSAN	110	JOG-JLT3	mghejog_gen	15:23	16:25	01:02	HAND TRIPPED
66	7-Jul-2020	HASSAN	110	JOG110-AMBTR2	JOG_110	15:28	16:16	00:48	LINE CLEAR AVAILED
67	7-Jul-2020	HASSAN	110	JOG110-LPH	JOG_110	12:29	14:07	01:38	LINE CLEAR AVAILED
68	7-Jul-2020	HASSAN	110	JOG110-LPH	JOG_110	15:32	16:16	00:44	LINE CLEAR AVAILED
69	7-Jul-2020	HASSAN	110	JOG110-MGHE	JOG_110	15:25	16:25	01:00	LINE CLEAR AVAILED
70	7-Jul-2020	HASSAN	110	KEMAR-Manipal2	KEMAR_220	09:44	13:11	03:27	LINE CLEAR AVAILED
71	7-Jul-2020	HASSAN	110	HV3	MANIPAL_110	10:35	14:17	03:42	LINE CLEAR AVAILED
72	7-Jul-2020	HASSAN	110	HV4	MANIPAL_110	09:51	17:39	07:48	LINE CLEAR AVAILED
73	7-Jul-2020	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	10:57	11:30	00:33	LINE FAULT
74	7-Jul-2020	HASSAN	66	HV2	BALEHONNUR_66	16:29	16:52	00:23	TRANSFORMER FAULT
75	7-Jul-2020	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	20:54	21:12	00:18	LINE FAULT
76	7-Jul-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	08:48	14:01	05:13	LINE CLEAR AVAILED
77	7-Jul-2020	HASSAN	66	HASSN220-SKPURA	HASSAN_220	20:54	21:10	00:16	LINE FAULT
78	7-Jul-2020	HASSAN	66	HV1	HASSAN_66	12:58	14:45	01:47	LINE CLEAR AVAILED
79	7-Jul-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	20:54	21:24	00:30	LINE FAULT
80	7-Jul-2020	HASSAN	66	HV1	MAGGE_66	20:54	21:15	00:21	MAIN SUPPLY FAILURE
81	7-Jul-2020	HASSAN	66	HV2	MAGGE_66	20:54	21:15	00:21	MAIN SUPPLY FAILURE
82	7-Jul-2020	MYSURU	66	HV3	KUSHALNAGARA_220	10:30	10:40	0:10	TRANSFORMER FAULT
83	7-Jul-2020	MYSURU	66	HOOTAGALLY-HUNSUR	NO STATIONS EFFECTED	15:00	16:36	1:36	LINE CLEAR AVAILED
84	7-Jul-2020	MYSURU	66	TUBINKERE-NAGAMANGLA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE 66 VADERALLI_66	7:01	7:06	0:05	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
85	7-Jul-2020	MYSURU	66	MANDYA-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 , BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	10:11	10:20	0:09	LINE FAULT
86	7-Jul-2020	MYSURU	66	MANDYA-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 , BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	10:11	10:20	0:09	LINE FAULT
87	7-Jul-2020	MYSURU	66	MANDYA-MC-2	MALAVALLI_66 HADLI_66 MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 , BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	10:25	10:32	0:07	LINE FAULT
88	7-Jul-2020	MYSURU	66	MANDYA-MC-2	MALAVALLI_66 HADLI_66 MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 , BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	10:25	10:32	0:07	LINE FAULT
89	7-Jul-2020	MYSURU	66	MANDYA-MC-2	MALAVALLI_66 HADLI_66 MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 , BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	10:42	10:53	0:11	LINE FAULT
90	7-Jul-2020	MYSURU	66	MANDYA-MC-4	NO STATIONS EFFECTED	10:42	14:35	3:53	LINE FAULT
91	7-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN , LINE FAULT
92	7-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
93	7-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
94	7-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
95	7-Jul-2020	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	12:44	14:09	1:24	LINE CLEAR AVAILED
96	7-Jul-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	16:25	19:36	3:11	LINE CLEAR AVAILED
97	7-Jul-2020	TUMKUR	220	NEELAGUNDA220KV- ITTAGI 220kv	NEELAGUNDA_220	11:47	20:40	8:52	LINE FAULT
98	7-Jul-2020	TUMKUR	220	GUTTUR 400- CHITRADURGA 220	CHITRADURGA_220	12:43	14:10	1:27	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
99	7-Jul-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	16:25	19:37	3:11	LINE CLEAR AVAILED
100	7-Jul-2020	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	11:47	20:40	8:52	LINE FAULT
101	7-Jul-2020	TUMKUR	66	TR-2	BADDIHALLI_66	9:24	12:24	2:59	LINE CLEAR AVAILED
102	7-Jul-2020	TUMKUR	66	TR-1	BAGUR_TMK_66	8:43	8:48	0:04	TRANSFORMER FAULT
103	7-Jul-2020	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, RELIANCE IPP 66, HIRIYUR 66	5:53	6:40	0:47	LINE FAULT
104	7-Jul-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	10:11	13:35	3:24	LINE CLEAR AVAILED
105	7-Jul-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	6:02	6:07	0:05	TRANSFORMER FAULT
106	7-Jul-2020	TUMKUR	66	HARIYABBE-CHIKKABANAGERE	HARIYABBE_66	15:15	15:19	0:03	HAND TRIPPED
107	7-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	12:03	12:34	0:30	TRANSFORMER FAULT
108	7-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	4:35	4:41	0:05	LINE FAULT
109	7-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:44	11:57	0:13	HAND TRIPPED
110	7-Jul-2020	TUMKUR	66	TR-1	KUNDUR_66	7:47	8:19	0:31	LINE CLEAR AVAILED
111	7-Jul-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	13:51	19:02	5:11	LINE CLEAR AVAILED
112	7-Jul-2020	TUMKUR	66	NEELAGUNDA220kV- HARPANAHALLI-1	HARAPPANAHALLI_66	12:04	12:21	0:17	HAND TRIPPED
113	7-Jul-2020	TUMKUR	66	NEELAGUNDA220kV- HARPANAHALLI-1	HARAPPANAHALLI_66	13:11	13:19	0:07	HAND TRIPPED
114	7-Jul-2020	TUMKUR	66	NEELAGUNDA 220kV- HULUVAGALU	HALUVAGALU_66	11:51	12:21	0:30	HAND TRIPPED
115	7-Jul-2020	TUMKUR	66	NEELAGUNDA 220kV- HULUVAGALU	HALUVAGALU_66	13:11	13:21	0:09	HAND TRIPPED
116	7-Jul-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	12:04	12:22	0:18	HAND TRIPPED
117	7-Jul-2020	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	13:11	13:43	0:32	HAND TRIPPED
118	7-Jul-2020	TUMKUR	66	NEELAGUNDA 220kV-TELADI	TELADI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	12:04	12:21	0:17	HAND TRIPPED
119	7-Jul-2020	TUMKUR	66	NEELAGUNDA 220kV-TELADI	TELADI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	13:11	13:18	0:07	HAND TRIPPED
1	8-Jul-2020	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	16:15	16:34	0:19	LINE CLEAR AVAILED
2	8-Jul-2020	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	13:13	13:27	0:14	TRANSFORMER FAULT
3	8-Jul-2020	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	12:31	12:54	0:23	LINE CLEAR AVAILED
4	8-Jul-2020	BAGALKOT	110	110/11KV, HV1(HV3)	GAJENDRAGAD_110	11:24	12:44	1:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
5	8-Jul-2020	BAGALKOT	110	110/11KV, HV3	SOUDATTI_110	14:30	18:10	3:40	TRANSFORMER FAULT
6	8-Jul-2020	BAGALKOT	110	110/11KV. HV2	SUVARNA SOUDA_110	11:20	14:07	2:47	LINE CLEAR AVAILED
7	8-Jul-2020	BAGALKOT	110	110/11KV. HV2	SHIROL_110	21:36	22:06	0:30	TRANSFORMER FAULT
8	8-Jul-2020	BAGALKOT	110	110/33KV, HV2(HV4)	GAJENDRAGAD_110,WIND1&2_34	12:46	13:23	0:37	LINE CLEAR AVAILED
9	8-Jul-2020	BAGALKOT	110	110/33KV, HV5	BELUR_110,UAS_33,UDL_33,TATA1&2,SOUTHERN TERO 33	13:10	13:46	0:36	TRANSFORMER FAULT
10	8-Jul-2020	BAGALKOT	110	110/33KV, HV5	BELUR_110,UAS_33,UDL_33,TATA1&2,SOUTHERN TERO 33	14:40	16:42	2:02	LINE CLEAR AVAILED
11	8-Jul-2020	BAGALKOT	110	220/110KV, LV3	HUBLI_220	9:35	16:06	6:31	HAND TRIPPED
12	8-Jul-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	23:20 (07.07.2020)	8:31 (08.08.2020)	9:11HRS	LINE CHARGED
13	8-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
14	8-Jul-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	13:03	13:11	0:08	LINE FAULT
15	8-Jul-2020	BAGALKOT	110	BAGEWADI-SINDAGI	SINDAGI_110	4:20	11:30	7:10	LINE FAULT
16	8-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN , LINE CLEAR AVAILED
17	8-Jul-2020	BAGALKOT	110	GATAPRABHA220-GOKAK	GOKAK_110	1:31	1:45	0:14	LINE FAULT
18	8-Jul-2020	BAGALKOT	110	GHATAPRABHA220-MANTUR	MANTUR_110	8:53	9:03	0:10	LINE FAULT
19	8-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN , LINE CLEAR AVAILED
20	8-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
21	8-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)			LINE OPEN , LINE CLEAR AVAILED
22	8-Jul-2020	BAGALKOT	110	JAMKHANDI SUGARS- TODALBAGI	TODALBAGI_110	6:39	7:00	0:21	LINE FAULT
23	8-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
24	8-Jul-2020	BAGALKOT	110	KIRUVATTI-UMMACHAGI	STATION NOT AFFECTED	13:20 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
25	8-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
26	8-Jul-2020	BAGALKOT	110	MAREGUDDI-MUNDUGANUR	MUNDUGANUR_110	03:54	3:56	0:02	LINE FAULT
27	8-Jul-2020	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	9:56 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
28	8-Jul-2020	BAGALKOT	110	SIRSI 220(ESALE )-UMMACHAGI	STATION NOT AFFECTED	12:25 (03.07.2020)	13:25 (08.07.2020)	222 hrs	LINE CHARGED
29	8-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN , LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
30	8-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
31	8-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
32	8-Jul-2020	BAGALKOT	220	220/110KV,HV1,LV1	RANEBENNUR_220	10:42	18:48	8:06	LINE CLEAR AVAILED
33	8-Jul-2020	BAGALKOT	220	220/110KV,HV1,LV1	MK HUBLI_220	10:07	15:51	5:44	LINE CLEAR AVAILED
34	8-Jul-2020	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	20:20 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
35	8-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
36	8-Jul-2020	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	9:37	11:20	1:43	LINE FAULT
37	8-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
38	8-Jul-2020	BAGALKOT	220	HAVERI-GUTTUR1	HAVERI_220	11:00	13:38	2:38	HAND TRIPPED
39	8-Jul-2020	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	17:23 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
40	8-Jul-2020	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	10:36 (08.07.2020)			LINE OPEN , LINE FAULT
41	8-Jul-2020	BAGALKOT	220	NARENDRA-BELGAUM	NARENDRA_220	8:57 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
42	8-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
43	8-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
44	8-Jul-2020	BENGALURU	220	HV1	KOLAR 220	12:30	14:00	01:30	LINE CLEAR AVAILED
45	8-Jul-2020	BENGALURU	220	HV1	KOLAR 220	15:35	16:30	00:55	LINE CLEAR AVAILED
46	8-Jul-2020	BENGALURU	220	HV2	KOLAR 220	12:30	14:00	01:30	LINE CLEAR AVAILED
47	8-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
48	8-Jul-2020	BENGALURU	400	NELAMANGALA 400 - MYSORE 2	NO STATIONS EFFECTED	23:22:00(08-07- 2020)			LINE OPEN , LINE FAULT
49	8-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
50	8-Jul-2020	BENGALURU	66	HV1	KOLAR 220	12:26	14:02	01:36	LINE CLEAR AVAILED
51	8-Jul-2020	BENGALURU	66	HV2	KOLAR 220	12:26	14:02	01:36	LINE CLEAR AVAILED
52	8-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN , LINE FAULT
53	8-Jul-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	12:26	14:02	01:36	LINE CLEAR AVAILED
54	8-Jul-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	14:30	14:37	00:07	LINE CLEAR AVAILED
55	8-Jul-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	14:50	14:55	00:05	LOAD CHANGE OVER
56	8-Jul-2020	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	18:45:00	18:52	00:07	LOAD CHANGE OVER
57	8-Jul-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	12:26	14:02	01:36	LINE CLEAR AVAILED
58	8-Jul-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	14:30	14:37	00:07	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
59	8-Jul-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	12:26	14:01	01:35	LINE CLEAR AVAILED
60	8-Jul-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	14:30	14:37	00:07	LINE CLEAR AVAILED
61	8-Jul-2020	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	15:35	16:04	00:29	LINE CLEAR AVAILED
62	8-Jul-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	12:26	14:02	01:36	LINE CLEAR AVAILED
63	8-Jul-2020	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR	14:30	14:37	00:07	LINE CLEAR AVAILED
64	8-Jul-2020	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	12:26	14:01	01:35	LINE CLEAR AVAILED
65	8-Jul-2020	BENGALURU	66	KOLAR 220 - SRINIVASPURA	DRDO(EHT), MALLASANDRA, DALASANUR, YELDUR	14:30	14:37	00:07	LINE CLEAR AVAILED
66	8-Jul-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:26	14:02	01:36	LINE CLEAR AVAILED
67	8-Jul-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	14:30	14:37	00:07	LINE CLEAR AVAILED
68	8-Jul-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	15:35	16:32	00:57	LINE CLEAR AVAILED
69	8-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
70	8-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
71	8-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN , LINE FAULT
72	8-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN , LINE FAULT
73	8-Jul-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	NO STATION AFFECTED	10:40(6-7-2020)			LINE OPEN , LINE CLEAR AVAILED
74	8-Jul-2020	GULBARGA	110	HANUMSAGAR-KUSHTAGI	HANUMASAGAR_110,HANUMAN AL_110,HIREGONNAGAR_110	21:25	21:45	00:20	MAIN SUPPLY FAILURE
75	8-Jul-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	18:48	19:00	00:12	LINE FAULT
76	8-Jul-2020	GULBARGA	110	HV2	HATTI_110	06:07	06:13	00:06	TRANSFORMER FAULT
77	8-Jul-2020	GULBARGA	110	HV2	HATTI_110	14:10	14:22	00:12	TRANSFORMER FAULT
78	8-Jul-2020	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	05:35	05:51	00:16	LINE FAULT
79	8-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	2:40(28.06.2020)	19:05(08.07.2020)	16:25 hrs	LINE CLEAR AVAILED
80	8-Jul-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTP SWATERWORKS	23:55	23:59	00:04	LINE FAULT
81	8-Jul-2020	GULBARGA	110	SIDHANOOR220-SIRUGUPPA	SIRUGUPPA_110	22:01	22:11	00:10	LINE FAULT
82	8-Jul-2020	GULBARGA	220	HV1,HV2	KAPANOOR_220	16:25	18:25	02:00	LINE CLEAR AVAILED
83	8-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN , LINE CLEAR AVAILED
84	8-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN , LINE FAULT
85	8-Jul-2020	GULBARGA	220	LINGAPUR-MUNIRABAD TR2	LINGAPUR_220	09:27	13:58	04:31	NFBC ISSUED
86	8-Jul-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	04:22	04:28	00:06	LINE FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
87	8-Jul-2020	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	10:34	13:22	02:48	NFBC ISSUED
88	8-Jul-2020	HASSAN	110	HV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN , LINE CLEAR AVAILED
89	8-Jul-2020	HASSAN	110	HV1	KADUR_220	10:16	10:54	00:38	TRANSFORMER FAULT
90	8-Jul-2020	HASSAN	110	HV1	KONAJE_110	10:07	10:12	00:05	HAND TRIPPED
91	8-Jul-2020	HASSAN	110	HV1	KONAJE_110	13:52	13:54	00:02	HAND TRIPPED
92	8-Jul-2020	HASSAN	110	HV2	KONAJE_110	10:07	10:13	00:06	HAND TRIPPED
93	8-Jul-2020	HASSAN	110	HV2	KONAJE_110	13:52	13:55	00:03	HAND TRIPPED
94	8-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
95	8-Jul-2020	HASSAN	110	HV3	KONAJE_110	10:07	10:12	00:05	HAND TRIPPED
96	8-Jul-2020	HASSAN	110	HV3	KONAJE_110	13:52	13:55	00:03	HAND TRIPPED
97	8-Jul-2020	HASSAN	110	KADUR-AJAMPURA	KADUR_220	10:16	10:54	00:38	LINE FAULT
98	8-Jul-2020	HASSAN	110	KADUR-NERELEKERE	KADUR_220	10:16	10:54	00:38	LINE FAULT
99	8-Jul-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	10:16	10:54	00:38	LINE FAULT
100	8-Jul-2020	HASSAN	110	KADUR-TNGL	KADUR_220	10:16	10:54	00:38	LINE FAULT
101	8-Jul-2020	HASSAN	110	KADUR-YGTI	KADUR_220	10:16	10:54	00:38	LINE FAULT
102	8-Jul-2020	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:00	17:21	00:21	LINE FAULT
103	8-Jul-2020	HASSAN	110	LV1	KADUR_220	10:16	10:54	00:38	TRANSFORMER FAULT
104	8-Jul-2020	HASSAN	110	LV2	KADUR_220	10:16	10:54	00:38	TRANSFORMER FAULT
105	8-Jul-2020	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	11:17	11:25	00:08	HAND TRIPPED
106	8-Jul-2020	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	09:55	13:19	03:24	LINE CLEAR AVAILED
107	8-Jul-2020	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	11:39	14:51	03:12	NFBC ISSUED
108	8-Jul-2020	HASSAN	220	GERSOPA-TALGUPPA	gerusoppa_gen	11:38	15:06	03:28	NFBC ISSUED
109	8-Jul-2020	HASSAN	220	HV1	KADUR_220	10:16	10:54	00:38	TRANSFORMER FAULT
110	8-Jul-2020	HASSAN	220	HV2	GOPALPURA_220	12:46	13:09	00:23	LINE CLEAR AVAILED
111	8-Jul-2020	HASSAN	220	HV2	KADUR_220	10:16	10:54	00:38	TRANSFORMER FAULT
112	8-Jul-2020	HASSAN	220	KADUR-DABUSET	KADUR_220	10:16	10:54	00:38	LINE FAULT
113	8-Jul-2020	HASSAN	220	KDUR-SHIMOGA	KADUR_220	10:16	10:54	00:38	LINE FAULT
114	8-Jul-2020	HASSAN	220	MRSSHM-STRP	MRSMSG_220	11:40	14:51	03:11	LINE CLEAR AVAILED
115	8-Jul-2020	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	04:22	12:45	08:23	LINE FAULT
116	8-Jul-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:37	15:05	03:28	LINE CLEAR AVAILED
117	8-Jul-2020	HASSAN	220	VARAHI-SHMG3	varahi_gen	04:21	12:44	08:23	LINE FAULT
118	8-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	21:49 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
119	8-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:44 (7.07.2020)	6:41 (8.07.2020)	18:56 hrs	LINE CHARGED
120	8-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	21:50 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
121	8-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:02 (3.07.2020)	6:37 (8.07.2020)	104:35 hrs	LINE CHARGED
122	8-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:23 (8.07.2020)			LINE OPEN , LINE CLEAR AVAILED
123	8-Jul-2020	HASSAN	66	ALUR-BALEHONNUR	ALDUR_66	11:20	12:04	00:44	LINE FAULT
124	8-Jul-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	20:16	20:31	00:15	TRANSFORMER FAULT
125	8-Jul-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	21:43	22:01	00:18	TRANSFORMER FAULT
126	8-Jul-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	10:48	11:20	00:32	LINE CLEAR AVAILED
127	8-Jul-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	13:19	13:27	00:08	TRANSFORMER FAULT
128	8-Jul-2020	HASSAN	66	HV2	UDAYAPURA_110	15:21	16:27	01:06	TRANSFORMER FAULT
129	8-Jul-2020	HASSAN	66	LV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN , LINE CLEAR AVAILED
130	8-Jul-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	08:11	12:53	04:42	LINE CLEAR AVAILED
131	8-Jul-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	08:11	12:54	04:43	LINE CLEAR AVAILED
132	8-Jul-2020	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	12:42	13:13	0:30	LINE CLEAR AVAILED
133	8-Jul-2020	MYSURU	66	BILIKERE-KHB	NO STATIONS EFFECTED	12:42	13:13	0:30	LINE CLEAR AVAILED
134	8-Jul-2020	MYSURU	66	BILIKERE-KR NAGARA	NO STATIONS EFFECTED	12:22	13:12	0:50	LINE CLEAR AVAILED
135	8-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
136	8-Jul-2020	MYSURU	66	HV2	BETTADHAPURA_66	12:46	12:50	0:03	TRANSFORMER FAULT
137	8-Jul-2020	MYSURU	66	KOPPA 66-NSL	NO STATIONS EFFECTED	9:45	19:05	9:20	LINE CLEAR AVAILED
138	8-Jul-2020	MYSURU	66	VAJAMANGALA -BANNUR	BANNUR_66MALIYURU_66	14:18	14:30	0:12	LINE FAULT
139	8-Jul-2020	TUMKUR	66	ANCHEPALYA 220KV- YEDIYUR(BG NAGAR)	YEDIYUR_66	13:12:42	13:21:33	0:08	LINE FAULT
140	8-Jul-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	02:47:53	02:57:44	0:09	LINE FAULT
141	8-Jul-2020	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES IPP_66	GOLDEN HATCHERIES_IPP_66	08:55:08	17:43:44	8:48	LINE CLEAR AVAILED
142	8-Jul-2020	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	01:45:50	02:02:52	0:17	LINE FAULT
143	8-Jul-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:06:57	13:06:16	1:59	LINE CLEAR AVAILED
144	8-Jul-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	06:10:11	06:21:09	0:10	LINE FAULT
145	8-Jul-2020	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:06:35	13:06:32	1:59	LINE CLEAR AVAILED
146	8-Jul-2020	TUMKUR	66	DEVARAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66	12:37:52	14:18:06	1:40	MAIN SUPPLY FAILURE
147	8-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN , LINE FAULT
148	8-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:54:22	13:39:53	0:45	LINE FAULT
149	8-Jul-2020	TUMKUR	66	HULIYURDURGA- DUNDANAHALLI	DUNDANAHALLI_66	12:50:34	13:12:54	0:22	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
150	8-Jul-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	12:54:55	15:32:27	2:37	LINE CLEAR AVAILED
151	8-Jul-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	12:40:51	15:15:20	2:34	LINE FAULT
152	8-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
153	8-Jul-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	12:37:52	14:18:06	1:40	MAIN SUPPLY FAILURE
154	8-Jul-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	18:16:52	19:19:53	1:03	LINE CLEAR AVAILED
155	8-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
156	8-Jul-2020	TUMKUR	66	TR-2	BELLAVI_66	09:51:03	11:55:22	2:04	LINE CLEAR AVAILED
157	8-Jul-2020	TUMKUR	66	TR-2	BUKKAPATNA_66	12:25:30	12:47:52	0:22	LINE CLEAR AVAILED
158	8-Jul-2020	TUMKUR	66	TR-2	HARIHAR_66	15:09:53	15:50:23	0:40	LINE CLEAR AVAILED
159	8-Jul-2020	TUMKUR	66	TR-2	HONNUDIKE_66	14:23:52	14:34:33	0:10	LINE CLEAR AVAILED
160	8-Jul-2020	TUMKUR	66	TR-2	RANGANATHAPURA_66	12:29:53	16:53:39	4:23	LINE CLEAR AVAILED
161	8-Jul-2020	TUMKUR	110	GUNGURMALE110-KB CROSS220	GUNGURMALE_110	14:16:47	14:23:52	0:07	HAND TRIPPED
162	8-Jul-2020	TUMKUR	110	TR-1	GUNGURMALE_110	14:16:47	14:23:52	0:07	HAND TRIPPED
163	8-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
164	8-Jul-2020	TUMKUR	110	TR-3	GUBBI_110	12:24:20	12:50:26	0:26	LINE CLEAR AVAILED
165	8-Jul-2020	TUMKUR	220	THALLAK 220kv- SEI VENUS DIAMOND IPP 66	SEI VENUS DIAMOND_IPP_66	18:39:41	20:40:02	2:00	LINE CLEAR AVAILED
1	9-Jul-2020	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	12:15	14:50	02:35	LINE CLEAR AVAILED
2	9-Jul-2020	BAGALKOT	110	110/11KV, HV1	KUDACHI_220	07:50	08:04	00:14	TRANSFORMER FAULT
3	9-Jul-2020	BAGALKOT	110	110/11KV, HV1	GULEDAGUDDA_110	11:40	14:17	02:37	LINE CLEAR AVAILED
4	9-Jul-2020	BAGALKOT	110	110/11KV, HV1	GOKAK_110	10:57	19:10	08:13	LINE CLEAR AVAILED
5	9-Jul-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	08:59	12:33	03:34	LINE CLEAR AVAILED
6	9-Jul-2020	BAGALKOT	110	110/11KV, HV2	ITANAL_110	13:01	14:48	01:47	LINE CLEAR AVAILED
7	9-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
8	9-Jul-2020	BAGALKOT	110	BAGALKOT-LOKAPUR	LOKAPUR_110	05:42	06:18	00:36	LINE FAULT
9	9-Jul-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	02:29	02:42	00:13	LINE FAULT
10	9-Jul-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR2	MAMADAPUR_110	02:29	02:42	00:13	LINE FAULT
11	9-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN , LINE CLEAR AVAILED
12	9-Jul-2020	BAGALKOT	110	BIDNAL - NAVALAGUND	NAVALAGUND_110	02:22	02:34	00:12	LINE FAULT
13	9-Jul-2020	BAGALKOT	110	CHIKKODI - ANKALI	ANKALI_110	20:23	20:47	00:24	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
14	9-Jul-2020	BAGALKOT	110	CHIKKODI - NIPPANI(KADAKALAT)	KADAKALAT_110	01:10	01:34	00:24	LINE FAULT
15	9-Jul-2020	BAGALKOT	110	CHIKKODI - NIPPANI(KADAKALAT)	KADAKALAT_110	02:21	02:35	00:14	LINE FAULT
16	9-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN , LINE CLEAR AVAILED
17	9-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
18	9-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)			LINE OPEN , LINE CLEAR AVAILED
19	9-Jul-2020	BAGALKOT	110	KERUR- BADAMI	BADAMI_110	16:52	17:45	00:53	LINE CLEAR AVAILED
20	9-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
21	9-Jul-2020	BAGALKOT	110	KIRUVATTI-UMMACHAGI	STATION NOT AFFECTED	13:20 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
22	9-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
23	9-Jul-2020	BAGALKOT	110	LAXMESHVAR- GADAG1	LAXMESHVAR_110	15:16			LINE OPEN , LINE FAULT
24	9-Jul-2020	BAGALKOT	110	LOKAPUR- SALAHALLI	SALAHALLI_110	05:42	06:41	00:59	LINE FAULT
25	9-Jul-2020	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	23:57 (09.07.2020)			LINE OPEN , LINE FAULT
26	9-Jul-2020	BAGALKOT	110	RAIBAG2- ITANAL	ITANAL_110	18:53	19:19	00:26	LINE FAULT
27	9-Jul-2020	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	9:56 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
28	9-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN , LINE CLEAR AVAILED
29	9-Jul-2020	BAGALKOT	110	SUARNASOUDA- MACHE	MACHE_110	05:55	06:15	00:20	LINE FAULT
30	9-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
31	9-Jul-2020	BAGALKOT	110	VIJAYNAGAR SUGARS-MUNDARGI	MUNDARGI_110	06:09	06:25	00:16	LINE FAULT
32	9-Jul-2020	BAGALKOT	110	VISHWANAT SUGARS- HUKKERI	HUKKERI_110	10:42	11:51	01:09	LINE CLEAR AVAILED
33	9-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
34	9-Jul-2020	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	20:20 (08.07.2020)	7:59 (09.07.2020)	11:39 hrs	LINE CHARGED
35	9-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
36	9-Jul-2020	BAGALKOT	220	BELGAUM - CHIKKODI 1	BELGUAM_220	07:49	08:21	00:32	LINE FAULT
37	9-Jul-2020	BAGALKOT	220	BELGAUM - NARENDRA1	BELGUAM_220	07:49	08:30	00:41	LINE CLEAR AVAILED
38	9-Jul-2020	BAGALKOT	220	BELGAUM -NARENDRA2	BELGUAM_220	07:49	08:30	00:41	LINE FAULT
39	9-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
40	9-Jul-2020	BAGALKOT	220	NARENDRA-AMBEWADI1	NARENDRA_220	17:23 (08.07.2020)	18:19 (09.07.2020)	24:56 hrs	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
41	9-Jul-2020	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	10:36 (08.07.2020)			LINE OPEN , LINE FAULT
42	9-Jul-2020	BAGALKOT	220	NARENDRA-BELGAUM	NARENDRA_220	8:57 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
43	9-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI 220	17:36 (18.05.2020)			LOAD CURTAILMENT
44	9-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI 220	17:39 (18.05.2020)			LOAD CURTAILMENT
45	9-Jul-2020	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	08:47	09:00	00:12	LINE FAULT
46	9-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
47	9-Jul-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	10:19	10:28	00:09	LOAD CHANGE OVER
48	9-Jul-2020	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	12:24	12:29	00:05	LOAD CHANGE OVER
49	9-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:21	19:47	01:25	LINE FAULT
50	9-Jul-2020	BENGALURU	66	DEVANAHALLI - DB PURA 1	NO STATION AFFECTED	18:21	19:49	01:28	LINE FAULT
51	9-Jul-2020	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	13:06	13:12	00:06	LOAD CHANGE OVER
52	9-Jul-2020	BENGALURU	66	ELECTRONIC CITY - YARANDANAHALLI 1 & 2	ELECTRONIC CITY, INFOSYS (EHT)	10:30	10:34	00:04	LOAD CHANGE OVER
53	9-Jul-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	11:21	11:34	00:12	LINE FAULT
54	9-Jul-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	11:34	11:49	00:15	LINE FAULT
55	9-Jul-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	13:37	14:33	00:56	LINE FAULT
56	9-Jul-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	NO STATION AFFECTED	19:59	21:07	01:08	LINE FAULT
57	9-Jul-2020	BENGALURU	66	HV1	IISC	07:29	07:32	00:03	LOAD CHANGE OVER
58	9-Jul-2020	BENGALURU	66	HV1	ATTUR YELAHANKA	12:32	12:33	00:01	LINE CLEAR AVAILED
59	9-Jul-2020	BENGALURU	66	HV1	SANKALGERE	10:15	13:52	03:37	LINE CLEAR AVAILED
60	9-Jul-2020	BENGALURU	66	HV1	HULLENAHALLI	00:00	00:05	00:05	TRANSFORMER FAULT
61	9-Jul-2020	BENGALURU	66	HV1	THAYALUR	12:02	12:05	00:02	LINE CLEAR AVAILED
62	9-Jul-2020	BENGALURU	66	HV1	KANAKAPURA 66	11:21	11:24	00:02	LINE CLEAR AVAILED
63	9-Jul-2020	BENGALURU	66	HV2	IISC	05:50	06:00	00:10	TRANSFORMER FAULT
64	9-Jul-2020	BENGALURU	66	HV2	ST.JOHN WOOD	11:24	11:28	00:04	LINE CLEAR AVAILED
65	9-Jul-2020	BENGALURU	66	HV2	THAYALUR	13:05	13:10	00:04	LINE CLEAR AVAILED
66	9-Jul-2020	BENGALURU	66	HV2	YELAHANKA 220	11:12	11:16	00:04	LINE CLEAR AVAILED
67	9-Jul-2020	BENGALURU	66	IISC - HEBBAL 220	IISC	05:42	05:50	00:08	LOAD CHANGE OVER
68	9-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN , LINE FAULT
69	9-Jul-2020	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	08:46	08:53	00:07	LINE FAULT
70	9-Jul-2020	BENGALURU	66	KORAMANGALA 220 - HAL 2	K & C VALLEY	12:13	12:27	00:14	LINE FAULT
71	9-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	15:03	15:22	00:19	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
72	9-Jul-2020	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	15:03	15:22	00:19	MAIN SUPPLY FAILURE
73	9-Jul-2020	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	15:03	15:23	00:19	MAIN SUPPLY FAILURE
74	9-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
75	9-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
76	9-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN , LINE FAULT
77	9-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN , LINE FAULT
78	9-Jul-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	NO STATION AFFECTED	10:40(6-7-2020)			LINE OPEN , LINE CLEAR AVAILED
79	9-Jul-2020	BENGALURU	66	YEDUMADU - KANAKAPURA	YEDUMADU	08:20	08:32	00:11	LINE FAULT
80	9-Jul-2020	BENGALURU	66	YELAHANKA 220 - LINE4	SAHAKARINAGAR, RAILWAYS (EHT)	07:47	09:49	02:01	LINE FAULT
81	9-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
82	9-Jul-2020	BENGALURU	400	NELAMANGALA 400 - MYSORE 2	NO STATIONS EFFECTED	23:22:00(08-07-2020)	6:28(9.7.2020)	06:54 hrs	LINE CHARGED
83	9-Jul-2020	GULBARGA	66	HV1	KUDLIGI_66	04:34	04:40	00:06	LINE CLEAR AVAILED
84	9-Jul-2020	GULBARGA	110	HV3	BEVOOR_110	23:20	23:24	00:04	TRANSFORMER FAULT
85	9-Jul-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	16:17	19:30	03:13	LINE FAULT
86	9-Jul-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	05:01	06:15	01:14	LINE FAULT
87	9-Jul-2020	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTP SWATERWORKS	00:00	00:05	00:05	LINE FAULT
88	9-Jul-2020	GULBARGA	110	SIDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,BTP SWATERWORKS	01:30	01:40	00:10	LINE FAULT
89	9-Jul-2020	GULBARGA	110	SIDHANOOR-NIRLOOTI	NIRLOOTI_110	01:35	02:15	00:40	LINE FAULT
90	9-Jul-2020	GULBARGA	110	SIDHANOOR-NIRLOOTI	NIRLOOTI_110	09:05	09:20	00:15	LINE FAULT
91	9-Jul-2020	GULBARGA	110	SIDHANOOR-RAICHUR2	MANVI_110,MADLAPUR_110,KUR UDICROSS_110	21:00	21:50	00:50	LINE FAULT
92	9-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN , LINE CLEAR AVAILED
93	9-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN , LINE FAULT
94	9-Jul-2020	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	03:59	04:53	00:54	LINE FAULT
95	9-Jul-2020	HASSAN	66	HASSN220-MALLALI	HASSAN_220	11:03	11:26	00:23	LINE CLEAR AVAILED
96	9-Jul-2020	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	06:53	07:01	00:08	TRANSFORMER FAULT
97	9-Jul-2020	HASSAN	66	HV1	MAGGE_66	21:46	22:46	01:00	TRANSFORMER FAULT
98	9-Jul-2020	HASSAN	66	HV2	HOLEHONNUR_66	13:03	14:22	01:19	LINE CLEAR AVAILED
99	9-Jul-2020	HASSAN	66	LV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN , LINE CLEAR AVAILED
100	9-Jul-2020	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	23:13	23:30	00:17	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
101	9-Jul-2020	HASSAN	110	HV1	NO STN AFFECTED	9:10 (5.07.2020)			LINE OPEN , LINE CLEAR AVAILED
102	9-Jul-2020	HASSAN	110	HV1	SHIVPURA_110	10:35	16:45	06:10	LINE CLEAR AVAILED
103	9-Jul-2020	HASSAN	110	HV2	BARANGI_110	17:29	18:01	00:32	LINE CLEAR AVAILED
104	9-Jul-2020	HASSAN	110	HV2	KONAJE_110	06:48	07:04	00:16	MAIN SUPPLY FAILURE
105	9-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
106	9-Jul-2020	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_110	23:30	23:41	00:11	HAND TRIPPED
107	9-Jul-2020	HASSAN	110	SHIVAPUR-BIRUR	SHIVPURA_110	12:07	14:06	01:59	LINE CLEAR AVAILED
108	9-Jul-2020	HASSAN	110	SHIVAPUR-NERLEKERE	SHIVPURA_110	12:07	14:06	01:59	LINE CLEAR AVAILED
109	9-Jul-2020	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	02:29	11:41	09:12	LINE FAULT
110	9-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	21:49 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
111	9-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	21:50 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
112	9-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	23:23 (8.07.2020)	6:42 (9.07.2020)	7:18 hrs	LINE CHARGED
113	9-Jul-2020	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	16:34	16:42	00:08	LINE FAULT
114	9-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	16:34	16:40	00:06	LINE FAULT
115	9-Jul-2020	MYSURU	66	HV1	HANGLA_66	12:58	13:08	00:10	LINE CLEAR AVAILED
116	9-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
117	9-Jul-2020	MYSURU	66	HV2	ADDIHALLI_66	10:29	11:25	00:55	LINE CLEAR AVAILED
118	9-Jul-2020	MYSURU	66	HV2	MALAVALLI_66	13:20	13:26	00:06	TRANSFORMER FAULT
119	9-Jul-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	09:51	09:54	00:02	HAND TRIPPED
120	9-Jul-2020	MYSURU	66	HV2	SANTHEMARAHALLI_66	15:13	16:02	00:49	LINE CLEAR AVAILED
121	9-Jul-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66 BASARALI_66	00:54	01:01	00:07	LINE FAULT
122	9-Jul-2020	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66	08:52	08:59	00:07	LINE FAULT
123	9-Jul-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	16:09	16:35	00:26	LINE FAULT
124	9-Jul-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	10:28	10:40	00:12	LINE FAULT
125	9-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- DAVANAGERE2	CHITRADURGA_66	09:15	12:33	03:18	LINE CLEAR AVAILED
126	9-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN , LINE FAULT
127	9-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:50	13:06	02:16	HAND TRIPPED
128	9-Jul-2020	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	10:50	12:37	01:47	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
129	9-Jul-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAM AGIRI_66	09:14	12:33	03:19	MAIN SUPPLY FAILURE
130	9-Jul-2020	TUMKUR	66	PANDARAHALLI- SPML _WIND _IPP_66	SPML _WIND _IPP_66	09:14	12:33	03:19	MAIN SUPPLY FAILURE
131	9-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
132	9-Jul-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	14:44	15:01	00:17	LINE CLEAR AVAILED
133	9-Jul-2020	TUMKUR	66	TR-1	HULIYURDURGA_66	14:51	15:15	00:24	TRANSFORMER FAULT
134	9-Jul-2020	TUMKUR	66	TR-1	KUNDUR_66	18:01	18:27	00:25	LINE CLEAR AVAILED
135	9-Jul-2020	TUMKUR	66	TR-1	MATHOD_66	12:44	14:25	01:41	LINE CLEAR AVAILED
136	9-Jul-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	12:17	17:04	04:46	LINE CLEAR AVAILED
137	9-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
138	9-Jul-2020	TUMKUR	66	TR-2	HALUVAGALU_66	08:32	08:34	00:02	TRANSFORMER FAULT
139	9-Jul-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	08:51	09:08	00:16	TRANSFORMER FAULT
140	9-Jul-2020	TUMKUR	66	TR-2	KORATAGERE_66	11:40	12:21	00:40	LINE CLEAR AVAILED
141	9-Jul-2020	TUMKUR	66	TR-2	MATHOD_66	13:31	14:25	00:53	LINE CLEAR AVAILED
142	9-Jul-2020	TUMKUR	66	TR-2	RANGANATHAPURA_66	12:23	17:55	05:32	LINE CLEAR AVAILED
143	9-Jul-2020	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	19:38	19:49	00:11	MAIN SUPPLY FAILURE
144	9-Jul-2020	TUMKUR	110	DODDAGUNI- NITTUR	DODDAGUNI_110	13:19	13:27	00:08	LINE CLEAR AVAILED
145	9-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
146	9-Jul-2020	TUMKUR	220	THALLAK 220kV- SEI VENUS DIAMOND IPP_66	SEI VENUS DIAMOND_IPP_66	18:45	20:36	01:50	LINE CLEAR AVAILED
147	10-Jul-2020	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	13:28	13:52	00:24	LINE CLEAR AVAILED
148	10-Jul-2020	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	12:32	13:45	01:13	LINE CLEAR AVAILED
149	10-Jul-2020	BAGALKOT	110	110/11KV, HV2	SHIROL_110	17:06	17:28	00:22	TRANSFORMER FAULT
150	10-Jul-2020	BAGALKOT	110	110/11KV, HV2	RANEENNUR_220	17:22 (10.07.2020)			LINE OPEN , LINE CLEAR AVAILED
151	10-Jul-2020	BAGALKOT	110	110/11KV,HV 2	GUTTAL_110	12:35	13:02	00:27	HAND TRIPPED
152	10-Jul-2020	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	17:23	17:28	00:05	HAND TRIPPED
153	10-Jul-2020	BAGALKOT	110	110/33KV, HV2	HUBLI_220	11:46	12:38	00:52	LINE CLEAR AVAILED
154	10-Jul-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110&KARADI&AMINA GAD_33	05:57	06:04	00:07	TRANSFORMER FAULT
155	10-Jul-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	03:40	07:53	04:13	HAND TRIPPED
156	10-Jul-2020	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	08:51	09:02	00:11	LINE FAULT
157	10-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
158	10-Jul-2020	BAGALKOT	110	ATHANI-THAVASI	THAVASI_110	06:59	07:07	00:08	LINE FAULT
159	10-Jul-2020	BAGALKOT	110	BAGEWADI- MUKARTIHAL	MUKARTIHAL_110	05:46	07:22	01:36	MAIN SUPPLY FAILURE
160	10-Jul-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	06:34	06:54	00:20	HAND TRIPPED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
161	10-Jul-2020	BAGALKOT	110	BALAJI SUGARS- MUDDEBIHAL	MUDDEBIHAL_110	05:47	06:05	00:18	MAIN SUPPLY FAILURE
162	10-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN , LINE CLEAR AVAILED
163	10-Jul-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN , LINE CLEAR AVAILED
164	10-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
165	10-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	08:52	13:40	04:48	LINE CLEAR AVAILED
166	10-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)			LINE OPEN , LINE CLEAR AVAILED
167	10-Jul-2020	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	09:01	09:06	00:05	LINE FAULT
168	10-Jul-2020	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	22:59	23:09	00:10	LINE FAULT
169	10-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
170	10-Jul-2020	BAGALKOT	110	KIRUVATTI-UMMACHAGI	STATION NOT AFFECTED	13:20 (08.07.2020)	19:55 (10.07.2020)	54:35 hrs	LINE OPEN , LINE CLEAR AVAILED
171	10-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
172	10-Jul-2020	BAGALKOT	110	LAXMESHWAR- GADAG1	LAXMESHWAR_110	15:16 (09.07.2020)	11:56 (10.07.2020)	20:40 hrs	LINE CHARGED
173	10-Jul-2020	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	23:57 (09.07.2020)	0:21 (10.07.2020)	0:24 hrs	LINE CHARGED
174	10-Jul-2020	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	20:26	20:29	00:03	LINE FAULT
175	10-Jul-2020	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	21:47 (10.07.2020)			LINE OPEN , LINE CLEAR AVAILED
176	10-Jul-2020	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	9:56 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
177	10-Jul-2020	BAGALKOT	110	RANNABELAGALI - UTTUR	RANNABELAGALI_110	11:18	11:57	00:39	LINE FAULT
178	10-Jul-2020	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	16:06	16:18	00:12	LINE CLEAR AVAILED
179	10-Jul-2020	BAGALKOT	110	SIRSI220- UMMACHAGI	UMMACHAGI_110	16:20	18:45	02:25	LINE CLEAR AVAILED
180	10-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN , LINE CLEAR AVAILED
181	10-Jul-2020	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	00:02	00:17	00:15	LINE FAULT
182	10-Jul-2020	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	03:56	08:42	04:46	LINE FAULT
183	10-Jul-2020	BAGALKOT	110	SOUDATTI220- RAMDURGA2	RAMDURGA_110	00:02	00:18	00:16	LINE FAULT
184	10-Jul-2020	BAGALKOT	110	SOUDATTI220- RAMDURGA2	RAMDURGA_110	03:56	08:43	04:47	LINE FAULT
185	10-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
186	10-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
187	10-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220	08:49	08:56	00:07	TRANSFORMER FAULT
188	10-Jul-2020	BAGALKOT	220	220/110KV, HV2& LV2	SOUDATTI_220	12:12	12:59	00:47	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
189	10-Jul-2020	BAGALKOT	220	220/110KV, HV2& LV2	MHALINGAPUR_220, RANNABELAGALI_110, BANAHATTI_110, DAVLESHWAR_110,GSML1&2	11:15	11:45	00:30	TRANSFORMER FAULT
190	10-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
191	10-Jul-2020	BAGALKOT	220	GUTTUR- RANEENNUR	STATION NOT AFFECTED RANEENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
192	10-Jul-2020	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	11:25	14:52	03:27	LINE CLEAR AVOIDED
193	10-Jul-2020	BAGALKOT	220	NARENDRA-AMBEWADI2	NARENDRA_220	10:36 (08.07.2020)	14:57 (10.07.2020)	52:51 hrs	LINE CHARGED
194	10-Jul-2020	BAGALKOT	220	NARENDRA-BELGAUM1&2	NARENDRA_220	8:57 (08.07.2020)			LINE OPEN , LINE CLEAR AVOIDED
195	10-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
196	10-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
197	10-Jul-2020	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	11:26	11:37	00:11	LOAD CHANGE OVER
198	10-Jul-2020	BENGALURU	66	ADUGODI - KORAMANGALA 220	ADUGODI, BOSCH (EHT)	15:36	15:45	00:09	LOAD CHANGE OVER
199	10-Jul-2020	BENGALURU	66	AMAR JYOTHI - LEELA VENTURE 1	AMAR JYOTHI	12:25	12:45	00:20	LINE FAULT
200	10-Jul-2020	BENGALURU	66	AMAR JYOTHI - LEELA VENTURE 1	AMAR JYOTHI	14:30	14:45	00:15	LINE FAULT
201	10-Jul-2020	BENGALURU	66	AMAR JYOTHI - LEELA VENTURE 2	AMAR JYOTHI	12:25	12:45	00:20	MAIN SUPPLY FAILURE
202	10-Jul-2020	BENGALURU	66	AMAR JYOTHI - LEELA VENTURE 2	AMAR JYOTHI	14:30	14:45	00:15	LOAD CHANGE OVER
203	10-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
204	10-Jul-2020	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	12:36	12:47	00:10	LINE FAULT
205	10-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	09:58	10:07	00:08	LINE CLEAR AVOIDED
206	10-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	18:20	18:30	00:08	LINE CLEAR AVOIDED
207	10-Jul-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	10:08	10:16	00:08	LINE CLEAR AVOIDED
208	10-Jul-2020	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	10:08	10:16	00:08	LINE CLEAR AVOIDED
209	10-Jul-2020	BENGALURU	66	GOKULA - SRS PEENYA 220	GOKULA, BEL (EHT), HMT (EHT)	22:23	22:32	00:09	LOAD CHANGE OVER
210	10-Jul-2020	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	12:20	12:25	00:05	LOAD CHANGE OVER
211	10-Jul-2020	BENGALURU	66	GOLF LINK - HSR LAYOUT 220	GOLF LINK	14:40	14:45	00:05	LOAD CHANGE OVER
212	10-Jul-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT), VIDYANAGARA	13:44	14:07	00:22	LINE FAULT
213	10-Jul-2020	BENGALURU	66	HV1	RAJANUKUNTE	14:10	15:40	01:30	LINE CLEAR AVOIDED
214	10-Jul-2020	BENGALURU	66	HV1	HEJJALA	02:35	02:45	00:10	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
215	10-Jul-2020	BENGALURU	66	HV1	ANDERSONPET	12:20	12:31	00:11	LINE CLEAR AVAILED
216	10-Jul-2020	BENGALURU	66	HV1	CB PURA URBAN	14:50	15:33	00:43	LINE CLEAR AVAILED
217	10-Jul-2020	BENGALURU	66	HV1	DEVANAHALLI	09:56	16:57	07:01	LINE CLEAR AVAILED
218	10-Jul-2020	BENGALURU	66	HV1	KYALANUR	10:14	10:56	00:42	LINE CLEAR AVAILED
219	10-Jul-2020	BENGALURU	66	HV1	MUDIYANUR	05:28	05:35	00:07	TRANSFORMER FAULT
220	10-Jul-2020	BENGALURU	66	HV2	DEVANAHALLI	09:56	16:57	07:01	LINE CLEAR AVAILED
221	10-Jul-2020	BENGALURU	66	HV2	HOSKOTE 66	11:01	11:26	00:24	LINE CLEAR AVAILED
222	10-Jul-2020	BENGALURU	66	IISC - NRS 220	IISC	07:27	07:36	00:09	LOAD CHANGE OVER
223	10-Jul-2020	BENGALURU	66	IRGAMPALLI - DIBBURAHALLI	NO STATION AFFECTED	03:59	04:36	00:37	LINE FAULT
224	10-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN , LINE FAULT
225	10-Jul-2020	BENGALURU	66	KODIHALLI - HUNSENAHALLI	HUNSENAHALLI, BIJJAHALLI	16:01	18:22	02:21	LINE CLEAR AVAILED
226	10-Jul-2020	BENGALURU	66	LAKSHMIPURA - TADIGOLU	SOMAYAJANAHALLI, LAKSHMIPURA, ADDAGAL	17:10	18:18	01:08	MAIN SUPPLY FAILURE
227	10-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
228	10-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
229	10-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN , LINE FAULT
230	10-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN , LINE FAULT
231	10-Jul-2020	BENGALURU	66	PATHPALYA - SOMANATHPURA	SOMANATHPURA, THIMMAMPALLI	08:27	08:54		LINE CLEAR AVAILED
232	10-Jul-2020	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	12:50	12:55	00:05	LOAD CHANGE OVER
233	10-Jul-2020	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	22:15	22:28	00:13	LOAD CHANGE OVER
234	10-Jul-2020	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	NO STATION AFFECTED	10:40(6-7-2020)	12:36	97:56 hrs	LINE OPEN , LINE CLEAR AVAILED
235	10-Jul-2020	BENGALURU	66	SOUTH CITY - SOMANAHALLI 220	SOUTH CITY	12:53	13:00	00:07	LOAD CHANGE OVER
236	10-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
237	10-Jul-2020	GULBARGA	110	HALBARGA-KAMTHANA	KAMTHANA_110,HABSIKOTE_110	16:43	16:54	00:11	LINE FAULT
238	10-Jul-2020	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110	05:42	05:53	00:11	LINE FAULT
239	10-Jul-2020	GULBARGA	110	HATTI-GAMESHA_IPP	HATTI_110	12:22	13:55	01:33	LINE CLEAR AVAILED
240	10-Jul-2020	GULBARGA	110	HV1	ALIPUR_220	14:25	14:55	00:30	LINE CLEAR AVAILED
241	10-Jul-2020	GULBARGA	110	HV1	CHINCHOLI_110	11:13	12:33	01:20	LINE CLEAR AVAILED
242	10-Jul-2020	GULBARGA	110	HV1	RAJESHWAR_110	01:10	01:17	00:07	TRANSFORMER FAULT
243	10-Jul-2020	GULBARGA	110	HV2	BISIHALLI_110	17:32	17:40	00:08	LINE CLEAR AVAILED
244	10-Jul-2020	GULBARGA	110	HV2	JEEWARGI_110	19:48	20:02	00:14	LINE CLEAR AVAILED
245	10-Jul-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	05:42	05:51	00:09	LINE FAULT
246	10-Jul-2020	GULBARGA	110	KAVITAL-GAMESHA_IPP	KAVITAL_110	14:03	14:07	00:04	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
247	10-Jul-2020	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	04:07	04:14	00:07	LINE CLEAR AVAILED
248	10-Jul-2020	GULBARGA	110	PDHALLI-CLNMAX_IPP	PD_HALLI_110	18:41	19:14	00:33	LINE CLEAR AVAILED
249	10-Jul-2020	GULBARGA	110	SINDHANOOR220- SINDHANOOR1	SINDHANOOR_110	10:46	10:48	00:02	LINE CLEAR AVAILED
250	10-Jul-2020	GULBARGA	110	SINDHANOOR220- SINDHANOOR1	SINDHANOOR_110	17:46	17:53	00:07	LINE CLEAR AVAILED
251	10-Jul-2020	GULBARGA	110	SINDHANOOR220- SINDHANOOR1	SINDHANOOR_110	19:15	19:19	00:04	LINE CLEAR AVAILED
252	10-Jul-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	03:51	04:02	00:11	LINE FAULT
253	10-Jul-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	20:08	20:25	00:17	LINE FAULT
254	10-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN , LINE CLEAR AVAILED
255	10-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN , LINE FAULT
256	10-Jul-2020	HASSAN	66	HV1	MAGGE_66	11:15	13:09	01:54	LINE CLEAR AVAILED
257	10-Jul-2020	HASSAN	66	HV2	RAMPURA_66	15:31	17:13	01:42	LINE CLEAR AVAILED
258	10-Jul-2020	HASSAN	66	LV1	MRSMSG_220	9:10 (5.07.2020)	10:20 (10.07.2020)	121:09 hrs	LINE OPEN , LINE CLEAR AVAILED
259	10-Jul-2020	HASSAN	110	HV1	MRSMSG_220	9:10 (5.07.2020)	10:20 (10.07.2020)	121:09 hrs	LINE OPEN , LINE CLEAR AVAILED
260	10-Jul-2020	HASSAN	110	HV2	ANAVATTI_110	15:56	16:20	00:24	TRANSFORMER FAULT
261	10-Jul-2020	HASSAN	110	HV2	NERALAKERE_110	13:04	14:35	01:31	LINE CLEAR AVAILED
262	10-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
263	10-Jul-2020	HASSAN	110	SINGATG-YAGATI	SINGATGERE_110	14:57	15:34	00:37	LINE CLEAR AVAILED
264	10-Jul-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:32	12:12	01:40	LINE CLEAR AVAILED
265	10-Jul-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:33	12:13	01:40	NFBC ISSUED
266	10-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	21:49 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
267	10-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	21:50 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
268	10-Jul-2020	MYSURU	66	CR NAGARA-KABBALLI	HARVEY_66	08:49	14:38	05:48	LINE FAULT
269	10-Jul-2020	MYSURU	66	HANNUR-AMP SOLAR	NO STATIONS EFFECTED	18:55	19:01	00:05	LINE FAULT
270	10-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	18:55	19:01	00:05	LINE FAULT
271	10-Jul-2020	MYSURU	66	HV1	KHBCOLONY_66	15:02	16:34	01:31	LINE CLEAR AVAILED
272	10-Jul-2020	MYSURU	66	HV1	KRPET_220	13:04	14:41	01:37	LINE CLEAR AVAILED
273	10-Jul-2020	MYSURU	66	HV1	NANJANGUDU_66	12:14	14:28	02:14	LINE CLEAR AVAILED
274	10-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
275	10-Jul-2020	MYSURU	66	KABHALLY-CHAMARAJANAGAR	NO STATIONS EFFECTED	08:49	14:39	05:49	LINE FAULT
276	10-Jul-2020	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	08:49	09:21	00:32	LINE FAULT
277	10-Jul-2020	MYSURU	66	KABHALLY-GUNDLUPETE	KABHALLY_66	09:07	09:21	00:14	LINE FAULT
278	10-Jul-2020	MYSURU	66	KM DODDI-TK HALLI	NO STATIONS EFFECTED	10:30	10:49	00:19	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
279	10-Jul-2020	MYSURU	66	KUNTHUR-DODDARAYAPETE	NO STATIONS EFFECTED	08:49	08:54	00:04	LINE FAULT
280	10-Jul-2020	TUMKUR	66	DAVANGERE66-DAVANGERE SRS	DAVANAGERE_66	11:06	11:08	00:01	HAND TRIPPED
281	10-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN , LINE FAULT
282	10-Jul-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	RANGANATHAPURA_66	17:43	20:11	02:27	LINE CLEAR AVAILED
283	10-Jul-2020	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	RANGANATHAPURA_66	17:43	20:11	02:27	LINE CLEAR AVAILED
284	10-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
285	10-Jul-2020	TUMKUR	66	TR-1	HALURAMESHWARA_66	08:09	08:14	00:05	TRANSFORMER FAULT
286	10-Jul-2020	TUMKUR	66	TR-1	HULIYURDURGA_66	13:25	14:11	00:46	LINE CLEAR AVAILED
287	10-Jul-2020	TUMKUR	66	TR-1	PAVAGADA_220	13:13	13:16	00:02	TRANSFORMER FAULT
288	10-Jul-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	17:49	19:10	01:21	LINE CLEAR AVAILED
289	10-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
290	10-Jul-2020	TUMKUR	66	TR-2	HULIYURDURGA_66	13:28	14:38	01:10	LINE CLEAR AVAILED
291	10-Jul-2020	TUMKUR	66	TR-2	MANGALWADA_66	12:44	15:02	02:18	LINE CLEAR AVAILED
292	10-Jul-2020	TUMKUR	66	TR-2	MANGALWADA_66	17:55	18:00	00:04	HAND TRIPPED
293	10-Jul-2020	TUMKUR	66	TR-2	RANGANATHAPURA_66	16:04	19:10	03:05	LINE CLEAR AVAILED
294	10-Jul-2020	TUMKUR	66	TR-2	SHYLAPURA_66	02:11	04:18	02:06	TRANSFORMER FAULT
295	10-Jul-2020	TUMKUR	66	TR-2	TAVAREKERE(H)_66	10:19	11:54	01:35	LINE CLEAR AVAILED
296	10-Jul-2020	TUMKUR	66	TR-3	DAVANGERE_SRS_220	11:10	12:55	01:45	LINE CLEAR AVAILED
297	10-Jul-2020	TUMKUR	66	TR-3	HARIYABBE_66	10:38	10:42	00:04	TRANSFORMER FAULT
298	10-Jul-2020	TUMKUR	110	TR-1	MAYASANDRA_110	09:48	10:14	00:26	TRANSFORMER FAULT
299	10-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
300	10-Jul-2020	TUMKUR	220	TR-3	DAVANGERE_SRS_220	11:10	12:55	01:44	LINE CLEAR AVAILED
301	11-Jul-2020	BAGALKOT	110	110/11KV, HV2	RANEENNUR_220	17:22 (10.07.2020)	17:26 (11.07.2020)	24:04 hrs	LINE CHARGED
302	11-Jul-2020	BAGALKOT	110	110/11KV,HV1	AREMALLAPUR_110	08:13	14:45	06:32	TRANSFORMER FAULT
303	11-Jul-2020	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	11:53	12:04	00:11	LINE CLEAR AVAILED
304	11-Jul-2020	BAGALKOT	110	110/33KV,HV3	MAMADAPUR(B)_110, DEVARGENNUR_33	13:21	17:23	04:02	LINE CLEAR AVAILED
305	11-Jul-2020	BAGALKOT	110	AMBEWADI-NK1	KAVLWAD_110	09:52	18:29	08:37	LINE FAULT
306	11-Jul-2020	BAGALKOT	110	AMBEWADI-NK2	HALIYAL_110	10:35	18:31	07:56	LINE CLEAR AVAILED
307	11-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
308	11-Jul-2020	BAGALKOT	110	BAGEWADI- MUKARTIHAL	MUKARTIHAL_110	10:20	11:00	00:40	MAIN SUPPLY FAILURE
309	11-Jul-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	10:09	10:55	00:46	HAND TRIPPED
310	11-Jul-2020	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	18:45	18:56	00:11	HAND TRIPPED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	11-Jul-2020	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	10:48	10:57	00:09	HAND TRIPPED
312	11-Jul-2020	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	19:01	19:05	00:04	HAND TRIPPED
313	11-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN , LINE CLEAR AVOIDED
314	11-Jul-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	23:15	23:31	00:16	LINE FAULT
315	11-Jul-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN , LINE CLEAR AVOIDED
316	11-Jul-2020	BAGALKOT	110	HALIYAL-GMR SUGARS	HALIYAL_110	10:41	12:43	02:02	HAND TRIPPED
317	11-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN , LINE CLEAR AVOIDED
318	11-Jul-2020	BAGALKOT	110	JAMAKHANDI-SHIROL	STATION NOT AFFECTED SHIROL_110	10:41 (24.06.2020)	12:59 (11.07.2020)	410:18 hrs	LINE CHARGED
319	11-Jul-2020	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	13:38	13:40	00:02	LINE FAULT
320	11-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
321	11-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN , LINE CLEAR AVOIDED
322	11-Jul-2020	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	21:47 (10.07.2020)	7:26 (11.07.2020)	09:39 hrs	LINE CHARGED
323	11-Jul-2020	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	9:56 (08.07.2020)	17:26 (11.07.2020)	79:30 hrs	LINE CHARGED
324	11-Jul-2020	BAGALKOT	110	SHIRGUPPI- BILAGI	BILAGI_110	06:28	06:40	00:12	LINE FAULT
325	11-Jul-2020	BAGALKOT	110	SIRSI220- UMMACHAGI	UMMACHAGI_110	12:11	15:57	03:46	HAND TRIPPED
326	11-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN , LINE CLEAR AVOIDED
327	11-Jul-2020	BAGALKOT	110	SUPA 1&2-AMBEWADI	AMBEWADI_220	10:35	12:11	01:36	LINE CLEAR AVOIDED
328	11-Jul-2020	BAGALKOT	110	UMMACHAGI- KIRUVATTI	UMMACHAGI_110	09:06	10:19	01:13	HAND TRIPPED
329	11-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN , LINE CLEAR AVOIDED
330	11-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
331	11-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, UGARKHUD_110	13:15	13:23	00:08	TRANSFORMER FAULT
332	11-Jul-2020	BAGALKOT	220	220/110KV, HV2& LV2	MHALINGAPUR_220, RANNABELAGALI_110, BANAHATTI_110, DAVLESHWAR_110,GSML1&2	12:20	12:48	00:28	HAND TRIPPED
333	11-Jul-2020	BAGALKOT	220	220/110KV, HV2& LV2	MHALINGAPUR_220, RANNABELAGALI_110, BANAHATTI_110, DAVLESHWAR_110,GSML1&2	14:19	15:15	00:56	HAND TRIPPED
334	11-Jul-2020	BAGALKOT	220	ATRIA1-BAGEWADI	BAGEWADI_220	14:08	14:12	00:04	HAND TRIPPED
335	11-Jul-2020	BAGALKOT	220	ATRIA2-BAGEWADI	BAGEWADI_220	17:42	18:01	00:19	HAND TRIPPED
336	11-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
337	11-Jul-2020	BAGALKOT	220	BAGEWADI-BIJAPUR 1	BAGEWADI_220	13:52	18:24	04:32	HAND TRIPPED
338	11-Jul-2020	BAGALKOT	220	BAGEWADI-RBRK	BAGEWADI_220	13:29	13:38	00:09	LINE FAULT
339	11-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
340	11-Jul-2020	BAGALKOT	220	NARENDRA-BELGAUM1&2	NARENDRA_220	8:57 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
341	11-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
342	11-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
343	11-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
344	11-Jul-2020	BENGALURU	66	CHELUR - YENNIGADALE	CHELUR	17:49	17:59	00:09	LINE CLEAR AVAILED
345	11-Jul-2020	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	09:54	09:55	00:01	LINE CLEAR AVAILED
346	11-Jul-2020	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA, ALAMBIC(EHT)	15:05	15:56	00:51	LINE CLEAR AVAILED
347	11-Jul-2020	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	00:38	00:39	00:01	LOAD CHANGE OVER
348	11-Jul-2020	BENGALURU	66	HV1	KEMBODI	09:10	09:50	00:40	LINE CLEAR AVAILED
349	11-Jul-2020	BENGALURU	66	HV1	SIDDALAGATTA	22:43	23:15	00:31	TRANSFORMER FAULT
350	11-Jul-2020	BENGALURU	66	HV1	MUDIYANUR	11:05	11:45	00:40	TRANSFORMER FAULT
351	11-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN , LINE FAULT
352	11-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A	05:32	05:48	00:15	LINE FAULT
353	11-Jul-2020	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A	08:45	08:50	00:05	LINE FAULT
354	11-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
355	11-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN , LINE CLEAR AVAILED
356	11-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN , LINE FAULT
357	11-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTc	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN , LINE FAULT
358	11-Jul-2020	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	00:45	00:50	00:05	LOAD CHANGE OVER
359	11-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
360	11-Jul-2020	GULBARGA	110	HUMNABAD-MANNA-EK-HALLI	MANNA-EK-HALLI_110	07:02	07:30	00:28	LINE FAULT
361	11-Jul-2020	GULBARGA	110	HUMNABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_11 0,MANTHAL_110	07:02	07:33	00:31	LINE FAULT
362	11-Jul-2020	GULBARGA	110	HV3	BEVOOR_110	05:58	06:18	00:20	TRANSFORMER FAULT
363	11-Jul-2020	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	01:22	01:33	00:11	LINE FAULT
364	11-Jul-2020	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	02:37	02:54	00:17	LINE FAULT
365	11-Jul-2020	GULBARGA	110	KUSHTAGI-ILKAL	ILKAL_110	05:53	06:14	00:21	LINE FAULT
366	11-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	01:50	07:04	05:14	LINE FAULT
367	11-Jul-2020	GULBARGA	220	HV1	HUMNABAD_220	07:02	07:15	00:13	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
368	11-Jul-2020	GULBARGA	220	HV1	HALBARGA_220	08:53	09:02	00:09	TRANSFORMER FAULT
369	11-Jul-2020	GULBARGA	220	HV2	SIDHANOOR_220	01:40	02:54	01:14	TRANSFORMER FAULT
370	11-Jul-2020	GULBARGA	220	HV2	SIDHANOOR_220	04:01	04:14	00:13	TRANSFORMER FAULT
371	11-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN , LINE CLEAR AVAILED
372	11-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN , LINE FAULT
373	11-Jul-2020	GULBARGA	220	RTPS-LINGASUGUR1&2	RTPS_220	05:40 (11.7.20)			LINE OPEN , LINE CLEAR AVAILED
374	11-Jul-2020	GULBARGA	220	RTPS-LINGASUGUR3	RTPS_220	20:58 (11.7.20)			LINE OPEN , LINE CLEAR AVAILED
375	11-Jul-2020	GULBARGA	220	SIDHANOOR220-LINGAPUR	SIDHANOOR_220	01:34	01:59	00:25	LINE FAULT
376	11-Jul-2020	GULBARGA	220	SIDHANOOR220-LINGAPUR	SIDHANOOR_220	02:48	03:07	00:19	LINE CLEAR AVAILED
377	11-Jul-2020	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	17:59	18:40	00:41	TRANSFORMER FAULT
378	11-Jul-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	11:49	14:33	02:44	LINE CLEAR AVAILED
379	11-Jul-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	11:49	14:33	02:44	LINE CLEAR AVAILED
380	11-Jul-2020	HASSAN	110	HV1	KULASHEKARA_110	10:01	13:26	03:25	LINE CLEAR AVAILED
381	11-Jul-2020	HASSAN	110	HV2	KULASHEKARA_110	10:01	13:26	03:25	LINE CLEAR AVAILED
382	11-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
383	11-Jul-2020	HASSAN	110	KAVOOR-BANTWAL	KAVOOR_220	11:05	13:44	02:39	LINE CLEAR AVAILED
384	11-Jul-2020	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	10:03	13:18	03:15	LINE CLEAR AVAILED
385	11-Jul-2020	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	10:01	13:18	03:17	LINE CLEAR AVAILED
386	11-Jul-2020	HASSAN	220	MRSSHM-SHARAVATHY4	MRS MG_220	14:01	15:41	01:40	LINE FAULT
387	11-Jul-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	14:01	15:41	01:40	LINE FAULT
388	11-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	21:49 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
389	11-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:59 (1.07.2020)			LINE OPEN , LINE FAULT
390	11-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	01:55	06:19	04:24	LINE FAULT
391	11-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	21:50 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
392	11-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
393	11-Jul-2020	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	09:50	10:03	00:12	LINE FAULT
394	11-Jul-2020	TUMKUR	66	CHITRADURGA 220kV- CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	10:10	12:48	02:37	LINE CLEAR AVAILED
395	11-Jul-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	10:00	12:43	02:43	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
396	11-Jul-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	15:52	16:13	00:20	LINE CLEAR AVAILED
397	11-Jul-2020	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, RAMAGIRI_66, CHI TRAHALLI_66	10:00	12:46	02:46	LINE CLEAR AVAILED
398	11-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	10:19	12:43	02:24	LINE CLEAR AVAILED
399	11-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	10:14	12:47	02:33	LINE CLEAR AVAILED
400	11-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	10:14	12:46	02:32	LINE CLEAR AVAILED
401	11-Jul-2020	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	10:13	12:46	02:32	LINE CLEAR AVAILED
402	11-Jul-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	08:52	09:06	00:13	LINE FAULT
403	11-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN , LINE FAULT
404	11-Jul-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66, HDPURA_66, RAM AGIRI_66	08:29	09:55	01:26	LINE FAULT
405	11-Jul-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66, HDPURA_66, RAM AGIRI_66	12:53	14:50	01:57	LINE CLEAR AVAILED
406	11-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
407	11-Jul-2020	TUMKUR	66	TR-1	TALKERE_110	19:17	19:31	00:14	HAND TRIPPED
408	11-Jul-2020	TUMKUR	66	TR-1	BENNEHALLI_66	09:53	10:11	00:17	TRANSFORMER FAULT
409	11-Jul-2020	TUMKUR	66	TR-1	CHITRADURGA_66	10:14	12:44	02:30	LINE CLEAR AVAILED
410	11-Jul-2020	TUMKUR	66	TR-1	RANGANATHAPURA_66	11:09	12:40	01:31	LINE CLEAR AVAILED
411	11-Jul-2020	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	10:01	12:36	02:35	LINE CLEAR AVAILED
412	11-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
413	11-Jul-2020	TUMKUR	66	TR-2	CHITRADURGA_66	10:14	12:46	02:32	LINE CLEAR AVAILED
414	11-Jul-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	18:30	18:59	00:28	LINE CLEAR AVAILED
415	11-Jul-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	15:51	16:03	00:12	TRANSFORMER FAULT
416	11-Jul-2020	TUMKUR	66	TR-2	RANGANATHAPURA_66	11:08	12:36	01:27	LINE CLEAR AVAILED
417	11-Jul-2020	TUMKUR	66	TR-3	CHITRADURGA_220	11:33	11:38	00:05	LINE CLEAR AVAILED
418	11-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
419	12-Jul-2020	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	13:41	14:01	00:20	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
420	12-Jul-2020	BAGALKOT	110	110/33KV,HV2	HUNGUND_110&KARADI&AMINA GAD_33	13:50	13:54	00:04	TRANSFORMER FAULT
421	12-Jul-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	00:09	09:04	08:55	HAND TRIPPED
422	12-Jul-2020	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	00:07	00:42	00:35	LINE FAULT
423	12-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
424	12-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT EFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN , LINE CLEAR AVAILED
425	12-Jul-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN , LINE CLEAR AVAILED
426	12-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
427	12-Jul-2020	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	00:25	00:29	00:04	LINE FAULT
428	12-Jul-2020	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	05:09	05:14	00:05	LINE FAULT
429	12-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
430	12-Jul-2020	BAGALKOT	110	KUDACHI220- AINAPUR	AINAPUR_110	00:07	00:24	00:17	LINE FAULT
431	12-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
432	12-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT EFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN , LINE CLEAR AVAILED
433	12-Jul-2020	BAGALKOT	110	VADAGOAN- BELGAUM	VADAGOAN_110	02:27	02:49	00:22	LINE FAULT
434	12-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
435	12-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT EFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
436	12-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, AINAPUR_110	00:07	00:18	00:11	TRANSFORMER FAULT
437	12-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220	04:48	05:02	00:14	TRANSFORMER FAULT
438	12-Jul-2020	BAGALKOT	220	220/110KV, HV2& LV2	MHALINGAPUR_220, BANAHATTI_110, GSML1&2_110	12:29	13:30	01:01	HAND TRIPPED
439	12-Jul-2020	BAGALKOT	220	ADPH 2-BAGEWADI	BAGEWADI_220	10:59			LOAD CURTAILMENT
440	12-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
441	12-Jul-2020	BAGALKOT	220	GADAG-DONI 1&2	GADAG_220	10:16	10:17	00:01	LOAD CURTAILMENT
442	12-Jul-2020	BAGALKOT	220	GADAG-HARTI 1&2	GADAG_220	09:46	09:51	00:05	LOAD CURTAILMENT
443	12-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT EFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
444	12-Jul-2020	BAGALKOT	220	NARENDRA-BELGAUM1&2	NARENDRA_220	8:57 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
445	12-Jul-2020	BAGALKOT	220	SHARAVATHY1&2- SIRSI	SIRSI_220	12:16	15:46	03:30	NFBC ISSUED
446	12-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)	14:20 (12.07.2020)	1316:44 hrs	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
447	12-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
448	12-Jul-2020	BENGALURU	66	ATTUR YELAHANKA - DG 3	ATTUR YELAHANKA	16:16	16:30	00:14	LINE FAULT
449	12-Jul-2020	BENGALURU	66	ATTUR YELAHANKA - DG 4	ATTUR YELAHANKA	17:45	17:49	00:04	LOAD CHANGE OVER
450	12-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
451	12-Jul-2020	BENGALURU	66	HV1	BYADRAHALLI	10:40	10:45	00:05	LINE CLEAR AVOIDED
452	12-Jul-2020	BENGALURU	66	HV1	NARASAPURA	11:05	13:08	02:03	LINE CLEAR AVOIDED
453	12-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN , LINE FAULT
454	12-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)			LINE OPEN , LINE CLEAR AVOIDED
455	12-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)			LINE OPEN , LINE CLEAR AVOIDED
456	12-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN , LINE FAULT
457	12-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTC	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN , LINE FAULT
458	12-Jul-2020	BENGALURU	66	SURYANAGAR - YERANDANAHALLI 220	NO STATION AFFECTED	18:02	18:53	00:50	LINE FAULT
459	12-Jul-2020	BENGALURU	66	SURYANAGAR - YERANDANAHALLI 220	NO STATION AFFECTED	11:40	12:13	00:33	LINE FAULT
460	12-Jul-2020	BENGALURU	66	SURYANAGAR - YERANDANAHALLI 220	SURYANAGAR	12:12	12:17	00:05	LINE CLEAR AVOIDED
461	12-Jul-2020	BENGALURU	66	SURYANAGAR - YERANDANAHALLI 220	SURYANAGAR	18:53	18:58	00:05	LINE CLEAR AVOIDED
462	12-Jul-2020	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	18:02	18:15	00:13	LOAD CHANGE OVER
463	12-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN,LINE CLEAR AVALIED
464	12-Jul-2020	GULBARGA	66	ITTAGI-HIREHADAGLI1	HIREHADAGLI_66	18:06	18:16	00:10	LINE FAULT
465	12-Jul-2020	GULBARGA	110	BETAGERA-KESHAVCEMENT_IPP	BETAGERA_110	08:37	10:50	02:13	LINE CLEAR AVOIDED
466	12-Jul-2020	GULBARGA	110	HATTI-GAMESHAWIND_IPP	HATTI_110	15:24	15:43	00:19	LINE FAULT
467	12-Jul-2020	GULBARGA	110	HV1	SHAHAPUR_220	14:52	15:09	00:17	TRANSFORMER FAULT
468	12-Jul-2020	GULBARGA	110	HV2	SHAHAPUR_220	01:00	02:45	01:45	TRANSFORMER FAULT
469	12-Jul-2020	GULBARGA	110	HV2	SHAHAPUR_220	07:15	07:35	00:20	LINE CLEAR AVOIDED
470	12-Jul-2020	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	05:45	05:55	00:10	LINE FAULT
471	12-Jul-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	20:07	20:17	00:10	LINE FAULT
472	12-Jul-2020	GULBARGA	110	MALLAT-KAVITHAL	KAVITHAL_110	05:38	05:48	00:10	LINE FAULT
473	12-Jul-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP, HUNASAGI_110,ASKI_110	04:20	04:25	00:05	LINE FAULT
474	12-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	03:40	04:10	00:30	LINE FAULT
475	12-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	04:10	08:20	04:10	LINE CLEAR AVOIDED
476	12-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN , LINE CLEAR AVOIDED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
477	12-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN , LINE FAULT
478	12-Jul-2020	GULBARGA	220	RTPS-LINGASUGUR1&2	RTPS_220	5:40(11.07.2020)	16:00(12.7.2020)	34:20HRS	LINE CHARGED
479	12-Jul-2020	GULBARGA	220	RTPS-LINGASUGUR3	RTPS_220	20:58(11.07.2020)	10:17(12.7.2020)	13:19HRS	LINE CHARGED
480	12-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
481	12-Jul-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	13:37	16:35	02:58	LINE FAULT
482	12-Jul-2020	HASSAN	220	SHRAVITY-SHIMOGA3	sharavathy_gen	11:23	14:31	03:08	LINE FAULT
483	12-Jul-2020	HASSAN	220	SHRAVITY-SHIMOGA4	sharavathy_gen	11:23	15:08	03:45	LINE FAULT
484	12-Jul-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:23 (12.07.2020)			LINE OPEN , LINE FAULT
485	12-Jul-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	11:23 (12.07.2020)			LINE OPEN , LINE FAULT
486	12-Jul-2020	HASSAN	220	SHRAVITY-TALAGUPPA 2	sharavathy_gen	11:23	15:11	03:48	LINE FAULT
487	12-Jul-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	13:37	16:35	02:58	LINE FAULT
488	12-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	21:49 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
489	12-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	21:50 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
490	12-Jul-2020	HASSAN	400	UPCL-HASSAN2	upcl_gen	18:01 (11.07.2020)			LINE OPEN , LINE CLEAR AVAILED
491	12-Jul-2020	MYSURU	66	HV1	KRPET_66	08:23	09:16	00:52	LINE CLEAR AVAILED
492	12-Jul-2020	MYSURU	66	HV1	NANJANGUDU_66	17:18	19:11	01:52	LINE CLEAR AVAILED
493	12-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
494	12-Jul-2020	MYSURU	66	HV3	KUSHALNAGARA_220	07:15	07:26	00:10	TRANSFORMER FAULT
495	12-Jul-2020	TUMKUR	66	ANTHRASANAHALLI 220KV-MELEKOTE	DODDASARANGI_66,MELKOTE_66 , BADDIHALLI_66, HONNUDIKE 66, HIREHALLY 66	06:14	07:03	00:48	LINE FAULT
496	12-Jul-2020	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	13:42	15:52	02:09	MAIN SUPPLY FAILURE
497	12-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN , LINE FAULT
498	12-Jul-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	07:22	17:35	10:12	HAND TRIPPED
499	12-Jul-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	09:33	09:42	00:08	HAND TRIPPED
500	12-Jul-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	18:14	18:27	00:12	HAND TRIPPED
501	12-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
502	12-Jul-2020	TUMKUR	66	TR-1	DEVARAHALLI_66	13:42	15:52	02:09	MAIN SUPPLY FAILURE
503	12-Jul-2020	TUMKUR	66	TR-1	SOKKE_66	09:34	09:42	00:07	HAND TRIPPED
504	12-Jul-2020	TUMKUR	66	TR-1	SOKKE_66	18:15	18:18	00:03	HAND TRIPPED
505	12-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
506	12-Jul-2020	TUMKUR	66	TR-2	HARIYABBE_66	11:05	11:12	00:06	TRANSFORMER FAULT
507	12-Jul-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	05:52	06:04	00:12	TRANSFORMER FAULT
508	12-Jul-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	09:51	10:01	00:10	TRANSFORMER FAULT
509	12-Jul-2020	TUMKUR	66	TR-2	TELADI_66	16:29	17:04	00:35	LINE CLEAR AVAILED
510	12-Jul-2020	TUMKUR	66	TR-2	URDIGERE_66	10:33	16:25	05:52	LINE CLEAR AVAILED
511	12-Jul-2020	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	10:37	16:25	05:47	LINE CLEAR AVAILED
512	12-Jul-2020	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	10:37	16:27	05:49	LINE CLEAR AVAILED
513	12-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
514	12-Jul-2020	TUMKUR	110	TR-2	HULIYAR_110	16:23	17:15	00:52	HAND TRIPPED
1	13-Jul-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN , LINE FAULT
2	13-Jul-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	18:51 (12.07.2020)			LOAD CURTAILMENT
3	13-Jul-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN , LINE FAULT
4	13-Jul-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
5	13-Jul-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN , LINE CLEAR AVAILED
6	13-Jul-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN , LINE CLEAR AVAILED
7	13-Jul-2020	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	15:16 (20.06.2020)			LINE OPEN , LINE CLEAR AVAILED
8	13-Jul-2020	BAGALKOT	110	SIRSI220-SIRSI 1& 2	STATION NOT AFFECTED SIRSI_220	16:46 (25.06.2020)			LINE OPEN , LINE CLEAR AVAILED
9	13-Jul-2020	BAGALKOT	220	220/110KV, HV1&LV1	STATION NOT AFFECTED MAHALINGAPUR_220	0:20 (26.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
10	13-Jul-2020	BAGALKOT	110	HATTARGI-HUKKERI	STATION NOT EFFECTED HATTARGI_110	18:16 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
11	13-Jul-2020	BAGALKOT	110	ANKALAGI-HIDIKAL DAM	STATION NOT EFFECTED HIDIKAL DAM_110	18:14 (02.07.2020)			LINE OPEN , LINE CLEAR AVAILED
12	13-Jul-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	STATION NOT AFFECTED RANEBENNUR_220	16:16 (03.07.2020)			LOAD CURTAILMENT
13	13-Jul-2020	BAGALKOT	220	NARENDRA-BELGAUM1&2	NARENDRA_220	8:57 (08.07.2020)			LINE OPEN , LINE CLEAR AVAILED
14	13-Jul-2020	BAGALKOT	220	ADPH 2-BAGEWADI	BAGEWADI_220	10:59 (12.07.2020)			LOAD CURTAILMENT
15	13-Jul-2020	BAGALKOT	110	ATHANI220 - THAVASI	THAVASI_110	6:33	6:43	0:10	LINE FAULT
16	13-Jul-2020	BAGALKOT	110	110/11KV, HV2	BAGALKOT_110	10:50	12:49	1:59	LINE CLEAR AVAILED
17	13-Jul-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	11:32	11:49	0:17	LINE CLEAR AVAILED
18	13-Jul-2020	BAGALKOT	110	BAGEWADI-NIDAGUNDI	NIDAGUNDI_110	13:42	13:55	0:13	HAND TRIPPED
19	13-Jul-2020	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	16:09	17:09	1:00	LINE CLEAR AVAILED
20	13-Jul-2020	BAGALKOT	220	220/110KV,HV1&LV1	BIJAPUR_220	13:06	13:36	0:30	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
21	13-Jul-2020	BAGALKOT	400	DHONI-GUTTUR	DHONI_400	11:01	18:11	7:10	LINE CLEAR AVAIED
22	13-Jul-2020	BAGALKOT	400	400/220KV,ICT 1	DHONI_400 & 220KV	11:03	18:02	6:59	LINE CLEAR AVAIED
23	13-Jul-2020	BAGALKOT	110	BELGAUM-UDYAMBAG	UDYMBAG_110	06:41	7:11	0:30	LINE FAULT
24	13-Jul-2020	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	6:41	7:13	0:32	LINE FAULT
25	13-Jul-2020	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR-110	11:48 (13.07.02020)			LINE OPEN , LINE CLEAR AVAIED
26	13-Jul-2020	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	11:26	14:54	3:28	NFBC ISSUED
27	13-Jul-2020	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	17:41	17:55	0:14	HAND TRIPPED
28	13-Jul-2020	BAGALKOT	220	SHARAVATHI1-SIRSI	SIRSI_220	8:49	14:37	5:48	LINE CLEAR AVAIED
29	13-Jul-2020	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	14:33 (13.07.2020)			LINE OPEN , LINE CLEAR AVAIED
30	13-Jul-2020	BAGALKOT	110	ILKAL1- HUNGUND	HUNGUND_110	5:55	6:29	0:34	LINE FAULT
31	13-Jul-2020	BAGALKOT	110	ILKAL1- HUNGUND	HUNGUND_110	5:55	6:31	0:36	LINE FAULT
32	13-Jul-2020	BAGALKOT	110	HUNGUND- KUDAL SANGAM	KUDAL SANGAM_110	5:55	6:36	0:41	LINE FAULT
33	13-Jul-2020	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	12:22	12:29	0:07	LINE FAULT
34	13-Jul-2020	BAGALKOT	110	ITANAL- HIDIKAL	HIDIKAL_110	12:22	12:29	0:07	LINE FAULT
35	13-Jul-2020	BAGALKOT	110	110/11KV, HV2	HIDIKAL_110	12:30	13:56	1:26	LINE CLEAR AVAIED
36	13-Jul-2020	BAGALKOT	110	110/33KV, HV3	HIDIKAL_110, KOLIGUDDA_33, ALAGAWADI 33	12:20	15:50	3:30	LINE CLEAR AVAIED
37	13-Jul-2020	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	12:40	13:51	1:11	LINE CLEAR AVAIED
38	13-Jul-2020	BAGALKOT	110	ITANAL- HIDIKAL	HIDIKAL_110	12:40	13:51	1:11	LINE CLEAR AVAIED
39	13-Jul-2020	BAGALKOT	110	MAHALINGAPUR- HIDIKAL	HIDIKAL_110	15:51	15:54	0:03	HAND TRIPPED
40	13-Jul-2020	BAGALKOT	110	ITANAL- HIDIKAL	HIDIKAL_110	15:51	15:54	0:03	HAND TRIPPED
41	13-Jul-2020	BENGALURU	66	PALLICHERLU - GANJIGUNTE	PALLICHERLU	02:50	02:55	00:05	MAIN SUPPLY FAILURE
42	13-Jul-2020	BENGALURU	66	HV2	SARJAPURA 220	11:36	13:48	02:11	LINE CLEAR AVAIED
43	13-Jul-2020	BENGALURU	66	HV1	MITTEMARI 220	15:35	16:01	00:26	LINE CLEAR AVAIED
44	13-Jul-2020	BENGALURU	66	HV1	MITTEMARI 220	15:35	16:01	00:26	LINE CLEAR AVAIED
45	13-Jul-2020	BENGALURU	66	HV2	AMARJYOTHI	14:01	16:20	02:18	TRANSFORMER FAULT
46	13-Jul-2020	BENGALURU	220	HV1	YERANDANAHALLI 2200	04:03	08:44	04:41	TRANSFORMER FAULT
47	13-Jul-2020	BENGALURU	66	HV2	YERANDANAHALLI 2200	04:03	04:19	00:16	MAIN SUPPLY FAILURE
48	13-Jul-2020	BENGALURU	66	HV1	GOKULA	13:31	13:34	00:03	LINE CLEAR AVAIED
49	13-Jul-2020	BENGALURU	66	HV2	GOKULA	10:01	10:05	00:04	LINE CLEAR AVAIED
50	13-Jul-2020	BENGALURU	66	HV1	AVANI	13:53	16:11	02:18	LINE CLEAR AVAIED
51	13-Jul-2020	BENGALURU	66	HV2	AVANI	12:05	12:10	00:05	LINE CLEAR AVAIED
52	13-Jul-2020	BENGALURU	66	HV1	BAIRAKURU	13:35	14:06	00:31	LINE CLEAR AVAIED
53	13-Jul-2020	BENGALURU	66	HV2	KODIHALLI KANAKAPURA	06:04	06:14	00:09	TRANSFORMER FAULT
54	13-Jul-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:41	13:51	00:10	LINE CLEAR AVAIED
55	13-Jul-2020	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	14:35	14:47	00:11	LINE CLEAR AVAIED
56	13-Jul-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	11:37	11:44	00:07	LINE CLEAR AVAIED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
57	13-Jul-2020	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:36	13:52	00:15	LINE CLEAR AVAILED
58	13-Jul-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	15:16	15:22	00:05	LINE CLEAR AVAILED
59	13-Jul-2020	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	16:16	16:26	00:09	LINE CLEAR AVAILED
60	13-Jul-2020	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	05:55	06:02	00:06	LINE FAULT
61	13-Jul-2020	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	05:55	06:02	00:06	LINE FAULT
62	13-Jul-2020	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	12:54	13:00	00:06	LOAD CHANGE OVER
63	13-Jul-2020	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT)	04:03	04:26	00:23	MAIN SUPPLY FAILURE
64	13-Jul-2020	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	12:26	13:16	00:49	LINE CLEAR AVAILED
65	13-Jul-2020	BENGALURU	66	GOKULA - HMT (EH)	HMT (EHT)	12:00	12:43	00:43	LINE CLEAR AVAILED
66	13-Jul-2020	BENGALURU	66	HAL 220 - ADUGODI 2	GOLF LINKS, AMARJYOTHI	14:00	14:04	00:04	LINE FAULT
67	13-Jul-2020	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:52	13:26	00:33	LINE FAULT
68	13-Jul-2020	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	15:04	16:39	01:34	LOAD CHANGE OVER
69	13-Jul-2020	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	16:37	16:39	00:02	LOAD CHANGE OVER
70	13-Jul-2020	BENGALURU	66	SOUTH CITY - BTM 4TH PHASE	SOUTH CITY	17:45	17:53	00:08	LOAD CHANGE OVER
71	13-Jul-2020	BENGALURU	66	AVANI - KOLAR 220	AVANI, MULBAGAL	15:09	16:24	01:15	LINE CLEAR AVAILED
72	13-Jul-2020	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	11:46	11:48	00:01	LOAD CHANGE OVER
73	13-Jul-2020	BENGALURU	66	CHANDAPURA - SARJAPURA 220	CHANDAPURA	15:19	15:22	00:03	LOAD CHANGE OVER
74	13-Jul-2020	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	16:18	16:50	00:32	LINE FAULT
75	13-Jul-2020	BENGALURU	220	HV2	MANYATHA TECH PARK	6:50(30/06/2020)			TRANSFORMER OPEN,LINE CLEAR AVAILED
76	13-Jul-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN , LINE FAULT
77	13-Jul-2020	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	NO STATION AFFECTED	1:45:00(25-6-2020)	9:20(13.7.20)	463:23 hrs	LINE CHARGED
78	13-Jul-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	NO STATION AFFECTED	1:49:00(25-6-2020)	9:20(13.7.20)	463:23 hrs	LINE CHARGED
79	13-Jul-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN , LINE FAULT
80	13-Jul-2020	BENGALURU	66	NIMHANS 220 - BMTCL	NO STATION AFFECTED	17:27(12/06/2020)			LINE OPEN , LINE FAULT
81	13-Jul-2020	BENGALURU	66	NIMHANS 220 - ADUGODI	NO STATION AFFECTED	13:47 (4-07-2020)			LINE OPEN , LINE FAULT
82	13-Jul-2020	BENGALURU	66	HV1	MELUR	21:54 (13-7-2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
83	13-Jul-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN , LINE FAULT
84	13-Jul-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN , LINE CLEAR AVAILED
85	13-Jul-2020	GULBARGA	110	YELBURGA-PRPJ_SLR	YELBURGA_110	10:07	10:18	00:11	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
86	13-Jul-2020	GULBARGA	110	HV1	MASKI_110	11:01	13:38	02:37	LINE CLEAR AVAILED
87	13-Jul-2020	GULBARGA	110	SINDHANOOR220-TURVIHAL	TURVIHAL_110	12:47	13:05	00:18	LINE FAULT
88	13-Jul-2020	GULBARGA	110	CHITAGUPPA-HUMNABAD	CHITAGUPPA_110, NIRNA_110	06:43	06:48	00:05	LINE FAULT
89	13-Jul-2020	GULBARGA	110	HV3	BEVOOR_110	17:23	18:27	01:04	LINE CLEAR AVAILED
90	13-Jul-2020	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	17:32	18:12	00:40	LINE CLEAR AVAILED
91	13-Jul-2020	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSLSUGARFACTOR Y,CHOWDAPUR_110	20:22	20:32	00:10	LINE FAULT
92	13-Jul-2020	GULBARGA	110	MALLAT-BYAGAWAT	BYAGWAT_110	01:56	02:06	00:10	LINE FAULT
93	13-Jul-2020	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	05:49	05:59	00:10	LINE FAULT
94	13-Jul-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	05:59	06:04	00:05	LINE FAULT
95	13-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	02:24	08:24	06:00	LINE FAULT
96	13-Jul-2020	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	08:24	08:54	00:30	LINE CLEAR AVAILED
97	13-Jul-2020	GULBARGA	66	HV1	TAMBRAHALI_66	16:05	16:41	00:36	TRANSFORMER FAULT
98	13-Jul-2020	HASSAN	110	HV3	NO STN AFFECTED	10:29(03.07.2020)			LINE OPEN , LINE CLEAR AVAILED
99	13-Jul-2020	HASSAN	400	HASSAN40-UPCL1	NO STN AFFECTED	21:49 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
100	13-Jul-2020	HASSAN	400	UPCL-HASSAN1	NO STN AFFECTED	21:50 (6.07.2020)			LINE OPEN , LINE CLEAR AVAILED
101	13-Jul-2020	HASSAN	400	UPCL-HASSAN2	NO STN AFFECTED	18:01 (11.07.2020)			LINE OPEN , LINE CLEAR AVAILED
102	13-Jul-2020	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	23:59 (11.07.2020)	7:06 (13.07.2020)	31:06 hrs	LINE CHARGED
103	13-Jul-2020	HASSAN	220	SHRAVITY-SIRISI 1	sharavathy_gen	11:23 (12.07.2020)	8:50 (13.07.2020)	21:26 hrs	LINE CHARGED
104	13-Jul-2020	HASSAN	220	SHRAVITY-SIRISI 2	sharavathy_gen	11:23 (12.07.2020)	14:33 (13.07.2020)	27:09 hrs	LINE CHARGED
105	13-Jul-2020	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	11:10	13:27	02:17	LINE CLEAR AVAILED
106	13-Jul-2020	HASSAN	220	MRSSHM-VARAH2	MRSMSG_220	13:31	16:30	02:59	LINE CLEAR AVAILED
107	13-Jul-2020	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	11:10	13:27	02:17	NFBC ISSUED
108	13-Jul-2020	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	13:31	16:30	02:59	NFBC ISSUED
109	13-Jul-2020	HASSAN	110	HV1	KAVOOR_220	12:05	12:46	00:41	HAND TRIPPED
110	13-Jul-2020	HASSAN	110	HV1	MOODABIDRE_110	10:10	10:45	00:35	LINE CLEAR AVAILED
111	13-Jul-2020	HASSAN	110	HV1	NERALAKERE_110	14:50	16:42	01:52	LINE CLEAR AVAILED
112	13-Jul-2020	HASSAN	66	CHANNARA-CRPATNA1	CHANNARAYAPATNA_66	13:12	15:12	02:00	LINE FAULT
113	13-Jul-2020	HASSAN	66	CHANNARA-CRPATNA2	CHANNARAYAPATNA_66	13:12	15:12	02:00	LINE FAULT
114	13-Jul-2020	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	13:12	15:36	02:24	MAIN SUPPLY FAILURE
115	13-Jul-2020	HASSAN	66	HV1	CHANNARAYAPATNA_66	13:12	15:15	02:03	MAIN SUPPLY FAILURE
116	13-Jul-2020	HASSAN	66	HV2	CHANNARAYAPATNA_66	13:12	15:15	02:03	MAIN SUPPLY FAILURE
117	13-Jul-2020	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	13:12	16:55	03:43	MAIN SUPPLY FAILURE
118	13-Jul-2020	HASSAN	66	CRPATNA2-CRPATNA1	CRPATNA_220	13:12	15:12	02:00	LINE FAULT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
119	13-Jul-2020	HASSAN	66	CRPATNA2-CRPTNA2	CRPATNA_220	13:12	15:12	02:00	LINE FAULT
120	13-Jul-2020	HASSAN	66	LV1	CRPATNA_220	11:03	15:10	04:07	LINE CLEAR AVAILED
121	13-Jul-2020	HASSAN	66	HV1	CRPATNA_220	11:03	15:10	04:07	LINE CLEAR AVAILED
122	13-Jul-2020	HASSAN	66	HV1	DODDAKADANUR_66	09:47	13:46	03:59	LINE CLEAR AVAILED
123	13-Jul-2020	HASSAN	66	HV1	SAKLESH PURA_66	19:20	19:30	00:10	TRANSFORMER FAULT
124	13-Jul-2020	MYSURU	66	BOOKANAKERE-PANDAVAPURA	BANANGADI_66 CHINAKURALI_66	18:48	18:53	0:05	LINE FAULT
125	13-Jul-2020	MYSURU	66	HV1	DMG_HALLI_66	15:01	16:00	0:58	LINE CLEAR AVAILED
126	13-Jul-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	9:40	9:45	0:05	LINE FAULT
127	13-Jul-2020	MYSURU	66	HANNUR-COWDALLI	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66	16:30	16:50	0:19	HAND TRIPPED
128	13-Jul-2020	MYSURU	66	HANNUR-AMPS SOLAR	NO STATIONS EFFECTED	16:30	16:50	0:20	HAND TRIPPED
129	13-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	14:23	14:30	0:07	HAND TRIPPED
130	13-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 1	HANNUR_66	16:30	16:47	0:17	HAND TRIPPED
131	13-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 2	NO STATIONS EFFECTED	14:20	14:23	0:03	HAND TRIPPED
132	13-Jul-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 2	HANNUR_66	16:30	18:30	1:59	HAND TRIPPED
133	13-Jul-2020	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	14:25	14:30	0:05	HAND TRIPPED
134	13-Jul-2020	MYSURU	66	HANNUR-KOTHANUR	NO STATIONS EFFECTED	16:30	16:50	0:19	HAND TRIPPED
135	13-Jul-2020	MYSURU	66	HV2	HEBBAL_66	10:47	14:33	3:46	LINE CLEAR AVAILED
136	13-Jul-2020	MYSURU	220	HOOTAGALLI-BASTIPURA 2	NO STATIONS EFFECTED	10:37	12:53	2:16	HAND TRIPPED
137	13-Jul-2020	MYSURU	66	HOOTAGALLI-DATTAGALLI	NO STATIONS EFFECTED	10:50	13:05	2:15	HAND TRIPPED
138	13-Jul-2020	MYSURU	66	HUNSUR-HOOTAGALLI	NO STATIONS EFFECTED	11:07	12:59	1:51	HAND TRIPPED
139	13-Jul-2020	MYSURU	66	KHB-HOOTAGALLI	NO STATIONS EFFECTED	11:30	12:56	1:26	HAND TRIPPED
140	13-Jul-2020	MYSURU	66	HV3	KUSHALNAGARA_220	11:33	11:50	0:16	TRANSFORMER FAULT
141	13-Jul-2020	MYSURU	66	HV3	KUSHALNAGARA_220	11:54	13:27	1:33	LINE CLEAR AVAILED
142	13-Jul-2020	MYSURU	66	HV1	PANDAVAPURA_66	13:00	13:11	0:10	HAND TRIPPED
143	13-Jul-2020	MYSURU	66	HV2	PANDAVAPURA_66	10:49	12:15	1:25	LINE CLEAR AVAILED
144	13-Jul-2020	MYSURU	66	PANDAVAPURA-TUBINKERE	NO STATIONS EFFECTED	14:30	15:40	1:10	LINE CLEAR AVAILED
145	13-Jul-2020	MYSURU	66	SANTESARGUR-MARUTI	NO STATIONS EFFECTED	9:26	17:12	7:46	LINE CLEAR AVAILED
146	13-Jul-2020	MYSURU	66	HV2	SUTTUR_66	9:37	10:47	1:10	TRANSFORMER FAULT
147	13-Jul-2020	MYSURU	66	HV1	HOOTAGALLY_220	14:33 (03.07.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
148	13-Jul-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN , LINE FAULT
149	13-Jul-2020	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN, TRANSFORMER FAULT
150	13-Jul-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
151	13-Jul-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	11:14:44(28.06.2020)			TRANSFORMER OPEN, TRANSFORMER FAULT
152	13-Jul-2020	TUMKUR	220	TR-1	ANTHRASANAHALLI_220	15:31	16:27	0:55	LINE CLEAR AVAILED
153	13-Jul-2020	TUMKUR	110	TR-1	TALKERE_110	12:16	12:46	0:30	LINE CLEAR AVAILED
154	13-Jul-2020	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	15:31	16:27	0:55	LINE CLEAR AVAILED
155	13-Jul-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	13:07	16:14	3:06	LINE CLEAR AVAILED
156	13-Jul-2020	TUMKUR	66	BRAHMASANDRA- THOVINKERE(KORA)	THOVINAKERE_66, KORA_66	13:59	16:16	2:16	LINE CLEAR AVAILED
157	13-Jul-2020	TUMKUR	66	BRAHMASANDRA- SIRA(KALLAMBELLA)	BRAHMASANDRA_66	13:04	16:45	3:41	LINE CLEAR AVAILED
158	13-Jul-2020	TUMKUR	66	BRAHMASANDRA- SIRA(KALLAMBELLA)	BRAHMASANDRA_66	17:14	18:42	1:28	LINE CLEAR AVAILED
159	13-Jul-2020	TUMKUR	66	TR-2	CHANNAGIRI_66	12:00	12:04	0:04	TRANSFORMER FAULT
160	13-Jul-2020	TUMKUR	66	CHITRADURGA 66KV- CHITRADURGA 1	CHITRADURGA_66	17:31	18:07	0:36	LINE CLEAR AVAILED
161	13-Jul-2020	TUMKUR	110	TR-1(HV SIDE)	DAVANGERE_SRS_220	9:21	9:27	0:06	HAND TRIPPED
162	13-Jul-2020	TUMKUR	66	TR-1	DAVANGERE_SRS_220	12:10	12:20	0:09	HAND TRIPPED
163	13-Jul-2020	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:10	12:34	0:23	HAND TRIPPED
164	13-Jul-2020	TUMKUR	66	TR-3(LV SIDE)	DAVANGERE_SRS_220	12:08	12:20	0:12	HAND TRIPPED
165	13-Jul-2020	TUMKUR	66	TR-2	HOLALKERE_66	10:53	10:55	0:01	TRANSFORMER FAULT
166	13-Jul-2020	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:47	18:08	0:20	HAND TRIPPED
167	13-Jul-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHAN GIDURGA_66, PALLAGATTE_66, SOKKE_66	12:31	15:16	2:44	LINE CLEAR AVAILED
168	13-Jul-2020	TUMKUR	66	NEELAGUNDA 220kv-TELADI	TELADI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	23:12	23:35	0:23	LINE FAULT
169	13-Jul-2020	TUMKUR	66	TR-1	SOKKE_66	7:57	8:08	0:10	HAND TRIPPED
170	13-Jul-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	7:57	8:07	0:10	HAND TRIPPED
171	13-Jul-2020	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	18:01	18:30	0:28	HAND TRIPPED