

400/220/110/66 kV TRANSMISSION OUTAGES FROM: 27.04.21 TO 03.05.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	27-Apr-2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
2	27-Apr-2021	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
3	27-Apr-2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
4	27-Apr-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
5	27-Apr-2021	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
6	27-Apr-2021	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
7	27-Apr-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
8	27-Apr-2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
9	27-Apr-2021	BAGALKOT	220	KUDACHI- CHIKKODI1	KUDACHI_220	8:15 (18.04.2021)	12:08 (27.04.2021)	219:53HRS	LINE CHARGED
10	27-Apr-2021	BAGALKOT	110	ATHANI-SATTI	SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
11	27-Apr-2021	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	10:39 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
12	27-Apr-2021	BAGALKOT	220	CHIKKODI-BELGAUM2	CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
13	27-Apr-2021	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	8:17 (23.04.2021)	17:53 (27.04.2021)	105:36HRS	LINE CHARGED
14	27-Apr-2021	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	7:17 (23.04.2021)	17:46 (27.04.2021)	106:29HRS	LINE CHARGED
15	27-Apr-2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	12:30 (25.04.2021)			LINE OPEN:LINE CLEAR AVAILED
16	27-Apr-2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	12:29 (25.04.2021)			LINE OPEN:LINE CLEAR AVAILED
17	27-Apr-2021	BAGALKOT	110	110/11KV,HV1(HV4)	GOPPANAKOPPA_110	13:47 (26.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
18	27-Apr-2021	BAGALKOT	110	110/11KV,HV2	BABALESHWAR_110	19:37	19:55	0:18	HAND TRIPPED
19	27-Apr-2021	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	20:07 (27.04.2021)			LINE OPEN:LINE CLEAR AVAILED
20	27-Apr-2021	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	17:29 (27.04.2021)			LINE OPEN:LINE CLEAR AVAILED
21	27-Apr-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	04:23	04:31	0:08	TRANSFORMER FAULT
22	27-Apr-2021	BAGALKOT	110	BIJ KDB-BIJAPUR CITY	BIJAPUR CITY_110	04:09	04:34	0:25	LINE FAULT
23	27-Apr-2021	BAGALKOT	110	CHIKKODI-SANKESHWAR	SANKESHWAR_110	3:33	3:36	0:03	LINE FAULT
24	27-Apr-2021	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	12:20	12:26	0:06	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
25	27-Apr-2021	BAGALKOT	110	110/11KV,HV1	HATTARAGI_110	10:29	14:30	12:00	LINE CLEAR AVAILED
26	27-Apr-2021	BAGALKOT	110	110/33KV,HV4	HIDIKAL_110 & ALGWADI_33	12:40	14:12	1:32	LINE CLEAR AVAILED
27	27-Apr-2021	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110 & KOLIGUDD,MAITRA SOLAR_33	12:40	14:42	2:02	LINE CLEAR AVAILED
28	27-Apr-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	07:51	07:58	0:07	TRANSFORMER FAULT
29	27-Apr-2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	11:38	11:45	0:07	TRANSFORMER FAULT
30	27-Apr-2021	BAGALKOT	110	TORVI- TAKKALKI	TAKKALKI_110	04:09	05:02	0:53	LINE FAULT
31	27-Apr-2021	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	21:14 (27.04.2021)			LINE OPEN:LINE FAULT
32	27-Apr-2021	BAGALKOT	110	SOUDATTI220- RAMDURGA2	RAMDURGA_110	01:25	01:47	0:22	LINE FAULT
33	27-Apr-2021	BAGALKOT	110	SOUDATTI220- RAMDURGA1	RAMDURGA_110	01:25	01:47	0:22	LINE FAULT
34	27-Apr-2021	BAGALKOT	110	SOUDATTI- MUNVALLY	MUNAVALLY_110	21:13 (27.04.2021)			LINE OPEN:LINE FAULT
35	27-Apr-2021	BAGALKOT	110	SOUDATTI- YARAGATTI	BENAKATTI_110, YARGATTI_110	21:13 (27.04.2021)			LINE OPEN:LINE FAULT
36	27-Apr-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	18:56 (27.04.2021)			LINE OPEN:LINE FAULT
37	27-Apr-2021	BAGALKOT	110	AFPL SOLAR- SAVANUR	SAVANUR_110	21:55	22:19	0:24	LINE FAULT
38	27-Apr-2021	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	13:36	13:55	0:19	LINE FAULT
39	27-Apr-2021	BAGALKOT	110	110/11KV, HV1	MANTUR_110	22:31	22:33	0:02	TRANSFORMER FAULT
40	27-Apr-2021	BAGALKOT	110	110/11KV, HV2	MANTUR_110	22:31	22:34	0:03	TRANSFORMER FAULT
41	27-Apr-2021	BAGALKOT	110	110/33KV, HV3	LAXMESHWAR_110	18:18	19:08	0:50	TRANSFORMER FAULT
42	27-Apr-2021	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110	20:41	20:53	0:12	TRANSFORMER FAULT
43	27-Apr-2021	BAGALKOT	110	110/11KV, HV2	KUD DHARWAD_110	6:50	7:02	0:12	TRANSFORMER FAULT
44	27-Apr-2021	BAGALKOT	110	KUDACHI220- AINAPUR	AINAPUR_110	10:43	11:00	0:17	LINE FAULT
45	27-Apr-2021	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	20:25	20:32	0:07	TRANSFORMER FAULT
46	27-Apr-2021	BENGALURU	66	MARALWADI - KANAKPURA 220	MARALWADI, GODURU	13:29	13:37	0:08	LINE FAULT
47	27-Apr-2021	BENGALURU	66	HV2	SRS PEENYA 220	11:46	12:50	1:04	LINE CLEAR AVAILED
48	27-Apr-2021	BENGALURU	66	HV1	SM MANGALA	13:55	14:15	0:20	LINE CLEAR AVAILED
49	27-Apr-2021	BENGALURU	66	HV2	SM MANGALA	13:55	14:15	0:20	LINE CLEAR AVAILED
50	27-Apr-2021	BENGALURU	66	HV3	KGF	18:31	20:30	1:58	TRANSFORMER FAULT
51	27-Apr-2021	BENGALURU	66	HV1	HAROBELE	16:00	17:59	1:58	LINE CLEAR AVAILED
52	27-Apr-2021	BENGALURU	66	HV1	GOWRIBIDANUR 220	19:25	19:40	0:15	TRANSFORMER FAULT
53	27-Apr-2021	BENGALURU	66	HV1	DABUSPET 220	11:23	11:28	0:05	LINE CLEAR AVAILED
54	27-Apr-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	BEVOOR, SANKALGERE, DASHAVARA, RAMANAGARA	12:15	12:20	0:05	LINE FAULT
55	27-Apr-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	18:20	18:32	0:12	LINE FAULT
56	27-Apr-2021	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	5:45	5:55	0:10	LINE FAULT
57	27-Apr-2021	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	14:48	14:55	0:06	LINE FAULT
58	27-Apr-2021	BENGALURU	66	SANKALGERE - ADANI SOLAR	ADANI SOLAR	17:15	20:05	2:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
59	27-Apr-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
60	27-Apr-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	04:15	04:22	00:07	LINE FAULT
61	27-Apr-2021	GULBARGA	110	HV2	DEODURGA_110	00:39	00:55	00:16	TRANSFORMER FAULT
62	27-Apr-2021	GULBARGA	110	KADAGANCHI-KBS	KADAGANCHI_110	09:24	09:31	00:07	MAIN SUPPLY FAILURE
63	27-Apr-2021	GULBARGA	110	HV2	BISIHALLI_110	13:10	13:16	00:06	TRANSFORMER FAULT
64	27-Apr-2021	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	07:25	19:48	12:23	LINE CLEAR AVAILED
65	27-Apr-2021	GULBARGA	110	HATTI-GMSH	HATTI_110	14:27	15:00	00:33	LINE CLEAR AVAILED
66	27-Apr-2021	GULBARGA	110	HV3	MANTHAL_110	23:01	23:19	00:18	TRANSFORMER FAULT
67	27-Apr-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	14:55	20:10	05:15	NFBC ISSUED
68	27-Apr-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	16:30	19:40	03:10	LINE CLEAR AVAILED
69	27-Apr-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	20:50(27.04.2021)			LINE OPEN:LINE CLEAR AVAILED
70	27-Apr-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110,KONKAL_110	11:55	12:20	00:25	LINE CLEAR AVAILED
71	27-Apr-2021	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110,KONKAL_110	17:30	17:50	00:20	LINE CLEAR AVAILED
72	27-Apr-2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	05:27	05:40	00:13	LINE FAULT
73	27-Apr-2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	14:55	15:18	00:23	LINE FAULT
74	27-Apr-2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	02:43	02:53	00:10	LINE FAULT
75	27-Apr-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	SHAHAPUR_110	06:02	06:06	00:04	LINE FAULT
76	27-Apr-2021	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	09:25	09:29	00:04	LINE FAULT
77	27-Apr-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
78	27-Apr-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
79	27-Apr-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
80	27-Apr-2021	HASSAN	220	HV1	SHIRALKOPPA_220	19:47(27.04.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
81	27-Apr-2021	HASSAN	110	LV1	SHIRALKOPPA_220	19:47(27.04.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
82	27-Apr-2021	HASSAN	110	ANANDA-LPH(LST-4)	ANANDPURA_110	22:35(25.04.2021)	15:00(27.4.2021)	40:25HRS	LINE CHARGED
83	27-Apr-2021	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:09	14:51	04:42	LINE FAULT
84	27-Apr-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:54	17:04	01:10	LINE FAULT
85	27-Apr-2021	HASSAN	220	KEMAR-HEGUNJE	KEMAR_220	14:41	14:55	00:14	LINE FAULT
86	27-Apr-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	14:57	15:21	00:24	LINE FAULT
87	27-Apr-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	14:57	16:08	01:11	LINE FAULT
88	27-Apr-2021	HASSAN	110	KEMAR-NANDHIKUR2	KEMAR_220	10:05	12:47	02:42	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
89	27-Apr-2021	HASSAN	220	HV1	SHIRALKOPPA_220	08:58	12:07	03:09	TRANSFORMER FAULT
90	27-Apr-2021	HASSAN	110	LV1	SHIRALKOPPA_220	08:58	12:07	03:09	TRANSFORMER FAULT
91	27-Apr-2021	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	09:00	09:18	00:18	HAND TRIPPED
92	27-Apr-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:22	15:32	00:10	LINE FAULT
93	27-Apr-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:54	17:05	01:11	LINE FAULT
94	27-Apr-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:26	15:33	00:07	LINE FAULT
95	27-Apr-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:50	16:04	00:14	LINE FAULT
96	27-Apr-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	16:05	17:06	01:01	LINE FAULT
97	27-Apr-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	11:04	11:18	00:14	LINE FAULT
98	27-Apr-2021	HASSAN	110	HV1	BARANGI_110	06:59	07:04	00:05	HAND TRIPPED
99	27-Apr-2021	HASSAN	110	HV2	BARANGI_110	06:59	07:04	00:05	HAND TRIPPED
100	27-Apr-2021	HASSAN	110	HV2	BARANGI_110	07:41	07:59	00:18	HAND TRIPPED
101	27-Apr-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	15:09	16:09	01:00	MAIN SUPPLY FAILURE
102	27-Apr-2021	HASSAN	110	HV1	HIRIYADKA_110	10:32	12:43	02:11	LINE CLEAR AVAILED
103	27-Apr-2021	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	16:13	16:34	00:21	LINE FAULT
104	27-Apr-2021	HASSAN	110	HV1	MOODABIDRE_110	02:14	04:30	02:16	TRANSFORMER FAULT
105	27-Apr-2021	HASSAN	110	HV2	NAVUNDA_110	03:17	03:30	00:13	TRANSFORMER FAULT
106	27-Apr-2021	HASSAN	66	HASSN22-SKPURA1	HASSAN_220	07:51	08:15	00:24	LINE FAULT
107	27-Apr-2021	HASSAN	66	HV1	HALLYMYSORE_66	09:28	09:31	00:03	TRANSFORMER FAULT
108	27-Apr-2021	HASSAN	66	KANDLI-HASSAN	KANDLI_66	07:51	08:23	00:32	LINE FAULT
109	27-Apr-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	07:51	08:30	00:39	LINE FAULT
110	27-Apr-2021	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	11:18	13:38	02:20	NFBC ISSUED
111	27-Apr-2021	HASSAN	66	HV1	MAGGE_66	07:58	08:32	00:34	MAIN SUPPLY FAILURE
112	27-Apr-2021	HASSAN	66	HV2	MAGGE_66	07:58	08:32	00:34	MAIN SUPPLY FAILURE
113	27-Apr-2021	HASSAN	66	HV2	MAGGE_66	11:21	13:40	02:19	NFBC ISSUED
114	27-Apr-2021	HASSAN	66	HV2	MAGGE_66	11:20	13:40	02:20	NFBC ISSUED
115	27-Apr-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPUR_66	07:51	08:48	00:57	LINE FAULT
116	27-Apr-2021	HASSAN	66	SAKALE-HASSAN	SAKLESHPUR_66	09:37	13:41	04:04	MAIN SUPPLY FAILURE
117	27-Apr-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPUR_66	08:48	19:01	10:13	LINE CLEAR AVAILED
118	27-Apr-2021	HASSAN	66	HV1	S.BELAGOLA_66	06:32	06:46	00:14	TRANSFORMER FAULT
119	27-Apr-2021	HASSAN	66	HV1	SINGAPURA_66	10:30	12:27	01:57	LINE CLEAR AVAILED
120	27-Apr-2021	HASSAN	66	HV2	SINGAPURA_66	08:27	12:27	04:00	LINE CLEAR AVAILED
121	27-Apr-2021	MYSURU	66	DEVNUR(N'GUD)-BASL 1	NO STATIONS EFFECTED	10:09	12:40	2:30	LINE CLEAR AVAILED
122	27-Apr-2021	MYSURU	66	DEVNUR(N'GUD)-BASL 2	NO STATIONS EFFECTED	10:14	12:40	2:26	LINE CLEAR AVAILED
123	27-Apr-2021	MYSURU	66	HV2	DKMAIDANA_66	13:04	14:44	1:39	LINE CLEAR AVAILED
124	27-Apr-2021	MYSURU	66	HV1	HANNUR_66	10:49	18:13	7:23	LINE CLEAR AVAILED
125	27-Apr-2021	MYSURU	66	HANNUR-MADHUVANAHALLI -1	NO STATIONS EFFECTED	11:50	11:52	0:02	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
126	27-Apr-2021	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	5:55	6:03	0:07	LINE FAULT
127	27-Apr-2021	MYSURU	66	KR NAGARA-CHUNCHANAKATTE	NO STATIONS EFFECTED	6:15	6:38	0:23	LINE FAULT
128	27-Apr-2021	MYSURU	66	KUSHALNAGARA-MYSORE-1	MIRLE_66	0:53	1:01	0:07	LINE FAULT
129	27-Apr-2021	MYSURU	220	HV1	KUSHALANAGARA_66	15:00	15:57	0:57	LINE CLEAR AVAILED
130	27-Apr-2021	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:14	18:22	0:07	LINE FAULT
131	27-Apr-2021	MYSURU	66	HV2	PANDAVAPURA_66	15:23	15:45	0:22	TRANSFORMER FAULT
132	27-Apr-2021	MYSURU	66	HV2	SATHEGALA_66	10:59	11:41	0:42	LINE CLEAR AVAILED
133	27-Apr-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/03/2021)			LINE OPEN:LINE CLEAR AVAILED
134	27-Apr-2021	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
135	27-Apr-2021	TUMKUR	220	TR-1(HV SIDE)	CHITRADURGA_220	14:21	14:40	0:18	TRANSFORMER FAULT
136	27-Apr-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	12:21	13:42	1:21	LINE CLEAR AVAILED
137	27-Apr-2021	TUMKUR	66	HARIHARA-DAVANGERE	HARIHAR_66	12:34	13:44	1:09	MAIN SUPPLY FAILURE
138	27-Apr-2021	TUMKUR	66	TR-1	HARIHAR_66	12:34	13:45	1:10	MAIN SUPPLY FAILURE
139	27-Apr-2021	TUMKUR	66	TR-2	HARIHAR_66	12:25	13:46	1:21	MAIN SUPPLY FAILURE
140	27-Apr-2021	TUMKUR	66	TR-1	HDPURA_66	15:23	15:26	0:03	TRANSFORMER FAULT
141	27-Apr-2021	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	11:27	11:38	0:11	LINE CLEAR AVAILED
142	27-Apr-2021	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	12:06	12:32	0:26	LINE CLEAR AVAILED
143	27-Apr-2021	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	12:34	12:41	0:07	LINE CLEAR AVAILED
144	27-Apr-2021	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	12:42	12:48	0:05	LINE CLEAR AVAILED
145	27-Apr-2021	TUMKUR	66	TR-1	HIRIYUR_66	17:50	17:55	0:04	HAND TRIPPED
146	27-Apr-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:44	17:50	1:06	LINE CLEAR AVAILED
147	27-Apr-2021	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	16:32	17:53	1:20	LINE CLEAR AVAILED
148	27-Apr-2021	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	16:32	17:53	1:20	LINE CLEAR AVAILED
149	27-Apr-2021	TUMKUR	66	TR-2	HONNUDIKE_66	8:00	8:03	0:03	TRANSFORMER FAULT
150	27-Apr-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	7:14	8:08	0:54	LINE CLEAR AVAILED
151	27-Apr-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:06	13:43	1:37	LINE CLEAR AVAILED
152	27-Apr-2021	TUMKUR	66	TR-2	MATHOD_66	9:00	9:04	0:04	HAND TRIPPED
153	27-Apr-2021	TUMKUR	66	MATHOD- PANCHANAHALLI	MATHOD_66,	18:07	18:18	0:11	LINE CLEAR AVAILED
154	27-Apr-2021	TUMKUR	66	TR-1	NAGASAMUDRA_66	6:47	6:59	0:12	TRANSFORMER FAULT
155	27-Apr-2021	TUMKUR	66	TR-1	NAGASAMUDRA_66	7:20	7:45	0:24	TRANSFORMER FAULT
156	27-Apr-2021	TUMKUR	66	PAVAGADA-NAGALAMADIKE	PAVAGADA_220	3:21	3:50	0:29	LINE FAULT
157	27-Apr-2021	TUMKUR	66	SANIKERE- HIRIYUR	SANIKERE_66	17:32	18:51	1:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
158	27-Apr-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA 1	CHITRADURGA_220	14:40	14:51	0:11	LINE FAULT
159	27-Apr-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA2	CHITRADURGA_220	14:40	14:52	0:11	LINE FAULT
160	27-Apr-2021	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	14:21	14:40	0:18	TRANSFORMER FAULT
161	27-Apr-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA3	CHITRADURGA_220	14:40	14:52	0:11	LINE FAULT
162	27-Apr-2021	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 1	CHITRADURGA_66	14:40	14:52	0:11	MAIN SUPPLY FAILURE
163	27-Apr-2021	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 2	CHITRADURGA_66	14:40	14:52	0:11	MAIN SUPPLY FAILURE
164	27-Apr-2021	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	14:49	14:57	0:08	MAIN SUPPLY FAILURE
165	27-Apr-2021	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	14:40	17:02	2:21	LINE FAULT
166	27-Apr-2021	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 4	CHITRADURGA_66	14:22	14:55	0:33	LINE FAULT
167	28-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
168	28-Apr-21	BAGALKOT	110	110/11KV,HV1	BIDNAL_220	14:37	17:00	2:23	LINE CLEAR AVAILED
169	28-Apr-21	BAGALKOT	110	110/11KV,HV1(HV4)	STATION NOT AFFECTED GOPPANAKOPPA_110	13:47 (26.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
170	28-Apr-21	BAGALKOT	110	110/11KV,HV2	THORVI_110	13:33	13:45	0:12	TRANSFORMER FAULT
171	28-Apr-21	BAGALKOT	110	110/11KV,HV2	ITNAL_110	22:36	22:41	0:05	TRANSFORMER FAULT
172	28-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110,NEVARGI_33, DULKHED_33	06:48	07:20	0:32	TRANSFORMER FAULT
173	28-Apr-21	BAGALKOT	110	AMBEWADI-NK2	KAVALWADA_110	12:20	12:40	0:20	LINE FAULT
174	28-Apr-21	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
175	28-Apr-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	6:43	07:03	0:20	LINE FAULT
176	28-Apr-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1&2	MAMADAPUR_110	8:10	08:29	0:19	LINE FAULT
177	28-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
178	28-Apr-21	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED ANNIGERI_110	20:07 (27.04.2021)	12:15 (28.04.2021)	16:08 hrs	LINE CHARGED
179	28-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	12:08	12:15	0:07	HAND TRIPPED
180	28-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	12:17 (28.04.2021)			LINE OPEN:LINE CLEAR AVAILED
181	28-Apr-21	BAGALKOT	110	GAJENDRAGAD-KUSTAGI	STATION NOT AFFECTED GAJENDRAGAD_110	8:48	9:00	0:12	HAND TRIPPED
182	28-Apr-21	BAGALKOT	110	GHATAPRABHA-SHIRGOAN	SHIRGOAN_110	11:15	11:29	0:14	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
183	28-Apr-21	BAGALKOT	110	KABHUR(MUGALKOD)-ITNAL	ITNAL_110	6:25	6:36	0:11	LINE FAULT
184	28-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
185	28-Apr-21	BAGALKOT	110	PG HUNSHYAL-NAGNUIR(MUDALGI)	NAGANUR_110	03:10	03:18	0:08	LINE FAULT
186	28-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
187	28-Apr-21	BAGALKOT	110	SOUDATTI- MUNVALLY	MUNAVALLY_110	21:13 (27.04.2021)	5:42 (28.04.2021)	8:29	LINE FAULT
188	28-Apr-21	BAGALKOT	110	SOUDATTI- YARAGATTI	BENAKATTI_110, YARGATTI_110	21:13 (27.04.2021)	17:12 (28.04.2021)	19:59	LINE FAULT
189	28-Apr-21	BAGALKOT	110	SOUDATTI220-MUNAVALLY	MUNAVALLI_110	12:12	17:12	5:00	LINE CLEAR AVAILED
190	28-Apr-21	BAGALKOT	110	SOUDATTI-ENERCON1	ENERCON IPP_110 STATION NOT AFFECTED SOUDATTI_110	22:04	22:31	0:27	LINE FAULT
191	28-Apr-21	BAGALKOT	110	SOUDATTI-ENERCON2	ENERCON IPP_110 STATION NOT AFFECTED SOUDATTI_110	22:04	22:28	0:24	LINE FAULT
192	28-Apr-21	BAGALKOT	110	SOUDATTI-SOUDATTI220 I/C2(NARAGUND)	STATION NOT AFFECTED SOUDATTI_110	23:29(28.04.21)			LINE OPEN:LINE FAULT
193	28-Apr-21	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED CHIKKODI_220	16:50	17:30	0:40	LINE CLEAR AVAILED
194	28-Apr-21	BAGALKOT	220	220/110KV,HV4	STATION NOT AFFECTED GADAG_220	11:31	18:03	6:32	LINE CLEAR AVAILED
195	28-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	1:19	1:56	0:37	LINE CLEAR AVAILED
196	28-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
197	28-Apr-21	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	1:18	1:44	0:26	LINE FAULT
198	28-Apr-21	BAGALKOT	220	BIDNAL-HARTI 1	STATION NOT AFFECTED BIDNAL_220	17:29 (27.04.2021)	10:45 (28.04.2021)	17:16 hrs	LINE CHARGED
199	28-Apr-21	BAGALKOT	220	BIDNAL-NARENDRA	STATION NOT AFFECTED BIDNAL_220	14:01	17:48	3:47	NFBC ISSUED
200	28-Apr-21	BAGALKOT	220	CHIKKODI-BELGAUM1	STATION NOT AFFECTED CHIKKODI_220	10:28	11:00	0:32	LOAD CURTAILMENT
201	28-Apr-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
202	28-Apr-21	BAGALKOT	220	CHIKKODI-KUDUCHI1	STATION NOT AFFECTED CHIKKODI_220	10:51	11:29	0:38	LOAD CURTAILMENT
203	28-Apr-21	BAGALKOT	220	CHIKKODI-KUDUCHI1	STATION NOT AFFECTED CHIKKODI_220	16:58	19:07	2:09	LOAD CURTAILMENT
204	28-Apr-21	BAGALKOT	220	CHIKKODI-KUDUCHI2	STATION NOT AFFECTED CHIKKODI_220	10:51	19:07	8:16	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
205	28-Apr-21	BAGALKOT	220	GADAG-DHONI1	STATION NOT AFFECTED GADAG_220	12:34	12:59	0:25	LINE CLEAR AVAILED
206	28-Apr-21	BAGALKOT	220	GHATAPRABHA-NARENDRA2	STATION NOT AFFECTED GHATAPRABHA_220	13:04	17:08	4:04	LINE FAULT
207	28-Apr-21	BAGALKOT	220	GHATAPRABHA-NARENDRA2	STATION NOT AFFECTED GHATAPRABHA_220	10:44	11:15	0:31	LINE FAULT
208	28-Apr-21	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	12:13	16:36	4:23	LINE CLEAR AVAILED
209	28-Apr-21	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	10:28	18:27	7:59	LINE FAULT
210	28-Apr-21	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	10:28	17:22	6:54	LINE FAULT
211	28-Apr-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
212	28-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR	13:39	18:19	4:40	LINE FAULT
213	28-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
214	28-Apr-21	BAGALKOT	220	NARENDRA-HAVERI1	STATION NOT AFFECTED NARENDRA_220	13:57	17:47	3:50	LINE CLEAR AVAILED
215	28-Apr-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:56 (27.04.2021)	16:22 (28.04.2021)	21:26 hrs	LINE CHARGED
216	28-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	12:29 (25.04.2021)			LINE OPEN:LINE CLEAR AVAILED
217	28-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	12:30 (25.04.2021)			LINE OPEN:LINE CLEAR AVAILED
218	28-Apr-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	21:14 (27.04.2021)	18:27 (28.04.2021)	21:13	LINE FAULT
219	28-Apr-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
220	28-Apr-21	BAGALKOT	220	VAJRAMATTI - MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
221	28-Apr-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	05:20	05:23	00:03	LOAD CHANGE OVER
222	28-Apr-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	02:55	03:20	00:25	MAIN SUPPLY FAILURE
223	28-Apr-2021	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE 1	NO STATION AFFECTED	20:45	20:58	00:13	LINE FAULT
224	28-Apr-2021	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	10:29	10:48	00:19	LINE FAULT
225	28-Apr-2021	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	15:02	17:34	02:32	LINE FAULT
226	28-Apr-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	15:54	17:35	01:40	LINE CLEAR AVAILED
227	28-Apr-2021	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	06:36	06:41	00:05	TRANSFORMER FAULT
228	28-Apr-2021	BENGALURU	66	HV2	LEELA VENTURE	22:39	22:44	00:05	TRANSFORMER FAULT
229	28-Apr-2021	BENGALURU	66	HV2	NGEF	12:58	13:08	00:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
230	28-Apr-2021	BENGALURU	66	HV2	CHANDAPURA	23:58 (28-04-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
231	28-Apr-2021	BENGALURU	66	HV3	HEBBALA 220	06:24	06:54	00:30	LINE CLEAR AVAILED
232	28-Apr-2021	BENGALURU	66	HV3	KGF	12:05	13:20	01:14	LINE CLEAR AVAILED
233	28-Apr-2021	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI	12:02	12:04	00:02	LOAD CHANGE OVER
234	28-Apr-2021	BENGALURU	66	MARALWADI - GODUR	GODUR	10:30	11:00	00:30	LINE CLEAR AVAILED
235	28-Apr-2021	BENGALURU	66	MARALWADI - GODUR	GODUR	18:45	19:00	00:15	LINE FAULT
236	28-Apr-2021	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 1	AREHALLI	02:55	03:20	00:25	LINE FAULT
237	28-Apr-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
238	28-Apr-2021	GULBARGA	66	HOSAHALLI-CJHALLI	HOSAHALLI_66	21:40	22:45	01:05	MAIN SUPPLY FAILURE
239	28-Apr-2021	GULBARGA	66	HV1,HV2	GUDEKOTE_66	20:47	22:57	02:10	LINE CLEAR AVAILED
240	28-Apr-2021	GULBARGA	66	HV2	KOGALI_66	15:20	15:35	00:15	TRANSFORMER FAULT
241	28-Apr-2021	GULBARGA	66	KOGALI-ATRSOLAR	KOGALI_66	20:19	21:08	00:49	LINE CLEAR AVAILED
242	28-Apr-2021	GULBARGA	66	KOGALI-ITTAGGI	KOGALI_66	19:35	20:15	00:40	LINE FAULT
243	28-Apr-2021	GULBARGA	66	KOGALI-KUDLIGI	KUDLIGI_66	19:35(28.04.2021)			LINE OPEN:LINE FAULT
244	28-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	20:35	20:45	00:10	LINE FAULT
245	28-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	22:01	22:10	00:09	LINE FAULT
246	28-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	01:21	01:35	00:14	LINE FAULT
247	28-Apr-2021	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	07:35	21:53	14:18	LINE CLEAR AVAILED
248	28-Apr-2021	GULBARGA	110	HANUMASAGAR-KUSHTAGI	HANUMASAGAR_110,HANUMANA NAL_110,HIREGONNAGAR_110	08:30	10:15	01:45	MAIN SUPPLY FAILURE
249	28-Apr-2021	GULBARGA	110	HV1	BENUR_110	07:00	07:13	00:13	TRANSFORMER FAULT
250	28-Apr-2021	GULBARGA	110	HV2	BISIHALLI_110	11:05	11:20	00:15	TRANSFORMER FAULT
251	28-Apr-2021	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANA NAL_110,HIREGONNAGAR_110	08:30	10:20	01:50	LINE CLEAR AVAILED
252	28-Apr-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	20:50(27.04.2021)			LINE OPEN:LINE CLEAR AVAILED
253	28-Apr-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	21:43	22:25	00:42	LINE FAULT
254	28-Apr-2021	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110,KONKAL_110	05:52	06:22	00:30	LINE FAULT
255	28-Apr-2021	GULBARGA	110	SEDAM-VICATSAGAR_IPP	SEDAM_220	12:20	13:20	01:00	LINE CLEAR AVAILED
256	28-Apr-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	03:12	03:36	00:24	LINE FAULT
257	28-Apr-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	02:35	02:42	00:07	LINE FAULT
258	28-Apr-2021	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	14:47	17:27	02:40	LINE CLEAR AVAILED
259	28-Apr-2021	HASSAN	66	HV1	BALEHONNUR_66	04:39	05:11	00:32	TRANSFORMER FAULT
260	28-Apr-2021	HASSAN	66	HV1	HAGARE_66	08:15	08:34	00:19	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
261	28-Apr-2021	HASSAN	66	HV1	MAGGE_66	12:16	14:32	02:16	NFBC ISSUED
262	28-Apr-2021	HASSAN	66	HV1	SALAGAME_66	10:37	13:54	03:17	LINE CLEAR AVAILED
263	28-Apr-2021	HASSAN	66	HV2	MAGGE_66	12:16	14:32	02:16	NFBC ISSUED
264	28-Apr-2021	HASSAN	66	KANDALI-SAKLESHPUR	KANDLI_66	12:16	14:29	02:13	LINE CLEAR AVAILED
265	28-Apr-2021	HASSAN	66	Lv1	HOLENARASIPURA_220	09:19	15:12	05:53	LINE CLEAR AVAILED
266	28-Apr-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
267	28-Apr-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
268	28-Apr-2021	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	12:15	14:29	02:14	NFBC ISSUED
269	28-Apr-2021	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
270	28-Apr-2021	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	08:51	19:23	10:32	LINE CLEAR AVAILED
271	28-Apr-2021	HASSAN	110	HV1	GANDASI_66	14:27	16:51	02:24	LINE CLEAR AVAILED
272	28-Apr-2021	HASSAN	110	HV1	GURUVAYANAKERE_110	12:05	13:37	01:32	LINE CLEAR AVAILED
273	28-Apr-2021	HASSAN	110	HV1	MOODABIDRE_66	12:27	12:53	00:26	LINE CLEAR AVAILED
274	28-Apr-2021	HASSAN	110	HV2	GANDASI_66	13:16	15:23	02:07	LINE CLEAR AVAILED
275	28-Apr-2021	HASSAN	110	KADUR-NERELEKERE	KADUR_220	11:59	12:15	00:16	HAND TRIPPED
276	28-Apr-2021	HASSAN	110	LV1	SHIRALKOPPA_220	19:47(27.04.2021)	18:28(28.04.2021)	22:43 hrs	TRANSFORMER CHARGED
277	28-Apr-2021	HASSAN	110	LV1	KAVOOR_220	10:32	13:00	02:28	LINE CLEAR AVAILED
278	28-Apr-2021	HASSAN	110	LV2	KAVOOR_220	13:02	14:51	01:49	LINE CLEAR AVAILED
279	28-Apr-2021	HASSAN	220	HV1	SHIRALKOPPA_220	19:47(27.04.2021)	18:25(28.04.2021)	22:40 hrs	TRANSFORMER CHARGED
280	28-Apr-2021	HASSAN	220	HV1	HOLENARASIPURA_220	09:20	15:10	05:50	LINE CLEAR AVAILED
281	28-Apr-2021	HASSAN	220	HV1	KAVOOR_220	10:32	13:00	02:28	LINE CLEAR AVAILED
282	28-Apr-2021	HASSAN	220	HV2	KAVOOR_220	13:02	14:51	01:49	LINE CLEAR AVAILED
283	28-Apr-2021	MYSURU	66	CR NAGARA-KABBALLI	NO STATIONS EFFECTED	18:01	18:07	0:06	LINE FAULT
284	28-Apr-2021	MYSURU	66	HV1	HANNUR_66	11:30	11:48	0:17	LINE CLEAR AVAILED
285	28-Apr-2021	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
286	28-Apr-2021	MYSURU	66	HV2	SANTHEBACHALLI_66	12:09	12:47	0:38	LINE CLEAR AVAILED
287	28-Apr-2021	MYSURU	66	KUSHALANAGARA 220-BYLUKUPPE	NO STATIONS EFFECTED	15:09	15:16	0:06	HAND TRIPPED
288	28-Apr-2021	MYSURU	66	KUSHALANAGARA 220-HARANGI	NO STATIONS EFFECTED	15:13	15:18	0:05	HAND TRIPPED
289	28-Apr-2021	MYSURU	66	KUSHALANAGARA 220-MERCERA-1	NO STATIONS EFFECTED	15:06	15:10	0:04	HAND TRIPPED
290	28-Apr-2021	MYSURU	66	KUSHALANAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	15:12	15:17	0:05	HAND TRIPPED
291	28-Apr-2021	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:14	18:22	0:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
292	28-Apr-2021	MYSURU	66	MUGUR-THAYURU	THAYURU_66 TNARASIPURA_66	3:10	3:15	0:05	LINE FAULT
293	28-Apr-2021	MYSURU	66	TUBINAKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	4:01	4:09	0:08	LINE FAULT
294	28-Apr-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/03/2021)			LINE OPEN:LINE CLEAR AVAILED
295	28-Apr-2021	TUMKUR	66	CHITRADURGA 220kV- CHITRADURGA 1	CHITRADURGA_220	07:22	09:37	02:15	NFBC ISSUED
296	28-Apr-2021	TUMKUR	66	HANAGAL-THALLAK	HANAGAL_66	21:58	22:07	00:09	LINE FAULT
297	28-Apr-2021	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:15	15:25	00:09	LINE FAULT
298	28-Apr-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:41	11:50	00:09	LINE FAULT
299	28-Apr-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	16:58	17:03	00:04	LINE FAULT
300	28-Apr-2021	TUMKUR	66	TR-1	HDPURA_66	20:05	20:07	00:01	TRANSFORMER FAULT
301	28-Apr-2021	TUMKUR	66	TR-1	HONNALI_66	11:30	11:38	00:08	HAND TRIPPED
302	28-Apr-2021	TUMKUR	66	TR-1	MAVINAKATTE_66	16:47	16:49	00:02	TRANSFORMER FAULT
303	28-Apr-2021	TUMKUR	66	TR-1	MYLANAHALLI_66	11:37	11:46	00:09	TRANSFORMER FAULT
304	28-Apr-2021	TUMKUR	66	TR-1	NAGASAMUDRA_66	22:04	22:17	00:12	TRANSFORMER FAULT
305	28-Apr-2021	TUMKUR	66	TR-1	KUNIGAL_66	11:31	13:54	02:22	LINE CLEAR AVAILED
306	28-Apr-2021	TUMKUR	66	TR-2	HARIYABBE_66	18:05	18:10	00:05	HAND TRIPPED
307	28-Apr-2021	TUMKUR	66	TR-2	THOVINAKERE_66	11:19	13:10	01:50	LINE CLEAR AVAILED
308	28-Apr-2021	TUMKUR	66	TR-2	KUNIGAL_66	11:31	13:54	02:22	LINE CLEAR AVAILED
309	28-Apr-2021	TUMKUR	66	TR-3	HARIYABBE_66	18:07	18:11	00:03	HAND TRIPPED
310	28-Apr-2021	TUMKUR	66	YEDIYUR- ANCHEPALYA220KV	YEDIYUR_66	10:34	14:46	04:12	LINE CLEAR AVAILED
311	28-Apr-2021	TUMKUR	110	NITTUR 220kV- GUBBI	GUBBI_110	22:05	22:44	00:39	LINE FAULT
312	28-Apr-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	13:12	18:19	05:06	LINE CLEAR AVAILED
313	28-Apr-2021	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	13:30	14:01	00:30	LINE FAULT
314	28-Apr-2021	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	13:30	14:02	00:32	LINE FAULT
315	29-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
316	29-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SIRSI_110	11:36	11:40	0:04	HAND TRIPPED
317	29-Apr-21	BAGALKOT	110	110/11KV,HV1(HV4)	STATION NOT AFFECTED GOPPANAKOPPA_110	13:47 (26.04.2021)	13:57 (29.04.2021)	72:10 hrs	TRANSFORMER CHARGED
318	29-Apr-21	BAGALKOT	110	110/11KV,HV4	STATION NOT AFFECTED HUKKERI_110	14:55	21:24	6:29	TRANSFORMER FAULT
319	29-Apr-21	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110,KOLIGUDDA_33,M YTRA SOLAR_33	14:50	16:39	1:49	LINE CLEAR AVAILED
320	29-Apr-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED NARENDRA_220	18:28 (29.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
321	29-Apr-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED HUBLI_220	9:25	13:47	4:22	LINE CLEAR AVAILED
322	29-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	15:16	16:06	0:50	LINE FAULT
323	29-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:08 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
324	29-Apr-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	21:58 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
325	29-Apr-21	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110	9:22	09:26	0:04	HAND TRIPPED
326	29-Apr-21	BAGALKOT	110	ARGA-ANKOLA	ANKOLA_110	12:29	12:38	0:09	HAND TRIPPED
327	29-Apr-21	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
328	29-Apr-21	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_220	16:07	16:16	0:09	LINE FAULT
329	29-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
330	29-Apr-21	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED BIDNAL_220	17:41 (29.04.2021)			LINE OPEN:LINE FAULT
331	29-Apr-21	BAGALKOT	110	BYADAGI- HOSAHONNATTI	HOSAHONNATTI_110	14:20	14:50	0:30	HAND TRIPPED
332	29-Apr-21	BAGALKOT	110	GADAG ROAD-BIDNAL(RAILWAY (SWR))	STATION NOT AFFECTED GADAG ROAD_110	19:03	23:55	4:52	LINE FAULT
333	29-Apr-21	BAGALKOT	110	GADAG ROAD-BIDNAL(RAILWAY (SWR))	STATION NOT AFFECTED GADAG ROAD_110	23:45	23:55	0:10	HAND TRIPPED
334	29-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	12:17 (28.04.2021)	18:16 (29.04.2021)	29:59 hrs	LINE CHARGED
335	29-Apr-21	BAGALKOT	110	GHATAPRABHA-HIDIKAL	STATION NOT AFFECTED HIDIKAL DAM_110	18:11	21:58	3:47	LINE FAULT
336	29-Apr-21	BAGALKOT	110	HUBLI220-KADANAKOPPA	STATION NOT AFFECTED HUBLI_220	15:23	17:07	1:44	LINE FAULT
337	29-Apr-21	BAGALKOT	110	HUBLI220-KADANAKOPPA	STATION NOT AFFECTED HUBLI_220	15:23	17:07	1:44	LINE FAULT
338	29-Apr-21	BAGALKOT	110	HUBLI-KADANAKOPPA	KADANAKOPPA_110	15:55	17:11	1:16	LINE FAULT
339	29-Apr-21	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	14:56(29.04.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
340	29-Apr-21	BAGALKOT	110	HUKKERI-KOTAWAGI LIS	STATION NOT AFFECTED HUKKERI_110	18:16	19:30	1:14	LINE FAULT
341	29-Apr-21	BAGALKOT	110	KADANAKOPPA- KAVALWADA(AMBEWADI)	STATION NOT AFFECTEDKADANAKOPPA_110	19:45 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
342	29-Apr-21	BAGALKOT	110	KARWAR220-ARGA	ARGA_110	9:20	12:23	3:03	LINE CLEAR AVAILED
343	29-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
344	29-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
345	29-Apr-21	BAGALKOT	110	RANEENNUR-BYADAGI	STATION NOT AFFECTED BYADAGI_110	14:20	14:55	0:35	LINE CLEAR AVAILED
346	29-Apr-21	BAGALKOT	110	SIRSI-KUMTA2	STATION NOT AFFECTED SIRSI_110	13:01	16:13	3:12	LINE CLEAR AVAILED
347	29-Apr-21	BAGALKOT	110	SOUDATTI-ENERCON1	ENERCON IPP_110 STATION NOT AFFECTED SOUDATTI_110	00:00	00:27	0:27	LINE FAULT
348	29-Apr-21	BAGALKOT	110	SOUDATTI-ENERCON2	ENERCON IPP_110 STATION NOT AFFECTED SOUDATTI_110	00:00	13:04	13:04	LINE FAULT
349	29-Apr-21	BAGALKOT	110	SOUDATTI-SOUDATTI220 I/C2(NARAGUND)	STATION NOT AFFECTED SOUDATTI_110	23:59 (28.04.2021)	00:20 (29.04.2021)	0:21:00	LINE FAULT
350	29-Apr-21	BAGALKOT	110	TAKKALKI-KN BIJAPUR SOLAR	KN BIJAPUR SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	13:59 (29.04.2021)			LINE OPEN:LINE FAULT
351	29-Apr-21	BAGALKOT	110	TUMMINAKATI- RANEENNUR220	STATION NOT AFFECTED TUMMINAKATTI_110	20:10 (29.04.2021)			LINE OPEN:LINE FAULT
352	29-Apr-21	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED NARENDRA_220	18:28	19:00	0:32	HAND TRIPPED
353	29-Apr-21	BAGALKOT	220	220/110KV, HV2	STATION NOT AFFECTED HUBLI_220	9:26	13:47	4:21	LINE CLEAR AVAILED
354	29-Apr-21	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	9:40	11:48	2:08	LINE CLEAR AVAILED
355	29-Apr-21	BAGALKOT	220	220/110KV,HV1,LV2	KARWAR_220	11:47	12:20	0:33	LINE CLEAR AVAILED
356	29-Apr-21	BAGALKOT	220	AMBEWADI-NARENDRA2	STATION NOT AFFECTED AMBEWADI_220	11:48	17:27	5:39	LOAD CURTAILMENT
357	29-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
358	29-Apr-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
359	29-Apr-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI1	GHATAPRABHA_220	17:16 (29.04.2021)			LOAD CURTAILMENT
360	29-Apr-21	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	18:23 (29.04.2021)			LINE OPEN:LINE FAULT
361	29-Apr-21	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	18:23 (29.04.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
362	29-Apr-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:40	17:04	3:24	LINE CLEAR AVOIDED
363	29-Apr-21	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	13:39	17:04	3:25	LINE CLEAR AVOIDED
364	29-Apr-21	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	13:39	17:04	3:25	LINE CLEAR AVOIDED
365	29-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
366	29-Apr-21	BAGALKOT	220	MUGALKOD-GHATAPRABHA1	MUGALKOD_220	17:35 (29.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
367	29-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
368	29-Apr-21	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	18:37	18:45	0:08	LINE FAULT
369	29-Apr-21	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	18:25 (29.04.2021)			LINE OPEN:LINE FAULT
370	29-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	12:29 (25.04.2021)	13:21 (29.04.2021)	96:52 hrs	LINE CHARGED
371	29-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
372	29-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	12:30 (25.04.2021)	13:19 (29.04.2021)	96:49 hrs	LINE CHARGED
373	29-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
374	29-Apr-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:18	17:00	3:42	NFBC ISSUED
375	29-Apr-21	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	13:20	17:00	3:40	NFBC ISSUED
376	29-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
377	29-Apr-21	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
378	29-Apr-2021	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	23:57 (29-04-2021)			LINE OPEN:LINE FAULT
379	29-Apr-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	22:54	23:14	00:20	LINE FAULT
380	29-Apr-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	22:54	23:14	00:20	LINE FAULT
381	29-Apr-2021	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	06:40	06:42	00:02	LOAD CHANGE OVER
382	29-Apr-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	04:35	05:00	00:24	LINE FAULT
383	29-Apr-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	06:09	06:39	00:30	LINE FAULT
384	29-Apr-2021	BENGALURU	66	HOSUR RAMAPURA - GOWRIBIDANUR 220	HOSURU RAMAPURA, NITRALLI	21:55	22:05	00:09	LINE FAULT
385	29-Apr-2021	BENGALURU	66	HV1	VIJAYANAGARA	23:40	23:59	00:19	MAIN SUPPLY FAILURE
386	29-Apr-2021	BENGALURU	66	HV1	VIJAYANAGARA	01:10	01:15	00:05	LOAD CHANGE OVER
387	29-Apr-2021	BENGALURU	66	HV1	L R BANDE	09:33	11:38	02:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
388	29-Apr-2021	BENGALURU	66	HV1	KIADB DB PURA 220	05:20	06:51	01:31	TRANSFORMER FAULT
389	29-Apr-2021	BENGALURU	66	HV1	TEKAL	10:25	10:29	00:04	TRANSFORMER FAULT
390	29-Apr-2021	BENGALURU	66	HV1	VOLVO	23:08	23:23	00:14	TRANSFORMER FAULT
391	29-Apr-2021	BENGALURU	66	HV1	KANAKAPURA 66	08:15	08:30	00:15	TRANSFORMER FAULT
392	29-Apr-2021	BENGALURU	66	HV2	L R BANDE	09:33	11:40	02:07	TRANSFORMER FAULT
393	29-Apr-2021	BENGALURU	66	HV2	CHANDAPURA	23:58 (28-04-2021)	01:20	01:22	TRANSFORMER FAULT
394	29-Apr-2021	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL, GOWNPALLI	04:20	04:37	00:17	LINE FAULT
395	29-Apr-2021	BENGALURU	66	REMCO - NRS	NO STATION AFFECTED	23:40(29/04/2021)			LINE OPEN:LINE FAULT
396	29-Apr-2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
397	29-Apr-2021	GULBARGA	66	HV1	TAMBRAHALI_66	14:15	14:20	00:05	TRANSFORMER FAULT
398	29-Apr-2021	GULBARGA	66	HV1	TAMBRAHALI_66	14:40	14:45	00:05	TRANSFORMER FAULT
399	29-Apr-2021	GULBARGA	66	HV1	TAMBRAHALI_66	14:50	14:55	00:05	TRANSFORMER FAULT
400	29-Apr-2021	GULBARGA	66	HV1	TAMBRAHALI_66	15:30	15:35	00:05	TRANSFORMER FAULT
401	29-Apr-2021	GULBARGA	66	HV1	TAMBRAHALI_66	19:40	19:45	00:05	TRANSFORMER FAULT
402	29-Apr-2021	GULBARGA	66	KOGALI-KUDLIGI	KUDLIGI_66	19:35(28.04.2021)	11:10(30.04.2021)	15:35 HRS	LINE CHARGED
403	29-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	15:50	15:55	00:05	LINE FAULT
404	29-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	16:25	16:35	00:10	LINE FAULT
405	29-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	17:10	18:17	01:07	LINE FAULT
406	29-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	19:54	20:26	00:32	LINE FAULT
407	29-Apr-2021	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	21:02	21:56	00:54	LINE FAULT
408	29-Apr-2021	GULBARGA	110	ALIPUR-MUNIRABAD	TORANGALLU_110,KUDITINI_110,KURUGOD_110,SHATVAHANA_IPP,AGARWAL_IPP,SUZLON_IPP,KAMALAPUR_110,MATRI_110, RBNS FACTORY	06:23	06:38	00:15	LINE FAULT
409	29-Apr-2021	GULBARGA	110	CHORNOOR-ACME SOLAR	CHORNOOR_66	15:43	16:17	00:34	LINE FAULT
410	29-Apr-2021	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	03:36	03:37	00:01	LINE FAULT
411	29-Apr-2021	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	07:35	17:00	09:25	LINE CLEAR AVAILED
412	29-Apr-2021	GULBARGA	110	HV1	CHORNOOR_66	14:45	14:50	00:05	TRANSFORMER FAULT
413	29-Apr-2021	GULBARGA	110	HV1	CHORNOOR_66	20:35	20:40	00:05	TRANSFORMER FAULT
414	29-Apr-2021	GULBARGA	110	HV1	METRI_110	19:58	20:05	00:07	TRANSFORMER FAULT
415	29-Apr-2021	GULBARGA	110	HV1	METRI_110	21:47	21:50	00:03	TRANSFORMER FAULT
416	29-Apr-2021	GULBARGA	110	HV2	DEODURGA_110	19:14	19:24	00:10	TRANSFORMER FAULT
417	29-Apr-2021	GULBARGA	110	HV2	KAMPLI_GLB_110	19:34	19:37	00:03	TRANSFORMER FAULT
418	29-Apr-2021	GULBARGA	110	HV3	GULBARGA UNIVERSITY	16:10	16:20	00:10	TRANSFORMER FAULT
419	29-Apr-2021	GULBARGA	110	HV4	YELBURGA_110	19:12	19:32	00:20	TRANSFORMER FAULT
420	29-Apr-2021	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	18:18	18:28	00:10	LINE FAULT
421	29-Apr-2021	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	22:08	22:18	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
422	29-Apr-2021	GULBARGA	110	METRI-ALIPUR	METRI_110	06:20	06:35	00:15	MAIN SUPPLY FAILURE
423	29-Apr-2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	12:00(29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
424	29-Apr-2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	20:50(27.04.2021)	11:55(29.04.2021)	39:05 HRS	LINE CHARGED
425	29-Apr-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	01:28	01:38	00:10	LINE FAULT
426	29-Apr-2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	14:35	14:45	00:10	LINE FAULT
427	29-Apr-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	17:50	18:06	00:16	LINE FAULT
428	29-Apr-2021	GULBARGA	110	SINDHANOOR-SINDHANOOR1	SINDHANOOR_110	18:10	18:25	00:15	LINE FAULT
429	29-Apr-2021	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	18:00	18:10	00:10	LINE FAULT
430	29-Apr-2021	GULBARGA	110	SIRWAR-ALKOD	SIRWAR_110	19:55	20:15	00:20	LINE CLEAR AVAILED
431	29-Apr-2021	GULBARGA	110	STARMETALLIC-MUNIRBAD	MUNIRABAD_220	19:44	22:07	02:23	LINE FAULT
432	29-Apr-2021	GULBARGA	220	LINGAPUR-BTPS	LINGAPUR_220	19:52	23:36	03:44	LINE FAULT
433	29-Apr-2021	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	15:21(29.4.21)			LINE OPEN:LINE CLEAR AVAILED
434	29-Apr-2021	GULBARGA	400	RTPS-BTPS	RTPS_400	16:45(29.4.21)			LINE OPEN:LINE FAULT
435	29-Apr-2021	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	14:45	15:00	00:15	LINE CLEAR AVAILED
436	29-Apr-2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	16:00	16:10	00:10	LINE FAULT
437	29-Apr-2021	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	20:01	20:36	00:35	HAND TRIPPED
438	29-Apr-2021	HASSAN	66	BHADRA-SHMGA 1	bhadra_gen	19:25	20:12	00:47	LINE FAULT
439	29-Apr-2021	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	20:01	20:25	00:24	LINE FAULT
440	29-Apr-2021	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	15:57	16:38	00:41	LINE FAULT
441	29-Apr-2021	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	12:50	12:55	00:05	LINE FAULT
442	29-Apr-2021	HASSAN	66	HV1	BANDISHETTYHALLI_66	12:50	13:00	00:10	MAIN SUPPLY FAILURE
443	29-Apr-2021	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	20:48	20:57	00:09	LINE FAULT
444	29-Apr-2021	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	20:45	20:50	00:05	LINE FAULT
445	29-Apr-2021	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
446	29-Apr-2021	HASSAN	66	Lv2	HOLENARASIPURA_220	09:39	14:48	05:09	LINE CLEAR AVAILED
447	29-Apr-2021	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
448	29-Apr-2021	HASSAN	66	MRSSHM-BD-1	MRSMSG_220	19:26	20:01	00:35	LINE FAULT
449	29-Apr-2021	HASSAN	66	MRSSHM-BD-2	MRSMSG_220	19:45	20:25	00:40	LINE FAULT
450	29-Apr-2021	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	19:35	20:08	00:33	LINE FAULT
451	29-Apr-2021	HASSAN	66	SAKALE-IPCL1	SAKLESHUPURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
452	29-Apr-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	01:13	01:27	00:14	LINE FAULT
453	29-Apr-2021	HASSAN	66	SAKALE-IPCL2	SAKLESHUPURA_66	09:57	18:39	08:42	LINE CLEAR AVAILED
454	29-Apr-2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:40 (29.04.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
455	29-Apr-2021	HASSAN	110	HV1	BANTWAL_110	10:19	12:37	02:18	LINE CLEAR AVAILED
456	29-Apr-2021	HASSAN	110	HV2	PUTUR_110	15:35(29.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
457	29-Apr-2021	HASSAN	110	KADUR-AJAMPURA	KADUR_220	20:34	20:42	00:08	LINE FAULT
458	29-Apr-2021	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	20:57(29.04.2021)			LINE OPEN:LINE FAULT
459	29-Apr-2021	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	19:15	20:57	01:42	LINE FAULT
460	29-Apr-2021	HASSAN	110	MRSSHM-BADRAVATY2	MRSMSG_220	19:15	20:58	01:43	LINE FAULT
461	29-Apr-2021	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	20:23(29.04.2021)			LINE OPEN:LINE FAULT
462	29-Apr-2021	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:28	13:47	03:19	LINE CLEAR AVAILED
463	29-Apr-2021	HASSAN	220	HV2	HOLENARASIPURA_220	09:39	14:48	05:09	LINE CLEAR AVAILED
464	29-Apr-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	21:40(29.04.21)			LINE OPEN:LINE FAULT
465	29-Apr-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	20:34	21:51	01:17	LINE FAULT
466	29-Apr-2021	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	10:29	13:47	03:18	LINE CLEAR AVAILED
467	29-Apr-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	20:34	21:52	01:18	LINE FAULT
468	29-Apr-2021	MYSURU	66	BANNIMANTAPA-VIJAYANAGAR	NO STATIONS EFFECTED	13:54	16:34	2:39	MAIN SUPPLY FAILURE
469	29-Apr-2021	MYSURU	66	CR NAGARA-PANYADAHUNDI	HEMMARGALA_66, PANDYADAHUNDI_66 & KARYA_66	18:07	18:20	0:12	LINE FAULT
470	29-Apr-2021	MYSURU	66	HV1	K_HONNALGERE_66	12:40	13:15	0:35	MAIN SUPPLY FAILURE
471	29-Apr-2021	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
472	29-Apr-2021	MYSURU	66	HV2	K_HONNALGERE_66	12:40	13:15	0:35	MAIN SUPPLY FAILURE
473	29-Apr-2021	MYSURU	66	HV2	KMDODDI_66	16:57	17:05	0:08	TRANSFORMER FAULT
474	29-Apr-2021	MYSURU	66	HV5	SFC SIVA	18:12	6:13	12:00	MAIN SUPPLY FAILURE
475	29-Apr-2021	MYSURU	66	KUSHALNAGARA-HARANGI	NO STATIONS EFFECTED	16:40	16:54	0:14	LINE FAULT
476	29-Apr-2021	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	CB HALLI_66, ALUR SIDDAPUR_66, RUDRAPATNA_66 & KANAGAL_66	16:26	16:38	0:12	LINE FAULT
477	29-Apr-2021	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	CB HALLI_66, ALUR SIDDAPUR_66, RUDRAPATNA_66 & KANAGAL_66	16:40	17:03	0:23	LINE FAULT
478	29-Apr-2021	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	9:04	9:09	0:05	LINE FAULT
479	29-Apr-2021	MYSURU	66	TUBINKERE-PANDAVAPURA	DB HALLI & PANDAVAPURA STATIONS INTERRUPTED.	18:34	18:40	0:05	LINE FAULT
480	29-Apr-2021	MYSURU	220	HV1	HOOTAGALLI	15:16	16:18	1:02	LINE CLEAR AVAILED
481	29-Apr-2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
482	29-Apr-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	22:19	22:49	00:30	LINE FAULT
483	29-Apr-2021	TUMKUR	66	ANTHRASANAHALLI 220KV-KORA	KORA_66, THOVINAKERE_66	20:48	21:03	00:15	LINE FAULT
484	29-Apr-2021	TUMKUR	66	CHANNAGIRI-LINGDHILI	CHANNAGIRI_66	17:48	19:13	01:25	MAIN SUPPLY FAILURE
485	29-Apr-2021	TUMKUR	66	CHITRADURGA 220kv-CHALLAKERE	BALENAHALLI_66, CHALLAKERE_66, SANIKERE_66	20:42	21:57	01:14	LINE CLEAR AVAILED
486	29-Apr-2021	TUMKUR	66	CHITRADURGA 220kv-TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	20:59	21:22	00:22	HAND TRIPPED
487	29-Apr-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	09:49	10:00	00:10	LINE FAULT
488	29-Apr-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	10:29	13:43	03:13	LINE CLEAR AVAILED
489	29-Apr-2021	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:32	13:48	00:16	LINE FAULT
490	29-Apr-2021	TUMKUR	66	HARIHARA-DAVANGERE	HARIHAR_66	10:30	13:55	03:25	MAIN SUPPLY FAILURE
491	29-Apr-2021	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KTTE)	HARIYABBE_66	21:07	22:03	00:56	HAND TRIPPED
492	29-Apr-2021	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	21:31	21:38	00:07	MAIN SUPPLY FAILURE
493	29-Apr-2021	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	21:00	21:06	00:06	LINE FAULT
494	29-Apr-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	22:17	22:33	00:16	MAIN SUPPLY FAILURE
495	29-Apr-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:14	18:43	00:29	LINE FAULT
496	29-Apr-2021	TUMKUR	66	HOLALKERE-PANDRAHALI2	HOLALKERE_66	22:17	22:33	00:16	MAIN SUPPLY FAILURE
497	29-Apr-2021	TUMKUR	66	HOLALKERE-PANDRAHALI2	HOLALKERE_66	18:14	18:29	00:15	LINE FAULT
498	29-Apr-2021	TUMKUR	66	HOLALKERE-PANDRAHALI2	HOLALKERE_66	16:13	16:22	00:09	LINE FAULT
499	29-Apr-2021	TUMKUR	66	HONNALLI 220kv-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	17:43	17:59	00:15	LINE FAULT
500	29-Apr-2021	TUMKUR	66	HONNALLI 220kv-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	18:46	21:11	02:25	LINE FAULT
501	29-Apr-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	17:48	18:02	00:13	LINE FAULT
502	29-Apr-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	18:02	19:13	01:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
503	29-Apr-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELA GUNDA_66	21:40	21:45	00:05	HAND TRIPPED
504	29-Apr-2021	TUMKUR	66	KORA- ANTHRASANAHALLI	KADEHALLI_110	20:50	21:13	00:23	MAIN SUPPLY FAILURE
505	29-Apr-2021	TUMKUR	66	KORA- BRAHMASANDRA	KORA_66, BRAHMASANDRA_66, THOVINAKERE_66	20:50	21:13	00:23	MAIN SUPPLY FAILURE
506	29-Apr-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66	19:40	19:57	00:16	LINE FAULT
507	29-Apr-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66	20:08	20:39	00:31	LINE FAULT
508	29-Apr-2021	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66	20:49	21:20	00:31	LINE FAULT
509	29-Apr-2021	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	18:24	18:34	00:10	LINE FAULT
510	29-Apr-2021	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	20:04	20:19	00:14	LINE FAULT
511	29-Apr-2021	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	21:36	21:59	00:23	LINE FAULT
512	29-Apr-2021	TUMKUR	66	PAVAGADA220-SHYLAPURA	PAVAGADA_220	21:20	21:40	00:20	LINE FAULT
513	29-Apr-2021	TUMKUR	66	PAVAGADA220-SHYLAPURA	PAVAGADA_220	22:25	22:35	00:10	LINE FAULT
514	29-Apr-2021	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	20:05	21:00	00:55	LINE FAULT
515	29-Apr-2021	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	22:25	22:50	00:25	LINE FAULT
516	29-Apr-2021	TUMKUR	66	PAVAGADA-MADHUGIRI(PAVAGADA 220)	PAVAGADA_66	23:10	00:10	01:00	LINE FAULT
517	29-Apr-2021	TUMKUR	66	PAVAGADA-MIDIGESHI	MEDIGESHI_66	22:43	23:22	00:38	MAIN SUPPLY FAILURE
518	29-Apr-2021	TUMKUR	66	PAVAGADA-NAGALAMADIKE	PAVAGADA_220	22:25	22:50	00:25	LINE FAULT
519	29-Apr-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	20:00	20:19	00:18	MAIN SUPPLY FAILURE
520	29-Apr-2021	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	22:48	22:57	00:09	MAIN SUPPLY FAILURE
521	29-Apr-2021	TUMKUR	66	TR-1	BALENAHALLI_66	09:49	09:54	00:04	TRANSFORMER FAULT
522	29-Apr-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	15:00	15:04	00:04	TRANSFORMER FAULT
523	29-Apr-2021	TUMKUR	66	TR-1	HARIHAR_66	10:30	13:55	03:25	MAIN SUPPLY FAILURE
524	29-Apr-2021	TUMKUR	66	TR-1	HULIYURDURGA_66	19:55	22:38	02:42	LINE CLEAR AVAILED
525	29-Apr-2021	TUMKUR	66	TR-1	PAVAGADA_66	22:49	23:43	00:53	MAIN SUPPLY FAILURE
526	29-Apr-2021	TUMKUR	66	TR-1	PAVAGADA_220	20:05	20:10	00:05	TRANSFORMER FAULT
527	29-Apr-2021	TUMKUR	66	TR-1	PAVAGADA_220	22:25	22:35	00:10	TRANSFORMER FAULT
528	29-Apr-2021	TUMKUR	66	TR-1	RAMPURA_66	12:21	12:33	00:12	TRANSFORMER FAULT
529	29-Apr-2021	TUMKUR	66	TR-2	HARIHAR_66	10:30	13:55	03:25	MAIN SUPPLY FAILURE
530	29-Apr-2021	TUMKUR	66	TR-2	HOLALKERE_66	17:41	18:28	00:47	TRANSFORMER FAULT
531	29-Apr-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	19:41	22:49	03:07	LINE CLEAR AVAILED
532	29-Apr-2021	TUMKUR	66	TR-2	PAVAGADA_66	22:49	23:43	00:53	MAIN SUPPLY FAILURE
533	29-Apr-2021	TUMKUR	66	TR-2	PAVAGADA_220	20:05	20:10	00:05	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
534	29-Apr-2021	TUMKUR	66	TR-2	PAVAGADA_220	22:25	22:35	00:10	TRANSFORMER FAULT
535	29-Apr-2021	TUMKUR	66	TR-2	SASUVEHALLI_66,	18:34	19:20	00:46	TRANSFORMER FAULT
536	29-Apr-2021	TUMKUR	66	TR-3	CHITRADURGA_220	20:42	21:21	00:38	HAND TRIPPED
537	29-Apr-2021	TUMKUR	66	URDIGERE-ANTHRASANAHALI	URDIGERE_66	22:25	22:49	00:23	MAIN SUPPLY FAILURE
538	29-Apr-2021	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	13:32	17:29	03:57	LINE FAULT
539	29-Apr-2021	TUMKUR	220	PAVAGADA 220kV- GREEN KO	HEBBUR_66, BHAKTARAHALLI_66	22:21	22:37	00:15	LINE FAULT
540	29-Apr-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 1	PAVAGADA_220	22:01	22:12	00:11	LINE FAULT
541	29-Apr-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 1	PAVAGADA_220	22:21	22:31	00:10	LINE FAULT
542	29-Apr-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 2	PAVAGADA_220	22:01	22:16	00:15	LINE FAULT
543	29-Apr-2021	TUMKUR	220	PAVAGADA 220kV- MADHUGIRI 2	PAVAGADA_220	22:21	22:25	00:04	LINE FAULT
544	29-Apr-2021	TUMKUR	220	TR-1	PAVAGADA_220	20:00	20:13	00:13	TRANSFORMER FAULT
545	29-Apr-2021	TUMKUR	220	TR-1	PAVAGADA_220	22:21	22:36	00:15	TRANSFORMER FAULT
546	29-Apr-2021	TUMKUR	220	TR-2	PAVAGADA_220	20:00	20:13	00:13	TRANSFORMER FAULT
547	29-Apr-2021	TUMKUR	220	TR-2	PAVAGADA_220	22:21	23:26	01:05	TRANSFORMER FAULT
548	29-Apr-2021	TUMKUR	220	TR-3	CHITRADURGA_220	20:42	21:01	00:19	TRANSFORMER FAULT
549	30-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
550	30-Apr-21	BAGALKOT	110	110/11KV, HV1	NAVANAGAR(H)_110	14:05	14:30	0:25	LINE CLEAR AVAILED
551	30-Apr-21	BAGALKOT	110	110/11KV, HV1	MUKARTIHAL_110	10:16	10:37	0:21	LINE CLEAR AVAILED
552	30-Apr-21	BAGALKOT	110	110/11KV, HV1&HV2	SUVARNASOUDA_110	06:07	06:16	0:09	TRANSFORMER FAULT
553	30-Apr-21	BAGALKOT	110	110/11KV,HV 1	GOPANAKOPPA_110	11:27	12:05	0:38	HAND TRIPPED
554	30-Apr-21	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED NARENDRA_220	18:28 (29.04.2021)	9:47 (30.04.2021)	15:19 hrs	TRANSFORMER CHARGED
555	30-Apr-21	BAGALKOT	110	AIGALI-SAVALAGI	SAVALAGI_110	10:25	10:39	0:14	LINE FAULT
556	30-Apr-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	6:20	06:23	0:03	LINE FAULT
557	30-Apr-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:08 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
558	30-Apr-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	21:58 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
559	30-Apr-21	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
560	30-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
561	30-Apr-21	BAGALKOT	110	BIDNAL-ANNIGERI	STATION NOT AFFECTED BIDNAL_220	17:41 (29.04.2021)	12:35 (30.04.2021)	18:54	LINE FAULT
562	30-Apr-21	BAGALKOT	110	GADAG -BETAGERI	BETAGERI_110	9:35	11:10	1:35	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
563	30-Apr-21	BAGALKOT	110	GADAG -BETAGERI	BETAGERI_110	13:39	15:18	1:39	LINE FAULT
564	30-Apr-21	BAGALKOT	110	HUBLI-KALAGATAGI	STATION NOT AFFECTED KALAGATAGI_110	14:56 (29.04.2021)	13:28 (30.04.2021)	22:32	LINE FAULT
565	30-Apr-21	BAGALKOT	110	ITNAL-RAIBAG 2	ITNAL_110	0:53	1:05	0:12	LINE FAULT
566	30-Apr-21	BAGALKOT	110	KADANAKOPPA- KAVALWADA(AMBEWADI)	STATION NOT AFFECTEDKADANAKOPPA_110	19:45 (29.04.2021)	15:53 (30.04.2021)	20:08 hrs	LINE CHARGED
567	30-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
568	30-Apr-21	BAGALKOT	110	MANALI SUGARS- MALGHAN (S)	MALGHAN(S)_110	4:00	6:00	2:00	LINE FAULT
569	30-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
570	30-Apr-21	BAGALKOT	110	TAKKALKI-KN BIJAPUR SOLAR	KN BIJAPUR SOLAR_110 STATION NOT AFFECTED TAKKALAKI_110	13:59 (29.04.2021)	2:58 (30.04.2021)	12:59	LINE FAULT
571	30-Apr-21	BAGALKOT	110	TUMMINAKATI- RANEBENNUR220	STATION NOT AFFECTED TUMMINAKATTI_110	20:10 (29.04.2021)			LINE OPEN:LINE FAULT
572	30-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
573	30-Apr-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
574	30-Apr-21	BAGALKOT	220	GHATAPRABHA -NARENDRA 2	GHATAPRABHA_220	5:19	5:48	0:29	LINE FAULT
575	30-Apr-21	BAGALKOT	220	GHATAPRABHA-CHIKKODI1	GHATAPRABHA_220	17:16 (29.04.2021)	7:42 (30.04.2021)	14:26	LOAD CURTAILMENT
576	30-Apr-21	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	18:23 (29.04.2021)	8:13 (30.04.2021)	13:50	LINE FAULT
577	30-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
578	30-Apr-21	BAGALKOT	220	MUGALKOD-GHATAPRABHA1	MUGALKOD_220	17:35 (29.04.2021)	7:46 (30.04.2021)	14:11 hrs	LINE CHARGED
579	30-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
580	30-Apr-21	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	18:25 (29.04.2021)	8:13 (30.04.2021)	13:48	LINE FAULT
581	30-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
582	30-Apr-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
583	30-Apr-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	19:30	21:31	2:01	LINE FAULT
584	30-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
585	30-Apr-21	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
586	30-Apr-21	BENGALURU	66	BMTC - EAST DIVISION COMPOUND	BMTC	14:09	14:23	00:14	MAIN SUPPLY FAILURE
587	30-Apr-21	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	23:57 (29-04-2021)	00:08	00:11	LINE FAULT
588	30-Apr-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	16:05	16:29	00:24	LINE CLEAR AVAILED
589	30-Apr-21	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	11:43	12:04	00:21	LINE FAULT
590	30-Apr-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	00:09	00:28	00:18	LINE FAULT
591	30-Apr-21	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN:LINE FAULT
592	30-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - AFTL (EHT)	AFTL (EHT)	13:40	13:45	00:05	LINE FAULT
593	30-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	00:09	00:19	00:10	LINE FAULT
594	30-Apr-21	BENGALURU	66	GUDIBANDE - D PALYA	GUDIBANDE	11:15	11:20	00:05	LINE CLEAR AVAILED
595	30-Apr-21	BENGALURU	66	GUDIBANDE - D PALYA	GUDIBANDE	12:05	12:10	00:05	LINE CLEAR AVAILED
596	30-Apr-21	BENGALURU	66	HV1	GUDIBANDE	02:20	02:30	00:10	TRANSFORMER FAULT
597	30-Apr-21	BENGALURU	66	HV1	GUDIBANDE	02:30	02:50	00:20	TRANSFORMER FAULT
598	30-Apr-21	BENGALURU	66	HV1	GUDIBANDE	11:20	12:13	00:52	TRANSFORMER FAULT
599	30-Apr-21	BENGALURU	66	HV1	GUDIBANDE	12:50	13:00	00:10	LINE CLEAR AVAILED
600	30-Apr-21	BENGALURU	66	HV1	GUDIBANDE	13:20	14:00	00:40	LINE CLEAR AVAILED
601	30-Apr-21	BENGALURU	66	HV1	GUDIBANDE	14:19	15:05	00:46	LINE CLEAR AVAILED
602	30-Apr-21	BENGALURU	66	HV1	VIJAYANAGARA	01:10	01:15	00:05	LOAD CHANGE OVER
603	30-Apr-21	BENGALURU	66	HV2	MAASTHI	10:03	10:09	00:05	TRANSFORMER FAULT
604	30-Apr-21	BENGALURU	66	HV2	MAASTHI	14:04	14:08	00:04	TRANSFORMER FAULT
605	30-Apr-21	BENGALURU	66	HV2	THAYALUR	14:40	15:54	01:14	LINE CLEAR AVAILED
606	30-Apr-21	BENGALURU	66	HV3	ADUGODI	01:15	01:26	00:11	TRANSFORMER FAULT
607	30-Apr-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA	20:07	20:31	00:24	LINE FAULT
608	30-Apr-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	07:13	07:18	00:05	LINE FAULT
609	30-Apr-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	18:12	18:35	00:23	LINE FAULT
610	30-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	06:52	06:57	00:05	LOAD CHANGE OVER
611	30-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLU KOTTUR	06:52	06:57	00:05	LOAD CHANGE OVER
612	30-Apr-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	06:52	06:57	00:05	LOAD CHANGE OVER
613	30-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	06:52	06:57	00:05	LOAD CHANGE OVER
614	30-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	SOMENAHALLI, PERESANDRA,	00:04	00:10	00:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
615	30-Apr-21	BENGALURU	66	SOMENAHALLI - PATHPALYA	SOMENAHALLI	00:04	00:21	00:16	LINE FAULT
616	30-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
617	30-Apr-21	BENGALURU	220	HV2	GOWRIBIDANUR 220	05:57	07:36	01:39	TRANSFORMER FAULT
618	30-Apr-21	GULBARGA	66	HV2	TAMBRAHALLI_66	08:20	08:25	00:05	TRANSFORMER FAULT
619	30-Apr-21	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	01:51	01:54	00:03	LINE FAULT
620	30-Apr-21	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	23:40	23:51	00:11	LINE FAULT
621	30-Apr-21	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	04:45	04:55	00:10	LINE FAULT
622	30-Apr-21	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110,KONKAL_110	05:30	05:35	00:05	LINE FAULT
623	30-Apr-21	GULBARGA	110	HALBARGA-CHIDRI2	CHIDRI_110	16:13	16:25	00:12	LINE FAULT
624	30-Apr-21	GULBARGA	110	HALBARGA-KOLHAR 1	KOLHAR_110,JANWADA_110,NS SK SUGAR FACTORY	16:13	16:25	00:12	LINE FAULT
625	30-Apr-21	GULBARGA	110	HALBARGA-KOLHAR 2	KOLHAR_110,JANWADA_110,NS SK SUGAR FACTORY	16:13	16:52	00:39	LINE FAULT
626	30-Apr-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGARGAO N_110,DIGGI_110	16:13	16:20	00:07	LINE FAULT
627	30-Apr-21	GULBARGA	110	HV1	BENUR_110	10:16	10:30	00:14	TRANSFORMER FAULT
628	30-Apr-21	GULBARGA	110	HV1	MANTHAL_110	18:30	18:40	00:10	LINE CLEAR AVAILED
629	30-Apr-21	GULBARGA	110	HV2	MANTHAL_110	15:30	18:25	02:55	LINE CLEAR AVAILED
630	30-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	04:29	04:40	00:11	LINE FAULT
631	30-Apr-21	GULBARGA	110	NALWAR-CLN SLR	NALWAR_110	09:00	09:27	00:27	LINE FAULT
632	30-Apr-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	12:00(29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
633	30-Apr-21	GULBARGA	110	SHAHABAD-BAGEWADI2	MORATAGI_110,YADRAMI_110	03:50	03:55	00:05	LINE FAULT
634	30-Apr-21	GULBARGA	110	SHAHABAD-RAICHUR1&2	NALWAR_110,JEWARAGI_110,SHAHAPUR_110	11:30(30.04.2021)			LINE OPEN:LINE CLEAR AVAILED
635	30-Apr-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	01:28	01:38	00:10	LINE FAULT
636	30-Apr-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	10:13	12:22	02:09	LINE FAULT
637	30-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	09:55	18:15	08:20	LINE CLEAR AVAILED
638	30-Apr-21	GULBARGA	110	SINDHANOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	05:15	05:20	00:05	LINE FAULT
639	30-Apr-21	GULBARGA	220	HV1	HALBARGA_220	16:13	16:19	00:06	TRANSFORMER FAULT
640	30-Apr-21	GULBARGA	220	LINGAPUR-JINDAL1	LINGAPUR_220	16:07	18:29	02:22	LINE CLEAR AVAILED
641	30-Apr-21	GULBARGA	220	LINGAPUR-JINDAL2	LINGAPUR_220	10:39	16:01	05:22	LINE CLEAR AVAILED
642	30-Apr-21	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	17:21	17:55	00:34	LINE FAULT
643	30-Apr-21	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	15:21(29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
644	30-Apr-21	GULBARGA	400	RTPS-BTPS	RTPS_400	16:45(29.04.2021)	14:14(30.04.2021)	21:29HRS	LINE CHARGED
645	30-Apr-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	15:29	16:01	00:32	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
646	30-Apr-21	HASSAN	66	HV1	MAGGE_66	11:34	12:09	00:35	TRANSFORMER FAULT
647	30-Apr-21	HASSAN	66	HV1	SALAGAME_66	11:13	12:16	01:03	LINE CLEAR AVAILED
648	30-Apr-21	HASSAN	66	HV1	SOMANAHALLI_66	11:55	11:58	00:03	HAND TRIPPED
649	30-Apr-21	HASSAN	66	KUDLIGE- SIGEBAGI	KUDLIGERE_66	13:30	13:55	00:25	MAIN SUPPLY FAILURE
650	30-Apr-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	08:05	10:45	02:40	MAIN SUPPLY FAILURE
651	30-Apr-21	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	07:30	08:05	00:35	NFBC ISSUED
652	30-Apr-21	HASSAN	66	KUDLIGE-SIGEBAGI	KUDLIGERE_66	10:35	11:00	00:25	HAND TRIPPED
653	30-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
654	30-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
655	30-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
656	30-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	08:45	18:49	10:04	LINE CLEAR AVAILED
657	30-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:40 (29.04.2021)			LINE OPEN:LINE FAULT
658	30-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	07:15	08:25	01:10	LINE CLEAR AVAILED
659	30-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	08:25	08:40	00:15	LINE FAULT
660	30-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	08:40	10:40	02:00	LINE FAULT
661	30-Apr-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	13:27	13:50	00:23	LINE FAULT
662	30-Apr-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	11:15	11:57	00:42	LINE FAULT
663	30-Apr-21	HASSAN	110	HV1	PUTTUR_110	9:19 (30.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
664	30-Apr-21	HASSAN	110	HV1	BARANGI_110	11:58	12:07	00:09	HAND TRIPPED
665	30-Apr-21	HASSAN	110	HV1	KONDENALU_110	11:11	13:49	02:38	LINE CLEAR AVAILED
666	30-Apr-21	HASSAN	110	HV2	PUTTUR_110	15:35(29.04.2021)	9:37 (30.04.2021)	18:01 hrs	TRANSFORMER CHARGED
667	30-Apr-21	HASSAN	110	HV2	BARANGI_110	11:58	12:07	00:09	HAND TRIPPED
668	30-Apr-21	HASSAN	110	HV2	KONDENALU_110	10:21	14:01	03:40	LINE CLEAR AVAILED
669	30-Apr-21	HASSAN	110	MRSSHM-BADRAVATY1	MRSMSG_220	20:57 (29.04.2021)	11:06 (30.04.2021)	14:08 hrs	LINE CHARGED
670	30-Apr-21	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	20:23(29.04.2021)	2:34 (30.04.2021)	6:08 hrs	LINE CHARGED
671	30-Apr-21	HASSAN	220	KADUR-DABUSET	KADUR_220	21:40(29.04.21)	9:14 (30.04.2021)	11:33hrs	LINE CHARGED
672	30-Apr-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:58 (30.04.2021)			LINE OPEN:LINE CLEAR AVAILED
673	30-Apr-21	MYSURU	66	BANNIMANTAPA-VIJAYANAGARA	NO STATIONS EFFECTED	11:13	15:22	4:08	LINE CLEAR AVAILED
674	30-Apr-21	MYSURU	66	HOOTAGALLY-BOGADHI	BOGADHI_66, KALAMANDIRA_66	6:00	6:25	0:25	LINE FAULT
675	30-Apr-21	MYSURU	66	HV1	KMDODDI_66	10:38	12:25	1:47	LINE CLEAR AVAILED
676	30-Apr-21	MYSURU	66	HV1	VAJAMANGALA_220	7:16	18:15	10:59	LINE CLEAR AVAILED
677	30-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
678	30-Apr-21	MYSURU	66	HV2	SFCSHIVA_66	9:36	14:00	4:24	LINE CLEAR AVAILED
679	30-Apr-21	MYSURU	66	HV4	SFCSHIVA_66	7:29	9:53	2:23	LINE CLEAR AVAILED
680	30-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	18:12 (29/04/2021)	6:14 (30/04/2021)	12:02 HRS	TRANSFORMER CHARGED
681	30-Apr-21	MYSURU	66	KADAKOLA-SARAGUR 2	DOORA_66 HURA_66 HULLAHALLI_66	14:59	15:04	0:05	LINE FAULT
682	30-Apr-21	MYSURU	66	KIADB MANDYA-TUMBEKERE	TUMBEKERE_66	22:46	22:54	0:07	HAND TRIPPED
683	30-Apr-21	MYSURU	66	KM DODDI-MANDYA	KIADBMANDYA_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	22:43	22:55	0:11	HAND TRIPPED
684	30-Apr-21	MYSURU	66	KM DODDI-TK HALLI	KMDODDI_66	19:55	20:10	0:14	LINE FAULT
685	30-Apr-21	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	22:26	22:38	0:11	LINE FAULT
686	30-Apr-21	MYSURU	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	22:38	22:43	0:05	LINE FAULT
687	30-Apr-21	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN:LINE CLEAR AVAILED
688	30-Apr-21	MYSURU	66	SFC SIVA-HV5	SFCSHIVA_66	23:07 (30/04/2021)			LINE OPEN:LINE CLEAR AVAILED
689	30-Apr-21	MYSURU	220	HV1	HOOTAGALLY_220	9:45	14:54	5:09	LINE CLEAR AVAILED
690	30-Apr-21	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN:LINE CLEAR AVAILED
691	30-Apr-21	TUMKUR	66	ANTHRASANAHALI 220KV-KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:08	17:13	06:04	LINE CLEAR AVAILED
692	30-Apr-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	17:40	18:01	00:21	HAND TRIPPED
693	30-Apr-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	15:18	15:28	00:09	LINE FAULT
694	30-Apr-21	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	16:13	18:20	02:07	LINE CLEAR AVAILED
695	30-Apr-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:05	15:27	00:22	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
696	30-Apr-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:41	15:50	00:09	LINE FAULT
697	30-Apr-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:08	18:13	00:05	LINE FAULT
698	30-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:02	11:16	00:13	LINE FAULT
699	30-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:25	12:41	00:16	LINE FAULT
700	30-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:22	22:36	00:14	LINE FAULT
701	30-Apr-21	TUMKUR	66	HARIYABBE-PD KOTE	HARIYABBE_66	16:01	19:31	03:29	LINE CLEAR AVAILED
702	30-Apr-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELA GUNDA_66	06:11	06:16	00:04	LINE FAULT
703	30-Apr-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	12:34	12:37	00:02	LINE FAULT
704	30-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	01:15	01:21	00:06	LINE FAULT
705	30-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	01:52	01:57	00:05	LINE FAULT
706	30-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	02:01	02:06	00:05	LINE FAULT
707	30-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	02:51	02:57	00:05	LINE FAULT
708	30-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	03:35	03:41	00:06	LINE FAULT
709	30-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	04:00	04:36	00:35	LINE FAULT
710	30-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:32	12:43	00:11	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
711	30-Apr-21	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:47	13:29	00:41	LINE FAULT
712	30-Apr-21	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:32	12:43	00:11	LINE FAULT
713	30-Apr-21	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:47	13:29	00:41	LINE FAULT
714	30-Apr-21	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	08:11	08:47	00:36	MAIN SUPPLY FAILURE
715	30-Apr-21	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	08:11	08:47	00:36	MAIN SUPPLY FAILURE
716	30-Apr-21	TUMKUR	66	PAVAGADA_220-PAVGD1	PAVAGADA_220	06:15	06:25	00:09	HAND TRIPPED
717	30-Apr-21	TUMKUR	66	PAVAGADA_220-PAVGD1	PAVAGADA_220	06:15	06:25	00:09	HAND TRIPPED
718	30-Apr-21	TUMKUR	66	PAVAGADA_220-PAVGD2	PAVAGADA_220	05:31	06:14	00:43	HAND TRIPPED
719	30-Apr-21	TUMKUR	66	PAVAGADA_220-PAVGD2	PAVAGADA_220	05:31	06:14	00:43	HAND TRIPPED
720	30-Apr-21	TUMKUR	66	TR-1	CHAWANAKUPPE_66	12:42	13:05	00:23	LINE CLEAR AVAILED
721	30-Apr-21	TUMKUR	66	TR-1	IDHALLY_66	07:10	07:12	00:01	HAND TRIPPED
722	30-Apr-21	TUMKUR	66	TR-1	KORATAGERE_66	08:12	08:32	00:20	TRANSFORMER FAULT
723	30-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	06:13	06:19	00:05	MAIN SUPPLY FAILURE
724	30-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	13:57	14:05	00:08	TRANSFORMER FAULT
725	30-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	14:10	14:22	00:12	TRANSFORMER FAULT
726	30-Apr-21	TUMKUR	66	TR-1	THIMMASANDRA_66	06:36	06:47	00:10	HAND TRIPPED
727	30-Apr-21	TUMKUR	66	TR-1	THOVINAKERE_66	05:40	05:50	00:09	HAND TRIPPED
728	30-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	06:13	06:19	00:05	MAIN SUPPLY FAILURE
729	30-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	13:57	14:05	00:08	TRANSFORMER FAULT
730	30-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	14:10	14:22	00:12	TRANSFORMER FAULT
731	30-Apr-21	TUMKUR	66	TR-1	THIMMASANDRA_66	06:36	06:47	00:10	HAND TRIPPED
732	30-Apr-21	TUMKUR	66	TR-1	THOVINAKERE_66	05:40	05:50	00:09	HAND TRIPPED
733	30-Apr-21	TUMKUR	66	TR-2	HINDASGHATTA_66	12:25	12:36	00:11	HAND TRIPPED
734	30-Apr-21	TUMKUR	66	TR-2	MADHUGIRI_66	11:32	11:56	00:23	LINE CLEAR AVAILED
735	30-Apr-21	TUMKUR	66	TR-2	PAVAGADA_66	06:13	06:18	00:05	MAIN SUPPLY FAILURE
736	30-Apr-21	TUMKUR	66	TR-2	URDIGERE_66	10:52	11:59	01:07	LINE CLEAR AVAILED
737	30-Apr-21	TUMKUR	66	TR-2	URDIGERE_66	14:27	15:26	00:58	HAND TRIPPED
738	30-Apr-21	TUMKUR	66	TR-2	URDIGERE_66	16:45	17:28	00:42	HAND TRIPPED
739	30-Apr-21	TUMKUR	66	TR-2	MADHUGIRI_66	11:32	11:56	00:23	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
740	30-Apr-21	TUMKUR	66	TR-2	PAVAGADA_66	06:13	06:18	00:05	MAIN SUPPLY FAILURE
741	30-Apr-21	TUMKUR	66	TR-2	URDIGERE_66	10:52	11:59	01:07	LINE CLEAR AVAILED
742	30-Apr-21	TUMKUR	66	TR-2	URDIGERE_66	14:27	15:26	00:58	HAND TRIPPED
743	30-Apr-21	TUMKUR	66	TR-2	URDIGERE_66	16:45	17:28	00:42	HAND TRIPPED
744	30-Apr-21	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	11:09	17:07	05:58	NFBC ISSUED
745	30-Apr-21	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	11:09	17:07	05:58	NFBC ISSUED
746	30-Apr-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	10:51	11:58	01:06	LINE CLEAR AVAILED
747	30-Apr-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	14:27	15:24	00:57	HAND TRIPPED
748	30-Apr-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	16:45	17:24	00:39	HAND TRIPPED
749	30-Apr-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	10:51	11:58	01:06	LINE CLEAR AVAILED
750	30-Apr-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	14:27	15:24	00:57	HAND TRIPPED
751	30-Apr-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	16:45	17:24	00:39	HAND TRIPPED
752	30-Apr-21	TUMKUR	110	TR-3	AMMASANDRA_110	06:04	06:25	00:20	TRANSFORMER FAULT
753	30-Apr-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	12:25	12:40	00:14	LINE FAULT
754	01-May-21	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
755	01-May-21	BAGALKOT	110	110/11KV, HV1	RON_110	20:07	20:55	0:48	TRANSFORMER FAULT
756	01-May-21	BAGALKOT	110	110/11KV, HV2	SIRSI_110	11:05	11:23	0:18	LINE CLEAR AVAILED
757	01-May-21	BAGALKOT	110	110/11KV,HV1	HOSAHONNATTI_110	17:09	17:40	0:31	TRANSFORMER FAULT
758	01-May-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	22:15	22:20	0:05	TRANSFORMER FAULT
759	01-May-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	18:22	18:54	0:32	TRANSFORMER FAULT
760	01-May-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	17:05	17:28	0:23	TRANSFORMER FAULT
761	01-May-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:08 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
762	01-May-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	21:58 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
763	01-May-21	BAGALKOT	110	ASF SOLAR- SAVANUR	SAVANUR_110	16:33	16:43	0:10	LINE FAULT
764	01-May-21	BAGALKOT	110	ASF SOLAR- SAVANUR	SAVANUR_110	17:26	17:39	0:13	LINE FAULT
765	01-May-21	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
766	01-May-21	BAGALKOT	110	BAGALKOT-ACHANUR	ACHANUR_110	16:06	16:11	0:05	HAND TRIPPED
767	01-May-21	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	6:22	06:42	0:20	LINE FAULT
768	01-May-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
769	01-May-21	BAGALKOT	110	GADAG -LAXMESHVAR	LAXMESHVAR_110	15:14	16:34	1:20	LINE FAULT
770	01-May-21	BAGALKOT	110	GADAG ROAD - GOPANAKOPPA(I/C BIDNAL)	GOPANAKOPPA_110	17:05 (01.05.2021)			LINE OPEN:LINE FAULT
771	01-May-21	BAGALKOT	110	GAMESHA- RON	RON_110	20:00	20:03	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
772	01-May-21	BAGALKOT	110	GUTTAL-BASAVANKATTE(F2 CB)	BASAVAN KATTE_110	16:27	17:01	0:34	LINE FAULT
773	01-May-21	BAGALKOT	110	HAVERI-BASAVANKATTE(F1 CB)	BASAVAN KATTE_110	16:27	16:51	0:24	LINE FAULT
774	01-May-21	BAGALKOT	110	HIREHAL-RON	HIREHAL_110	19:12	19:36	0:24	LINE FAULT
775	01-May-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
776	01-May-21	BAGALKOT	110	LAXMESHWAR- GADAG1	LAXMESHWAR_110	15:14	16:39	1:25	LINE FAULT
777	01-May-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
778	01-May-21	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	20:50 (01.05.2021)			LINE OPEN:LINE FAULT
779	01-May-21	BAGALKOT	110	TUMMINAKATI- RANEBENNUR220	STATION NOT AFFECTED TUMMINAKATTI_110	20:10 (29.04.2021)	13:25 (01.05.2021)	40:15 hrs	LINE CHARGED
780	01-May-21	BAGALKOT	110	UGARSUGARS- UGARKHUD	UGARKHUD_110	14:19	14:45	0:26	LINE CLEAR AVAILED
781	01-May-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	20:54 (1.5.2021)			LINE OPEN:LINE FAULT
782	01-May-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
783	01-May-21	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	16:07	18:24	2:17	LINE FAULT
784	01-May-21	BAGALKOT	220	BIDNAL-HARTI 2	BIDNAL_220	16:24	18:25	2:01	LINE FAULT
785	01-May-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
786	01-May-21	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	18:29 (01.05.2021)			LINE OPEN:LINE FAULT
787	01-May-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	16:48 (01.05.2021)			LINE OPEN:LINE FAULT
788	01-May-21	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	16:58	20:31	3:33	LINE FAULT
789	01-May-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	16:49 (01.05.2021)			LINE OPEN:LINE FAULT
790	01-May-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
791	01-May-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
792	01-May-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
793	01-May-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
794	01-May-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	15:30	17:05	1:35	LINE FAULT
795	01-May-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
796	01-May-21	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
797	01-May-21	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	15:19(01/05/2021)			LINE OPEN:LINE FAULT
798	01-May-21	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
799	01-May-21	BENGALURU	66	HV1	M GOLLAHALLI	04:20	04:35	00:15	TRANSFORMER FAULT
800	01-May-21	BENGALURU	66	HV1	GOWRIBIDANUR 220	10:29	10:39	00:10	TRANSFORMER FAULT
801	01-May-21	BENGALURU	66	HV2	R R NAGAR	10:57	11:24	00:27	TRANSFORMER FAULT
802	01-May-21	BENGALURU	66	SOMANAHALLI 220 - KANAKAPURA 1	HANUMANTH NAGAR, YEDUMADU	09:02	09:11	00:09	LINE FAULT
803	01-May-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
804	01-May-21	GULBARGA	66	HV1	TAMBRAHALLI_66	11:10	11:15	00:05	TRANSFORMER FAULT
805	01-May-21	GULBARGA	66	HV1	TAMBRAHALLI_66	18:05	18:10	00:05	TRANSFORMER FAULT
806	01-May-21	GULBARGA	66	KOTTUR-UJJANI	UJJANI_66	14:20	14:35	00:15	MAIN SUPPLY FAILURE
807	01-May-21	GULBARGA	66	UJJANI-BREIPL	UJJANI_66	16:28	16:54	00:26	LINE FAULT
808	01-May-21	GULBARGA	110	HALBARGA-CHIDRI1	KAMTHANA_110,HABSIKOTE_110	15:52	15:56	00:04	LINE FAULT
809	01-May-21	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	14:50	15:07	00:17	LINE FAULT
810	01-May-21	GULBARGA	110	HUMNABAD-MANNAEKHELI	MANNAEKHELI_110	14:50	15:05	00:15	LINE FAULT
811	01-May-21	GULBARGA	110	HV1	SHAHABAD_220	18:25	18:30	00:05	TRANSFORMER FAULT
812	01-May-21	GULBARGA	110	HV1	KADAGANCHI_110	15:08	15:10	00:02	TRANSFORMER FAULT
813	01-May-21	GULBARGA	110	HV2	NIRNA_110	10:57	11:02	00:05	TRANSFORMER FAULT
814	01-May-21	GULBARGA	110	HV3	HALBARGA_220	19:24	19:30	00:06	TRANSFORMER FAULT
815	01-May-21	GULBARGA	110	HV3	KEREHALLI_110	08:00	08:17	00:17	TRANSFORMER FAULT
816	01-May-21	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110,TORANGALLU_110	21:34	21:40	00:06	LINE FAULT
817	01-May-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANA_110,HIREGONNAGAR_110	18:37(01.05.2021)			LINE OPEN:LINE FAULT
818	01-May-21	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDINNI_110	23:45	23:55	00:10	LINE FAULT
819	01-May-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	23:07	23:17	00:10	LINE FAULT
820	01-May-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	05:03	05:13	00:10	LINE FAULT
821	01-May-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	01:39	01:58	00:19	LINE FAULT
822	01-May-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	12:00(29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
823	01-May-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MORATAGI_110,YADRAMI_110	17:30	17:40	00:10	LINE FAULT
824	01-May-21	GULBARGA	110	SHAHABAD-CHITHAPUR	CHITHAPUR_110,KORWAR TEMPLE_110	16:55	17:00	00:05	LINE FAULT
825	01-May-21	GULBARGA	110	SHAHABAD-RAICHUR1&2	NALWAR_110,JEWARAGI_110,SHAHAPUR_110	11:30(30.04.2021)			LINE OPEN:LINE CLEAR AVAILED
826	01-May-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IP	21:37	21:45	00:08	LINE FAULT
827	01-May-21	GULBARGA	110	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	11:20	12:42	01:22	LINE CLEAR AVAILED
828	01-May-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	02:46	02:52	00:06	LINE FAULT
829	01-May-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	11:00	12:44	01:44	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
830	01-May-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	09:35	17:30	07:55	LINE CLEAR AVAILED
831	01-May-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	18:36	18:48	00:12	LINE FAULT
832	01-May-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	20:05	20:15	00:10	LINE FAULT
833	01-May-21	GULBARGA	220	HUMNABAD-SEDAM1,2	HALBARGA_220,KAPNOOR_220	11:57	12:25	00:28	LINE FAULT
834	01-May-21	GULBARGA	220	HV1	KUSHATGI_220	18:37	20:17	01:40	TRANSFORMER FAULT
835	01-May-21	GULBARGA	220	KUSHTAGI-SUZLON1	KUSHTAGI_220	18:03	20:39	02:36	LINE FAULT
836	01-May-21	GULBARGA	220	SEDAM-ORIENTCEMENTS_IPP	ORIENTCEMENTS_IPP	12:01	12:28	00:27	LINE FAULT
837	01-May-21	GULBARGA	400	BTPS-GUTTUR	GUTTUR_400	15:21(29.04.2021)	20:36(01.05.2021)	53:15 HRS	LINE CHARGED
838	01-May-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	15:15	15:29	00:14	LINE FAULT
839	01-May-21	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	16:14	16:19	00:05	MAIN SUPPLY FAILURE
840	01-May-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	17:07	17:12	00:05	LINE FAULT
841	01-May-21	HASSAN	66	HV1	HNPURA_66	17:07	17:12	00:05	MAIN SUPPLY FAILURE
842	01-May-21	HASSAN	66	HV1	MAGGE_66	15:55	16:27	00:32	MAIN SUPPLY FAILURE
843	01-May-21	HASSAN	66	HV1	SIGEBAGI_66	12:35	14:05	01:30	LINE CLEAR AVAILED
844	01-May-21	HASSAN	66	HV2	HNPURA_66	17:07	17:12	00:05	MAIN SUPPLY FAILURE
845	01-May-21	HASSAN	66	HV2	MAGGE_66	15:55	16:27	00:32	MAIN SUPPLY FAILURE
846	01-May-21	HASSAN	66	KANDLI-HASSAN	KANDLI_66	15:54	16:27	00:33	LINE FAULT
847	01-May-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:54	16:27	00:33	LINE FAULT
848	01-May-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	15:15	15:33	00:18	LINE FAULT
849	01-May-21	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	15:54	16:25	00:31	LINE FAULT
850	01-May-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
851	01-May-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	08:44	19:10	10:26	LINE CLEAR AVAILED
852	01-May-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:40 (29.04.2021)			LINE OPEN:LINE FAULT
853	01-May-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	16:46	17:42	00:56	LINE FAULT
854	01-May-21	HASSAN	110	HV1	PUTTUR_110	9:19 (30.04.2021)	12:35 (1.05.2021)	27:15 hrs	TRANSFORMER CHARGED
855	01-May-21	HASSAN	110	HV1	PUTTUR_110	11:41	17:56	06:15	MAIN SUPPLY FAILURE
856	01-May-21	HASSAN	110	HV1	PUTTUR_110	11:41	17:56	06:15	MAIN SUPPLY FAILURE
857	01-May-21	HASSAN	110	JOG-JLT4	mghejog_gen	11:45	13:48	02:03	LINE CLEAR AVAILED
858	01-May-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	16:46	17:42	00:56	LINE FAULT
859	01-May-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	17:33	18:16	00:43	LINE FAULT
860	01-May-21	HASSAN	110	LPH-MGHE 2	lph_gen	11:38	13:47	02:09	LINE CLEAR AVAILED
861	01-May-21	HASSAN	110	LV1	MRSMSG_220	09:20	14:04	04:44	LINE CLEAR AVAILED
862	01-May-21	HASSAN	110	MRSSHM-MYSORE	MRSMSG_220	10:16	17:03	06:47	LINE CLEAR AVAILED
863	01-May-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	17:30	17:54	00:24	MAIN SUPPLY FAILURE
864	01-May-21	HASSAN	220	HV1	MRSMSG_220	09:20	14:04	04:44	LINE CLEAR AVAILED
865	01-May-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	18:16 (1.05.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
866	01-May-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:58 (30.04.2021)	9:39 (1.05.2021)	14:40 hrs	LINE CHARGED
867	01-May-21	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	18:41	19:00	00:19	LINE FAULT
868	01-May-21	MYSURU	66	CR NAGARA-YELANDURU	YELANDUR_66	5:45	5:51	0:06	LINE FAULT
869	01-May-21	MYSURU	66	HV1	SANIVARASANTHE_66	16:28	16:45	0:16	TRANSFORMER FAULT
870	01-May-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
871	01-May-21	MYSURU	66	HV2	HEBBAL_66	15:42	16:33	0:51	LINE CLEAR AVAILED
872	01-May-21	MYSURU	66	HV5	SFCSHIVA_66	21:20 (01/05/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
873	01-May-21	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN:LINE CLEAR AVAILED
874	01-May-21	MYSURU	66	SFC SIVA-HV5	SFCSHIVA_66	23:07 (30/04/2021)	3:42 (01/05/2021)	4:35 HRS	LINE CHARGED
875	01-May-21	MYSURU	66	TUBINAKERE-NAGAMANGALA 2	SHIVALLY_66	18:21	18:28	0:06	LINE FAULT
876	01-May-21	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN:LINE CLEAR AVAILED
877	01-May-21	TUMKUR	66	BASAVAPATNA-VESTAE WIND	BASAVAPATNA_66	20:49	21:07	00:18	LINE FAULT
878	01-May-21	TUMKUR	66	BASAVAPATNA-VESTAE WIND	BASAVAPATNA_66	21:54	22:02	00:07	LINE FAULT
879	01-May-21	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	18:30	19:18	00:48	HAND TRIPPED
880	01-May-21	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	18:30	19:15	00:45	HAND TRIPPED
881	01-May-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	18:30	19:20	00:50	HAND TRIPPED
882	01-May-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:53	15:04	00:10	LINE FAULT
883	01-May-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	18:30	19:19	00:49	HAND TRIPPED
884	01-May-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	18:30	19:17	00:47	HAND TRIPPED
885	01-May-21	TUMKUR	66	HARIHARA-DAVANGERE	HARIHAR_66	18:30	19:25	00:55	MAIN SUPPLY FAILURE
886	01-May-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	10:46	10:54	00:07	LINE FAULT
887	01-May-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:43	12:40	00:56	LINE FAULT
888	01-May-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	10:38	10:52	00:14	LINE FAULT
889	01-May-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	18:30	19:20	00:50	MAIN SUPPLY FAILURE
890	01-May-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	00:41	00:47	00:05	LINE FAULT
891	01-May-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	02:37	02:42	00:04	LINE FAULT
892	01-May-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	05:13	05:21	00:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
893	01-May-21	TUMKUR	66	LINGADAHALLI-SHIMOGA(NALLUR)	LINGDHALLI_66	18:57	19:04	00:07	LINE FAULT
894	01-May-21	TUMKUR	66	THALLAK 220kV-GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	05:45	06:11	00:26	HAND TRIPPED
895	01-May-21	TUMKUR	66	THALLAK 220kV-GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	18:53	20:46	01:53	LINE CLEAR AVAILED
896	01-May-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	05:45	06:11	00:26	HAND TRIPPED
897	01-May-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:53	20:46	01:53	LINE CLEAR AVAILED
898	01-May-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	05:45	06:11	00:26	HAND TRIPPED
899	01-May-21	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUNSOLAR1_IPP_66	18:53	20:46	01:53	LINE CLEAR AVAILED
900	01-May-21	TUMKUR	66	TR-1	HARIHAR_66	18:30	19:25	00:55	MAIN SUPPLY FAILURE
901	01-May-21	TUMKUR	66	TR-1	NAGASAMUDRA_66	13:46	14:11	00:24	LINE CLEAR AVAILED
902	01-May-21	TUMKUR	66	TR-1(LV-1)	DAVANGERE_SRS_220	19:14	20:37	01:23	LINE CLEAR AVAILED
903	01-May-21	TUMKUR	66	TR-2	BELLAVI_66	10:39	11:02	00:23	LINE CLEAR AVAILED
904	01-May-21	TUMKUR	66	TR-2	HARIHAR_66	18:30	19:25	00:55	MAIN SUPPLY FAILURE
905	01-May-21	TUMKUR	66	TR-2	LINGADAHALLY_66	18:05	18:10	00:04	TRANSFORMER FAULT
906	01-May-21	TUMKUR	66	TR-2	MAYAKONDA_66	09:12	09:38	00:26	LINE CLEAR AVAILED
907	01-May-21	TUMKUR	66	TR-2	URDIGERE_66	12:07	12:18	00:11	HAND TRIPPED
908	01-May-21	TUMKUR	66	TR-3(LV-3)	THALLAKK_220	18:53	20:49	01:56	TRANSFORMER FAULT
909	01-May-21	TUMKUR	66	URDIGERE-KOLALA	KOLALA_66	12:07	12:48	00:40	HAND TRIPPED
910	01-May-21	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	22:12	22:18	00:06	TRANSFORMER FAULT
911	01-May-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-1	DAVANGERE_SRS_220	18:30	19:07	00:37	LINE FAULT
912	01-May-21	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	16:45	19:12	02:26	LINE FAULT
913	01-May-21	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	10:08	14:01	03:53	LINE CLEAR AVAILED
914	01-May-21	TUMKUR	220	TR-3	THALLAKK_220	05:45	06:11	00:26	TRANSFORMER FAULT
915	01-May-21	TUMKUR	220	TR-3	THALLAKK_220	18:53	20:45	01:52	TRANSFORMER FAULT
916	01-May-21	TUMKUR	400	GUTTUR 400KV- BEERANAHALLI2	GUTTUR 400KV	16:50	22:10	05:20	LINE FAULT
917	02-May-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
918	02-May-21	BAGALKOT	110	110/11KV, HV1	TAKKALKI_110	09:46	09:49	0:03	TRANSFORMER FAULT
919	02-May-21	BAGALKOT	110	110/11KV, HV1	TAKKALKI_110	12:46	12:51	0:05	TRANSFORMER FAULT
920	02-May-21	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	18:37	18:50	0:13	TRANSFORMER FAULT
921	02-May-21	BAGALKOT	110	110/11KV, HV1	MUDEBIHAL_110	06:37	11:40	5:03	TRANSFORMER FAULT
922	02-May-21	BAGALKOT	110	110/11KV, HV2	YELPARHATTI_110	10:25	10:44	0:19	LINE CLEAR AVAILED
923	02-May-21	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	18:37	18:50	0:13	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
924	02-May-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	15:38	16:15	0:37	TRANSFORMER FAULT
925	02-May-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	12:15	12:22	0:07	TRANSFORMER FAULT
926	02-May-21	BAGALKOT	110	110/33KV, HV3	TARIHAL_110	03:32	05:14	1:42	LINE CLEAR AVAILED
927	02-May-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	20:07	21:09	1:02	TRANSFORMER FAULT
928	02-May-21	BAGALKOT	110	220/110KV ,LV1	BELGAUM_220	11:16	14:06	2:50	LINE CLEAR AVAILED
929	02-May-21	BAGALKOT	110	AMBEWADI(SIRSI)-KIRUVATTI	STATION NOT AFFECTED KIRUVATTI_110	16:08 (29.04.2021)	18:34 (02.05.2021)	74:26 hrs	LINE CHARGED
930	02-May-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	21:58 (29.04.2021)	11:11 (02.05.2021)	61:13 hrs	LINE CHARGED
931	02-May-21	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVAILED
932	02-May-21	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	10:47	14:30	3:43	LINE CLEAR AVAILED
933	02-May-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
934	02-May-21	BAGALKOT	110	GADAG ROAD - GOPANAKOPPA(I/C BIDNAL)	GOPANAKOPPA_110	17:05 (01.05.2021)	11:52 (02.05.2021)	18:47	LINE FAULT
935	02-May-21	BAGALKOT	110	GADAG-ANNIGERI	ANNIGERI_110	18:47	19:11	0:24	HAND TRIPPED
936	02-May-21	BAGALKOT	110	ITNAL-KABBUR(HDKL2)	KABBUR_110	18:36 (02.05.2021)			LINE OPEN:LINE FAULT
937	02-May-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
938	02-May-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
939	02-May-21	BAGALKOT	110	SIRSI- KUMTA2	SIRSI_110	20:50 (01.05.2021)	16:26 (02.05.2021)	19:36	LINE FAULT
940	02-May-21	BAGALKOT	220	220/110KV, HV1&LV1	MUGALKOD_110, ITANAL_110, RAIBAG_110	18:37	20:26	1:49	TRANSFORMER FAULT
941	02-May-21	BAGALKOT	220	220/110KV, HV2&LV2	MUGALKOD_110, ITANAL_110, RAIBAG_110	18:37	20:25	1:48	TRANSFORMER FAULT
942	02-May-21	BAGALKOT	220	220/110KV,HV1	BELGAUM_220	11:16	12:04	0:48	LINE CLEAR AVAILED
943	02-May-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	20:54 (1.5.2021)	9:31 (02.05.2021)	12:37	LINE FAULT
944	02-May-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
945	02-May-21	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	14:15	20:31	6:16	NFBC ISSUED
946	02-May-21	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN:LINE CLEAR AVAILED
947	02-May-21	BAGALKOT	220	HAVERI- BIDNAL	HAVERI_220	14:15	20:31	6:16	LINE CLEAR AVAILED
948	02-May-21	BAGALKOT	220	HAVERI- GUTTUR2	HAVERI_220	18:29 (01.05.2021)	6:41 (02.05.2021)	12:12	LINE FAULT
949	02-May-21	BAGALKOT	220	HUBLI- NAGJHARI3	HUBLI_220	13:37	19:51	6:14	LINE CLEAR AVAILED
950	02-May-21	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	16:48 (01.05.2021)			LINE OPEN:LINE FAULT
951	02-May-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	16:49 (01.05.2021)	9:57 (02.05.2021)	17:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
952	02-May-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
953	02-May-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
954	02-May-21	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
955	02-May-21	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
956	02-May-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	19:30 (02.05.2021)			LINE OPEN:LINE FAULT
957	02-May-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
958	02-May-21	BAGALKOT	220	VAJRAMATTI - MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
959	02-May-21	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	15:19(01/05/2021)			LINE OPEN:LINE FAULT
960	02-May-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	19:30	19:40	00:09	LINE FAULT
961	02-May-21	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTC	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN:LINE FAULT
962	02-May-21	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	08:42	09:15	00:33	LINE FAULT
963	02-May-21	BENGALURU	66	HOSKOTE 220 - BOODIGERE	NO STATION AFFECTED	05:46	07:46	01:59	LINE FAULT
964	02-May-21	BENGALURU	66	HV1	MITTEMARI 220	06:43	06:49	00:06	TRANSFORMER FAULT
965	02-May-21	BENGALURU	66	HV1	ALLIMARADANAHALLI	11:30	11:59	00:29	LINE CLEAR AVAILED
966	02-May-21	BENGALURU	66	HV2	MAASTHI	10:30	10:45	00:14	TRANSFORMER FAULT
967	02-May-21	BENGALURU	66	HV2	SIDDALAGATTA	09:30	10:30	01:00	TRANSFORMER FAULT
968	02-May-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	06:44	06:53	00:09	LINE FAULT
969	02-May-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
970	02-May-21	GULBARGA	66	HV1	TAMBRAHALLI_66	14:35	18:30	03:55	TRANSFORMER FAULT
971	02-May-21	GULBARGA	110	HV1	CHITAGUPPA_110	11:10	11:15	00:05	TRANSFORMER FAULT
972	02-May-21	GULBARGA	110	HV2	BISIHALLI_110	08:50	09:00	00:10	TRANSFORMER FAULT
973	02-May-21	GULBARGA	110	HV2	SANKLAPUR_110	15:04	15:10	00:06	TRANSFORMER FAULT
974	02-May-21	GULBARGA	110	HV2	CHITAGUPPA_110	12:58	13:11	00:13	TRANSFORMER FAULT
975	02-May-21	GULBARGA	110	HV3	HALIKHED_110	16:45	16:58	00:13	TRANSFORMER FAULT
976	02-May-21	GULBARGA	110	JEWARGI-SHAHABAD	JEWARGI_110	16:05	19:15	03:10	LINE CLEAR AVAILED
977	02-May-21	GULBARGA	110	KUSHTAGI-HANUMASAGAR	HANUMASAGAR_110,HANUMANA L_110,HIREGONNAGAR_110	18:37(01.05.2021)	13:20(02.05.2021)	18:43HRS	LINE CHARGED
978	02-May-21	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDINNI_110	04:40	04:57	00:17	LINE FAULT
979	02-May-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	19:50	20:00	00:10	LINE FAULT
980	02-May-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	12:00(29.04.2021)	15:59(02.05.2021)	75:59 HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
981	02-May-21	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	18:50(02.05.2021)			LINE OPEN:LINE FAULT
982	02-May-21	GULBARGA	110	PDHALLI-JANAKI STEELS	PD_HALLI_110	08:45	17:20	08:35	LINE CLEAR AVAILED
983	02-May-21	GULBARGA	110	SHAHABAD-RAICHUR1&2	NALWAR_110,JEWARAGI_110,S HAHAPUR_110	11:30:00 AM(30.04.2021)	14:22(02.05.2021)	50:52HRS	LINE CHARGED
984	02-May-21	GULBARGA	110	SHAHAPUR-SEDAM	SHAHAPUR_220	10:20	19:10	08:50	LINE FAULT
985	02-May-21	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	01:54	02:02	00:08	LINE FAULT
986	02-May-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	09:40	18:30	08:50	LINE CLEAR AVAILED
987	02-May-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	05:52	06:02	00:10	LINE FAULT
988	02-May-21	GULBARGA	220	HV1	SHAHABAD_220	18:56	20:58	02:02	TRANSFORMER FAULT
989	02-May-21	GULBARGA	220	HV1	HALBARGA_220	08:32	08:58	00:26	TRANSFORMER FAULT
990	02-May-21	GULBARGA	220	HV1	HALBARGA_220	19:31	19:41	00:10	TRANSFORMER FAULT
991	02-May-21	GULBARGA	220	HV2	SHAHABAD_220	18:56	19:45	00:49	TRANSFORMER FAULT
992	02-May-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	10:31	14:06	03:35	LINE FAULT
993	02-May-21	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	17:30	17:42	00:12	MAIN SUPPLY FAILURE
994	02-May-21	HASSAN	66	ALDUR-CHIKKAMAGLUR	ALDUR_66	14:56	17:30	02:34	MAIN SUPPLY FAILURE
995	02-May-21	HASSAN	66	ARAKAL-HASSAN	ARKD_66	15:53	16:13	00:20	MAIN SUPPLY FAILURE
996	02-May-21	HASSAN	66	ARAKAL-HASSAN	ARKD_66	16:23	16:54	00:31	MAIN SUPPLY FAILURE
997	02-May-21	HASSAN	66	BALLUPE-KANDLI	BALLUPETE_66	15:53	19:00	03:07	LINE FAULT
998	02-May-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	17:15	18:03	00:48	LINE FAULT
999	02-May-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	15:53	16:13	00:20	LINE FAULT
1000	02-May-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	16:23	16:54	00:31	LINE FAULT
1001	02-May-21	HASSAN	66	HASSN22-BELUR	HASSAN_220	15:15	15:36	00:21	LINE FAULT
1002	02-May-21	HASSAN	66	HV1	HALLIMYSORE_66	15:21	15:38	00:17	TRANSFORMER FAULT
1003	02-May-21	HASSAN	66	HV1	MAGGE_66	16:05	19:07	03:02	MAIN SUPPLY FAILURE
1004	02-May-21	HASSAN	66	HV1	YESLUR_66	09:48	12:31	02:43	TRANSFORMER FAULT
1005	02-May-21	HASSAN	66	HV1	YESLUR_66	12:35	13:45	01:10	LINE CLEAR AVAILED
1006	02-May-21	HASSAN	66	HV1	YESLUR_66	13:50	15:11	01:21	LINE CLEAR AVAILED
1007	02-May-21	HASSAN	66	HV2	MAGGE_66	16:05	19:07	03:02	MAIN SUPPLY FAILURE
1008	02-May-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	15:50	18:10	02:20	LINE FAULT
1009	02-May-21	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	18:10	19:05	00:55	LINE CLEAR AVAILED
1010	02-May-21	HASSAN	66	SAKALE-HASSAN	SAKLESHPURA_66	16:42	19:07	02:25	LINE FAULT
1011	02-May-21	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
1012	02-May-21	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	10:31	20:52	10:21	LINE CLEAR AVAILED
1013	02-May-21	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:40 (29.04.2021)			LINE OPEN:LINE FAULT
1014	02-May-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	17:19	17:33	00:14	LINE FAULT
1015	02-May-21	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	15:14	15:48	00:34	LINE FAULT
1016	02-May-21	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	17:53 (2.05.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1017	02-May-21	HASSAN	110	HV2	ANANDAPURA_110	15:35	16:05	00:30	TRANSFORMER FAULT
1018	02-May-21	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	17:53	19:16	01:23	LINE FAULT
1019	02-May-21	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:16	11:26	01:10	LINE CLEAR AVAILED
1020	02-May-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	18:16 (1.05.2021)	12:20 (2.05.2021)	17:20 hrs	LINE CHARGED
1021	02-May-21	MYSURU	66	HV1	DMG_HALLI_66	7:00	7:26	0:26	TRANSFORMER FAULT
1022	02-May-21	MYSURU	66	HV1	KOLLEGALA_66	7:47	8:09	0:21	TRANSFORMER FAULT
1023	02-May-21	MYSURU	66	HV1	KOLLEGALA_66	8:52	9:06	0:13	TRANSFORMER FAULT
1024	02-May-21	MYSURU	66	HV1	KOLLEGALA_66	16:30	16:46	0:16	HAND TRIPPED
1025	02-May-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1026	02-May-21	MYSURU	66	HV2	HARVEY_66	11:00	11:52	0:52	LINE CLEAR AVAILED
1027	02-May-21	MYSURU	66	HV5	SFCSHIVA_66	22:58 (02/05/201)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1028	02-May-21	MYSURU	66	HV5	SFCSHIVA_66	21:20 (01/05/2021)	0:57 (02/05/2021)	3:37 HRS	TRANSFORMER CHARGED
1029	02-May-21	MYSURU	66	KUSHALANAGARA 220- MERCERA-1	MADIKERI_66	17:38	17:53	0:14	LINE FAULT
1030	02-May-21	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN:LINE CLEAR AVAILED
1031	02-May-21	MYSURU	66	SATHEGALA-HEBBANI	NO STATIONS EFFECTED	18:50	18:58	0:07	LINE FAULT
1032	02-May-21	MYSURU	66	SUNTIKOPPA-MADIKERI	MADIKERI_66	17:38	17:55	0:16	LINE FAULT
1033	02-May-21	MYSURU	66	TUBINAKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	6:03	6:11	0:08	LINE FAULT
1034	02-May-21	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN:LINE CLEAR AVAILED
1035	02-May-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	15:36	15:55	00:18	LINE FAULT
1036	02-May-21	TUMKUR	66	CHITRADURGA 66kv- DAVANAGERE2	CHITRADURGA_66	14:46	17:09	02:23	LINE FAULT
1037	02-May-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	12:33	12:38	00:05	MAIN SUPPLY FAILURE
1038	02-May-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	KUKKAWADA_66	14:43	14:53	00:09	LINE FAULT
1039	02-May-21	TUMKUR	66	PAVAGADA_220-PAVGD1	PAVAGADA_220	13:31	13:37	00:05	LINE FAULT
1040	02-May-21	TUMKUR	66	PAVAGADA220-SHYLAPURA	PAVAGADA_220	14:13	14:20	00:06	LINE FAULT
1041	02-May-21	TUMKUR	66	PAVAGADA-VENKATAPURA	VENKATAPURA_66	13:31	13:38	00:06	MAIN SUPPLY FAILURE
1042	02-May-21	TUMKUR	66	SHYLAPURA- MADHUGIRI	YNHOSKOTE_66, MANGALWADA_66,LINGDHALLI _66	14:13	14:22	00:09	MAIN SUPPLY FAILURE
1043	02-May-21	TUMKUR	66	TR-1	BUKKAPATNA_66	12:18	12:59	00:40	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1044	02-May-21	TUMKUR	66	TR-2	CHITRADURGA_66	01:50	02:09	00:19	TRANSFORMER FAULT
1045	03 May 2021	BAGALKOT	66	HONNALLI(BANUVALLI)- HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOIDED
1046	03 May 2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	18:49	18:55	0:06	TRANSFORMER FAULT
1047	03 May 2021	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	20:22	20:26	0:04	TRANSFORMER FAULT
1048	03 May 2021	BAGALKOT	110	110/11KV,HV2	THORVI_110	6:50	6:57	0:07	TRANSFORMER FAULT
1049	03 May 2021	BAGALKOT	110	110/11KV,HV2	BYADAGI_110	12:31	14:20	1:49	TRANSFORMER FAULT
1050	03 May 2021	BAGALKOT	110	110/11KV,HV2	KANABARGI LAY OUT_110	22:15	22:48	0:33	HAND TRIPPED
1051	03 May 2021	BAGALKOT	110	110/11KV,HV2A	JAMAKHANDI_110	8:55	9:18	0:23	LINE CLEAR AVOIDED
1052	03 May 2021	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	21:16	21:30	0:14	TRANSFORMER FAULT
1053	03 May 2021	BAGALKOT	110	ATHANI-SATTI	STATION NOT AFFECTED SATTI_110	13:19 (20.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
1054	03 May 2021	BAGALKOT	110	BAGALKOT-BAGALKOT 2	BAGALKOT_110	0:27	00:35	0:08	LINE FAULT
1055	03 May 2021	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	11:53	13:00	1:07	LINE CLEAR AVOIDED
1056	03 May 2021	BAGALKOT	110	BELGAUM220- VADAGOAN	VADAGOAN_110	13:09	15:30	2:21	LINE CLEAR AVOIDED
1057	03 May 2021	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
1058	03 May 2021	BAGALKOT	110	ITNAL-KABBUR(HDKL2)	KABBUR_110	18:36 (02.05.2021)	10:26 (3.5.2021)	15:50	LINE FAULT
1059	03 May 2021	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN:LINE FAULT
1060	03 May 2021	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN:LINE FAULT
1061	03 May 2021	BAGALKOT	110	RON- GAMESHA	RON_110	10:40	10:56	0:16	HAND TRIPPED
1062	03 May 2021	BAGALKOT	110	RON- HIREHAL	RON_110	10:56	11:15	0:19	HAND TRIPPED
1063	03 May 2021	BAGALKOT	110	RON- HIREHAL	RON_110	17:17	17:25	0:08	HAND TRIPPED
1064	03 May 2021	BAGALKOT	220	220/110KV,HV2&LV2	CHIKKODI_220	10:11	11:50	1:39	LINE CLEAR AVOIDED
1065	03 May 2021	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	10:39 (21.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
1066	03 May 2021	BAGALKOT	220	BIDNAL-HAVERI	BIDNAL_220	11:01	13:01	2:00	LINE CLEAR AVOIDED
1067	03 May 2021	BAGALKOT	220	CHIKKODI-BELGAUM2	STATION NOT AFFECTED CHIKKODI_220	12:05 (21.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
1068	03 May 2021	BAGALKOT	220	HAVERI- BIDNAL	HAVERI_220	11:00	13:01	2:01	LINE CLEAR AVOIDED
1069	03 May 2021	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	16:48 (01.05.2021)	16:38 (03.05.2021)	23:50	LINE FAULT
1070	03 May 2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVOIDED
1071	03 May 2021	BAGALKOT	220	NAGJHARI 1-AMBEWADI	AMBEWADI_220	19:08	19:57	0:49	LINE FAULT
1072	03 May 2021	BAGALKOT	220	NARENDRA- AMBEWADI1	NARENDRA_220	17:20	19:19	1:59	LOAD CURTAILMENT
1073	03 May 2021	BAGALKOT	220	NARENDRA- HUBLI2	NARENDRA_220	10:58	16:38	5:40	LINE CLEAR AVOIDED
1074	03 May 2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1075	03 May 2021	BAGALKOT	220	SIRSI- SHARAVATHY1	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1076	03 May 2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	17:00 (29.04.2021)	14:06 (03.05.2021)	93:06 hrs	LINE CHARGED
1077	03 May 2021	BAGALKOT	220	SIRSI- SHARAVATHY2	STATION NOT AFFECTED SIRSI_220	14:06 (03.05.2021)			LINE OPEN:LINE CLEAR AVAILED
1078	03 May 2021	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	19:30 (02.05.2021)	9:07 (03.05.2021)	13:37	LINE FAULT
1079	03 May 2021	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	09:07	17:22	8:15	LOAD CURTAILMENT
1080	03 May 2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
1081	03 May 2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1082	03 May 2021	BENGALURU	66	A STATION 220 - C STATION	NO STATION AFFECTED	15:19(01/05/2021)			LINE OPEN:LINE FAULT
1083	03 May 2021	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	19:14	19:22	00:07	LINE FAULT
1084	03 May 2021	BENGALURU	66	DODALAHALLI - GRT SOLAR	GRT SOLAR	13:33	13:45	00:12	LINE FAULT
1085	03 May 2021	BENGALURU	66	EAST DIVISION COMPOUND 220 - BMTc	NO STATION AFFECTED	14:09:00(30/04/2021)			LINE OPEN:LINE FAULT
1086	03 May 2021	BENGALURU	66	HV1	HUKUNDA	15:58	17:00	01:02	LINE CLEAR AVAILED
1087	03 May 2021	BENGALURU	66	HV1	VIJAYAPURA	16:06	16:18	00:12	LINE CLEAR AVAILED
1088	03 May 2021	BENGALURU	66	HV1	VOLVO	06:14	06:30	00:16	TRANSFORMER FAULT
1089	03 May 2021	BENGALURU	66	HV2	GUDIBANDE	03:50	05:30	01:40	TRANSFORMER FAULT
1090	03 May 2021	BENGALURU	66	HV2	HSR LAYOUT 220	17:51	19:42	01:50	TRANSFORMER FAULT
1091	03 May 2021	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJAHALLI, KUNUR	13:33	13:44	00:11	LINE FAULT
1092	03 May 2021	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN:LINE FAULT
1093	03 May 2021	GULBARGA	66	HV1	TAMBRAHALLI_66	10:25	10:30	00:05	TRANSFORMER FAULT
1094	03 May 2021	GULBARGA	110	HV2	KOLHAR_110	19:30	20:00	00:30	TRANSFORMER FAULT
1095	03 May 2021	GULBARGA	110	HV2	BISIHALLI_110	11:05	11:10	00:05	TRANSFORMER FAULT
1096	03 May 2021	GULBARGA	110	HV2	DEODURGA_110	19:35	19:51	00:16	TRANSFORMER FAULT
1097	03 May 2021	GULBARGA	110	MALLAT-BYAGWAT1	BYAGWAT_110,VALKAMDINNI_110	23:50	23:59	00:09	LINE FAULT
1098	03 May 2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	18:50(02.05.2021)	14:40(03.05.2021)	19:50 HRS	LINE CHARGED
1099	03 May 2021	GULBARGA	110	NALWAR-SHAHABAD	NALWAR_110	20:10	20:15	00:05	MAIN SUPPLY FAILURE
1100	03 May 2021	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	14:40	19:15	04:35	NFBC ISSUED
1101	03 May 2021	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	21:26	21:34	00:08	LINE CLEAR AVAILED
1102	03 May 2021	GULBARGA	110	SHAHAPUR-SHAHAPUR2	SHAHAPUR_110	21:16	23:12	01:56	LINE FAULT
1103	03 May 2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	15:23	17:36	02:13	LINE CLEAR AVAILED
1104	03 May 2021	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	10:10	17:45	07:35	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1105	03 May 2021	GULBARGA	110	SINDHNOOR-SIRIGUPPA	SIRIGUPPA_110,DHADESUGAR_110,TEKKALKOTE_110,NSLSUGAR_IPP	10:05	10:40	00:35	LINE CLEAR AVAILED
1106	03 May 2021	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	10:00	10:36	00:36	LINE CLEAR AVAILED
1107	03 May 2021	GULBARGA	220	HV1	HALBARGA_220	08:07	08:18	00:11	LINE CLEAR AVAILED
1108	03 May 2021	GULBARGA	220	HV1	HALBARGA_220	16:56	17:07	00:11	LINE CLEAR AVAILED
1109	03 May 2021	GULBARGA	220	RAICHUR-JURALA1	RAICHUR	14:36	17:34	02:58	LINE CLEAR AVAILED
1110	03 May 2021	GULBARGA	220	RAICHUR-JURALA2	RAICHUR	14:36	17:18	02:42	LINE CLEAR AVAILED
1111	03 May 2021	GULBARGA	220	SEDAM-SHAHAPUR_220	SHAHAPUR_220	18:26	18:58	00:32	LINE FAULT
1112	03 May 2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	13:42	13:50	00:08	LINE FAULT
1113	03 May 2021	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	14:45	14:46	00:01	HAND TRIPPED
1114	03 May 2021	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	16:05	16:16	00:11	LINE FAULT
1115	03 May 2021	HASSAN	66	GORUR-HASSAN	GORUR_66	16:45	21:03	04:18	LINE FAULT
1116	03 May 2021	HASSAN	66	HASSN220-ARAKALGUD1	HASSAN_220	16:45	21:02	04:17	LINE FAULT
1117	03 May 2021	HASSAN	66	HASSN220-ARAKALGUD2	HASSAN_220	16:45	21:02	04:17	LINE FAULT
1118	03 May 2021	HASSAN	66	HV1	GANGUR_110	14:00	15:13	01:13	LINE CLEAR AVAILED
1119	03 May 2021	HASSAN	66	HV1	MALLIPATNA_66	15:02	16:25	01:23	LINE CLEAR AVAILED
1120	03 May 2021	HASSAN	66	HV1	SAKLESHPURA_66	16:10	16:51	00:41	LINE CLEAR AVAILED
1121	03 May 2021	HASSAN	66	HV2	MATNAVILE_66	14:23	14:40	00:17	LINE CLEAR AVAILED
1122	03 May 2021	HASSAN	66	HV2	RAMNATHPURA_66	19:03	20:38	01:35	TRANSFORMER FAULT
1123	03 May 2021	HASSAN	66	HV2	RAMNATHPURA_66	20:49	22:48	01:59	TRANSFORMER FAULT
1124	03 May 2021	HASSAN	66	HV2	SAKLESHPURA_66	16:10	16:51	00:41	LINE CLEAR AVAILED
1125	03 May 2021	HASSAN	66	HV2	SHRAVANABELAGOLA_66	12:26	12:46	00:20	LINE CLEAR AVAILED
1126	03 May 2021	HASSAN	66	HV2	SHRAVANABELAGOLA_66	13:39	13:53	00:14	LINE CLEAR AVAILED
1127	03 May 2021	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
1128	03 May 2021	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	16:10	16:51	00:41	LINE CLEAR AVAILED
1129	03 May 2021	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGI_66	18:40 (29.04.2021)			LINE OPEN:LINE FAULT
1130	03 May 2021	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJNUR_110	17:53 (2.05.2021)	8:23 (3.05.2021)	14:29 hrs	LINE CHARGED
1131	03 May 2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	19:07	20:28	01:21	MAIN SUPPLY FAILURE
1132	03 May 2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	19:07	20:18	01:11	MAIN SUPPLY FAILURE
1133	03 May 2021	HASSAN	110	HV1	PUTTUR_110	15:35(29.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1134	03 May 2021	HASSAN	110	HV1	BARANGI_110	10:23	10:50	00:27	LINE CLEAR AVAILED
1135	03 May 2021	HASSAN	110	HV2	BAIKAMPADI_110	09:30	16:24	06:54	LINE CLEAR AVAILED
1136	03 May 2021	HASSAN	110	HV2	MRSMSG_220	09:20	15:57	06:37	LINE CLEAR AVAILED
1137	03 May 2021	HASSAN	110	HV2	SHIRALKOPPA_110	13:00	13:11	00:11	TRANSFORMER FAULT
1138	03 May 2021	HASSAN	110	HV2	SORABA_110	17:29	18:29	01:00	LINE CLEAR AVAILED
1139	03 May 2021	HASSAN	110	HV3	PUTTUR_110	09:52	12:03	02:11	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1140	03 May 2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	19:04	20:25	01:21	LINE FAULT
1141	03 May 2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	19:04	20:18	01:14	LINE FAULT
1142	03 May 2021	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	09:58	12:42	02:44	LINE CLEAR AVAILED
1143	03 May 2021	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	19:58	20:31	00:33	MAIN SUPPLY FAILURE
1144	03 May 2021	HASSAN	110	LV2	MRSMSG_220	09:18	15:57	06:39	LINE CLEAR AVAILED
1145	03 May 2021	HASSAN	110	MRSSHM-GAJNUR	MRSMSG_220	08:08	08:21	00:13	HAND TRIPPED
1146	03 May 2021	HASSAN	110	MRSSHM-SS1	MRSMSG_220	09:11	09:13	00:02	HAND TRIPPED
1147	03 May 2021	HASSAN	110	MRSSHM-SS1	MRSMSG_220	15:07	15:58	00:51	HAND TRIPPED
1148	03 May 2021	HASSAN	110	MRSSHM-SS2	MRSMSG_220	09:11	09:14	00:03	HAND TRIPPED
1149	03 May 2021	HASSAN	110	MRSSHM-SS2	MRSMSG_220	15:58	15:59	00:01	HAND TRIPPED
1150	03 May 2021	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	17:21	17:23	00:02	HAND TRIPPED
1151	03 May 2021	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	02:08	20:10	18:02	MAIN SUPPLY FAILURE
1152	03 May 2021	HASSAN	110	SHIVAPUR-BIRUR	SHIVPURA_110	13:18	13:21	00:03	HAND TRIPPED
1153	03 May 2021	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1154	03 May 2021	MYSURU	66	HV2	SFCSHIVA_66	10:07	14:39	4:31	LINE CLEAR AVAILED
1155	03 May 2021	MYSURU	66	HV3	KIKKERI_66	13:46	14:10	0:23	LINE CLEAR AVAILED
1156	03 May 2021	MYSURU	66	HV5	SFCSHIVA_66	18:28 (03/05/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1157	03 May 2021	MYSURU	66	HV5	SFCSHIVA_66	22:58 (02/05/2021)	4:52 (03/05/2021)	5:54 HRS	TRANSFORMER CHARGED
1158	03 May 2021	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66	6:09	6:23	0:14	LINE FAULT
1159	03 May 2021	MYSURU	66	KUSHALNAGARA-PERIYAPATNA 2	NO STATIONS INTERRUPTED	14:54	15:00	0:06	LINE FAULT
1160	03 May 2021	MYSURU	66	RK NAGARA-MANDAKALLI	NO STATIONS EFFECTED	15:09 (30/04/2021)			LINE OPEN:LINE CLEAR AVAILED
1161	03 May 2021	MYSURU	220	KADAKOLA-KOZHICODE	NO STATIONS EFFECTED	6:30 (20/04/2021)			LINE OPEN:LINE CLEAR AVAILED
1162	03 May 2021	MYSURU	220	KUSHALNAGARA-BASTIPURA 2	NO STATIONS EFFECTED	11:06	16:23	5:17	LINE CLEAR AVAILED
1163	03 May 2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66	11:22	11:34	0:11	LINE FAULT
1164	03 May 2021	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	11:59	12:07	0:08	LINE FAULT
1165	03 May 2021	TUMKUR	66	MADHUGIRI 220- KALLAMBELLA	KALLAMBELLA_66, SIRA_66	11:51	12:13	0:21	LINE FAULT
1166	03 May 2021	TUMKUR	66	MADHUGIRI 220kv- SIRA 1	KALLAMBELLA_66, BUKKAPATNA_66	08:40	09:11	0:31	LINE FAULT
1167	03 May 2021	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	03:28	03:42	0:13	LINE FAULT
1168	03 May 2021	TUMKUR	66	SIRA- KALLAMBELLA	SIRA_66	11:51	14:00	2:08	LINE FAULT
1169	03 May 2021	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	03:28	03:42	0:13	LINE FAULT
1170	03 May 2021	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	11:51	14:00	2:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1171	03 May 2021	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	16:18	16:21	0:03	TRANSFORMER FAULT
1172	03 May 2021	TUMKUR	66	TR-1	DAVANGERE_SRS_220	14:15	14:28	0:13	HAND TRIPPED
1173	03 May 2021	TUMKUR	66	TR-2	CHANNAGIRI_66	08:34	08:37	0:02	TRANSFORMER FAULT
1174	03 May 2021	TUMKUR	66	TR-2	NAYAKANAHATTI_66	13:03	13:16	0:12	TRANSFORMER FAULT
1175	03 May 2021	TUMKUR	66	TR-2	SHYLAPURA_66	20:58	21:39	0:40	TRANSFORMER FAULT
1176	03 May 2021	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	14:55	15:04	0:09	TRANSFORMER FAULT
1177	03 May 2021	TUMKUR	110	TR-1	HUNASEGHATTA_110	15:22	16:15	0:52	LINE CLEAR AVAILED