

400/220/110/66 kV TRANSMISSION OUTAGES FROM 14.12.21 TO 20.12.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1	14-Dec-2021	BAGALKOT	110	110/11KV HV 1	AIGALI_110	10:08	17:38	7:30	LINE CLEAR AVAILED
2	14-Dec-2021	BAGALKOT	110	110/11KV,HV1(HV2)	KADANKOPPA_110	19:20	21:47	2:27	LINE CLEAR AVAILED
3	14-Dec-2021	BAGALKOT	110	110/11KV,HV4	KERUR_110	15:48	17:15	1:27	LINE CLEAR AVAILED
4	14-Dec-2021	BAGALKOT	110	110/33KV,HV3	BILAGI_110 &ANAGAWADI_33	14:06	14:30	0:24	HAND TRIPPED
5	14-Dec-2021	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	11:25	19:55	8:30	LINE CLEAR AVAILED
6	14-Dec-2021	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	0:49(13.12.2021)	8:25 (14.12.2021)	31:36 hrs	TRANSFORMER CHARGED
7	14-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
8	14-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
9	14-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
10	14-Dec-2021	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAL_110	14:40	14:50	0:10	HAND TRIPPED
11	14-Dec-2021	BAGALKOT	110	HUNGUND-JINDAL	HUNGUND_110	5:57	6:05	0:08	LINE FAULT
12	14-Dec-2021	BAGALKOT	110	IDLE(BADAMI)-HIREHAL	HIREHAL_110	11:00 (13.12.2021)	14:45(14.12.2021)	27:45 hrs	LINE CHARGED
13	14-Dec-2021	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	13:00	14:30	1:30	LINE CLEAR AVAILED
14	14-Dec-2021	BAGALKOT	110	RON-GAJENDRAGAD1	RON_110	14:45	15:24	0:39	HAND TRIPPED
15	14-Dec-2021	BAGALKOT	110	RON-GAJENDRAGAD2	RON_110	14:45	15:24	0:39	HAND TRIPPED
16	14-Dec-2021	BAGALKOT	110	RON-GAMESH	RON_110	14:45	15:12	0:27	HAND TRIPPED
17	14-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
18	14-Dec-2021	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	19:10	19:15	0:05	LINE FAULT
19	14-Dec-2021	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	21:35	21:40	0:05	LINE FAULT
20	14-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25(08.12.2021)			LINE OPEN, LINE FAULT
21	14-Dec-2021	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)			LINE OPEN,LINE CLEAR AVAILED
22	14-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
23	14-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
24	14-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56(26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
25	14-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
26	14-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
27	14-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
28	14-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
29	14-Dec-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	9:04	18:37	9:34	LINE CLEAR AVAILED
30	14-Dec-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	9:02	18:36	9:34	LINE CLEAR AVAILED
31	14-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
32	14-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
33	14-Dec-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	7:05	7:06	0:01	LOAD CHANGE OVER
34	14-Dec-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	7:05	7:06	0:01	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
35	14-Dec-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	2:57	3:10	0:13	LOAD CHANGE OVER
36	14-Dec-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	2:57	3:10	0:13	LOAD CHANGE OVER
37	14-Dec-2021	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	12:56	17:06	4:10	LINE CLEAR AVAILED
38	14-Dec-2021	BENGALURU	66	AUSTIN TOWN - EAST DIVISION COMPOUND 220	AUSTIN TOWN	12:56	17:06	4:10	LINE CLEAR AVAILED
39	14-Dec-2021	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	5:28	6:09	0:41	MAIN SUPPLY FAILURE
40	14-Dec-2021	BENGALURU	66	AUSTIN TOWN - KORAMANGALA 220	AUSTIN TOWN	5:28	6:09	0:41	MAIN SUPPLY FAILURE
41	14-Dec-2021	BENGALURU	66	BMTC - NIMHANS 220	BMTC, NATIONAL COLLEGE	5:28	5:52	0:24	MAIN SUPPLY FAILURE
42	14-Dec-2021	BENGALURU	66	BMTC - NIMHANS 220	BMTC, NATIONAL COLLEGE	5:28	5:52	0:24	MAIN SUPPLY FAILURE
43	14-Dec-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	6:27	6:32	0:05	LINE FAULT
44	14-Dec-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	6:27	6:32	0:05	LINE FAULT
45	14-Dec-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:38	12:58	1:20	LINE CLEAR AVAILED
46	14-Dec-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:38	12:58	1:20	LINE CLEAR AVAILED
47	14-Dec-2021	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI	11:30	18:14	6:44	LINE CLEAR AVAILED
48	14-Dec-2021	BENGALURU	66	GANJIGUNTE - DIBBURAHALLI	DIBBURAHALLI	11:30	18:14	6:44	LINE CLEAR AVAILED
49	14-Dec-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	16:10	16:24	0:14	MAIN SUPPLY FAILURE
50	14-Dec-2021	BENGALURU	66	HENNUR CROSS - VIDYANAGARA	HENNUR CROSS	16:10	16:24	0:14	MAIN SUPPLY FAILURE
51	14-Dec-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT)	12:15	13:35	1:20	LINE CLEAR AVAILED
52	14-Dec-2021	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1(DG4)(VIDYANAGAR)	GRINDWELL (EHT)	12:15	13:35	1:20	LINE CLEAR AVAILED
53	14-Dec-2021	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	14:35	14:40	0:05	LOAD CHANGE OVER
54	14-Dec-2021	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	14:35	14:40	0:05	LOAD CHANGE OVER
55	14-Dec-2021	BENGALURU	66	HV1	AMAR JYOTHI	5:28	5:38	0:10	MAIN SUPPLY FAILURE
56	14-Dec-2021	BENGALURU	66	HV1	BANGARPET	16:18	16:53	0:34	LINE CLEAR AVAILED
57	14-Dec-2021	BENGALURU	66	HV1	CHINTAMANI 66	16:37	16:42	0:04	LINE CLEAR AVAILED
58	14-Dec-2021	BENGALURU	66	HV1	IRGAMPALLI	14:02	14:12	0:10	LINE CLEAR AVAILED
59	14-Dec-2021	BENGALURU	66	HV1	AMAR JYOTHI	5:28	5:38	0:10	MAIN SUPPLY FAILURE
60	14-Dec-2021	BENGALURU	66	HV1	BANGARPET	16:18	16:53	0:34	LINE CLEAR AVAILED
61	14-Dec-2021	BENGALURU	66	HV1	CHINTAMANI 66	16:37	16:42	0:04	LINE CLEAR AVAILED
62	14-Dec-2021	BENGALURU	66	HV1	IRGAMPALLI	14:02	14:12	0:10	LINE CLEAR AVAILED
63	14-Dec-2021	BENGALURU	66	HV2	AUSTIN TOWN	10:15	10:20	0:05	LINE CLEAR AVAILED
64	14-Dec-2021	BENGALURU	66	HV2	SUBRAMANYAPURA 66	10:49	10:50	0:01	LINE CLEAR AVAILED
65	14-Dec-2021	BENGALURU	66	HV2	IRGAMPALLI	11:45	11:50	0:04	LINE CLEAR AVAILED
66	14-Dec-2021	BENGALURU	66	HV2	MALLASANDRA	13:41	14:45	1:04	LINE CLEAR AVAILED
67	14-Dec-2021	BENGALURU	66	HV2	AUSTIN TOWN	10:15	10:20	0:05	LINE CLEAR AVAILED
68	14-Dec-2021	BENGALURU	66	HV2	SUBRAMANYAPURA 66	10:49	10:50	0:01	LINE CLEAR AVAILED
69	14-Dec-2021	BENGALURU	66	HV2	IRGAMPALLI	11:45	11:50	0:04	LINE CLEAR AVAILED
70	14-Dec-2021	BENGALURU	66	HV2	MALLASANDRA	13:41	14:45	1:04	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
71	14-Dec-2021	BENGALURU	66	KGF - LINE 2	BEML (EHT)	14:35	15:00	0:25	LOAD CHANGE OVER
72	14-Dec-2021	BENGALURU	66	KGF - LINE 2	BEML (EHT)	15:15	15:25	0:10	LOAD CHANGE OVER
73	14-Dec-2021	BENGALURU	66	KGF - LINE 2	BEML (EHT)	14:35	15:00	0:25	LOAD CHANGE OVER
74	14-Dec-2021	BENGALURU	66	KGF - LINE 2	BEML (EHT)	15:15	15:25	0:10	LOAD CHANGE OVER
75	14-Dec-2021	BENGALURU	66	KGF - MALUR 220	KGF, KAMASAMUDRA	14:35	15:00	0:25	LOAD CHANGE OVER
76	14-Dec-2021	BENGALURU	66	KGF - MALUR 220	KGF, KAMASAMUDRA	14:35	15:00	0:25	LOAD CHANGE OVER
77	14-Dec-2021	BENGALURU	66	KGF - T GOLAHALLI 220	KGF, KAMASAMUDRA	15:15	15:25	0:10	LOAD CHANGE OVER
78	14-Dec-2021	BENGALURU	66	KGF - T GOLAHALLI 220	KGF, KAMASAMUDRA	15:15	15:25	0:10	LOAD CHANGE OVER
79	14-Dec-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	16:45	17:02	0:17	LINE FAULT
80	14-Dec-2021	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSNUR, YELDUR	16:45	17:02	0:17	LINE FAULT
81	14-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN, LINE FAULT
82	14-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN, LINE FAULT
83	14-Dec-2021	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	5:28	6:30	1:02	MAIN SUPPLY FAILURE
84	14-Dec-2021	BENGALURU	66	KORMANGALA 220 - K & C VALLEY	K & C VALLEY, NAL (EHT)	5:28	6:30	1:02	MAIN SUPPLY FAILURE
85	14-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	6:03	6:14	0:11	LINE FAULT
86	14-Dec-2021	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	6:03	6:14	0:11	LINE FAULT
87	14-Dec-2021	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	5:28	6:30	1:02	MAIN SUPPLY FAILURE
88	14-Dec-2021	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	5:28	6:30	1:02	MAIN SUPPLY FAILURE
89	14-Dec-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	5:28	6:28	1:00	MAIN SUPPLY FAILURE
90	14-Dec-2021	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR	5:28	6:28	1:00	MAIN SUPPLY FAILURE
91	14-Dec-2021	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	5:28	6:20	0:52	LINE FAULT
92	14-Dec-2021	BENGALURU	66	PADMANABHANAGARA - NATIONAL COLLEGE	PADMANABHANAGARA	5:28	6:20	0:52	LINE FAULT
93	14-Dec-2021	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	6:50	6:54	0:04	LOAD CHANGE OVER
94	14-Dec-2021	BENGALURU	66	PADMANABHANAGARA - SUBRAMANYAPURA 220	PADMANABHANAGARA	6:50	6:54	0:04	LOAD CHANGE OVER
95	14-Dec-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:07	18:35	0:27	MAIN SUPPLY FAILURE
96	14-Dec-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	18:07	18:35	0:27	MAIN SUPPLY FAILURE
97	14-Dec-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:07	18:36	0:29	MAIN SUPPLY FAILURE
98	14-Dec-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	18:07	18:36	0:29	MAIN SUPPLY FAILURE
99	14-Dec-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:07	18:35	0:28	MAIN SUPPLY FAILURE
100	14-Dec-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	18:07	18:35	0:28	MAIN SUPPLY FAILURE
101	14-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	10:33	10:49	0:16	LOAD CHANGE OVER
102	14-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66, ISKON	10:33	10:49	0:16	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
103	14-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	17:15	17:25	0:10	LOAD CHANGE OVER
104	14-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66, ISKON	17:15	17:25	0:10	LOAD CHANGE OVER
105	14-Dec-2021	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	16:08	16:23	0:14	LINE CLEAR AVAILED
106	14-Dec-2021	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	16:08	16:23	0:14	LINE CLEAR AVAILED
107	14-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:06(14/12/2021)			LINE OPEN, LINE FAULT
108	14-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:06(14/12/2021)			LINE OPEN, LINE FAULT
109	14-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	4:22	6:44	2:22	MAIN SUPPLY FAILURE
110	14-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	4:22	6:44	2:22	MAIN SUPPLY FAILURE
111	14-Dec-2021	BENGALURU	220	KOLAR 220 - MALUR 3	SARIJAPURA 220, VIKAS TECH PARK 220	18:06	18:31	0:24	LINE FAULT
112	14-Dec-2021	BENGALURU	220	KOLAR 220 - MALUR 3	SARIJAPURA 220, VIKAS TECH PARK 220	18:06	18:31	0:24	LINE FAULT
113	14-Dec-2021	BENGALURU	220	KORAMANGALA 220 - NIMHANS 220	KORAMANGALA 220	5:28	6:20	0:52	MAIN SUPPLY FAILURE
114	14-Dec-2021	BENGALURU	220	KORAMANGALA 220 - NIMHANS 220	KORAMANGALA 220	5:28	6:20	0:52	MAIN SUPPLY FAILURE
115	14-Dec-2021	BENGALURU	220	NIMHANS 220 - EAST DIVISION COMPOUND 220	NIMHANS 220	5:28	6:20	0:52	LINE FAULT
116	14-Dec-2021	BENGALURU	220	NIMHANS 220 - EAST DIVISION COMPOUND 220	NIMHANS 220	5:28	6:20	0:52	LINE FAULT
117	14-Dec-2021	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	18:06	18:55	0:49	MAIN SUPPLY FAILURE
118	14-Dec-2021	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	18:06	18:55	0:49	MAIN SUPPLY FAILURE
119	14-Dec-2021	GULBARGA	66	HV1	BENNEHALLI_66	14:49	14:58	0:09	LINE CLEAR AVAILED
120	14-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
121	14-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	6:08	6:16	0:08	MAIN SUPPLY FAILURE
122	14-Dec-2021	GULBARGA	110	BISIHALLI-BELLARYNORTH	BISIHALLI_110	5:39	5:50	0:11	MAIN SUPPLY FAILURE
123	14-Dec-2021	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	18:40	19:20	0:40	LINE FAULT
124	14-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	3:35	3:40	0:05	MAIN SUPPLY FAILURE
125	14-Dec-2021	GULBARGA	110	HV1	SOMASUMUDRA_110	5:09	7:56	13:05	LINE CLEAR AVAILED
126	14-Dec-2021	GULBARGA	110	HV1	KAVITAL_110	17:27	17:37	0:10	TRANSFORMER FAULT
127	14-Dec-2021	GULBARGA	110	HV1	KAVITAL_110	21:05	21:10	0:05	TRANSFORMER FAULT
128	14-Dec-2021	GULBARGA	110	HV2	SOMASUMUDRA_110	0:18	14:42	15:00	LINE CLEAR AVAILED
129	14-Dec-2021	GULBARGA	110	HV2	YELBURGA_110	12:30	12:39	0:09	TRANSFORMER FAULT
130	14-Dec-2021	GULBARGA	110	HV3	SOMASUMUDRA_110	0:30	12:15	12:45	LINE CLEAR AVAILED
131	14-Dec-2021	GULBARGA	110	HV3	VALKAMDINI_110	23:30	23:35	0:05	TRANSFORMER FAULT
132	14-Dec-2021	GULBARGA	110	KAMALNAGAR-DONGARGAON	KAMALNAGAR_110	13:45	14:25	0:40	MAIN SUPPLY FAILURE
133	14-Dec-2021	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIRE GONNAGAR_110,HANUMAL_110	6:39	6:59	0:20	LINE FAULT
134	14-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN,LINE CLEAR AVAILED
135	14-Dec-2021	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINI_110	5:51	6:11	0:20	LINE FAULT
136	14-Dec-2021	GULBARGA	110	MALLAT-KAVITAL	KAVITAL_110	21:03	21:13	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
137	14-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110,ADAVIAMARESHWAR_110	2:00	2:05	0:05	LINE FAULT
138	14-Dec-2021	GULBARGA	110	MUNIRABAD-HAGARI	SANKALAPUR_110,RBSNN_IPP,KAMALAPUR_110	19:15 (14.12.2021)			LINE OPEN, LINE FAULT
139	14-Dec-2021	GULBARGA	110	PDHALLI-ALIPUR	PDHALLI_110	5:38	6:05	0:27	MAIN SUPPLY FAILURE
140	14-Dec-2021	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	15:20	16:00	0:40	LINE CLEAR AVAILED
141	14-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	18:41	19:23	0:42	LINE CLEAR AVAILED
142	14-Dec-2021	GULBARGA	110	RAICHUR-SINDHANOOR2	KURDI CROSS_110,MANVI_110,MADLAPUR_110	15:28 (13.12.2021)	13:10 (14.12.2021)	21:42 HRS	LINE CHARGED
143	14-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
144	14-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAISAPUR_110,WADAGERA_110,SAN NATHI_IPP,COREGREENSUGARS_IPP	2:57	3:09	0:12	LINE FAULT
145	14-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	18:36			LINE OPEN,LINE CLEAR AVAILED
146	14-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	10:55	11:20	0:25	LINE FAULT
147	14-Dec-2021	GULBARGA	110	STAR METALLIC-MUNIRABAD	MUNIRABAD_220	19:14	19:38	0:24	LINE FAULT
148	14-Dec-2021	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	6:37	6:53	0:16	LINE FAULT
149	14-Dec-2021	GULBARGA	220	HUMNABAD-KAPNOOR1	HUMNABAD_220	21:48 (13.12.2021)	7:17 (14.12.2021)	9:29 HRS	LINE CHARGED
150	14-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
151	14-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
152	14-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:05 (13.12.2021)	6:47 (14.12.2021)	8:42 HRS	LINE CHARGED
153	14-Dec-2021	HASSAN	66	BAGUR-RAMAPUR	BAGUR_66	11:35	13:30	1:55	LINE CLEAR AVAILED
154	14-Dec-2021	HASSAN	66	HASSN220-HN PURA	HASSAN_220	15:35	16:11	0:36	HAND TRIPPED
155	14-Dec-2021	HASSAN	66	HASSN220-HSN66	HASSAN_220	10:05	10:08	0:03	HAND TRIPPED
156	14-Dec-2021	HASSAN	66	HASSN220-MALLALI	HASSAN_220	15:22	16:11	0:49	LINE FAULT
157	14-Dec-2021	HASSAN	66	RAMPUR-BEGUR	RAMPURA_66	11:46	13:29	1:43	NFBC ISSUED
158	14-Dec-2021	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:04	13:38	3:34	LINE CLEAR AVAILED
159	14-Dec-2021	HASSAN	110	HV2	KUNDAPURA_110	9:32	16:25	6:53	LINE CLEAR AVAILED
160	14-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	15:40(14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
161	14-Dec-2021	HASSAN	110	LV1	PUTTUR_220	17:09(13.12.2021)	16:18(14.12.2021)	23:09hrs	TRANSFORMER CHARGED
162	14-Dec-2021	HASSAN	110	LV1	MSEZ_220	9:52	17:01	7:09	LINE CLEAR AVAILED
163	14-Dec-2021	HASSAN	110	LV2	MSEZ_220	17:12	19:51	2:39	LINE CLEAR AVAILED
164	14-Dec-2021	HASSAN	110	LV2	PUTTUR_220	16:18	19:27	3:09	LINE CLEAR AVAILED
165	14-Dec-2021	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_1101	10:00	13:39	3:39	NFBC ISSUED
166	14-Dec-2021	HASSAN	110	MADHUV-KUNDAPURA	MADHUVANA_1101	13:39	14:26	0:47	LINE CLEAR AVAILED
167	14-Dec-2021	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	12:10	13:40	1:30	NFBC ISSUED
168	14-Dec-2021	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	6:45	12:08	5:23	LINE CLEAR AVAILED
169	14-Dec-2021	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	18:28 (11.12.2021)	14:14(14.12.2021)	19:46hrs	LINE CHARGED
170	14-Dec-2021	HASSAN	220	HASSN220-CHIKMAGALUR	HASSAN_220	10:33	15:09	4:36	NFBC ISSUED
171	14-Dec-2021	HASSAN	220	HV1	PUTTUR_220	17:09(13.12.2021)	16:17(14.12.2021)	23:08hrs	TRANSFORMER CHARGED
172	14-Dec-2021	HASSAN	220	HV1	MSEZ_220	9:52	17:09	7:17	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
173	14-Dec-2021	HASSAN	220	HV2	MSEZ_220	17:12	19:51	2:39	LINE CLEAR AVAILED
174	14-Dec-2021	HASSAN	220	HV2	PUTTUR_220	16:18	19:27	3:09	LINE CLEAR AVAILED
175	14-Dec-2021	HASSAN	220	MRSSHM-CHMLR	MRSMSG_220	15:21	18:18	2:57	LINE CLEAR AVAILED
176	14-Dec-2021	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	18:28 (11.12.20221)	13:58(14.12.2021)	19:30hrs	LINE CHARGED
177	14-Dec-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:37(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
178	14-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN,LINE CLEAR AVAILED
179	14-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
180	14-Dec-2021	MYSURU	66	HEBBANI-SFC01	NO STATIONS EFFECTED	13:18	13:42	0:24	LINE CLEAR AVAILED
181	14-Dec-2021	MYSURU	66	HEBBANI-SFC02	NO STATIONS EFFECTED	12:59	13:17	0:18	LINE CLEAR AVAILED
182	14-Dec-2021	MYSURU	66	HEBBANI-SFC06	NO STATIONS EFFECTED	12:17	12:51	0:34	LINE CLEAR AVAILED
183	14-Dec-2021	MYSURU	66	HEBBANI-SFC07	NO STATIONS EFFECTED	11:32	12:16	0:44	LINE CLEAR AVAILED
184	14-Dec-2021	MYSURU	66	HEBBANI-SFC08	NO STATIONS EFFECTED	9:13	9:39	0:26	LINE CLEAR AVAILED
185	14-Dec-2021	MYSURU	66	HEBBANI-VADKEPURA	NO STATIONS EFFECTED	11:18	14:49	3:31	LINE CLEAR AVAILED
186	14-Dec-2021	MYSURU	66	HV1	HARVEY_66	14:49	16:08	1:19	LINE CLEAR AVAILED
187	14-Dec-2021	MYSURU	66	HV2	HARVEY_66	12:45	14:49	2:04	LINE CLEAR AVAILED
188	14-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN,LINE CLEAR AVAILED
189	14-Dec-2021	MYSURU	66	MADHUVANALLI-HANNUR1	NO STATIONS EFFECTED	13:10	14:56	1:46	LINE CLEAR AVAILED
190	14-Dec-2021	MYSURU	66	MADHUVANALLI-HANNUR2	NO STATIONS EFFECTED	13:10	14:56	1:46	LINE CLEAR AVAILED
191	14-Dec-2021	MYSURU	66	MADHUVANALLI-MAMBALLI	MAMBALLI_66	17:01	17:06	0:05	LINE FAULT
192	14-Dec-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	0:56:43 (14.12.2021)			LINE OPEN, LINE FAULT
193	14-Dec-2021	TUMKUR	66	DEVARAHALLI-CHANNAGIRI(NALLUR)	DEVARAHALLI_66	15:47	17:22	1:34	MAIN SUPPLY FAILURE
194	14-Dec-2021	TUMKUR	66	HONNALLI 220kV-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	15:17	16:24	1:06	LINE FAULT
195	14-Dec-2021	TUMKUR	66	HONNALLI 220kV-CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	16:28	16:34	0:05	HAND TRIPPED
196	14-Dec-2021	TUMKUR	66	MADANAYAKANAHALLI66-TURUVANUR66	MADANAYAKANAHALLI_66	7:24	7:32	0:07	HAND TRIPPED
197	14-Dec-2021	TUMKUR	66	MADHUGIRI 220kV-NITRAHALLI66	NITRAHALLI_66	17:17	17:52	0:35	LINE FAULT
198	14-Dec-2021	TUMKUR	66	PAVAGADA220-MEDEGESHI66	MEDIGESHI_66,I D HALLI_66,HOSKERE_66	1:03	2:08	1:05	LINE FAULT
199	14-Dec-2021	TUMKUR	66	PAVAGADA220-SHYLAPURA_66	SHYLAPURA_66	9:57	9:58	0:01	LINE FAULT
200	14-Dec-2021	TUMKUR	66	TR-1	MAYAKONDA_66	8:23	8:27	0:04	TRANSFORMER FAULT
201	14-Dec-2021	TUMKUR	66	TR-1	YEDIYUR_66	10:28	15:45	5:17	LINE CLEAR AVAILED
202	14-Dec-2021	TUMKUR	66	TR-1(LV SIDE)	THALLAK_220	6:30	6:43	0:13	TRANSFORMER FAULT
203	14-Dec-2021	TUMKUR	66	TR-2	HOLALKERE_66	10:27	10:41	0:13	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
204	14-Dec-2021	TUMKUR	66	TR-2	JAVAGONDANAHALLY_66	11:05	13:45	2:40	LINE CLEAR AVAILED
205	14-Dec-2021	TUMKUR	220	TR-1	THALLAK_220	6:30	6:42	0:12	TRANSFORMER FAULT
206	15-Dec-2021	BAGALKOT	66	66/11KV,HV2	HARIHAR-HOSPET_66	10:25	12:04	1:39	LINE CLEAR AVAILED
207	15-Dec-2021	BAGALKOT	110	110/11KV,HV1	DEVANGOAN_110	6:16	6:23	0:07	TRANSFORMER FAULT
208	15-Dec-2021	BAGALKOT	110	110/11KV,HV2	TILUVALI_110	10:20	18:31	8:11	LINE CLEAR AVAILED
209	15-Dec-2021	BAGALKOT	110	110/11KV,HV4	KERUR_110	10:30	11:39	1:09	LINE CLEAR AVAILED
210	15-Dec-2021	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	13:24	16:50	3:26	LINE CLEAR AVAILED
211	15-Dec-2021	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	0:52	7:25	6:33	LINE CLEAR AVAILED
212	15-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
213	15-Dec-2021	BAGALKOT	110	BAGEWADI-MUDEDEBIHAL	MUDEDEBIHAL_110	16:18	16:27	0:09	HAND TRIPPED
214	15-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
215	15-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
216	15-Dec-2021	BAGALKOT	110	MUDEDEBIHAL-KNM SOLAR	MUDEDEBIHAL_110	16:18	16:27	0:09	HAND TRIPPED
217	15-Dec-2021	BAGALKOT	110	MURDESHWAR -KR TRACTION(HONNAVAR)	MURDESHWAR_110	17:18	18:48	1:30	LINE FAULT
218	15-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
219	15-Dec-2021	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	13:11	13:31	0:20	LINE CLEAR AVAILED
220	15-Dec-2021	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	14:52	16:16	1:24	LINE CLEAR AVAILED
221	15-Dec-2021	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	23:33	23:38	0:05	LINE FAULT
222	15-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25(08.12.2021)			LINE OPEN, LINE FAULT
223	15-Dec-2021	BAGALKOT	220	220/110KV, HV1&LV1	KARWAR_220	13:38	14:18	0:40	LINE CLEAR AVAILED
224	15-Dec-2021	BAGALKOT	220	AMBEWADI- NARENDRA2	AMBEWADI_220	10:45 (06.12.2021)	11:40 (15.12.2021)	240:55 hrs	LINE CHARGED
225	15-Dec-2021	BAGALKOT	220	BAGALKOT - VAJARAMATTI1	BAGALKOT_220	13:51	17:42	3:51	LINE FAULT
226	15-Dec-2021	BAGALKOT	220	BAGALKOT - VAJARAMATTI2	BAGALKOT_220	13:48	17:43	3:55	LINE FAULT
227	15-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
228	15-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
229	15-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56(26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
230	15-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
231	15-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
232	15-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
233	15-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
234	15-Dec-2021	BAGALKOT	220	VAJRAMATTI- BAGALKOT1	VAJRAMATTI_220	13:51	17:36	3:45	LINE FAULT
235	15-Dec-2021	BAGALKOT	220	VAJRAMATTI- BAGALKOT2	VAJRAMATTI_220	13:48	17:39	3:51	LINE FAULT
236	15-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
237	15-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
238	15-Dec-2021	BENGALURU	66	AREHALLI - BANASHANKARI	AREHALLI	17:45	17:47	0:02	LOAD CHANGE OVER
239	15-Dec-2021	BENGALURU	66	AREHALLI - SUBRAMANYAPURA 220	AREHALLI	15:47	15:48	0:01	LOAD CHANGE OVER
240	15-Dec-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	5:55	6:41	0:46	LINE FAULT
241	15-Dec-2021	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	5:55	6:27	0:32	LINE FAULT
242	15-Dec-2021	BENGALURU	66	GANIJUGUNTE - DIBBURAHALLI	DIBBURAHALLI	11:30	18:14	6:44	LINE CLEAR AVAILED
243	15-Dec-2021	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	8:18	10:51	2:33	LINE FAULT
244	15-Dec-2021	BENGALURU	66	HV1	NRS 220	10:19	17:26	7:07	LINE CLEAR AVAILED
245	15-Dec-2021	BENGALURU	66	HV1	MALUR 220	9:30	17:50	8:19	LINE CLEAR AVAILED
246	15-Dec-2021	BENGALURU	66	HV1	KYALANUR	14:07	14:22	0:14	LINE CLEAR AVAILED
247	15-Dec-2021	BENGALURU	66	HV1	KAMASAMUDRA	11:18	11:59	0:41	LINE CLEAR AVAILED
248	15-Dec-2021	BENGALURU	66	HV2	NRS 220	10:19	17:17	6:58	LINE CLEAR AVAILED
249	15-Dec-2021	BENGALURU	66	HV2	MALUR 220	9:31	17:25	7:54	LINE CLEAR AVAILED
250	15-Dec-2021	BENGALURU	66	HV2	THIMMAMPALLI	13:08	15:15	2:06	LINE CLEAR AVAILED
251	15-Dec-2021	BENGALURU	66	HV2	KYALANUR	13:16	13:20	0:03	LINE CLEAR AVAILED
252	15-Dec-2021	BENGALURU	66	HV2	GUDIBANDE	16:12	16:20	0:07	LINE CLEAR AVAILED
253	15-Dec-2021	BENGALURU	66	HV3	NRS 220	10:19	17:18	6:59	LINE CLEAR AVAILED
254	15-Dec-2021	BENGALURU	66	HV4	NRS 220	10:19	17:15	6:56	LINE CLEAR AVAILED
255	15-Dec-2021	BENGALURU	66	HV5	NRS 220	10:19	17:17	6:58	LINE CLEAR AVAILED
256	15-Dec-2021	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	16:20	16:24	0:04	LOAD CHANGE OVER
257	15-Dec-2021	BENGALURU	66	KGF - LINE 2	BEML (EHT)	17:55	18:15	0:20	LOAD CHANGE OVER
258	15-Dec-2021	BENGALURU	66	KGF - T GOLAHALLI 220	KGF, KAMASAMUDRA	17:55	18:15	0:20	LOAD CHANGE OVER
259	15-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN, LINE FAULT
260	15-Dec-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	NO STATION AFFECTED	9:30	17:43	8:13	LINE CLEAR AVAILED
261	15-Dec-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:30	17:55	8:25	LINE CLEAR AVAILED
262	15-Dec-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	9:30	10:10	0:39	LINE CLEAR AVAILED
263	15-Dec-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	9:30	10:10	0:39	LINE CLEAR AVAILED
264	15-Dec-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	9:30	17:33	8:03	LINE CLEAR AVAILED
265	15-Dec-2021	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	9:44	17:31	7:47	LINE CLEAR AVAILED
266	15-Dec-2021	BENGALURU	66	MALUR 220 - MALUR I/A	MALUR I/A, ADL (EHT), BEST STEEL(EHT)	9:30	17:31	8:00	LINE CLEAR AVAILED
267	15-Dec-2021	BENGALURU	66	MELLAHALLI - JALAMANGALA	JALAMANGALA	15:37	18:49	3:12	LINE CLEAR AVAILED
268	15-Dec-2021	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	10:10	17:19	7:09	LINE CLEAR AVAILED
269	15-Dec-2021	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	10:08	17:40	7:32	LINE CLEAR AVAILED
270	15-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	5:55	6:22	0:27	LINE FAULT
271	15-Dec-2021	BENGALURU	66	ST.JOHNS WOOD - ADUGODI	ST.JOHNS WOOD	8:28	8:35	0:07	LOAD CHANGE OVER
272	15-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:06(14/12/2021)			LINE OPEN, LINE FAULT
273	15-Dec-2021	BENGALURU	220	GOWRIBIDANUR 220 - MITTEMARI 2	NO STATION AFFECTED	4:22	6:44	2:22	LINE CLEAR AVAILED
274	15-Dec-2021	GULBARGA	66	HV1	HANASI_66	17:45	17:55	0:10	TRANSFORMER FAULT
275	15-Dec-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	6:00	6:10	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
276	15-Dec-2021	GULBARGA	110	HV1	KAMALANAGAR_110	13:02	13:13	0:11	TRANSFORMER FAULT
277	15-Dec-2021	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIRE GONNAGAR_110,HANUMANA L_110	11:55	12:05	0:10	LINE FAULT
278	15-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN,LINE CLEAR AVAILED
279	15-Dec-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	22:47	22:57	0:10	LINE FAULT
280	15-Dec-2021	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDI NNI_110	22:50	22:59	0:09	LINE FAULT
281	15-Dec-2021	GULBARGA	110	MUNIRABAD-HAGARI	SANKALAPUR_110,RBSNN_ IPP,KAMALAPUR_110	19:15 (14.12.2021)	8:10 (15.12.2021)	12:55 HRS	LINE CHARGED
282	15-Dec-2021	GULBARGA	110	MUNIRABAD-HAGARI	SANKALAPUR_110,RBSNN_ IPP,KAMALAPUR_110	15:06	17:10	2:04	LINE CLEAR AVAILED
283	15-Dec-2021	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	15:35	15:47	0:12	LINE CLEAR AVAILED
284	15-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	2:15	2:25	0:10	LINE FAULT
285	15-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	18:00	19:06	1:06	LINE CLEAR AVAILED
286	15-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	6:45	7:05	0:20	LINE CLEAR AVAILED
287	15-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	17:45	18:50	1:05	LINE CLEAR AVAILED
288	15-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
289	15-Dec-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	20:49	20:58	0:09	LINE FAULT
290	15-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	18:36 (14.12.2021)	11:27 (15.12.2021)	16:51 HRS	LINE CHARGED
291	15-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	12:45	12:55	0:10	LINE FAULT
292	15-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
293	15-Dec-2021	GULBARGA	220	HV1	HUMNABAD_220	8:36	10:40	2:04	TRANSFORMER FAULT
294	15-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
295	15-Dec-2021	GULBARGA	220	LINGAPUR-BMMISPAT	LINGAPUR_220	9:12	17:54	8:42	LINE CLEAR AVAILED
296	15-Dec-2021	GULBARGA	220	MALLAT-RTPS3	MALLAT_220	2:13	2:37	0:24	LINE FAULT
297	15-Dec-2021	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	2:14	2:37	0:23	LINE FAULT
298	15-Dec-2021	GULBARGA	220	RTPS-RAICHUR2	RAICHUR_220	9:35	17:32	7:57	LINE CLEAR AVAILED
299	15-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:12 (15.12.2021)			LINE OPEN,LINE CLEAR AVAILED
300	15-Dec-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	13:43	13:57	0:14	LINE FAULT
301	15-Dec-2021	HASSAN	66	HASSN22-SKPURA	HASSAN_220	13:30	14:32	1:02	LINE CLEAR AVAILED
302	15-Dec-2021	HASSAN	66	HV1	KALASAPURA_66	9:59	10:52	0:53	LINE CLEAR AVAILED
303	15-Dec-2021	HASSAN	66	HV1	SHANTHIGRAMA_66	12:11	13:12	1:01	LINE CLEAR AVAILED
304	15-Dec-2021	HASSAN	66	HV2	SHANTHIGRAMA_66	10:30	12:11	1:41	LINE CLEAR AVAILED
305	15-Dec-2021	HASSAN	66	KANDLI-HASSAN	KANDLI_66	13:30	14:30	1:00	LINE CLEAR AVAILED
306	15-Dec-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:14	15:36	5:22	LINE CLEAR AVAILED
307	15-Dec-2021	HASSAN	110	HV1	GURUVAYANAKERE_110	0:29	0:48	0:19	TRANSFORMER FAULT
308	15-Dec-2021	HASSAN	110	HV1	GURUVAYANAKERE_110	9:47	14:49	5:02	LINE CLEAR AVAILED
309	15-Dec-2021	HASSAN	110	HV1	MSEZ_220	10:29	15:03	4:34	LINE CLEAR AVAILED
310	15-Dec-2021	HASSAN	110	HV1	SAGARA_110	11:31	12:57	1:26	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
311	15-Dec-2021	HASSAN	110	HV2	HALADY_110	11:50	12:06	0:16	LINE CLEAR AVAILED
312	15-Dec-2021	HASSAN	110	HV2	HALADY_110	12:29	12:41	0:12	LINE CLEAR AVAILED
313	15-Dec-2021	HASSAN	110	HV2	KONAJE_110	10:18	17:10	6:52	LINE CLEAR AVAILED
314	15-Dec-2021	HASSAN	110	HV3	SAGARA_110	11:44	12:06	0:22	LINE CLEAR AVAILED
315	15-Dec-2021	HASSAN	110	JOG110-LPH	JOG_110	15:40(14.12.2021)	13:55(15.12.2021)	22:15hrs	LINE CHARGED
316	15-Dec-2021	HASSAN	110	JOG-JLT4	mghejog_gen	9:17	17:54	8:37	NFBC ISSUED
317	15-Dec-2021	HASSAN	110	KADUR-YGTI	KADUR_220	22:19	22:31	0:12	LINE FAULT
318	15-Dec-2021	HASSAN	110	KARKLA-L1 CBreaker	KARKALA_110	8:01(15.12.2021)			LINE OPEN,LINE CLEAR AVAILED
319	15-Dec-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	10:14	15:36	5:22	NFBC ISSUED
320	15-Dec-2021	HASSAN	110	LV1	KAVOOR_220	9:13	12:08	2:55	LINE CLEAR AVAILED
321	15-Dec-2021	HASSAN	110	LV2	KAVOOR_220	12:09	18:40	6:31	LINE CLEAR AVAILED
322	15-Dec-2021	HASSAN	110	LV3	KAVOOR_220	15:45	18:40	2:55	LINE CLEAR AVAILED
323	15-Dec-2021	HASSAN	110	TALAGU-L1-LST 3 LPH	TALAGUPPA_110	14:37	17:36	2:59	NFBC ISSUED
324	15-Dec-2021	HASSAN	220	HV1	KAVOOR_220	9:13	12:08	2:55	LINE CLEAR AVAILED
325	15-Dec-2021	HASSAN	220	HV2	KAVOOR_220	12:09	18:40	6:31	LINE CLEAR AVAILED
326	15-Dec-2021	HASSAN	220	HV3	KAVOOR_220	15:45	18:40	2:55	LINE CLEAR AVAILED
327	15-Dec-2021	HASSAN	220	HV3	KEMAR_220	12:31	16:27	3:56	LINE CLEAR AVAILED
328	15-Dec-2021	HASSAN	220	KADUR-DABUSET	KADUR_220	10:30	13:05	2:35	LINE CLEAR AVAILED
329	15-Dec-2021	HASSAN	220	KEMAR-KEMAR2	varahi_gen	10:12	13:37	3:25	NFBC ISSUED
330	15-Dec-2021	HASSAN	220	KEMAR-VARAH12	KEMAR_220	10:12	13:37	3:25	LINE CLEAR AVAILED
331	15-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:50(15.12.2021)			LINE OPEN,LINE CLEAR AVAILED
332	15-Dec-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:22(15.12.2021)			LINE OPEN,LINE CLEAR AVAILED
333	15-Dec-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:37(13.12.2021)	19:16(15.12.2021)	20:39hrs	LINE CHARGED
334	15-Dec-2021	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	10:13	16:24	6:10	LINE CLEAR AVAILED
335	15-Dec-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	10:29	10:39	0:09	LINE FAULT
336	15-Dec-2021	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	12:37	12:54	0:17	LINE FAULT
337	15-Dec-2021	MYSURU	66	CR NAGARA-YALANDUR	YELANDUR_66	19:13	19:20	0:07	LINE FAULT
338	15-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN,LINE CLEAR AVAILED
339	15-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
340	15-Dec-2021	MYSURU	66	HEBBANI-MEGALAPURA	CHIDRAVALLI_66 BGPURA_66	21:16	21:25	0:09	LINE FAULT
341	15-Dec-2021	MYSURU	66	HEBBANI-MEGALAPURA	CHIDRAVALLI_66 BGPURA_66	22:53	23:03	0:10	LINE FAULT
342	15-Dec-2021	MYSURU	66	HUNSUR-HOOTAGALLI	HOSURGATE_66	16:11	17:59	1:48	NFBC ISSUED
343	15-Dec-2021	MYSURU	66	HV1	KIKKERI_66	13:17	16:28	3:11	LINE CLEAR AVAILED
344	15-Dec-2021	MYSURU	66	HV1	MADESWARAPURA_66	10:31	11:03	0:31	LINE CLEAR AVAILED
345	15-Dec-2021	MYSURU	66	HV1	NAGAMANGALA_66	11:05	11:08	0:03	HAND TRIPPED
346	15-Dec-2021	MYSURU	66	HV1	NAGAMANGALA_66	15:40	16:46	1:05	LINE CLEAR AVAILED
347	15-Dec-2021	MYSURU	66	HV1	NANJANGUD_66	12:29	17:17	4:48	LINE CLEAR AVAILED
348	15-Dec-2021	MYSURU	66	HV2	KIKKERI_66	11:02	13:19	2:17	LINE CLEAR AVAILED
349	15-Dec-2021	MYSURU	66	HV2	NAGAMANGALA_66	11:05	11:09	0:03	HAND TRIPPED
350	15-Dec-2021	MYSURU	66	HV2	NAGAMANGALA_66	16:36	17:44	1:07	LINE CLEAR AVAILED
351	15-Dec-2021	MYSURU	66	HV3	KIKKERI_66	15:33	16:56	1:22	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
352	15-Dec-2021	MYSURU	66	JAKKANAHALLI-NAGAMANGLA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	18:26	18:32	0:06	LINE FAULT
353	15-Dec-2021	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	14:11	14:15	0:04	LINE FAULT
354	15-Dec-2021	MYSURU	66	KR NAGARA-BILIKERE	BILIKERE_66	10:28	16:19	5:51	LINE CLEAR AVAILED
355	15-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN,LINE CLEAR AVAILED
356	15-Dec-2021	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA 1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66	0:59	1:07	0:07	LINE FAULT
357	15-Dec-2021	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA 1	KANAGAL_66 ALUR SIDDAPUR_66 CB HALLI_66 RUDRAPATNA_66	1:07	11:41	10:34	LINE FAULT
358	15-Dec-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	10:42	10:46	0:03	LINE FAULT
359	15-Dec-2021	MYSURU	66	MALLAVALLI-TK HALLI	MALAVALLI_66 HADLI_66	12:09	13:12	1:02	LINE CLEAR AVAILED
360	15-Dec-2021	MYSURU	66	MEGALAPURA-HEBBANI	CHIDRAVALLI_66	8:16	10:20	2:03	NFBC ISSUED
361	15-Dec-2021	MYSURU	66	MEGALAPURA-HEBBANI	NO STATIONS EFFECTED	13:48	14:02	0:14	LINE FAULT
362	15-Dec-2021	MYSURU	66	NAGAMANGALA-KR PETE 220	NO STATIONS EFFECTED	11:02	16:43	5:40	LINE CLEAR AVAILED
363	15-Dec-2021	MYSURU	66	SANTHESARGUR-KADAKOLA 2	NO STATIONS EFFECTED	9:58	10:05	0:07	HAND TRIPPED
364	15-Dec-2021	MYSURU	66	SFC SIVA-10MW	NO STATIONS EFFECTED	21:15:00 (15.12.2021)			LINE OPEN, LINE FAULT
365	15-Dec-2021	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	8:31:00 (15.12.2021)			LINE OPEN,LINE CLEAR AVAILED
366	15-Dec-2021	MYSURU	220	KADAKOLA-KOZIKODE	NO STATIONS EFFECTED	0:56:43 (14.12.2021)	10:45:41 (15.12.2021)	33:48 hrs	LINE CHARGED
367	15-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	8:51	9:04	0:12	LINE FAULT
368	15-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV- YEDIYUR(BG NAGAR)	JIDDIGERE_66, YEDIYUR_66	14:15	14:29	0:13	LINE FAULT
369	15-Dec-2021	TUMKUR	66	DAVANGERE SRS- AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKAT TE_66,KADAJJI_66	3:25	3:32	0:06	LINE FAULT
370	15-Dec-2021	TUMKUR	66	DAVANGERE SRS- HARIHARA(YARAGUNTA)	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	7:35	8:14	0:38	HAND TRIPPED
371	15-Dec-2021	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJJIHALLI_66	8:19	8:21	0:02	HAND TRIPPED
372	15-Dec-2021	TUMKUR	66	DEVARABELEKERE-BANUVALLI	BANUVALLI_66	11:15	11:23	0:08	LINE FAULT
373	15-Dec-2021	TUMKUR	66	DEVARABELEKERE-KUNDUR	DEVARABELEKERE_66	11:15	11:23	0:08	LINE FAULT
374	15-Dec-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:34	6:47	0:12	LINE FAULT
375	15-Dec-2021	TUMKUR	66	HONNALLI 220kV- LINGADAHALLI- CHANNAGIRI(NALLUR)	DEVARAHALLI_66, LINGADAHALLI_66, NALLUR_66, GOPPENAHALLI_66	14:41	15:14	0:32	LINE CLEAR AVAILED
376	15-Dec-2021	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,	12:41	14:36	1:54	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
377	15-Dec-2021	TUMKUR	66	LINGADAHALLI- HONNALLI	LINGDHALLI_66	13:01	14:41	1:40	NFBC ISSUED
378	15-Dec-2021	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	13:00	14:40	1:40	NFBC ISSUED
379	15-Dec-2021	TUMKUR	66	MADHUGIRI 220KV- KORATAGERE 1	KORATAGERE_66	6:00	6:17	0:17	LINE FAULT
380	15-Dec-2021	TUMKUR	66	MADHUGIRI 220kv- PULLAMAGATTA	PULLAMGATTA_66	6:19	6:29	0:09	LINE FAULT
381	15-Dec-2021	TUMKUR	66	PAVAGADA220-NAGALMADIKE	NAGALMADIKE_66	0:07	0:12	0:05	LINE FAULT
382	15-Dec-2021	TUMKUR	66	SIRA- MADHUGIRI 1	BUKKAPATNA_66, KALLAMBELLA_66	15:58	16:08	0:10	HAND TRIPPED
383	15-Dec-2021	TUMKUR	66	TR-1	CHIKKATHOTTILUKERE_66	6:19	6:25	0:06	TRANSFORMER FAULT
384	15-Dec-2021	TUMKUR	66	TR-1	DAVANGERE_SRS_220	9:22	9:29	0:06	HAND TRIPPED
385	15-Dec-2021	TUMKUR	66	TR-1	DAVANGERE_SRS_220	10:40	11:08	0:28	LINE CLEAR AVAILED
386	15-Dec-2021	TUMKUR	66	TR-1	SIRA_220	16:02	16:11	0:08	HAND TRIPPED
387	15-Dec-2021	TUMKUR	66	TR-2	ID HALLI_66	10:35	13:30	2:54	TRANSFORMER FAULT
388	15-Dec-2021	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,KADEH ALLI_110	5:23	5:42	0:19	LINE FAULT
389	15-Dec-2021	TUMKUR	220	KDBVNP- MADHUGIRI220	KDBVNO_220	13:16	13:27	0:10	MAIN SUPPLY FAILURE
390	15-Dec-2021	TUMKUR	220	MADHUGIRI 220kv- HIRIYUR	MADHUGIRI_220	13:14	13:22	0:08	LINE CLEAR AVAILED
391	15-Dec-2021	TUMKUR	220	MADHUGIRI 220kv- VASANTANARASAPURA 1	MADHUGORI_220	13:14	13:23	0:09	LINE CLEAR AVAILED
392	15-Dec-2021	TUMKUR	220	MADHUGIRI 220kv- GOWRIBIDANUR220	MADHUGIRI_220	13:23	13:32	0:09	LINE CLEAR AVAILED
393	15-Dec-2021	TUMKUR	220	MADHUGIRI 220kv-PAVAGADA_220 1	MADHUGIRI_220	13:19	13:23	0:03	LINE CLEAR AVAILED
394	15-Dec-2021	TUMKUR	220	TR-2	SIRA_220	16:06	17:47	1:40	LINE CLEAR AVAILED
395	16-Dec-2021	BAGALKOT	110	110/11KV,HV 1	ATHARGA_110	14:03	15:05	1:02	LINE CLEAR AVAILED
396	16-Dec-2021	BAGALKOT	110	110/33KV,HV 2	GULEDGUDDA_110 & SHIRUR_33,KAMATAGI_33, ACME SOLAR_33	6:24	6:48	0:24	LINE CLEAR AVAILED
397	16-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
398	16-Dec-2021	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	22:04	22:35	0:31	LINE FAULT
399	16-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
400	16-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
401	16-Dec-2021	BAGALKOT	110	LAXMESHVAR-SHIRAHATTI	SHIRAHATTI_110	2:35	11:49	9:14	LINE FAULT
402	16-Dec-2021	BAGALKOT	110	MALGHAN(S)-MANALI SUGARS	MALGHAN(S)_110	18:17	18:22	0:05	LINE FAULT
403	16-Dec-2021	BAGALKOT	110	RANEENNUR-AREMALLAPURA	AREMALLAPURA_110	14:11	14:16	0:05	MAIN SUPPLY FAILURE
404	16-Dec-2021	BAGALKOT	110	RANEENNUR-BYADAGI	BYADAGI_110	14:11	14:17	0:06	MAIN SUPPLY FAILURE
405	16-Dec-2021	BAGALKOT	110	RANEENNUR-HIREKERUR	HIREKERUR_110	14:11	14:16	0:05	MAIN SUPPLY FAILURE
406	16-Dec-2021	BAGALKOT	110	RANEENNUR-RATTIHALLI	RATTIHALLI_110	14:11	14:16	0:05	MAIN SUPPLY FAILURE
407	16-Dec-2021	BAGALKOT	110	SATTI-RABAKAVI	SATTI_110	12:11	12:16	0:05	LINE CLEAR AVAILED
408	16-Dec-2021	BAGALKOT	110	SHIRAHATTI-BPLC 2(GADAG)	SHIRAHATTI_110	2:35	2:56	0:21	LINE FAULT
409	16-Dec-2021	BAGALKOT	110	SHIRAHATTI-LAKSHMESHVAR	LAKSHMESHVAR_110	1:42	11:47	10:05	LINE FAULT
410	16-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
411	16-Dec-2021	BAGALKOT	110	TAKKALAKI-TIKOTA	TIKOTA_110	5:58	6:03	0:05	LINE FAULT
412	16-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25(08.12.2021)			LINE OPEN, LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
413	16-Dec-2021	BAGALKOT	220	BAGALKOT - ALAMATTI-2	BAGALKOT_220	4:53	6:15	1:22	LINE FAULT
414	16-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
415	16-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
416	16-Dec-2021	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56(26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
417	16-Dec-2021	BAGALKOT	220	HAVERI-GUTTUR 1	HAVERI_220	10:53	14:58	4:05	LINE CLEAR AVAILED
418	16-Dec-2021	BAGALKOT	220	HAVERI-GUTTUR 2	HAVERI_220	10:53	14:58	4:05	LINE CLEAR AVAILED
419	16-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
420	16-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
421	16-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
422	16-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
423	16-Dec-2021	BAGALKOT	220	RANEBENNUR-BALLIGAVI	RANEBENNUR_220	14:07	15:31	1:24	LINE FAULT
424	16-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
425	16-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
426	16-Dec-2021	BENGALURU	66	ABBIGERE - ATTUR YELAHANKA	ABBIGERE	17:25	17:54	0:29	MAIN SUPPLY FAILURE
427	16-Dec-2021	BENGALURU	66	ABBIGERE - WELCAST	ABBIGERE	19:41	19:44	0:03	LOAD CHANGE OVER
428	16-Dec-2021	BENGALURU	66	ATTUR YELAHANKA - DG3	ABBIGERE	17:25	17:54	0:29	LINE FAULT
429	16-Dec-2021	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	6:31	6:38	0:07	LINE FAULT
430	16-Dec-2021	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD	6:31	6:52	0:21	LINE FAULT
431	16-Dec-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	23:51:26(16-12-2021)			LINE OPEN, LINE FAULT
432	16-Dec-2021	BENGALURU	66	GANJIGUNTE - DIBURALLI	DIBURALLI	15:30	17:58	2:28	LINE CLEAR AVAILED
433	16-Dec-2021	BENGALURU	66	GURUVINAPURA - BV HALLI	BV HALLI	7:18	7:30	0:12	LINE FAULT
434	16-Dec-2021	BENGALURU	66	HV1	TK HALLI 220	16:25	16:29	0:04	TRANSFORMER FAULT
435	16-Dec-2021	BENGALURU	66	HV1	KYALANUR	15:35	15:48	0:12	TRANSFORMER FAULT
436	16-Dec-2021	BENGALURU	66	HV1	KEMBODI	14:53	16:34	1:41	LINE CLEAR AVAILED
437	16-Dec-2021	BENGALURU	66	HV1	BRIGADE MEADOWS	23:29(16/12/2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
438	16-Dec-2021	BENGALURU	66	HV2	AUSTIN TOWN	11:08	11:10	0:02	LINE CLEAR AVAILED
439	16-Dec-2021	BENGALURU	66	HV2	REMCO	14:25	14:38	0:13	LINE CLEAR AVAILED
440	16-Dec-2021	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	8:40	8:45	0:05	LOAD CHANGE OVER
441	16-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN, LINE FAULT
442	16-Dec-2021	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	13:45	14:08	0:23	MAIN SUPPLY FAILURE
443	16-Dec-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:45	14:09	0:24	MAIN SUPPLY FAILURE
444	16-Dec-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:45	14:12	0:26	MAIN SUPPLY FAILURE
445	16-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	6:31	6:51	0:20	LINE FAULT
446	16-Dec-2021	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	18:06(14/12/2021)	22:14(16/12/2021)	52:14HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
447	16-Dec-2021	BENGALURU	220	HV1	GOWRIBIDANUR 220	10:28	10:45	0:16	LINE CLEAR AVOID
448	16-Dec-2021	BENGALURU	220	KOLAR 220 - MALUR 3	SARJAPURA 220, VIKAS TEC PARK 220	13:44	14:03	0:19	LINE FAULT
449	16-Dec-2021	GULBARGA	66	HV1	BENNEHALLI	16:25	16:35	0:10	LINE CLEAR AVOID
450	16-Dec-2021	GULBARGA	66	HV1	TELAGI_66	9:10	9:20	0:10	TRANSFORMER FAULT
451	16-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
452	16-Dec-2021	GULBARGA	66	ITTAGI-HIREHADAGALI2	HIREHADAGALI_66,GIRYAPUR_66,MANGALA_66,SOVENHALLI_66, TUNGA BHADRA_IPP	19:28	19:34	0:06	LINE FAULT
453	16-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	11:52(16.12.2021)			MAIN SUPPLY FAILURE
454	16-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	18:19	18:27	0:08	LINE FAULT
455	16-Dec-2021	GULBARGA	110	GULBARGAUNIVERSITY-SHAHABAD2	GULBARGAUNIVERSITY_110	11:35	11:45	0:10	MAIN SUPPLY FAILURE
456	16-Dec-2021	GULBARGA	110	GULBARGAWEST-GULBARGASOUTH	GULBARGASOUTH_110	9:55	12:05	2:10	NFBC ISSUED
457	16-Dec-2021	GULBARGA	110	HALBARGA-BHALKI	BHALKI_110,MGSSK_IPP,LADHA_110,BHALKI SUGAR_IPP	5:33	5:40	0:07	LINE FAULT
458	16-Dec-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:35	4:45	0:10	MAIN SUPPLY FAILURE
459	16-Dec-2021	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	4:35	4:45	0:10	MAIN SUPPLY FAILURE
460	16-Dec-2021	GULBARGA	110	HV1	VALKAMDINNI_110	12:10	16:10	4:00	LINE CLEAR AVOID
461	16-Dec-2021	GULBARGA	110	HV1	ALIPUR_220	1:23	1:39	0:16	TRANSFORMER FAULT
462	16-Dec-2021	GULBARGA	110	HV2	HATTI_110	12:52	12:59	0:07	TRANSFORMER FAULT
463	16-Dec-2021	GULBARGA	110	HV2	GULBARGAWEST_110	10:17	10:49	0:32	LINE CLEAR AVOID
464	16-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN,LINE CLEAR AVOID
465	16-Dec-2021	GULBARGA	110	LV1	SHAHABAD_220	9:20	21:18	11:58	LINE CLEAR AVOID
466	16-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110,MANVI_110	23:01	23:10	0:09	LINE FAULT
467	16-Dec-2021	GULBARGA	110	NANDUR-GULBARGAUNIVERSITY	NANDUR_110	11:37	11:49	0:12	MAIN SUPPLY FAILURE
468	16-Dec-2021	GULBARGA	110	NANDUR-SHAHABAD	NANDUR_110	11:37	11:43	0:06	MAIN SUPPLY FAILURE
469	16-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVOID
470	16-Dec-2021	GULBARGA	110	SHAHABAD-FARTHABAD	FARTHABAD_110,GULBARGA SOUTH_110	11:35	15:20	3:45	LINE CLEAR AVOID
471	16-Dec-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	19:42	19:50	0:08	LINE FAULT
472	16-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	8:45	17:30	8:45	LINE CLEAR AVOID
473	16-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	23:21	23:30	0:09	LINE FAULT
474	16-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	8:45	17:30	8:45	LINE CLEAR AVOID
475	16-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	23:21	23:30	0:09	LINE FAULT
476	16-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:30 (16.12.2021)			LINE OPEN,LINE CLEAR AVOID
477	16-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARATAGI_110,SR NAGAR_110	11:55	12:10	0:15	LINE FAULT
478	16-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVOID
479	16-Dec-2021	GULBARGA	220	HV1	HUMNABAD_220	8:36	10:40	2:04	TRANSFORMER FAULT
480	16-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
481	16-Dec-2021	GULBARGA	220	ITTAGI-NEELAGUNDA	NEELAGUNDA_220	12:30	14:00	1:30	LINE CLEAR AVOID
482	16-Dec-2021	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	10:00	15:10	5:10	NFBC ISSUED
483	16-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	21:12 (15.12.2021)	7:28 (16.12.2021)	8:42 HRS	LINE CHARGED
484	16-Dec-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	1:47	2:05	0:18	LINE FAULT
485	16-Dec-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	4:06	4:20	0:14	LINE FAULT
486	16-Dec-2021	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	5:31	5:42	0:11	LINE FAULT
487	16-Dec-2021	HASSAN	66	HASSN220-HN PURA	HASSAN_220	10:09	11:57	1:48	LINE FAULT
488	16-Dec-2021	HASSAN	66	HASSN220-MALLALI	HASSAN_220	10:40	11:57	1:17	LINE CLEAR AVOID
489	16-Dec-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	9:46	12:02	2:16	LINE CLEAR AVOID
490	16-Dec-2021	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	17:06	18:20	1:14	LINE CLEAR AVOID
491	16-Dec-2021	HASSAN	66	HV1	HALLYMYSORE_66	17:12	18:36	1:24	MAIN SUPPLY FAILURE
492	16-Dec-2021	HASSAN	66	HV1	HANGARAHALLY_66	11:20	12:25	1:05	LINE CLEAR AVOID
493	16-Dec-2021	HASSAN	66	HV1	HANGARAHALLY_66	12:25	14:00	1:35	LINE CLEAR AVOID
494	16-Dec-2021	HASSAN	66	HV1	KANDLI_66	21:27	21:33	0:06	TRANSFORMER FAULT
495	16-Dec-2021	HASSAN	66	HV1	MAGGE_66	13:10	14:00	0:50	LINE CLEAR AVOID
496	16-Dec-2021	HASSAN	66	HV1	YESLUR_66	1:49	2:06	0:17	MAIN SUPPLY FAILURE
497	16-Dec-2021	HASSAN	66	HV1	YESLUR_66	4:08	4:21	0:13	MAIN SUPPLY FAILURE
498	16-Dec-2021	HASSAN	66	HV1	YESLUR_66	5:38	5:43	0:05	MAIN SUPPLY FAILURE
499	16-Dec-2021	HASSAN	66	HV2	ARKD_66	1:47	12:06	10:19	TRANSFORMER FAULT
500	16-Dec-2021	HASSAN	66	HV2	ARKD_66	4:06	4:16	0:10	TRANSFORMER FAULT
501	16-Dec-2021	HASSAN	66	HV2	ARKD_66	5:31	5:40	0:09	TRANSFORMER FAULT
502	16-Dec-2021	HASSAN	66	HV2	HALLYMYSORE_66	17:12	18:36	1:24	MAIN SUPPLY FAILURE
503	16-Dec-2021	HASSAN	66	HV2	KANDLI_66	21:27	21:32	0:05	TRANSFORMER FAULT
504	16-Dec-2021	HASSAN	66	HV2	MAGGE_66	12:05	13:20	1:15	LINE CLEAR AVOID
505	16-Dec-2021	HASSAN	66	HV3	BALEHONNUR_66	11:53	13:38	1:45	LINE CLEAR AVOID
506	16-Dec-2021	HASSAN	110	ALKOLA-MRS	ALKOLA_110	11:06	14:05	2:59	NFBC ISSUED
507	16-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	17:24 (16.12.2021)			LINE OPEN,LINE CLEAR AVOID
508	16-Dec-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	10:51	14:30	3:39	LINE CLEAR AVOID
509	16-Dec-2021	HASSAN	110	HV1	KARAYA_110	9:56	12:36	2:40	LINE CLEAR AVOID
510	16-Dec-2021	HASSAN	110	HV1	SHIRALKOPPA_110	12:45	17:00	4:15	LINE CLEAR AVOID
511	16-Dec-2021	HASSAN	110	HV2	KARAYA_110	9:56	12:36	2:40	LINE CLEAR AVOID
512	16-Dec-2021	HASSAN	110	HV2	MSEZ_220	10:21	14:28	4:07	LINE CLEAR AVOID
513	16-Dec-2021	HASSAN	110	HV2	SHIRALKOPPA_110	10:30	18:50	8:20	LINE CLEAR AVOID
514	16-Dec-2021	HASSAN	110	KARKLA-L1 CBreaker	KARKALA_110	8:01(15.12.2021)			LINE OPEN,LINE CLEAR AVOID
515	16-Dec-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	8:48	8:50	0:02	HAND TRIPPED
516	16-Dec-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	14:52	14:56	0:04	HAND TRIPPED
517	16-Dec-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	10:51	14:30	3:39	LINE CLEAR AVOID
518	16-Dec-2021	HASSAN	110	LST4	SAGARA_110	9:55	13:35	3:40	LINE CLEAR AVOID
519	16-Dec-2021	HASSAN	110	LV1	KADUR_220	10:27	13:54	3:27	LINE CLEAR AVOID
520	16-Dec-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	9:47	17:21	7:34	LINE CLEAR AVOID
521	16-Dec-2021	HASSAN	110	MRSSHM-SS1	MRSMG_220	11:03	14:05	3:02	LINE CLEAR AVOID
522	16-Dec-2021	HASSAN	110	PUTTUR-PUTUR 1	PUTTUR_110	10:46	11:18	0:32	LINE CLEAR AVOID
523	16-Dec-2021	HASSAN	110	PUTTUR-SULIA	PUTTUR_110	10:33	11:34	1:01	LINE CLEAR AVOID
524	16-Dec-2021	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	10:01	12:26	2:25	LINE CLEAR AVOID

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
525	16-Dec-2021	HASSAN	110	VITTAL-PUTR_SLTUR	VITTALA_110	10:03	12:26	2:23	LINE CLEAR AVAILED
526	16-Dec-2021	HASSAN	220	HV1	KADUR_220	10:27	13:54	3:27	LINE CLEAR AVAILED
527	16-Dec-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:18	14:44	4:26	LINE CLEAR AVAILED
528	16-Dec-2021	HASSAN	220	VARAHI-KEMAR1	VARAHI	10:18	14:44	4:26	LINE CLEAR AVAILED
529	16-Dec-2021	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	9:50(15.12.2021)	15:37(16.12.2021)	29:46 hrs	LINE CHARGED
530	16-Dec-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:22(15.12.2021)			LINE OPEN,LINE CLEAR AVAILED
531	16-Dec-2021	MYSURU	66	BEGURU 220-SANTESARGUR	B MATAKERE_66	15:18	15:51	0:33	LINE CLEAR AVAILED
532	16-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN,LINE CLEAR AVAILED
533	16-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
534	16-Dec-2021	MYSURU	66	HEBBANI-MEGHALAPURA	NO STATIONS EFFECTED	3:27	3:35	0:08	LINE FAULT
535	16-Dec-2021	MYSURU	66	HOOTGALLY-HAMPAPURA(KAGGERE)	HAMPAPURA(K)_66	18:07	18:21	0:14	LINE FAULT
536	16-Dec-2021	MYSURU	66	HV1	DODDABYADARAHALLI_66	12:08	14:18	2:10	LINE CLEAR AVAILED
537	16-Dec-2021	MYSURU	66	HV1	HARADANAHALI(JAK)_66	11:25	15:15	3:50	LINE CLEAR AVAILED
538	16-Dec-2021	MYSURU	66	HV1	KRNAGARA_66	15:00	16:21	1:21	LINE CLEAR AVAILED
539	16-Dec-2021	MYSURU	66	HV1	HEBBANI_66	9:00	11:57	2:57	LINE CLEAR AVAILED
540	16-Dec-2021	MYSURU	66	HV2	COWDALLI_66	9:57	17:56	7:58	LINE CLEAR AVAILED
541	16-Dec-2021	MYSURU	66	HV2	DODDABYADARAHALLI_66	14:06	15:52	1:46	LINE CLEAR AVAILED
542	16-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN,LINE CLEAR AVAILED
543	16-Dec-2021	MYSURU	66	SANTESARGUR-B MATAKERE	B MATAKERE_66	10:20	18:20	8:00	LINE CLEAR AVAILED
544	16-Dec-2021	MYSURU	66	SANTESARGUR-KADAKOLA2	NO STATIONS EFFECTED	13:50	14:50	1:00	LINE CLEAR AVAILED
545	16-Dec-2021	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	8:31:00 (15.12.2021)			LINE OPEN,LINE CLEAR AVAILED
546	16-Dec-2021	TUMKUR	66	ANCHEPALYA 220kV-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	3:40	3:55	0:14	LINE FAULT
547	16-Dec-2021	TUMKUR	66	CHITRADURGA 220kV-PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	10:26	16:41	6:14	LINE CLEAR AVAILED
548	16-Dec-2021	TUMKUR	66	DAVANGERE SRS-AVAREGERE66(CTA-1)	AVAREGERE_66,MELLEKAT TE_66,KADAJJI_66	12:56	13:00	0:03	LINE FAULT
549	16-Dec-2021	TUMKUR	66	HANGAL66-RAMPURA	HANAGAL_66	6:37	6:43	0:06	LINE FAULT
550	16-Dec-2021	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	13:01	13:11	0:09	LINE FAULT
551	16-Dec-2021	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	9:33	9:46	0:13	LINE FAULT
552	16-Dec-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66	5:54	5:58	0:04	LINE FAULT
553	16-Dec-2021	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66	23:39	23:41	0:02	LINE FAULT
554	16-Dec-2021	TUMKUR	66	NAGASAMUDRA- RAMPUR	NAGASAMUDRA_66, RAMPURA_66	6:50	6:52	0:01	LINE FAULT
555	16-Dec-2021	TUMKUR	66	PAVAGADA220-MIDIGESHI	MIDIGESHI_66	6:24	6:40	0:15	LINE FAULT
556	16-Dec-2021	TUMKUR	66	PAVAGADA220-NAGALMADIKE	NAGALMADIKE_66	17:17	17:22	0:04	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
557	16-Dec-2021	TUMKUR	66	PAVAGADA220-PAVAGADA2	PAVAGADA_220	6:24	6:41	0:16	LINE FAULT
558	16-Dec-2021	TUMKUR	66	TR-1	TUMKUR_66	9:40	17:54	8:14	LINE CLEAR AVAILED
559	16-Dec-2021	TUMKUR	66	TR-1(HV-1)	KDBVNO_220	13:14	13:29	0:14	LINE CLEAR AVAILED
560	16-Dec-2021	TUMKUR	66	TR-1(LV-1)	KDBVNO_220	12:05	13:12	1:06	LINE CLEAR AVAILED
561	16-Dec-2021	TUMKUR	66	TR-1(LV-1)	PAVAGADA_220	6:24	6:31	0:07	TRANSFORMER FAULT
562	16-Dec-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	9:20	9:25	0:04	TRANSFORMER FAULT
563	16-Dec-2021	TUMKUR	66	TR-2(HV-2)	KDBVNO_220	13:31	13:46	0:14	LINE CLEAR AVAILED
564	16-Dec-2021	TUMKUR	66	TR-2(HV-2)	LKOLALA_66	12:24	14:33	2:09	LINE CLEAR AVAILED
565	16-Dec-2021	TUMKUR	66	TR-2(LV-2)	PAVAGADA_220	6:24	6:37	0:13	TRANSFORMER FAULT
566	16-Dec-2021	TUMKUR	220	GUTTUR 400KV- HAVERI 1	HAVERI_220	10:55	14:58	4:03	NFBC ISSUED
567	16-Dec-2021	TUMKUR	220	TR-1	KDBVNO_220	12:05	12:44	0:38	LINE CLEAR AVAILED
568	16-Dec-2021	TUMKUR	220	TR-1	PAVAGADA_220	6:24	6:30	0:05	TRANSFORMER FAULT
569	16-Dec-2021	TUMKUR	220	TR-2	KDBVNO_220	12:48	13:10	0:22	LINE CLEAR AVAILED
570	16-Dec-2021	TUMKUR	220	TR-2	PAVAGADA_220	6:24	6:37	0:13	TRANSFORMER FAULT
571	16-Dec-2021	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	10:46	17:27	6:41	LINE CLEAR AVAILED
572	16-Dec-2021	TUMKUR	400	GUTTUR 400KV- NARENDRA-2	NARENDRA -2 LINE	3:47	6:48	3:00	LINE CLEAR AVAILED
573	17-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
574	17-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
575	17-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
576	17-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
577	17-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
578	17-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
579	17-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
580	17-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56(26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
581	17-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25(08.12.2021)			LINE OPEN, LINE FAULT
582	17-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
583	17-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
584	17-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
585	17-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
586	17-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
587	17-Dec-2021	BAGALKOT	110	110/11KV,HV 2	ALMEL_110	11:19	11:28	0:09	HAND TRIPPED
588	17-Dec-2021	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	4:58	5:03	0:05	HAND TRIPPED
589	17-Dec-2021	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	4:58	5:03	0:05	HAND TRIPPED
590	17-Dec-2021	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110 & NAGATHAN &HONNUTAGI_33	12:29	12:44	0:15	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
591	17-Dec-2021	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	0:53	1:07	0:14	LINE FAULT
592	17-Dec-2021	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	6:17	7:46	1:29	LINE FAULT
593	17-Dec-2021	BAGALKOT	110	DAMBAL-EILS(L1)	DAMBAL_110	18:21	19:05	0:44	HAND TRIPPED
594	17-Dec-2021	BAGALKOT	220	NARENDRA- HAVERI	NARENDRA_220	15:17	17:21	2:04	LINE CLEAR AVAILED
595	17-Dec-2021	BAGALKOT	220	HAVERI- NARENDRA	HAVERI_220	15:17	17:21	2:04	LINE CLEAR AVAILED
596	17-Dec-2021	BAGALKOT	110	110/11KV, HV2	TILUVALLI_110	11:20	12:32	1:12	LINE CLEAR AVAILED
597	17-Dec-2021	BAGALKOT	110	110/11KV, HV1	SIRSI_110	13:12	13:29	0:17	LINE CLEAR AVAILED
598	17-Dec-2021	BAGALKOT	110	SATTI- RABAKAVI	SATTI_110	10:12	10:16	0:04	HAND TRIPPED
599	17-Dec-2021	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	20:37	21:07	0:30	HAND TRIPPED
600	17-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE FAULT
601	17-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE CLEAR AVAILED
602	17-Dec-2021	BAGALKOT	110	RON- GAMESHA	RON_110	21:07	21:14	0:07	HAND TRIPPED
603	17-Dec-2021	BAGALKOT	110	NAVALGUND- KONNUR	NAVALGUND_110	2:28	2:53	0:25	LINE FAULT
604	17-Dec-2021	BAGALKOT	110	110/11KV, HV1	MAMADAPUR(G)_110	6:50	8:56	2:06	LINE CLEAR AVAILED
605	17-Dec-2021	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	10:21	13:20	2:59	LINE CLEAR AVAILED
606	17-Dec-2021	BAGALKOT	110	LAXMESHVAR- BELLATTI	LAXMESHVAR_110	4:37	4:59	0:22	LINE FAULT
607	17-Dec-2021	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR 33	17:23	17:30	0:07	TRANSFORMER FAULT
608	17-Dec-2021	BAGALKOT	110	110/11KV, HV4	KERUR_110	19:46	20:25	0:39	TRANSFORMER FAULT
609	17-Dec-2021	BAGALKOT	110	KUDALSANGAM- HUNGUND	KUDALSANGAM_110	12:24	13:10	0:46	LINE CLEAR AVAILED
610	17-Dec-2021	BAGALKOT	110	VAJRAMATTI220- SHIRGUPPI	VAJRAMATTI_220	6:35	6:40	0:05	LINE FAULT
611	17-Dec-2021	BAGALKOT	110	SIRAGUPPI-BILAGI	SHIRAGUPPI_110, BILAGI_110	6:35	6:45	0:10	LINE FAULT
612	17-Dec-2021	BAGALKOT	110	110/11KV, HV1	MUDHOL_110	10:03	12:48	2:45	LINE CLEAR AVAILED
613	17-Dec-2021	BAGALKOT	220	BALLIGAVI- RANEBENNUR	RANEBENNUR_220	10:25	10:30	0:05	HAND TRIPPED
614	17-Dec-2021	BENGALURU	66	HV2	WEL CAST STEEL	12:39	13:22	0:42	LINE CLEAR AVAILED
615	17-Dec-2021	BENGALURU	66	HV2	THAYALUR	13:35	13:42	0:06	TRANSFORMER FAULT
616	17-Dec-2021	BENGALURU	66	HV2	TEMAGONDALU	17:53	18:17	0:23	LINE CLEAR AVAILED
617	17-Dec-2021	BENGALURU	66	HV3	KGF	17:36	18:07	0:31	TRANSFORMER FAULT
618	17-Dec-2021	BENGALURU	66	HV2	CHANDAPURA	11:56	12:24	0:28	LINE CLEAR AVAILED
619	17-Dec-2021	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	8:00	8:05	0:05	LINE FAULT
620	17-Dec-2021	BENGALURU	220	MALUR 220 - SOMANAHALLI 1	VIKAS TEC PARK 220, SARJAPURA 220	7:38	8:12	0:34	LINE FAULT
621	17-Dec-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	7:34	7:43	0:09	LINE FAULT
622	17-Dec-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	18:24	21:52	3:28	LINE FAULT
623	17-Dec-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	23:55	23:59	0:04	LINE FAULT
624	17-Dec-2021	BENGALURU	220	HV1	MALUR 220	18:24	18:40	0:16	TRANSFORMER FAULT
625	17-Dec-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	18:24	18:44	0:20	MAIN SUPPLY FAILURE
626	17-Dec-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	18:24	18:44	0:20	MAIN SUPPLY FAILURE
627	17-Dec-2021	BENGALURU	220	HV1	SARJAPURA 220	12:03	13:45	1:42	LINE CLEAR AVAILED
628	17-Dec-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	12:03	12:08	0:05	MAIN SUPPLY FAILURE
629	17-Dec-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	12:03	12:08	0:05	MAIN SUPPLY FAILURE
630	17-Dec-2021	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	13:42	13:46	0:04	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
631	17-Dec-2021	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	13:42	13:46	0:04	LOAD CHANGE OVER
632	17-Dec-2021	BENGALURU	66	TELECOM LAYOUT - NRS 1	TELECOM LAYOUT	15:38	15:49	0:10	LINE CLEAR AVAILED
633	17-Dec-2021	BENGALURU	66	VIKAS TEC PARK 220 - RMZ	RMZ	7:38	8:12	0:34	MAIN SUPPLY FAILURE
634	17-Dec-2021	BENGALURU	66	VIKAS TEC PARK 220 - EMBASSY TEC VILLAGE	EMBASSY TEC VILLAGE	7:38	8:12	0:34	MAIN SUPPLY FAILURE
635	17-Dec-2021	BENGALURU	66	VIKAS TEC PARK 220 - PRIMAL	PRIMAL	7:38	8:12	0:34	MAIN SUPPLY FAILURE
636	17-Dec-2021	BENGALURU	66	HV1	NATIONAL COLLEGE	11:26	11:30	0:03	LINE CLEAR AVAILED
637	17-Dec-2021	BENGALURU	66	HV1	NATIONAL COLLEGE	13:55	14:00	0:05	LINE CLEAR AVAILED
638	17-Dec-2021	BENGALURU	66	HV5	NRS 220	14:30	14:39	0:08	TRANSFORMER FAULT
639	17-Dec-2021	BENGALURU	66	HV1	BTM 4TH PHASE	11:00	12:50	1:49	LINE CLEAR AVAILED
640	17-Dec-2021	BENGALURU	66	HV1	BRIDAGE MEADOWS	10:40	12:06	1:26	LINE CLEAR AVAILED
641	17-Dec-2021	BENGALURU	66	HV1	BRINDAVAN 220	14:53	17:28	2:35	TRANSFORMER FAULT
642	17-Dec-2021	BENGALURU	66	HV1	CHATRA	5:59	6:11	0:11	TRANSFORMER FAULT
643	17-Dec-2021	BENGALURU	66	HV1	CHATRA	7:33	7:41	0:08	TRANSFORMER FAULT
644	17-Dec-2021	BENGALURU	66	KC VALLEY - NAL(EHT)	NAL(EHT)	15:39	16:04	0:25	LINE FAULT
645	17-Dec-2021	BENGALURU	66	HV1	BRIGADE MEADOWS	23:29(16/12/2021)	00:14:00(17/12/2021)	0:45hrs	TRANSFORMER CHARGED
646	17-Dec-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	23:51:26(16-12-2021)	0:01(17-12-2021)	0:08hrs	LINE CHARGED
647	17-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
648	17-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
649	17-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:03(17.12.2021)			LINE OPEN,LINE CLEAR AVAILED
650	17-Dec-2021	GULBARGA	220	LV2	SEDAM_220	18:55	19:36	0:41	TRANSFORMER FAULT
651	17-Dec-2021	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	10:33	19:30	8:57	LINE CLEAR AVAILED
652	17-Dec-2021	GULBARGA	220	RTPS-LINGASUGUR2	RTPS_220	10:08	13:19	3:11	NFBC ISSUED
653	17-Dec-2021	GULBARGA	220	HUMNABAD-KAPNOOR1	KAPNOOR_220	12:56	16:23	3:27	NFBC ISSUED
654	17-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
655	17-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN,LINE CLEAR AVAILED
656	17-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:35			LINE OPEN,LINE CLEAR AVAILED
657	17-Dec-2021	GULBARGA	110	HV1	JAWALGERA_110	11:50	12:20	0:30	LINE CLEAR AVAILED
658	17-Dec-2021	GULBARGA	110	HV3	HATTI_110	6:39	6:45	0:06	TRANSFORMER FAULT
659	17-Dec-2021	GULBARGA	110	HV3	LADHA_110	16:07	16:56	0:49	LINE CLEAR AVAILED
660	17-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	11:52(16.12.2021)	8:30(17.12.2021)	20:38 hrs	LINE CHARGED
661	17-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	9:13	18:30	9:17	LINE CLEAR AVAILED
662	17-Dec-2021	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	9:13	18:30	9:17	LINE CLEAR AVAILED
663	17-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	20:30 (16.12.2021)	10:58(17.12.2021)	14:28HRS	LINE CHARGED
664	17-Dec-2021	GULBARGA	110	RAICHUR-GABBUR	GABBUR_110	1:50	1:55	0:05	MAIN SUPPLY FAILURE
665	17-Dec-2021	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	16:45	16:52	0:07	MAIN SUPPLY FAILURE
666	17-Dec-2021	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	9:00	18:40	9:40	MAIN SUPPLY FAILURE
667	17-Dec-2021	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	16:09	17:20	1:11	LINE CLEAR AVAILED
668	17-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110 ,MANVI_110	0:09	0:35	0:26	LINE FAULT
669	17-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	MADLAPUR_110 ,MANVI_110	3:00	3:12	0:12	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
670	17-Dec-2021	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	4:28	4:39	0:11	LINE FAULT
671	17-Dec-2021	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,SAIDAPUR_110,WADAGERA_110,SAN NATHI_110,CORE GREEN SUGAR_IPP	18:47	18:52	0:05	LINE FAULT
672	17-Dec-2021	GULBARGA	110	SINDHANOOR-SIRUGUPPA	SIRUGUPPA_110,DHADESU GUR_110,TEKKALKOTE_110,NSL SUGARS_IPP,SIRIGERE CROSS_110	15:40	20:50	5:10	LINE FAULT
673	17-Dec-2021	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,P D HALLI_110,BISIHALLI_110,J ANAKI_IPP,BASAI STEELS	16:44	16:54	0:10	LINE FAULT
674	17-Dec-2021	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110,GULBARGA SOUTH_110	11:20	17:38	6:18	LINE CLEAR AVAILED
675	17-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
676	17-Dec-2021	GULBARGA	66	ITTAGI-BENNEHALLI	KOTTUR_66,UJJAINI_66,BENNEHALLI_66	1:05	1:15	0:10	LINE FAULT
677	17-Dec-2021	HASSAN	220	ARSK2-SHMG	ARSKERE_220	16:27	16:57	0:30	HAND TRIPPED
678	17-Dec-2021	HASSAN	220	MRSSHN-HASSAN	MRSMSG_220	16:27	16:52	0:25	HAND TRIPPED
679	17-Dec-2021	HASSAN	220	MRSSHN-KBCRS	MRSMSG_220	16:55	17:21	0:26	HAND TRIPPED
680	17-Dec-2021	HASSAN	220	HV1	MSEZ_220	10:17	15:27	5:10	LINE CLEAR AVAILED
681	17-Dec-2021	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	11:49	12:46	0:57	NFBC ISSUED
682	17-Dec-2021	HASSAN	220	HV1	PUTTUR_220	7:12	15:51	8:39	LINE CLEAR AVAILED
683	17-Dec-2021	HASSAN	110	LV1	MSEZ_220	10:17	15:27	5:10	LINE CLEAR AVAILED
684	17-Dec-2021	HASSAN	110	LV1	PUTTUR_220	7:12	15:51	8:39	LINE CLEAR AVAILED
685	17-Dec-2021	HASSAN	220	SHRAVITY-SHIRALKOPPA	sharavathy_gen	10:30	15:02	4:32	NFBC ISSUED
686	17-Dec-2021	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_110	10:30	15:02	4:32	LINE CLEAR AVAILED
687	17-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	17:24 (16.12.2021)	8:06(17.12.2021)	14:32HRS	LINE CHARGED
688	17-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	17:59(17.12.2021)			LINE OPEN,LINE CLEAR AVAILED
689	17-Dec-2021	HASSAN	110	HV1	GURUVAYANKERE_110	10:05	14:07	4:02	LINE CLEAR AVAILED
690	17-Dec-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	16:17	16:48	0:31	NFBC ISSUED
691	17-Dec-2021	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	15:13	16:14	1:01	NFBC ISSUED
692	17-Dec-2021	HASSAN	110	HV2	HALADY_110	17:08	17:24	0:16	LINE CLEAR AVAILED
693	17-Dec-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:16	16:49	0:33	LINE CLEAR AVAILED
694	17-Dec-2021	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:12	16:14	1:02	LINE CLEAR AVAILED
695	17-Dec-2021	HASSAN	110	KEMAR-NANDHIKUR1	KEMAR_220	13:03	14:15	1:12	LINE CLEAR AVAILED
696	17-Dec-2021	HASSAN	110	KEMAR-BELMAN	KEMAR_220	10:19	13:01	2:42	LINE CLEAR AVAILED
697	17-Dec-2021	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	8:08	17:57	9:49	LINE CLEAR AVAILED
698	17-Dec-2021	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	10:18	13:01	2:43	NFBC ISSUED
699	17-Dec-2021	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	6:31	6:35	0:04	LINE FAULT
700	17-Dec-2021	MYSURU	220	HOOTAGALLI-VAJMANGALA	NO STATIONS EFFECTED	11:40	15:11	3:31	LINE CLEAR AVAILED
701	17-Dec-2021	MYSURU	66	HEBBANI-MEGALAPURA	CHIDRAVALLI_66	13:10	14:41	1:31	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
702	17-Dec-2021	MYSURU	66	HEBBANI-SFC4	NO STATIONS EFFECTED	17:08	18:34	1:26	LINE CLEAR AVAIED
703	17-Dec-2021	MYSURU	66	HEBBANI-SFC 5	NO STATIONS EFFECTED	17:08	18:34	1:26	LINE CLEAR AVAIED
704	17-Dec-2021	MYSURU	66	HUNSUR-ELWALA	ELAVALA_66 GAVADAGERE_66	10:39	18:23	7:43	LINE CLEAR AVAIED
705	17-Dec-2021	MYSURU	66	BILIKERE-GV GUDI	GVGUDI_66	6:16	6:30	0:14	LINE FAULT
706	17-Dec-2021	MYSURU	66	CHUNCHANAKATTE-KR NAGARA	NO STATIONS EFFECTED	3:35	3:48	0:12	LINE FAULT
707	17-Dec-2021	MYSURU	66	HV2	COWDALLI_66	11:48	13:50	2:01	LINE CLEAR AVAIED
708	17-Dec-2021	MYSURU	66	HANAGODU-HUNSUR	HANAGODU_66	10:00	18:24	8:24	LINE CLEAR AVAIED
709	17-Dec-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66VIRAJPET_66	15:41	17:08	1:27	LINE CLEAR AVAIED
710	17-Dec-2021	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66VIRAJPET_66	12:55	14:11	1:16	LINE CLEAR AVAIED
711	17-Dec-2021	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	9:29	9:34	0:05	LINE FAULT
712	17-Dec-2021	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	9:35	10:22	0:46	LINE FAULT
713	17-Dec-2021	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	16:17	16:38	0:21	LINE FAULT
714	17-Dec-2021	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	16:52	21:59	5:07	LINE FAULT
715	17-Dec-2021	MYSURU	66	KR NAGARA-KUSHALNAGARA	BILIKERE_66 KR NAGARA_66GVGUDI_66 DMG_HALLI_66	3:35	3:53	0:18	LINE FAULT
716	17-Dec-2021	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	18:16	21:27	3:10	LINE CLEAR AVAIED
717	17-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN,LINE CLEAR AVAIED
718	17-Dec-2021	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	8:31:00 (15.12.2021)	15:16:00 (17.12.2021)	54:45 hrs	LINE CHARGED
719	17-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAIED
720	17-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN,LINE CLEAR AVAIED
721	17-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN,LINE CLEAR AVAIED
722	17-Dec-2021	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	11:49	17:54	6:05	LINE CLEAR AVAIED
723	17-Dec-2021	TUMKUR	220	HIRIYUR 220KV- ENERCON1_IPP_66	ENERCON1_IPP_66	5:06	5:42	0:36	LINE FAULT
724	17-Dec-2021	TUMKUR	220	KB CROSS 220kv- SHIMOGA1	KBCROSS_220	16:54	17:19	0:25	HAND TRIPPED
725	17-Dec-2021	TUMKUR	110	TR-1	KATRIKEHAL_110	16:57	17:27	0:30	HAND TRIPPED
726	17-Dec-2021	TUMKUR	110	TR-1	SOMLAPURA_110	12:51	13:42	0:51	LINE CLEAR AVAIED
727	17-Dec-2021	TUMKUR	66	ANTHRASANAHALLI 220kv- KORATAGERE66	KORATAGERE_66,CHIKKAT OTALKERE_66	16:44	19:14	2:29	LINE CLEAR AVAIED
728	17-Dec-2021	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	11:49	17:55	6:06	LINE CLEAR AVAIED
729	17-Dec-2021	TUMKUR	66	TR-1	BELLAVI_66	13:33	15:19	1:46	LINE CLEAR AVAIED
730	17-Dec-2021	TUMKUR	66	TR-2	BELLAVI_66	11:23	15:19	3:55	LINE CLEAR AVAIED
731	17-Dec-2021	TUMKUR	66	TR-2	BEVINAHALLI_66	11:49	12:40	0:51	LINE CLEAR AVAIED
732	17-Dec-2021	TUMKUR	66	TR-1	CHALLAKERE_66	15:10	16:26	1:16	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
733	17-Dec-2021	TUMKUR	66	TR-1	CHITRADURGA_66	20:55	21:20	0:25	TRANSFORMER FAULT
734	17-Dec-2021	TUMKUR	66	GUTUR_66-DAVANGERE SRS2	GUTUR_66	11:39	17:39	6:00	LINE CLEAR AVAILED
735	17-Dec-2021	TUMKUR	66	TR-1	GUTUR_66	11:39	17:44	6:05	LINE CLEAR AVAILED
736	17-Dec-2021	TUMKUR	66	TR-1	HANAGAL_66	11:00	11:11	0:10	LINE CLEAR AVAILED
737	17-Dec-2021	TUMKUR	66	TR-2	HINDASGHATTA_66	10:43	12:36	1:52	LINE CLEAR AVAILED
738	17-Dec-2021	TUMKUR	66	HIRIYUR 220KV-P R PURA	P R PURA_66	1:02	1:16	0:14	LINE FAULT
739	17-Dec-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:52	6:55	0:03	LINE FAULT
740	17-Dec-2021	TUMKUR	66	TR-1	KUNIGAL_66	15:54	18:21	2:27	LINE CLEAR AVAILED
741	17-Dec-2021	TUMKUR	66	TR-2	KUNIGAL_66	15:54	18:21	2:27	LINE CLEAR AVAILED
742	17-Dec-2021	TUMKUR	66	TR-1	MATHOD_66	2:59	3:05	0:05	TRANSFORMER FAULT
743	17-Dec-2021	TUMKUR	66	TR-1	MATHOD_66	7:34	8:10	0:35	TRANSFORMER FAULT
744	17-Dec-2021	TUMKUR	66	TR-2	MATHOD_66	6:10	6:20	0:10	TRANSFORMER FAULT
745	17-Dec-2021	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE66	NAYAKANHATTI_66, HIREMALLANAHOLE_66	6:47	7:20	0:32	LINE FAULT
746	17-Dec-2021	TUMKUR	66	TR-1	RAMAPURA_66	15:02	15:46	0:43	LINE CLEAR AVAILED
747	17-Dec-2021	TUMKUR	66	TR-2	RAMAPURA_66	15:20	15:46	0:25	LINE CLEAR AVAILED
748	17-Dec-2021	TUMKUR	66	TR-1	RANGANATHAPURA_66	10:15	11:27	1:11	LINE CLEAR AVAILED
749	17-Dec-2021	TUMKUR	66	TR-2	RANGANATHAPURA_66	10:53	11:26	0:33	HAND TRIPPED
750	17-Dec-2021	TUMKUR	66	TR-1	THIPPUR_66	10:50	14:20	3:29	LINE CLEAR AVAILED
751	17-Dec-2021	TUMKUR	66	TR-1	YEDIYUR_66	13:37	13:50	0:13	LINE CLEAR AVAILED
752	18-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
753	18-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
754	18-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
755	18-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
756	18-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
757	18-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
758	18-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
759	18-Dec-2021	BAGALKOT	220	CHIKKODI-KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56(26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
760	18-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25(08.12.2021)			LINE OPEN, LINE FAULT
761	18-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
762	18-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
763	18-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
764	18-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
765	18-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
766	18-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE FAULT
767	18-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
768	18-Dec-2021	BAGALKOT	110	110/11KV,HV2	AIGALI_110	8:03	8:13	0:10	TRANSFORMER FAULT
769	18-Dec-2021	BAGALKOT	110	ALMEL-JAMAKHANDI SUGARS	ALMEL_110	19:06	19:45	0:39	LINE CLEAR AVAILED
770	18-Dec-2021	BAGALKOT	110	ALMEL-JKPR SUGARS	ALMEL_110	19:06	19:45	0:39	LINE CLEAR AVAILED
771	18-Dec-2021	BAGALKOT	110	BYADAGI-SUZLON	BYDAGI_110	23:17	23:27	0:10	LINE FAULT
772	18-Dec-2021	BAGALKOT	110	110/33KV,HV3	GADAG_110 & LAKKUNDI& HULKOTI_33	10:03	17:16	7:13	LINE CLEAR AVAILED
773	18-Dec-2021	BAGALKOT	110	110/33KV,HV4	GADAG_110 & LAKKUNDI& HULKOTI_34	10:03	17:16	7:13	LINE CLEAR AVAILED
774	18-Dec-2021	BAGALKOT	110	HUNGUND-JINDAL	HUNGUND_110	5:01	5:25	0:24	LINE FAULT
775	18-Dec-2021	BAGALKOT	110	110/11KV,HV 1&2	MANTUR_110	7:38	7:50	0:12	TRANSFORMER FAULT
776	18-Dec-2021	BAGALKOT	110	RON-GAMESH	RON_110	15:48	16:18	0:30	LINE CLEAR AVAILED
777	18-Dec-2021	BAGALKOT	110	SHIGGOAN-AVANTI	SHIGGOAN_110	15:31	15:45	0:14	LINE FAULT
778	18-Dec-2021	BAGALKOT	220	KUDACHI- MAHALINGAPUR2	KUDACHI_220	3:00	3:34	0:34	LINE FAULT
779	18-Dec-2021	BAGALKOT	110	110/11KV,HV1	KUDACHI_220	13:21	13:37	0:16	LINE CLEAR AVAILED
780	18-Dec-2021	BAGALKOT	110	110/11KV,HV1	KUDACHI_220	13:50	14:01	0:11	LINE CLEAR AVAILED
781	18-Dec-2021	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	9:15	15:08	5:53	LINE CLEAR AVAILED
782	18-Dec-2021	BAGALKOT	220	220/110KV, HV1& LV1	HUBLI_220	10:29	13:05	2:36	LINE CLEAR AVAILED
783	18-Dec-2021	BAGALKOT	110	110/11KV,HV1	ZALKI_110	18:13	18:15	0:02	TRANSFORMER FAULT
784	18-Dec-2021	BAGALKOT	110	110/11KV,HV1	ZALKI_110	13:34	13:37	0:03	TRANSFORMER FAULT
785	18-Dec-2021	BAGALKOT	110	110/11KV, HV2	SHIROL_110	12:00	14:00	2:00	LINE CLEAR AVAILED
786	18-Dec-2021	BAGALKOT	110	MANTUR- SHIROL	MANTUR_110	14:05	17:05	3:00	LINE CLEAR AVAILED
787	18-Dec-2021	BAGALKOT	110	110/11KV, HV2	KATARKI_110	11:05	14:35	3:03	LINE CLEAR AVAILED
788	18-Dec-2021	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	9:15	15:08	5:53	LINE CLEAR AVAILED
789	18-Dec-2021	BENGALURU	66	ABBIGERE - YELAHANKA 220	ABBIGERE	11:16	11:21	0:05	LOAD CHANGE OVER
790	18-Dec-2021	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	18:32	18:36	0:04	LOAD CHANGE OVER
791	18-Dec-2021	BENGALURU	66	ATTUR YELAHANKA - YELAHANKA 220	ATTUR YELAHANKA	11:20	12:42	1:22	LINE CLEAR AVAILED
792	18-Dec-2021	BENGALURU	66	ATTUR YELAHANKA - YELAHANKA 220	ATTUR YELAHANKA	16:18	17:57	1:39	LINE CLEAR AVAILED
793	18-Dec-2021	BENGALURU	66	CESSNA - SHOBHA APARTMENT	CESSNA, EXORA	10:35	10:45	0:10	LOAD CHANGE OVER
794	18-Dec-2021	BENGALURU	66	CESSNA - VIKAS TECH PARK 220	CESSNA, EXORA	17:05	17:10	0:05	LOAD CHANGE OVER
795	18-Dec-2021	BENGALURU	66	CHANDRA LAYOUT - VRISHABHAVATHI 220	CHANDRA LAYOUT	10:22	16:37	6:15	LINE CLEAR AVAILED
796	18-Dec-2021	BENGALURU	66	HANUMANTHNAGARA - SOMANAHALLI 220	HANUMANTHNAGARA, YEDUMADU	9:27	9:32	0:05	LOAD CHANGE OVER
797	18-Dec-2021	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	14:10	14:20	0:10	LINE FAULT
798	18-Dec-2021	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	15:18	15:20	0:02	LOAD CHANGE OVER
799	18-Dec-2021	BENGALURU	66	HV1	JAYANAGARA	16:20	16:27	0:07	LINE CLEAR AVAILED
800	18-Dec-2021	BENGALURU	66	SAHAKARINAGAR - MANYATHA TECH PARK 220	SAHAKARINAGAR	11:23	12:47	1:24	LINE CLEAR AVAILED
801	18-Dec-2021	BENGALURU	66	SAHAKARINAGAR - YELAHANKA 220	SAHAKARINAGAR	16:24	17:51	1:27	LOAD CHANGE OVER
802	18-Dec-2021	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	NO STATION AFFECTED	11:54	12:19	0:25	LINE FAULT
803	18-Dec-2021	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI	10:15	10:20	0:05	LOAD CHANGE OVER
804	18-Dec-2021	BENGALURU	66	SHOBHA APARTMENT - HSR LAYOUT 220	SHOBHA APARTMENT	10:38	16:15	5:37	LINE CLEAR AVAILED
805	18-Dec-2021	BENGALURU	66	HV1	TADIGOLU	16:03	16:51	0:47	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
806	18-Dec-2021	BENGALURU	66	HV1	MALLANAYAKANA HALLI	9:05	9:50	0:44	LINE CLEAR AVAILED
807	18-Dec-2021	BENGALURU	66	HV3	KGF	8:46	9:20	0:34	LINE CLEAR AVAILED
808	18-Dec-2021	BENGALURU	66	HV1	DODDAKARI	13:33	15:22	1:48	LINE CLEAR AVAILED
809	18-Dec-2021	BENGALURU	66	HV2	DODDAKARI	11:51	13:30	1:39	LINE CLEAR AVAILED
810	18-Dec-2021	BENGALURU	66	HV2	DODDAKARI	15:09	15:22	0:12	TRANSFORMER FAULT
811	18-Dec-2021	BENGALURU	66	HV2	DODDAKARI	17:08	17:16	0:07	TRANSFORMER FAULT
812	18-Dec-2021	BENGALURU	66	HV2	DODDAKARI	18:16	18:46	0:30	TRANSFORMER FAULT
813	18-Dec-2021	BENGALURU	66	HV2	HOSKOTE 66	17:30	17:45	0:15	LINE CLEAR AVAILED
814	18-Dec-2021	BENGALURU	66	HV2	HOSKOTE 66	15:25	15:55	0:30	LINE CLEAR AVAILED
815	18-Dec-2021	BENGALURU	220	HV1	DB PURA 220	11:01	13:26	2:25	LINE CLEAR AVAILED
816	18-Dec-2021	BENGALURU	220	LV1	DB PURA 220	11:01	13:37	2:36	LINE CLEAR AVAILED
817	18-Dec-2021	BENGALURU	220	HV2	DB PURA 220	13:28	17:10	3:42	LINE CLEAR AVAILED
818	18-Dec-2021	BENGALURU	220	LV2	DB PURA 220	13:28	17:18	3:50	LINE CLEAR AVAILED
819	18-Dec-2021	BENGALURU	66	HV1	CHELUR	17:15	17:51	0:35	LINE CLEAR AVAILED
820	18-Dec-2021	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	10:16	10:32	0:16	LINE FAULT
821	18-Dec-2021	BENGALURU	66	WELCAST STEEL - ABBIGERE	ABBIGERE	11:23	12:15	0:52	LINE FAULT
822	18-Dec-2021	BENGALURU	66	WELCAST STEEL - ABBIGERE	ABBIGERE	12:15	12:50	0:35	LINE FAULT
823	18-Dec-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	13:29	13:41	0:11	LINE CLEAR AVAILED
824	18-Dec-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 2	CHIKKABALLAPURA I/A, CHIKKABALLAPURA URBAN, NALLIMARADANAHALLI	17:10	17:18	0:08	LINE CLEAR AVAILED
825	18-Dec-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	13:29	13:41	0:11	LINE CLEAR AVAILED
826	18-Dec-2021	BENGALURU	66	DB PURA 220 - CHIKKABALLAPURA I/A 1	TUBUGERE	17:10	17:18	0:08	LINE CLEAR AVAILED
827	18-Dec-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	11:00	11:07	0:07	LINE CLEAR AVAILED
828	18-Dec-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 1	KUNDANA	13:29	13:39	0:10	LINE CLEAR AVAILED
829	18-Dec-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	11:00	11:07	0:07	LINE CLEAR AVAILED
830	18-Dec-2021	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	DEVANAHALLI	13:29	13:39	0:10	LINE CLEAR AVAILED
831	18-Dec-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:00	11:07	0:06	LINE CLEAR AVAILED
832	18-Dec-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:40	12:00	0:20	LINE FAULT
833	18-Dec-2021	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	13:29	13:37	0:08	LINE CLEAR AVAILED
834	18-Dec-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	11:00	11:07	0:07	LINE CLEAR AVAILED
835	18-Dec-2021	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:29	13:37	0:08	LINE CLEAR AVAILED
836	18-Dec-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	13:29	13:39	0:10	LINE CLEAR AVAILED
837	18-Dec-2021	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	17:10	17:18	0:08	LINE CLEAR AVAILED
838	18-Dec-2021	BENGALURU	66	D PALYA - MANDIKAL	MANDIKAL, PERESANDRA	11:50	12:07	0:17	LINE CLEAR AVAILED
839	18-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	10:34	10:37	0:03	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
840	18-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - KUMBALAGODU	KUMBALAGODU, PROVIDENT HOUSING (EHT), CHANDRAPPA CIRCLE	18:14	18:16	0:02	LOAD CHANGE OVER
841	18-Dec-2021	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, THORALAKKI	12:48	13:27	0:39	MAIN SUPPLY FAILURE
842	18-Dec-2021	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	12:48	13:27	0:39	MAIN SUPPLY FAILURE
843	18-Dec-2021	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	12:48	13:24	0:36	MAIN SUPPLY FAILURE
844	18-Dec-2021	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	12:48	13:33	0:45	MAIN SUPPLY FAILURE
845	18-Dec-2021	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	12:48	13:18	0:30	LINE FAULT
846	18-Dec-2021	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	12:48	13:33	0:45	MAIN SUPPLY FAILURE
847	18-Dec-2021	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	12:48	13:26	0:38	MAIN SUPPLY FAILURE
848	18-Dec-2021	BENGALURU	220	HV1	MALUR 220	12:48	13:24	0:36	MAIN SUPPLY FAILURE
849	18-Dec-2021	BENGALURU	220	HV2	MALUR 220	12:48	13:24	0:36	MAIN SUPPLY FAILURE
850	18-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN, LINE FAULT
851	18-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
852	18-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
853	18-Dec-2021	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	20:20			LINE OPEN,LINE CLEAR AVAILED
854	18-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:03(17.12.2021)	6:50(18.12.2021)	8:47HRS	LINE CHARGED
855	18-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
856	18-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:35(17.12.2021)			LINE OPEN,LINE CLEAR AVAILED
857	18-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN,LINE CLEAR AVAILED
858	18-Dec-2021	GULBARGA	110	HATTI-RENEWSOLAR_IPP	HATTI_110	18:25(18.12.2021)			LINE OPEN,LINE CLEAR AVAILED
859	18-Dec-2021	GULBARGA	110	PD HALLI-JANAKI STEELS	PD_HALLI_110	10:55(18.12.2021)			LINE OPEN,LINE CLEAR AVAILED
860	18-Dec-2021	GULBARGA	110	HV2	MANVI_110	14:18	14:45	0:27	TRANSFORMER FAULT
861	18-Dec-2021	GULBARGA	110	HV1	NIRNA_110	13:02	13:16	0:14	LINE CLEAR AVAILED
862	18-Dec-2021	GULBARGA	110	BISILAHALLI-ALIPUR	BISILAHALLI_110	6:18	6:26	0:08	MAIN SUPPLY FAILURE
863	18-Dec-2021	GULBARGA	110	METRI-ALIPUR	METRI_110	16:35	16:40	0:05	MAIN SUPPLY FAILURE
864	18-Dec-2021	GULBARGA	110	METRI-ALIPUR	METRI_110	21:25	21:35	0:10	MAIN SUPPLY FAILURE
865	18-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	6:21	6:33	0:12	MAIN SUPPLY FAILURE
866	18-Dec-2021	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,P D HALLI_110,BISIHALLI_110,J ANAKI_IPP,BASAI STEELS	6:17	6:26	0:09	LINE FAULT
867	18-Dec-2021	GULBARGA	110	PD HALLI-ALIPUR	PD_HALLI_110	6:18	6:27	0:09	MAIN SUPPLY FAILURE
868	18-Dec-2021	GULBARGA	110	BISLAHALLI-BELLARYNORTH	BISIHALLI_110	6:18	6:20	0:02	MAIN SUPPLY FAILURE
869	18-Dec-2021	GULBARGA	110	GULBARGAWEST-KAPNOOR	GULBARGAWEST_110	10:25	18:50	8:25	NFBC ISSUED
870	18-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	6:23	6:33	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
871	18-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	17:54	18:05	0:11	MAIN SUPPLY FAILURE
872	18-Dec-2021	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGAWEST_110,GULBARGA SOUTH_110	10:14	18:50	8:36	LINE CLEAR AVAILED
873	18-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	6:22	6:33	0:11	LINE FAULT
874	18-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	17:54	18:04	0:10	LINE FAULT
875	18-Dec-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	21:15	21:22	0:07	LINE FAULT
876	18-Dec-2021	GULBARGA	110	MUNIRABAD-HAGRI	HAGRI_110,SANKLAPUR_110,RBSNS,KAMALAPUR_110	11:50	13:53	2:03	LINE CLEAR AVAILED
877	18-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	19:10	19:17	0:07	LINE FAULT
878	18-Dec-2021	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	19:10	19:17	0:07	LINE FAULT
879	18-Dec-2021	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	23:05	23:15	0:10	LINE FAULT
880	18-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
881	18-Dec-2021	GULBARGA	66	HV2	HALAVAGALU_66	7:30	7:35	0:05	TRANSFORMER FAULT
882	18-Dec-2021	GULBARGA	66	HV2	HALAVAGALU_66	8:30	8:35	0:05	TRANSFORMER FAULT
883	18-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	17:59(17.12.2021)	9:50(18.12.2021)	15:51hrs	LINE CHARGED
884	18-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	17:48(18.12.2021)			LINE OPEN,LINE CLEAR AVAILED
885	18-Dec-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:06	13:22	3:16	LINE CLEAR AVAILED
886	18-Dec-2021	HASSAN	220	MRSSHM-VARAH13	MRSMG_220	10:29	15:46	5:17	LINE CLEAR AVAILED
887	18-Dec-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:06	13:22	3:16	NFBC ISSUED
888	18-Dec-2021	HASSAN	220	VARAHI-SHMG3	varahi_gen	10:29	15:46	5:17	LINE CLEAR AVAILED
889	18-Dec-2021	HASSAN	110	HV2	HALADY_110	11:38	15:29	3:51	LINE CLEAR AVAILED
890	18-Dec-2021	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	12:57	14:15	1:18	NFBC ISSUED
891	18-Dec-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	12:57	14:15	1:18	NFBC ISSUED
892	18-Dec-2021	HASSAN	66	HV1	BALLUPETE_66	11:42	12:26	0:44	LINE CLEAR AVAILED
893	18-Dec-2021	HASSAN	66	HV2	BELUR_66	8:00	14:22	6:22	TRANSFORMER FAULT
894	18-Dec-2021	HASSAN	66	HV2	HOLALUR_66	12:01	12:12	0:11	LINE CLEAR AVAILED
895	18-Dec-2021	MYSURU	66	HV1	ADICHUNCHANAGIRI_66	0:50	1:22	0:32	TRANSFORMER FAULT
896	18-Dec-2021	MYSURU	66	HV1	ADICHUNCHANAGIRI_66	10:30	11:51	1:21	LINE CLEAR AVAILED
897	18-Dec-2021	MYSURU	66	BESAGAGARAHALLI-DUDDENHALLY	NO STATIONS EFFECTED	18:41	19:45	1:04	LINE FAULT
898	18-Dec-2021	MYSURU	66	HV1	DUNDANAHALLI_66	11:11	11:29	0:18	LINE CLEAR AVAILED
899	18-Dec-2021	MYSURU	66	HAMPAPURA-BASARALU	KOPPA_66 BESAGARAHALLI_66	18:07	18:17	0:10	LINE FAULT
900	18-Dec-2021	MYSURU	66	HV2	HANNUR_66	12:15	17:12	4:57	LINE CLEAR AVAILED
901	18-Dec-2021	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	17:36	18:15	0:38	HAND TRIPPED
902	18-Dec-2021	MYSURU	220	HV2	KADAKOLA_220	10:12	11:59	1:46	LINE CLEAR AVAILED
903	18-Dec-2021	MYSURU	66	KADAKOLA-NANJANGUD1	NO STATIONS EFFECTED	10:01	13:01	3:00	LOAD CHANGE OVER
904	18-Dec-2021	MYSURU	66	KADAKOLA-NANJANGUD2	NO STATIONS EFFECTED	10:01	13:01	3:00	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
905	18-Dec-2021	MYSURU	66	KADAKOLA-MYSORE SOUTH	NO STATIONS EFFECTED	10:07	13:17	3:10	LOAD CHANGE OVER
906	18-Dec-2021	MYSURU	66	KOLLEGALA-CR NAGARA	NO STATIONS EFFECTED	12:16	12:48	0:31	LINE FAULT
907	18-Dec-2021	MYSURU	66	KUSHALNAGARA-RAMANTHAPURA1	RAMATHPURA_66 ALURSIDDAPURA_66 KANAGAL_66 RUDRAPATNA_66 CB HALLI_66	18:12	18:18	0:05	LINE FAULT
908	18-Dec-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	MAMBALLI_66	13:09	13:15	0:05	LINE FAULT
909	18-Dec-2021	MYSURU	66	MADHUVANAHALLI-MAMBALLI	NO STATIONS EFFECTED	18:03	19:32	1:28	LINE CLEAR AVAILED
910	18-Dec-2021	MYSURU	66	MADHUVANAHALLI-KUNTHUR	NO STATIONS EFFECTED	17:37	19:12	1:34	LINE CLEAR AVAILED
911	18-Dec-2021	MYSURU	66	MADHUVANAHALLI-CR NAGARA 1	NO STATIONS EFFECTED	19:13	19:29	0:15	HAND TRIPPED
912	18-Dec-2021	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	17:39	19:30	1:51	LINE CLEAR AVAILED
913	18-Dec-2021	MYSURU	66	HV2	MEGALAPURA_66	13:25	15:20	1:54	LINE CLEAR AVAILED
914	18-Dec-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	11:58	12:07	0:09	LINE CLEAR AVAILED
915	18-Dec-2021	MYSURU	66	HV1	TUBINKERE_66	15:16	16:04	0:48	LINE CLEAR AVAILED
916	18-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN,LINE CLEAR AVAILED
917	18-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
918	18-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN,LINE CLEAR AVAILED
919	18-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN,LINE CLEAR AVAILED
920	18-Dec-2021	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	2:10	7:34	5:24	LINE CLEAR AVAILED
921	18-Dec-2021	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	10:31	17:38	7:07	LINE CLEAR AVAILED
922	18-Dec-2021	TUMKUR	220	NITTUR 220-NELAMANGALA	NITTUR_220	11:48	14:19	2:30	LINE CLEAR AVAILED
923	18-Dec-2021	TUMKUR	110	TR-2	BANDIHALLI_110	12:12	12:42	0:30	LINE CLEAR AVAILED
924	18-Dec-2021	TUMKUR	110	TR-1	BANDIHALLI_110	12:44	13:01	0:17	LINE CLEAR AVAILED
925	18-Dec-2021	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110, TALKERE_110,KADEHALLI_110,	1:50	2:14	0:24	LINE FAULT
926	18-Dec-2021	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	10:31	17:38	7:07	LINE CLEAR AVAILED
927	18-Dec-2021	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66 , TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	18:17	18:52	0:35	LINE FAULT
928	18-Dec-2021	TUMKUR	66	TR-1	DEVARAHALLI_66	13:13	13:29	0:15	HAND TRIPPED
929	18-Dec-2021	TUMKUR	66	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:45	11:55	0:09	HAND TRIPPED
930	18-Dec-2021	TUMKUR	66	TR-1	GOWRASAMUDRA_66	10:12	11:13	1:00	LINE CLEAR AVAILED
931	18-Dec-2021	TUMKUR	66	TR-1	MADHUGIRI_220	15:36	15:58	0:21	TRANSFORMER FAULT
932	18-Dec-2021	TUMKUR	66	SAVALANGA 66kv-HNLI220_NYMT	SAVALANGA_66	17:08	17:54	0:45	LINE CLEAR AVAILED
933	18-Dec-2021	TUMKUR	66	TR-1	SAVALANGA_66	17:07	18:57	1:50	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
934	18-Dec-2021	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66	7:33	7:47	0:14	LINE FAULT
935	18-Dec-2021	TUMKUR	66	TR-2	GUTTUR_66	11:12	18:36	7:24	LINE CLEAR AVAILED
936	19-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
937	19-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVAILED
938	19-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17(23.02.2021)			LINE OPEN, LINE FAULT
939	19-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
940	19-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15(24.06.2021)			LINE OPEN,LINE CLEAR AVAILED
941	19-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
942	19-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN,LINE CLEAR AVAILED
943	19-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56(26.11.2021)			LINE OPEN,LINE CLEAR AVAILED
944	19-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25(08.12.2021)			LINE OPEN, LINE FAULT
945	19-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
946	19-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
947	19-Dec-2021	BAGALKOT	220	HUBLI-SIRS1	HUBLI_220	11:00(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
948	19-Dec-2021	BAGALKOT	220	HUBLI-SIRS2	HUBLI_220	11:01(13.12.2021)			LINE OPEN,LINE CLEAR AVAILED
949	19-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVAILED
950	19-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE FAULT
951	19-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE CLEAR AVAILED
952	19-Dec-2021	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	23:33	23:38	0:05	TRANSFORMER FAULT
953	19-Dec-2021	BAGALKOT	110	110/11KV,HV1	HALAKI_110	10:44	15:31	4:47	LINE CLEAR AVAILED
954	19-Dec-2021	BAGALKOT	110	110/11KV,HV3	HUKKERI_110	11:29	15:06	3:37	LINE CLEAR AVAILED
955	19-Dec-2021	BAGALKOT	110	JAMBAGI-HALAKI(MUDHOL)	JAMBAGI_110	10:39	15:31	4:52	LINE CLEAR AVAILED
956	19-Dec-2021	BAGALKOT	110	VAJRAMATTI-JAMBAGI	JAMBAGI_110	12:02	15:32	3:30	LINE CLEAR AVAILED
957	19-Dec-2021	BAGALKOT	110	JAMBAGI-HALAKI(MUDHOL)	JAMBAGI_110	15:37	15:47	3:37	LINE CLEAR AVAILED
958	19-Dec-2021	BAGALKOT	110	110/11KV,HV 1&2	MANTUR_110	15:03	15:17	0:14	TRANSFORMER FAULT
959	19-Dec-2021	BAGALKOT	110	HUBLI-TARIHAL	TARIHAL_110	2:54	13:44	10:50	LINE CLEAR AVAILED
960	19-Dec-2021	BAGALKOT	220	220/110KV, HV3& LV3	HUBLI_220	3:17	11:24	8:07	TRANSFORMER FAULT
961	19-Dec-2021	BAGALKOT	110	HUBLI- TARIHAL1	HUBLI_220	15:20	15:26	0:06	HAND TRIPPED
962	19-Dec-2021	BAGALKOT	110	HUBLI- TARIHAL2	HUBLI_220	15:21	15:26	0:05	HAND TRIPPED
963	19-Dec-2021	BAGALKOT	110	110/11KV, HV3	RANEBENNUR_220	4:30	9:00	4:30	TRANSFORMER FAULT
964	19-Dec-2021	BAGALKOT	110	110/11KV, HV3	RANEBENNUR_220	9:00	14:21	5:21	LINE CLEAR AVAILED
965	19-Dec-2021	BAGALKOT	110	VAJRAMATTI- MUDHOL(K.D.JAMBAGI)	VAJRAMATTI_220	12:10	15:17	3:07	LINE CLEAR AVAILED
966	19-Dec-2021	BAGALKOT	110	VAJRAMATTI220-MUDHOL	MUDHOL_110	12:03	12:11	0:08	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
967	19-Dec-2021	BAGALKOT	110	VAJRAMATTI220-MUDHOL	MUDHOL_110	14:19	14:36	0:17	MAIN SUPPLY FAILURE
968	19-Dec-2021	BAGALKOT	110	VAJRAMATTI220-MUDHOL	MUDHOL_110	15:13	15:21	0:08	MAIN SUPPLY FAILURE
969	19-Dec-2021	BAGALKOT	110	ZALKI-INDI 1&2	ZALKI_110	6:58	7:25	0:27	LINE FAULT
970	19-Dec-2021	BAGALKOT	110	ZALKI-CHADCHAN	ZALKI_110	7:05	7:29	0:24	HAND TRIPPED
971	19-Dec-2021	BENGALURU	66	A STATION 66 - A STATION 220	A STATION 66	12:48	12:55	0:07	LOAD CHANGE OVER
972	19-Dec-2021	BENGALURU	66	A STATION 66 - NRS 220	A STATION 66	18:02	18:12	0:10	LOAD CHANGE OVER
973	19-Dec-2021	BENGALURU	66	SHOBHA INDRAPRASTA - A STATION 220	SHOBHA INDRAPRASTA	9:43	9:46	0:03	LOAD CHANGE OVER
974	19-Dec-2021	BENGALURU	66	VICTORIA - A STATION 220	VICTORIA	10:08	10:13	0:05	LOAD CHANGE OVER
975	19-Dec-2021	BENGALURU	66	VICTORIA - NRS 220	VICTORIA	18:16	18:20	0:04	LOAD CHANGE OVER
976	19-Dec-2021	BENGALURU	66	BIDADI 220 - BOSCH (EHT)	BOSCH (EHT)	9:02	10:49	1:47	LINE FAULT
977	19-Dec-2021	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	9:15	9:20	0:05	LOAD CHANGE OVER
978	19-Dec-2021	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	15:15	15:20	0:05	LOAD CHANGE OVER
979	19-Dec-2021	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA, YEDUMADU	10:45	10:50	0:05	LOAD CHANGE OVER
980	19-Dec-2021	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 2	RANGANDODDI	11:58	12:04	0:06	LINE FAULT
981	19-Dec-2021	BENGALURU	66	KANTEERAVA - A STATION 220	KANTEERAVA	10:13	17:37	7:24	LINE CLEAR AVAILED
982	19-Dec-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	10:56	11:02	0:06	LOAD CHANGE OVER
983	19-Dec-2021	BENGALURU	66	KOTHIPURA 220 - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	17:08	17:13	0:05	LOAD CHANGE OVER
984	19-Dec-2021	BENGALURU	66	NANDINI LAYOUT - SRS PEENYA 220	NANDINI LAYOUT	11:45	11:56	0:11	MAIN SUPPLY FAILURE
985	19-Dec-2021	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	13:03	13:09	0:06	LOAD CHANGE OVER
986	19-Dec-2021	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	11:30	13:15	1:45	LINE CLEAR AVAILED
987	19-Dec-2021	BENGALURU	66	SRS PEENYA 220 - NRS 1	NANDINI LAYOUT	11:45	11:56	0:11	LINE FAULT
988	19-Dec-2021	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI	8:20	8:30	0:10	LOAD CHANGE OVER
989	19-Dec-2021	BENGALURU	66	HV1	YEDUMADU	10:29	10:40	0:11	TRANSFORMER FAULT
990	19-Dec-2021	BENGALURU	66	HV2	N G HULKUR	11:39	12:53	1:14	LINE CLEAR AVAILED
991	19-Dec-2021	BENGALURU	220	HV1	BEGUR 220	10:20	14:08	3:47	LINE CLEAR AVAILED
992	19-Dec-2021	BENGALURU	66	HV1	BANGARPET	16:00	17:21	1:20	LINE CLEAR AVAILED
993	19-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	13:40	13:45	0:05	LINE FAULT
994	19-Dec-2021	BENGALURU	66	HV2	MANCHENAHALLI	8:06	8:39	0:33	LINE CLEAR AVAILED
995	19-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN, LINE FAULT
996	19-Dec-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	00:15(19.12.2021)			LINE OPEN,LINE CLEAR AVAILED
997	19-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
998	19-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
999	19-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:04(19.12.2021(LINE OPEN,LINE CLEAR AVAILED
1000	19-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	2:11	6:25	4:14	LINE CLEAR AVAILED
1001	19-Dec-2021	GULBARGA	220	RTPS-LINGASUGUR1	LINGASUGUR_220	20:20(18.12.2021)	13:37(19.12.2021)	17:17HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1002	19-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1003	19-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:13(19.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1004	19-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1005	19-Dec-2021	GULBARGA	110	HV1	MANVI_110	23:13	23:16	0:03	TRANSFORMER FAULT
1006	19-Dec-2021	GULBARGA	110	HV1	MANVI_110	23:19	23:22	0:03	TRANSFORMER FAULT
1007	19-Dec-2021	GULBARGA	110	PD HALLI-JANAKI STEELS	PD_HALLI_110	10:55(18.12.2021	12:58(19.12.2021	26:03 hrs	LINE CHARGED
1008	19-Dec-2021	GULBARGA	110	PD HALLI-ALIPUR	PD_HALLI_110	18:00	18:24	0:24	MAIN SUPPLY FAILURE
1009	19-Dec-2021	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	3:20	3:25	0:05	MAIN SUPPLY FAILURE
1010	19-Dec-2021	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	13:55	14:00	0:05	MAIN SUPPLY FAILURE
1011	19-Dec-2021	GULBARGA	110	HATTI-RENEWSOLAR_IPP	HATTI_110	18:25(18.12.2021)	00:24(19.12.2021)	5:59HRS	LINE CHARGED
1012	19-Dec-2021	GULBARGA	110	MASKI-SINDHNOOR	MASKI_110	6:09	6:31	0:22	MAIN SUPPLY FAILURE
1013	19-Dec-2021	GULBARGA	110	MASKI-RENEWSOLAR_IPP	MASKI_110	17:55	22:30	4:35	LINE CLEAR AVAILED
1014	19-Dec-2021	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	10:05	10:15	0:10	MAIN SUPPLY FAILURE
1015	19-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	3:20	3:25	0:05	LINE FAULT
1016	19-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	5:40	5:50	0:10	LINE FAULT
1017	19-Dec-2021	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	13:55	14:00	0:05	LINE FAULT
1018	19-Dec-2021	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	3:40	3:45	0:05	MAIN SUPPLY FAILURE
1019	19-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	3:40	6:10	2:30	LINE FAULT
1020	19-Dec-2021	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	6:17	6:28	0:11	MAIN SUPPLY FAILURE
1021	19-Dec-2021	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	6:20	6:35	0:15	MAIN SUPPLY FAILURE
1022	19-Dec-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	3:20	3:25	0:05	LINE FAULT
1023	19-Dec-2021	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,CHOWDAPUR_110,NSL SUGARS FACTORY	13:54	14:02	0:08	LINE FAULT
1024	19-Dec-2021	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110,DONGAR GAON_110,DIGGI_110	3:15	3:20	0:05	LINE FAULT
1025	19-Dec-2021	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	6:15	6:25	0:10	LINE FAULT
1026	19-Dec-2021	GULBARGA	110	MALLAT-BYAGAWATH1	BYAGAWATH_110,VALKAM DINNI_110	20:02	20:12	0:10	LINE FAULT
1027	19-Dec-2021	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	3:40	3:45	0:05	LINE FAULT
1028	19-Dec-2021	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	19:10	19:14	0:04	LINE FAULT
1029	19-Dec-2021	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	21:02	21:15	0:13	LINE FAULT
1030	19-Dec-2021	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERDONA_110,SRNAGAR_110,MALLAPURA_110	10:05	10:15	0:10	LINE FAULT
1031	19-Dec-2021	GULBARGA	110	SINDHANOOR-SUZLON_IPP	SINDHANOOR_220	21:53	22:18	0:25	LINE FAULT
1032	19-Dec-2021	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGA VATHI_110,DR NAGAR_110,KARATAGI_110	1:35	1:45	0:10	LINE FAULT
1033	19-Dec-2021	GULBARGA	110	KUSTAGI-KUSTAGI SOLAR_IPP	KUSTAGI_220	20:44	23:00	2:16	LINE CLEAR AVAILED
1034	19-Dec-2021	GULBARGA	110	SHAHPUR-KBJNL	KBJNL_110	1:50	1:57	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1035	19-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1036	19-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	17:48(18.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1037	19-Dec-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	13:48	16:33	2:45	LINE CLEAR AVAILED
1038	19-Dec-2021	HASSAN	220	KEMAR-Varahi2	KEMAR_220	13:50	16:33	2:43	LINE CLEAR AVAILED
1039	19-Dec-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	13:48	16:33	2:45	NFBC ISSUED
1040	19-Dec-2021	HASSAN	220	VARAHI-KEMAR2	varahi_gen	13:50	16:33	2:43	NFBC ISSUED
1041	19-Dec-2021	HASSAN	66	HV2	ARAKALGUD_66	14:14	14:18	0:04	TRANSFORMER FAULT
1042	19-Dec-2021	HASSAN	66	BELUR66-MUDIGERE	BELUR_66	10:48	12:43	1:55	LINE CLEAR AVAILED
1043	19-Dec-2021	HASSAN	66	GENDEHA-MUDIGERE	GENDEHALLY_66	12:47	16:34	3:47	LINE CLEAR AVAILED
1044	19-Dec-2021	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATANAHALLI_66	14:03	14:35	0:32	LINE FAULT
1045	19-Dec-2021	HASSAN	66	UGANE-CHIKMNGLR	UGANE_66	10:30	10:40	0:10	MAIN SUPPLY FAILURE
1046	19-Dec-2021	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	11:00	11:15	0:15	LINE FAULT
1047	19-Dec-2021	MYSURU	66	BILIKERE-GVGUDI	GVGUDI_66	7:24	7:35	0:10	LINE FAULT
1048	19-Dec-2021	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	NO STATIONS EFFECTED	7:01	8:10	1:09	LINE CLEAR AVAILED
1049	19-Dec-2021	MYSURU	66	DEVNUR(N'GUD)-KADAKOLA	NO STATIONS EFFECTED	14:35	16:27	1:52	LINE CLEAR AVAILED
1050	19-Dec-2021	MYSURU	66	HV2	HANNUR_66	8:07	8:17	0:09	HAND TRIPPED
1051	19-Dec-2021	MYSURU	66	HV1	HEBBAL_66	10:22	13:42	3:20	LINE CLEAR AVAILED
1052	19-Dec-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	13:12	13:33	0:20	LINE CLEAR AVAILED
1053	19-Dec-2021	MYSURU	220	TUBINKERE-KOTHHIPURA	NO STATIONS EFFECTED	10:55	17:15	6:20	LINE CLEAR AVAILED
1054	19-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1055	19-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1056	19-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN,LINE CLEAR AVAILED
1057	19-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN,LINE CLEAR AVAILED
1058	19-Dec-2021	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	8:24	8:44	0:20	HAND TRIPPED
1059	19-Dec-2021	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	8:24	8:44	0:20	HAND TRIPPED
1060	19-Dec-2021	TUMKUR	220	TR-1	KIADB V N PURA_220	9:23	17:23	7:59	LINE CLEAR AVAILED
1061	19-Dec-2021	TUMKUR	220	TR-2	KIADB V N PURA_220	9:23	17:23	7:59	LINE CLEAR AVAILED
1062	19-Dec-2021	TUMKUR	220	KIADB V N PURA220-PGCIL V N PURA	KIADB V N PURA_220	9:23	17:23	7:59	LINE CLEAR AVAILED
1063	19-Dec-2021	TUMKUR	220	KIADB V N PURA220-MADHUGIRI220	MADHUGIRI_220	9:23	17:23	7:59	LINE CLEAR AVAILED
1064	19-Dec-2021	TUMKUR	220	KIADB V N PURA220-TMTP_6	TMTP_66	9:23	17:23	7:59	LINE CLEAR AVAILED
1065	19-Dec-2021	TUMKUR	110	NITTUR 220-KALLUR	KALLUR_110	3:32	3:39	0:07	LINE FAULT
1066	19-Dec-2021	TUMKUR	66	TR-2(LV SIDE)	CHITRADURGA_220	8:02	9:08	1:05	LINE CLEAR AVAILED
1067	19-Dec-2021	TUMKUR	66	TR-1	CHIKKATOTTLUKERE	7:15	7:54	0:39	TRANSFORMER FAULT
1068	19-Dec-2021	TUMKUR	66	TR-1	JIDDIGERE_66	15:42	18:00	2:18	LINE CLEAR AVAILED
1069	19-Dec-2021	TUMKUR	66	TR-1	KIADB V N PURA_220	9:20	17:33	8:12	LINE CLEAR AVAILED
1070	19-Dec-2021	TUMKUR	66	TR-2	KIADB V N PURA_220	9:20	17:34	8:13	LINE CLEAR AVAILED
1071	19-Dec-2021	TUMKUR	66	KORATAGERE-HOLAVANHALLI	KORATAGERE_66	7:15	8:09	0:53	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1072	19-Dec-2021	TUMKUR	66	PD KOTE 66-CLEAR SOLAR _IPP_66	CLEAR SOLAR _IPP_66	10:35	10:46	0:10	LINE FAULT
1073	19-Dec-2021	TUMKUR	66	TR-1	PD KOTE_66	8:05	8:18	0:12	TRANSFORMER FAULT
1074	19-Dec-2021	TUMKUR	66	TR-1	PD KOTE_66	10:35	10:41	0:06	TRANSFORMER FAULT
1075	19-Dec-2021	TUMKUR	66	TR-1	PD KOTE_66	14:32	14:41	0:09	TRANSFORMER FAULT
1076	19-Dec-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	8:12	8:32	0:19	LINE FAULT
1077	19-Dec-2021	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR2	WELSPUN SOLAR2	14:59	15:09	0:09	LINE FAULT
1078	20-Dec-2021	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
1079	20-Dec-2021	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN,LINE CLEAR AVOIDED
1080	20-Dec-2021	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN, LINE FAULT
1081	20-Dec-2021	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22(30.03.2021)			LINE OPEN, LINE FAULT
1082	20-Dec-2021	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15(24.06.2021)			LINE OPEN,LINE CLEAR AVOIDED
1083	20-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL1 (BIJAPUR1)	BAGEWADI_220	22:13 (20.11.2021)			LINE OPEN,LINE CLEAR AVOIDED
1084	20-Dec-2021	BAGALKOT	220	BAGEWADI-NANDIHAL2 (BIJAPUR2)	BAGEWADI_220	22:14 (20.11.2021)			LINE OPEN,LINE CLEAR AVOIDED
1085	20-Dec-2021	BAGALKOT	220	CHIKKODI- KOLAPUR2(MUDASHINGHI)	CHIKKODI_220	10:56(26.11.2021)			LINE OPEN,LINE CLEAR AVOIDED
1086	20-Dec-2021	BAGALKOT	110	UMMACHAGI - KIRUVATTI	UMMACHAGI_110	15:25(08.12.2021)			LINE OPEN, LINE FAULT
1087	20-Dec-2021	BAGALKOT	110	SRS HUBLI-PH COMPOUND	PH COMPOUND_110	10:18 (13.12.2021)			LINE OPEN,LINE CLEAR AVOIDED
1088	20-Dec-2021	BAGALKOT	110	ANKALAGI-BELGAUM 2	ANKALAGI_110	10:27 (13.12.2021)			LINE OPEN,LINE CLEAR AVOIDED
1089	20-Dec-2021	BAGALKOT	220	HUBLI-SIRSI1	HUBLI_220	11:00(13.12.2021)			LINE OPEN,LINE CLEAR AVOIDED
1090	20-Dec-2021	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	11:01(13.12.2021)			LINE OPEN,LINE CLEAR AVOIDED
1091	20-Dec-2021	BAGALKOT	110	GADAG220- BETAGERI	GADAG_220	15:42 (14.12.2021)			LINE OPEN,LINE CLEAR AVOIDED
1092	20-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD2	RON_110	20:37 (17.12.2021)			LINE OPEN, LINE FAULT
1093	20-Dec-2021	BAGALKOT	110	RON- GAJENDRAGAD1	RON_110	20:37 (17.12.2021)			LINE OPEN,LINE CLEAR AVOIDED
1094	20-Dec-2021	BAGALKOT	110	BAGALKOT220- GULEDAGUDDA	BAGALKOT_220	19:48	20:15	0:27	LINE FAULT
1095	20-Dec-2021	BAGALKOT	110	RANEENNUR- BYADAGI	RANEENNUR_220	11:21	18:20	6:59	LINE CLEAR AVOIDED
1096	20-Dec-2021	BAGALKOT	110	RANEENNUR- RATTIHALI(TUMMINKATTI)	RANEENNUR_220	16:30	18:20	1:50	LINE CLEAR AVOIDED
1097	20-Dec-2021	BAGALKOT	110	RANEENNUR- BYADAGI	RANEENNUR_220	18:21	19:36	1:15	LINE CLEAR AVOIDED
1098	20-Dec-2021	BAGALKOT	110	220/110KV, LV2	HUBLI_220	10:33	18:05	7:32	LINE CLEAR AVOIDED
1099	20-Dec-2021	BAGALKOT	110	MKHUBLI220- MK HUBLI2	MK HUBLI_220	12:27	12:30	0:03	HAND TRIPPED
1100	20-Dec-2021	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220	15:01	17:14	2:13	LINE CLEAR AVOIDED
1101	20-Dec-2021	BAGALKOT	110	KUDACHI220- TERDAL(MORAB)	KUDACHI_220	17:43	17:51	0:08	LINE FAULT
1102	20-Dec-2021	BAGALKOT	110	110/11KV,HV1	YADWAD_110	15:20	15:41	0:21	LINE CLEAR AVOIDED
1103	20-Dec-2021	BAGALKOT	66	66/33,HV3	HARIHAR HOSPET_66	13:23(20.12.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1104	20-Dec-2021	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	13:26	13:39	0:13	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1105	20-Dec-2021	BAGALKOT	110	BYADAGI-SUZLON	BYADAGI_110	15:11	16:42	1:31	LINE CLEAR AVAILED
1106	20-Dec-2021	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	14:00	14:56	0:56	LINE CLEAR AVAILED
1107	20-Dec-2021	BAGALKOT	110	RANEENNUR-HOSAHONNATTI	HOSAHONNATTI_110	15:02	19:39	4:37	LINE CLEAR AVAILED
1108	20-Dec-2021	BAGALKOT	110	110/33KV,HV3	MACHE_110 &ASHOK IRON &ALUCAST_33	22:27	22:43	0:16	LINE CLEAR AVAILED
1109	20-Dec-2021	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	11:00	11:56	0:56	LINE CLEAR AVAILED
1110	20-Dec-2021	BAGALKOT	110	BAGALKOT220- KERUR	BAGALKOT_220	20:15	20:50	0:35	LINE CLEAR AVAILED
1111	20-Dec-2021	BAGALKOT	110	110/11KV, HV1	MANTUR(B)_110	10:54	10:59	0:05	TRANSFORMER FAULT
1112	20-Dec-2021	BAGALKOT	110	110/11KV, HV1	SHIRAGUPPI_110	12:55	14:25	1:30	LINE CLEAR AVAILED
1113	20-Dec-2021	BAGALKOT	220	RANEENNUR- GUTTUR	RANEENNUR_220	10:45	17:05	6:20	LINE CLEAR AVAILED
1114	20-Dec-2021	BAGALKOT	110	RANEENNUR- HONNATTI	RANEENNUR_220	11:20	18:20	7:00	LINE CLEAR AVAILED
1115	20-Dec-2021	BAGALKOT	110	RANEENNUR- GUTTAL	RANEENNUR_220	11:20	18:20	7:00	LINE CLEAR AVAILED
1116	20-Dec-2021	BAGALKOT	110	RANEENNUR- HIREKERUR	RANEENNUR_220	11:21	18:20	6:59	LINE CLEAR AVAILED
1117	20-Dec-2021	BAGALKOT	220	220/110KV, HV2&LV2	RANEENNUR_220	11:28	17:06	5:38	LINE CLEAR AVAILED
1118	20-Dec-2021	BAGALKOT	220	220/110KV, HV1&LV1	RANEENNUR_220	16:40	18:14	1:34	LINE CLEAR AVAILED
1119	20-Dec-2021	BAGALKOT	220	RANEENNUR- BELLIGAVI	RANEENNUR_220	16:40	18:12	1:32	LINE CLEAR AVAILED
1120	20-Dec-2021	BAGALKOT	220	RANEENNUR- GUTTUR	RANEENNUR_220	18:06 (20.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1121	20-Dec-2021	BAGALKOT	110	RANEENNUR- HONNATTI	RANEENNUR_220	18:42	19:40	0:58	LINE CLEAR AVAILED
1122	20-Dec-2021	BAGALKOT	110	RANEENNUR- GUTTAL	RANEENNUR_220	18:21	19:42	1:21	LINE CLEAR AVAILED
1123	20-Dec-2021	BAGALKOT	110	RANEENNUR- HIREKERUR	RANEENNUR_220	18:42	19:42	1:00	LINE CLEAR AVAILED
1124	20-Dec-2021	BAGALKOT	110	220/110KV, LV2	RANEENNUR_220	11:28	17:06	5:38	LINE CLEAR AVAILED
1125	20-Dec-2021	BAGALKOT	220	220/110KV, HV2	HUBLI_220	9:43	18:04	8:21	LINE CLEAR AVAILED
1126	20-Dec-2021	BENGALURU	66	BOODIGERE - BEGUR 220	BOODIGERE	15:40	15:48	0:08	LOAD CHANGE OVER
1127	20-Dec-2021	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	19:00	19:05	0:05	LOAD CHANGE OVER
1128	20-Dec-2021	BENGALURU	66	SARAKKI - SUBRAMANYAPURA 220	SARAKKI	5:52	6:00	0:08	LOAD CHANGE OVER
1129	20-Dec-2021	BENGALURU	66	SARAKKI - JAYADEVA	SARAKKI	15:47	15:52	0:05	LOAD CHANGE OVER
1130	20-Dec-2021	BENGALURU	66	KHB - YELAHANKA 220	KHB	12:13	12:18	0:05	LOAD CHANGE OVER
1131	20-Dec-2021	BENGALURU	66	KHB - SRS PEENYA 220	KHB	14:18	14:21	0:03	LOAD CHANGE OVER
1132	20-Dec-2021	BENGALURU	66	SOMANAHALLI 220 - SUBRAMANYAPURA 1	ISKON, SUBRAMANYAPURA 66	0:25	0:50	0:25	LINE FAULT
1133	20-Dec-2021	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	ISKON, SUBRAMANYAPURA 66	15:38	15:45	0:07	LOAD CHANGE OVER
1134	20-Dec-2021	BENGALURU	66	TELECOM LAYOUT - NRS 2	TELECOM LAYOUT	12:44	12:49	0:05	LOAD CHANGE OVER
1135	20-Dec-2021	BENGALURU	66	SHOBHA INDRAPRASTA - NRS 220	SHOBHA INDRAPRASTA	6:47	6:53	0:06	LOAD CHANGE OVER
1136	20-Dec-2021	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	6:18	6:28	0:10	LINE FAULT
1137	20-Dec-2021	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	11:07	12:13	1:06	MAIN SUPPLY FAILURE
1138	20-Dec-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	18:14	18:22	0:08	LINE FAULT
1139	20-Dec-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 1	NARASAPURA, HONDA (EHT), KC VALLEY (EHT)	11:08	12:12	1:04	MAIN SUPPLY FAILURE
1140	20-Dec-2021	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	11:08	12:12	1:04	MAIN SUPPLY FAILURE
1141	20-Dec-2021	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPETE	11:06	11:15	0:08	MAIN SUPPLY FAILURE
1142	20-Dec-2021	BENGALURU	66	GOWRIBIDANUR 220 - DB PURA 2	MANCHENAHALLI, THONDEBHAVI, GUNDAMGERE	6:26	6:34	0:08	LINE FAULT
1143	20-Dec-2021	BENGALURU	66	AGALAKOTE - MATHIKERE	MATHIKERE	11:14	11:52	0:38	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1144	20-Dec-2021	BENGALURU	66	HV2	YEDUMADU	1:19	1:40	0:20	TRANSFORMER FAULT
1145	20-Dec-2021	BENGALURU	66	HV2	YEDUMADU	10:00	18:23	8:22	TRANSFORMER FAULT
1146	20-Dec-2021	BENGALURU	66	HV2	YELAHANKA 220	11:28	11:30	0:01	LINE CLEAR AVAILED
1147	20-Dec-2021	BENGALURU	220	HV2	KOLAR 220	11:12	12:05	0:52	LINE CLEAR AVAILED
1148	20-Dec-2021	BENGALURU	66	LV2	KOLAR 220	11:08	12:05	0:57	MAIN SUPPLY FAILURE
1149	20-Dec-2021	BENGALURU	66	HV2	KACHMARANAHALLI	3:35	3:40	0:05	TRANSFORMER FAULT
1150	20-Dec-2021	BENGALURU	66	BANGARPETE - MALUR 220	BANGARPETE	12:25	12:30	0:05	LOAD CHANGE OVER
1151	20-Dec-2021	BENGALURU	66	KORAMANGALA 220 - HSR LAYOUT 2	NO STATION AFFECTED	16:25(29/11/2021)			LINE OPEN, LINE FAULT
1152	20-Dec-2021	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	00:15(19.12.2021)	8:33(20.12.2021)	32:18HRS	LINE CHARGED
1153	20-Dec-2021	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1154	20-Dec-2021	GULBARGA	220	HV1	RAICHUR_220	13:31 (14.12.2021)			TRANSFORMER OPEN,LINE CLEAR AVAILED
1155	20-Dec-2021	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	22:04(19.12.2021(07:32(20.12.2021)	09:28HRS	LINE CHARGED
1156	20-Dec-2021	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN,LINE CLEAR AVAILED
1157	20-Dec-2021	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	19:313(19.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1158	20-Dec-2021	GULBARGA	110	LADHA-BHALKI	LADHA_110	10:40(7.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1159	20-Dec-2021	GULBARGA	110	HV2	NANDUR_110	11:28	12:48	1:20	LINE CLEAR AVAILED
1160	20-Dec-2021	GULBARGA	110	HV1	HALAKUNDI_110	10:20	10:35	0:15	TRANSFORMER FAULT
1161	20-Dec-2021	GULBARGA	110	HV1	GOOGLE_110	11:10	11:15	0:05	TRANSFORMER FAULT
1162	20-Dec-2021	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	3:00	3:05	0:05	MAIN SUPPLY FAILURE
1163	20-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	3:00	6:05	3:05	LINE FAULT
1164	20-Dec-2021	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	5:05	5:10	0:05	MAIN SUPPLY FAILURE
1165	20-Dec-2021	GULBARGA	110	GABBUR-BPSOLAR_IPP	GABBUR_110	5:05	6:10	1:05	LINE FAULT
1166	20-Dec-2021	GULBARGA	110	GULBARGAUNIVERSITY- GULBARGANORTH	GULBARGAUNIVERSITY_11 0	13:40	14:15	0:35	LINE CLEAR AVAILED
1167	20-Dec-2021	GULBARGA	110	MATAMARI-RAICHUR	MATAMARI_110	18:15	18:50	0:35	MAIN SUPPLY FAILURE
1168	20-Dec-2021	GULBARGA	110	RAICHUR-SHAHPUR1	GABBUR_110	5:03	5:09	0:06	LINE FAULT
1169	20-Dec-2021	GULBARGA	110	SINDHANOOR-THURVIHAL	GANDHINAGAR_110,THUR VIHAL_110	11:25	17:45	6:20	LINE CLEAR AVAILED
1170	20-Dec-2021	GULBARGA	110	HALAWARTHI-GINIGERA	GINIGERA_110	9:30	16:47	7:17	LINE CLEAR AVAILED
1171	20-Dec-2021	GULBARGA	110	HALAVARTHI-MUNIRABAD	MUNIRABAD_110	11:25	14:45	3:20	LINE FAULT
1172	20-Dec-2021	GULBARGA	66	HV3	ITTAGI_220	18:13 (20.11.2021)			TRANSFORMER OPEN, TRANSFORMER FAULT
1173	20-Dec-2021	GULBARGA	66	NEELAGUNDA-HARAPANAHALLI	HARAPANAHALLI_66	18:20	18:30	0:10	LINE FAULT
1174	20-Dec-2021	GULBARGA	66	TELAGI-YARAGUNTA	YARAGUNTA_110	2:25	2:35	0:10	LINE FAULT
1175	20-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	17:48(18.12.2021)	10:02(20.12.2021)	36:13 hrs	LINE CHARGED
1176	20-Dec-2021	HASSAN	400	UPCL-HASSAN1	upcl_gen	20:07(20.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1177	20-Dec-2021	HASSAN	110	GURUPUR-KAVOOR	GURUPURA_110	18:14(20.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1178	20-Dec-2021	HASSAN	400	UPCL-HASSAN2	upcl_gen	15:22	19:22	4:00	LINE CLEAR AVAILED
1179	20-Dec-2021	HASSAN	220	KEMAR-Varahi1	KEMAR_220	11:41	13:45	2:04	LINE CLEAR AVAILED
1180	20-Dec-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	10:05	17:50	7:45	NFBC ISSUED
1181	20-Dec-2021	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	18:02	18:15	0:13	HAND TRIPPED
1182	20-Dec-2021	HASSAN	220	SHRAVTY-TALAGUPPA 1	sharavathy_gen	17:02	19:11	2:09	LINE CLEAR AVAILED
1183	20-Dec-2021	HASSAN	220	SHRAVTY-TALAGUPPA 2	sharavathy_gen	11:51	15:46	3:55	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1184	20-Dec-2021	HASSAN	220	TALAGU-SGS1	TALAGUPPA_400	17:02	19:11	2:09	LINE CLEAR AVAILED
1185	20-Dec-2021	HASSAN	220	TALAGU-SGS2	TALAGUPPA_400	11:51	15:46	3:55	LINE CLEAR AVAILED
1186	20-Dec-2021	HASSAN	220	VARAHI-KEMAR1	varahi_gen	11:41	13:45	2:04	NFBC ISSUED
1187	20-Dec-2021	HASSAN	110	HV1	BIRUR_110	11:07	11:49	0:42	LINE CLEAR AVAILED
1188	20-Dec-2021	HASSAN	110	HV2	GANDASI_110	12:14	13:40	1:26	LINE CLEAR AVAILED
1189	20-Dec-2021	HASSAN	110	KEMAR1	GURUVAYANKERE_110	9:25	14:40	5:15	LINE CLEAR AVAILED
1190	20-Dec-2021	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	9:25	14:39	5:14	LINE FAULT
1191	20-Dec-2021	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	9:41	11:48	2:07	LINE FAULT
1192	20-Dec-2021	HASSAN	66	HV1	BASAVAGHATTA_66	10:40	11:08	0:28	LINE CLEAR AVAILED
1193	20-Dec-2021	HASSAN	66	HASSN220-BELUR	HASSAN_220	10:12	13:01	2:49	LINE CLEAR AVAILED
1194	20-Dec-2021	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	11:25	11:29	0:04	HAND TRIPPED
1195	20-Dec-2021	HASSAN	66	HV1	SAKALESHPUR_66	9:36	12:42	3:06	LINE CLEAR AVAILED
1196	20-Dec-2021	MYSURU	66	HV1	DUNDANAHALLI_66	14:31	15:40	1:08	LINE CLEAR AVAILED
1197	20-Dec-2021	MYSURU	66	HV1	HALAGUR_66	13:00	13:24	0:23	LINE CLEAR AVAILED
1198	20-Dec-2021	MYSURU	66	HV1	KABHALLY_66	12:01	13:50	1:48	LINE CLEAR AVAILED
1199	20-Dec-2021	MYSURU	66	HV2	KMDODDI_66	12:36	13:51	1:15	LINE CLEAR AVAILED
1200	20-Dec-2021	MYSURU	66	HV2	KMDODDI_66	16:04	16:50	0:46	HAND TRIPPED
1201	20-Dec-2021	MYSURU	66	HV2	KMDODDI_66	18:06	18:19	0:12	HAND TRIPPED
1202	20-Dec-2021	MYSURU	66	HV1	KRPET_66	15:11	15:55	0:44	LINE CLEAR AVAILED
1203	20-Dec-2021	MYSURU	66	MEGALAPURA-HEBBANI	CHIDRAVALI_66THUMBLA_66	13:46	15:28	1:41	NFBC ISSUED
1204	20-Dec-2021	MYSURU	66	MEGALAPURA-VAJMANGALA	NO STATIONS EFFECTED	12:46	13:12	0:26	LINE FAULT
1205	20-Dec-2021	MYSURU	66	HV2	PANDAVAPURA_66	14:05	14:42	0:36	LINE CLEAR AVAILED
1206	20-Dec-2021	MYSURU	66	HV1	PERIYAPATNA_66	13:58	16:46	2:48	LINE CLEAR AVAILED
1207	20-Dec-2021	MYSURU	66	HV2	PERIYAPATNA_66	11:21	13:48	2:26	LINE CLEAR AVAILED
1208	20-Dec-2021	MYSURU	66	HV2	PERIYAPATNA_66	13:52	13:54	0:01	TRANSFORMER FAULT
1209	20-Dec-2021	MYSURU	66	HV2	SANTHESARAGUR_66	12:17	14:03	1:45	LINE CLEAR AVAILED
1210	20-Dec-2021	MYSURU	66	HV1	SINDHUVALI_66	13:42	16:16	2:34	LINE CLEAR AVAILED
1211	20-Dec-2021	MYSURU	66	HV2	SINDHUVALI_66	11:05	13:40	2:35	LINE CLEAR AVAILED
1212	20-Dec-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	11:09	12:21	1:12	LINE CLEAR AVAILED
1213	20-Dec-2021	MYSURU	66	HV1	SRIRANGAPATNA_66	14:15	15:26	1:10	LINE CLEAR AVAILED
1214	20-Dec-2021	MYSURU	66	SUNTIKOPPA-KUSHALNAGAR	NO STATIONS EFFECTED	10:30	11:43	1:13	LINE CLEAR AVAILED
1215	20-Dec-2021	MYSURU	66	SUNTIKOPPA-MADIKERI	SUNTIKOPPA_66	10:30	11:37	1:07	LINE CLEAR AVAILED
1216	20-Dec-2021	MYSURU	66	TALAKADU-ADANI	NO STATIONS EFFECTED	3:25	3:35	0:10	LINE FAULT
1217	20-Dec-2021	MYSURU	66	VAJMANGALA-BANNUR	NO STATIONS EFFECTED	8:26	9:57	1:31	LINE CLEAR AVAILED
1218	20-Dec-2021	MYSURU	66	VAJMANGALA-KADAKOLA1	AYRALLI_66 MARADIHUNDI_66	0:56	1:09	0:13	LINE FAULT
1219	20-Dec-2021	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	10:32	11:52	1:20	LINE FAULT
1220	20-Dec-2021	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	12:20	13:37	1:17	LINE FAULT
1221	20-Dec-2021	MYSURU	66	VAJMANGALA-HEBBANI	NO STATIONS EFFECTED	14:28	15:20	0:52	NFBC ISSUED
1222	20-Dec-2021	MYSURU	220	MADHUVANAHALLI-CR NAGARA 2	NO STATIONS EFFECTED	13:03	13:06	0:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_at	Duration	REASON
1223	20-Dec-2021	MYSURU	66	HEBBANI - VADKEPURA	VADKEPURA_66	12:46	12:53	0:07	LINE FAULT
1224	20-Dec-2021	MYSURU	66	HEBBANI-SATHEGALA	NO STATIONS EFFECTED	13:52	15:37	1:45	LINE CLEAR AVAILED
1225	20-Dec-2021	MYSURU	66	HEBBANI-VAJMANGALA	NO STATIONS EFFECTED	17:08:00 (17.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1226	20-Dec-2021	MYSURU	66	HEBBANI-MADHUVANAHLI	NO STATIONS EFFECTED	15:16 (8.12.2021)			LINE OPEN,LINE CLEAR AVAILED
1227	20-Dec-2021	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN,LINE CLEAR AVAILED
1228	20-Dec-2021	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN,LINE CLEAR AVAILED
1229	20-Dec-2021	TUMKUR	400	JAGALUR 400KV-BPS2(BALLARI400kv)	JAGALUR 400kv	11:25	15:58	4:33	LINE CLEAR AVAILED
1230	20-Dec-2021	TUMKUR	220	TR-1	PAVAGADA_220	14:27	14:35	0:07	TRANSFORMER FAULT
1231	20-Dec-2021	TUMKUR	220	TR-2	PAVAGADA_220	14:27	14:36	0:08	TRANSFORMER FAULT
1232	20-Dec-2021	TUMKUR	220	TR-1	THALLAK_220	15:24	17:46	2:22	LINE CLEAR AVAILED
1233	20-Dec-2021	TUMKUR	110	TR-1	KBCROSS_220	16:12	18:00	1:48	LINE CLEAR AVAILED
1234	20-Dec-2021	TUMKUR	66	TR-1	BHARAMAGIRI_66	14:35	14:40	0:05	TRANSFORMER FAULT
1235	20-Dec-2021	TUMKUR	66	TR-1	BILCHODU_66	8:37	8:52	0:14	TRANSFORMER FAULT
1236	20-Dec-2021	TUMKUR	66	TR-2	CHITRADURGA_66	14:07	14:17	0:09	HAND TRIPPED
1237	20-Dec-2021	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	6:48	6:50	0:01	LINE FAULT
1238	20-Dec-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	8:21	8:26	0:05	MAIN SUPPLY FAILURE
1239	20-Dec-2021	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	11:03	11:10	0:07	MAIN SUPPLY FAILURE
1240	20-Dec-2021	TUMKUR	66	TR-2	HULIYURDURGA_66	14:56	16:56	2:00	LINE CLEAR AVAILED
1241	20-Dec-2021	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	12:18	12:29	0:10	HAND TRIPPED
1242	20-Dec-2021	TUMKUR	66	MATHOD- ENERCON1_IPP_66	ENERCON1_IPP_66	0:31	0:35	0:04	LINE FAULT
1243	20-Dec-2021	TUMKUR	66	TR-1	PKOTE_66	12:20	12:33	0:12	TRANSFORMER FAULT
1244	20-Dec-2021	TUMKUR	66	TR-1	PKOTE_66	13:52	13:55	0:03	TRANSFORMER FAULT
1245	20-Dec-2021	TUMKUR	66	TR-1	PKOTE_66	14:43	14:48	0:05	TRANSFORMER FAULT
1246	20-Dec-2021	TUMKUR	66	TR-1	PAVAGADA_220	12:08	12:13	0:05	TRANSFORMER FAULT
1247	20-Dec-2021	TUMKUR	66	TR-1(LV-1)	PAVAGADA_220	14:27	14:35	0:07	TRANSFORMER FAULT
1248	20-Dec-2021	TUMKUR	66	TR-2(LV-2)	PAVAGADA_220	14:27	14:36	0:09	TRANSFORMER FAULT
1249	20-Dec-2021	TUMKUR	66	PAVAGADA220-MIDIGESHI	MIDIGESHI_66	14:27	14:38	0:10	LINE FAULT
1250	20-Dec-2021	TUMKUR	66	TR-2	TAVAREKERE(H)_66	12:50	13:08	0:18	HAND TRIPPED
1251	20-Dec-2021	TUMKUR	66	TR-2	THALLAK_220	15:24	17:48	2:24	LINE CLEAR AVAILED