

400/220/110/66 kV TRANSMISSION OUTAGES FROM: 06.04.21 TO 12.04.21

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	6-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOID
2	6-Apr-21	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	13:00	15:16	2:16	LINE CLEAR AVOID
3	6-Apr-21	BAGALKOT	110	110/11KV, HV1A	JAMKHANDI_110	10:57	13:26	2:29	LINE CLEAR AVOID
4	6-Apr-21	BAGALKOT	110	110/11KV, HV2	YARAGATTI_110	18:51	18:56	0:05	TRANSFORMER FAULT
5	6-Apr-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	22:23	22:51	0:28	TRANSFORMER FAULT
6	6-Apr-21	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	14:49	15:00	0:11	TRANSFORMER FAULT
7	6-Apr-21	BAGALKOT	110	110/11KV,HV2	HATTARAGI_110	9:51	16:21	6:30	LINE CLEAR AVOID
8	6-Apr-21	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	15:03	15:22	0:19	HAND TRIPPED
9	6-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	05:49	05:52	0:03	TRANSFORMER FAULT
10	6-Apr-21	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	11:39	11:44	0:05	LINE FAULT
11	6-Apr-21	BAGALKOT	110	BELGAUM220- VODAGOAN	STATION NOT AFFECTED VODAGOAN_110	14:05	14:21	0:16	HAND TRIPPED
12	6-Apr-21	BAGALKOT	110	BELGAUM220- VODAGOAN	STATION NOT AFFECTED VODAGOAN_110	15:18	17:31	2:13	LINE CLEAR AVOID
13	6-Apr-21	BAGALKOT	110	BETAGERI-NAREGALL	BETAGERI (STATION NOT AFFECTED)	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVOID
14	6-Apr-21	BAGALKOT	110	GADAG ROAD-RAILWAY(BIDNAL)	GADAG ROAD_110	16:11	16:48	0:37	LINE CLEAR AVOID
15	6-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVOID
16	6-Apr-21	BAGALKOT	110	GHATAPRABHA- MANTUR(MUDALAGI)	MANTUR_110	18:59	19:08	0:09	LINE FAULT
17	6-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVOID
18	6-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVOID
19	6-Apr-21	BAGALKOT	110	ILKAL 1-HUNGUND	HUNGUND_110	4:43	4:44	0:01	LINE FAULT
20	6-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVOID
21	6-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
22	6-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVOID
23	6-Apr-21	BAGALKOT	110	NAREGAL- RON	STATION NOT AFFECTED NAREGAL_110	09:10	09:59	0:49	HAND TRIPPED
24	6-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVOID
25	6-Apr-21	BAGALKOT	110	RANEENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
26	6-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVOID
27	6-Apr-21	BAGALKOT	110	UDYAMBAG-MACHE	STATION NOT AFFECTED MACHE_110	8:35 (02.04.2021)	15:20 (06.04.2021)	102:45HRS	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
28	6-Apr-21	BAGALKOT	110	VAJRAMATTI220- MELLIGERI	MELLIGERI_110	00:03	00:07	0:04	HAND TRIPPED
29	6-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	10:31 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED
30	6-Apr-21	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	19:03 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
31	6-Apr-21	BAGALKOT	220	CHIKKODI -BELGAUM1	CHIKKODI_220	12:04	19:43	7:39	NFBC ISSUED
32	6-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
33	6-Apr-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	14:38	18:58	4:20	LINE FAULT
34	6-Apr-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	10:54	15:37	4:43	LINE CLEAR AVAILED
35	6-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
36	6-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	7:23 (02.04.2021)	13:20 (06.04.2021)	117:15HRS	LINE CHARGED
37	6-Apr-21	BAGALKOT	220	NAGJHARI-BIDNAL	BIDNAL_220	15:28 (05.04.2021)	12:34 (06.04.2021)	21:06HRS	LINE FAULT
38	6-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
39	6-Apr-21	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	14:49	18:58	4:09	LINE FAULT
40	6-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
41	6-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
42	6-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	7:25 (02.04.2021)	13:26 (06.04.2021)	117:18HRS	LINE CHARGED
43	6-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1	STATION NOT AFFECTED VAJRAMATTI_220	12:03 (05.04.2021)	13:46 (06.04.2021)	25:43HRS	LINE CHARGED
44	6-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1&2	VAJRAMATTI_220	14:32 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
45	6-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI2	STATION NOT AFFECTED VAJRAMATTI_220	12:04 (05.04.2021)	13:46 (06.04.2021)	25:43HRS	LINE CHARGED
46	6-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
47	6-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
48	6-Apr-21	BENGALURU	66	ANJANAPURA - KHODAYS 220	ANJANAPURA	09:55	10:08	00:13	LINE CLEAR AVAILED
49	6-Apr-21	BENGALURU	66	ATTUR YELAHANKA - DG4	PLATINUM CITY	14:50	15:10	00:20	LINE FAULT
50	6-Apr-21	BENGALURU	66	BOODIGERE - HOSKOTE 220	BOODIGERE	08:05	08:10	00:05	LOAD CHANGEOVER
51	6-Apr-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	11:46	13:31	01:44	LINE CLEAR AVAILED
52	6-Apr-21	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	07:35	08:05	00:30	LINE FAULT
53	6-Apr-21	BENGALURU	66	HOODY 220 - HOSKOTE 66	HOSKOTE 66	15:52	16:15	00:23	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
54	6-Apr-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	09:30	09:35	00:05	LOAD CHANGEOVER
55	6-Apr-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	17:00	17:05	00:05	LOAD CHANGEOVER
56	6-Apr-21	BENGALURU	66	HV1	ANJANAPURA	09:40	09:45	00:05	LINE CLEAR AVAILED
57	6-Apr-21	BENGALURU	66	HV1	TK HALLI 220	15:50	16:41	00:51	LINE CLEAR AVAILED
58	6-Apr-21	BENGALURU	66	HV1	H GOLHALLI	18:25(5-4-2021)	13:44:53	18:28HRS	TRANSFORMER CHARGED
59	6-Apr-21	BENGALURU	66	HV2	EDC 220	12:33	12:39	00:05	LINE CLEAR AVAILED
60	6-Apr-21	BENGALURU	66	HV2	TELECOM LAYOUT	11:22	11:35	00:13	LINE CLEAR AVAILED
61	6-Apr-21	BENGALURU	66	HV2	BANGARPET	16:10	17:07	00:57	LINE CLEAR AVAILED
62	6-Apr-21	BENGALURU	66	HV2	KONDASPURA	14:20	14:27	00:07	TRANSFORMER FAULT
63	6-Apr-21	BENGALURU	66	HV2	SARJAPURA 220	13:14	13:29	00:14	TRANSFORMER FAULT
64	6-Apr-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	17:45	17:50	00:05	LOAD CHANGEOVER
65	6-Apr-21	BENGALURU	66	YEDUMADU - KANAKAPURA 220	YEDUMADU	18:30	18:32	00:02	LOAD CHANGEOVER
66	6-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
67	6-Apr-21	GULBARGA	66	BANAVEKAL-SLRSYS	BANAVEKAL_66	03:30	03:44	00:14	LINE FAULT
68	6-Apr-21	GULBARGA	66	BANAVEKAL-SLRSYS	BANAVEKAL_66	04:30	04:50	00:20	LINE FAULT
69	6-Apr-21	GULBARGA	66	HV1	TAMBRAHALLI_66	08:50	09:00	00:10	TRANSFORMER FAULT
70	6-Apr-21	GULBARGA	66	HV1	CHORNOOR_66	12:00	12:04	00:04	TRANSFORMER FAULT
71	6-Apr-21	GULBARGA	110	HV1	SHAHAPUR_220	18:32(6.4.21)			TRANSFORMER OPEN: TRANSFORMER FAULT
72	6-Apr-21	GULBARGA	110	HV2	SHAHAPUR_220	11:35	11:50	00:15	TRANSFORMER FAULT
73	6-Apr-21	GULBARGA	110	HV2	SHAHAPUR_220	13:18	13:30	00:12	TRANSFORMER FAULT
74	6-Apr-21	GULBARGA	110	HV3	MANTHAL_110	11:22	11:43	00:21	LINE CLEAR AVAILED
75	6-Apr-21	GULBARGA	110	HV3	MANTHAL_110	11:22	11:43	00:21	LINE CLEAR AVAILED
76	6-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35(01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
77	6-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35(01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
78	6-Apr-21	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110	19:30	20:50	01:20	MAIN SUPPLY FAILURE
79	6-Apr-21	GULBARGA	110	KUDITINI-BELLARY	KUDITINI_110	19:30	20:50	01:20	MAIN SUPPLY FAILURE
80	6-Apr-21	GULBARGA	110	LINGASUGUR-ILKAL	ILKAL_110	04:07	04:20	00:13	LINE FAULT
81	6-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	03:17	11:26	08:09	LINE CLEAR AVAILED
82	6-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	02:10	02:20	00:10	LINE FAULT
83	6-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	02:41	02:51	00:10	LINE FAULT
84	6-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	03:17	11:26	08:09	LINE CLEAR AVAILED
85	6-Apr-21	GULBARGA	110	SINDHANOOR-PGLR_WIND	SINDHANOOR_220	00:55	01:05	00:10	LINE FAULT
86	6-Apr-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVAMARESHWARA_110	00:10	00:25	00:15	LINE FAULT
87	6-Apr-21	GULBARGA	220	ALIPUR-RAGALPADU	NEELGUNDA_220,GUTTI_220	10:25	14:27	04:02	LINE CLEAR AVAILED
88	6-Apr-21	GULBARGA	220	ALIPUR-RAGALPADU	NEELGUNDA_220,GUTTI_220	10:25	14:27	04:02	LINE CLEAR AVAILED
89	6-Apr-21	GULBARGA	220	HV1	ALIPUR_220	23:45(06.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
90	6-Apr-21	GULBARGA	220	HV1	ALIPUR_220	19:30	23:45	04:15	TRANSFORMER FAULT
91	6-Apr-21	GULBARGA	220	HV1	ALIPUR_220	23:45(06.04.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
92	6-Apr-21	GULBARGA	220	MALLAT-RTPS	MALLAT_220	12:20	12:50	00:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
93	6-Apr-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	18:19(5.04.2021)	13:20(06.04.2021)	19:01HRS	LINE CHARGED
94	6-Apr-21	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	18:19(5.04.2021)	13:20(06.04.2021)	19:01HRS	LINE CHARGED
95	6-Apr-21	HASSAN	66	HV1	HOLEHONNUR_66	15:33(5.4.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
96	6-Apr-21	HASSAN	66	HV1	GORUPURA_66	11:02	12:03	01:01	LINE CLEAR AVAILED
97	6-Apr-21	HASSAN	66	HV1	HALEBEDU_66	10:41	12:07	01:26	LINE CLEAR AVAILED
98	6-Apr-21	HASSAN	66	HV1	KUDLIGERE_66	16:47	18:18	01:31	LINE CLEAR AVAILED
99	6-Apr-21	HASSAN	66	HV2	MALLAPURA_66	13:54	14:41	00:47	LINE CLEAR AVAILED
100	6-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
101	6-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
102	6-Apr-21	HASSAN	66	MALLIP-SANIVARSANTE	MALLIPATNA_66	11:40	11:48	00:08	LINE FAULT
103	6-Apr-21	HASSAN	66	MRSSHM-TAVARECHATNAHALLY	MRSMSG_220	11:54	11:59	00:05	LINE FAULT
104	6-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESHUPURA_66	09:38	19:56	10:18	LINE CLEAR AVAILED
105	6-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKALESHUPURA_66	09:38	19:56	10:18	LINE CLEAR AVAILED
106	6-Apr-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	07:22	08:21	00:59	LOAD CURTAILMENT
107	6-Apr-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	12:01	12:03	00:02	MAIN SUPPLY FAILURE
108	6-Apr-21	HASSAN	110	HV1	ARSKERE_220	11:11	13:24	02:13	LINE CLEAR AVAILED
109	6-Apr-21	HASSAN	110	HV1	BRAHMAVARA_110	09:57	12:52	02:55	LINE CLEAR AVAILED
110	6-Apr-21	HASSAN	110	LV2	SHIRALKOPPA_220	11:03	11:12	00:09	TRANSFORMER FAULT
111	6-Apr-21	HASSAN	110	MSEZ-GSS31	MSEZ_220	10:05	12:15	02:10	LINE CLEAR AVAILED
112	6-Apr-21	HASSAN	110	MSEZ-GSS32	MSEZ_220	12:16	13:12	00:56	LINE CLEAR AVAILED
113	6-Apr-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:03	11:20	00:17	HAND TRIPPED
114	6-Apr-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:03	11:20	00:17	HAND TRIPPED
115	6-Apr-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:03	11:19	00:16	HAND TRIPPED
116	6-Apr-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:03	11:18	00:15	HAND TRIPPED
117	6-Apr-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:03	11:15	00:12	HAND TRIPPED
118	6-Apr-21	HASSAN	220	HV2	SHIRALKOPPA_220	11:03	11:12	00:09	TRANSFORMER FAULT
119	6-Apr-21	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:39(3.4.2021)	11:01(6.4.2021)	21:22hrs	LINE CHARGED
120	6-Apr-21	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:05(6.4.2021)			LINE OPEN:LINE CLEAR AVAILED
121	6-Apr-21	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMSG_220	10:00	12:13	02:13	LINE FAULT
122	6-Apr-21	HASSAN	220	SHSHRAVITY-IMOGA4	sharavathy_gen	10:01	12:13	02:12	LINE FAULT
123	6-Apr-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:22	13:49	03:27	NFBC ISSUED
124	6-Apr-21	MYSURU	66	CHINAKURALI-BOOKANAKERE	CHINAKURALI_66 BANANGADI_66	12:17	12:23	0:06	LINE FAULT
125	6-Apr-21	MYSURU	66	CR NAGARA-BADANKUPPE 2	BADANAGUPPE_66	12:49	15:31	2:42	LINE CLEAR AVAILED
126	6-Apr-21	MYSURU	66	CR NAGARA-PANYADAHUNDI	NO STATION EFFECTED	12:37	15:29	2:52	LINE CLEAR AVAILED
127	6-Apr-21	MYSURU	66	HV1	GAMANAHALLY_66	10:45	12:30	1:45	LINE CLEAR AVAILED
128	6-Apr-21	MYSURU	66	HV1	TUBINAKERE_220	11:50	17:00	5:10	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
129	6-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
130	6-Apr-21	MYSURU	66	HV2	TUBINAKERE_220	11:50	12:02	0:12	LINE CLEAR AVAILED
131	6-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
132	6-Apr-21	MYSURU	66	JAKKANAHALLI-NAGAMANGALA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 NAGAMANGALA_66	6:20	6:25	0:05	LINE FAULT
133	6-Apr-21	MYSURU	66	KADAKOLA-DEVNUR(N'GUD)	DEVANOORNGUDU_66 SUTTUR_66	5:57	6:06	0:09	LINE FAULT
134	6-Apr-21	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66	5:36	5:45	0:09	LINE FAULT
135	6-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN: LINE FAULT
136	6-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
137	6-Apr-21	MYSURU	66	KR PETE 220- MAHADESHWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	14:28	14:31	0:02	LINE FAULT
138	6-Apr-21	MYSURU	66	RK NAGARA-KADAKOLA	NO STATION EFFECTED	21:46 (06/04/2021)			LINE OPEN:LINE CLEAR AVAILED
139	6-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	7:28	7:33	0:05	LINE FAULT
140	6-Apr-21	MYSURU	66	TUBINKERE-MANDYA 2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	6:10	6:20	0:10	LINE FAULT
141	6-Apr-21	MYSURU	66	TUBINKERE-MANDYA 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66	6:10	6:21	0:11	LINE FAULT
142	6-Apr-21	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	5:46	5:59	0:13	LINE FAULT
143	6-Apr-21	TUMKUR	66	ANCHEPALYA 220- ANCHEPALYA 2	KUDUR_66, HULLENHALLI_66	13:59	14:13	0:13	LINE FAULT
144	6-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,	13:48	14:15	0:26	LINE FAULT
145	6-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- ANCHEPALYA1	ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66	13:59	14:01	0:01	LINE FAULT
146	6-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	13:59	14:04	0:04	LINE FAULT
147	6-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	13:59	14:15	0:15	LINE FAULT
148	6-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- T G HALLI	MAGADI_66, TGHALLI_66, VGDODDI_66	13:59	14:15	0:15	LINE FAULT
149	6-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	13:59	14:15	0:15	LINE FAULT
150	6-Apr-21	TUMKUR	66	CHIKKABANAGERE- GLOBAL TECKPARK	GLOBAL TECKPARK_IPP_66	18:09	18:59	0:49	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
151	6-Apr-21	TUMKUR	66	CHITRADURGA 220kv- PANDARAHALLI 1	HIREGUNTANUR_66,SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	10:20	11:09	0:49	LOAD CURTAILMENT
152	6-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66,SOKKE_66	6:30	6:50	0:19	LINE FAULT
153	6-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66,SOKKE_66	11:32	11:48	0:15	LINE FAULT
154	6-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	20:19(1.4.21)			LOAD CURTAILMENT
155	6-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66,BASAVAPATNA_66, SANTEBENNUR_66	12:05	12:15	0:10	LINE FAULT
156	6-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66,BASAVAPATNA_66, SANTEBENNUR_66	13:25	13:35	0:10	LINE FAULT
157	6-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66,BASAVAPATNA_66, SANTEBENNUR_66	12:05	12:23	0:18	LINE FAULT
158	6-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66,BASAVAPATNA_66, SANTEBENNUR_66	13:25	13:36	0:11	LINE FAULT
159	6-Apr-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	12:05	12:10	0:05	LINE FAULT
160	6-Apr-21	TUMKUR	66	MADHUGIRI 220kv- PULAMAGATTA	PULAMG_66	18:56	19:10	0:13	LINE FAULT
161	6-Apr-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	18:18	20:36	2:17	LINE CLEAR AVAILED
162	6-Apr-21	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR2	WELSPUNSOLAR2_IPP_66	18:18	20:36	2:17	LINE CLEAR AVAILED
163	6-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	13:48	13:52	0:04	TRANSFORMER FAULT
164	6-Apr-21	TUMKUR	66	TR-1	HDPURA_66	23:22	23:27	0:04	TRANSFORMER FAULT
165	6-Apr-21	TUMKUR	66	TR-1	KORATAGERE_66	11:47	19:27	7:39	LINE CLEAR AVAILED
166	6-Apr-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	11:45	11:47	0:02	TRANSFORMER FAULT
167	6-Apr-21	TUMKUR	66	TR-1	KANCHIPURA_66	15:59	16:05	0:05	TRANSFORMER FAULT
168	6-Apr-21	TUMKUR	66	TR-1 & 2 LV SIDE	ANCHEPALYA_220	13:47	14:00	0:12	TRANSFORMER FAULT
169	6-Apr-21	TUMKUR	66	TR-2	CHITRADURGA_66	13:04	15:15	2:10	LINE CLEAR AVAILED
170	6-Apr-21	TUMKUR	66	TR-2	MAVINAKATTE_66	13:46	13:50	0:04	TRANSFORMER FAULT
171	6-Apr-21	TUMKUR	66	TR-2	RANGANATHAPURA_66	10:40	10:50	0:09	TRANSFORMER FAULT
172	6-Apr-21	TUMKUR	66	TR-2	RANGANATHAPURA_66	10:40	10:50	0:09	TRANSFORMER FAULT
173	6-Apr-21	TUMKUR	110	NITTUR 220kv- SOMALAPURA	NITTUR_220	4:30	7:30	3:00	LOAD CURTAILMENT
174	6-Apr-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	11:07	17:28	6:21	LOAD CURTAILMENT
175	6-Apr-21	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	11:02	13:05	2:03	LINE CLEAR AVAILED
176	6-Apr-21	TUMKUR	220	TR-2	ANCHEPALYA_220	13:49	14:00	0:10	TRANSFORMER FAULT
177	7-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
178	7-Apr-21	BAGALKOT	110	110/11KV, HV2	MURDESHWAR_110	09:59	13:16	3:17	LINE CLEAR AVAILED
179	7-Apr-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110	07:31	08:02	0:31	LINE CLEAR AVAILED
180	7-Apr-21	BAGALKOT	110	110/11KV, HV3	JAMKHANDI_110	10:58	11:16	0:18	LINE CLEAR AVAILED
181	7-Apr-21	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	10:54	12:00	1:06	LINE CLEAR AVAILED
182	7-Apr-21	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	18:31	18:35	0:04	HAND TRIPPED
183	7-Apr-21	BAGALKOT	110	110/11KV,HV1	ATHANI_220	9:34	9:55	0:21	TRANSFORMER FAULT
184	7-Apr-21	BAGALKOT	110	110/11KV,HV1	ATHANI_220	10:12	10:19	0:07	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
185	7-Apr-21	BAGALKOT	110	110/11KV,HV2	ANKOLA_110	10:00	12:39	2:39	LINE CLEAR AVAILED
186	7-Apr-21	BAGALKOT	110	110/33KV, HV2	HANGAL_110, BOMMANAHALLI_33, BELAGALPET_33	09:27	09:38	0:11	TRANSFORMER FAULT
187	7-Apr-21	BAGALKOT	110	110/33KV, HV4	LAKMANHALLI_110, ALNAVAR_33	14:37	14:42	0:05	TRANSFORMER FAULT
188	7-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	10:59	11:06	0:07	TRANSFORMER FAULT
189	7-Apr-21	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	9:06	9:30	0:24	LINE FAULT
190	7-Apr-21	BAGALKOT	110	ATHANI-BALIGERI	BALIGERI_110	9:34	9:53	0:19	LINE FAULT
191	7-Apr-21	BAGALKOT	110	ATHANI-BALIGERI	BALIGERI_110	10:12	10:17	0:05	LINE FAULT
192	7-Apr-21	BAGALKOT	110	ATHANI-SATTI	SATTI_110	9:34	9:53	0:19	LINE FAULT
193	7-Apr-21	BAGALKOT	110	ATHANI-SATTI	SATTI_110	10:12	10:19	0:07	LINE FAULT
194	7-Apr-21	BAGALKOT	110	ATHARGA-KN SOLAR	ATHARGA_110 (STATION NOT AFFECTED)	5:03	5:37	0:34	LINE FAULT
195	7-Apr-21	BAGALKOT	110	BELGAUM220- VODAGOAN	VODAGOAN_110	12:51	13:11	0:20	HAND TRIPPED
196	7-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	BETAGERI (STATION NOT AFFECTED)	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
197	7-Apr-21	BAGALKOT	110	BIJAPUR-ENERCON(BAGEWADI)	BIJAPUR_220	6:29	6:33	0:04	LINE FAULT
198	7-Apr-21	BAGALKOT	110	DAMBAL-SAMBAPUR ROAD(GADAG)	DAMBAL_110 (STATION NOT AFFECTED)	10:08	17:05	6:57	LINE CLEAR AVAILED
199	7-Apr-21	BAGALKOT	110	GADAG220- SAMBAPUR ROAD	SAMBAPUR ROAD_110	10:03	18:20	8:17	LINE CLEAR AVAILED
200	7-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
201	7-Apr-21	BAGALKOT	110	GHATAPRABHA220- GHATAPRABHA2	GHATAPRABHA_110	5:13	5:24	0:11	LINE FAULT
202	7-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
203	7-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)			LINE OPEN:LINE CLEAR AVAILED
204	7-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
205	7-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	8:44	8:51	0:07	LINE FAULT
206	7-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
207	7-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
208	7-Apr-21	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	01:15	01:36	0:21	LINE FAULT
209	7-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
210	7-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
211	7-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
212	7-Apr-21	BAGALKOT	220	BAGEWADI-FORTUNE FIVE 2	BAGEWADI_220	16:02	18:47	2:45	LINE CLEAR AVAILED
213	7-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:31 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
214	7-Apr-21	BAGALKOT	220	BIDNAL-HARTI 1	BIDNAL_220	19:03 (06.04.2021)	8:23 (07.04.2021)	13:20	LINE CHARGED
215	7-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
216	7-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
217	7-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
218	7-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
219	7-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
220	7-Apr-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	SOUDATTI_220	08:15	13:06	4:51	LOAD CURTAILMENT
221	7-Apr-21	BAGALKOT	220	VAJRAMATTI- KUDAGI1&2	VAJRAMATTI_220	14:32 (06.04.2021)	16:17 (07.04.2021)	25:45 hrs	LINE CHARGED
222	7-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
223	7-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
224	7-Apr-21	BAGALKOT	400	DHONI- GUTTUR	STATION NOT AFFECTED DHONI_400	10:59	16:10	5:11	LINE CLEAR AVAILED
225	7-Apr-21	BENGALURU	66	HANUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	18:35	18:40	00:05	LOAD CHANGEOVER
226	7-Apr-21	BENGALURU	66	HANUMANTHNAGAR - YEDUMADU	HANUMANTHNAGAR	13:00	13:10	00:10	LOAD CHANGEOVER
227	7-Apr-21	BENGALURU	66	HOSKOTE 220 - VIDYANAGAR	GRINDWELL EHT	06:18	06:40	00:22	LINE FAULT
228	7-Apr-21	BENGALURU	66	HV1	JIGANI LINK ROAD	11:53	13:53	02:00	LINE CLEAR AVAILED
229	7-Apr-21	BENGALURU	66	HV1	KGF	11:30	11:50	00:20	LINE CLEAR AVAILED
230	7-Apr-21	BENGALURU	66	HV1	NIMHANS 220	13:57	14:05	00:08	MAIN SUPPLY FAILURE
231	7-Apr-21	BENGALURU	66	HV2	BMTC	10:35	10:46	00:10	LINE CLEAR AVAILED
232	7-Apr-21	BENGALURU	66	HV2	JIGANI LINK ROAD	12:46	12:56	00:10	LINE CLEAR AVAILED
233	7-Apr-21	BENGALURU	66	HV2	MAASTHI	10:35	10:42	00:06	TRANSFORMER FAULT
234	7-Apr-21	BENGALURU	66	HV2	NIMHANS 220	13:57	14:05	00:08	MAIN SUPPLY FAILURE
235	7-Apr-21	BENGALURU	66	HV3	JIGANI LINK ROAD	14:40	14:45	00:05	LINE CLEAR AVAILED
236	7-Apr-21	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	06:15	06:21	00:06	LINE FAULT
237	7-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	06:15	06:20	00:05	LINE FAULT
238	7-Apr-21	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI	13:57	14:05	00:08	MAIN SUPPLY FAILURE
239	7-Apr-21	BENGALURU	66	NIMHANS 220 - BMTC	BMTC, NATIONAL COLLEGE	13:57	14:05	00:08	MAIN SUPPLY FAILURE
240	7-Apr-21	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	13:57	14:05	00:08	MAIN SUPPLY FAILURE
241	7-Apr-21	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	13:57	14:07	00:10	MAIN SUPPLY FAILURE
242	7-Apr-21	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	10:27	10:36	00:08	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
243	7-Apr-21	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	10:27	10:36	00:08	MAIN SUPPLY FAILURE
244	7-Apr-21	BENGALURU	66	SUBRAMANYAPURA 220 - SOMANAHALLI 2	SHOBHA FOREST, BRIGADE	10:27	10:36	00:08	MAIN SUPPLY FAILURE
245	7-Apr-21	BENGALURU	66	YEDUMADU - KANAKAPURA	YEDUMADU, HANUMANTHNAGAR	18:35	18:37	00:02	LOAD CHANGEOVER
246	7-Apr-21	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU, HANUMANTHNAGAR	13:00	13:10	00:10	LOAD CHANGEOVER
247	7-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
248	7-Apr-21	BENGALURU	220	HV1	NIMHANS 220	13:57	14:05	00:08	MAIN SUPPLY FAILURE
249	7-Apr-21	BENGALURU	220	HV2	NIMHANS 220	13:57	14:05	00:08	MAIN SUPPLY FAILURE
250	7-Apr-21	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	10:10	13:40	03:30	LINE CLEAR AVAILED
251	7-Apr-21	GULBARGA	66	HANASI-MUNIRABAD	HANASI_66	18:50	19:00	00:10	LINE FAULT
252	7-Apr-21	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110	19:08	19:14	00:06	LINE FAULT
253	7-Apr-21	GULBARGA	110	HV1	HUMNABAD_220	05:26	13:01	07:35	TRANSFORMER FAULT
254	7-Apr-21	GULBARGA	110	HV1	KUSHTAGI_220	00:00	17:55	17:55	TRANSFORMER FAULT
255	7-Apr-21	GULBARGA	110	HV1	SHAHAPUR_220	18:32(06.04.2021)	16:06(07.04.2021)	21:34HRS	TRANSFORMER CHARGED
256	7-Apr-21	GULBARGA	110	HV1	SHAHAPUR_220	18:16	18:25	00:09	LINE CLEAR AVAILED
257	7-Apr-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:05	19:10	00:05	LINE FAULT
258	7-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	03:45	03:55	00:10	LINE FAULT
259	7-Apr-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	11:41	11:50	00:09	LINE FAULT
260	7-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	17:45	24:00:00	06:15	LOAD CURTAILMENT
261	7-Apr-21	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VALKAMDINNI_110	07:45	07:49	00:04	LINE CLEAR AVAILED
262	7-Apr-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	10:08	17:25	07:17	LINE CLEAR AVAILED
263	7-Apr-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	10:08	12:40	02:32	LINE CLEAR AVAILED
264	7-Apr-21	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	04:30	04:55	00:25	LINE FAULT
265	7-Apr-21	GULBARGA	220	HV1	ALIPUR_220	23:45(06.04.2021)	3:12(07.04.2021)	03:27	TRANSFORMER CHARGED
266	7-Apr-21	GULBARGA	220	HV1	KUSHTAGI_220	15:25	17:55	02:30	LINE CLEAR AVAILED
267	7-Apr-21	GULBARGA	220	HV1	RAICHUR_220	09:15	10:49	01:34	LINE CLEAR AVAILED
268	7-Apr-21	HASSAN	66	HV1	ALDUR_66	22:31	22:53	00:22	TRANSFORMER FAULT
269	7-Apr-21	HASSAN	66	HV1	HOLEHONNUR_66	15:33(5.4.2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
270	7-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
271	7-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
272	7-Apr-21	HASSAN	66	MRSSHM-TAVARECHATNAHALLY	MRSMSG_220	11:18	11:21	00:03	LINE FAULT
273	7-Apr-21	HASSAN	66	MRSSHM-TAVARECHATNAHALLY	MRSMSG_220	11:30	14:36	03:06	LINE CLEAR AVAILED
274	7-Apr-21	HASSAN	66	TAVAREC-HANNALLI	TAVARECHATNAHALLY_66	11:24	14:54	03:30	MAIN SUPPLY FAILURE
275	7-Apr-21	HASSAN	66	TAVAREC-MRS	TAVARECHATNAHALLY_66	11:58	14:54	02:56	MAIN SUPPLY FAILURE
276	7-Apr-21	HASSAN	110	ARSK2-GANDSI	ARASIKERE_220	04:55	05:09	00:14	LINE FAULT
277	7-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	14:35	15:30	00:55	LINE FAULT
278	7-Apr-21	HASSAN	110	HV1	GURUVAYANAKERE_110	09:59	10:05	00:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
279	7-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	14:35	15:30	00:55	LINE FAULT
280	7-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	09:56	10:05	00:09	HAND TRIPPED
281	7-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	17:14	17:22	00:08	HAND TRIPPED
282	7-Apr-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	13:12	13:37	00:25	MAIN SUPPLY FAILURE
283	7-Apr-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	13:11	13:37	00:26	MAIN SUPPLY FAILURE
284	7-Apr-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	13:29	13:52	00:23	MAIN SUPPLY FAILURE
285	7-Apr-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	13:12	13:35	00:23	MAIN SUPPLY FAILURE
286	7-Apr-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	13:12	13:41	00:29	MAIN SUPPLY FAILURE
287	7-Apr-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	15:23	16:36	01:13	LINE CLEAR AVAILED
288	7-Apr-21	HASSAN	220	MRSSHM-HONNALLI	MRSMSG_220	13:05(6.4.2021)	9:44(7.4.2021)	20:39hrs	LINE CHARGED
289	7-Apr-21	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	10:16	16:33	06:17	LINE CLEAR AVAILED
290	7-Apr-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	10:16	16:33	06:17	LINE CLEAR AVAILED
291	7-Apr-21	MYSURU	66	CR NAGARA-CHANDAKAWADI	CHANDAKAVADI_66	16:17	16:27	0:10	LINE FAULT
292	7-Apr-21	MYSURU	66	DATAGALLI-RK NAGARA	NO STATION EFFECTED	8:52	19:15	10:22	LOAD CHANGE OVER
293	7-Apr-21	MYSURU	66	HV1	BILIKERE_66	12:34	13:54	1:20	LINE CLEAR AVAILED
294	7-Apr-21	MYSURU	66	HV1	JYOTHINAGARA_66	18:08	18:53	0:44	TRANSFORMER FAULT
295	7-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
296	7-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
297	7-Apr-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATION EFFECTED	18:56	19:15	0:18	LINE FAULT
298	7-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN: LINE FAULT
299	7-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
300	7-Apr-21	MYSURU	66	KUNTHUR-DR PETE	NO STATION EFFECTED	2:14	2:23	0:08	LINE FAULT
301	7-Apr-21	MYSURU	66	MUGUR -THAYUR	THAYURU_66 TNARASIPURA_66	2:15	2:20	0:05	LINE FAULT
302	7-Apr-21	MYSURU	66	RK NAGARA-KADAKOLA	NO STATION EFFECTED	21:46 (06/04/2021)	8:52 (07/04/2021)	11:05 HRS	LINE CHARGED
303	7-Apr-21	MYSURU	66	SFC SIVA-PGL	NO STATION EFFECTED	18:50	19:01	0:11	LINE FAULT
304	7-Apr-21	MYSURU	66	SFC SIVA-SATHEGALA	NO STATION EFFECTED	18:50	19:04	0:14	LINE FAULT
305	7-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:07	10:12	0:05	LINE FAULT
306	7-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- AMRUTHUR	AMRUTHUR_66, SANTEMNAVATTUR_66,	17:11	18:20	1:08	LOAD CURTAILMENT
307	7-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	06:35	06:46	0:11	LINE FAULT
308	7-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	13:04	13:15	0:11	LINE FAULT
309	7-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	8:19:25 PM (FROM 1.4.2021)			LOAD CURTAILMENT
310	7-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:20	13:35	0:15	LINE FAULT
311	7-Apr-21	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:20	13:30	0:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
312	7-Apr-21	TUMKUR	66	KUKKAWADA-LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	08:30	08:40	0:10	LINE FAULT
313	7-Apr-21	TUMKUR	66	MADHUGIRI 66KV-BADAVANAHALLI	MADHUGIRI_66	06:52	07:10	0:18	LOAD CURTAILMENT
314	7-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	18:16	18:21	0:05	TRANSFORMER FAULT
315	7-Apr-21	TUMKUR	66	TR-1	SHYLAPURA_66	09:21	09:26	0:04	TRANSFORMER FAULT
316	7-Apr-21	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	12:20	14:45	2:25	LINE CLEAR AVOIDED
317	7-Apr-21	TUMKUR	110	NITTUR 220kv- KG TEMPLE	KGTEMPLE_110, UNGRA_110	16:26	16:58	0:32	LINE FAULT
318	7-Apr-21	TUMKUR	110	TR-1	HUNSEGHATTA_110	12:19	12:24	0:04	HAND TRIPPED
319	7-Apr-21	TUMKUR	110	TR-1	NITTUR_220	10:21	15:48	5:27	LINE CLEAR AVOIDED
320	7-Apr-21	TUMKUR	110	TR-1(LV-1)	NITTUR_220	17:08	18:18	1:09	LINE CLEAR AVOIDED
321	7-Apr-21	TUMKUR	220	DAVANGERE SRS- HONNALI 220	HONNALLI_220	10:24	13:00	2:36	LINE CLEAR AVOIDED
322	7-Apr-21	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	10:26	13:01	2:35	LINE CLEAR AVOIDED
323	7-Apr-21	TUMKUR	220	HONNALLI 220kv- DAVANAGERE 220kv	HONNALLI_220	09:45	17:36	7:51	LOAD CURTAILMENT
324	8-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOIDED
325	8-Apr-21	BAGALKOT	110	110/11KV, HV1	RANNABELAGALI_110	00:36	00:39	0:03	HAND TRIPPED
326	8-Apr-21	BAGALKOT	110	110/11KV, HV1	KALADAGI_110	18:29	18:45	0:16	HAND TRIPPED
327	8-Apr-21	BAGALKOT	110	110/11KV, HV1A	JAMKHANDI_110	08:58	09:59	1:01	LINE CLEAR AVOIDED
328	8-Apr-21	BAGALKOT	110	110/11KV, HV1A	JAMKHANDI_110	12:40	13:13	0:33	LINE CLEAR AVOIDED
329	8-Apr-21	BAGALKOT	110	110/11KV, HV2	MUDEDEBIHAL_110	08:25	08:29	0:04	TRANSFORMER FAULT
330	8-Apr-21	BAGALKOT	110	110/11KV, HV2	MUNAVALLI_110	08:23	08:32	0:09	TRANSFORMER FAULT
331	8-Apr-21	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	0:36	0:46	0:10	HAND TRIPPED
332	8-Apr-21	BAGALKOT	110	110/11KV, HV2A	JAMKHANDI_110	08:58	10:00	1:02	LINE CLEAR AVOIDED
333	8-Apr-21	BAGALKOT	110	110/11KV, HV3	JAMKHANDI_110	08:58	10:00	1:02	LINE CLEAR AVOIDED
334	8-Apr-21	BAGALKOT	110	110/11KV, HV1	ATHANI_220	10:52	11:01	0:09	TRANSFORMER FAULT
335	8-Apr-21	BAGALKOT	110	110/11KV, HV2	ANKALI_110	12:20	12:31	0:11	TRANSFORMER FAULT
336	8-Apr-21	BAGALKOT	110	110/11KV, HV2	ANKALI_110	22:12	22:18	0:06	TRANSFORMER FAULT
337	8-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	10:12	10:23	0:11	TRANSFORMER FAULT
338	8-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, ALSANGI_33, NEVARGI_33	15:27	15:33	0:06	TRANSFORMER FAULT
339	8-Apr-21	BAGALKOT	110	110/33KV, HV2	HANAGALL_110 & BOMMANALLI, BELAGALPET_33	22:41	22:50	0:09	TRANSFORMER FAULT
340	8-Apr-21	BAGALKOT	110	ARHANI-SATTI	SATTI_110	10:51	11:04	0:13	LINE FAULT
341	8-Apr-21	BAGALKOT	110	ATHANI-AIGALI	AIGALI_110	11:43	12:21	0:38	LINE FAULT
342	8-Apr-21	BAGALKOT	110	ATHANI-BALIGERI(THAVASI)	BALIGERI_110	10:51	11:04	0:13	LINE FAULT
343	8-Apr-21	BAGALKOT	110	BAGALKOT220- NAVANAGAR1&2	NAVANAGAR_110	09:53	13:21	3:28	LINE CLEAR AVOIDED
344	8-Apr-21	BAGALKOT	110	BAGALKOT-NAVANAGAR1&2	NAVANAGAR(B)_110	09:48	13:14	3:26	LINE CLEAR AVOIDED
345	8-Apr-21	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	10:32	10:41	0:09	LINE FAULT
346	8-Apr-21	BAGALKOT	110	BELGAUM-ANKALAGI	ANKALAGI_110	16:06 (08.04.2021)			LINE OPEN:LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
347	8-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	BETAGERI (STATION NOT AFFECTED)	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
348	8-Apr-21	BAGALKOT	110	CHIKKODI-NIPPANI	NIPPANI_110	10:14	10:22	0:08	LINE FAULT
349	8-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
350	8-Apr-21	BAGALKOT	110	HATTARAGI-DADDI(BELGAUM)	HATTARAGI_110 (STATION NOT AFFECTED)	13:11	14:11	1:00	HAND TRIPPED
351	8-Apr-21	BAGALKOT	110	HATTARAGI-HUKKERI	HATTARAGI_110 (STATION NOT AFFECTED)	12:30	13:11	0:41	HAND TRIPPED
352	8-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
353	8-Apr-21	BAGALKOT	110	HIDIKAL-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	14:11 (30.03.2021)	15:09 (08.04.2021)	216:58 hrs	LINE CHARGED
354	8-Apr-21	BAGALKOT	110	HUDLI-ANKALI	ANKALI_110	16:35	17:12	0:37	LINE FAULT
355	8-Apr-21	BAGALKOT	110	HUKKERI-VS	(STATION NOT AFFECTED) HUKKERI_110	13:14	14:09	0:55	HAND TRIPPED
356	8-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
357	8-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BHUTANAL	BHUTANAL_110	9:52	9:54	0:02	LINE FAULT
358	8-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
359	8-Apr-21	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	18:28 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
360	8-Apr-21	BAGALKOT	110	KIRUVATTI- UMACHAGI	KIRUVATTI_110	18:25	18:27	0:02	HAND TRIPPED
361	8-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
362	8-Apr-21	BAGALKOT	110	KUSHTAGI-GAJENDRAGAD	GAJENDRAGAD_110	10:17	19:17 00:36	9:00	LINE CLEAR AVAILED
363	8-Apr-21	BAGALKOT	110	MAHALINGAPUR- RANNABELGALI	RANNABELAGALI_110	22:00 (07.04.2021)	(08.04.2021)	2:36	LINE CHARGED
364	8-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
365	8-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
366	8-Apr-21	BAGALKOT	110	RANNABELGALI- MUDHOL	MUDHOL_110	22:00 (07.04.2021)	00:36 (08.04.2021)	2:36	LINE CHARGED
367	8-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
368	8-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1&2	GAJENDRAGAD_110	10:18	17:14	6:56	LINE CLEAR AVAILED
369	8-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN: LINE FAULT
370	8-Apr-21	BAGALKOT	110	RON- GAMESHA	RON_110	21:31	21:35	0:04	HAND TRIPPED
371	8-Apr-21	BAGALKOT	110	SANKESHWAR- HUKKERI	HUKKERI_110	11:51	13:54	2:03	LINE CLEAR AVAILED
372	8-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
373	8-Apr-21	BAGALKOT	110	SOUDATTI220- MUNAVALLY	MUNAVALLY_110	08:41	14:51	6:10	LINE FAULT
374	8-Apr-21	BAGALKOT	220	ALAMATTI 2-BAGALKOT	BAGALKOT_220	21:36 (08.04.2021)			LINE OPEN: LINE FAULT
375	8-Apr-21	BAGALKOT	220	BAGALKOT-VAJRAMATTI2	BAGALKOT_220	6:35	8:00	1:25	LINE CLEAR AVAILED
376	8-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	10:31 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED
377	8-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
378	8-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
379	8-Apr-21	BAGALKOT	220	MAHALINGAPUR- SOUDATTI	MAHALINGAPUR_220	15:17	19:54	4:37	LOAD CURTAILMENT
380	8-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
381	8-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
382	8-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
383	8-Apr-21	BAGALKOT	220	SOUDATTI- MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	18:02	19:49	1:47	LINE FAULT
384	8-Apr-21	BAGALKOT	220	VAJRAMATTI- BAGALKOT2	VAJRAMATTI_220	06:06	08:02	1:56	LINE FAULT
385	8-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
386	8-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
387	8-Apr-21	BENGALURU	66	CHANDAPURA - YARANDANAHALLI	CHANDAPURA	19:20	19:24	00:04	LOAD CHANGEVER
388	8-Apr-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	11:31	13:50	02:19	LINE FAULT
389	8-Apr-21	BENGALURU	66	DALASANUR - SRINIVASPURA	YELDUR	15:16	15:43	00:27	LOAD CURTAILMENT
390	8-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	18:10	18:20	00:10	LINE FAULT
391	8-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	06:14	06:40	00:25	LINE FAULT
392	8-Apr-21	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	13:08	14:14	01:06	LINE CLEAR AVAILED
393	8-Apr-21	BENGALURU	66	HV1	HAROBELE	12:35	12:40	00:05	TRANSFORMER FAULT
394	8-Apr-21	BENGALURU	66	HV1	MUDIYANUR	11:20	11:25	00:05	LINE CLEAR AVAILED
395	8-Apr-21	BENGALURU	66	HV2	APPAREL PARK	20:29	20:47	00:17	TRANSFORMER FAULT
396	8-Apr-21	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	11:10	11:25	00:15	LINE FAULT
397	8-Apr-21	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	18:03	18:10	00:06	LINE FAULT
398	8-Apr-21	BENGALURU	220	BEGUR 220 - HOODY 220	NO STATION AFFECTED	13:33	15:32	01:59	LINE FAULT
399	8-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
400	8-Apr-21	BENGALURU	220	MALUR 220 - HOODY 400	SARJAPURA 220, VIKAS TEC PARK 220	16:34	18:18	01:44	LINE FAULT
401	8-Apr-21	GULBARGA	110	HV2	TEKKALKOTE_110	00:30	00:40	00:10	TRANSFORMER FAULT
402	8-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35(01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
403	8-Apr-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	01:12	01:22	00:10	MAIN SUPPLY FAILURE
404	8-Apr-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	04:03	04:13	00:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
405	8-Apr-21	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	05:16	05:40	00:24	MAIN SUPPLY FAILURE
406	8-Apr-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	08:17	17:07	08:50	LINE CLEAR AVAILED
407	8-Apr-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADO NA_110,SRERAMNAGAR_110,MALLAP URA_110	10:50	11:00	00:10	LINE FAULT
408	8-Apr-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	18:34(08.04.2021)			LINE OPEN: LINE FAULT
409	8-Apr-21	HASSAN	66	ARAKAL-HASSAN	ARAKALGUD_66	06:08	06:28	00:20	MAIN SUPPLY FAILURE
410	8-Apr-21	HASSAN	66	DUDDA-BASAVAGHATTA	DUDDA_66	10:50	12:45	01:55	LINE CLEAR AVAILED
411	8-Apr-21	HASSAN	66	DUDDA-CKNDGL	DUDDA_66	10:51	12:31	01:40	LINE CLEAR AVAILED
412	8-Apr-21	HASSAN	66	HASSN220-ARAKALGUD	HASSAN_220	06:08	06:26	00:18	LINE FAULT
413	8-Apr-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:25	13:06	01:41	LINE CLEAR AVAILED
414	8-Apr-21	HASSAN	66	HV1	HNPURA_66	11:18	12:47	01:29	LINE CLEAR AVAILED
415	8-Apr-21	HASSAN	66	HV1	HOLEHONUR_66	15:33(5.4.2021)	12:31(8.4.2 021)	69:08hrs	TRANSFORMER CHARGED
416	8-Apr-21	HASSAN	66	HV1	KUDLIGERE_66	14:34	15:38	01:04	LINE CLEAR AVAILED
417	8-Apr-21	HASSAN	66	HV1	KUDLIGERE_66	17:11	17:12	00:01	MAIN SUPPLY FAILURE
418	8-Apr-21	HASSAN	66	HV1	MOSALEHOSAHALLI_66	11:29	12:55	01:26	NFBC ISSUED
419	8-Apr-21	HASSAN	66	HV2	HNPURA_66	12:06	13:40	01:34	LINE CLEAR AVAILED
420	8-Apr-21	HASSAN	66	HV2	HOLEHONUR_66	12:34	12:43	00:09	MAIN SUPPLY FAILURE
421	8-Apr-21	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	17:10	17:15	00:05	MAIN SUPPLY FAILURE
422	8-Apr-21	HASSAN	66	LV2	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
423	8-Apr-21	HASSAN	66	LV4	MRSMG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
424	8-Apr-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSAHALLI_66	11:29	12:54	01:25	NFBC ISSUED
425	8-Apr-21	HASSAN	66	MRRSH-DVG2	MRSMG_220	17:08	17:12	00:04	LINE FAULT
426	8-Apr-21	HASSAN	66	MRRSH-DVG2	MRSMG_220	18:07	18:13	00:06	LINE FAULT
427	8-Apr-21	HASSAN	66	MRRSH-DVG2	MRSMG_220	22:09	22:23	00:14	LINE FAULT
428	8-Apr-21	HASSAN	66	MRRSH-HOLUR	MRSMG_220	12:31	12:41	00:10	LINE FAULT
429	8-Apr-21	HASSAN	110	HV1	ARASIKERE_110	16:25	17:13	00:48	LINE CLEAR AVAILED
430	8-Apr-21	HASSAN	110	HV2	ARASIKERE_110	16:25	17:03	00:38	LINE CLEAR AVAILED
431	8-Apr-21	HASSAN	110	HV2	KULASHEKARA_110	10:15	15:16	05:01	LINE CLEAR AVAILED
432	8-Apr-21	HASSAN	110	KADUR-NGNHL	KADUR_220	04:03	04:20	00:17	LINE FAULT
433	8-Apr-21	HASSAN	110	LV1	MSEZ_220	11:15	15:04	03:49	LINE CLEAR AVAILED
434	8-Apr-21	HASSAN	110	LV2	MSEZ_220	09:44	11:14	01:30	LINE CLEAR AVAILED
435	8-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	12:36	12:39	00:03	HAND TRIPPED
436	8-Apr-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	12:30	13:55	01:25	LINE CLEAR AVAILED
437	8-Apr-21	HASSAN	220	HV1	MSEZ_220	11:15	15:04	03:49	LINE CLEAR AVAILED
438	8-Apr-21	HASSAN	220	HV2	MSEZ_220	09:44	11:13	01:29	LINE CLEAR AVAILED
439	8-Apr-21	MYSURU	66	CHANDAKAWADI-CR NAGARA	CHANDAKAVADI_66	9:13	10:50	1:36	LINE CLEAR AVAILED
440	8-Apr-21	MYSURU	66	DK MAIDANA-KADAKOLA	NO STATION EFFECTED	17:20	18:15	0:54	LOAD CHANGE OVER
441	8-Apr-21	MYSURU	66	HV1	AKKIHEBBAL_66	16:04	17:38	1:34	LINE CLEAR AVAILED
442	8-Apr-21	MYSURU	66	HV1	CHANDAKAVADI_66	14:52	18:02	3:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
443	8-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
444	8-Apr-21	MYSURU	66	HV2	AKKIHEBBAL_66	5:24	5:32	0:07	TRANSFORMER FAULT
445	8-Apr-21	MYSURU	66	HV2	AKKIHEBBAL_66	17:02	17:28	0:26	LINE CLEAR AVAILED
446	8-Apr-21	MYSURU	66	HV2	DODDINADUVADI_66	10:30	15:32	5:02	LINE CLEAR AVAILED
447	8-Apr-21	MYSURU	66	HV2	SATHEGALA_66	6:37	7:00	0:22	TRANSFORMER FAULT
448	8-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
449	8-Apr-21	MYSURU	66	KIADB MANDYA-MADDUR	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66 K HONNALGERE_66	13:30	14:05	0:35	HAND TRIPPED
450	8-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN: LINE FAULT
451	8-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
452	8-Apr-21	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATION EFFECTED	18:21	18:27	0:05	LINE FAULT
453	8-Apr-21	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	0:00	8:46	8:46	LINE FAULT
454	8-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:27	10:34	0:07	LINE FAULT
455	8-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	11:10	11:17	0:07	LINE FAULT
456	8-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI_66	10:22	10:28	0:06	LINE FAULT
457	8-Apr-21	MYSURU	66	VAJMANGALA-MEGALAPURA	MEGALAPURA_66	10:14	17:55	7:41	NFBC ISSUED
458	8-Apr-21	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	09:31	10:09	00:38	HAND TRIPPED
459	8-Apr-21	TUMKUR	66	H D PURA- MMCLWINDMILL	MMCLWINDMILL_IPP_66	09:30	11:12	01:41	LINE CLEAR AVAILED
460	8-Apr-21	TUMKUR	66	H D PURA- SUZLON1_IPP_66	SUZLON1_IPP_66	09:30	10:10	00:39	HAND TRIPPED
461	8-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	8:19:25 PM (FROM 01.04.2021)			LOAD CURTAILMENT
462	8-Apr-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	18:18	18:32	00:13	MAIN SUPPLY FAILURE
463	8-Apr-21	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	08:30	08:36	00:06	LINE FAULT
464	8-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	12:51	12:54	00:03	LINE FAULT
465	8-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	18:59	19:06	00:07	LINE FAULT
466	8-Apr-21	TUMKUR	66	THOVINAKERE-ANTHRASANAHALLI	THOVINAKERE_66	13:29	13:45	00:15	LINE FAULT
467	8-Apr-21	TUMKUR	66	TR-1	BENKIKERE_66	19:06	19:09	00:02	TRANSFORMER FAULT
468	8-Apr-21	TUMKUR	66	TR-1	CHANNAGIRI_66	10:15	10:21	00:05	TRANSFORMER FAULT
469	8-Apr-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	08:20	09:03	00:42	LINE CLEAR AVAILED
470	8-Apr-21	TUMKUR	66	TR-1	HALURAMESHWARA_66	08:52	08:56	00:03	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
471	8-Apr-21	TUMKUR	66	TR-1	HDPURA_66	09:31	10:00	00:29	HAND TRIPPED
472	8-Apr-21	TUMKUR	66	TR-1	KORATAGERE_66	06:20	06:52	00:32	TRANSFORMER FAULT
473	8-Apr-21	TUMKUR	66	TR-2	SASALUHALLA_66	09:27	10:07	00:40	LINE CLEAR AVAILED
474	8-Apr-21	TUMKUR	66	TR-2	TAVAREKERE(C)_66	19:26	19:54	00:27	TRANSFORMER FAULT
475	8-Apr-21	TUMKUR	66	TT-1	PAVAGADA_220	08:59	09:04	00:04	TRANSFORMER FAULT
476	8-Apr-21	TUMKUR	110	TR-1(LV SIDE	NITTUR_220	17:17	17:41	00:23	LINE CLEAR AVAILED
477	8-Apr-21	TUMKUR	110	TR-2(LV SIDE)	NITTUR_220	09:03	17:14	08:11	LINE CLEAR AVAILED
478	8-Apr-21	TUMKUR	220	GUTUR_400-NEELAGUNDA	NEELAGUNDA_220	14:43	17:40	02:56	LINE CLEAR AVAILED
479	8-Apr-21	TUMKUR	220	TR-1(HV SIDE)	NITTUR_220	17:17	17:39	00:22	LINE CLEAR AVAILED
480	8-Apr-21	TUMKUR	220	TR-2(HV SIDE)	NITTUR_220	09:02	17:12	08:09	LINE CLEAR AVAILED
481	9-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVAILED
482	9-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED SHIRGAON	12:15	12:47	0:32	LINE CLEAR AVAILED
483	9-Apr-21	BAGALKOT	110	110/11KV, HV1	STATION NOT AFFECTED PH COMPOUND_110	11:25	11:42	0:17	LINE CLEAR AVAILED
484	9-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIROL_110	19:05	19:14	0:09	TRANSFORMER FAULT
485	9-Apr-21	BAGALKOT	110	110/11KV,HV1	AINAPUR_110	7:27	7:40	0:13	TRANSFORMER FAULT
486	9-Apr-21	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	22:03	22:10	0:07	TRANSFORMER FAULT
487	9-Apr-21	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	10:05	17:35	7:30	LINE CLEAR AVAILED
488	9-Apr-21	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	7:27	7:38	0:11	TRANSFORMER FAULT
489	9-Apr-21	BAGALKOT	110	110/33KV, HV4	DULAKHED_33, NEVARGI_33, HALASNGI_33 STATION NOT AFFECTED ZALKI_110	08:34	08:42	0:08	TRANSFORMER FAULT
490	9-Apr-21	BAGALKOT	110	110/33KV, HV4	DULAKHED_33, NEVARGI_33, HALASNGI_33 STATION NOT AFFECTED ZALKI_110	17:33	17:48	0:15	TRANSFORMER FAULT
491	9-Apr-21	BAGALKOT	110	110/33KV,HV1	MK HUBLI_110,GANDIGAWADA_33 HANAGAL_110,AKKI	16:28	17:11	0:43	TRANSFORMER FAULT
492	9-Apr-21	BAGALKOT	110	110/33KV,HV2	ALURU_33,BELAGALPETE_33,LAXMIPU R,BOMMANAHALLI_32	10:04	10:16	0:12	TRANSFORMER FAULT
493	9-Apr-21	BAGALKOT	110	110/33KV,HV3	BAGALKOT_220,KATARAKI_33,GADDA NAKERI_33	10:50	11:08	0:18	HAND TRIPPED
494	9-Apr-21	BAGALKOT	110	220/11KV, LV1	VAJJRAMATTI_220	10:29	11:09	0:40	HAND TRIPPED
495	9-Apr-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	STATION NOT AFFECTED AINAPUR_110	5:01	5:28	0:27	LINE FAULT
496	9-Apr-21	BAGALKOT	110	AINAPUR-ATHANI-(AINAPUR LIS)	AINAPUR_110	12:30	15:12	2:42	LINE CLEAR AVAILED
497	9-Apr-21	BAGALKOT	110	AINAPUR-ATHANI-SUGARS	AINAPUR_110	12:29	15:34	3:05	LINE CLEAR AVAILED
498	9-Apr-21	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	17:55	18:15	0:20	LINE FAULT
499	9-Apr-21	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	18:17	19:15	0:58	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
500	9-Apr-21	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	10:50	11:01	0:11	HAND TRIPPED
501	9-Apr-21	BAGALKOT	110	BAGALKOT220-KATARAKI(NEERBUDIHAL)	NEERBUDIHAL_110	10:50	11:13	0:23	HAND TRIPPED
502	9-Apr-21	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	10:50	11:10	0:20	HAND TRIPPED
503	9-Apr-21	BAGALKOT	110	BAGALKOT220-LOKAPUR	LOKAPUR_110	10:50	11:04	0:14	HAND TRIPPED
504	9-Apr-21	BAGALKOT	110	BAGALKOT220-NAVANAGAR1&2	NAVANAGAR_110	10:50	10:51	0:01	HAND TRIPPED
505	9-Apr-21	BAGALKOT	110	BELGAUM-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	16:06 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
506	9-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
507	9-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVAILED
508	9-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
509	9-Apr-21	BAGALKOT	110	HIREHAL-RON	HIREHAL_110,RON_110	9:50	11:17	1:27	LINE CLEAR AVAILED
510	9-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVAILED
511	9-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
512	9-Apr-21	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	18:28 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
513	9-Apr-21	BAGALKOT	110	KUDUCHI220-AINAPUR	AINAPUR_110	12:30	14:44	2:14	LINE CLEAR AVAILED
514	9-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVAILED
515	9-Apr-21	BAGALKOT	110	LOKAPUR-SALAHALLI	SALAHALLI_110	18:34	19:17	0:43	LINE FAULT
516	9-Apr-21	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	14:59	15:24	0:25	LOAD CURTAILMENT
517	9-Apr-21	BAGALKOT	110	MAHALINGAPUR-HIDIKAL	HIDIKAL_110	16:16	16:35	0:19	LOAD CURTAILMENT
518	9-Apr-21	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	19:30 (9.04.2021)			LINE OPEN:LINE CLEAR AVAILED
519	9-Apr-21	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	14:59	15:23	0:24	LOAD CURTAILMENT
520	9-Apr-21	BAGALKOT	110	MAHALINGAPUR-RABAKAVI	RABAKAVI_110	16:18	16:43	0:25	LOAD CURTAILMENT
521	9-Apr-21	BAGALKOT	110	NARAGUND-BPCL IPP	BPCL IPP_110 STATION NOT AFFECTED NARAGUND_110	16:37	16:39	0:02	LINE FAULT
522	9-Apr-21	BAGALKOT	110	NAVALAGUND-KONNUR (NARAGUND)	KONNUR_110	15:40	16:33	0:53	LINE FAULT
523	9-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVAILED
524	9-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
525	9-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
526	9-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
527	9-Apr-21	BAGALKOT	110	RON-GAMESH IPP	GAMESH IPP_110 STATION NOT AFFECTED RON_110,	11:20	11:27	0:07	HAND TRIPPED
528	9-Apr-21	BAGALKOT	110	RON-NAREGAL	NAREGAL_110	10:28	14:21	3:53	LINE CLEAR AVALIED
529	9-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVALIED
530	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-BILAGI	BILAGI_110	05:49	05:59	0:10	LINE FAULT
531	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-BILAGI	BILAGI_110	09:37	11:21	1:44	LINE CLEAR AVALIED
532	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-KATARKI	KATARKI_110	10:00	11:29	1:29	LINE CLEAR AVALIED
533	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-LOKAPUR	LOKAPUR_110	10:06	12:53	2:47	LINE CLEAR AVALIED
534	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-MANTUR1	MANTUR_110	09:37	11:55	2:18	LINE CLEAR AVALIED
535	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-MANTUR2	MANTUR_110	09:37	11:56	2:19	LINE CLEAR AVALIED
536	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-MELLIGERI	MELLIGERI_110	10:00	12:05	2:05	LINE CLEAR AVALIED
537	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-MUDHOL (MANTUR)	MUDHOL_110	09:37	11:53	2:16	LINE CLEAR AVALIED
538	9-Apr-21	BAGALKOT	110	VAJJRAMATTI220-VAJJRAMATTI	VAJJRAMATTI_110	10:00	12:04	2:04	LINE CLEAR AVALIED
539	9-Apr-21	BAGALKOT	220	220/110,HV2,LV2	STATION NOT AFFECTED BELGAUM_220	11:25	12:54	1:29	LINE CLEAR AVALIED
540	9-Apr-21	BAGALKOT	220	220/110,HV2,LV2	GADAG_220	9:24	17:40	8:16	LINE CLEAR AVALIED
541	9-Apr-21	BAGALKOT	220	220/110,HV2,LV2	GADAG_220	8:31	20:49	12:18	LINE CLEAR AVALIED
542	9-Apr-21	BAGALKOT	220	220/110KV, HV1	VAJJRAMATTI_220	10:28	10:36	0:08	HAND TRIPPED
543	9-Apr-21	BAGALKOT	220	220/110KV, HV2	VAJJRAMATTI_220	10:28	10:37	0:09	HAND TRIPPED
544	9-Apr-21	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220,HIDIKAL_110,RA BAKAVI_110	14:22	14:30	0:08	TRANSFORMER FAULT
545	9-Apr-21	BAGALKOT	220	220/110KV,HV3,LV3	MAHALINGAPUR_220,HIDIKAL_110,RA BAKAVI_111	14:45	16:28	1:43	TRANSFORMER FAULT
546	9-Apr-21	BAGALKOT	220	ALAMATTI 1-BAGALKOT	BAGALKOT_220	21:36 (08.04.2021)	12:25 (9.04.2021)	14:49HRS	LINE CHARGED
547	9-Apr-21	BAGALKOT	220	BAGALKOT-ALMATTI2	BAGALKOT_220	9:30	12:23	2:53	LINE CLEAR AVALIED
548	9-Apr-21	BAGALKOT	220	BAGALKOT-GADAG1&2	BAGALKOT_220	10:50	12:29	1:39	MAIN SUPPLY FAILURE
549	9-Apr-21	BAGALKOT	220	BAGALKOT-VAJJRAMATTI1&2	BAGALKOT_220	10:50	10:59	0:09	MAIN SUPPLY FAILURE
550	9-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:31 (05.04.2021)			LINE OPEN:LINE CLEAR AVALIED
551	9-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI2	STATION NOT AFFECTED BELGAUM_220	17:46	22:13	4:27	LINE FAULT
552	9-Apr-21	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	17:39	22:11	4:32	LINE FAULT
553	9-Apr-21	BAGALKOT	220	BIDNAL-HARTI2	STATION NOT AFFECTED BIDNAL_220	14:50	18:16	3:26	LINE FAULT
554	9-Apr-21	BAGALKOT	220	BIDNAL-NAGJHARI2	STATION NOT AFFECTED BIDNAL_220	18:18	19:11	0:53	LINE FAULT
555	9-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVALIED
556	9-Apr-21	BAGALKOT	220	GADAG-BAGALKOT1	STATION NOT AFFECTED GADAG_220	9:30	10:38	1:08	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
557	9-Apr-21	BAGALKOT	220	HAVERI-NARENDRA1	STATION NOT AFFECTED HAVERI_220	12:55	13:37	0:42	LINE CLEAR AVAILED
558	9-Apr-21	BAGALKOT	220	HUBLI-NAGZARI1	STATION NOT AFFECTED HUBLI_220	17:13	17:14	0:01	LINE FAULT
559	9-Apr-21	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	19:00	20:47	1:47	LINE CLEAR AVAILED
560	9-Apr-21	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED HUBLI_220	16:53	20:46	3:53	LINE FAULT
561	9-Apr-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	19:00 (09.04.2021)			LINE OPEN: LINE FAULT
562	9-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
563	9-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	9:38 (09.04.2021)			LOAD CURTAILMENT
564	9-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
565	9-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)			LOAD CURTAILMENT
566	9-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
567	9-Apr-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:54 (09.04.2021)			LINE OPEN: LINE FAULT
568	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-BAGALKOT1	VAJJRAMATTI_220	10:31	10:59	0:28	HAND TRIPPED
569	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-BAGALKOT2	VAJJRAMATTI_220	10:31	11:01	0:30	HAND TRIPPED
570	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-KAVATAGI LIS	VAJJRAMATTI_220, KAVATAGI LIS_220	10:30	10:46	0:16	HAND TRIPPED
571	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-KUDAGI1	VAJJRAMATTI_220	10:30	10:35	0:05	HAND TRIPPED
572	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-KUDAGI1	VAJJRAMATTI_220	15:25	18:13	2:48	LINE CLEAR AVAILED
573	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-KUDAGI2	VAJJRAMATTI_220	10:30	10:36	0:06	HAND TRIPPED
574	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-KUDAGI2	VAJJRAMATTI_220	15:25	18:14	2:49	LINE CLEAR AVAILED
575	9-Apr-21	BAGALKOT	220	VAJJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
576	9-Apr-21	BAGALKOT	220	VAJJRAMATTI-MAAHALINGAPUR2	STATION NOT AFFECTED VAJJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
577	9-Apr-21	BENGALURU	66	BAGHMANE WORLD TECH PARK - ITI 220	BAGHMANE WORLD TECH PARK	13:29	16:33	03:04	LINE CLEAR AVAILED
578	9-Apr-21	BENGALURU	66	EPIP 220 - KADUGODI	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	13:35	13:38	00:03	MAIN SUPPLY FAILURE
579	9-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	05:55	06:05	00:10	LINE FAULT
580	9-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - KODIGENAHALLI	KODIGENAHALLI, ID HALLI	06:45	06:54	00:09	LINE FAULT
581	9-Apr-21	BENGALURU	66	HAL 220 - ISRO (EHT)	ISRO (EHT), NAL (EHT)	13:17	20:56	07:39	LINE CLEAR AVAILED
582	9-Apr-21	BENGALURU	66	HOSKOTE 66 - HOSKOTE 220	HOSKOTE 66	15:05	15:10	00:05	LOAD CHANGEOVER
583	9-Apr-21	BENGALURU	66	HV1	MAHALAKSHMI LAYOUT	12:04	13:00	00:55	LINE CLEAR AVAILED
584	9-Apr-21	BENGALURU	66	HV1	NATIONAL COLLEGE	08:26	08:30	00:03	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
585	9-Apr-21	BENGALURU	66	HV2	APPAREL PARK	15:20	15:30	00:10	TRANSFORMER FAULT
586	9-Apr-21	BENGALURU	66	HV2	KADUGODI	17:15	17:18	00:03	MAIN SUPPLY FAILURE
587	9-Apr-21	BENGALURU	66	HV2	NATIONAL COLLEGE	15:17	15:25	00:07	LINE CLEAR AVAILED
588	9-Apr-21	BENGALURU	66	HV3	EPIP 220	13:36	13:39	00:03	MAIN SUPPLY FAILURE
589	9-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALAHALLI	06:56	07:30	00:33	LINE FAULT
590	9-Apr-21	BENGALURU	66	KEMBODI - NANGALI	MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	00:16	00:47	00:30	LINE CLEAR AVAILED
591	9-Apr-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	09:03	09:13	00:10	LINE FAULT
592	9-Apr-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	09:19	09:27	00:08	LINE FAULT
593	9-Apr-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	13:57	14:17	00:20	LINE FAULT
594	9-Apr-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	09:03	09:13	00:10	LINE FAULT
595	9-Apr-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	09:19	09:27	00:08	LINE FAULT
596	9-Apr-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	13:57	14:20	00:23	LINE FAULT
597	9-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI	21:17	22:26	01:09	LOAD CURTAILMENT
598	9-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI, GUNDLUKOTTURU	19:35	19:40	00:05	LOAD CURTAILMENT
599	9-Apr-21	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI	19:35	19:40	00:05	LOAD CURTAILMENT
600	9-Apr-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHELUR, CHAKAVELU, YENIGADALE	19:35	19:40	00:05	LOAD CURTAILMENT
601	9-Apr-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	12:09	12:50	00:40	MAIN SUPPLY FAILURE
602	9-Apr-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	14:38	15:28	00:50	LOAD CURTAILMENT
603	9-Apr-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	12:06	12:21	00:14	MAIN SUPPLY FAILURE
604	9-Apr-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	13:42	13:48	00:05	LINE FAULT
605	9-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	09:06	09:20	00:14	LINE FAULT
606	9-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	06:00	06:10	00:09	LINE FAULT
607	9-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	09:06	09:20	00:14	LINE FAULT
608	9-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:05	21:13	00:08	LOAD CURTAILMENT
609	9-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:05	21:13	00:08	LOAD CURTAILMENT
610	9-Apr-21	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	TK HALLI 220	12:06	12:24	00:17	LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
611	9-Apr-21	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	HALAGUR, HONNIGANAHALLI, DODDALAHALLI, SATHNUR (ACHLU)	12:38	15:44	03:05	MAIN SUPPLY FAILURE
612	9-Apr-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	07:01	07:23	00:22	LINE FAULT
613	9-Apr-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	06:32	06:45	00:13	LINE FAULT
614	9-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
615	9-Apr-21	BENGALURU	220	HV2	EPIP 220	13:37	13:41	00:03	TRANSFORMER FAULT
616	9-Apr-21	BENGALURU	220	HV2	TK HALLI 220	12:06	12:13	00:06	TRANSFORMER FAULT
617	9-Apr-21	BENGALURU	220	HV2	TK HALLI 220	12:20	12:23	00:03	TRANSFORMER FAULT
618	9-Apr-21	BENGALURU	220	SRS PEENYA 220 - SUBRAMANYAPURA 220	NO STATION AFFECTED	16:10	18:55	02:45	LINE FAULT
619	9-Apr-21	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	18:50	19:10	00:20	LINE FAULT
620	9-Apr-21	GULBARGA	66	TBHALLI-ITTAGGI	TAMBRAHALLI_66	07:20	08:00	00:40	LINE FAULT
621	9-Apr-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	17:10	17:45	00:35	LINE CLEAR AVAILED
622	9-Apr-21	GULBARGA	110	GABUR-RAICHUR	GABUR_110,DEODURGA_110	16:45	16:55	00:10	MAIN SUPPLY FAILURE
623	9-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY-SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)			LINE OPEN:LINE CLEAR AVAILED
624	9-Apr-21	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	16:31	16:34	00:03	LINE CLEAR AVAILED
625	9-Apr-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	23:44	23:53	00:09	LINE FAULT
626	9-Apr-21	GULBARGA	110	HV2	KUDLIGI_220	18:50(09.04.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
627	9-Apr-21	GULBARGA	110	KAPNOOR-GULBARGA WEST	GULBARGA WEST_110	6:35(01.04.2021)	16:29(09.04.2021)	201:54HRS	LINE CHARGED
628	9-Apr-21	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110,NSL SUGAR FACTORY,CHOWDAPUR_110	22:55	23:05	00:10	LINE FAULT
629	9-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALOKD_110	23:38	23:48	00:10	LINE FAULT
630	9-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	20:02	20:15	00:13	LINE FAULT
631	9-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	23:05	23:17	00:12	LINE FAULT
632	9-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	00:00	09:10	09:10	LOAD CURTAILMENT
633	9-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	17:50	24:00:00	06:10	LOAD CURTAILMENT
634	9-Apr-21	GULBARGA	110	SANKLAPUR-MUNIRABAD	SANKLAPUR_110	06:10	06:20	00:10	MAIN SUPPLY FAILURE
635	9-Apr-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	08:36	17:03	08:27	LINE CLEAR AVAILED
636	9-Apr-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	03:15	03:25	00:10	LINE FAULT
637	9-Apr-21	GULBARGA	110	SINDHANOOR110-SINDHANOOR1	SINDHANOOR_110	14:20	15:05	00:45	LINE CLEAR AVAILED
638	9-Apr-21	GULBARGA	110	SINDHANOOR110-SINDHANOOR2	SINDHANOOR_110	13:45	14:20	00:35	LINE CLEAR AVAILED
639	9-Apr-21	GULBARGA	110	SINDHANOOR-RAICHUR2	ADVIMARESHWARA_110	23:36	23:46	00:10	LINE FAULT
640	9-Apr-21	GULBARGA	110	TEKKALKOTE-ABMN_SLR	TEKKALKOTE_110	00:50	00:58	00:08	LINE FAULT
641	9-Apr-21	GULBARGA	220	LINGAPUR-BMM ISPAT	ITTAGI_220	09:14	17:25	08:11	LINE CLEAR AVAILED
642	9-Apr-21	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	18:34(08.04.2021)	8:16(09.04.2021)	13:42HRS	LINE CHARGED
643	9-Apr-21	HASSAN	66	HV1	HOLEHONNUR_66	10:51	11:23	00:32	LINE CLEAR AVAILED
644	9-Apr-21	HASSAN	66	HV2	HOLEHONNUR_66	11:55	12:14	00:19	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
645	9-Apr-21	HASSAN	66	LV2	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
646	9-Apr-21	HASSAN	66	LV4	MRSMSG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
647	9-Apr-21	HASSAN	66	MRSSHM-TAVARECHATNAHALLY	MRSMSG_220	13:53	13:57	00:04	LINE FAULT
648	9-Apr-21	HASSAN	66	MRSSHM-TAVARECHATNAHALLY	MRSMSG_220	15:47	15:52	00:05	LINE FAULT
649	9-Apr-21	HASSAN	66	MRSSHM-TAVARECHATNAHALLY	MRSMSG_220	16:05	16:09	00:04	LINE FAULT
650	9-Apr-21	HASSAN	66	MRSSHM-TAVARECHATNAHALLY	MRSMSG_220	16:13	17:00	00:47	LINE CLEAR AVAILED
651	9-Apr-21	HASSAN	110	BARANG-ANVATTI	BARANGI_110	09:42	09:44	00:02	HAND TRIPPED
652	9-Apr-21	HASSAN	110	BARANG-ANVATTI	BARANGI_110	14:00	14:17	00:17	HAND TRIPPED
653	9-Apr-21	HASSAN	110	HV1	BELGUMBA_110	10:06	14:30	04:24	LINE CLEAR AVAILED
654	9-Apr-21	HASSAN	110	HV2	BELGUMBA_110	10:06	14:30	04:24	LINE CLEAR AVAILED
655	9-Apr-21	HASSAN	110	KADUR-NERELEKERE	KADUR_220	15:41	15:51	00:10	HAND TRIPPED
656	9-Apr-21	HASSAN	110	LV1	MSEZ_220	11:05	13:10	02:05	LINE CLEAR AVAILED
657	9-Apr-21	HASSAN	110	LV2	MSEZ_220	09:51	11:03	01:12	LINE CLEAR AVAILED
658	9-Apr-21	HASSAN	220	HV1	MSEZ_220	11:05	13:10	02:05	LINE CLEAR AVAILED
659	9-Apr-21	HASSAN	220	HV2	MSEZ_220	09:51	11:03	01:12	LINE CLEAR AVAILED
660	9-Apr-21	HASSAN	220	KADUR-SHIMOGA	KADUR_220	15:43	18:46	03:03	LINE CLEAR AVAILED
661	9-Apr-21	MYSURU	66	ELWALA-HUNSUR	GAVADAGERE_66	4:10	4:21	0:11	LINE FAULT
662	9-Apr-21	MYSURU	66	ELWALA-HUNSUR	GAVADAGERE_66	5:22	5:35	0:12	LINE FAULT
663	9-Apr-21	MYSURU	66	ELWALA-HUNSUR	GAVADAGERE_66	5:45	9:48	4:03	LINE FAULT
664	9-Apr-21	MYSURU	66	HOOTAGALLI-HUNSUR	BANNIKUPPE_66 HOSURGATE_66 HUNSUR_66	9:18	9:31	0:13	LINE FAULT
665	9-Apr-21	MYSURU	66	HV1	JYOTHINAGARA_66	11:56	12:09	0:13	HAND TRIPPED
666	9-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	6:02	6:17	0:15	MAIN SUPPLY FAILURE
667	9-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	9:06	9:28	0:22	MAIN SUPPLY FAILURE
668	9-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	12:07	12:25	0:18	MAIN SUPPLY FAILURE
669	9-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	21:11	21:13	0:02	MAIN SUPPLY FAILURE
670	9-Apr-21	MYSURU	66	HV1	KIADBMANDYA_66	9:07	9:23	0:16	MAIN SUPPLY FAILURE
671	9-Apr-21	MYSURU	66	HV1	KIADBMANDYA_66	12:07	12:13	0:05	MAIN SUPPLY FAILURE
672	9-Apr-21	MYSURU	66	HV1	KIADBMANDYA_66	12:21	12:27	0:06	MAIN SUPPLY FAILURE
673	9-Apr-21	MYSURU	66	HV1	KIADBMANDYA_66	21:06	21:15	0:08	MAIN SUPPLY FAILURE
674	9-Apr-21	MYSURU	66	HV1	RAMAPURA_MYS_66	10:22	12:00	1:37	LINE CLEAR AVAILED
675	9-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
676	9-Apr-21	MYSURU	66	HV2	JAIPUR_66	11:13	12:20	1:06	LINE CLEAR AVAILED
677	9-Apr-21	MYSURU	66	HV2	K_HONNALGERE_66	14:38	15:35	0:57	MAIN SUPPLY FAILURE
678	9-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
679	9-Apr-21	MYSURU	66	JAIPURA-KADAKOLA	JAIPUR_66	12:35	13:43	1:08	LINE CLEAR AVAILED
680	9-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN: LINE FAULT
681	9-Apr-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	22:12(10.4.21)			LOAD CURTAILMENT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
682	9-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
683	9-Apr-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66	12:06	17:13	5:07	LINE CLEAR AVAILED
684	9-Apr-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 KR NAGARA_66 DMG HALLI_66	16:18	16:31	0:12	LINE FAULT
685	9-Apr-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 KR NAGARA_66 DMG HALLI_66	13:57	14:13	0:16	LINE FAULT
686	9-Apr-21	MYSURU	66	MADHUVANAHALLI-DODDINADUVADI	DODDINADUVADI_66 KOTTANUR_66	21:21	21:33	0:12	LOAD CURTAILMENT
687	9-Apr-21	MYSURU	66	MADHUVANAHALLI-HANNUR 1	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66 HANNUR_66	21:19	21:32	0:13	LOAD CURTAILMENT
688	9-Apr-21	MYSURU	66	MADHUVANAHALLI-HANNUR 2	BANDALLI_66 COWDALLI_66 MARTAHALLI_66 RAMAPURA_MYS_66 AJJIPURA_66 HANNUR_66	21:19	21:32	0:13	LOAD CURTAILMENT
689	9-Apr-21	MYSURU	66	SFC SIVA-PPCL	NO STATION EFFECTED	17:01	18:59	1:58	LINE CLEAR AVAILED
690	9-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	10:04	10:14	0:10	LINE FAULT
691	9-Apr-21	MYSURU	220	HV1	HOOTAGALLY_220	14:18	14:48	0:30	TRANSFORMER FAULT
692	9-Apr-21	MYSURU	220	HV2	HOOTAGALLY_220	14:18	14:48	0:30	TRANSFORMER FAULT
693	9-Apr-21	TUMKUR	66	ANCHEPALYA 220kv-KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	0:19	0:28	0:08	LOAD CURTAILMENT
694	9-Apr-21	TUMKUR	66	ANCHEPALYA 220kv- YEDIYUR(BG NAGAR)	YEDIYUR_66	17:06	17:20	0:14	LINE FAULT
695	9-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV-CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	23:07	23:58	0:50	LINE FAULT
696	9-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	9:19	9:38	0:19	LINE FAULT
697	9-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:42	12:52	0:10	LINE FAULT
698	9-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:01	14:05	0:04	LINE FAULT
699	9-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:39	14:40	0:01	LINE FAULT
700	9-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:22	16:23	0:01	LINE FAULT
701	9-Apr-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	9:03	12:38	3:35	LINE CLEAR AVAILED
702	9-Apr-21	TUMKUR	66	DEVARAHALLI- NALLUR	DEVARAHALLI_66	14:58	18:57	3:59	MAIN SUPPLY FAILURE
703	9-Apr-21	TUMKUR	66	DEVARAHALLI- NALLUR	DEVARAHALLI_66	14:58	18:57	3:59	MAIN SUPPLY FAILURE
704	9-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	22:58(09.4.21)			LINE OPEN:LINE CLEAR AVAILED
705	9-Apr-21	TUMKUR	66	HOLALKERE-CHIKAJAJUR1	HOLALKERE_66	8:19:25 PM (01.04.2021)	22:58(9.4.21)	75:00HRS	LINE CHARGED
706	9-Apr-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	22:58(09.4.21)			LINE OPEN:LINE CLEAR AVAILED
707	9-Apr-21	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	9:01	14:48	5:46	LINE CLEAR AVAILED
708	9-Apr-21	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	9:10	14:47	5:36	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
709	9-Apr-21	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	14:57	18:53	3:56	LINE CLEAR AVOIDED
710	9-Apr-21	TUMKUR	66	HONNALLI 220kV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	14:48	18:53	4:05	LINE CLEAR AVOIDED
711	9-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	0:35	4:17	3:41	LINE CLEAR AVOIDED
712	9-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	4:17	4:18	0:01	LINE CLEAR AVOIDED
713	9-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	4:18	7:16	2:57	LINE CLEAR AVOIDED
714	9-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	8:02	8:06	0:03	LINE CLEAR AVOIDED
715	9-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	9:55	10:02	0:06	LINE CLEAR AVOIDED
716	9-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	10:08	10:16	0:08	LINE CLEAR AVOIDED
717	9-Apr-21	TUMKUR	66	LINGDAHALLI- NALLUR	LINGDHALLI_66	20:44	20:52	0:08	LINE FAULT
718	9-Apr-21	TUMKUR	66	MALEBENNUR- HONNALLI 220	MALEBENNUR_66	9:10	14:45	5:35	MAIN SUPPLY FAILURE
719	9-Apr-21	TUMKUR	66	SAVALANGA 66kV- HNLI 220_NYMT	SAVALANGA_66	9:43	15:59	6:15	MAIN SUPPLY FAILURE
720	9-Apr-21	TUMKUR	66	SAVALANGA 66kV- HNLI 220_NYMT	SAVALANGA_66	9:43	15:59	6:15	MAIN SUPPLY FAILURE
721	9-Apr-21	TUMKUR	66	TR-1	KORATAGERE_66	12:10	12:20	0:10	TRANSFORMER FAULT
722	9-Apr-21	TUMKUR	66	TR-1	KUNDUR_66	9:40	14:10	4:29	MAIN SUPPLY FAILURE
723	9-Apr-21	TUMKUR	66	TR-1	LINGDHALLI_66	16:10	16:13	0:02	TRANSFORMER FAULT
724	9-Apr-21	TUMKUR	66	TR-1	SHYLAPURA_66	12:13	12:37	0:23	TRANSFORMER FAULT
725	9-Apr-21	TUMKUR	66	TR-1(66kV HV SIDE)	HONNALLI_220	14:48	14:57	0:08	LINE CLEAR AVOIDED
726	9-Apr-21	TUMKUR	66	TR-1(66kV LV SIDE)	HONNALLI_220	14:58	18:52	3:53	LINE CLEAR AVOIDED
727	9-Apr-21	TUMKUR	66	TR-2	KOLALA_66	16:11	16:33	0:22	LINE CLEAR AVOIDED
728	9-Apr-21	TUMKUR	66	TR-2	NAYAKANAHATTI_66	16:14	16:56	0:41	LINE CLEAR AVOIDED
729	9-Apr-21	TUMKUR	66	TR-2	NYAMATHI_66	16:39	18:49	2:09	TRANSFORMER FAULT
730	9-Apr-21	TUMKUR	66	TR-2(66kV HV SIDE)	HONNALLI_220	14:57	19:11	4:13	LINE CLEAR AVOIDED
731	9-Apr-21	TUMKUR	66	TR-2(66kV LV SIDE)	HONNALLI_220	9:41	14:38	4:56	LINE CLEAR AVOIDED
732	9-Apr-21	TUMKUR	66	TR-3	HOLALKERE_66	13:33	13:40	0:06	TRANSFORMER FAULT
733	9-Apr-21	TUMKUR	110	CHIKKANAYAKANAHALLI- HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	8:38	8:54	0:15	LINE FAULT
734	9-Apr-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110	11:12	11:17	0:05	HAND TRIPPED
735	9-Apr-21	TUMKUR	110	KB CROSS 220kV- MAYASANDRA	MAYASANDRA_110, TALKERE_110	11:56	12:05	0:08	HAND TRIPPED
736	9-Apr-21	TUMKUR	110	TR-1	BIDARE_110	10:13	10:48	0:35	LINE CLEAR AVOIDED
737	9-Apr-21	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	18:05	18:15	0:10	TRANSFORMER FAULT
738	9-Apr-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	9:20	17:28	8:07	LINE CLEAR AVOIDED
739	9-Apr-21	TUMKUR	220	THALLAK 220kV- HIRIYUR	THALLAK_220	12:44	12:52	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
740	9-Apr-21	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	14:59	18:51	3:52	LINE CLEAR AVOIDED
741	9-Apr-21	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	11:02	11:16	0:13	TRANSFORMER FAULT
742	9-Apr-21	TUMKUR	220	TR-1(HV SIDE)	KBCROSS_220	11:52	12:03	0:10	TRANSFORMER FAULT
743	10-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOIDED
744	10-Apr-21	BAGALKOT	110	110/11KV ,HV1	STATION NOT AFFECTED ZALKI_110	13:34	20:31	6:57	TRANSFORMER FAULT
745	10-Apr-21	BAGALKOT	110	110/11KV, HV3	STATION NOT AFFECTED TIKOTA_110	06:59	08:38	1:39	LINE CLEAR AVOIDED
746	10-Apr-21	BAGALKOT	110	110/11KV,HV2	MUNAVALLI_110	10:48	11:01	0:13	TRANSFORMER FAULT
747	10-Apr-21	BAGALKOT	110	110/33KV, HV4	DULAKHED_33, NEVARGI_33, HALASNGI_33 STATION NOT AFFECTED ZALKI_110	21:45	22:11	0:26	TRANSFORMER FAULT
748	10-Apr-21	BAGALKOT	110	110/33KV,HV2	HANAGAL_110,AKKI ALURU_33,BELAGALPETE_33,LAXMIPUR, BOMMANAHALLI_33	8:30	20:40	12:10	LINE CLEAR AVOIDED
749	10-Apr-21	BAGALKOT	110	110/KV, HV3	STATION NOT AFFECTED SAVALAGI_110	9:08	9:33	0:25	TRANSFORMER FAULT
750	10-Apr-21	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED AMBEWADI_220	19:58	20:01	0:03	LINE CLEAR AVOIDED
751	10-Apr-21	BAGALKOT	110	BELGAUM-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	16:06 (08.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
752	10-Apr-21	BAGALKOT	110	BELLATTI- AB SOLAR	BELLATTI_110	18:59	22:42	3:43	LINE CLEAR AVOIDED
753	10-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
754	10-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)			LINE OPEN:LINE CLEAR AVOIDED
755	10-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVOIDED
756	10-Apr-21	BAGALKOT	110	HAVERI-HANGAL	HANAGAL_110	8:35	20:36	12:01	LINE CLEAR AVOIDED
757	10-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
758	10-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
759	10-Apr-21	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	18:28 (08.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
760	10-Apr-21	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	12:15	12:16	0:01	HAND TRIPPED
761	10-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
762	10-Apr-21	BAGALKOT	110	MAHALINGAPUR-JAMAKHANDI	JAMAKHANDI_110	19:30 (9.04.2021)	17:52 (10.04.2021)	22:22HRS	LINE CHARGED
763	10-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)			LINE OPEN:LINE CLEAR AVOIDED
764	10-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
765	10-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
766	10-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN: LINE FAULT
767	10-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
768	10-Apr-21	BAGALKOT	110	SIRSI- SIRSI2201 (HUBLI1)	STATION NOT AFFECTED SIRSI_110	15:45	20:08	4:23	LINE FAULT
769	10-Apr-21	BAGALKOT	110	ZALKI_INCHAGERI (CHADACHAN)	INCHAGERI_110	08:06	09:36	1:30	LINE CLEAR AVAILED
770	10-Apr-21	BAGALKOT	220	220/110,HV1,LV1,HV2,LV2	GHATAPRABHA_220,GHATAPRABHA_110,P G HUNSHYAL_110,GOKAK_110,SHIRGOA N_110,KABBUR_110,MANTUR_110	9:30	9:46	0:16	TRANSFORMER FAULT
771	10-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:31 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED
772	10-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
773	10-Apr-21	BAGALKOT	220	HAVERI-GUTTUR1	STATION NOT AFFECTED HAVERI_220	10:16	12:38	2:22	LINE CLEAR AVAILED
774	10-Apr-21	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	19:00 (09.04.2021)	17:30 (10.04.2021)	22:30HRS	LINE CHARGED
775	10-Apr-21	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	10:43	17:37	6:54	LINE CLEAR AVAILED
776	10-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
777	10-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	9:38 (09.04.2021)			LOAD CURTAILMENT
778	10-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
779	10-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	18:38 (13.03.2021)	10:40 (10.04.2021)	664:20HRS	LINE CHARGED
780	10-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	17:31 (10.04.2021)			LOAD CURTAILMENT
781	10-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
782	10-Apr-21	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	17:54 (09.04.2021)	17:30 (10.04.2021)	23:36HRS	LINE CHARGED
783	10-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
784	10-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
785	10-Apr-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	09:15	09:34	00:19	LINE FAULT
786	10-Apr-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	09:51	10:05	00:14	LINE FAULT
787	10-Apr-21	BENGALURU	66	HOSKOTE 66 - HOODY 220	HOSKOTE 66	16:00	16:05	00:05	LOAD CHANGE OVER
788	10-Apr-21	BENGALURU	66	HV1	ALLIMARADANAHALI	10:55	11:15	00:20	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
789	10-Apr-21	BENGALURU	66	HV1	SOUTH CITY	01:40	01:45	00:05	TRANSFORMER FAULT
790	10-Apr-21	BENGALURU	66	HV2	YELAHANKA 220	12:21	12:29	00:08	TRANSFORMER FAULT
791	10-Apr-21	BENGALURU	66	HV2	MAASTHI	09:55	10:05	00:10	LINE CLEAR AVAILED
792	10-Apr-21	BENGALURU	66	ISKON - SOMANAHALLI 220	ISKON	10:32	10:53	00:21	LOAD CHANGEOVER
793	10-Apr-21	BENGALURU	66	ISKON - SUBRAMANYAPURA 220	ISKON	19:55	20:03	00:08	LOAD CHANGEOVER
794	10-Apr-21	BENGALURU	66	ITI 220 - BAGHMANE WTP	BAGHMANE WORLD TECH PARK	04:54	06:50	01:56	LINE FAULT
795	10-Apr-21	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, VANDARGUPPE	11:15	13:30	02:15	LINE CLEAR AVAILED
796	10-Apr-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	14:57	15:02	00:05	LINE FAULT
797	10-Apr-21	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	15:10	19:20	04:09	LINE CLEAR AVAILED
798	10-Apr-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	16:10	19:22	03:12	LOAD CURTAILMENT
799	10-Apr-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA, DRDO (EHT), DALSNUR	16:10	19:24	03:14	LOAD CURTAILMENT
800	10-Apr-21	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	16:10	19:22	03:12	LOAD CURTAILMENT
801	10-Apr-21	BENGALURU	66	SUBRAMANYAPURA 66 - SOMANAHALLI 220	SUBRAMANYAPURA 66	10:32	10:45	00:13	LOAD CHANGEOVER
802	10-Apr-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	19:29	19:55	00:25	LINE FAULT
803	10-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	02:08	02:15	00:07	LINE FAULT
804	10-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	02:08	02:15	00:07	LINE FAULT
805	10-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	08:25	09:06	00:41	LOAD CHANGEOVER
806	10-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
807	10-Apr-21	GULBARGA	66	HV2	TAMBRAHALLI_66	13:57	14:27	00:30	TRANSFORMER FAULT
808	10-Apr-21	GULBARGA	66	TBHALLI-ITTAGGI	TAMBRAHALLI_66	11:05	11:25	00:20	LINE FAULT
809	10-Apr-21	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	09:30	11:05	01:35	NFBC ISSUED
810	10-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY- SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)			LINE OPEN:LINE CLEAR AVAILED
811	10-Apr-21	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	6:40(10.04.2021)			LINE OPEN:LINE CLEAR AVAILED
812	10-Apr-21	GULBARGA	110	HATTI-SINDHANOOR	HATTI_110	04:23	04:27	00:04	LINE FAULT
813	10-Apr-21	GULBARGA	110	HV1	BENUR_110	18:30	18:45	00:15	TRANSFORMER FAULT
814	10-Apr-21	GULBARGA	110	HV1	SIRWAR_110	15:00	15:25	00:25	TRANSFORMER FAULT
815	10-Apr-21	GULBARGA	110	HV2	BISIHALLI_110	10:15	10:21	00:06	TRANSFORMER FAULT
816	10-Apr-21	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110	18:40	18:50	00:10	MAIN SUPPLY FAILURE
817	10-Apr-21	GULBARGA	110	KADAGANCHI-KAPNOOR	KADAGANCHI_110	18:50	24:00:00	05:10	LINE FAULT
818	10-Apr-21	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	16:35	16:50	00:15	LINE FAULT
819	10-Apr-21	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	17:26	19:27	02:01	LINE FAULT
820	10-Apr-21	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	19:30(10.04.2021)			LINE OPEN: LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
821	10-Apr-21	GULBARGA	110	KUSHTAGI-ILKAL1&2	ILKAL_110	10:50	16:37	05:47	NFBC ISSUED
822	10-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALOKD_110	05:50	05:59	00:09	LINE FAULT
823	10-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALOKD_110	22:00	22:10	00:10	LINE FAULT
824	10-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	04:41	04:56	00:15	LINE FAULT
825	10-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	00:00	09:10	09:10	LOAD CURTAILMENT
826	10-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	17:25	24:00:00	06:35	LOAD CURTAILMENT
827	10-Apr-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	08:27	17:02	08:35	LINE CLEAR AVAILED
828	10-Apr-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGARSUGAR_IPP	05:34	05:43	00:09	LINE FAULT
829	10-Apr-21	GULBARGA	220	HV2	KUDLIGI_220	18:50(09.04.2021)	9:55(10.04.2021)	15:05HRS	TRANSFORMER CHARGED
830	10-Apr-21	HASSAN	66	HASSN22-ARAKALGUD	HASSAN_220	09:23	09:45	00:22	HAND TRIPPED
831	10-Apr-21	HASSAN	66	HASSN22-SKPURA	HASSAN_220	09:16	09:43	00:27	LINE FAULT
832	10-Apr-21	HASSAN	66	HNPR2-HASS3	HNPURA_220	14:27	14:33	00:06	LINE FAULT
833	10-Apr-21	HASSAN	66	HNPR2-HASS3	HNPURA_220	15:20	17:10	01:50	LINE CLEAR AVAILED
834	10-Apr-21	HASSAN	66	HV1	CHIKABOMENAHALLY_66	12:05	15:00	02:55	TRANSFORMER FAULT
835	10-Apr-21	HASSAN	66	HV1	HOLALUR_66	10:00	18:07	08:07	LINE CLEAR AVAILED
836	10-Apr-21	HASSAN	66	HV1	MOSALEHOSHALLY_66	14:42	17:07	02:25	NFBC ISSUED
837	10-Apr-21	HASSAN	66	HV2	HOLALUR_66	10:01	18:07	08:06	LINE CLEAR AVAILED
838	10-Apr-21	HASSAN	66	LV1	HASSAN_220	09:16	09:43	00:27	TRANSFORMER FAULT
839	10-Apr-21	HASSAN	66	MOSALEH-HNPRA	MOSALEHOSHALLY_66	15:26	17:07	01:41	NFBC ISSUED
840	10-Apr-21	HASSAN	66	MRSSHM-DVG2	MRSMSG_220	22:01	22:06	00:05	LINE FAULT
841	10-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	08:50	19:47	10:57	LINE CLEAR AVAILED
842	10-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	08:50	19:47	10:57	LINE CLEAR AVAILED
843	10-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	15:56	17:08	01:12	LINE FAULT
844	10-Apr-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	15:56	16:41	00:45	LINE FAULT
845	10-Apr-21	HASSAN	110	HALADY-HEGGUNJE	HALADY_110	10:48	11:43	00:55	LINE FAULT
846	10-Apr-21	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	10:50	11:30	00:40	MAIN SUPPLY FAILURE
847	10-Apr-21	HASSAN	110	HV1	BARANGI_110	12:05	13:25	01:20	LINE CLEAR AVAILED
848	10-Apr-21	HASSAN	110	HV1	SHIRALKOPPA_110	10:40	19:30	08:50	LINE CLEAR AVAILED
849	10-Apr-21	HASSAN	110	HV1	SHIVAPURA_110	08:29	08:44	00:15	TRANSFORMER FAULT
850	10-Apr-21	HASSAN	110	HV2	SHIRALKOPPA_110	10:40	18:30	07:50	LINE CLEAR AVAILED
851	10-Apr-21	HASSAN	110	JOG110-LPH	JOG_110	17:36	17:39	00:03	HAND TRIPPED
852	10-Apr-21	HASSAN	110	JOG110-MGHE	JOG_110	17:09	18:02	00:53	LINE FAULT
853	10-Apr-21	HASSAN	110	JOG-JLT3	mghejog_gen	17:58	18:04	00:06	HAND TRIPPED
854	10-Apr-21	HASSAN	110	JOG-JLT4	mghejog_gen	09:44	16:33	06:49	NFBC ISSUED
855	10-Apr-21	HASSAN	110	JOG-JST2	mghejog_gen	17:09	18:10	01:01	LINE FAULT
856	10-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:56	17:06	01:10	LINE FAULT
857	10-Apr-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:56	16:41	00:45	LINE FAULT
858	10-Apr-21	HASSAN	110	SAGARA-JST2	SAGARA_110	17:09	18:10	01:01	LINE FAULT
859	10-Apr-21	HASSAN	110	SHIRAL-SHKARPURA	SHIRALKOPPA_110	10:09	10:30	00:21	HAND TRIPPED
860	10-Apr-21	HASSAN	220	HV1	HASSAN_220	09:16	09:42	00:26	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
861	10-Apr-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	09:45	09:55	00:10	HAND TRIPPED
862	10-Apr-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	09:46	09:54	00:08	HAND TRIPPED
863	10-Apr-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:52	16:36	00:44	LINE FAULT
864	10-Apr-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:52	16:37	00:45	LINE FAULT
865	10-Apr-21	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATION EFFECTED	18:40	21:04	2:24	LOAD CHANGEOVER
866	10-Apr-21	MYSURU	66	G UKKADA-PANDAVAPURA	PANDAVAPURA_66	9:42	18:09	8:26	NFBC ISSUED
867	10-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	2:16	2:52	0:35	MAIN SUPPLY FAILURE
868	10-Apr-21	MYSURU	66	HV1	K_HONNALGERE_66	2:58	7:15	4:16	MAIN SUPPLY FAILURE
869	10-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
870	10-Apr-21	MYSURU	66	HV2	KMDODDI_66	3:33	3:46	0:12	TRANSFORMER FAULT
871	10-Apr-21	MYSURU	66	HV2	KMDODDI_66	7:47	8:10	0:22	TRANSFORMER FAULT
872	10-Apr-21	MYSURU	66	HV2	KMDODDI_66	14:12	14:17	0:04	TRANSFORMER FAULT
873	10-Apr-21	MYSURU	66	HV2	KMDODDI_66	14:31	14:41	0:10	TRANSFORMER FAULT
874	10-Apr-21	MYSURU	66	HV2	KMDODDI_66	14:43	14:53	0:09	TRANSFORMER FAULT
875	10-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
876	10-Apr-21	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66	7:22	7:26	0:04	LINE FAULT
877	10-Apr-21	MYSURU	66	KIADB MANDYA-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	2:08	7:15	5:06	LINE FAULT
878	10-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN: LINE FAULT
879	10-Apr-21	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	22:12 (9/04/2021)	02:03 (10/04/2021)	3:50 HRS	LINE CHARGED
880	10-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
881	10-Apr-21	MYSURU	66	KR PETE-AKIEBAL1	KRPET_66 AKKIEBBAL_66	10:09	15:04	4:54	LINE CLEAR AVAILED
882	10-Apr-21	MYSURU	66	KR PETE-AKIEBAL2	KRPET_66 AKKIEBBAL_66	10:09	15:04	4:54	LINE CLEAR AVAILED
883	10-Apr-21	MYSURU	66	KR PETE-HUYGONALLY 2	KRPET_66 AKKIEBBAL_66	10:10	15:04	4:54	LINE CLEAR AVAILED
884	10-Apr-21	MYSURU	66	KR PETE-KIKKERI	KRPET_66 AKKIEBBAL_66	10:10	15:04	4:54	LINE CLEAR AVAILED
885	10-Apr-21	MYSURU	66	PANDAVAPURA-TUBINKERE	PANDAVAPURA_66	10:00	17:26	7:26	LINE CLEAR AVAILED
886	10-Apr-21	MYSURU	66	TN PURA-THAYUR	TNARASIPURA_66	16:28 (10/04/2021)			MAIN SUPPLY FAILURE
887	10-Apr-21	MYSURU	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	10:34	11:25	0:51	LINE CLEAR AVAILED
888	10-Apr-21	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	7:02	7:29	0:26	LINE FAULT
889	10-Apr-21	TUMKUR	66	CHITRADURGA 220kv- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	9:17	9:54	0:36	LINE FAULT
890	10-Apr-21	TUMKUR	66	CHITRADURGA 220kv- TURUVANUR	MADANAYAKANAHALLI_66, TURUVANUR_66, BIDARKERE_66, JAGALUR_66, SOKKE_66	6:54	17:10	10:16	LINE CLEAR AVAILED
891	10-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:51	6:57	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
892	10-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:04	6:15	0:10	LINE FAULT
893	10-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_67	11:28	11:39	0:11	LINE FAULT
894	10-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_68	12:58	13:02	0:04	LINE FAULT
895	10-Apr-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	(9.04.2021)10:58:31 PM	1:44(10.4.21)	2:46HRS	LINE CHARGED
896	10-Apr-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	(9.04.2021)10:58:31 PM	1:44(10.4.21)	2:46HRS	LINE CHARGED
897	10-Apr-21	TUMKUR	66	HOLALKERE-PANDRAHALLI2	HOLALKERE_66	5:34	5:53	0:18	LINE FAULT
898	10-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:35	12:40	0:05	LINE CLEAR AVOIDED
899	10-Apr-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	5:55	6:05	0:10	LINE CLEAR AVOIDED
900	10-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	12:20	12:28	0:07	LINE FAULT
901	10-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	16:59	17:05	0:06	LINE FAULT
902	10-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	21:18	21:25	0:07	LINE FAULT
903	10-Apr-21	TUMKUR	66	TR-1(HV SIDE)	PAVAGADA_220	9:58	10:03	0:05	TRANSFORMER FAULT
904	10-Apr-21	TUMKUR	66	TR-2	CHANNAGIRI_66	14:13	14:36	0:22	TRANSFORMER FAULT
905	10-Apr-21	TUMKUR	66	TR-2	HOLALKERE_66	13:30	13:32	0:01	TRANSFORMER FAULT
906	10-Apr-21	TUMKUR	66	TR-2	KOLALA_66	10:51	11:29	0:38	LINE CLEAR AVOIDED
907	10-Apr-21	TUMKUR	66	TR-2	LINGDHALLI_66	8:40	9:42	1:02	TRANSFORMER FAULT
908	10-Apr-21	TUMKUR	66	TR-2	SHYLAPURA_66	13:23	13:36	0:12	TRANSFORMER FAULT
909	10-Apr-21	TUMKUR	66	TR-2	SHYLAPURA_66	14:00	14:02	0:02	TRANSFORMER FAULT
910	10-Apr-21	TUMKUR	220	NITTUR 220KV- ARASIKERE	NITTUR_220	10:12	15:53	5:40	LINE CLEAR AVOIDED
911	11-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN:LINE CLEAR AVOIDED
912	11-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED SHIROL_110	14:07	14:10	0:03	TRANSFORMER FAULT
913	11-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIDAGUNDI_110	17:29	18:39	1:10	TRANSFORMER FAULT
914	11-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED NIDAGUNDI_110	18:39	18:46	0:07	TRANSFORMER FAULT
915	11-Apr-21	BAGALKOT	110	110/11KV,HV2	GUTTAL_110	6:10	6:15	0:05	TRANSFORMER FAULT
916	11-Apr-21	BAGALKOT	110	110/11KV,HV2	MAMADAPURG_110	18:41 (11.04.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
917	11-Apr-21	BAGALKOT	110	110/33KV,HV1	HANAGAL_110,BASAPUR_33,PALA_33	10:46	11:39	0:53	HAND TRIPPED
918	11-Apr-21	BAGALKOT	110	110/33KV,HV3	MUNAVALLI_110,MUNAVALLI_33,MAL LUR_33,	17:27	17:36	0:09	HAND TRIPPED
919	11-Apr-21	BAGALKOT	110	BELGAUM-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	16:06 (08.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
920	11-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVOIDED
921	11-Apr-21	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	14:36	18:39	4:03	LINE FAULT
922	11-Apr-21	BAGALKOT	110	BIDNAL-P H COMPOUND	STATION NOT AFFECTED BIDNAL_220	15:45	15:53	0:08	HAND TRIPPED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
923	11-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	15:23 (05.01.2021)	15:11 (11.04.2021)	2279:48HRS	LINE CHARGED
924	11-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN:LINE CLEAR AVAILED
925	11-Apr-21	BAGALKOT	110	HALIYAL-ALNAVAR	ALNAVAR HALIYAL_110	16:09 (11.04.2021)			LINE OPEN:LINE CLEAR AVAILED
926	11-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
927	11-Apr-21	BAGALKOT	110	HAVERI-HANGAL	HANAGAL_110	18:19	18:32	0:13	LINE FAULT
928	11-Apr-21	BAGALKOT	110	HUNGUND-ILKAL1&2	STATION NOT AFFECTED HUNGUND_110	11:00	17:17	6:17	LINE CLEAR AVAILED
929	11-Apr-21	BAGALKOT	110	KADANAKOPPA-KAVALWADA	STATION NOT AFFECTED KADANAKOPPA_110	12:35 (01.04.2021)	10:19 (11.04.2021)	237:44HRS	LINE CHARGED
930	11-Apr-21	BAGALKOT	110	KARWAR-KUMTA(ARGA)	KARWAR_220	12:44	12:46	0:02	HAND TRIPPED
931	11-Apr-21	BAGALKOT	110	KARWAR-SOLARIS(BINAGA)	KARWAR_220	10:52	12:43	1:51	LINE FAULT
932	11-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
933	11-Apr-21	BAGALKOT	110	KIRUVATTI- SIRSI(AMBEWADI)	STATION NOT AFFECTED KIRUVATTI_110	18:28 (08.04.2021)	10:00 (11.04.2021)	63:32HRS	LINE CHARGED
934	11-Apr-21	BAGALKOT	110	KUDUCHI220-AINAPUR	STATION NOT AFFECTED KUDUCHI_220	12:45	15:06	2:21	LINE CLEAR AVAILED
935	11-Apr-21	BAGALKOT	110	KUMTA-SIRSI1	STATION NOT AFFECTED KUMTA_110	16:14 (02.04.2021)	10:08 (11.04.2021)	209:54HRS	LINE CHARGED
936	11-Apr-21	BAGALKOT	110	PH COMPOUND-BIDNAL	STATION NOT AFFECTED PH COMPOUND_110	16:11 (29.03.2021)	16:00 (11.04.2021)	311:49HRS	LINE CHARGED
937	11-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
938	11-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
939	11-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN: LINE FAULT
940	11-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED
941	11-Apr-21	BAGALKOT	110	SOUDATTI220-MUNAVALLY	MUNAVALLY_110	15:55	17:16	1:21	LINE FAULT
942	11-Apr-21	BAGALKOT	110	SOUDATTI220-YARAGATTI	YARAGATTI_110	15:55	17:30	1:35	LINE FAULT
943	11-Apr-21	BAGALKOT	110	VADAGOAN-BELAGAUM220	STATION NOT AFFECTED VADAGOAN_110	9:00	13:54	4:54	NFBC ISSUED
944	11-Apr-21	BAGALKOT	220	220/110KV,HV1,LV1	KARWAR_220	10:52	12:32	1:40	TRANSFORMER FAULT
945	11-Apr-21	BAGALKOT	220	AMBEWADI-XELDOM	STATION NOT AFFECTED AMBEWADI_220	7:00	13:19	6:19	LINE CLEAR AVAILED
946	11-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:31 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
947	11-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
948	11-Apr-21	BAGALKOT	220	KARWAR-KADRA1	KARWAR_220	10:52 (11.04.2021)			LINE OPEN: LINE FAULT
949	11-Apr-21	BAGALKOT	220	KARWAR-KADRA2	KARWAR_220	10:52	12:27	1:35	LINE FAULT
950	11-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
951	11-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	MAHALINGAPUR_220	9:38 (09.04.2021)			LOAD CURTAILMENT
952	11-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
953	11-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	17:31 (10.04.2021)			LOAD CURTAILMENT
954	11-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
955	11-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT
956	11-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
957	11-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
958	11-Apr-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	08:10	08:20	00:10	LOAD CHANGEOVER
959	11-Apr-21	BENGALURU	66	ATTIBELE - SARJAPURA	ATTIBELE	19:20	19:25	00:05	LOAD CHANGEOVER
960	11-Apr-21	BENGALURU	66	CHAKAVELU - YENNIGADALE	CHAKAVELU	17:57	18:15	00:18	LINE FAULT
961	11-Apr-21	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	07:07	07:52	00:45	LINE FAULT
962	11-Apr-21	BENGALURU	66	HV1	CHAKAVELU	17:57	18:15	00:17	TRANSFORMER FAULT
963	11-Apr-21	BENGALURU	66	HV1	VIJAYANAGARA	11:47	12:07	00:19	LINE CLEAR AVAILED
964	11-Apr-21	BENGALURU	66	HV1	YERANDANAHALLI 220	08:23	09:00	00:37	LINE CLEAR AVAILED
965	11-Apr-21	BENGALURU	66	HV1	YERANDANAHALLI 220	17:35	17:55	00:20	LINE CLEAR AVAILED
966	11-Apr-21	BENGALURU	66	HV1	VOLVO	23:37	23:46	00:09	TRANSFORMER FAULT
967	11-Apr-21	BENGALURU	66	HV1	TEKAL	18:10	18:19	00:08	TRANSFORMER FAULT
968	11-Apr-21	BENGALURU	66	HV1	SOMENAHALLI	11:03	11:46	00:42	LINE CLEAR AVAILED
969	11-Apr-21	BENGALURU	66	HV2	VIJAYANAGARA	10:36	10:58	00:21	LINE CLEAR AVAILED
970	11-Apr-21	BENGALURU	66	HV2	YERANDANAHALLI 220	08:17	08:20	00:03	LINE CLEAR AVAILED
971	11-Apr-21	BENGALURU	66	HV2	VOLVO	07:10	08:20	01:10	TRANSFORMER FAULT
972	11-Apr-21	BENGALURU	66	HV3	YERANDANAHALLI 220	08:23	09:06	00:43	LINE CLEAR AVAILED
973	11-Apr-21	BENGALURU	66	HV3	YERANDANAHALLI 220	17:35	17:55	00:20	LINE CLEAR AVAILED
974	11-Apr-21	BENGALURU	66	JIGANI 66 - JIGANI 220	JIGANI 66	08:15	08:32	00:17	LOAD CHANGEOVER
975	11-Apr-21	BENGALURU	66	JIGANI 66 - JIGANI LINK ROAD	JIGANI 66	17:54	18:02	00:08	LOAD CHANGEOVER
976	11-Apr-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	09:50	10:18	00:28	LINE CLEAR AVAILED
977	11-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENHALLI, HAROBELE, BIJJALAHALLI	07:22	07:25	00:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
978	11-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALAHALLI	03:30	06:40	03:10	LINE FAULT
979	11-Apr-21	BENGALURU	66	L R BANDE - HBR LAYOUT	HBR LAYOUT	10:42	10:58	00:16	LINE FAULT
980	11-Apr-21	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 1	VATADOSANAHALLI, GUNDLUKOTTURU	06:45	07:35	00:50	LOAD CURTAILMENT
981	11-Apr-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	06:13	06:19	00:06	LINE FAULT
982	11-Apr-21	BENGALURU	66	SHOBHA FOREST - SUBRAMANYAPURA 220	SHOBHA FOREST	19:10	19:19	00:09	LOAD CHANGEOVER
983	11-Apr-21	BENGALURU	66	SUBRAMANYAPURA 66 - SUBRAMANYAPURA 220	SUBRAMANYAPURA 66	16:12	16:20	00:08	LOAD CHANGEOVER
984	11-Apr-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	09:03	09:11	00:08	MAIN SUPPLY FAILURE
985	11-Apr-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	09:03	09:11	00:08	MAIN SUPPLY FAILURE
986	11-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:56	12:01	00:04	LOAD CURTAILMENT
987	11-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	09:03	09:15	00:11	MAIN SUPPLY FAILURE
988	11-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	09:03	09:15	00:11	MAIN SUPPLY FAILURE
989	11-Apr-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	11:56	12:01	00:04	LOAD CURTAILMENT
990	11-Apr-21	BENGALURU	66	YELAHANKA 220 - LINE8	RAJANKUNTE	08:00	08:13	00:13	LINE FAULT
991	11-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	08:23	09:09	00:46	LOAD CHANGEOVER
992	11-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	17:38	18:06	00:28	LOAD CHANGEOVER
993	11-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 2	ANEKAL	08:23	09:09	00:46	LOAD CHANGEOVER
994	11-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 2	ANEKAL	17:38	18:08	00:30	LOAD CHANGEOVER
995	11-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	08:50	09:04	00:14	LINE CLEAR AVAILED
996	11-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	17:35	18:06	00:31	LINE CLEAR AVAILED
997	11-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - TIMES OF INDIA (EHT)	TIMES OF INDIA (EHT)	17:35	18:04	00:29	LINE CLEAR AVAILED
998	11-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
999	11-Apr-21	BENGALURU	220	HV2	TK HALLI 220	09:03	09:07	00:03	TRANSFORMER FAULT
1000	11-Apr-21	BENGALURU	220	JIGANI 220 - SOMENAHALLI 220	JIGANI 220	08:15	09:06	00:51	LINE CLEAR AVAILED
1001	11-Apr-21	BENGALURU	220	JIGANI 220 - YERANDANAHALLI 220	JIGANI 220	17:36	17:47	00:11	LOAD CHANGEOVER
1002	11-Apr-21	GULBARGA	66	HV2	TAMBRAHALLI_66	06:49	06:52	00:03	TRANSFORMER FAULT
1003	11-Apr-21	GULBARGA	66	UJJAINI-KOTTUR	UJJANI_66	18:35	19:20	00:45	LINE FAULT
1004	11-Apr-21	GULBARGA	110	BENUR-YERADONA	BENUR_110	01:40	01:55	00:15	MAIN SUPPLY FAILURE
1005	11-Apr-21	GULBARGA	110	GULBARGA SOUTH-FARTHABAD	GULBARGA SOUTH_110	06:35	07:05	00:30	LINE CLEAR AVAILED
1006	11-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY- SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1007	11-Apr-21	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	6:40(10.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1008	11-Apr-21	GULBARGA	110	HALBURGA-SANTHAPUR	SANTHAPUR_110,DONGARGAON_110, DIGGI_110	19:02	19:05	00:03	LINE FAULT
1009	11-Apr-21	GULBARGA	110	HV1	NIRNA_110	11:40	11:46	00:06	TRANSFORMER FAULT
1010	11-Apr-21	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	19:00	19:16	00:16	LINE FAULT
1011	11-Apr-21	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	18:40	18:48	00:08	LINE FAULT
1012	11-Apr-21	GULBARGA	110	KUSHTAGI-ILKAL1	ILKAL_110	19:30(10.04.2021)	13:13(11.04.2021)	17:43HRS	LINE CHARGED
1013	11-Apr-21	GULBARGA	110	LV1	SHAHAPUR_220	23:16	23:48	00:32	TRANSFORMER FAULT
1014	11-Apr-21	GULBARGA	110	MALLAT-ALKOD	ALOKD_110	06:00	06:10	00:10	LINE FAULT
1015	11-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	00:28	00:38	00:10	LINE FAULT
1016	11-Apr-21	GULBARGA	110	MALLAT-BYAGWAT2	MADLAPUR_110,MANVI_110	22:41	22:51	00:10	LINE FAULT
1017	11-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	00:00	08:30	08:30	LOAD CURTAILMENT
1018	11-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	SHAHAPUR_110	17:25	24:00:00	06:35	LOAD CURTAILMENT
1019	11-Apr-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	KAMPLI_110,MUKUNDA(IDLE)_110,KE REHALLI_110,MALLAPUR_110	01:45	01:55	00:10	LINE FAULT
1020	11-Apr-21	GULBARGA	220	HV2	HUMNABAD_220	06:24	07:40	01:16	LINE CLEAR AVAILED
1021	11-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	03:39	04:03	00:24	LINE FAULT
1022	11-Apr-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	05:00	05:15	00:15	LINE FAULT
1023	11-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	03:39	04:04	00:25	LINE FAULT
1024	11-Apr-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	05:00	05:13	00:13	LINE FAULT
1025	11-Apr-21	HASSAN	66	HV2	UDAYAPURA_66	09:59	10:06	00:07	TRANSFORMER FAULT
1026	11-Apr-21	HASSAN	66	HV2	UDAYAPURA_66	20:36(11.4.2021)			TRANSFORMER OPEN: TRANSFORMER FAULT
1027	11-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKALESH PURA_66	09:01	19:26	10:25	LINE CLEAR AVAILED
1028	11-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKALESH PURA_66	09:01	19:26	10:25	LINE CLEAR AVAILED
1029	11-Apr-21	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	04:07	04:11	00:04	MAIN SUPPLY FAILURE
1030	11-Apr-21	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	04:07	04:16	00:09	MAIN SUPPLY FAILURE
1031	11-Apr-21	HASSAN	66	UDAYAP-SHANTIGRAMA	UDAYAPURA_66	04:07	12:15	08:08	LINE FAULT
1032	11-Apr-21	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	13:46	14:00	00:14	LINE CLEAR AVAILED
1033	11-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	16:01	16:22	00:21	LINE FAULT
1034	11-Apr-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	16:30	18:12	01:42	LINE FAULT
1035	11-Apr-21	HASSAN	110	HIRIYA-MADHUVANA	HIRIYADKA_110	17:04	20:01	02:57	LINE FAULT
1036	11-Apr-21	HASSAN	110	HV1	BAIKAMPADY_110	08:41	17:37	08:56	LINE CLEAR AVAILED
1037	11-Apr-21	HASSAN	110	HV2	BAIKAMPADY_110	08:40	17:34	08:54	LINE CLEAR AVAILED
1038	11-Apr-21	HASSAN	110	HV4	BAIKAMPADY_110	08:40	17:34	08:54	LINE CLEAR AVAILED
1039	11-Apr-21	HASSAN	110	KAVOOR-AMR	KAVOOR_220	20:50	21:59	01:09	LINE FAULT
1040	11-Apr-21	HASSAN	110	KAVOOR-BAIKAMPADI	KAVOOR_220	08:00	17:25	09:25	LINE CLEAR AVAILED
1041	11-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:01	16:22	00:21	LINE FAULT
1042	11-Apr-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	16:30	18:11	01:41	LINE FAULT
1043	11-Apr-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	21:04	22:11	01:07	LINE FAULT
1044	11-Apr-21	HASSAN	110	LV1	KAVOOR_220	11:03	14:05	03:02	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1045	11-Apr-21	HASSAN	110	MADHUV-HIRIYADKA	MADHUVANA_110	18:11	20:02	01:51	NFBC ISSUED
1046	11-Apr-21	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	21:15	22:03	00:48	HAND TRIPPED
1047	11-Apr-21	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	21:15	22:03	00:48	MAIN SUPPLY FAILURE
1048	11-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
1049	11-Apr-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
1050	11-Apr-21	HASSAN	110	MSEZ-BAIKAMPADY	MSEZ_220	20:09	22:17	02:08	LINE FAULT
1051	11-Apr-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	21:04	22:02	00:58	LINE FAULT
1052	11-Apr-21	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	21:04	21:29	00:25	LINE FAULT
1053	11-Apr-21	HASSAN	220	HV1	KAVOOR_220	11:03	14:02	02:59	LINE CLEAR AVAILED
1054	11-Apr-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:56	16:15	00:19	LINE FAULT
1055	11-Apr-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:50	16:15	00:25	LINE FAULT
1056	11-Apr-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:56	16:10	00:14	LINE FAULT
1057	11-Apr-21	MYSURU	66	BG PURA-CHANDALLY	BGPURA_66 CHANDALLI_66 PARINAMIPURA_66 THALAKADU_66	13:33	13:51	0:18	LINE FAULT
1058	11-Apr-21	MYSURU	66	CHINAKURALI-BOOKANKERE	CHINAKURALI_66 BANANGADI_66	14:15	14:50	0:35	LINE CLEAR AVAILED
1059	11-Apr-21	MYSURU	66	GUNDLUPETE-BEGUR 2	NO STATION EFFECTED	18:06	18:20	0:13	LINE FAULT
1060	11-Apr-21	MYSURU	66	HV1	CHINAKURALI_66	9:30	15:01	5:31	LINE CLEAR AVAILED
1061	11-Apr-21	MYSURU	66	HV1	DKMAIDANA_66	1:55	4:06	2:11	TRANSFORMER FAULT
1062	11-Apr-21	MYSURU	66	HV1	KIADBMANDYA_66	9:04	9:16	0:12	MAIN SUPPLY FAILURE
1063	11-Apr-21	MYSURU	66	HV1	KIADBMANDYA_66	11:57	12:08	0:11	MAIN SUPPLY FAILURE
1064	11-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1065	11-Apr-21	MYSURU	66	HV2	CHINAKURALI_66	9:30	15:01	5:31	LINE CLEAR AVAILED
1066	11-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1067	11-Apr-21	MYSURU	66	KOLLEGALA-CR NAGARA	KOLLEGALA_66	10:32	14:26	3:54	LINE CLEAR AVAILED
1068	11-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)			LINE OPEN: LINE FAULT
1069	11-Apr-21	MYSURU	66	KOLLEGALA-SATHEGALA	KOLLEGALA_66	10:31	14:31	4:00	LINE CLEAR AVAILED
1070	11-Apr-21	MYSURU	66	KOLLEGALA-TALKADU	KOLLEGALA_66	10:07	14:34	4:27	LINE CLEAR AVAILED
1071	11-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1072	11-Apr-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-1	MIRLE_66	2:23	2:37	0:14	LINE FAULT
1073	11-Apr-21	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	BETTADHAPURA_66 KITTUR_66 RAVANDUR_66 CHUNCHUNKATTE_66 BILIKERE_66 GVGUDI_66 KR NAGARA_66	5:36	5:58	0:22	LINE FAULT
1074	11-Apr-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	6:31	6:36	0:05	LINE FAULT
1075	11-Apr-21	MYSURU	66	THANDYA-KADAKOLA	THANDYA_66	10:06	13:57	3:51	LINE CLEAR AVAILED
1076	11-Apr-21	MYSURU	66	THANDYA-NANJUNGUD	THANDYA_66	10:11	14:00	3:48	LINE CLEAR AVAILED
1077	11-Apr-21	MYSURU	66	TN PURA-THAYUR	TNARASIPURA_66	16:28 (10/04/2021)	13:54 (11/04/2021)	21:26 HRS	LINE CHARGED
1078	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:03	6:10	0:06	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1079	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	6:45	6:53	0:08	LINE FAULT
1080	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:10	8:15	0:05	LINE FAULT
1081	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:17	11:21	0:04	LINE FAULT
1082	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:17	12:22	0:04	LINE FAULT
1083	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:41	12:46	0:05	LINE FAULT
1084	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	12:49	12:59	0:10	LINE FAULT
1085	11-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	22:10	22:20	0:10	LINE FAULT
1086	11-Apr-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJHALLI_66	8:31	8:41	0:09	LINE FAULT
1087	11-Apr-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:37	12:46	0:09	HAND TRIPPED
1088	11-Apr-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	10:01	10:11	0:09	LINE FAULT
1089	11-Apr-21	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	16:04	16:14	0:09	LINE FAULT
1090	11-Apr-21	TUMKUR	66	LINGADAHALLI- NALLUR	LINGDHALLI_66	10:36	10:41	0:05	LINE FAULT
1091	11-Apr-21	TUMKUR	66	TR-1	HULIYURDURGA_66	12:28	12:42	0:13	TRANSFORMER FAULT
1092	11-Apr-21	TUMKUR	66	TR-1	HULIYURDURGA_66	14:15	14:37	0:22	TRANSFORMER FAULT
1093	11-Apr-21	TUMKUR	66	TR-1	MAVINAKATTE_66	10:07	10:44	0:36	LINE CLEAR AVAILED
1094	11-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	0:04	0:17	0:12	TRANSFORMER FAULT
1095	11-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	11:09	11:18	0:08	TRANSFORMER FAULT
1096	11-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	14:40	15:03	0:22	TRANSFORMER FAULT
1097	11-Apr-21	TUMKUR	66	TR-1	MAYAKONDA_66	12:34	12:39	0:05	TRANSFORMER FAULT
1098	11-Apr-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	8:16	8:23	0:07	LINE CLEAR AVAILED
1099	11-Apr-21	TUMKUR	66	TR-1	GOWRASAMUDRA_66	12:09	12:12	0:03	LINE CLEAR AVAILED
1100	11-Apr-21	TUMKUR	66	TR-2	MATHOD_66	15:05	15:11	0:05	TRANSFORMER FAULT
1101	11-Apr-21	TUMKUR	66	TR-2	MAVINAKATTE_66	10:07	10:44	0:37	LINE CLEAR AVAILED
1102	11-Apr-21	TUMKUR	110	TR-1	KALLUR_110	11:00	11:37	0:37	LINE CLEAR AVAILED
1103	11-Apr-21	TUMKUR	110	TR-1	KALLUR_110	13:56	14:25	0:28	LINE CLEAR AVAILED
1104	11-Apr-21	TUMKUR	110	TR-1	SHETTYKERE_110	0:50	1:00	0:09	TRANSFORMER FAULT
1105	12-Apr-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
1106	12-Apr-21	BAGALKOT	110	110/11KV, HV1	RATTIHALLI_110	11:20	12:23	1:03	LINE CLEAR AVAILED
1107	12-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED KALAGHATAGI_110	11:45	11:58	0:13	TRANSFORMER FAULT
1108	12-Apr-21	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	14:39	14:47	0:08	TRANSFORMER FAULT
1109	12-Apr-21	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MAMADAPURG_110	18:41 (11.04.2021)	12:38 (12.04.2021)	17:57hrs	TRANSFORMER CHARGED
1110	12-Apr-21	BAGALKOT	110	110/11KV, HV2	MURDESHWAR_110	13:49	14:03	0:14	LINE CLEAR AVAILED
1111	12-Apr-21	BAGALKOT	110	110/33KV, HV1	MURDESHWAR_110, KASARGOD_33, BHATKAL_33	13:49	13:58	0:09	LINE CLEAR AVAILED
1112	12-Apr-21	BAGALKOT	110	110/33KV, HV3	MUNAVALLY_110, MALLUR_33, MUNVALLI_33	17:56	18:33	0:37	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1113	12-Apr-21	BAGALKOT	110	110/33KV, HV4	ALAGAVADI_33 STATON NOT AFFECTED HIDAKAL_110	8:08	15:35	7:27	LINE CLEAR AVAILED
1114	12-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	10:40	10:55	0:15	TRANSFORMER FAULT
1115	12-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	10:56	13:23	2:27	LINE CLEAR AVAILED
1116	12-Apr-21	BAGALKOT	110	110/33KV, HV4	ZALKI_110, DHULKED_33, NEVARGI_33, ALSANGI_33	17:10	17:30	0:20	TRANSFORMER FAULT
1117	12-Apr-21	BAGALKOT	110	220/110KV, LV1	STATON NOT AFFECTED BAGALKOT_220	6:25	6:47	0:22	HAND TRIPPED
1118	12-Apr-21	BAGALKOT	110	220/110KV, LV1	STATON NOT AFFECTED CHIKKODI_220	14:21	14:47	0:26	HAND TRIPPED
1119	12-Apr-21	BAGALKOT	110	220/110KV, LV1	STATON NOT AFFECTED KARWAR_220	10:37	12:22	1:45	LINE CLEAR AVAILED
1120	12-Apr-21	BAGALKOT	110	220/110KV, LV2	STATON NOT AFFECTED BAGALKOT_220	6:25	6:41	0:16	HAND TRIPPED
1121	12-Apr-21	BAGALKOT	110	220/110KV, LV3	STATON NOT AFFECTED BAGALKOT_220	6:25	6:39	0:14	HAND TRIPPED
1122	12-Apr-21	BAGALKOT	110	AINAPUR-ATHANI SUGARS	ATHANI SUGARS_110 STATION NOT AFFECTED AINAPUR_110	06:06	06:28	0:22	LINE FAULT
1123	12-Apr-21	BAGALKOT	110	ANKOLA-KUMTA(L2)	STATION NOT AFFECTED ANKOLA_110	23:03 (12.04.2021)			LINE OPEN: LINE FAULT
1124	12-Apr-21	BAGALKOT	110	ANNIGERI-GADAG	STATON NOT AFFECTED ANNIGERI_110	15:12 (03.04.2021)	12:29 (12.04.2021)	213:17hrs	LINE CHARGED
1125	12-Apr-21	BAGALKOT	110	ANNIGERI-GADAG	STATON NOT AFFECTED ANNIGERI_110	14:14	17:38	3:24	LINE CLEAR AVAILED
1126	12-Apr-21	BAGALKOT	110	BAGALKOT220-BAGALKOT2	BAGALKOT_110	6:44	6:47	0:03	HAND TRIPPED
1127	12-Apr-21	BAGALKOT	110	BAGALKOT220-GULEDAGUDDA	GULEDAGUDDA_110	6:44	6:55	0:11	HAND TRIPPED
1128	12-Apr-21	BAGALKOT	110	BAGALKOT220-KATARKI	KATARKI_110	6:44	6:55	0:11	HAND TRIPPED
1129	12-Apr-21	BAGALKOT	110	BAGALKOT220-KERUR	KERUR_110	6:44	6:55	0:11	HAND TRIPPED
1130	12-Apr-21	BAGALKOT	110	BAGALKOT220-LOKAPUR1	LOKAPUR_110	6:44	7:02	0:18	HAND TRIPPED
1131	12-Apr-21	BAGALKOT	110	BAGALKOT220-NAVANAGAR1	NAVANAGAR_110	6:44	6:50	0:06	HAND TRIPPED
1132	12-Apr-21	BAGALKOT	110	BAGALKOT220-NAVANAGAR2	NAVANAGAR_110	6:44	6:50	0:06	HAND TRIPPED
1133	12-Apr-21	BAGALKOT	110	BAGEWADI220-MAMDAPUR1	MAMDAPUR_110	6:39	7:23	0:44	HAND TRIPPED
1134	12-Apr-21	BAGALKOT	110	BAGEWADI220-MUDEDEBIHAL	MUDEDEBIHAL_110	5:52	7:23	1:31	LINE CLEAR AVAILED
1135	12-Apr-21	BAGALKOT	110	BAGEWADI220-NIDAGUNDI (RAMPUR)	NIDAGUNDI_110	6:39	7:30	0:51	HAND TRIPPED
1136	12-Apr-21	BAGALKOT	110	BAGEWADI220-SINDAGI	SINDAGI_110	6:39	7:26	0:47	HAND TRIPPED
1137	12-Apr-21	BAGALKOT	110	BELGAUM-ANKALAGI	STATION NOT AFFECTED ANKALAGI_110	16:06 (08.04.2021)	12:43 (12.04.2021)	92:37HRS	LINE CHARGED
1138	12-Apr-21	BAGALKOT	110	BETAGERI-NAREGAL	STATION NOT AFFECTED BETAGERI_110	9:39 (06.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1139	12-Apr-21	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:17	14:01	3:44	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1140	12-Apr-21	BAGALKOT	110	GADAG-ANNIGERI	STATION NOT AFFECTED GADAG_110	16:18 (11.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1141	12-Apr-21	BAGALKOT	110	HALIYAL-ALNAVAR	STATION NOT AFFECTED HALIYAL_110	16:09 (11.04.2021)	7:30 (12.04.2021)	15:21hrs	LINE CHARGED
1142	12-Apr-21	BAGALKOT	110	HALIYAL-GMR IPP	GMR IPP_110 STATION NOT AFFECTED HALIYAL_110	11:19	12:31	1:12	LINE CLEAR AVAILED
1143	12-Apr-21	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN:LINE CLEAR AVAILED
1144	12-Apr-21	BAGALKOT	110	HIDAKAL-MAHALINGAPUR220	HIDAKAL_110	15:32	15:34	0:02	HAND TRIPPED
1145	12-Apr-21	BAGALKOT	110	HIREBEVANUR-RODAGI (INDI- LACHYAN)	RODAGI_110	15:40	17:04	1:24	LINE FAULT
1146	12-Apr-21	BAGALKOT	110	HUDLI-BELAGAUM220	STATION NOT AFFECTED HUDLI_110	17:15 (08.04.2021)	12:48 (12.04.2021)	91:33hrs	LINE CHARGED
1147	12-Apr-21	BAGALKOT	110	KARWAR220-SOLARIS	SOLARIS_110 STATION NOT AFFECTED KARWAR_220	10:37	12:21	1:44	LINE CLEAR AVAILED
1148	12-Apr-21	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
1149	12-Apr-21	BAGALKOT	110	KIRUVATTI- UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	17:37	19:13	1:36	LINE CLEAR AVAILED
1150	12-Apr-21	BAGALKOT	110	KIRUVATTI-AMBEWADI(SIRSI)	STATION NOT AFFECTED KIRUVATTI_110	20:08	23:33	3:25	LINE CLEAR AVAILED
1151	12-Apr-21	BAGALKOT	110	KONNUR-KERUR	STATION NOT AFFECTED KONNUR_110	13:26	13:27	0:01	HAND TRIPPED
1152	12-Apr-21	BAGALKOT	110	KULAGERI CROSS-KONNUR	KULAGERI CROSS_110	13:00	13:29	0:29	LINE CLEAR AVAILED
1153	12-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	12:48 (11.04.2021)	9:27 (12.04.2021)	20:39hrs	LINE CHARGED
1154	12-Apr-21	BAGALKOT	110	KUMATA-SIRSI 1	KUMATA_110	12:22 (12.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1155	12-Apr-21	BAGALKOT	110	LOKAPUR- SALAHALLI	SALAHALLI_110	16:08	16:17	0:09	HAND TRIPPED
1156	12-Apr-21	BAGALKOT	110	MACHE- UDYAMBAG	STATION NOT AFFECTED MACHE_110	8:11 (12.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1157	12-Apr-21	BAGALKOT	110	NAVALGUND- KONNUR	STATION NOT AFFECTED NAVALGUND_110	12:26	13:22	0:56	LINE CLEAR AVAILED
1158	12-Apr-21	BAGALKOT	110	RANEBENNUR- TUMMINKATTI	STATION NOT AFFECTED TUMMINKATTI_110	10:40	13:30	2:50	LINE CLEAR AVAILED
1159	12-Apr-21	BAGALKOT	110	RANEBENNUR220- HONNATTI (AREMALLAPUR)	NO STATION AFFECTED RANEBENNUR_220	13:16 (17.11.2020)			LINE OPEN: LINE FAULT
1160	12-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD1	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1161	12-Apr-21	BAGALKOT	110	RON- GAJENDRAGAD2	STATION NOT AFFECTED RON_110	21:31 (08.04.2021)			LINE OPEN: LINE FAULT
1162	12-Apr-21	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED SATTI_110	10:57 (05.03.2021)			LINE OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1163	12-Apr-21	BAGALKOT	110	SIRSI220- UMMACHAGI	STATION NOT AFFECTED UMMACHAGI_110	16:38	17:37	0:59	LINE CLEAR AVAILED
1164	12-Apr-21	BAGALKOT	110	SOUDATTI220- NARAGUND	STATION NOT AFFECTED NARAGUND_110	14:37 (12.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1165	12-Apr-21	BAGALKOT	110	VAJRAMATTI220- BILAGI	BILAGI_110	06:18	07:45	1:27	LINE CLEAR AVAILED
1166	12-Apr-21	BAGALKOT	110	VAJRAMATTI220- MANTUR1&2	MANTUR_110	06:18	07:53	1:35	LINE CLEAR AVAILED
1167	12-Apr-21	BAGALKOT	110	VAJRAMATTI220- MUDHOL	MUDHOL_110	06:37	07:54	1:17	LINE CLEAR AVAILED
1168	12-Apr-21	BAGALKOT	110	ZALKI- CHADCHAN	CHADCHAN_110	09:05	09:30	0:25	LINE FAULT
1169	12-Apr-21	BAGALKOT	220	220/110KV, HV1	STATON NOT AFFECTED BAGALKOT_220	6:44	6:46	0:02	HAND TRIPPED
1170	12-Apr-21	BAGALKOT	220	220/110KV, HV1	STATON NOT AFFECTED CHIKKODI_220	14:21	14:46	0:25	HAND TRIPPED
1171	12-Apr-21	BAGALKOT	220	220/110KV, HV1	STATON NOT AFFECTED KARWAR_220	9:47	12:14	2:27	LINE CLEAR AVAILED
1172	12-Apr-21	BAGALKOT	220	220/110KV, HV1&LV1	VAJRAMATTI_220	06:56	07:18	0:22	HAND TRIPPED
1173	12-Apr-21	BAGALKOT	220	220/110KV, HV2	STATON NOT AFFECTED BAGALKOT_220	6:25	6:40	0:15	HAND TRIPPED
1174	12-Apr-21	BAGALKOT	220	220/110KV, HV2&LV2	VAJRAMATTI_220	06:56	07:19	0:23	HAND TRIPPED
1175	12-Apr-21	BAGALKOT	220	220/110KV, HV3	STATON NOT AFFECTED BAGALKOT_220	6:25	6:38	0:13	HAND TRIPPED
1176	12-Apr-21	BAGALKOT	220	BAGALKOT-ALAMATTI1	BAGALKOT_220	6:44	7:01	0:17	HAND TRIPPED
1177	12-Apr-21	BAGALKOT	220	BAGALKOT-ALAMATTI2	BAGALKOT_220	6:44	7:00	0:16	HAND TRIPPED
1178	12-Apr-21	BAGALKOT	220	BAGALKOT-GADAG1	BAGALKOT_220	6:25	06:37	0:12	HAND TRIPPED
1179	12-Apr-21	BAGALKOT	220	BAGALKOT-GADAG2	STATON NOT AFFECTED BAGALKOT_220	6:44	10:21	3:37	LINE CLEAR AVAILED
1180	12-Apr-21	BAGALKOT	220	BAGALKOT-VAJJRAMATTI1	VAJJRAMATTI_220	6:44	07:17	0:33	HAND TRIPPED
1181	12-Apr-21	BAGALKOT	220	BAGALKOT-VAJJRAMATTI1	VAJJRAMATTI_220	6:44	07:18	0:34	HAND TRIPPED
1182	12-Apr-21	BAGALKOT	220	BAGEWADI-ADPH1(ALAMATTI1)	STATON NOT AFFECTED BAGAEWADI_220	5:52	7:03	1:11	LINE CLEAR AVAILED
1183	12-Apr-21	BAGALKOT	220	BAGEWADI-ADPH1(ALAMATTI1)	STATON NOT AFFECTED BAGAEWADI_220	8:51	17:24	8:33	LINE CLEAR AVAILED
1184	12-Apr-21	BAGALKOT	220	BAGEWADI-ADPH2(ALAMATTI2)	STATON NOT AFFECTED BAGAEWADI_220	6:38	7:04	0:26	HAND TRIPPED
1185	12-Apr-21	BAGALKOT	220	BAGEWADI-ADPH2(ALAMATTI2)	STATON NOT AFFECTED BAGAEWADI_220	8:51	17:24	8:33	LINE CLEAR AVAILED
1186	12-Apr-21	BAGALKOT	220	BAGEWADI-ATRIA1&2	ATRIYA IPP_220 STATON NOT AFFECTED BAGAEWADI_220	6:40	7:13	0:33	HAND TRIPPED
1187	12-Apr-21	BAGALKOT	220	BAGEWADI-FORTUNE 1&2	FORTUNE IPP_220 STATON NOT AFFECTED BAGAEWADI_220	5:52	7:08	1:16	LINE CLEAR AVAILED
1188	12-Apr-21	BAGALKOT	220	BAGEWADI-LINGASUR1	BAGAEWADI_220	5:52	7:08	1:16	LINE CLEAR AVAILED
1189	12-Apr-21	BAGALKOT	220	BAGEWADI-LINGASUR2	STATON NOT AFFECTED BAGAEWADI_220	5:52	17:10	11:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1190	12-Apr-21	BAGALKOT	220	BAGEWADI-RBRK	RBRK_IPP_220 STATON NOT AFFECTED BAGAEWADI_220	6:40	7:12	0:32	HAND TRIPPED
1191	12-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI 1	STATION NOT AFFECTED BELGAUM_220	6:57 (12.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1192	12-Apr-21	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	10:31 (05.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1193	12-Apr-21	BAGALKOT	220	GADAG- BAGALKOT2	STATION NOT AFFECTED GADAG_220	10:48 (16.12.2020)			LINE OPEN:LINE CLEAR AVAILED
1194	12-Apr-21	BAGALKOT	220	GADAG-HARTI1(HARTI2)	STATON NOT AFFECTED GADAG_220	12:34	13:26	0:52	HAND TRIPPED
1195	12-Apr-21	BAGALKOT	220	KARWAR-KADRA1	STATION NOT AFFECTED KARWAR_220	10:52 (11.04.2021)	12:11 (12.04.2021)	25:19hrs	LINE CHARGED
1196	12-Apr-21	BAGALKOT	220	MAAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1197	12-Apr-21	BAGALKOT	220	MAHALINGAPUR-SOUDATTI	STATION NOT AFFECTED MAHALINGAPUR_220	9:38 (09.04.2021)			LOAD CURTAILMENT
1198	12-Apr-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN: LINE FAULT
1199	12-Apr-21	BAGALKOT	220	RANEENNUR- SHIRALKOPPA (BELLIGAVI)	RANEENNUR_220	20:05	20:20	0:15	LINE FAULT
1200	12-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI1	STATION NOT AFFECTED SIRSI_220	17:31 (10.04.2021)			LOAD CURTAILMENT
1201	12-Apr-21	BAGALKOT	220	SIRSI220-SHARAVATHI2	STATION NOT AFFECTED SIRSI_220	18:08 (06.03.2021)			LOAD CURTAILMENT
1202	12-Apr-21	BAGALKOT	220	SOUDATTI-MAHALINGAPUR	STATION NOT AFFECTED SOUDATTI_220	16:35 (11.04.2021)			LINE OPEN: LINE FAULT
1203	12-Apr-21	BAGALKOT	220	VAJRAMATTI- MAAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN: LINE FAULT
1204	12-Apr-21	BAGALKOT	220	VAJRAMATTI -MAAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN:LINE CLEAR AVAILED
1205	12-Apr-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	17:25	17:30	0:05	LOAD CHANGEOVER
1206	12-Apr-21	BENGALURU	66	BIDADI 220 - HEJJALA	HEJJALA	5:52	6:00	0:08	LINE FAULT
1207	12-Apr-21	BENGALURU	66	GOWRIBIDANUR 220 - PERESANDRA	PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE	5:50	5:57	0:07	LINE FAULT
1208	12-Apr-21	BENGALURU	66	HENNUR CROSS - VIDYANAGAR	HENNUR CROSS	14:25	15:30	1:05	LINE CLEAR AVAILED
1209	12-Apr-21	BENGALURU	66	HV1	SARJAPURA 220	16:25	16:51	0:25	MAIN SUPPLY FAILURE
1210	12-Apr-21	BENGALURU	66	HV1	KANAKAPURA 66	14:19	14:30	0:10	TRANSFORMER FAULT
1211	12-Apr-21	BENGALURU	66	HV1	TEKAL	12:03	18:25	6:21	LINE CLEAR AVAILED
1212	12-Apr-21	BENGALURU	66	HV1	PRESTIGE SHANTINIKETHAN	22:05	22:13	0:08	TRANSFORMER FAULT
1213	12-Apr-21	BENGALURU	66	HV1	SOUTH CITY	11:38	12:33	0:55	TRANSFORMER FAULT
1214	12-Apr-21	BENGALURU	66	HV2	MAASTHI	10:20	10:57	0:36	LINE CLEAR AVAILED
1215	12-Apr-21	BENGALURU	66	HV2	BTM 4TH PHASE	14:28	14:32	0:04	TRANSFORMER FAULT
1216	12-Apr-21	BENGALURU	66	HV2	CHATRA	7:56	9:06	1:10	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1217	12-Apr-21	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE, BIJJALAHALLI	11:53	11:59	0:06	LINE FAULT
1218	12-Apr-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	10:12	10:16	0:04	LINE FAULT
1219	12-Apr-21	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	10:12	10:16	0:04	LINE FAULT
1220	12-Apr-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	16:25	17:05	0:39	LINE FAULT
1221	12-Apr-21	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	NO STATION AFFECTED	7:28	7:46	0:17	LINE FAULT
1222	12-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 1	SURYANAGAR	13:05	13:27	0:22	LINE CLEAR AVAILED
1223	12-Apr-21	BENGALURU	66	YERANDANAHALLI 220 - ANEKAL 2	ANEKAL	13:05	13:27	0:22	LINE CLEAR AVAILED
1224	12-Apr-21	BENGALURU	220	EDC 220 - NIMHANS 220	NO STATION AFFECTED	20:01(16/02/2021)			LINE OPEN: LINE FAULT
1225	12-Apr-21	BENGALURU	220	GOWRIBIDANUR 220 - AFTL SOLAR	AFTL SOLAR	5:50	5:57	0:07	LINE FAULT
1226	12-Apr-21	BENGALURU	220	GOWRIBIDANUR 220 - PGCIL 2	NO STATION AFFECTED	13:30	13:45	0:15	LINE FAULT
1227	12-Apr-21	BENGALURU	220	HV2	SARJAPURA 220	16:25	17:12	0:47	TRANSFORMER FAULT
1228	12-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY- GULBARGA NORTH2	GULBARGA UNIVERSITY_110	13:55	14:15	00:20	MAIN SUPPLY FAILURE
1229	12-Apr-21	GULBARGA	110	GULBARGA UNIVERSITY- SHAHABAD1	GULBARGA UNIVERSITY_110	8:30(9.04.2021)			LINE OPEN:LINE CLEAR AVAILED
1230	12-Apr-21	GULBARGA	110	GULBARGA WEST-GULBARGA SOUTH	GULBARGA SOUTH_110	6:40(10.04.2021)	19:43(12.04 .2021)	61:03 HRS	LINE CHARGED
1231	12-Apr-21	GULBARGA	110	HV1	BENUR_110	10:05	10:25	00:20	TRANSFORMER FAULT
1232	12-Apr-21	GULBARGA	110	HV1	SIRWAR_110	22:10	22:20	00:10	LINE CLEAR AVAILED
1233	12-Apr-21	GULBARGA	110	HV1	NIRNA_110	07:15	07:20	00:05	TRANSFORMER FAULT
1234	12-Apr-21	GULBARGA	110	HV2	DEODURGA_110	11:15	11:31	00:16	TRANSFORMER FAULT
1235	12-Apr-21	GULBARGA	110	HV2	DEODURGA_110	17:08	17:15	00:07	TRANSFORMER FAULT
1236	12-Apr-21	GULBARGA	110	HV3	KOLHAR	11:25	11:35	00:10	TRANSFORMER FAULT
1237	12-Apr-21	GULBARGA	110	KADAGANCHI-KAPANOOR	KADAGANCHI_110	16:00	20:30	04:30	LINE CLEAR AVAILED
1238	12-Apr-21	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	05:54	06:00	00:06	MAIN SUPPLY FAILURE
1239	12-Apr-21	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	06:08	06:22	00:14	MAIN SUPPLY FAILURE
1240	12-Apr-21	GULBARGA	110	LINGASUGUR-HATTI	HATTI_110	06:33	06:35	00:02	MAIN SUPPLY FAILURE
1241	12-Apr-21	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	14:30	19:09	04:39	LINE FAULT
1242	12-Apr-21	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	18:57	19:10	00:13	LINE FAULT
1243	12-Apr-21	GULBARGA	110	SEDAM-ULTRATECHCEMENTS_IPP	SEDAM_220	08:30	16:32	08:02	LINE CLEAR AVAILED
1244	12-Apr-21	GULBARGA	110	UJJAINI-KOTTUR	UJJANI_66	09:20	09:55	00:35	LINE CLEAR AVAILED
1245	12-Apr-21	GULBARGA	110	YERADONA-BENUR	BENUR_110	01:40	01:55	00:15	MAIN SUPPLY FAILURE
1246	12-Apr-21	GULBARGA	220	HV2	KUDLIGI_220	04:00	05:10	01:10	TRANSFORMER FAULT
1247	12-Apr-21	GULBARGA	220	MALLAT-LINGASUGUR	LINGAPUR_220	05:55	06:22	00:27	LINE FAULT
1248	12-Apr-21	GULBARGA	220	SHAHAPUR-LINGSUGUR	SHAHAPUR_220	05:52	06:15	00:23	LINE FAULT
1249	12-Apr-21	GULBARGA	220	SINDHANOOR-LINGASUGUR	SINDHANOOR_220	05:58	06:43	00:45	LINE FAULT
1250	12-Apr-21	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	08:05	08:16	00:11	LINE FAULT
1251	12-Apr-21	HASSAN	66	CHMANGA-KALSAPURA	CHIKMAGALUR_220	16:36	16:46	00:10	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1252	12-Apr-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:41	13:34	01:53	LINE CLEAR AVAILED
1253	12-Apr-21	HASSAN	66	HV1	HOLEHONNUR_66	11:30	12:35	01:05	MAIN SUPPLY FAILURE
1254	12-Apr-21	HASSAN	66	HV1	KUDLIGERE_66	11:42	12:50	01:08	TRANSFORMER FAULT
1255	12-Apr-21	HASSAN	66	HV1	MOSALEHOSAHALLY_66	11:50	13:35	01:45	NFBC ISSUED
1256	12-Apr-21	HASSAN	66	HV1	SAKLESH PURA_66	16:29	16:41	00:12	TRANSFORMER FAULT
1257	12-Apr-21	HASSAN	66	HV2	UDAYAPURA_66	20:36(11.4.2021)	9:04(12.4.2021)	12:28hrs	TRANSFORMER CHARGED
1258	12-Apr-21	HASSAN	66	HV2	KANDLI_66	10:40	12:30	01:50	LINE CLEAR AVAILED
1259	12-Apr-21	HASSAN	66	LV2	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1260	12-Apr-21	HASSAN	66	LV4	MRS MG_220	9:16 (13.11.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1261	12-Apr-21	HASSAN	66	MRSSHM-DVG2	MRS MG_220	17:11	17:16	00:05	LINE FAULT
1262	12-Apr-21	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	8:50(12.4.2021)			LINE OPEN:LINE CLEAR AVAILED
1263	12-Apr-21	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	08:50	20:07	11:17	LINE CLEAR AVAILED
1264	12-Apr-21	HASSAN	110	HV1	BAIKAMPADY_110	10:17	10:30	00:13	LINE CLEAR AVAILED
1265	12-Apr-21	HASSAN	110	HV1	KONAJE_110	13:26	13:29	00:03	HAND TRIPPED
1266	12-Apr-21	HASSAN	110	HV2	BAIKAMPADY_110	10:38	10:48	00:10	LINE CLEAR AVAILED
1267	12-Apr-21	HASSAN	110	HV2	KONAJE_110	13:26	13:29	00:03	HAND TRIPPED
1268	12-Apr-21	HASSAN	110	HV2	KONDENALU_110	15:00	16:00	01:00	LINE CLEAR AVAILED
1269	12-Apr-21	HASSAN	110	HV2	SAGARA_110	23:29	23:50	00:21	TRANSFORMER FAULT
1270	12-Apr-21	HASSAN	110	HV3	HIRIYADKA_110	10:35	12:36	02:01	LINE CLEAR AVAILED
1271	12-Apr-21	HASSAN	110	HV3	HIRIYADKA_110	23:07	23:13	00:06	TRANSFORMER FAULT
1272	12-Apr-21	HASSAN	110	HV3	KONAJE_110	13:26	13:28	00:02	HAND TRIPPED
1273	12-Apr-21	HASSAN	110	HV4	BAIKAMPADY_110	10:57	11:02	00:05	LINE CLEAR AVAILED
1274	12-Apr-21	HASSAN	110	JOG-JLT4	mghejog_gen	08:57	12:16	03:19	NFBC ISSUED
1275	12-Apr-21	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	23:06(12.4.2021)			LINE OPEN: LINE FAULT
1276	12-Apr-21	HASSAN	110	LPH-MGHE 2	lph_gen	08:59	12:15	03:16	LINE CLEAR AVAILED
1277	12-Apr-21	HASSAN	110	MOODAB-SOHAM1	MOODABIDRE_110	21:15(11.4.2021)			LINE OPEN: LINE FAULT
1278	12-Apr-21	HASSAN	110	MOODAB-SOHAM2	MOODABIDRE_110	21:15(11.4.2021)	11:05(12.4.2021)	13:50hrs	LINE CHARGED
1279	12-Apr-21	HASSAN	110	NERALA-TEREKERE	NERALAKERE_110	12:14	13:18	01:04	LINE CLEAR AVAILED
1280	12-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	00:14	00:27	00:13	HAND TRIPPED
1281	12-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	14:00	14:04	00:04	HAND TRIPPED
1282	12-Apr-21	HASSAN	110	SAGARA-SORABA	SAGARA_110	21:11	21:23	00:12	HAND TRIPPED
1283	12-Apr-21	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	21:04(11.4.21)	13:08(12.4.2021)	16:04hrs	LINE CHARGED
1284	12-Apr-21	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	17:23	17:55	00:32	MAIN SUPPLY FAILURE
1285	12-Apr-21	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	09:59	13:52	03:53	LINE CLEAR AVAILED
1286	12-Apr-21	MYSURU	66	BANNIMANTAP-FTS	NO STATIONS EFFECTED	11:43 (12/04/2021)			LINE OPEN:LINE CLEAR AVAILED
1287	12-Apr-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	12:38	14:19	1:41	LINE CLEAR AVAILED
1288	12-Apr-21	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	18:32	20:30	1:57	LOAD CHANGEOVER
1289	12-Apr-21	MYSURU	66	HV1	ARAKERE_66	7:35	9:53	2:18	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1290	12-Apr-21	MYSURU	66	HV1	ARAKERE_66	14:33	14:37	0:03	TRANSFORMER FAULT
1291	12-Apr-21	MYSURU	66	HV1	ARAKERE_66	15:39	15:45	0:05	TRANSFORMER FAULT
1292	12-Apr-21	MYSURU	66	HV1	DMG_HALLI_66	8:35	8:42	0:07	TRANSFORMER FAULT
1293	12-Apr-21	MYSURU	66	HV1	DODDINADUVADI_66	11:00	14:55	3:55	LINE CLEAR AVAILED
1294	12-Apr-21	MYSURU	66	HV1	PONNAMPET_66	12:36	12:40	0:03	HAND TRIPPED
1295	12-Apr-21	MYSURU	66	HV1	TUBINAKERE_220	11:44	11:57	0:13	TRANSFORMER FAULT
1296	12-Apr-21	MYSURU	66	HV1	SFCSHIVA_66	13:19 (30/03/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1297	12-Apr-21	MYSURU	66	HV2	BGPURA_66	11:34	14:09	2:34	LINE CLEAR AVAILED
1298	12-Apr-21	MYSURU	66	HV2	HAMPAPURA_66	16:00	16:04	0:03	TRANSFORMER FAULT
1299	12-Apr-21	MYSURU	66	HV2	PONNAMPET_66	12:36	12:41	0:04	HAND TRIPPED
1300	12-Apr-21	MYSURU	66	HV3	PONNAMPET_66	12:35	12:38	0:02	HAND TRIPPED
1301	12-Apr-21	MYSURU	66	HV5	SFCSHIVA_66	8:19 (4/4/2021)			TRANSFORMER OPEN:LINE CLEAR AVAILED
1302	12-Apr-21	MYSURU	66	KADAKOLA-DK MAIDANA	NO STATIONS EFFECTED	5:50	6:24	0:33	LINE FAULT
1303	12-Apr-21	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATIONS EFFECTED	5:33 (24/03/2021)	11:20 (12/04/2021)	461:47 HRS	LINE CHARGED
1304	12-Apr-21	MYSURU	66	KR NAGARA-BHERYA	NO STATIONS EFFECTED	10:30 (19/01/2021)			LINE OPEN:LINE CLEAR AVAILED
1305	12-Apr-21	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	12:41	13:26	0:45	HAND TRIPPED
1306	12-Apr-21	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	15:17	15:54	0:36	HAND TRIPPED
1307	12-Apr-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	7:30	7:37	0:07	LINE FAULT
1308	12-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 ADICHUNCHANAGIRI_66 BASARALU_66 BGNAGARA_66 HARADANAHALLI(JAK)_66 KESLAGERE_66 VADERALLI_66	11:11	11:19	0:07	LINE FAULT
1309	12-Apr-21	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	15:44	15:50	0:06	HAND TRIPPED
1310	12-Apr-21	MYSURU	66	VAJMANGALA-KADAKOLA 2	NO STATIONS EFFECTED	5:32	5:56	0:23	LINE FAULT
1311	12-Apr-21	TUMKUR	66	BRAHMASANDRA- SIRA	SIRA_66,ANKASANDRA_66	13:45	14:09	0:24	LINE FAULT
1312	12-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	2:51	3:10	0:18	LINE FAULT
1313	12-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:44	11:55	0:10	LINE FAULT
1314	12-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	14:22	14:42	0:19	LINE FAULT
1315	12-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:24	15:40	0:15	LINE FAULT
1316	12-Apr-21	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	16:51	17:05	0:14	LINE FAULT
1317	12-Apr-21	TUMKUR	66	JAVAGONDANAHALLI- SIRA	JAVAGONDANAHALLI_66	10:03	10:22	0:18	LINE FAULT
1318	12-Apr-21	TUMKUR	66	KALAMARANAHALLI- TATA SOLAR IPP_66	TATA SOLAR_IPP_66	10:54	10:58	0:03	LINE FAULT
1319	12-Apr-21	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:44	13:41	0:56	LINE CLEAR AVAILED
1320	12-Apr-21	TUMKUR	66	TR-1	LINGDHALLI_66	16:16	16:22	0:05	TRANSFORMER FAULT
1321	12-Apr-21	TUMKUR	66	TR-1	PAVAGADA_66	13:21	13:41	0:19	LINE CLEAR AVAILED
1322	12-Apr-21	TUMKUR	66	TR-2	CHIKKABANAGERE_66	13:44	14:06	0:21	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1323	12-Apr-21	TUMKUR	110	CHIKKANAYAKANAHALLI- K B CROSS	CHIKKANAYAKANAHALLI_110,	5:51	6:11	0:19	LINE FAULT
1324	12-Apr-21	TUMKUR	110	CHIKKANAYAKANAHALLI-HULIYAR	CHIKKANAYAKANAHALLI_110, TIMMANAHALLI_110, HANDANKERE_110, HULIYAR_110, SHETYKERE_110	5:51	6:11	0:19	LINE FAULT
1325	12-Apr-21	TUMKUR	110	TR-1	SHETYKERE_110	15:02	15:08	0:06	TRANSFORMER FAULT
1326	12-Apr-21	TUMKUR	110	TR-2	TURUVEKERE_110	19:08	19:18	0:09	TRANSFORMER FAULT
1327	12-Apr-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	9:15	18:48	9:32	LOAD CURTAILMENT