

**400/220/110/66 kV TRANSMISSION OUTAGES FROM 02.11.21 TO 08.11.21**

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1	2-Nov-21	BAGALKOT	66	66/33KV, HV3	STATION NOT AFFECTED HARIHAR HOSPET_66	10:22 (12.09.2021)	13:43 (02.11.2021)	1467:21HRS	TRANSFORMER CHARGED
2	2-Nov-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAIED
3	2-Nov-21	BAGALKOT	110	110/11KV, HV1	HALIYAL_110	18:42	18:52	0:10	TRANSFORMER FAULT
4	2-Nov-21	BAGALKOT	110	110/11KV, HV1	KONNUR_110	12:00	12:45	0:45	MAIN SUPPLY FAILURE
5	2-Nov-21	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	12:00	12:45	0:45	MAIN SUPPLY FAILURE
6	2-Nov-21	BAGALKOT	110	110/11KV, HV1	TADASINKOPPA_110	8:09	9:03	0:54	LINE CLEAR AVAIED
7	2-Nov-21	BAGALKOT	110	110/11KV, HV1	YARAGATTI_110	11:08	14:15	3:07	LINE CLEAR AVAIED
8	2-Nov-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110KV	4:10	4:20	0:10	TRANSFORMER FAULT
9	2-Nov-21	BAGALKOT	110	110/11KV, HV2	SHIROL_110KV	12:30	14:50	2:20	LINE CLEAR AVAIED
10	2-Nov-21	BAGALKOT	110	110/11KV,HV1	AKSHAYA COLONY_110	6:39 (28.10.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
11	2-Nov-21	BAGALKOT	110	110/33KV, HV2	RATTIHALI_110, MASUR_33, HALLUR_33	12:55	13:30	0:35	LINE CLEAR AVAIED
12	2-Nov-21	BAGALKOT	110	110/33KV, HV2	KONNUR_110	12:00	12:45	0:45	MAIN SUPPLY FAILURE
13	2-Nov-21	BAGALKOT	110	AMBEWADI- NK2	KAVALWADA_110	9:50	13:40	3:50	LINE CLEAR AVAIED
14	2-Nov-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.2021)			LINE OPEN: LINE CLEAR AVAIED
15	2-Nov-21	BAGALKOT	110	ANKALGI- ISLAMPUR	ISLAMPUR_110	14:45	15:00	0:15	LINE FAULT
16	2-Nov-21	BAGALKOT	110	BAGALKOT220- NARAGUND	NARAGUND_110	12:00	12:45	0:45	MAIN SUPPLY FAILURE
17	2-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAIED
18	2-Nov-21	BAGALKOT	110	ILKAL- KASHTAGI2	ILKAL_110	7:10	14:10	7:00	HAND TRIPPED
19	2-Nov-21	BAGALKOT	110	KERUR- KONNUR	KONNUR_110	12:00	12:15	0:15	LINE FAULT
20	2-Nov-21	BAGALKOT	110	NARAGUND- BPCL	NARAGUND_110	12:00	12:45	0:45	MAIN SUPPLY FAILURE
21	2-Nov-21	BAGALKOT	110	NAVALGUND- KONNUR	KONNUR_110	12:00	12:45	0:45	MAIN SUPPLY FAILURE
22	2-Nov-21	BAGALKOT	110	RANEBENNUR220- GUTTAL	GUTTAL_110	11:58	12:04	0:06	HAND TRIPPED
23	2-Nov-21	BAGALKOT	110	RANEBENNUR220- HIREKERUR	HIREKERUR_110	11:58	12:04	0:06	HAND TRIPPED
24	2-Nov-21	BAGALKOT	110	RANEBENNUR220- HONNATTI	HONNATTI_110	11:58	12:04	0:06	HAND TRIPPED
25	2-Nov-21	BAGALKOT	110	RANEBENNUR220- TUMMINKATTI	TUMMINKATTI_110	11:58	12:04	0:06	HAND TRIPPED
26	2-Nov-21	BAGALKOT	220	BALLUGAVI- RANEBENNUR	RANEBENNUR_220	11:58	12:31	0:33	MAIN SUPPLY FAILURE
27	2-Nov-21	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	7:01 (02.11.2021)			LINE OPEN: LINE CLEAR AVAIED
28	2-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN:LINE FAULT
29	2-Nov-21	BAGALKOT	220	BELGAUM-KANABARGI1(NARENDRA1)	BELGAUM_220	15:18 (02.11.2021)			LINE OPEN: LINE CLEAR AVAIED
30	2-Nov-21	BAGALKOT	220	BELGAUM-KANABARGI2(NARENDRA2)	BELGAUM_220	12:25	13:38	1:13	HAND TRIPPED
31	2-Nov-21	BAGALKOT	220	BIDNAL- NAGJHARI2	BIDNAL_220	12:38	15:50	3:12	LINE CLEAR AVAIED
32	2-Nov-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAIED
33	2-Nov-21	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	12:35	14:21	1:46	LINE CLEAR AVAIED
34	2-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
35	2-Nov-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN: LINE CLEAR AVAIED
36	2-Nov-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN: LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
37	2-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
38	2-Nov-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
39	2-Nov-21	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	17:55	18:07	0:11	LINE FAULT
40	2-Nov-21	BENGALURU	66	DALSANUR - SRINIVASAPURA	NO STATION AFFECTED	1:20	2:52	1:32	LINE FAULT
41	2-Nov-21	BENGALURU	66	DB PURA 220 - VIJAYAPURA	VIJAYAPURA, JANGAMAKOTE	1:01	1:11	0:10	LINE FAULT
42	2-Nov-21	BENGALURU	66	HV2	TADIGOLU	13:25	14:30	1:05	LINE CLEAR AVAILED
43	2-Nov-21	BENGALURU	66	HV2	RANGANDODDI	12:08	12:41	0:32	TRANSFORMER FAULT
44	2-Nov-21	BENGALURU	66	HV2	HOSKOTE 66	21:27	21:46	0:19	TRANSFORMER FAULT
45	2-Nov-21	BENGALURU	66	HV2	HUKUNDA	6:29	6:33	0:03	TRANSFORMER FAULT
46	2-Nov-21	BENGALURU	66	KOLAR 220 - MULBAGAL	NO STATION AFFECTED	6:13	6:19	0:05	LINE FAULT
47	2-Nov-21	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	12:14	13:34	1:20	LINE FAULT
48	2-Nov-21	BENGALURU	66	KOLAR 220 - SRINIVASAPURA	MALLASANDRA/TD HALLI, DRDO (EHT), DALSINUR, YELDUR	1:22	1:27	0:05	LINE FAULT
49	2-Nov-21	BENGALURU	66	MALLASANDRA - DALASANUR	DALSINUR, YELDUR	1:22	1:45	0:23	MAIN SUPPLY FAILURE
50	2-Nov-21	BENGALURU	66	MALLASANDRA - KOLAR 220	MALLASANDRA, DALSINUR, YELDUR	1:22	1:35	0:13	LINE FAULT
51	2-Nov-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, TORLAKKI	17:56	18:09	0:12	LINE FAULT
52	2-Nov-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	17:56	18:09	0:12	LINE FAULT
53	2-Nov-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	15:50	15:55	0:05	LINE CLEAR AVAILED
54	2-Nov-21	BENGALURU	220	LV1	MITTEMARI 220	10:44(2-11-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
55	2-Nov-21	BENGALURU	400	NELAMANGALA 400 - HIRIYUR 400		3:58	7:21	3:23	LINE FAULT
56	2-Nov-21	GULBARGA	66	UCCHANGIDURGA-NEELAGUNDA	UCCHANGIDURGA_66	6:20	6:30	0:10	MAIN SUPPLY FAILURE
57	2-Nov-21	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	6:05	6:10	0:05	MAIN SUPPLY FAILURE
58	2-Nov-21	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	22:15	22:25	0:10	LINE FAULT
59	2-Nov-21	GULBARGA	110	GHATTARGA-SHAHABAD	GHATTARGA_110	22:15	22:20	0:05	MAIN SUPPLY FAILURE
60	2-Nov-21	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	4:40	4:50	0:10	MAIN SUPPLY FAILURE
61	2-Nov-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	2:20	2:30	0:10	MAIN SUPPLY FAILURE
62	2-Nov-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	22:10	22:20	0:10	MAIN SUPPLY FAILURE
63	2-Nov-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	23:55	0:00	0:05	MAIN SUPPLY FAILURE
64	2-Nov-21	GULBARGA	110	HV1	KAMALNAGAR_110	16:10	16:14	0:04	LINE CLEAR AVAILED
65	2-Nov-21	GULBARGA	110	HV1	CHOWDAPUR_110	11:45	11:50	0:05	TRANSFORMER FAULT
66	2-Nov-21	GULBARGA	110	HV2	GHATTARGA_110	17:45	17:50	0:05	TRANSFORMER FAULT
67	2-Nov-21	GULBARGA	110	KADAGANCHI-KAPANOOR	KADAGANCHI_110	0:17	0:25	0:08	MAIN SUPPLY FAILURE
68	2-Nov-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADAGANCHI_110	0:19	0:25	0:06	LINE FAULT
69	2-Nov-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	6:00	6:12	0:12	LINE FAULT
70	2-Nov-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	18:39	18:46	0:07	LINE FAULT
71	2-Nov-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	4:34	4:44	0:10	LINE FAULT
72	2-Nov-21	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	5:42	5:50	0:08	LINE FAULT
73	2-Nov-21	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	7:00	12:40	5:40	MAIN SUPPLY FAILURE
74	2-Nov-21	GULBARGA	110	NALWAR-SHAHPUR	NALWAR_110	5:40	5:45	0:05	LINE FAULT
75	2-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	4:37	4:45	0:08	LINE FAULT
76	2-Nov-21	GULBARGA	110	SEDAM-KURUKUNTA	KURUKUNTA_110	12:20	15:50	3:30	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
77	2-Nov-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAO N_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	1:57	2:04	0:07	LINE FAULT
78	2-Nov-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAO N_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	4:45	4:48	0:03	LINE FAULT
79	2-Nov-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAO N_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	6:05	6:10	0:05	LINE FAULT
80	2-Nov-21	GULBARGA	110	SHAHABAD-BAGEWADI1	MADEWAL_110,MORATAGI_110,DEVANGAO N_110,RENUKA_IPP,AFZALPUR_110,KARAJAGI_110	11:52	12:20	0:28	LINE FAULT
81	2-Nov-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	6:05	6:10	0:05	LINE FAULT
82	2-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
83	2-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN:LINE FAULT
84	2-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
85	2-Nov-21	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGURS_IPP,ASKI_IPP,HUNSAGI_110	23:54	23:58	0:04	LINE FAULT
86	2-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	3:34	3:50	0:16	LINE FAULT
87	2-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	3:34	3:50	0:16	LINE FAULT
88	2-Nov-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADONA_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	1:28	1:38	0:10	LINE FAULT
89	2-Nov-21	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,YERADONA_110,BENNUR_110,BTPS WATER WORKS,KAMPLI_110	3:58	4:08	0:10	LINE FAULT
90	2-Nov-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	1:30	1:40	0:10	MAIN SUPPLY FAILURE
91	2-Nov-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	3:50	4:10	0:20	MAIN SUPPLY FAILURE
92	2-Nov-21	GULBARGA	110	YERADONA-SINDHNOOR	YERADONA_110	21:30	21:40	0:10	MAIN SUPPLY FAILURE
93	2-Nov-21	GULBARGA	220	HV 1 & 2	KUSTAGI_220	6:54	12:32	5:38	LINE CLEAR AVAILED
94	2-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
95	2-Nov-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:22(01.11.2021)	8:06(02.11.2021)	9:44HRS	LINE CHARGED
96	2-Nov-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	5:37	5:56	0:19	LINE FAULT
97	2-Nov-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	6:17	7:43	1:26	LINE FAULT
98	2-Nov-21	HASSAN	66	ARAKAL-MALLIPATNA	ARKD_66	12:32	12:45	0:13	LINE FAULT
99	2-Nov-21	HASSAN	66	CHANNAR-HIRESAVE	CHANNARAYAPATNA_66	11:41	12:50	1:09	LINE CLEAR AVAILED
100	2-Nov-21	HASSAN	66	HV1	YESLUR_66	12:32	12:47	0:15	MAIN SUPPLY FAILURE
101	2-Nov-21	HASSAN	66	SAKALE-HANBAL	SAKLESHIPURA_66	8:13	8:32	0:19	LINE FAULT
102	2-Nov-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	19:15	19:45	0:30	LINE FAULT
103	2-Nov-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	19:15	19:32	0:17	HAND TRIPPED
104	2-Nov-21	HASSAN	110	HIRIYA-MANIPAL	HIRIYADKA_110	9:44	13:40	3:56	LINE CLEAR AVAILED
105	2-Nov-21	HASSAN	110	HV1	ESSUR_110	10:01	13:37	3:36	LINE CLEAR AVAILED
106	2-Nov-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
107	2-Nov-21	HASSAN	110	HV2	SHIRALKOPPA_220	16:25	19:26	3:01	TRANSFORMER FAULT
108	2-Nov-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	19:15	19:46	0:31	LINE FAULT
109	2-Nov-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	19:15	19:32	0:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
110	2-Nov-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	16:36	17:13	0:37	LINE FAULT
111	2-Nov-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	16:36	17:54	1:18	LINE FAULT
112	2-Nov-21	HASSAN	110	LV2	MSEZ_220	10:50	13:52	3:02	LINE CLEAR AVAIED
113	2-Nov-21	HASSAN	110	LV2	MSEZ_220	10:50	13:52	3:02	LINE CLEAR AVAIED
114	2-Nov-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	16:35	17:17	0:42	MAIN SUPPLY FAILURE
115	2-Nov-21	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:44	13:40	3:56	NFBC ISSUED
116	2-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	16:35	17:17	0:42	MAIN SUPPLY FAILURE
117	2-Nov-21	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	11:57	12:32	0:35	MAIN SUPPLY FAILURE
118	2-Nov-21	HASSAN	110	SHRLKP-KITTADAHALLI	SHIRALKOPPA_220	11:57	12:32	0:35	MAIN SUPPLY FAILURE
119	2-Nov-21	HASSAN	110	SHRLKP-SHIKARIPURA	SHIRALKOPPA_220	11:57	12:32	0:35	MAIN SUPPLY FAILURE
120	2-Nov-21	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:57	12:32	0:35	MAIN SUPPLY FAILURE
121	2-Nov-21	HASSAN	110	SHRLKP-SORAB	SHIRALKOPPA_220	11:57	12:32	0:35	MAIN SUPPLY FAILURE
122	2-Nov-21	HASSAN	110	SORABA-SHR220	SORABA_110	13:13 (30.10.2021)			LINE OPEN: LINE CLEAR AVAIED
123	2-Nov-21	HASSAN	220	KEMAR-HEGGUNJE	KEMAR_220	10:12	11:46	1:34	NFBC ISSUED
124	2-Nov-21	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	10:25	11:27	1:02	LINE FAULT
125	2-Nov-21	HASSAN	220	SHRAVTY-SHIMOGA3	SHRAVTY	10:25	11:27	1:02	LINE FAULT
126	2-Nov-21	HASSAN	220	SHRAVTY-SHIRALKOPPA	sharavathy_gen	11:57	16:00	4:03	LINE FAULT
127	2-Nov-21	HASSAN	220	SHRLKP-SGS	SHIRALKOPPA_220	11:57	16:00	4:03	LINE FAULT
128	2-Nov-21	HASSAN	220	VARAHHI-HEGGUNJE	varahi_gen	11:53	12:50	0:57	LINE CLEAR AVAIED
129	2-Nov-21	MYSURU	66	BEGURU-B MATAKERE	NO STATIONS EFFECTED	5:59	6:14	22:44	LINE FAULT
130	2-Nov-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	9:45	9:51	0:06	LINE FAULT
131	2-Nov-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN: LINE CLEAR AVAIED
132	2-Nov-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN: LINE CLEAR AVAIED
133	2-Nov-21	MYSURU	66	HV1	HONNALLY_MYS_66	12:27	13:15	0:48	LINE CLEAR AVAIED
134	2-Nov-21	MYSURU	66	HV1	HANNUR_66	8:25:31 (01.11.2021)	14:30:00 (2.11.2021)	30:04HRS	TRANSFORMER CHARGED
135	2-Nov-21	MYSURU	66	HV2	THANDYA_66	12:14	13:53	1:39	LINE CLEAR AVAIED
136	2-Nov-21	MYSURU	66	KR NAGARA-BILIKERE	BILIKERE_66 GVGUDI_66	10:40	13:23	2:42	NFBC ISSUED
137	2-Nov-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN: LINE CLEAR AVAIED
138	2-Nov-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN: LINE CLEAR AVAIED
139	2-Nov-21	MYSURU	66	KUSHALANAGARA-MYSORE 1	MIRLE_66 BILIKERE_66 GVGUDI_66 KRNAGARA_66	0:58	1:04	0:06	LINE FAULT
140	2-Nov-21	MYSURU	66	MADHUVANAHALLI-LOKKANAHALLI	LOKKANAHALLI_66 PG PALYA_66	23:58:54(01.11.2021)	00:02:00 (2.11.2021)	03:06HRS	LINE CHARGED
141	2-Nov-21	MYSURU	66	MADHUVANALLI-KUNTHUR	KUNTHUR_66 MUGUR_66 THAYURU_66 JANNUR_66 TNARASIPURA_66	6:49	6:52	0:03	LINE FAULT
142	2-Nov-21	MYSURU	66	MADHUVANALLI-LOKKANAHALLI	PGPALYA_66 LOKKANNALLI_66	21:58	22:13	0:15	LINE FAULT
143	2-Nov-21	MYSURU	66	MEGHALAPURA-HEBBANI	BGPURA_66 CHANDALLI_66 THALAKADU_66 VYASRAJPURA_66 GARGESHWARI_66 THUMBLA_66 PARINAMIPURA_66 CHIDRAVALLI_66	18:22	18:39	0:16	LINE FAULT
144	2-Nov-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN: LINE CLEAR AVAIED
145	2-Nov-21	MYSURU	66	VAJMANGALA-KADAKOLAZ	NO STATIONS EFFECTED	10:54	11:00	0:06	LINE FAULT
146	2-Nov-21	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
147	2-Nov-21	TUMKUR	66	ANCHEPALYA 220KV- AMRUTHUR	AMRUTHUR_66, SANTEMVATTUR_66, YADAVANI_66	5:50	6:04	0:13	LINE FAULT
148	2-Nov-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:37	12:48	0:10	LINE FAULT
149	2-Nov-21	TUMKUR	66	DAVANGERE SRS- YARAGUNTA(HARIHARA)	YARAGUNTA_66, OBAJIHALLI_66	12:37	12:46	0:08	LINE FAULT
150	2-Nov-21	TUMKUR	66	HARIYABBE-CHIKKABANAGERE(P D KOTE)	HARIYABBE_66	12:42	13:01	0:19	HAND TRIPPED
151	2-Nov-21	TUMKUR	66	HARIYABBE-HIRIYUR	HARIYABBE_66	12:41	13:01	0:19	HAND TRIPPED
152	2-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:22	6:26	0:03	LINE FAULT
153	2-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:16	10:22	0:05	LINE FAULT
154	2-Nov-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66	21:28(2.11.21)	1:00:25 AM(3.11.21)	3:57HRS	LINE CHARGED
155	2-Nov-21	TUMKUR	66	PAVAGADA- (GOWRIBIDANUR)VENKATAPURA	VENKATAPURA_66(GOWRIBIDANUR_66)	11:08	11:20	0:11	LINE FAULT
156	2-Nov-21	TUMKUR	66	TR-1	BEVINAHALLI_66	16:21	16:31	0:10	HAND TRIPPED
157	2-Nov-21	TUMKUR	66	TR-1	PAVAGADA_66	13:01	14:16	1:14	LINE CLEAR AVAILED
158	2-Nov-21	TUMKUR	66	TR2	GULIGENAHALLI_66	15:55	16:01	0:05	TRANSFORMER FAULT
159	2-Nov-21	TUMKUR	66	TR-2	PAVAGADA_66	13:01	14:01	0:59	LINE CLEAR AVAILED
160	2-Nov-21	TUMKUR	66	TR-2	RAMAPURA_66	11:04	12:21	1:16	LINE CLEAR AVAILED
161	2-Nov-21	TUMKUR	110	TR-1	KBCROSS_220	6:04	16:25	10:20	TRANSFORMER FAULT
162	3-Nov-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
163	3-Nov-21	BAGALKOT	110	110/11KV, HV1	SOUDATTI_220	6:13	7:39	1:26	HAND TRIPPED
164	3-Nov-21	BAGALKOT	110	110/11KV, HV2	MUDDEBIHAL_110	12:07	12:13	0:06	TRANSFORMER FAULT
165	3-Nov-21	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(G)_110	11:10	14:07	2:57	LINE CLEAR AVAILED
166	3-Nov-21	BAGALKOT	110	110/11KV, HV2	KULIGOD_110	13:53	16:16	2:23	LINE CLEAR AVAILED
167	3-Nov-21	BAGALKOT	110	110/11KV, HV2	ALMEL_110	18:11	18:16	0:05	TRANSFORMER FAULT
168	3-Nov-21	BAGALKOT	110	110/11KV, HV1	AKSHAYA COLONY_110	6:39 (28.10.2021)	12:09 (03.11.2021)	149:30HRS	TRANSFORMER CHARGED
169	3-Nov-21	BAGALKOT	110	220/110KV, LV3	HUBLI_220	13:19 (03.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
170	3-Nov-21	BAGALKOT	110	ALMEL- JAMKHANDI SUGARS	ALMEL_110	1:27	1:30	0:03	LINE FAULT
171	3-Nov-21	BAGALKOT	110	ALMEL- KPR SUGARS	ALMEL_110	1:27	1:30	0:03	LINE FAULT
172	3-Nov-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.2021)			LINE OPEN: LINE CLEAR AVAILED
173	3-Nov-21	BAGALKOT	110	BELGAUM220- BELGAUM	BELGAUM_110	18:50	20:20	1:30	HAND TRIPPED
174	3-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
175	3-Nov-21	BAGALKOT	110	HUBLI220- RAMANKOPPA	RAMANKOPPA_110	0:24	7:48	7:24	LINE FAULT
176	3-Nov-21	BAGALKOT	110	INDI220- DEVARHIPPARAGI	ATHARGA_110, HIREMASALI_110, DEVAR HIPPARAGI_110	4:20	4:35	0:15	LINE FAULT
177	3-Nov-21	BAGALKOT	110	INDI220- LACHYAN	LACHYAN_110, HIREBEVNUR_110, RODAGI_110	4:20	4:35	0:15	LINE FAULT
178	3-Nov-21	BAGALKOT	110	JOG- SIRSI	SIRSI_110	20:50 (03.11.2021)			LINE OPEN:LINE FAULT
179	3-Nov-21	BAGALKOT	110	MALGHAN- MANALI SUGARS	MALGHAN(S)_110	18:28	18:33	0:05	LINE FAULT
180	3-Nov-21	BAGALKOT	110	MALGHAN- MANALI SUGARS	MALGHAN(S)_110	18:35	18:48	0:13	LINE FAULT
181	3-Nov-21	BAGALKOT	110	SOUDATTI220- ARATAGAL	ARATAGAL_110	6:15	7:55	1:40	MAIN SUPPLY FAILURE
182	3-Nov-21	BAGALKOT	110	SOUDATTI220- BENAKATTI	BENAKATTI_110	6:15	7:55	1:40	MAIN SUPPLY FAILURE
183	3-Nov-21	BAGALKOT	110	SOUDATTI220- KATKOL	KATAKOL_110	6:15	8:05	1:50	MAIN SUPPLY FAILURE
184	3-Nov-21	BAGALKOT	110	SOUDATTI220- MMCL	SOUDATTI_220	6:15	8:18	2:03	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
185	3-Nov-21	BAGALKOT	110	SLOUDATTI220- MUNAVALLI	MUNAVALLI_110	7:08	7:51	1:35	HAND TRIPPED
186	3-Nov-21	BAGALKOT	110	SLOUDATTI220- RAMDURGA1	RAMADURGA_110	7:08	8:07	2:47	HAND TRIPPED
187	3-Nov-21	BAGALKOT	110	SLOUDATTI220- RAMDURGA2	RAMADURGA_110	7:08	7:54	1:42	HAND TRIPPED
188	3-Nov-21	BAGALKOT	110	SLOUDATTI220- SOUDATTI1&2	SOUDATTI	7:08	7:58	1:45	HAND TRIPPED
189	3-Nov-21	BAGALKOT	110	SLOUDATTI220- UDIKERI	UDIKERI_110	6:15	8:05	1:50	MAIN SUPPLY FAILURE
190	3-Nov-21	BAGALKOT	110	SLOUDATTI220- YARAGATTI	YARAGATTI_110	7:08	7:56	1:42	HAND TRIPPED
191	3-Nov-21	BAGALKOT	220	220/110KV, HV1	SOUDATTI_220	6:13	7:41	1:28	TRANSFORMER FAULT
192	3-Nov-21	BAGALKOT	220	220/110KV, HV3	HUBLI_220	13:19	15:08	1:49	LINE CLEAR AVAILED
193	3-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN:LINE FAULT
194	3-Nov-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
195	3-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
196	3-Nov-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN: LINE CLEAR AVAILED
197	3-Nov-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN: LINE CLEAR AVAILED
198	3-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
199	3-Nov-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
200	3-Nov-21	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	8:50	8:55	0:05	LOAD CHANGE OVER
201	3-Nov-21	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:10	18:15	0:04	LINE FAULT
202	3-Nov-21	BENGALURU	66	DB PURA 220 - DG 2	DODDABELAVANGALA	13:14	13:26	0:12	LINE CLEAR AVAILED
203	3-Nov-21	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	7:27	8:27	1:00	MAIN SUPPLY FAILURE
204	3-Nov-21	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	7:27	7:41	0:14	MAIN SUPPLY FAILURE
205	3-Nov-21	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	7:27	7:48	0:21	MAIN SUPPLY FAILURE
206	3-Nov-21	BENGALURU	66	HENNUR CROSS - SHOBHA CITY	HENNUR CROSS	15:06	15:08	0:02	LOAD CHANGE OVER
207	3-Nov-21	BENGALURU	66	HV1	SM MANGALA	9:30	10:22	0:51	LINE CLEAR AVAILED
208	3-Nov-21	BENGALURU	66	HV1	M GOLLAHALLI	20:54	21:11	0:16	TRANSFORMER FAULT
209	3-Nov-21	BENGALURU	66	HV1	KGF	7:00	7:38	0:38	TRANSFORMER FAULT
210	3-Nov-21	BENGALURU	66	HV1	RR NAGAR	13:08	14:35	1:27	TRANSFORMER FAULT
211	3-Nov-21	BENGALURU	66	KANASWADI - DB PURA 220	KANASWADI	14:20	14:25	0:05	LOAD CHANGE OVER
212	3-Nov-21	BENGALURU	66	MAHALAKSHMI LAYOUT - SRS PEENYA 220	MAHALAKSHMI LAYOUT	7:27	7:40	0:13	MAIN SUPPLY FAILURE
213	3-Nov-21	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	7:41	9:04	1:22	LOAD CHANGE OVER
214	3-Nov-21	BENGALURU	66	MITTEMARI 220 - SOMANATHPURA	SOMANATHPURA, CHAKAVELU, CHELUR, YENIGADALE	17:57	18:05	0:08	LINE FAULT
215	3-Nov-21	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	8:03	8:10	0:07	LOAD CHANGE OVER
216	3-Nov-21	BENGALURU	66	NANDINI LAYOUT - NRS 220	NANDINI LAYOUT	8:56	9:02	0:06	LOAD CHANGE OVER
217	3-Nov-21	BENGALURU	66	PLATINUM CITY - DG 4	PLATINUM CITY	10:15	10:20	0:05	LOAD CHANGE OVER
218	3-Nov-21	BENGALURU	66	REMCO - VIJAYNAGAR	VIJAYNAGAR	16:18	16:33	0:15	LINE FAULT
219	3-Nov-21	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	7:27	7:47	0:19	MAIN SUPPLY FAILURE
220	3-Nov-21	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	7:27	7:47	0:19	MAIN SUPPLY FAILURE
221	3-Nov-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	7:39	8:17	0:37	MAIN SUPPLY FAILURE
222	3-Nov-21	BENGALURU	66	SRS PEENYA 220 - PLATINUM CITY	PLATINUM CITY	7:27	7:54	0:26	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
223	3-Nov-21	BENGALURU	66	SRS PEENYA 220 - WEL CAST	WEL CAST	7:39	8:28	0:49	MAIN SUPPLY FAILURE
224	3-Nov-21	BENGALURU	66	SRS PEENYA 220 - WEL CAST	NO STATION AFFECTED	8:38	10:16	1:37	LINE FAULT
225	3-Nov-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	11:02	11:09	0:07	LINE CLEAR AVAIED
226	3-Nov-21	BENGALURU	66	SUBRAMANYAPURA 220 - REMCO 2	GLOBAL VILLAGE (EHT)	13:08	13:15	0:06	LINE CLEAR AVAIED
227	3-Nov-21	BENGALURU	66	VIDYANAGAR - HENNUR CROSS	HENNUR CROSS	7:45	7:58	0:12	LINE FAULT
228	3-Nov-21	BENGALURU	66	VIDYANAGAR - HOSKOTE 220	NO STATION AFFECTED	9:46	14:20	4:33	LINE CLEAR AVAIED
229	3-Nov-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	12:32	13:25	0:52	LINE FAULT
230	3-Nov-21	BENGALURU	220	HV2	SRS PEENYA 220	7:27	8:14	0:46	TRANSFORMER FAULT
231	3-Nov-21	BENGALURU	220	HV4	SRS PEENYA 220	7:27	8:11	0:43	TRANSFORMER FAULT
232	3-Nov-21	BENGALURU	220	LV1	MITTEMARI 220	10:44(2-11-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
233	3-Nov-21	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66	3:25	3:30	0:05	MAIN SUPPLY FAILURE
234	3-Nov-21	GULBARGA	66	BENNEHALLI-ITTAGGI	BENNEHALLI_66	6:00	6:20	0:20	MAIN SUPPLY FAILURE
235	3-Nov-21	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	19:35	19:45	0:10	MAIN SUPPLY FAILURE
236	3-Nov-21	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66,KOTTUR_66, UJJAINI_66	3:24	3:30	0:06	LINE FAULT
237	3-Nov-21	GULBARGA	66	ITTAGI-SUZLON2	ITTAGI_220	18:03	18:35	0:32	LINE FAULT
238	3-Nov-21	GULBARGA	66	KUDLIGI-KUDLIGI_66	KUDLIGI_66,HANSI_66	19:30	19:40	0:10	LINE FAULT
239	3-Nov-21	GULBARGA	66	LV1	ITTAGI_220	18:03	18:15	0:12	TRANSFORMER FAULT
240	3-Nov-21	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,RSSTEELS_66,UPHALLI_66,H BHALLI_66	6:04	6:18	0:14	LINE FAULT
241	3-Nov-21	GULBARGA	66	MUNIRABAD-MSDLINE	HANASI_66	2:45	2:50	0:05	LINE FAULT
242	3-Nov-21	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66	21:05	21:15	0:10	MAIN SUPPLY FAILURE
243	3-Nov-21	GULBARGA	66	UCCHANGIDURGA-NEELAGUNDA	UCCHANGIDURGA_66	21:05	21:15	0:10	MAIN SUPPLY FAILURE
244	3-Nov-21	GULBARGA	110	HUNSIGI-KEMBHAVI	HUNSIGI_110	19:20	19:30	0:10	MAIN SUPPLY FAILURE
245	3-Nov-21	GULBARGA	110	HV1	BENNUR_110	13:00	13:10	0:10	TRANSFORMER FAULT
246	3-Nov-21	GULBARGA	110	HV1	MATAMARI_110	10:45	10:50	0:05	TRANSFORMER FAULT
247	3-Nov-21	GULBARGA	110	HV1,HV2	BAYYAPURA_110	9:45	11:30	1:45	LINE CLEAR AVAIED
248	3-Nov-21	GULBARGA	110	HV2	GHATTARGA_110	10:10	10:20	0:10	TRANSFORMER FAULT
249	3-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	19:05	19:30	0:25	LINE FAULT
250	3-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	21:40	21:45	0:05	LINE FAULT
251	3-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	23:40	23:45	0:05	LINE FAULT
252	3-Nov-21	GULBARGA	110	KUSTAGI-HANUMASAGAR	HANUMASAGAR_110,HIREGONNAGAR_110,H ANUMNAL_110	19:30	19:43	0:13	LINE FAULT
253	3-Nov-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	19:05	19:15	0:10	LINE FAULT
254	3-Nov-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	20:50	20:58	0:08	LINE FAULT
255	3-Nov-21	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110,VALKAMDINNI_110	19:29	19:41	0:12	LINE FAULT
256	3-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	16:10	16:19	0:09	LINE FAULT
257	3-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	15:54	18:30	2:36	LINE CLEAR AVAIED
258	3-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	23:04	23:22	0:18	LINE FAULT
259	3-Nov-21	GULBARGA	110	SHAHABAD-BAGEWADI2	YADRAMI_110,MORATAGI_110	22:10	22:16	0:06	LINE FAULT
260	3-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAIED
261	3-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN:LINE FAULT
262	3-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
263	3-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR1 & 2	DEODURGA_110	16:36	18:29	1:53	LINE CLEAR AVAILED
264	3-Nov-21	GULBARGA	110	STARMETALLICS_IPP-SINDHNOOR	SINDHNOOR_220	6:00	6:22	0:22	LINE FAULT
265	3-Nov-21	GULBARGA	110	VALKAMDINNI-SINDHANOOR	VALKAMDINNI_110	19:15	19:30	0:15	MAIN SUPPLY FAILURE
266	3-Nov-21	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	12:40	13:05	0:25	MAIN SUPPLY FAILURE
267	3-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
268	3-Nov-21	GULBARGA	220	HV2	ITTAGI_220	18:03	18:18	0:15	TRANSFORMER FAULT
269	3-Nov-21	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	1:00	1:16	0:16	LINE FAULT
270	3-Nov-21	GULBARGA	220	SHAHAPUR-RTPS1	SHAHAPUR_220	4:17	4:53	0:36	LINE FAULT
271	3-Nov-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	15:59	17:06	1:07	MAIN SUPPLY FAILURE
272	3-Nov-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	15:59	17:06	1:07	MAIN SUPPLY FAILURE
273	3-Nov-21	HASSAN	110	HALADY1-HEGGUNJE	HALADY_110	12:42	16:24	3:42	LINE CLEAR AVAILED
274	3-Nov-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
275	3-Nov-21	HASSAN	110	HV2	BANAVARA_110	13:55	14:15	0:20	MAIN SUPPLY FAILURE
276	3-Nov-21	HASSAN	110	JOG-JLT4	mghejog_gen	10:30	12:45	2:15	LINE CLEAR AVAILED
277	3-Nov-21	HASSAN	110	JOG-NK2	mghejog_gen	21:11 (3.110.2021)			LINE OPEN: LINE CLEAR AVAILED
278	3-Nov-21	HASSAN	110	JOG-NK2	mghejog_gen	20:54	21:00	0:06	LINE FAULT
279	3-Nov-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:59	17:06	1:07	LINE FAULT
280	3-Nov-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	15:59	17:06	1:07	LINE FAULT
281	3-Nov-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	19:56 (3.11.2021)			LINE OPEN: LINE CLEAR AVAILED
282	3-Nov-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	17:27	18:15	0:48	LINE FAULT
283	3-Nov-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	18:56	19:16	0:20	LINE FAULT
284	3-Nov-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	17:27	18:15	0:48	LINE FAULT
285	3-Nov-21	HASSAN	110	KEMAR-Manipal2	KEMAR_220	19:08	19:40	0:32	LINE FAULT
286	3-Nov-21	HASSAN	110	LPH-MGHE 2	lph_gen	10:36	12:36	2:00	LINE CLEAR AVAILED
287	3-Nov-21	HASSAN	110	LV1	ARASIKERE_220	13:54	14:14	0:20	TRANSFORMER FAULT
288	3-Nov-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	17:20	18:50	1:30	LINE FAULT
289	3-Nov-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	19:18	19:46	0:28	HAND TRIPPED
290	3-Nov-21	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	18:58 (3.11.2021)			LINE OPEN:LINE FAULT
291	3-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	2015(3.11.2021)			LINE OPEN: LINE CLEAR AVAILED
292	3-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	17:28	18:50	1:22	MAIN SUPPLY FAILURE
293	3-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	18:58	19:16	0:18	HAND TRIPPED
294	3-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	19:18	19:40	0:22	LINE FAULT
295	3-Nov-21	HASSAN	110	SORABA-SHR220	SORABA_110	13:13 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
296	3-Nov-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:44 (3.11.2021)			LINE OPEN:LINE FAULT
297	3-Nov-21	HASSAN	220	HV1	ARASIKERE_220	13:54	14:14	0:20	TRANSFORMER FAULT
298	3-Nov-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:54	17:03	1:09	LINE FAULT
299	3-Nov-21	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	5:56	10:37	4:41	NFBC ISSUED
300	3-Nov-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:44(3.11.2021)			LINE OPEN:LINE FAULT
301	3-Nov-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:54	17:04	1:10	LINE FAULT
302	3-Nov-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:54	17:02	1:08	HAND TRIPPED
303	3-Nov-21	MYSURU	66	DK MAIDANA-VAJMANGALA	NO STATIONS EFFECTED	19:19	22:40	3:20	LOAD CHANGE OVER



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
304	3-Nov-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
305	3-Nov-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
306	3-Nov-21	MYSURU	66	HUNSUR-ELWALA	GAVADAGERE_66	6:14	6:31	0:17	LINE FAULT
307	3-Nov-21	MYSURU	66	HV1	HANNUR_66	11:41	12:47	1:06	LINE CLEAR AVAILED
308	3-Nov-21	MYSURU	66	HV2	DATTAGALLY_66	11:13	12:34	22:44	LINE CLEAR AVAILED
309	3-Nov-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
310	3-Nov-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN: LINE CLEAR AVAILED
311	3-Nov-21	MYSURU	66	KUSHALANAGARA-MYSORE-2	KITTUR_66 RAVANDUR_66 BETTADHAPURA_66	23:10	23:30	0:20	LINE FAULT
312	3-Nov-21	MYSURU	66	MADHUVANALLI-KOLLEGALA	NO STATIONS EFFECTED	10:54	10:59	0:05	LINE FAULT
313	3-Nov-21	MYSURU	66	MEGHALAPURA-HEBBANI	BGPURA_66 CHANDALLI_66 THALAKADU_66 VYASRAJPURA_66 GARGESHWARI_66 THUMBLA_66 PARINAMIPURA_66 CHIDRAVALLI_66	6:31	6:46	0:14	LINE FAULT
314	3-Nov-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50(5.10.2021)			LINE OPEN: LINE CLEAR AVAILED
315	3-Nov-21	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
316	3-Nov-21	TUMKUR	66	BENNEHALLI-RBPL-ITTAGI	BENNEHALLI_66	3:24	3:36	0:12	LINE FAULT
317	3-Nov-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	18:04	18:13	0:08	LINE FAULT
318	3-Nov-21	TUMKUR	66	DAVANGERE SRS- CHITRADURGA1	CHITRADURGA_220	18:04	18:13	0:08	LINE FAULT
319	3-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:42	10:49	0:06	HAND TRIPPED
320	3-Nov-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66	23:32	23:35	0:03	LINE FAULT
321	3-Nov-21	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	13:17	13:22	0:04	LINE FAULT
322	3-Nov-21	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	JAVAGONDANAHALLI_66	13:17	13:18	0:01	LINE FAULT
323	3-Nov-21	TUMKUR	66	LINGADAHALLI- SHIMOGA(NALLUR)	LINGDHALLI_66	15:14	15:21	0:07	LINE FAULT
324	3-Nov-21	TUMKUR	66	THALLAK 220kV- GOWRASAMUDRA	CHALLAKERE_66, SANIKERE_66	6:20	9:05	2:45	LINE FAULT
325	3-Nov-21	TUMKUR	66	TR-1	HANGAL_66	11:12	11:26	0:13	LINE CLEAR AVAILED
326	3-Nov-21	TUMKUR	66	TR-1	JIDDIGERE_66	8:19	8:22	0:02	HAND TRIPPED
327	3-Nov-21	TUMKUR	66	TR-1	LOKIKERE_66	14:56	15:10	0:14	TRANSFORMER FAULT
328	3-Nov-21	TUMKUR	220	CHITRADURGA 220- GUTTUR 220	CHITRADURGA_220	14:47(3.11.21)	7:48(4.11.21)	17:01HRS	LINE CHARGED
329	4-Nov-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
330	4-Nov-21	BAGALKOT	110	110/11KV, HV1	ZALKI_110	18:02	18:53	0:51	TRANSFORMER FAULT
331	4-Nov-21	BAGALKOT	110	110/11KV, HV2	TIKOTA_110	16:57	17:06	0:09	TRANSFORMER FAULT
332	4-Nov-21	BAGALKOT	110	110/11KV, HV2	SINDAGI_110	21:10 (04.11.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
333	4-Nov-21	BAGALKOT	110	110/11KV,HV1	MANTUR(GHP)_110	1:30	8:25	6:55	TRANSFORMER FAULT
334	4-Nov-21	BAGALKOT	110	110/11KV,HV1	BISNAL_110	22:00	22:15	0:15	HAND TRIPPED
335	4-Nov-21	BAGALKOT	110	110/11KV,HV1	MANTUR(GHP)_110	1:30	8:25	6:55	TRANSFORMER FAULT
336	4-Nov-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:08	13:38	1:30	LINE CLEAR AVAILED
337	4-Nov-21	BAGALKOT	110	110/11KV,HV2	KIADBBIJAPUR_110	3:19	4:14	0:55	TRANSFORMER FAULT
338	4-Nov-21	BAGALKOT	110	110/11KV,HV2	MANTUR(GHP)_110	1:30	8:25	6:55	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
339	4-Nov-21	BAGALKOT	110	110/11KV,HV2	MANTUR(GHP)_110	1:30	8:25	6:55	TRANSFORMER FAULT
340	4-Nov-21	BAGALKOT	110	110/33KV, HV2	UTTUR_110, YADAWAD_33	4:23	4:31	0:08	TRANSFORMER FAULT
341	4-Nov-21	BAGALKOT	110	110/33KV, HV3	TODALBAGI_110, HIREPADASALAGI_33, BIDARI_33, JRK_33	13:54	14:08	0:14	TRANSFORMER FAULT
342	4-Nov-21	BAGALKOT	110	110/33KV,HV2	TEGGI_33 BISNAL_110	22:00	22:15	0:15	HAND TRIPPED
343	4-Nov-21	BAGALKOT	110	220/110KV, LV3	HUBLI_220	13:19 (03.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
344	4-Nov-21	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	17:35 (04.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
345	4-Nov-21	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	1:05	8:50	7:45	HAND TRIPPED
346	4-Nov-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.2021)			LINE OPEN: LINE CLEAR AVAILED
347	4-Nov-21	BAGALKOT	110	BILAGI-BISNAL	BISNAL_110	22:05	22:15	0:10	MAIN SUPPLY FAILURE
348	4-Nov-21	BAGALKOT	110	BILAGI-GIRISAGAR	BILAGI_110	22:05	22:15	0:10	MAIN SUPPLY FAILURE
349	4-Nov-21	BAGALKOT	110	BILAGI-GIRISAGAR	GIRISAGAR_110	22:05	22:15	0:10	MAIN SUPPLY FAILURE
350	4-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
351	4-Nov-21	BAGALKOT	110	HIDIKAL 1-ITANAL	ITANAL_110	10:26	10:57	0:31	LINE FAULT
352	4-Nov-21	BAGALKOT	110	JOG2(JOG)- SIRSI	SIRSI_110	20:50 (03.11.2021)	14:29 (04.11.2021)	17:39 hrs	LINE CHARGED
353	4-Nov-21	BAGALKOT	110	MK HUBLI-HIREBAGEWADI	MK HUBLI_220	20:02 (04.11.2021)			LINE OPEN: LINE CLEAR AVAILED
354	4-Nov-21	BAGALKOT	110	MUGALKHOD-ITNAL1	MUGALKHOD_220	15:26	23:20	7:54	LINE FAULT
355	4-Nov-21	BAGALKOT	110	MUGALKHOD-ITNAL1	MUGALKHOD_220	15:26	23:20	7:54	LINE FAULT
356	4-Nov-21	BAGALKOT	110	MUNDAGOD- HUBLI(RAMANKOPPA)	MUNDAGOD_110	6:06	9:12	3:06	HAND TRIPPED
357	4-Nov-21	BAGALKOT	110	SHIRAGUPPI-BILAGI	SHIRAGUPPI_110	22:05	22:10	0:05	LINE FAULT
358	4-Nov-21	BAGALKOT	110	SHIRAGUPPI-TOLAMATTI	TOLAMATTI_110	22:05	22:10	0:05	MAIN SUPPLY FAILURE
359	4-Nov-21	BAGALKOT	110	SIRSI- JOG1(SIDDAPUR)	SIRSI_110	12:43	14:24	1:41	LINE CLEAR AVAILED
360	4-Nov-21	BAGALKOT	110	SIRSI- JOG2(JOG)	SIRSI_110	17:39	18:36	0:57	LINE FAULT
361	4-Nov-21	BAGALKOT	110	VAJRAMATTI-SHIRAGUPPI	SHIRAGUPPI_110	22:05	22:10	0:05	LINE FAULT
362	4-Nov-21	BAGALKOT	220	BAGALKOT- ALAMATTI1	BAGALKOT_220	11:21	11:40	0:19	LINE FAULT
363	4-Nov-21	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	7:01 (02.11.2021)	1:06 (04.11.2021)	18:05 hrs	LINE CHARGED
364	4-Nov-21	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	6:54	15:33	8:39	HAND TRIPPED
365	4-Nov-21	BAGALKOT	220	BELGAUM- CHIKKODI2	BELGAUM_220	19:11	22:29	3:18	HAND TRIPPED
366	4-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN:LINE FAULT
367	4-Nov-21	BAGALKOT	220	BELGAUM-KANABARGI1(NARENDRA1)	BELGAUM_220	15:18 (02.11.2021)			LINE OPEN: LINE CLEAR AVAILED
368	4-Nov-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
369	4-Nov-21	BAGALKOT	220	NAGJHARI3- HUBLI	HUBLI_220	12:35	14:21	1:46	LINE CLEAR AVAILED
370	4-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
371	4-Nov-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN: LINE CLEAR AVAILED
372	4-Nov-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN: LINE CLEAR AVAILED
373	4-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
374	4-Nov-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
375	4-Nov-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	9:15	9:52	0:37	LINE FAULT
376	4-Nov-21	BENGALURU	66	HEBBAL 220 - BANASWADI	BANASWADI	20:44	21:53	1:09	LINE FAULT
377	4-Nov-21	BENGALURU	66	HV1	DABUSPET 220	9:15	9:32	0:17	MAIN SUPPLY FAILURE
378	4-Nov-21	BENGALURU	66	HV1	BIJJAHALLI	11:40	12:52	1:11	LINE CLEAR AVAILED
379	4-Nov-21	BENGALURU	66	HV2	KUNDANA	13:04	13:10	0:05	LINE CLEAR AVAILED
380	4-Nov-21	BENGALURU	66	HV2	ANEKAL	11:31	13:25	1:53	LINE CLEAR AVAILED
381	4-Nov-21	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	13:31	13:32	0:01	LOAD CHANGE OVER
382	4-Nov-21	BENGALURU	66	JIGANI LINK ROAD - JIGANI 66	JIGANI LINK ROAD	13:26	13:33	0:07	LOAD CHANGE OVER
383	4-Nov-21	BENGALURU	66	REMCO - VIJAYNAGAR	VIJAYNAGAR	9:20	9:30	0:10	LINE FAULT
384	4-Nov-21	BENGALURU	220	HV1	DABUSPET 220	9:15	9:30	0:15	TRANSFORMER FAULT
385	4-Nov-21	BENGALURU	220	ITI 220 - MANYATHA TECH PARK 220	NO STATION AFFECTED	13:42	15:54	2:11	LINE FAULT
386	4-Nov-21	BENGALURU	220	LV1	MITTEMARI 220	10:44(2-11-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
387	4-Nov-21	BENGALURU	220	LV1	MITTEMARI 220	10:44(2-11-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
388	4-Nov-21	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,RSSTEELS_66,UPHALLI_66,H BHALLI_66	1:38	2:14	0:36	LINE FAULT
389	4-Nov-21	GULBARGA	66	MUNIRABAD-MHDLINE	VENKATAPUR_66,RSSTEELS_66,UPHALLI_66,H BHALLI_66	2:18	2:21	0:03	LINE CLEAR AVAILED
390	4-Nov-21	GULBARGA	66	NEELGUNDA-PUNABGHATTA	PUNABGHATA_66	0:12	0:21	0:09	MAIN SUPPLY FAILURE
391	4-Nov-21	GULBARGA	66	PUNABGHATA-NEELAGUNDA	PUNABGHATA_66	0:05	0:15	0:10	MAIN SUPPLY FAILURE
392	4-Nov-21	GULBARGA	66	UCCHANGIDURGA-NEELAGUNDA	UCCHANGIDURGA_66	0:10	0:20	0:10	MAIN SUPPLY FAILURE
393	4-Nov-21	GULBARGA	110	ADAVI AMARESHWAR-MALLAT	ADAVI AMARESHWAR_110	0:04	0:49	0:45	MAIN SUPPLY FAILURE
394	4-Nov-21	GULBARGA	110	GOOGLE-RAICHUR	GOOGLE_110	1:15	1:25	0:10	MAIN SUPPLY FAILURE
395	4-Nov-21	GULBARGA	110	HUMNABAD-DUBALAGUNDI	DUBALAGUNDI_110	17:56	18:55	0:59	MAIN SUPPLY FAILURE
396	4-Nov-21	GULBARGA	110	HV1	KURKUNTA_110	14:10	15:40	1:30	TRANSFORMER FAULT
397	4-Nov-21	GULBARGA	110	HV3	VALKAMDINNI_110	14:51	14:56	0:05	TRANSFORMER FAULT
398	4-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	3:35	3:40	0:05	LINE FAULT
399	4-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR	ADVIAMRESHWAR_110	5:20	5:25	0:05	LINE FAULT
400	4-Nov-21	GULBARGA	110	JAWALGERA-SINDHANOOR	JAWALGERA_110	4:50	5:00	0:10	MAIN SUPPLY FAILURE
401	4-Nov-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GANDHINAGAR_110	1:25	1:35	0:10	MAIN SUPPLY FAILURE
402	4-Nov-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GANDHINAGAR_110	3:48	3:58	0:10	MAIN SUPPLY FAILURE
403	4-Nov-21	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	0:39	0:49	0:10	MAIN SUPPLY FAILURE
404	4-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110,GABBUR_110	1:16	1:25	0:09	MAIN SUPPLY FAILURE
405	4-Nov-21	GULBARGA	110	RAICHUR-SINDHANOOR2	SINDHANOOR_110	2:15	2:23	0:08	MAIN SUPPLY FAILURE
406	4-Nov-21	GULBARGA	110	RAICHUR-SINDHANOOR2	SINDHANOOR_110	19:27	19:30	0:03	MAIN SUPPLY FAILURE
407	4-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
408	4-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN:LINE FAULT
409	4-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
410	4-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR1	DEODURGA_110	19:27	19:36	0:09	MAIN SUPPLY FAILURE
411	4-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR2	DEODURGA_110	19:27	19:36	0:09	MAIN SUPPLY FAILURE
412	4-Nov-21	GULBARGA	110	SINDHANOOR-ADVIAMARESHWARA	ADVIAMARESHWARA_110	4:43	4:58	13:40	LINE FAULT
413	4-Nov-21	GULBARGA	110	STARMETALLICS_IPP-SINDHANOOR	SINDHANOOR_220	1:30	1:50	0:20	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
414	4-Nov-21	GULBARGA	110	YERAGERA-MALIYABAD	MALIYABAD_110	6:10	6:15	0:05	MAIN SUPPLY FAILURE
415	4-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
416	4-Nov-21	GULBARGA	220	LINGAPUR-BPTS	LINGAPUR_220	11:41	14:32	2:51	MAIN SUPPLY FAILURE
417	4-Nov-21	GULBARGA	220	SINDHANOOR-LINGASUGUR	LINGASUGUR_220	15:48	17:28	1:40	MAIN SUPPLY FAILURE
418	4-Nov-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:15(04.11.2021)			LINE OPEN: LINE CLEAR AVAILED
419	4-Nov-21	HASSAN	66	HV1	ARKD_66	15:26	15:30	0:04	HAND TRIPPED
420	4-Nov-21	HASSAN	66	HV1	SALAGAME_66	7:55	9:32	1:37	LINE CLEAR AVAILED
421	4-Nov-21	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLI_66	4:49	5:00	0:11	LINE FAULT
422	4-Nov-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:49(04.10.2021)	7:21(05.11.2021)	15:32 hrs	LINE CHARGED
423	4-Nov-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	14:36	18:01	3:25	LINE FAULT
424	4-Nov-21	HASSAN	110	HALADY1-HIRIYADKA	HALADY_110	15:45	16:34	0:49	LINE FAULT
425	4-Nov-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
426	4-Nov-21	HASSAN	110	JOG110-AMBTR1	JOG_110	7:30	13:30	6:00	HAND TRIPPED
427	4-Nov-21	HASSAN	110	JOG110-AMBTR2	JOG_110	7:30	7:41	0:11	HAND TRIPPED
428	4-Nov-21	HASSAN	110	JOG-NK2	mghejog_gen	21:11 (3.11.2021)	14:30 (4.11.2021)	17:19 hrs	LINE CHARGED
429	4-Nov-21	HASSAN	110	JOG-NK2	mghejog_gen	17:40	18:27	0:47	LINE FAULT
430	4-Nov-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:49 (4.11.2021)	7:21(05.11.2021)	15:32 hrs	LINE CHARGED
431	4-Nov-21	HASSAN	110	KEMAR-Guruvykere2	KEMAR_220	14:36	18:01	3:25	LINE FAULT
432	4-Nov-21	HASSAN	110	KEMAR-KAVOOR3	KEMAR_220	17:23	18:04	0:41	LINE FAULT
433	4-Nov-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	19:56 (3.11.2021)			LINE OPEN: LINE CLEAR AVAILED
434	4-Nov-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	15:41	18:20	2:39	LINE FAULT
435	4-Nov-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	16:44	17:40	0:56	LINE FAULT
436	4-Nov-21	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	18:58 (3.11.2021)			LINE OPEN:LINE FAULT
437	4-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	20:15(3.11.2021)	2:52(4.10.2021)	6:37 hrs	LINE CHARGED
438	4-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	15:41	18:20	2:39	LINE FAULT
439	4-Nov-21	HASSAN	110	MSEZ-GSS31	MSEZ_220	10:45	14:37	3:52	LINE CLEAR AVAILED
440	4-Nov-21	HASSAN	110	MSEZ-GSS31	MSEZ_220	22:19	23:43	1:24	HAND TRIPPED
441	4-Nov-21	HASSAN	110	MSEZ-GSS32	MSEZ_220	22:19	23:33	1:14	HAND TRIPPED
442	4-Nov-21	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	11:43	17:29	5:46	HAND TRIPPED
443	4-Nov-21	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	13:44 (3.11.2021)	16:17(4.11.2021)	26:33 hrs	LINE CHARGED
444	4-Nov-21	HASSAN	220	KAVOOR-KEMAR3	KAVOOR_220	17:23	18:05	0:42	LINE FAULT
445	4-Nov-21	HASSAN	220	KEMAR-Varahi1	KEMAR_220	14:53	18:07	3:14	LINE FAULT
446	4-Nov-21	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	11:41	17:29	5:48	LINE CLEAR AVAILED
447	4-Nov-21	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	13:44(3.11.2021)	16:17(4.11.2021)	26:33 hrs	LINE CHARGED
448	4-Nov-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	14:52	18:07	3:15	LINE FAULT
449	4-Nov-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	14:52	15:17	0:25	LINE FAULT
450	4-Nov-21	HASSAN	400	UPCL-HASSAN2	upcl_gen	2:09	7:23	5:14	HAND TRIPPED
451	4-Nov-21	MYSURU	66	BEGUR-B MATAKERE	B MATKERE_66	16:43	16:55	0:11	LINE FAULT
452	4-Nov-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
453	4-Nov-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
454	4-Nov-21	MYSURU	66	KR PETE 220-BOOKANAKERE	CHINAKURALI_66 BANANGADI_66 GANJIGERE_66 SHEELUNERE_66 BOOKANAKERE_66	22:17	22:24	0:06	LINE FAULT
455	4-Nov-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
456	4-Nov-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN: LINE CLEAR AVAILED
457	4-Nov-21	MYSURU	66	KUNTHUR-MADHUVANAHALLI	NO STATIONS EFFECTED	18:09	18:20	0:11	LINE FAULT
458	4-Nov-21	MYSURU	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	16:30	16:35	0:04	LINE FAULT
459	4-Nov-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:09:04 (4.11.2021)			LINE OPEN:LINE FAULT
460	4-Nov-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN: LINE CLEAR AVAILED
461	4-Nov-21	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
462	4-Nov-21	TUMKUR	66	BILCHODU66-PALLAGATTE66	PALLAGATTE_66,SOKKE_66,JAGALUR_66	15:10	15:20	0:10	LINE FAULT
463	4-Nov-21	TUMKUR	66	CHAWDANKUPPE- ESENGY_IPP_SOLAR_66	ESENGY_IPP_SOLAR_66	14:33	14:36	0:03	LINE CLEAR AVAILED
464	4-Nov-21	TUMKUR	66	CHAWDANKUPPE- ESENGY_IPP_SOLAR_66	ESENGY_IPP_SOLAR_66	14:53	15:04	0:11	LINE CLEAR AVAILED
465	4-Nov-21	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	1:33	1:48	0:15	LINE FAULT
466	4-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	10:32	10:41	0:08	LINE FAULT
467	4-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	18:49	18:50	0:01	LINE FAULT
468	4-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	22:29	22:37	0:07	LINE FAULT
469	4-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	21:22	21:23	0:01	LINE FAULT
470	4-Nov-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	23:37	23:42	0:04	LINE FAULT
471	4-Nov-21	TUMKUR	66	TR-1	CHAWDANKUPPE_66	14:10	14:40	0:30	LINE CLEAR AVAILED
472	4-Nov-21	TUMKUR	66	TR-1	CHITRAHALLI_66	10:49	10:51	0:02	TRANSFORMER FAULT
473	4-Nov-21	TUMKUR	66	TR-1	MADADAKERE_66	12:45	12:50	0:04	TRANSFORMER FAULT
474	4-Nov-21	TUMKUR	66	TR-1(LV SIDE)	PAVAGADA_220	11:06	11:49	0:43	LINE CLEAR AVAILED
475	4-Nov-21	TUMKUR	66	TR-2	BEVINAHALLI_66	15:13	17:35	2:21	LINE CLEAR AVAILED
476	4-Nov-21	TUMKUR	66	TR-2	CHAWDANKUPPE_66	13:20	14:40	1:20	LINE CLEAR AVAILED
477	4-Nov-21	TUMKUR	220	TR-1(HV SIDE)	PAVAGADA_220	11:06	11:49	0:43	LINE CLEAR AVAILED
478	5-Nov-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
479	5-Nov-21	BAGALKOT	110	110/11KV, HV2	SINDAGI_110	21:10 (04.11.2021)	12:00 (05.11.2021)	14:50 hrs	TRANSFORMER CHARGED
480	5-Nov-21	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	18:53	19:10	0:17	TRANSFORMER FAULT
481	5-Nov-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	9:13	9:22	0:09	LINE CLEAR AVAILED
482	5-Nov-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	13:09	13:38	0:29	LINE CLEAR AVAILED
483	5-Nov-21	BAGALKOT	110	110/11KV,HV2	KIADBBIJAPUR_110	3:19	4:14	0:55	TRANSFORMER FAULT
484	5-Nov-21	BAGALKOT	110	110/11KV,HV2	SHIROL_110	11:50	12:00	0:10	TRANSFORMER FAULT
485	5-Nov-21	BAGALKOT	110	110/11KV,HV2	MANTUR_110	4:15	4:20	0:05	TRANSFORMER FAULT
486	5-Nov-21	BAGALKOT	110	110/33KV, HV4	HIDIKAL_110, KOLIGUDDA_33,MYTRA SOLAR_33	14:45	14:53	0:08	TRANSFORMER FAULT
487	5-Nov-21	BAGALKOT	110	220/110KV, LV3	HUBLI_220	13:19 (03.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
488	5-Nov-21	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	17:35 (04.11.2021)	7:05 (05.11.2021)	13:30 hrs	TRANSFORMER CHARGED
489	5-Nov-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
490	5-Nov-21	BAGALKOT	110	BIJAPUR220- KIADB BIJAPUR1	KIADB BIJAPUR_110	11:03	12:02	0:59	LINE FAULT
491	5-Nov-21	BAGALKOT	110	BIJAPUR220- KIADB BIJAPUR2	KIADB BIJAPUR_110	11:22	12:06	0:44	HAND TRIPPED
492	5-Nov-21	BAGALKOT	110	BIJKDB-B BAGEWADI 2(RAMBAPUR 1)	KIADBBIJAPUR_110	11:03	12:12	1:09	LINE FAULT
493	5-Nov-21	BAGALKOT	110	BIJKDB-BIJAPUR CITY (RAMBAPUR 2)	KIADBBIJAPUR_110	11:03	12:12	1:09	LINE FAULT
494	5-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVOIDED
495	5-Nov-21	BAGALKOT	110	HAVERI(SAVANUR)-RAMANKOPPA	RAMANKOPPA_110	5:34	8:19	2:45	LINE FAULT
496	5-Nov-21	BAGALKOT	110	MAHALINGAPUR220- HIDIKAL	HIDIKAL_110	11:03 (05.11.2021)			LINE OPEN: LINE CLEAR AVOIDED
497	5-Nov-21	BAGALKOT	110	MK HUBLI-HIREBAGEWADI	MK HUBLI_220	20:02 (04.11.2021)	7:53 (05.11.2021)	11:45 hrs	LINE CHARGED
498	5-Nov-21	BAGALKOT	110	RAIBAG 2(KABBUR)-ITANAL	ITANAL_110	15:27	23:18	7:51	LINE FAULT
499	5-Nov-21	BAGALKOT	110	TAKKALAKI -KN SOLAR	TAKKALAKI_110	11:04	12:30	1:26	HAND TRIPPED
500	5-Nov-21	BAGALKOT	110	TAKKALAKI -WARADA SOLAR	TAKKALAKI_110	11:04	12:30	1:26	HAND TRIPPED
501	5-Nov-21	BAGALKOT	110	TORVI- BHUTNAL	TORVI_110	11:03	12:28	1:25	HAND TRIPPED
502	5-Nov-21	BAGALKOT	220	220/110KV, HV2&LV2	BIJAPUR_220, KIADB BIJAPUR_110, TORVI_110, TAKKALAKI_110, TIKOTA_110, BHUTNAL_110	11:03	12:23	1:20	TRANSFORMER FAULT
503	5-Nov-21	BAGALKOT	220	ADPH2-BAGEWADI 220	BAGEWADI_220	11:22	11:51	0:29	LINE FAULT
504	5-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN:LINE FAULT
505	5-Nov-21	BAGALKOT	220	BELGAUM-KANABARGI1(NARENDRA1)	BELGAUM_220	15:18 (02.11.2021)			LINE OPEN: LINE CLEAR AVOIDED
506	5-Nov-21	BAGALKOT	220	BIJAPUR- BAGEWADI2(GMR2)	BIJAPUR_220	11:03	12:22	1:19	LINE FAULT
507	5-Nov-21	BAGALKOT	220	BIJAPUR- VAISHALI2	BIJAPUR_220	11:03	12:29	1:26	LINE FAULT
508	5-Nov-21	BAGALKOT	220	HUBLI- NAGIHARI1	HUBLI_220	15:02	16:39	1:37	LINE FAULT
509	5-Nov-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
510	5-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
511	5-Nov-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN: LINE CLEAR AVOIDED
512	5-Nov-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN: LINE CLEAR AVOIDED
513	5-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
514	5-Nov-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVOIDED
515	5-Nov-21	BENGALURU	66	APPAREL PARK - DB PURA 220	APPAREL PARK	23:30	23:55	0:25	LOAD CHANGE OVER
516	5-Nov-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	6:17	6:51	0:33	LINE FAULT
517	5-Nov-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	6:51	7:00	0:08	LINE FAULT
518	5-Nov-21	BENGALURU	66	DABUSPET 220 - HIREHALLI	HIREHALLI, HONNUDIKE	14:21	14:26	0:04	LOAD CHANGE OVER
519	5-Nov-21	BENGALURU	66	DB PURA 220 - DEVANAHALLI 2	NO STATION AFFECTED	8:01	8:05	0:03	LINE FAULT
520	5-Nov-21	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	13:36	13:42	0:06	LINE FAULT
521	5-Nov-21	BENGALURU	66	DEVANAHALLI - DB PURA 2	DEVANAHALLI	8:01	8:06	0:04	LINE FAULT
522	5-Nov-21	BENGALURU	66	DODDALAHALLI - SOLAR (IPP)	NO STATION AFFECTED	16:01	16:33	0:31	LINE FAULT
523	5-Nov-21	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	8:14	8:32	0:17	MAIN SUPPLY FAILURE
524	5-Nov-21	BENGALURU	66	GOKULA - MATHIKERE	MATHIKERE	8:15	8:30	0:14	MAIN SUPPLY FAILURE
525	5-Nov-21	BENGALURU	66	GOKULA - RMV	RMV, TATA INSTITUTE (EHT)	8:15	8:29	0:13	MAIN SUPPLY FAILURE
526	5-Nov-21	BENGALURU	66	HV1	BIDADI 220	1:08	2:15	1:06	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
527	5-Nov-21	BENGALURU	66	HV1	GOKULA	8:15	9:42	0:14	MAIN SUPPLY FAILURE
528	5-Nov-21	BENGALURU	66	HV1	PATH PALYA	17:23	17:32	0:09	TRANSFORMER FAULT
529	5-Nov-21	BENGALURU	66	HV1	KGF	14:45	15:10	0:24	TRANSFORMER FAULT
530	5-Nov-21	BENGALURU	66	HV2	SOUTH CITY	0:13	0:17	0:03	TRANSFORMER FAULT
531	5-Nov-21	BENGALURU	66	HV2	SOUTH CITY	9:38	11:48	2:10	TRANSFORMER FAULT
532	5-Nov-21	BENGALURU	66	HV2	GOKULA	8:15	9:42	0:14	MAIN SUPPLY FAILURE
533	5-Nov-21	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU, GODURU	16:00	16:18	0:18	LINE FAULT
534	5-Nov-21	BENGALURU	66	KIADB DB PURA 220 - APPEATEL PARK	APPEATEL PARK	13:36	14:35	0:58	LINE FAULT
535	5-Nov-21	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	10:15	10:19	0:04	LOAD CHANGEOVER
536	5-Nov-21	BENGALURU	66	RMV -HEBBAL 220	RMV	10:10	10:13	0:03	LOAD CHANGEOVER
537	5-Nov-21	BENGALURU	66	SHAMRAJ TECH PARK - KACHMARANAHALLI	KACHMARANAHALLI	12:15	12:50	0:35	LINE FAULT
538	5-Nov-21	BENGALURU	66	SK STEEL (EHT) - KOLALA	KOLALA	6:14	7:57	1:43	LINE FAULT
539	5-Nov-21	BENGALURU	66	SRS PEENYA 220 - DG2	ALUR, BIEC, NELAMANGALA 66	14:30	15:00	0:30	LINE FAULT
540	5-Nov-21	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, BEL (EHT), HMT (EHT)	8:14	9:28	1:14	LINE FAULT
541	5-Nov-21	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, BEL (EHT), HMT (EHT)	8:14	9:29	1:14	LINE FAULT
542	5-Nov-21	BENGALURU	66	T GOLLAHALLI 220 - THAYALUR	THAYALUR, M N HALLI, N G JULKUR	16:34	17:00	0:26	LINE FAULT
543	5-Nov-21	BENGALURU	220	HOODY 400 - HSR LAYOUT 220	NO STATION AFFECTED	13:17	16:32	3:14	LINE FAULT
544	5-Nov-21	GULBARGA	66	KOTTUR-SUZLON_IPP	KOTTUR_66	15:45	15:55	0:10	LINE FAULT
545	5-Nov-21	GULBARGA	66	MUNIRABAD-VYSANKERE1	DONIMALAI_66,NMDC_FACTORY	16:30	16:37	0:07	LINE FAULT
546	5-Nov-21	GULBARGA	110	HV2	KANAKAGIRI_110	16:15	16:30	0:15	TRANSFORMER FAULT
547	5-Nov-21	GULBARGA	110	HV3	VALKAMDINNI_110	17:46	17:49	0:03	TRANSFORMER FAULT
548	5-Nov-21	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	4:46	5:01	0:15	MAIN SUPPLY FAILURE
549	5-Nov-21	GULBARGA	110	RAICHUR-MALIYABAD	MALIYABAD_110,YERAGERA_110,VADAVATI_110,YAPALADINNI_110	6:11	6:15	0:04	MAIN SUPPLY FAILURE
550	5-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVOIDED
551	5-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN:LINE FAULT
552	5-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVOIDED
553	5-Nov-21	GULBARGA	110	STARMETALLICS_IPP-MUNIRABAD	STAR METALLIC_IPP	16:29	16:35	0:06	LINE FAULT
554	5-Nov-21	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	6:10	6:15	0:05	MAIN SUPPLY FAILURE
555	5-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
556	5-Nov-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	22:15(04.11.2021)	08:31(5.11.2021)	10:16 hrs	LINE CHARGED
557	5-Nov-21	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	15:29	15:36	0:07	LINE FAULT
558	5-Nov-21	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	21:59(5.11.2021)			LINE OPEN:LINE FAULT
559	5-Nov-21	HASSAN	66	CHIKKAK-HASN	CHIKKAKONDAGOLA_66	21:59(5.11.2021)			LINE OPEN: LINE CLEAR AVOIDED
560	5-Nov-21	HASSAN	66	HV2	TAVARECHATNAHALLI_66	7:44	8:00	0:16	TRANSFORMER FAULT
561	5-Nov-21	HASSAN	66	LV2	CHANNARAYAPATNA_66	11:38	12:27	0:49	TRANSFORMER FAULT
562	5-Nov-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	15:49(04.10.2021)	7:21(05.11.2021)	15:32 hrs	LINE CHARGED
563	5-Nov-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
564	5-Nov-21	HASSAN	110	HV2	HOSANGADI_110	19:10	20:42	1:32	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
565	5-Nov-21	HASSAN	110	JOG110-MGHE	JOG_110	10:30(5.11.2021)			LINE OPEN: LINE CLEAR AVAILED
566	5-Nov-21	HASSAN	110	JOG-JLT3	mghejog_gen	10:30(5.11.2021)			LINE OPEN: LINE CLEAR AVAILED
567	5-Nov-21	HASSAN	110	KEMAR-Guruvykere1	KEMAR_220	15:49 (4.11.2021)	7:21(05.11.2021)	15:32 hrs	LINE CHARGED
568	5-Nov-21	HASSAN	110	KEMAR-Manipal1	KEMAR_220	19:56 (3.11.2021)			LINE OPEN: LINE CLEAR AVAILED
569	5-Nov-21	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	0:55	0:57	0:02	HAND TRIPPED
570	5-Nov-21	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	18:58 (3.11.2021)			LINE OPEN:LINE FAULT
571	5-Nov-21	HASSAN	220	HV2	CHANNARAYAPATNA_66	11:38	12:27	0:49	TRANSFORMER FAULT
572	5-Nov-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:40	16:00	0:20	LINE FAULT
573	5-Nov-21	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:40	16:01	0:21	LINE FAULT
574	5-Nov-21	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:16	7:17	7:01	HAND TRIPPED
575	5-Nov-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
576	5-Nov-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
577	5-Nov-21	MYSURU	66	HOOTAGALLI-HAMPAPURA(KAGGERE)	HAMPAPURA(KAGGERE)_66	18:05	18:16	0:11	LINE FAULT
578	5-Nov-21	MYSURU	66	HV1	MADDUR_66	9:57	10:30	0:33	LINE CLEAR AVAILED
579	5-Nov-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31(30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
580	5-Nov-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30(24.10.2021)			LINE OPEN: LINE CLEAR AVAILED
581	5-Nov-21	MYSURU	66	MADHUVANAHALLI-HANNUR1	NO STATIONS EFFECTED	4:59	5:05	0:06	LINE FAULT
582	5-Nov-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	18:09:04 (4.11.2021)	8:49:00 (5.11.2021)	14:39 hrs	LINE CHARGED
583	5-Nov-21	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	NO STATIONS EFFECTED	14:57	15:02	0:05	LINE FAULT
584	5-Nov-21	MYSURU	66	MEGALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	23:17	23:37	0:19	LINE FAULT
585	5-Nov-21	MYSURU	66	MUGUR-CLEAN SOLAR	NO STATIONS EFFECTED	4:56	5:01	0:04	LINE FAULT
586	5-Nov-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50(5.10.2021)			LINE OPEN: LINE CLEAR AVAILED
587	5-Nov-21	MYSURU	220	HV2	TUBINKERE_220	15:10:00(25.10.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
588	5-Nov-21	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	11:14	11:33	0:19	LINE FAULT
589	5-Nov-21	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	1:11	1:23	0:11	LINE FAULT
590	5-Nov-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA 1	CHITRADURGA_220	1:11	1:35	0:24	LINE FAULT
591	5-Nov-21	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	1:11	1:33	0:21	LINE FAULT
592	5-Nov-21	TUMKUR	66	CHITRADURGA 66kV- CHITRADURGA 2	CHITRADURGA_66	1:12	1:40	0:28	LINE FAULT
593	5-Nov-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1_IPP_66	MEGMICON 1_IPP_66	1:12	6:25	5:13	LINE FAULT
594	5-Nov-21	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2_IPP_66	MEGMICON 2_IPP_66	1:20	1:52	0:32	LINE FAULT
595	5-Nov-21	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:55	13:05	0:10	LINE FAULT
596	5-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:00	5:01	0:01	LINE FAULT
597	5-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:05	5:24	0:19	LINE FAULT



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
598	5-Nov-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	2:30	2:34	0:04	LINE FAULT
599	5-Nov-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	5:16	5:22	0:05	LINE FAULT
600	5-Nov-21	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	6:15	6:25	0:09	LINE FAULT
601	5-Nov-21	TUMKUR	66	TR-1	MADADAKERE_66	12:54	12:57	0:02	TRANSFORMER FAULT
602	5-Nov-21	TUMKUR	66	TR-2	BEVINAHALLI_66	13:55	14:40	0:45	LINE CLEAR AVAIED
603	5-Nov-21	TUMKUR	66	TR-2	BEVINAHALLI_66	16:15	17:25	1:10	LINE CLEAR AVAIED
604	6-Nov-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAIED
605	6-Nov-21	BAGALKOT	110	110/11KV, HV1	PHCOMPOUND_110	2:44	11:32	8:48	TRANSFORMER FAULT
606	6-Nov-21	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	7:26	7:42	0:16	TRANSFORMER FAULT
607	6-Nov-21	BAGALKOT	110	110/11KV, HV1	NANADI_110	15:17	16:05	0:48	LINE CLEAR AVAIED
608	6-Nov-21	BAGALKOT	110	110/11KV, HV1	KANABARGI LAYOUT_110	11:40	12:47	1:07	LINE CLEAR AVAIED
609	6-Nov-21	BAGALKOT	110	110/11KV, HV1	KADANKOPPA_110	18:42	18:45	0:03	HAND TRIPPED
610	6-Nov-21	BAGALKOT	110	110/11KV, HV1	HLIYAL_110	5:35	5:55	0:20	TRANSFORMER FAULT
611	6-Nov-21	BAGALKOT	110	110/11KV, HV1	BELAUR_110	11:26	15:17	3:51	LINE CLEAR AVAIED
612	6-Nov-21	BAGALKOT	110	110/11KV,HV1	THORVI_110	16:08	17:12	1:04	HAND TRIPPED
613	6-Nov-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	11:46	12:23	0:37	LINE CLEAR AVAIED
614	6-Nov-21	BAGALKOT	110	110/11KV,HV2	ALMEL_110	12:50	13:16	0:26	LINE CLEAR AVAIED
615	6-Nov-21	BAGALKOT	110	110/33KV, HV3	HIDIKAL DAM_110, RUSTUMPUR_33	10:33	10:49	0:16	LINE CLEAR AVAIED
616	6-Nov-21	BAGALKOT	110	110/33KV, HV3	HIDIKAL_110, KOLIGUDDA_33, ALAGWADI_33	13:01	13:28	0:27	LINE CLEAR AVAIED
617	6-Nov-21	BAGALKOT	110	110/33KV, HV3	SINDAGI_110	14:50	14:55	0:05	TRANSFORMER FAULT
618	6-Nov-21	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	8:55 (06.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
619	6-Nov-21	BAGALKOT	110	220/110KV, LV3	HUBLI_220	13:19 (03.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
620	6-Nov-21	BAGALKOT	110	AIGALI-SAVALAGI (YELLAMANAWADI )	AIGALI_110	12:05 (27.10.2021)	12:39 (06.11.2021)	216:34 hrs	LINE CHARGED
621	6-Nov-21	BAGALKOT	110	AMBEWADI- NK1 (HALIYAL)	HALIYAL_110	5:33	13:19	7:46	LINE FAULT
622	6-Nov-21	BAGALKOT	110	AMBEWADI- NK1 (HALIYAL)	HALIYAL_110	13:22	14:04	0:42	LINE FAULT
623	6-Nov-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.2021)			LINE OPEN: LINE CLEAR AVAIED
624	6-Nov-21	BAGALKOT	110	ATHANI 220-HALIYAL	HALIYAL_110	23:11	23:33	0:22	LINE FAULT
625	6-Nov-21	BAGALKOT	110	BGWDI-F8-MAMDAPURI ( LINE 2)	MAMDAPUR_110	22:56	23:17	0:21	LINE FAULT
626	6-Nov-21	BAGALKOT	110	BIJAPUR- KIADB BIJAPUR	KIADB BIJAPUR_110	11:15	12:27	1:12	LINE CLEAR AVAIED
627	6-Nov-21	BAGALKOT	110	BIJKDB-BIJAPUR CITY	KIADB BIJAPUR_110	10:48	12:29	1:41	LINE CLEAR AVAIED
628	6-Nov-21	BAGALKOT	110	GHATAPRABHA220- GOKAK	GOKAK_110	4:13	4:27	0:14	LINE FAULT
629	6-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAIED
630	6-Nov-21	BAGALKOT	110	HUBLI- KADANKOPPA	KADANKOPPA_110	18:39	18:42	0:03	HAND TRIPPED
631	6-Nov-21	BAGALKOT	110	KADANKOPPA- KAVALWADA	KADANKOPPA_110	18:03	22:32	4:29	HAND TRIPPED
632	6-Nov-21	BAGALKOT	110	MAHALINGAPUR220- HIDIKAL	HIDIKAL_110	11:03 (05.11.2021)	13:22 (06.11.2021)	26:19 hrs	LINE CHARGED
633	6-Nov-21	BAGALKOT	220	AMBEWADI- NAGJHARIZ	AMBEWADI_220	14:07	14:22	0:15	LINE FAULT
634	6-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN:LINE FAULT
635	6-Nov-21	BAGALKOT	220	BELGAUM-KANABARGI1(NARENDRA1)	BELGAUM_220	15:18 (02.11.2021)			LINE OPEN: LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
636	6-Nov-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
637	6-Nov-21	BAGALKOT	220	NAGJHARI2-BIDNAL	BIDNAL_220	11:55	12:33	0:38	LINE FAULT
638	6-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
639	6-Nov-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN: LINE CLEAR AVAILED
640	6-Nov-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN: LINE CLEAR AVAILED
641	6-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
642	6-Nov-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
643	6-Nov-21	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	16:40	16:55	0:15	LOAD CHANGEOVER
644	6-Nov-21	BENGALURU	66	AUSTIN TOWN - EDC 220	AUSTIN TOWN	9:50	9:54	0:03	LOAD CHANGEOVER
645	6-Nov-21	BENGALURU	66	AUSTIN TOWN - KORMANGALA 220	AUSTIN TOWN	17:08	17:13	0:05	LOAD CHANGEOVER
646	6-Nov-21	BENGALURU	66	HV1	BG ROAD	10:02	17:19	7:17	LINE CLEAR AVAILED
647	6-Nov-21	BENGALURU	66	HV1	IISC	10:48	10:50	0:01	LINE CLEAR AVAILED
648	6-Nov-21	BENGALURU	66	HV1	DEVANAHALLI	8:54	9:04	0:10	TRANSFORMER FAULT
649	6-Nov-21	BENGALURU	66	HV1	ATTIBELE	16:11	16:16	0:04	LOAD CHANGEOVER
650	6-Nov-21	BENGALURU	66	HV2	BG ROAD	10:02	12:34	2:32	LINE CLEAR AVAILED
651	6-Nov-21	BENGALURU	66	HV2	C STATION	10:05	17:36	7:31	LINE CLEAR AVAILED
652	6-Nov-21	BENGALURU	66	HV2	C STATION	10:05	17:45	7:40	LINE CLEAR AVAILED
653	6-Nov-21	BENGALURU	66	HV2	IISC	13:18	13:25	0:06	LINE CLEAR AVAILED
654	6-Nov-21	BENGALURU	66	HV2	KIADB DB PURA 220	11:43	11:52	0:09	LINE CLEAR AVAILED
655	6-Nov-21	BENGALURU	66	HV3	BANASWADI	12:04	12:10	0:05	LINE CLEAR AVAILED
656	6-Nov-21	BENGALURU	66	KADUGODI - EPIP 220	KADUGODI, ARMY WELFARE ORGANIZATION, KONDASPURA	11:17	11:59	0:42	LINE FAULT
657	6-Nov-21	BENGALURU	66	KGF - KAMASAMUDRA	KAMASAMUDRA	1:42	2:50	1:07	LINE FAULT
658	6-Nov-21	BENGALURU	66	NAGNATHPURA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT), JAKKASANDRA	10:08	16:04	5:55	LINE CLEAR AVAILED
659	6-Nov-21	BENGALURU	66	T GOLLAHALLI 220 - AVANI	AVANI, MULBAGAL	11:14	12:30	1:16	LINE CLEAR AVAILED
660	6-Nov-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:08	16:16	0:07	LINE FAULT
661	6-Nov-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	16:08	16:16	0:07	LINE FAULT
662	6-Nov-21	BENGALURU	66	WELCAST STEEL - DG 3	WELCAST STEEL	12:35	12:45	0:10	LOAD CHANGEOVER
663	6-Nov-21	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	22:10	22:16	0:06	LOAD CHANGEOVER
664	6-Nov-21	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	12:17	12:26	0:09	LINE FAULT
665	6-Nov-21	BENGALURU	220	LV1	MITTEMARI 220	10:44(2-11-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
666	6-Nov-21	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	13:35	13:45	0:10	MAIN SUPPLY FAILURE
667	6-Nov-21	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	14:15	14:30	0:15	MAIN SUPPLY FAILURE
668	6-Nov-21	GULBARGA	110	HV1	KADAGANCHI_110	6:43	7:35	0:52	TRANSFORMER FAULT
669	6-Nov-21	GULBARGA	110	HV1	MATAMARI_110	8:10	8:15	0:05	TRANSFORMER FAULT
670	6-Nov-21	GULBARGA	110	HV1	HUNSIGI_110	11:00	11:40	0:40	LINE CLEAR AVAILED
671	6-Nov-21	GULBARGA	110	HV3	VALKAMDINNI_110	13:33	14:19	0:46	TRANSFORMER FAULT
672	6-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR(IDLE LINE)	ADVIAMRESHWAR_110	3:45	3:50	0:05	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
673	6-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR(IDLE LINE)	ADVIAMRESHWAR_110	5:40	5:55	0:15	LINE FAULT
674	6-Nov-21	GULBARGA	110	KANAKAGIRI-KUSHTAGI	KANAKAGIRI_110	8:35	16:20	7:45	MAIN SUPPLY FAILURE
675	6-Nov-21	GULBARGA	110	KUSTAGI-KANAKGIRI	KANAKGIRI_110,GANADAL_110,NAVLI_110	9:02	16:12	7:10	LINE CLEAR AVAIED
676	6-Nov-21	GULBARGA	110	LADHA-RENEWSOLAR_IPP	LADHA_110	20:00	20:05	0:05	LINE FAULT
677	6-Nov-21	GULBARGA	110	LADHA-SANTHAPUR	SANTHAPUR_110	4:25	4:30	0:05	LINE FAULT
678	6-Nov-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GANDHINAGAR_110	4:29	4:39	0:10	MAIN SUPPLY FAILURE
679	6-Nov-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GANDHINAGAR_110	20:45	20:55	0:10	MAIN SUPPLY FAILURE
680	6-Nov-21	GULBARGA	110	MALLAT-BYAGAWAT	BYAGAWAT_110,VALKAMDINNI_110	18:12	18:23	0:11	MAIN SUPPLY FAILURE
681	6-Nov-21	GULBARGA	110	MANGALORE-BEVOOR	MANGALORE_110	11:00	11:10	0:10	MAIN SUPPLY FAILURE
682	6-Nov-21	GULBARGA	110	MUNIRABAD-SINDHANOOR1	VENKATAGIRI_110,GANGAVATHI_110,DR NAGAR_110,KARATAGI_110	12:51	12:58	0:07	MAIN SUPPLY FAILURE
683	6-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAIED
684	6-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN:LINE FAULT
685	6-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAIED
686	6-Nov-21	GULBARGA	110	SHAHAPUR-SHORAPUR	SHORAPUR_110	3:45	3:50	0:05	MAIN SUPPLY FAILURE
687	6-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
688	6-Nov-21	HASSAN	66	CHANNAR-MALLALI	CHANNARAYAPATNA_66	20:11	20:45	0:34	LINE CLEAR AVAIED
689	6-Nov-21	HASSAN	66	CHANNAR-UDAYAPURA	CHANNARAYAPATNA_66	20:09	20:45	0:36	LINE CLEAR AVAIED
690	6-Nov-21	HASSAN	66	CHIKKAK-DUDDA	CHIKKAKONDAGOLA_66	21:59(5.11.2021)	0:32 (6.11.2021)	2:33 hrs	LINE CHARGED
691	6-Nov-21	HASSAN	66	CHIKKAK-HASN	CHIKKAKONDAGOLA_66	21:59(5.11.2021)	0:32 (6.11.2021)	2:33 hrs	LINE CHARGED
692	6-Nov-21	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	12:46	13:02	0:16	HAND TRIPPED
693	6-Nov-21	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	11:11	11:30	0:19	HAND TRIPPED
694	6-Nov-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	11:57	12:05	0:08	LINE FAULT
695	6-Nov-21	HASSAN	66	HV1	MALALI_66	12:47	13:06	0:19	MAIN SUPPLY FAILURE
696	6-Nov-21	HASSAN	66	HV1	UDAYAPURA_66	20:02	20:48	0:46	HAND TRIPPED
697	6-Nov-21	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:24	13:03	1:39	LINE CLEAR AVAIED
698	6-Nov-21	HASSAN	66	TAVAREC-IDLE	RAMNATHPURA_66	11:36	11:49	0:13	LINE FAULT
699	6-Nov-21	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPPALU_66	12:10	12:35	0:25	HAND TRIPPED
700	6-Nov-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANKERE_110	15:57	17:03	1:06	LINE FAULT
701	6-Nov-21	HASSAN	110	GURUVA-KEMAR2	GURUVAYANKERE_110	15:57	17:01	1:04	LINE FAULT
702	6-Nov-21	HASSAN	110	JOG110MGHE	JOG_110	10:30(5.11.2021)	12:53(06.11.2021)	26:23 hrs	LINE CHARGED
703	6-Nov-21	HASSAN	110	JOG-JLT3	mghejog_gen	10:30(5.11.2021)	12:52(06.11.2021)	26:22 hrs	LINE CHARGED
704	6-Nov-21	HASSAN	110	KALLUSA-KADUR	KALLUSADRAHALLY_66	11:00	14:10	3:10	MAIN SUPPLY FAILURE
705	6-Nov-21	HASSAN	110	LPH-JLT3	lph_gen	14:27	15:45	1:18	LINE CLEAR AVAIED
706	6-Nov-21	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	18:58(3.11.2021)	9:40(6.11.2021)	14:42 hrs	LINE CHARGED
707	6-Nov-21	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	11:58	14:11	2:13	NFBC ISSUED
708	6-Nov-21	HASSAN	220	HV3	KAVOOR_220	9:53	16:30	6:37	LINE CLEAR AVAIED
709	6-Nov-21	HASSAN	220	PUTTUR-KEMAR2	PUTTUR_220	16:05	17:07	1:02	LINE FAULT
710	6-Nov-21	HASSAN	220	VARAHI-KEMAR1	VARAHI	10:32	13:48	3:16	NFBC ISSUED
711	6-Nov-21	MYSURU	66	CR NAGARA-HONNALLI	ATTIGULIPURA_66 HONNALLY_MYS_66 ARAKALAWADI_66	11:23	11:33	0:09	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
712	6-Nov-21	MYSURU	66	DR PETE-KUNTHUR	SANTHEMARAHALLI_66 THAYURU_66 MUGUR_66 JANNUR_66TNARASIPURA_66	17:48	17:54	0:05	LINE FAULT
713	6-Nov-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN: LINE CLEAR AVAIED
714	6-Nov-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN: LINE CLEAR AVAIED
715	6-Nov-21	MYSURU	66	HV1	ADDIHALLI_66	10:25	15:04	4:38	LINE CLEAR AVAIED
716	6-Nov-21	MYSURU	66	HV1	MADDUR_66 K_HONNALGERE_66 KMDODDI_66 KKDODDI_66 KIADBMANDYA_66 SOMANAHALLI_66 TUMBKERE_66 TALAGAWADI_66	16:08	16:30	0:21	HAND TRIPPED
717	6-Nov-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN: LINE CLEAR AVAIED
718	6-Nov-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN: LINE CLEAR AVAIED
719	6-Nov-21	MYSURU	66	MEGHALAPURA-HEBBANI	THUMBLA_66 GARGESHWARI_66 VYSARAJAPURA_66 CHIDRAVALLI_66BGPURA_66 PARINAMIPURA_66 THALAKADU_66 CHANDALLI_66	1:02	1:16	0:13	LINE FAULT
720	6-Nov-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN: LINE CLEAR AVAIED
721	6-Nov-21	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
722	6-Nov-21	MYSURU	220	KADAKOLA-BEGURU	NO STATIONS EFFECTED	21:05	21:21	0:16	LINE FAULT
723	6-Nov-21	TUMKUR	66	AFTL SOLAR_IPP_66	BEVINAHALLI- AFTL SOLAR_IPP_66	10:06	10:25	0:19	MAIN SUPPLY FAILURE
724	6-Nov-21	TUMKUR	66	TR-1	ANTHRASANAHALLI_220	15:15	17:48	2:33	LINE CLEAR AVAIED
725	6-Nov-21	TUMKUR	66	TR-1	CHITRAHALLI	14:50	14:55	0:05	TRANSFORMER FAULT
726	6-Nov-21	TUMKUR	66	TR-1	MAVINAKATTE	8:12	12:25	4:13	LINE CLEAR AVAIED
727	6-Nov-21	TUMKUR	66	TR-1	MATHOD_66	9:08	9:18	0:10	TRANSFORMER FAULT
728	6-Nov-21	TUMKUR	66	TR-1	MAVINAKATTE	8:12	12:25	4:12	TRANSFORMER FAULT
729	6-Nov-21	TUMKUR	66	TR-1	PD KOTE	11:59	12:43	0:43	TRANSFORMER FAULT
730	6-Nov-21	TUMKUR	66	TR-1	PD KOTE	13:43	14:44	1:01	TRANSFORMER FAULT
731	6-Nov-21	TUMKUR	66	TR-1	PAVAGADA_220	8:01	8:04	0:03	TRANSFORMER FAULT
732	6-Nov-21	TUMKUR	66	TR-2	KORA	6:10	6:36	0:26	TRANSFORMER FAULT
733	6-Nov-21	TUMKUR	66	YNHOSAKOTE	YNHOSAKOTE	15:40	16:08	0:28	MAIN SUPPLY FAILURE
734	6-Nov-21	TUMKUR	110	SHETTIKERE- HANDANKERE	SHETYKERE_110	15:47	16:33	0:46	LINE CLEAR AVAIED
735	6-Nov-21	TUMKUR	220	THALLAK 220- SEIVENUS_IPP_66	SEIVENUS_IPP_66	15:15	17:48	2:33	LINE CLEAR AVAIED
736	7-Nov-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAIED
737	7-Nov-21	BAGALKOT	110	110/11KV, HV1	UDYAMBAG_110	7:50	9:01	1:11	LINE CLEAR AVAIED
738	7-Nov-21	BAGALKOT	110	110/11KV, HV1	NIDAGUNDI_110	17:49	17:56	0:07	TRANSFORMER FAULT
739	7-Nov-21	BAGALKOT	110	110/11KV, HV1	GADAG_110	9:38	9:59	0:21	TRANSFORMER FAULT
740	7-Nov-21	BAGALKOT	110	110/11KV, HV1	KONNUR_110	12:20	12:30	0:10	MAIN SUPPLY FAILURE
741	7-Nov-21	BAGALKOT	110	110/11KV, HV1	NARAGUND_110	12:20	12:30	0:10	MAIN SUPPLY FAILURE
742	7-Nov-21	BAGALKOT	110	110/11KV, HV2	GADAG_110	9:38	9:59	0:21	TRANSFORMER FAULT
743	7-Nov-21	BAGALKOT	110	110/11KV,HV1	AKSHAY COLONY_110	12:49	14:08	1:19	HAND TRIPPED
744	7-Nov-21	BAGALKOT	110	110/11KV,HV1	ALMEL_110	12:28	12:30	0:02	TRANSFORMER FAULT
745	7-Nov-21	BAGALKOT	110	110/33KV, HV2	KONNUR_110	12:20	12:30	0:10	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
746	7-Nov-21	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	8:55 (06.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAIED
747	7-Nov-21	BAGALKOT	110	220/110KV, LV3	HUBLI_220	13:19 (03.11.2021)	16:07 (07.11.2021)	98:48 hrs	TRANSFORMER CHARGED
748	7-Nov-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.2021)			LINE OPEN: LINE CLEAR AVAIED
749	7-Nov-21	BAGALKOT	110	BANAHATTI-JAMKHANDI (NAVALAGI)	NAVALAGI_110	5:30	6:03	0:33	LINE FAULT
750	7-Nov-21	BAGALKOT	110	BGWDI-F8-MAMDAPUR1 ( LINE 2)	MAMADAPUR_110	4:27	4:43	0:16	LINE FAULT
751	7-Nov-21	BAGALKOT	110	BGWDI-F8-MAMDAPUR1 ( LINE 2)	MAMADAPUR_110	22:07	22:18	0:11	LINE FAULT
752	7-Nov-21	BAGALKOT	110	BGWDI-F8-MAMDAPUR2 ( LINE 1)	MAMADAPUR_110	22:07	22:18	0:11	LINE FAULT
753	7-Nov-21	BAGALKOT	110	BIDNAL- KONNUR	KONNUR_110	5:55	6:30	0:35	MAIN SUPPLY FAILURE
754	7-Nov-21	BAGALKOT	110	BIDNAL- NARAGUND	NARAGUND_110	5:55	6:30	0:35	MAIN SUPPLY FAILURE
755	7-Nov-21	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	5:55	10:47	4:52	LINE FAULT
756	7-Nov-21	BAGALKOT	110	GHATAPRABHA220- PG HUNSHYALY	PG HUNSHYAL_110	5:21	5:31	0:10	LINE FAULT
757	7-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL- NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAIED
758	7-Nov-21	BAGALKOT	110	HAVERI220- TILUVALI (HANGAL)	HANGAL_110	5:03	5:21	0:18	LINE FAULT
759	7-Nov-21	BAGALKOT	110	INDI220- DEVARHIPPARAGI	DEVAR HIPPARAGI_110, HIREMASALI_110, ATHARGA_110	2:50	3:00	0:10	LINE FAULT
760	7-Nov-21	BAGALKOT	110	KULIGOD-GAMESHA	KULIGOD_110	5:20	5:45	0:25	HAND TRIPPED
761	7-Nov-21	BAGALKOT	110	MALGHAN(S)- MANALI SUGARS	MALGHAN(S)_110	4:21	4:27	0:06	LINE FAULT
762	7-Nov-21	BAGALKOT	110	NAVALGUND- BIDNAL	NAVALGUND_110	6:31	12:37	6:06	HAND TRIPPED
763	7-Nov-21	BAGALKOT	110	PG HUNSHYAL- MUDALGI(NAGNUR)	MUDALGI_110, NAGNUR_110	5:20	5:35	0:15	HAND TRIPPED
764	7-Nov-21	BAGALKOT	110	PG HUNSHYAL- SATTI SUGARS	PG HUNSHYAL_110	5:20	5:34	0:14	HAND TRIPPED
765	7-Nov-21	BAGALKOT	110	SINDAGI ( CHANDKAVATE)-ALMEL	ALMEL_110	1:05	1:10	0:05	MAIN SUPPLY FAILURE
766	7-Nov-21	BAGALKOT	110	TODALBAGI- JAMKHANDI SUGARS	TODALBAGI_110	22:21	22:25	0:04	LINE FAULT
767	7-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN:LINE FAULT
768	7-Nov-21	BAGALKOT	220	BELGAUM-KANABARG1(NARENDRA1)	BELGAUM_220	15:18 (02.11.2021)			LINE OPEN: LINE CLEAR AVAIED
769	7-Nov-21	BAGALKOT	220	CHIKKODI- BELGAUM1	CHIKKODI_220	20:39 (07.11.2021)			LINE OPEN: LINE CLEAR AVAIED
770	7-Nov-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAIED
771	7-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
772	7-Nov-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN: LINE CLEAR AVAIED
773	7-Nov-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN: LINE CLEAR AVAIED
774	7-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
775	7-Nov-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAIED
776	7-Nov-21	BENGALURU	66	ALUR - NELMANGALA 66	ALUR	9:01	9:11	0:10	LOAD CHANGE OVER
777	7-Nov-21	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	16:01	16:07	0:05	LOAD CHANGE OVER
778	7-Nov-21	BENGALURU	66	CHANDAPURA - YERANDANAHALLI 220	CHANDAPURA	16:32	16:38	0:06	LOAD CHANGE OVER
779	7-Nov-21	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	9:20	9:35	0:15	LOAD CHANGE OVER
780	7-Nov-21	BENGALURU	66	ELECTRONIC CITY - YERANDANAHALLI 1	ELECTRONIC CITY, INFOSYS (EHT), HULIMANGALA	18:35	18:42	0:07	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
781	7-Nov-21	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	7:55	8:09	0:13	LOAD CHANGEOVER
782	7-Nov-21	BENGALURU	66	GOKULA - BEL (EH)	BEL (EHT)	15:47	15:53	0:05	LOAD CHANGEOVER
783	7-Nov-21	BENGALURU	66	GOKULA - RMV	GOKULA, BEL (EHT), HMT (EHT)	15:47	15:52	0:04	LOAD CHANGEOVER
784	7-Nov-21	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	7:55	8:10	0:14	LOAD CHANGEOVER
785	7-Nov-21	BENGALURU	66	HAL 220 - HOODY 1	KADUBISANAHALLI, ISRO (EHT), CESSNA (EHT)	18:30	19:12	0:41	LINE FAULT
786	7-Nov-21	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	8:57	9:13	0:16	LINE FAULT
787	7-Nov-21	BENGALURU	66	HV1	SRIGANDAKAVAL	14:52	14:55	0:02	LINE CLEAR AVAIED
788	7-Nov-21	BENGALURU	66	HV1	WEL CAST STEEL	11:20	11:28	0:07	LINE CLEAR AVAIED
789	7-Nov-21	BENGALURU	66	HV1	TEKAL	9:21	17:44	8:23	LINE CLEAR AVAIED
790	7-Nov-21	BENGALURU	66	HV1	SARJAPURA 220	9:12	9:17	0:05	LOAD CHANGEOVER
791	7-Nov-21	BENGALURU	66	HV1	SARJAPURA 220	16:08	16:12	0:04	LOAD CHANGEOVER
792	7-Nov-21	BENGALURU	66	HV1	KAMASAMUDRA	9:11	17:49	8:38	LINE CLEAR AVAIED
793	7-Nov-21	BENGALURU	66	HV1	CHANDAPURA	0:40	0:48	0:08	LINE CLEAR AVAIED
794	7-Nov-21	BENGALURU	66	HV1	CHANDAPURA	8:31	8:36	0:05	LOAD CHANGEOVER
795	7-Nov-21	BENGALURU	66	HV2	SRIGANDAKAVAL	14:52	14:55	0:02	LINE CLEAR AVAIED
796	7-Nov-21	BENGALURU	66	HV2	WEL CAST STEEL	12:50	13:00	0:10	LINE CLEAR AVAIED
797	7-Nov-21	BENGALURU	66	HV2	THAYALUR	1:46	2:47	1:01	TRANSFORMER FAULT
798	7-Nov-21	BENGALURU	66	HV2	THAYALUR	3:04	4:00	0:55	LINE CLEAR AVAIED
799	7-Nov-21	BENGALURU	66	HV2	THAYALUR	16:10	17:30	1:20	LINE CLEAR AVAIED
800	7-Nov-21	BENGALURU	66	HV2	TEKAL	9:21	17:45	8:23	LINE CLEAR AVAIED
801	7-Nov-21	BENGALURU	66	HV2	SIDDALAGATTA	13:08	14:58	1:50	LINE CLEAR AVAIED
802	7-Nov-21	BENGALURU	66	HV2	SARJAPURA 220	9:12	9:16	0:03	LOAD CHANGEOVER
803	7-Nov-21	BENGALURU	66	HV2	SARJAPURA 220	16:04	16:11	0:07	LOAD CHANGEOVER
804	7-Nov-21	BENGALURU	66	HV2	CHANDAPURA	0:40	0:48	0:08	LINE CLEAR AVAIED
805	7-Nov-21	BENGALURU	66	HV2	CHANDAPURA	8:31	8:36	0:05	LOAD CHANGEOVER
806	7-Nov-21	BENGALURU	66	KAMASAMUDRA - KGF	KAMASAMUDRA	9:11	17:49	8:38	LINE CLEAR AVAIED
807	7-Nov-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	9:02	17:40	8:38	LINE CLEAR AVAIED
808	7-Nov-21	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	5:07	5:20	0:13	LINE FAULT
809	7-Nov-21	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	9:02	17:40	8:38	LINE CLEAR AVAIED
810	7-Nov-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, THORALAKKI	6:15	6:33	0:18	LINE FAULT
811	7-Nov-21	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA, THORALAKKI	9:02	17:40	8:38	LINE CLEAR AVAIED
812	7-Nov-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	6:15	6:33	0:18	LINE FAULT
813	7-Nov-21	BENGALURU	66	MALUR 220 - KGF 2	BEML (EHT)	9:02	17:40	8:38	LINE CLEAR AVAIED
814	7-Nov-21	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	9:02	17:40	8:38	LINE CLEAR AVAIED
815	7-Nov-21	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	9:02	17:40	8:37	LINE CLEAR AVAIED
816	7-Nov-21	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	7:45	8:05	0:20	LOAD CHANGEOVER
817	7-Nov-21	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	16:02	16:11	0:09	LOAD CHANGEOVER
818	7-Nov-21	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	6:54	6:58	0:03	LOAD CHANGEOVER
819	7-Nov-21	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	7:48	8:01	0:13	LOAD CHANGEOVER
820	7-Nov-21	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	16:02	16:07	0:04	LOAD CHANGEOVER
821	7-Nov-21	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	9:11	9:15	0:03	LOAD CHANGEOVER
822	7-Nov-21	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	SARJAPURA 220	16:04	16:11	0:07	LOAD CHANGEOVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
823	7-Nov-21	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	9:11	9:22	0:11	LOAD CHANGEOVER
824	7-Nov-21	BENGALURU	66	SARIJAPURA 220 - DOMMASANDRA	DOMMASANDRA	16:07	16:13	0:05	LOAD CHANGEOVER
825	7-Nov-21	BENGALURU	66	SARIJAPURA 220 - MALUR 3	SARIJAPURA 220	9:05	9:11	0:06	LOAD CHANGEOVER
826	7-Nov-21	BENGALURU	66	SOLDEVANAHALLI - BEIC	BEIC	16:07	16:32	0:25	LOAD CHANGEOVER
827	7-Nov-21	BENGALURU	66	SRS PEENYA 220 - BEIC	BEIC	9:16	9:32	0:16	LOAD CHANGEOVER
828	7-Nov-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	9:31	9:38	0:06	LOAD CHANGEOVER
829	7-Nov-21	BENGALURU	66	SRS PEENYA 220 - MEI LAYOUT	MEI LAYOUT, WIDIA, WIDIA (EHT)	15:45	15:47	0:02	LOAD CHANGEOVER
830	7-Nov-21	BENGALURU	66	TEKAL - MALUR	TEKAL, BUDIKOTE	9:21	17:44	8:23	LINE CLEAR AVAILED
831	7-Nov-21	BENGALURU	66	TK HALLI 220 - SHIMSHA 1	TK HALLI 220	10:10	10:38	0:28	LINE FAULT
832	7-Nov-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	9:45	10:02	0:17	LOAD CHANGEOVER
833	7-Nov-21	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	16:07	16:32	0:25	LOAD CHANGEOVER
834	7-Nov-21	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	VIKAS TECH PARK 220	16:05	16:20	0:15	LOAD CHANGEOVER
835	7-Nov-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	9:45	10:02	0:17	LOAD CHANGEOVER
836	7-Nov-21	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	16:07	16:32	0:25	LOAD CHANGEOVER
837	7-Nov-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	9:45	10:02	0:17	LOAD CHANGEOVER
838	7-Nov-21	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	16:07	16:32	0:25	LOAD CHANGEOVER
839	7-Nov-21	BENGALURU	220	HV1	MALUR 220	9:02	17:36	8:34	LINE CLEAR AVAILED
840	7-Nov-21	BENGALURU	220	HV2	MALUR 220	9:02	17:36	8:33	LINE CLEAR AVAILED
841	7-Nov-21	BENGALURU	220	KOLAR 220 - MALUR 1	MALUR 220	10:25	16:05	5:40	LINE CLEAR AVAILED
842	7-Nov-21	BENGALURU	220	KOLAR 220 - MALUR 3	SARIJAPURA 220, VIKAS TECH PARK 220	10:25	16:02	5:37	LINE CLEAR AVAILED
843	7-Nov-21	BENGALURU	220	LV1	MITTEMARI 220	10:44(2-11-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
844	7-Nov-21	BENGALURU	220	MALUR 220 - HOODY 400	NO STATION AFFECTED	10:09	16:05	5:56	LINE CLEAR AVAILED
845	7-Nov-21	BENGALURU	220	MALUR 220 - KOLAR 1	MALUR 220	10:09	17:35	7:26	LINE CLEAR AVAILED
846	7-Nov-21	BENGALURU	220	MALUR 220 - SARIJAPURA 220	SARIJAPURA 220, VIKAS TECH PARK 220	10:09	16:04	5:54	LINE CLEAR AVAILED
847	7-Nov-21	BENGALURU	220	VIKAS TECH PARK 220 - MALUR 220	VIKAS TECH PARK 220	9:45	10:00	0:15	LOAD CHANGEOVER
848	7-Nov-21	BENGALURU	400	NELMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	2:40	10:10	7:30	LINE FAULT
849	7-Nov-21	GULBARGA	66	HV1	ITTAGI_220	7:50	17:40	9:50	LINE CLEAR AVAILED
850	7-Nov-21	GULBARGA	66	HV1	UCHCHANAGIDURGA_66	10:40	12:00	1:20	LINE CLEAR AVAILED
851	7-Nov-21	GULBARGA	66	HV2	ITTAGI_220	16:03	16:24	0:21	LINE CLEAR AVAILED
852	7-Nov-21	GULBARGA	66	HV2	TAMBRAHALI_66	6:18	6:28	0:10	TRANSFORMER FAULT
853	7-Nov-21	GULBARGA	110	ADAVI AMARESHWARA-MALLAT	ADAVI AMARESHWARA_110	20:45	20:55	0:10	MAIN SUPPLY FAILURE
854	7-Nov-21	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	11:00	11:05	0:05	MAIN SUPPLY FAILURE
855	7-Nov-21	GULBARGA	110	BAYYAPURA-MUDGAL	BAYYAPURA_110	12:20	12:30	0:10	MAIN SUPPLY FAILURE
856	7-Nov-21	GULBARGA	110	CHOWDAPUR-AFZALPUR	CHOWDAPUR_110	13:10	13:45	0:35	LINE CLEAR AVAILED
857	7-Nov-21	GULBARGA	110	CHOWDAPUR-MADIYAL	CHOWDAPUR_110	13:45	15:35	1:50	MAIN SUPPLY FAILURE
858	7-Nov-21	GULBARGA	110	HV2	MADIYAL_110	4:32	4:40	0:08	TRANSFORMER FAULT
859	7-Nov-21	GULBARGA	110	HV3	VALKAMDINNI_110	13:51	13:54	0:03	TRANSFORMER FAULT
860	7-Nov-21	GULBARGA	110	MADIYAL-CHOWDAPUR	CHOWDAPUR_110	13:30	15:50	2:20	LINE CLEAR AVAILED
861	7-Nov-21	GULBARGA	110	MADIYAL-NSLSUGAR_IPP	MADIYAL_110	4:25	4:30	0:05	LINE FAULT
862	7-Nov-21	GULBARGA	110	MALLAT-BYAGAWAT	BYAGAWAT_110,VALKAMDINNI_110	2:50	2:58	0:08	MAIN SUPPLY FAILURE
863	7-Nov-21	GULBARGA	110	MALLAT-MADLAPUR	ADAVI AMARESHWAR_110	20:47	20:55	0:08	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
864	7-Nov-21	GULBARGA	110	MUNIRABAD-SINDHANOOR2	KAMPLI_110,MUKUNDA_110,KEREHALLI_110, MALLAPUR_110	12:15	13:48	1:33	MAIN SUPPLY FAILURE
865	7-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	2:45	2:50	0:05	LINE FAULT
866	7-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	3:38	3:40	0:02	LINE FAULT
867	7-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	4:08	4:12	0:04	LINE FAULT
868	7-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	5:45	6:35	0:50	LINE FAULT
869	7-Nov-21	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110	22:40	22:45	0:05	LINE FAULT
870	7-Nov-21	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	5:41	5:58	0:17	MAIN SUPPLY FAILURE
871	7-Nov-21	GULBARGA	110	SEDAM-VICAT SAGAR_IPP	SEDAM_220	18:58	19:15	0:17	MAIN SUPPLY FAILURE
872	7-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAILED
873	7-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN:LINE FAULT
874	7-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAILED
875	7-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR1	RAICHUR_110	2:39	2:50	0:11	MAIN SUPPLY FAILURE
876	7-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR2	RAICHUR_110	2:39	2:50	0:11	MAIN SUPPLY FAILURE
877	7-Nov-21	GULBARGA	110	SINDHANOOR-SIRAGUPPA	TEKKALAKOTE_110, SIRIGUPPA_110,DHADESUGUR_110,SIRIGERA CROSS_110,NSL SUGAR_IPP,VOORA_IPP	5:40	5:50	0:10	MAIN SUPPLY FAILURE
878	7-Nov-21	GULBARGA	110	STARMETALLI-MUNIRABAD	MUNIRABAD_220	12:14	12:25	0:11	LINE FAULT
879	7-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
880	7-Nov-21	GULBARGA	220	MALLAT-LINGASUGUR	MALLAT_220	0:54	6:15	5:21	LINE FAULT
881	7-Nov-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	13:00	13:11	0:11	LINE FAULT
882	7-Nov-21	HASSAN	66	HV1	HALLYMYSORE_66	10:17(6.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
883	7-Nov-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	13:13	13:16	0:03	LINE FAULT
884	7-Nov-21	HASSAN	110	HV1	NANDIKUR_110	3:07	3:35	0:28	TRANSFORMER FAULT
885	7-Nov-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
886	7-Nov-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	6:06	6:14	0:07	LINE FAULT
887	7-Nov-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:18	11:24	0:06	LINE FAULT
888	7-Nov-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
889	7-Nov-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
890	7-Nov-21	MYSURU	66	HARADANAHALLI(JAK)-LAXJEET	NO STATIONS EFFECTED	9:07	9:14	0:06	LINE FAULT
891	7-Nov-21	MYSURU	66	HV1	DATAGALLI_66	7:23	17:26	10:02	TRANSFORMER FAULT
892	7-Nov-21	MYSURU	66	HV2	AKIHEBBAL_66	22:49	22:58	0:08	TRANSFORMER FAULT
893	7-Nov-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
894	7-Nov-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN: LINE CLEAR AVAILED
895	7-Nov-21	MYSURU	66	MADHUVANALLI-HANNUR2	NO STATIONS EFFECTED	8:29	8:33	0:04	LINE FAULT
896	7-Nov-21	MYSURU	66	MADHUVANALLI-HANNUR2	NO STATIONS EFFECTED	11:51	11:57	0:06	LINE FAULT
897	7-Nov-21	MYSURU	66	MADHUVANALLI-LOKKANAHALLI	LOKKANAHALLI_66 PG PALYA_66	5:55	6:00	0:04	LINE FAULT
898	7-Nov-21	MYSURU	66	MEGHALAPURA-VAJMANGALA	NO STATIONS EFFECTED	13:08	13:18	0:10	LINE FAULT
899	7-Nov-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN: LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
900	7-Nov-21	MYSURU	220	HV2	TUBINKERE_220	15:10:00 (25.10.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
901	7-Nov-21	TUMKUR	66	DAVANGERE SRS- AVAREGERE66	AVAREGERE_66,MELLEKATTE_66,KADAJJI_66	14:05	15:16	1:10	LINE FAULT
902	7-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:13	6:27	0:14	LINE FAULT
903	7-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	23:07	23:13	0:06	LINE FAULT
904	7-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	3:26	3:34	0:07	LINE FAULT
905	7-Nov-21	TUMKUR	66	TR-1	MATHOD	9:08	9:18	0:10	TRANSFORMER FAULT
906	7-Nov-21	TUMKUR	66	TR-1	CHITRALI_66	14:50	14:51	0:01	TRANSFORMER FAULT
907	8-Nov-21	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
908	8-Nov-21	BAGALKOT	110	110/11KV, HV1	SHIRGOAN_110	8:30	14:52	6:22	LINE CLEAR AVAILED
909	8-Nov-21	BAGALKOT	110	110/11KV, HV2	MATTIHAL_110	17:58	18:06	0:08	LINE CLEAR AVAILED
910	8-Nov-21	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	13:31	15:30	1:59	LINE CLEAR AVAILED
911	8-Nov-21	BAGALKOT	110	110/11KV, HV3	MUDHOL_110	9:56	10:09	0:13	HAND TRIPPED
912	8-Nov-21	BAGALKOT	110	110/11KV,HV1	BENAKATTI_110	20:00	21:10	1:10	TRANSFORMER FAULT
913	8-Nov-21	BAGALKOT	110	110/11KV,HV2	AMBEWADI_220	16:10	16:14	0:04	TRANSFORMER FAULT
914	8-Nov-21	BAGALKOT	110	110/11KV,HV2	BENAKATTI_110	20:00	21:09	1:09	TRANSFORMER FAULT
915	8-Nov-21	BAGALKOT	110	110/11KV,HV3	BIJAPUR_110	11:20	11:38	0:18	TRANSFORMER FAULT
916	8-Nov-21	BAGALKOT	110	110/33KV, HV1	TIKOTA_110, BIJARAGI_33	9:02	14:00	4:58	LINE CLEAR AVAILED
917	8-Nov-21	BAGALKOT	110	110/33KV, HV1	TIKOTA_110, BIJARAGI_33	14:33	14:39	0:06	TRANSFORMER FAULT
918	8-Nov-21	BAGALKOT	110	110/33KV, HV2 & SHIRABUR_33,YELPARAHATTI_33,SAPT ASAGAR_33 LINES	KUDACHI_110	14:53	14:55	0:02	TRANSFORMER FAULT
919	8-Nov-21	BAGALKOT	110	110/33KV, HV3 & KOLIGUDDA_33,MYTRA SOLAR_33 LINES	HIDIKAL_110	11:45	14:13	2:28	LINE CLEAR AVAILED
920	8-Nov-21	BAGALKOT	110	220/110KV, LV1	MK HUBLI_220	0:53	6:30	5:37	HAND TRIPPED
921	8-Nov-21	BAGALKOT	110	220/110KV, LV2	MKHUBLI_220	8:55 (06.11.2021)	8:19 (08.11.2021)	47:24 hrs	TRANSFORMER CHARGED
922	8-Nov-21	BAGALKOT	110	220/110KV, LV2	STATON NOT EFFECTED KARWAR_220	12:38	16:26	3:48	LINE CLEAR AVAILED
923	8-Nov-21	BAGALKOT	110	220/110KV,LV1	STATON NOT EFFECTED KARWAR_220	12:36	16:25	3:51	LINE CLEAR AVAILED
924	8-Nov-21	BAGALKOT	110	AMBEWADI-HALIYAL	AMBEWADI_220	10:44	12:11	1:27	LINE CLEAR AVAILED
925	8-Nov-21	BAGALKOT	110	ANKALAGI-HIDIKAL	ANKALAGI_110	13:31 (31.10.2021)			LINE OPEN: LINE CLEAR AVAILED
926	8-Nov-21	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_220	11:10	11:25	0:15	HAND TRIPPED
927	8-Nov-21	BAGALKOT	110	GHATAPRABHA-SHIRGOAN	SHIRGOAN_110	10:09	14:52	4:43	LINE CLEAR AVAILED
928	8-Nov-21	BAGALKOT	110	GOPANKOPPA-BIDNAL-NVLKD(NARAGUND)	STATION NOT AFFECTED GOPANAKOPPA_110	18:15 (24.06.2021)			LINE OPEN: LINE CLEAR AVAILED
929	8-Nov-21	BAGALKOT	110	MALGHAN(S)- MANALI SUGARS	MALGHAN(S)_110	17:57	18:04	0:07	LINE FAULT
930	8-Nov-21	BAGALKOT	110	MALGHAN(S)- MANALI SUGARS	MALGHAN(S)_110	23:39	23:43	0:04	LINE FAULT
931	8-Nov-21	BAGALKOT	110	MKHUBLI220- BAILHONGAL	BAILHONGAL_110	11:25	12:30	1:05	LINE CLEAR AVAILED
932	8-Nov-21	BAGALKOT	110	SIRSI 1-KUMTA	KUMTA_110	22:35 (08.11.2021)			LINE OPEN: LINE CLEAR AVAILED
933	8-Nov-21	BAGALKOT	110	TIKOTA- BHUTNAL(TAKKALAKI)	TIKOTA_110	14:33	14:36	0:03	HAND TRIPPED
934	8-Nov-21	BAGALKOT	220	AMBEWADI-NAGJHARI2	AMBEWADI_220	13:03	13:16	0:13	LINE FAULT
935	8-Nov-21	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	8:32 (23.10.2021)			LINE OPEN:LINE FAULT
936	8-Nov-21	BAGALKOT	220	BELGAUM-KANABARGI1(NARENDRA1)	BELGAUM_220	15:18 (02.11.2021)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
937	8-Nov-21	BAGALKOT	220	CHIKKODI- BELGAUM1	CHIKKODI_220	20:39 (07.11.2021)	7:21 (08.11.2021)	10:42 hrs	LINE CHARGED
938	8-Nov-21	BAGALKOT	220	HUBLI- NAGJHARI1	HUBLI_220	15:43	15:46	0:03	HAND TRIPPED
939	8-Nov-21	BAGALKOT	220	HUBLI- SIRSI1	HUBLI_220	9:58	14:02	4:04	LINE CLEAR AVAILED
940	8-Nov-21	BAGALKOT	220	HUBLI- SIRSI2	HUBLI_220	11:53	14:03	2:10	LINE CLEAR AVAILED
941	8-Nov-21	BAGALKOT	220	KARWAR -KADRA1	STATON NOT EFFECTED KARWAR_220	12:42	16:25	3:43	LINE CLEAR AVAILED
942	8-Nov-21	BAGALKOT	220	KARWAR -KADRA2	STATON NOT EFFECTED KARWAR_220	12:42	16:25	3:43	LINE CLEAR AVAILED
943	8-Nov-21	BAGALKOT	220	MAHALINGAPUR-VAJRAMATTI 2	STATION NOT AFFECTED MAHALINGAPUR_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
944	8-Nov-21	BAGALKOT	220	NARENDRA-AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	17:22 (30.03.2021)			LINE OPEN:LINE FAULT
945	8-Nov-21	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	18:51 (01.11.2021)			LINE OPEN: LINE CLEAR AVAILED
946	8-Nov-21	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	17:47 (04.10.2021)			LINE OPEN: LINE CLEAR AVAILED
947	8-Nov-21	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR1	STATION NOT AFFECTED VAJRAMATTI_220	16:17 (23.02.2021)			LINE OPEN:LINE FAULT
948	8-Nov-21	BAGALKOT	220	VAJRAMATTI -MAHALINGAPUR2	STATION NOT AFFECTED VAJRAMATTI_220	10:07 (24.02.2021)			LINE OPEN: LINE CLEAR AVAILED
949	8-Nov-21	BENGALURU	66	GOLF LINK - KORMANGALA 220	GOLF LINK	12:18	12:35	0:17	MAIN SUPPLY FAILURE
950	8-Nov-21	BENGALURU	66	HV1	HOSUR RAMAPURA	8:32	8:50	0:17	LINE CLEAR AVAILED
951	8-Nov-21	BENGALURU	66	HV1	GODURU	14:10	15:13	1:03	LINE CLEAR AVAILED
952	8-Nov-21	BENGALURU	66	HV1	CHANDAPURA	13:00	14:51	1:50	LINE CLEAR AVAILED
953	8-Nov-21	BENGALURU	66	HV2	T K HALLI 220	20:47	21:04	0:16	MAIN SUPPLY FAILURE
954	8-Nov-21	BENGALURU	66	HV2	T K HALLI 220	21:48	21:55	0:07	MAIN SUPPLY FAILURE
955	8-Nov-21	BENGALURU	66	HV2	HAL 220	7:48	8:56	1:08	TRANSFORMER FAULT
956	8-Nov-21	BENGALURU	66	JIGANI LINK ROAD - BG ROAD	JIGANI LINK ROAD	10:11	10:17	0:06	LOAD CHANGEOVER
957	8-Nov-21	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI	23:32	23:40	0:08	LINE FAULT
958	8-Nov-21	BENGALURU	66	KOLAR 220 - VEMGAL	TALAGUNDA, VEMGAL, KYALNUR	7:08	7:21	0:12	LINE FAULT
959	8-Nov-21	BENGALURU	66	KORMANGALA 220 - GOLF LINK HAL 1	AMARJYOTHI	12:18	14:05	1:47	MAIN SUPPLY FAILURE
960	8-Nov-21	BENGALURU	66	KORMANGALA 220 - GOLF LINK HAL 2	K&C VALLEY, NAL(EHT)	12:18	14:05	1:47	MAIN SUPPLY FAILURE
961	8-Nov-21	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, DIBBURAHALLI	6:16	6:25	0:08	LINE FAULT
962	8-Nov-21	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	12:18	12:37	0:19	MAIN SUPPLY FAILURE
963	8-Nov-21	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, PADMANABHANAGAR	12:18	12:37	0:19	MAIN SUPPLY FAILURE
964	8-Nov-21	BENGALURU	66	PLATINUM CITY - ATTUR YELAHANKA	PLATINUM CITY	7:14	7:18	0:04	LOAD CHANGEOVER
965	8-Nov-21	BENGALURU	66	T GOLAHALLI - PGCIL 2	NO STATION AFFECTED	10:55	17:15	6:20	LINE CLEAR AVAILED
966	8-Nov-21	BENGALURU	66	T GOLAHALLI 220 - NANGLI	BAIRAKURU, NANGALI	16:02	16:25	0:23	LINE FAULT
967	8-Nov-21	BENGALURU	66	T K HALLI 220 - LIMBAVALI(IPP)	LIMBAVALI(IPP)	20:47	21:04	0:16	MAIN SUPPLY FAILURE
968	8-Nov-21	BENGALURU	66	T K HALLI 220 - LIMBAVALI(IPP)	LIMBAVALI(IPP)	21:48	21:55	0:07	MAIN SUPPLY FAILURE
969	8-Nov-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	20:47	21:04	0:16	MAIN SUPPLY FAILURE
970	8-Nov-21	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE	21:48	21:55	0:07	MAIN SUPPLY FAILURE
971	8-Nov-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, B V HALLI, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	20:47	21:04	0:16	MAIN SUPPLY FAILURE
972	8-Nov-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, B V HALLI, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	21:48	21:55	0:07	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
973	8-Nov-21	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, B V HALLI, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	22:00:11(8-11-2021)			LINE OPEN: LINE CLEAR AVAILED
974	8-Nov-21	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, YATAMBADI, K HONNALGERE, SOMANAHALLI(I/A)	20:47	21:04	0:16	MAIN SUPPLY FAILURE
975	8-Nov-21	BENGALURU	66	TK HALLI 220 - IGGALUR	IGGALUR, YATAMBADI, K HONNALGERE, SOMANAHALLI(I/A)	21:48	21:55	0:07	MAIN SUPPLY FAILURE
976	8-Nov-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	20:47	21:04	0:16	MAIN SUPPLY FAILURE
977	8-Nov-21	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	21:48	21:55	0:07	MAIN SUPPLY FAILURE
978	8-Nov-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA, TALAGWADI	20:47	21:04	0:16	MAIN SUPPLY FAILURE
979	8-Nov-21	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA, TALAGWADI	21:48	21:55	0:07	MAIN SUPPLY FAILURE
980	8-Nov-21	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	NO STATION AFFECTED	20:47	21:04	0:16	MAIN SUPPLY FAILURE
981	8-Nov-21	BENGALURU	66	TK HALLI 220 - SOMANAHALLI 2	NO STATION AFFECTED	21:48	21:55	0:07	MAIN SUPPLY FAILURE
982	8-Nov-21	BENGALURU	66	WELCASTE STEEL - ABBIGERE	WELCASTE STEEL	7:48	7:51	0:03	LOAD CHANGEOVER
983	8-Nov-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	4:32	4:55	0:23	MAIN SUPPLY FAILURE
984	8-Nov-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	7:17	7:24	0:07	LOAD CHANGEOVER
985	8-Nov-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	10:25	10:32	0:07	LOAD CHANGEOVER
986	8-Nov-21	BENGALURU	66	YERANDANAHALLI 220 - ELECTRONIC CITY 2	BIOCON (EHT), BOMMASANDRA I/A	14:23	14:27	0:04	LOAD CHANGEOVER
987	8-Nov-21	BENGALURU	220	HSR LAYOUT 220 - KORAMANGALA 220	NIMHANS 220, KORMANGALA 220	12:18	12:37	0:19	LINE FAULT
988	8-Nov-21	BENGALURU	220	HV1	YARANDANAHALLI 220	4:32	4:55	0:23	TRANSFORMER FAULT
989	8-Nov-21	BENGALURU	220	HV2	T K HALLI 220	20:47	21:04	0:16	TRANSFORMER FAULT
990	8-Nov-21	BENGALURU	220	HV2	T K HALLI 220	21:48	21:55	0:07	TRANSFORMER FAULT
991	8-Nov-21	BENGALURU	220	KORAMANGALA 220 - NIMHANS 220	KORMANGALA 220	12:18	14:00	1:42	LINE FAULT
992	8-Nov-21	BENGALURU	220	LV1	MITTEMARI 220	10:44(2-11-2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
993	8-Nov-21	BENGALURU	220	LV2	T K HALLI 220	21:48	22:02	0:13	TRANSFORMER FAULT
994	8-Nov-21	BENGALURU	220	NIMHANS 220 - KORMANGALA 220	NIMHANS 220	12:18	12:37	0:19	LINE FAULT
995	8-Nov-21	GULBARGA	66	HANASI-BADALADUKU	HANASI_66	9:05	12:05	3:00	MAIN SUPPLY FAILURE
996	8-Nov-21	GULBARGA	66	HV1	KOGALI_66	16:10	16:50	0:40	LINE CLEAR AVAILED
997	8-Nov-21	GULBARGA	66	HV1	KOGALI_66	17:50	19:05	1:15	TRANSFORMER FAULT
998	8-Nov-21	GULBARGA	66	HV2	BENNEHALLI_66	2:05	2:10	0:05	TRANSFORMER FAULT
999	8-Nov-21	GULBARGA	66	HV2	BENNEHALLI_66	17:40	18:10	0:30	LINE CLEAR AVAILED
1000	8-Nov-21	GULBARGA	66	HV2	TAMBRAHALLI_66	13:16	14:26	1:10	LINE CLEAR AVAILED
1001	8-Nov-21	GULBARGA	66	HV3,HV4	TUNGABHADRA SWITCHING STATION_66	1:20	1:26	0:06	LINE CLEAR AVAILED
1002	8-Nov-21	GULBARGA	66	KOGALI-ATRSOLAR_IPP	KOGALI_66	18:20	18:50	0:30	LINE CLEAR AVAILED
1003	8-Nov-21	GULBARGA	66	TAMBRAHALLI-ITTAGGI	TAMBRAHALLI_66	15:15	16:50	1:35	LINE CLEAR AVAILED
1004	8-Nov-21	GULBARGA	110	ADAVI AMARESHWARA-SINDHANOOR	JAWALGERA_110	9:50(08.11.2021)			LINE OPEN: LINE CLEAR AVAILED
1005	8-Nov-21	GULBARGA	110	ALIPUR-BELLARY NORTH	SOMASAMUDRA_110,BELLARY NORTH_110,MOKA_110,PD HALLI_110,BISIHALLI_110,JANAKI_IPP,BASAI STEELA ACC	12:02	12:07	0:05	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1006	8-Nov-21	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	9:00	10:00	1:00	MAIN SUPPLY FAILURE
1007	8-Nov-21	GULBARGA	110	GABBUR-RAICHUR	GABBUR_110	20:10	20:15	0:05	MAIN SUPPLY FAILURE
1008	8-Nov-21	GULBARGA	110	GALAG-ALKOD	GALAG_110	5:15	5:30	0:15	MAIN SUPPLY FAILURE
1009	8-Nov-21	GULBARGA	110	HV2	SIRIGERICROSS_110	6:33	6:43	0:10	TRANSFORMER FAULT
1010	8-Nov-21	GULBARGA	110	HV2	HATTI_110	9:03	9:07	0:04	TRANSFORMER FAULT
1011	8-Nov-21	GULBARGA	110	HV3	VALKAMDINNI_110	16:29	17:02	0:33	TRANSFORMER FAULT
1012	8-Nov-21	GULBARGA	110	HV3	CHINCHOLI_110	11:20	14:28	3:08	LINE CLEAR AVAIED
1013	8-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR(IDLE)	ADVIAMRESHWAR_110	9:55	14:20	4:25	LINE CLEAR AVAIED
1014	8-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR(IDLE)	ADVIAMRESHWAR_110	21:20	21:25	0:05	LINE FAULT
1015	8-Nov-21	GULBARGA	110	JAWALGERA-ADVIAMRESHWAR(IDLE)	ADVIAMRESHWAR_110	23:35	23:40	0:05	LINE FAULT
1016	8-Nov-21	GULBARGA	110	KANAKAGIRI-KUSHTAGI	KANAKAGIRI_110	12:30	16:25	3:55	MAIN SUPPLY FAILURE
1017	8-Nov-21	GULBARGA	110	KAPNOOR-ALAND	ALAND_110,KADGANCHI_110	23:39	23:45	0:06	LINE FAULT
1018	8-Nov-21	GULBARGA	110	LV1	RAICHUR_220	9:25	9:50	0:25	TRANSFORMER FAULT
1019	8-Nov-21	GULBARGA	110	MALLAPUR-MUNIRABAD	MALLAPUR_110	11:20	11:45	0:25	LINE CLEAR AVAIED
1020	8-Nov-21	GULBARGA	110	MALLAT-ALKOD	ALKOD_110,GALAG_110	5:20	5:28	0:08	LINE FAULT
1021	8-Nov-21	GULBARGA	110	MALLAT-MADALAPUR	ADAVI AMARESHWAR_110	15:34	15:44	0:10	LINE FAULT
1022	8-Nov-21	GULBARGA	110	MATAMARI-RAICHUR	MATAMARI_110	9:30	9:55	0:25	MAIN SUPPLY FAILURE
1023	8-Nov-21	GULBARGA	110	NAVALI-KUSHTAGI	NAVALI_110	12:30	16:30	4:00	MAIN SUPPLY FAILURE
1024	8-Nov-21	GULBARGA	110	PDHALLI-ALIPUR	PD_HALLI_110	12:02	12:07	0:05	MAIN SUPPLY FAILURE
1025	8-Nov-21	GULBARGA	110	PDHALLI-BASAI STEELS_IPP	PD_HALLI_110	10:48	18:10	7:22	LINE CLEAR AVAIED
1026	8-Nov-21	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI_110	18:05	19:17	1:12	LINE CLEAR AVAIED
1027	8-Nov-21	GULBARGA	110	RAICHUR-SHAHAHPUR 1	GABBUR_110	20:08	20:14	0:06	LINE FAULT
1028	8-Nov-21	GULBARGA	110	RAICHUR-SHAHAHPUR 1&2	GOOGLE_110,GABBUR_110	12:00	12:58	0:58	LINE CLEAR AVAIED
1029	8-Nov-21	GULBARGA	110	RAICHUR-SHAHAHPUR2	GOOGLE_110	6:15	6:20	0:05	LINE FAULT
1030	8-Nov-21	GULBARGA	110	SHAHABAD-CHITAPUR	CHITAPUR_110,KORAWAR TEMPLE_110	14:55(30.07.2021)			LINE OPEN: LINE CLEAR AVAIED
1031	8-Nov-21	GULBARGA	110	SHAHABAD-FARATHABAD	FARTHABAD_110,GULBARGA SOUTH_110	14:50	17:10	2:20	LINE CLEAR AVAIED
1032	8-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY1 (IDLE LINE)	GULBARGA UNIVERSITY_110	12:40 (31.10.2021)			LINE OPEN:LINE FAULT
1033	8-Nov-21	GULBARGA	110	SHAHABAD-GULBARGA UNIVERSITY2	GULBARGA UNIVERSITY_110	09:17(14.08.2021)			LINE OPEN: LINE CLEAR AVAIED
1034	8-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR1	RAICHUR_110	20:14	20:28	0:14	LINE FAULT
1035	8-Nov-21	GULBARGA	110	SHAHAPUR-RAICHUR2	RAICHUR_110	20:14	20:28	0:14	LINE FAULT
1036	8-Nov-21	GULBARGA	110	YAPALDINI-VADAVATTI	YAPALDINI_110	9:35	10:00	0:25	MAIN SUPPLY FAILURE
1037	8-Nov-21	GULBARGA	110	YERAGERA-RAICHUR	YERAGERA_110	9:30	10:00	0:30	MAIN SUPPLY FAILURE
1038	8-Nov-21	GULBARGA	220	HV2	KUDLIGI_220	16:18(12.08.2021)			TRANSFORMER OPEN:TRANSFORMER FAULT
1039	8-Nov-21	GULBARGA	220	HV2	RAICHUR_220	9:25	11:10	1:45	TRANSFORMER FAULT
1040	8-Nov-21	GULBARGA	220	LINGASUGUR-RTPS1	LINGASUGUR_220	18:36	19:27	0:51	LINE FAULT
1041	8-Nov-21	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	22:02(08.11.2021)			LINE OPEN: LINE CLEAR AVAIED
1042	8-Nov-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	1:36	7:45	6:09	LINE CLEAR AVAIED
1043	8-Nov-21	GULBARGA	400	BTPSG-HIRIYUR2	HIRIYUR_400	23:36(08.11.2021)			LINE OPEN: LINE CLEAR AVAIED
1044	8-Nov-21	HASSAN	66	CHANNARA-UDAYAPURA	CHANNARAYAPATNA_66	12:05	14:21	2:16	LINE CLEAR AVAIED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1045	8-Nov-21	HASSAN	66	GORUR-HASSAN	GORUR_66	2:26	2:45	0:19	MAIN SUPPLY FAILURE
1046	8-Nov-21	HASSAN	66	HASSN220-ARKALGD	HASSAN_220	2:26	2:43	0:17	LINE FAULT
1047	8-Nov-21	HASSAN	66	HNPR2-HNPR1	HOLENARASIPURA_220	16:45	16:53	0:08	LINE FAULT
1048	8-Nov-21	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	10:35	10:42	0:07	LINE FAULT
1049	8-Nov-21	HASSAN	66	HV1	HALLYMYSORE_66	10:17(6.11.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1050	8-Nov-21	HASSAN	66	HV1	DODDAKADNUR_66	9:41	13:49	4:08	LINE CLEAR AVAILED
1051	8-Nov-21	HASSAN	66	HV1	DODDAKADNUR_66	14:52	16:32	1:40	LINE CLEAR AVAILED
1052	8-Nov-21	HASSAN	66	HV1	HNPURA_66	16:47	16:53	0:06	MAIN SUPPLY FAILURE
1053	8-Nov-21	HASSAN	66	HV2	HNPURA_66	16:47	16:54	0:07	MAIN SUPPLY FAILURE
1054	8-Nov-21	HASSAN	66	RAMNAT-KATTEPURA_MINIH	RAMNATHPURA_66	10:35	11:25	0:50	MAIN SUPPLY FAILURE
1055	8-Nov-21	HASSAN	66	UDYAP-SATHENAHALLI	UDAYAPURA_66	8:41	8:52	0:11	LINE FAULT
1056	8-Nov-21	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	10:26	15:53	5:27	NFBC ISSUED
1057	8-Nov-21	HASSAN	110	HV1	NANDIKUR_110	3:07	3:35	0:28	TRANSFORMER FAULT
1058	8-Nov-21	HASSAN	110	HV1	BLGUMBA_110	11:00	11:48	0:48	LINE CLEAR AVAILED
1059	8-Nov-21	HASSAN	110	HV2	AJJAMPURA_110	15:53(17.09.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1060	8-Nov-21	HASSAN	110	HV2	BIRUR_110	11:16	12:14	0:58	LINE CLEAR AVAILED
1061	8-Nov-21	HASSAN	110	HV2	JOG_110	19:47	20:45	0:58	LINE CLEAR AVAILED
1062	8-Nov-21	HASSAN	110	HV2	SAGARA_110	11:11	12:15	1:04	LINE CLEAR AVAILED
1063	8-Nov-21	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:57	12:43	1:46	NFBC ISSUED
1064	8-Nov-21	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	12:24	12:34	0:09	LINE FAULT
1065	8-Nov-21	MYSURU	66	FTS-HOOTAGALLI 1	NO STATIONS EFFECTED	9:30:05(30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
1066	8-Nov-21	MYSURU	66	FTS-HOOTAGALLI 2	NO STATIONS EFFECTED	9:30:01 (30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
1067	8-Nov-21	MYSURU	66	HV1	CHUNCHUNKATTE_66	8:15	8:23	0:07	TRANSFORMER FAULT
1068	8-Nov-21	MYSURU	66	HV1	KRPET_66	9:52	17:08	7:16	LINE CLEAR AVAILED
1069	8-Nov-21	MYSURU	66	HV1	MADDUR_66	20:47	21:05	0:18	HAND TRIPPED
1070	8-Nov-21	MYSURU	66	HV2	KRPET_66	9:52	17:08	7:16	LINE CLEAR AVAILED
1071	8-Nov-21	MYSURU	66	HV2	MADDUR_66	21:49	22:01	0:12	HAND TRIPPED
1072	8-Nov-21	MYSURU	66	HV2	THANDYA_66	12:01	12:13	0:11	LINE CLEAR AVAILED
1073	8-Nov-21	MYSURU	66	HV3	KRPET_66	9:52	17:08	7:16	LINE CLEAR AVAILED
1074	8-Nov-21	MYSURU	66	JAKKANAHALLI-NAGAMANGALA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	19:19	19:25	0:06	LINE FAULT
1075	8-Nov-21	MYSURU	66	JAKKANAHALLI-NAGAMANGALA	G MALLIGERE_66 BOGADHI MANDYA_66 GUDDENAHALLI_66 NAGAMANGALA_66	20:24	20:29	0:05	LINE FAULT
1076	8-Nov-21	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	NO STATIONS EFFECTED	11:03:31(30.10.2021)			LINE OPEN: LINE CLEAR AVAILED
1077	8-Nov-21	MYSURU	66	KR PETE 220-SANTHEBACALLI	NO STATIONS EFFECTED	9:03:30 (24.10.2021)			LINE OPEN: LINE CLEAR AVAILED
1078	8-Nov-21	MYSURU	66	KUSHALNAGARA 220-BYLKUPPE	BYLKUPPE_66	16:03	16:07	0:03	LINE FAULT
1079	8-Nov-21	MYSURU	66	MADHUVANAHALLI-HANNUR 2	NO STATIONS EFFECTED	13:26	13:30	0:04	LINE FAULT
1080	8-Nov-21	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	6:42	6:45	0:03	LINE FAULT
1081	8-Nov-21	MYSURU	66	PERIYAPATNA-HANGODU	HANAGODU_66 HUNSUR_66 PONNAMPET_66 VIRAJPET_66	9:52	11:14	1:21	LINE CLEAR AVAILED
1082	8-Nov-21	MYSURU	66	PERIYAPATNA-HUNSUR	KAMPLAPURA_66	6:38	6:45	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	Open_at	Closed_At	Duration	REASON
1083	8-Nov-21	MYSURU	66	RK NAGARA-DATTAGALLI	NO STATIONS EFFECTED	19:42:50 (5.10.2021)			LINE OPEN: LINE CLEAR AVAILED
1084	8-Nov-21	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE_66 GAMANAHALLY_66 TARIPURA_66	5:15	5:25	0:10	LINE FAULT
1085	8-Nov-21	MYSURU	66	TUBINKERE-NAGAMANGALA 2	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 SHIVALLY_66 KESLAGERE_66	23:34	23:47	0:13	LINE FAULT
1086	8-Nov-21	MYSURU	220	HV2	TUBINKERE_220	15:10:00(25.10.2021)			TRANSFORMER OPEN: LINE CLEAR AVAILED
1087	8-Nov-21	TUMKUR	66	ANCHEPALYA 220KV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	11:07	11:41	0:34	LINE CLEAR AVAILED
1088	8-Nov-21	TUMKUR	66	ANCHEPALYA 220KV- KEMPANAHALLI	KEMPANAHALLI_66, AGALKOTE_66	15:24	15:37	0:13	LINE FAULT
1089	8-Nov-21	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	6:50	6:59	0:09	LINE FAULT
1090	8-Nov-21	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	6:03	6:22	0:18	LINE FAULT
1091	8-Nov-21	TUMKUR	66	HONNALLI 220KV- KUNDUR66	KUNDUR_66,MALEBENNUR_66 ,DEVARABELKERE_66	14:04	14:14	0:09	LINE FAULT
1092	8-Nov-21	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	14:01	14:17	0:16	LINE FAULT
1093	8-Nov-21	TUMKUR	66	HONNALLI 220KV- NYAMATHI	CHILLUR_66, NYAMATHI_66, SAVALANGA_66	14:04	14:14	0:10	LINE FAULT
1094	8-Nov-21	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	6:21	6:47	0:26	LINE FAULT
1095	8-Nov-21	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKWADA_66	13:33	13:34	0:01	HAND TRIPPED
1096	8-Nov-21	TUMKUR	66	SIRA- BUKKAPATNA	BUKKAPATNA_66	16:40	16:52	0:11	LINE FAULT
1097	8-Nov-21	TUMKUR	66	SIRA- MADHUGIRI 2	BUKKAPATNA_66, KALLAMBELLA_66	16:40	16:51	0:11	LINE FAULT
1098	8-Nov-21	TUMKUR	66	TR-1	PD KOTE	11:17	11:29	0:11	TRANSFORMER FAULT
1099	8-Nov-21	TUMKUR	66	TR-2	BENNEHALLI_66	2:04	2:10	0:05	TRANSFORMER FAULT
1100	8-Nov-21	TUMKUR	66	TR-2	BENNEHALLI_66	17:40	18:14	0:34	LINE CLEAR AVAILED
1101	8-Nov-21	TUMKUR	110	HONNAVALLI 110- KADUR220(ARASEKERE)	HONNAVALLI_110	15:47	15:58	0:10	HAND TRIPPED
1102	8-Nov-21	TUMKUR	110	TR-1	HONNAVALLI_110	11:23	14:35	3:12	LINE CLEAR AVAILED
1103	8-Nov-21	TUMKUR	110	TR-1	HONNAVALLI_110	15:48	15:58	0:09	HAND TRIPPED
1104	8-Nov-21	TUMKUR	220	JAGALUR 400KV-THALLAKK 220KV	THALLAKK_220	10:53	14:27	3:33	NFBC ISSUED
1105	8-Nov-21	TUMKUR	220	THALLAK 220KV- HIREMALLANAHOLE 2	HIREMALLANAHOLE 2	10:57	14:28	3:30	NFBC ISSUED
1106	8-Nov-21	TUMKUR	400	GUTTUR 400KV- BEERANAHALLI2	BEERANAHALLI2	9:48	17:44	7:56	LINE CLEAR AVAILED
1107	8-Nov-21	TUMKUR	400	GUTTUR 400KV- KAIGA 400KV	GUTUR_400	0:16	8:14	7:58	LOAD CURTAILMENT