

**400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM:02.06.2020 TO 08.06.2020**

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	2-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
2	2-Jun-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
3	2-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
4	2-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
5	2-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
6	2-Jun-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)- GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED
7	2-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
8	2-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
9	2-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
10	2-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
11	2-Jun-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	18:20 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
12	2-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
13	2-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
14	2-Jun-2020	BAGALKOT	110	KUMATA -SIRSI 1	NO STATION EFFECTED KUMATA_110	11:50 (31.05.2020)	21:00 (02.06.2020)	57:10hr	LINE CHARGED
15	2-Jun-2020	BAGALKOT	110	KUMATA -SIRSI 2	NO STATION EFFECTED KUMATA_110	11:52 (31.05.2020)	21:00 (02.06.2020)	57:08hr	LINE CHARGED
16	2-Jun-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	8:37 (31.05.2020)			LOAD CURTAILMENT
17	2-Jun-2020	BAGALKOT	220	ALAMATT 2-BAGALKOT	NO STATION EFFECTED BAGALKOT_220	9:45 (01.06.2020)	11:52 (02.06.2020)	26:07hr	LINE CHARGED
18	2-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	23:06 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
19	2-Jun-2020	BAGALKOT	220	VAJRAMATTI-MAHALINGPUR 1	VAJRAMATTI_220	17:56 (01.06.2020)	11:20 (02.06.2020)	17:26hr	LINE CHARGED
20	2-Jun-2020	BAGALKOT	110	RANEENNUR 220-HONNATTI 1	HONNATTI_110	2:07	12:18	10:11	LINE FAULT
21	2-Jun-2020	BAGALKOT	110	RANEENNUR 220-GUTTAL	GUTTAL_110	2:07	9:00	6:53	LINE FAULT
22	2-Jun-2020	BAGALKOT	220	VAJRAMATTI-MAHALINGPUR 2	VAJRAMATTI_220,KATARKI_110,BILAGI_110,MELLIGERI_110,MANTUR_110,VAJRAMATTI_110,JKCEMENT_110	9:38	11:27	1:49	NFBC ISSUED
23	2-Jun-2020	BAGALKOT	110	VAJRAMATTI220 -BILAGI	BILAGI_110	9:50	12:08	2:18	LINE FAULT
24	2-Jun-2020	BAGALKOT	110	VAJRAMATTI220 -MUDHOL	MUDHOL_110	11:58	12:13	0:15	HAND TRIPPED
25	2-Jun-2020	BAGALKOT	110	110/11KV,HV1	SALAHALLI_110	10:30	12:00	1:30	TRANSFORMER FAULT
26	2-Jun-2020	BAGALKOT	220	ALAMATT 1-BAGALKOT	NO STATION EFFECTED BAGALKOT_220	9:45	11:52	2:07	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
27	2-Jun-2020	BENGALURU	66	HV1	BRINDAVAN	16:26	16:35	0:09	TRANSFORMER FAULT
28	2-Jun-2020	BENGALURU	66	HEJJALA - BIDADI 220	HEJJALA	15:15	15:30	0:15	LINE FAULT
29	2-Jun-2020	BENGALURU	66	HV1	HEJJALA	15:15	15:30	0:15	TRANSFORMER FAULT
30	2-Jun-2020	BENGALURU	66	HEJJALA - BIDADI 220	HEJJALA	17:35	17:45	0:10	LINE FAULT
31	2-Jun-2020	BENGALURU	66	SOMAYAJNAHALLI - TATA SOLAR	TATA SOLAR	6:20	6:28	0:07	LINE FAULT
32	2-Jun-2020	BENGALURU	66	HV1	KYALANUR	10:07	10:15	0:07	TRANSFORMER FAULT
33	2-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
34	2-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
35	2-Jun-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
36	2-Jun-2020	BENGALURU	66	HV1	RR NAGAR	11:11 (1-6-2020)			LINE OPEN, LINE CLEAR AVAILED
37	2-Jun-2020	GULBARGA	400	YTPS-BPS1	YTPS_400	21:16(1.6.2020)	14:50	17:34HRS	LINE CHARGED
38	2-Jun-2020	GULBARGA	400	JSWL-GUTTUR	JSWL_400	3:01(1.6.2020)	16:50	37:49HRS	LINE CHARGED
39	2-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
40	2-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
41	2-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	SHAHABAD_220	10:05(1.6.2020)	11:00	24:55HRS	LINE CHARGED
42	2-Jun-2020	GULBARGA	220	ITTAGI-NEELANGUNDA	NEELANGUNDA_220	18:25(1.6.2020)	14:21	19:56 HRS	LINE CHARGED
43	2-Jun-2020	GULBARGA	220	ITTAGI-LINGAPUR	ITTAGI_220	12:28	12:40	0:12	LINE FAULT
44	2-Jun-2020	GULBARGA	220	LV1,LV2	ITTAGI_220	12:28	12:42	0:14	LINE CLEAR AVAILED
45	2-Jun-2020	GULBARGA	220	RTPS-LINGASUGUR3	LINGASUGUR_220	3:15	4:56	1:41	LINE FAULT
46	2-Jun-2020	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	10:36	19:05	8:29	NFBC ISSUED
47	2-Jun-2020	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	15:08	17:40	2:32	LINE CLEAR AVAILED
48	2-Jun-2020	GULBARGA	220	MALLAT-RTPS	MALLAT_220	3:15	4:56	1:41	LINE FAULT
49	2-Jun-2020	GULBARGA	220	KAPANOOR-HUMNABAD1,2	KAPANOOR_220	10:35	12:33	1:58	LINE FAULT
50	2-Jun-2020	GULBARGA	220	HUMNABAD-HALBARGA1	HALBARGA_220	1:34	7:20	5:46	LINE CLEAR AVAILED
51	2-Jun-2020	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	13:24	13:34	0:10	NFBC ISSUED
52	2-Jun-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	2:00	9:16	7:16	LINE CLEAR AVAILED
53	2-Jun-2020	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	10:36	11:18	0:42	LINE FAULT
54	2-Jun-2020	GULBARGA	220	HUMNABAD-SEDAM2	SEDAM_220	10:36	11:36	1:00	LINE FAULT
55	2-Jun-2020	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	0:53	9:28	8:35	LINE CLEAR AVAILED
56	2-Jun-2020	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	1:55	9:18	7:23	LINE CLEAR AVAILED
57	2-Jun-2020	GULBARGA	220	SEDAM-RTPS1	RTPS_220	10:38	19:07	8:29	LINE FAULT
58	2-Jun-2020	GULBARGA	220	HV1	SEDAM_220	11:00	11:20	0:20	LINE CLEAR AVAILED
59	2-Jun-2020	GULBARGA	220	HV2	SEDAM_220	11:00(02.06.2020)			LINE OPEN, LINE CLEAR AVAILED
60	2-Jun-2020	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	11:05	11:11	0:06	LINE FAULT
61	2-Jun-2020	GULBARGA	220	SEDAM-SHAHAPUR	SHAHAPUR_220	13:20	17:34	4:14	LINE CLEAR AVAILED
62	2-Jun-2020	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	13:50	19:07	5:17	LINE CLEAR AVAILED
63	2-Jun-2020	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	15:08	17:38	2:30	LINE CLEAR AVAILED
64	2-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	2:55	4:34	1:39	LINE FAULT
65	2-Jun-2020	GULBARGA	110	SIDHANOOR-NIRLOOTI	SINDHANOOR_220	0:20	0:40	0:20	LINE FAULT
66	2-Jun-2020	GULBARGA	110	SIDHANOOR220-SINDHANOOR	SINDHANOOR_110	3:25	3:35	0:10	LINE FAULT
67	2-Jun-2020	GULBARGA	110	KAPANOOR-ALAND	ALAND_110	1:30	1:40	0:10	LINE FAULT
68	2-Jun-2020	GULBARGA	110	SIDHANOOR-SUZLON1	SIDHANOOR_220	1:50	2:05	0:15	LINE FAULT
69	2-Jun-2020	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	0:09	0:19	0:10	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
70	2-Jun-2020	GULBARGA	110	MALLAT-ALKOD	ALKOD_110	10:00	10:20	0:20	LINE FAULT
71	2-Jun-2020	GULBARGA	110	MALLAT-BYAGWAT	BYAGWAT_110	0:08	0:18	0:10	LINE FAULT
72	2-Jun-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	0:30	0:38	0:08	LINE FAULT
73	2-Jun-2020	GULBARGA	110	SHAHAPUR-YADGIR	YADGIR_110	3:00	3:06	0:06	LINE FAULT
74	2-Jun-2020	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110	2:38	2:48	0:10	LINE FAULT
75	2-Jun-2020	GULBARGA	110	SHAHAPUR-KBJNL	KBJNL_110	4:55	5:03	0:08	LINE FAULT
76	2-Jun-2020	GULBARGA	110	HV1,HV2	HANUMNAL_110	23:50(1.6.2020)	0:15(2.6.2020)	0:25 hrs	TRANSFRMER CHARGED
77	2-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	2:55	4:35	1:40	MAIN SUPPLY FAILURE
78	2-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110,NIRNA_110	10:35	11:35	1:00	MAIN SUPPLY FAILURE
79	2-Jun-2020	GULBARGA	110	CHITAGUPPA-ACMESOLAR IPP	CHITAGUPPA_110	10:35	12:14	1:39	LINE CLEAR AVAILED
80	2-Jun-2020	GULBARGA	110	KOLHAR-NSSK	JANAWADA_110,NSSK SUGAR FACTORY_IPP	6:41	6:48	0:07	LINE FAULT
81	2-Jun-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	12:10	12:16	0:06	LINE FAULT
82	2-Jun-2020	GULBARGA	110	KOLHAR-HUMNABAD	KOLHAR_110,JANAWADA_110,NSSK SUGAR FACTORY_IPP	10:35	11:20	0:45	MAIN SUPPLY FAILURE
83	2-Jun-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNSAGI_110,ASKI_110, UGAR SUGAR_IPP	5:33	5:38	0:05	LINE FAULT
84	2-Jun-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNSAGI_110,ASKI_110, UGAR SUGAR_IPP	2:40	2:50	0:10	LINE FAULT
85	2-Jun-2020	GULBARGA	110	KEMBHAVI-SHAHAPUR	KEMBHAVI_110,HUNSAGI_110,ASKI_110, UGAR SUGAR_IPP	5:03	5:14	0:11	LINE FAULT
86	2-Jun-2020	GULBARGA	110	KEMBHAVI-HUNSAGI	HUNSAGI_110	1:00	1:10	0:10	LINE FAULT
87	2-Jun-2020	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI	0:09	0:34	0:25	LINE FAULT
88	2-Jun-2020	GULBARGA	110	HV1	MASKI_110	12:46	13:02	0:16	LINE CLEAR AVAILED
89	2-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	3:16	3:25	0:09	LINE FAULT
90	2-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	2:30	2:35	0:05	MAIN SUPPLY FAILURE
91	2-Jun-2020	GULBARGA	110	RAJESHWAR-WARDHA SOLAR	RAJESHWAR_110	11:25	12:03	0:38	MAIN SUPPLY FAILURE
92	2-Jun-2020	GULBARGA	110	HV2	MANVI_110	15:21	15:34	0:13	TRANSFORMER FAULT
93	2-Jun-2020	GULBARGA	110	HV2	MANVI_110	15:51	16:03	0:12	TRANSFORMER FAULT
94	2-Jun-2020	GULBARGA	110	HV2	MANVI_110	16:57	17:14	0:19	TRANSFORMER FAULT
95	2-Jun-2020	GULBARGA	110	KAPNOOR-HUMNABAD2	HUMNABAD_220	23:38	23:45	0:07	LINE FAULT
96	2-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	20:04	20:16	0:12	LINE FAULT
97	2-Jun-2020	GULBARGA	110	LV1	HUMNABAD_220	10:36	11:42	1:06	TRANSFORMER FAULT
98	2-Jun-2020	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_IPP	10:36	11:27	0:51	LINE FAULT
99	2-Jun-2020	GULBARGA	110	LV1	SHAHAPUR_220	23:08	23:28	0:20	TRANSFORMER FAULT
100	2-Jun-2020	GULBARGA	110	HV2	TAMBRAHALLI_110	6:15	7:05	0:50	LINE CLEAR AVAILED
101	2-Jun-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	0:38	3:45	3:07	LINE FAULT
102	2-Jun-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	3:46	9:00	5:14	LINE FAULT
103	2-Jun-2020	GULBARGA	110	SEDAM-MALKHEDRAILWAYTRACK	MALKHEDRAILWAYTRACK_110	0:07	0:45	0:38	LINE FAULT
104	2-Jun-2020	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	1:30	2:20	0:50	LINE FAULT
105	2-Jun-2020	GULBARGA	110	SEDAM-VCATSAGARCEMENTS	VCATSAGARCEMENTS_IPP	4:35	5:00	0:25	LINE FAULT
106	2-Jun-2020	GULBARGA	110	LV1	SEDAM_220	10:38	11:26	0:48	TRANSFORMER FAULT
107	2-Jun-2020	GULBARGA	110	SEDAM-CHITAPUR	CHITAPUR_110	11:15	11:31	0:16	LINE CLEAR AVAILED
108	2-Jun-2020	GULBARGA	110	SEDAM-GURUMITKAL	GURUMITKAL_110	11:15	11:39	0:24	LINE CLEAR AVAILED
109	2-Jun-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110, MUDDAPUR_110	20:03	20:12	0:09	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
110	2-Jun-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SIDHANOOR_220	20:42	21:05	0:23	LINE FAULT
111	2-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110, SREERAMNAGAR_110, GANGAVATHI_110, VENKATGIRI_110	21:56	22:09	0:13	LINE FAULT
112	2-Jun-2020	GULBARGA	110	SINDHANOOR-SUZLON1	SIDHANOOR_220	23:45	23:56	0:11	LINE FAULT
113	2-Jun-2020	GULBARGA	66	ITTAGI-KUDLIGI1&2	KUDLIGI_66,KOGALI_66,HANASI_66,CJHALI_66,GUDEKOTE_66,CHORNOOR_66,HOSAHALI_66,BANVEKAL_66	11:20	11:26	0:06	LINE FAULT
114	2-Jun-2020	GULBARGA	66	ITTAGI-CLNMAX1	ITTAGI_220	13:40	13:45	0:05	LINE FAULT
115	2-Jun-2020	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	7:45	10:45	3:00	LINE CLEAR AVAILED
116	2-Jun-2020	GULBARGA	66	HV2	HANASI_66	7:45	10:50	3:05	TRANSFORMER FAULT
117	2-Jun-2020	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	17:25	17:30	0:05	TRANSFORMER FAULT
118	2-Jun-2020	GULBARGA	66	HBHALLI-ITTAGGI	HAGARIBOMMANAHALLI_66	12:30	12:45	0:15	MAIN SUPPLY FAILURE
119	2-Jun-2020	GULBARGA	66	HBHALLI-ITTAGGI	HAGARIBOMMANAHALLI_66	16:08	16:40	0:32	MAIN SUPPLY FAILURE
120	2-Jun-2020	GULBARGA	66	HV1	HAGARIBOMMANAHALLI_66	18:00	18:05	0:05	TRANSFORMER FAULT
121	2-Jun-2020	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	3:49(31.05.2020)	16:05	61:01hrs	LINE CHARGED
122	2-Jun-2020	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	3:50 (31.05.2020)	12:48	56:57hrs	LINE CHARGED
123	2-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
124	2-Jun-2020	HASSAN	110	JOG-AMBTR2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
125	2-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
126	2-Jun-2020	HASSAN	110	HV1	STATION NOT AFFECTED	23:02 (01.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
127	2-Jun-2020	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	22:34 (2.06.2020)			LINE OPEN, LINE CLEAR AVAILED
128	2-Jun-2020	HASSAN	220	MRSSHM-STRP1	MRSMSG_220	12:48	15:33	2:45	LINE FAULT
129	2-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:35	17:50	0:15	HAND TRIPPED
130	2-Jun-2020	HASSAN	220	KAVOOR-BAJPE2	KAVOOR_220	2:28	8:09	5:41	LINE CLEAR AVAILED
131	2-Jun-2020	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	2:25	8:04	5:39	LINE CLEAR AVAILED
132	2-Jun-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	8:54	15:34	6:40	LINE CLEAR AVAILED
133	2-Jun-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	2:28	8:09	5:41	LINE CLEAR AVAILED
134	2-Jun-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	2:26	8:04	5:38	LINE CLEAR AVAILED
135	2-Jun-2020	HASSAN	110	MSEZ-KAVOOR	MSEZ_220	6:13	9:44	3:31	LINE CLEAR AVAILED
136	2-Jun-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	8:54	15:39	6:45	LINE CLEAR AVAILED
137	2-Jun-2020	HASSAN	110	HV1	ANANDAPURA_110	12:35	16:44	4:09	LINE CLEAR AVAILED
138	2-Jun-2020	HASSAN	110	HV2	ANANDAPURA_110	12:35	16:44	4:09	LINE CLEAR AVAILED
139	2-Jun-2020	HASSAN	110	HV1	ARASIKERE_110	13:23	14:10	0:47	TRANSFORMER FAULT
140	2-Jun-2020	HASSAN	110	HV2	HOSANGADI_110	9:30	17:29	7:59	LINE CLEAR AVAILED
141	2-Jun-2020	HASSAN	110	HV2	NANDIKUR_110	12:22	13:09	0:47	LINE CLEAR AVAILED
142	2-Jun-2020	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTYHALLI_66	10:03	15:53	5:50	LINE CLEAR AVAILED
143	2-Jun-2020	HASSAN	66	HV1	HASSAN_66	12:12	12:25	0:13	LINE CLEAR AVAILED
144	2-Jun-2020	HASSAN	66	CHANNAR-SHETTHALLY	CHANNARAYAPATNA_66	5:37	5:55	0:18	LINE FAULT
145	2-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
146	2-Jun-2020	MYSURU	66	HV2	AKKIHEBBAL_66	12:16	12:29	0:12	TRANSFORMER FAULT
147	2-Jun-2020	MYSURU	66	HV1	ARAKERE_66	11:59	13:20	1:21	LINE CLEAR AVAILED
148	2-Jun-2020	MYSURU	66	HAMPAPURA-BASARALU	BASARALU_66 BESAGARAHALLI_66 KOPPA_66	6:36	6:42	0:05	LINE FAULT
149	2-Jun-2020	MYSURU	66	HOOTAGALLI-FTS1	NO STATIONS EFFECTED	9:22	13:32	4:09	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
150	2-Jun-2020	MYSURU	66	HOOTAGALLI-FTS2	NO STATIONS EFFECTED	9:22	13:32	4:10	LINE CLEAR AVAILED
151	2-Jun-2020	MYSURU	66	HV1	K_HONNALGERE_66	18:47	18:53	0:06	MAIN SUPPLY FAILURE
152	2-Jun-2020	MYSURU	66	HV2	K_HONNALGERE_66	18:47	18:53	0:06	MAIN SUPPLY FAILURE
153	2-Jun-2020	MYSURU	66	HV3	KUSHALANAGARA_66	6:00	6:18	0:18	TRANSFORMER FAULT
154	2-Jun-2020	MYSURU	66	NANJANGUDU-NESTLE	NO STATIONS EFFECTED	5:38	6:00	0:22	LINE FAULT
155	2-Jun-2020	MYSURU	66	HV1	PANDAVAPURA_66	16:20	18:01	1:41	LINE CLEAR AVAILED
156	2-Jun-2020	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	8:15	8:18	0:02	LINE FAULT
157	2-Jun-2020	MYSURU	66	HV1	TARIPURA_66	9:11	11:05	1:54	LINE CLEAR AVAILED
158	2-Jun-2020	MYSURU	66	HV1	TARIPURA_66	11:53	13:41	1:48	LINE CLEAR AVAILED
159	2-Jun-2020	MYSURU	66	TARIPURA-MHS	NO STATIONS EFFECTED	9:12	11:06	1:53	LINE CLEAR AVAILED
160	2-Jun-2020	MYSURU	66	CR NAGARA-BADANAKUPPE-2	NO STATIONS EFFECTED	12:15	12:38	0:23	HAND TRIPPED
161	2-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
162	2-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	15:20(2.6.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
163	2-Jun-2020	TUMKUR	220	NEELAGUNDA220kv- ITTAGI 220kv	NEELAGUNDA_220	18:22:40(01.06.2020)	14:20	20:42hrs	LINE CHARGED
164	2-Jun-2020	TUMKUR	66	BEVINAHALLI- AFTL SOLAR	AFTLSOLAR_IPP_66	15:54	16:36	0:42	LINE CLEAR AVAILED
165	2-Jun-2020	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	15:39	18:40	3:01	LINE CLEAR AVAILED
166	2-Jun-2020	TUMKUR	66	TR-2	HALUVAGALU_66	15:11	15:23	0:11	TRANSFORMER FAULT
167	2-Jun-2020	TUMKUR	66	TR-2	HALUVAGALU_66	16:11	16:15	0:03	TRANSFORMER FAULT
168	2-Jun-2020	TUMKUR	66	TR-3	HARIYABBE_66	14:28	14:33	0:05	TRANSFORMER FAULT
169	2-Jun-2020	TUMKUR	66	H D PURA- CHITRADURGA220	HDPURA_66	19:57	20:01	0:04	LINE FAULT
170	2-Jun-2020	TUMKUR	66	I D HALLI- MEDIGESHI	IDHALLY_66	12:22	12:30	0:07	HAND TRIPPED
171	2-Jun-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	17:25	17:27	0:02	LINE FAULT
172	2-Jun-2020	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	10:08	10:11	0:02	HAND TRIPPED
173	2-Jun-2020	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURG A_66,PALLAGATTE_66, SOKKE_66	4:20	4:32	0:12	LINE FAULT
174	2-Jun-2020	TUMKUR	66	TR-2( LV SIDE)	THALLAKK_220	7:45	7:47	0:02	HAND TRIPPED
175	2-Jun-2020	TUMKUR	66	THALLAK 220kv- SEI DIAMOND SOLAR_IPP_66	SEL DIAMOND SOLAR_IPP_66	13:31	16:32	3:00	LINE CLEAR AVAILED
176	2-Jun-2020	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	5:44	6:18	0:34	LINE FAULT
177	2-Jun-2020	TUMKUR	66	TR-1	YNHOSKOTE_66	7:44	7:59	0:14	TRANSFORMER FAULT
178	3-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
179	3-Jun-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
180	3-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
181	3-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
182	3-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
183	3-Jun-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)-GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
184	3-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
185	3-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
186	3-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
187	3-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
188	3-Jun-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	18:20 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
189	3-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
190	3-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
191	3-Jun-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEENNUR	NO STATION EFFECTED RANEENNUR_220	8:37 (31.05.2020)			LOAD CURTAILMENT
192	3-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	23:06 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
193	3-Jun-2020	BAGALKOT	220	BAGALKOT -GADAG 1	BAGALKOT_220	17:45(3.6.2020)			LINE OPEN, LINE CLEAR AVAILED
194	3-Jun-2020	BAGALKOT	110	110/11KV,HV2	ACHANUR_110	14:02	14:07	0:05	TRANSFORMER FAULT
195	3-Jun-2020	BAGALKOT	220	220/110KV,HV1	SIRSI_220	8:40	8:45	0:05	TRANSFORMER FAULT
196	3-Jun-2020	BAGALKOT	110	SIRSI-SIRSI1	SIRSI_2110	8:41	8:46	0:05	LINE FAULT
197	3-Jun-2020	BAGALKOT	220	220/110KV,HV1	SIRSI_220	13:10	13:52	0:42	HAND TRIPPED
198	3-Jun-2020	BENGALURU	220	BIDADI 220 - SOMANAHALLI 220	NO STATION AFFECTED	7:33	8:20	0:47	LINE FAULT
199	3-Jun-2020	BENGALURU	220	BIDADI 220 - SOMANAHALLI 220	NO STATION AFFECTED	8:20	8:29	0:09	LINE FAULT
200	3-Jun-2020	BENGALURU	66	BTM 4TH PHASE - KHODAYS 220	BTM 4TH PHASE	15:37	15:50	0:13	LINE FAULT
201	3-Jun-2020	BENGALURU	66	HV2	CHATRA	12:06	12:54	0:48	LINE CLEAR AVAILED
202	3-Jun-2020	BENGALURU	66	ELECTRONIC CITY P2 S1 - NAGANATHPURA 220	ELECTRONIC CITY P2 S1	17:28	17:34	0:06	LINE CLEAR AVAILED
203	3-Jun-2020	BENGALURU	66	GOLF LINK - HAL 220	GOLF LINK	10:15	10:25	0:10	LOAD CHANGE OVER
204	3-Jun-2020	BENGALURU	66	GOLF LINK - HSR LAYOUT 220	GOLF LINK	19:25	19:30	0:05	LOAD CHANGE OVER
205	3-Jun-2020	BENGALURU	66	HEJJALA - BIDADI 220	HEJJALA	16:38	16:49	0:11	LINE FAULT
206	3-Jun-2020	BENGALURU	66	HV1	HEJJALA	16:38	16:49	0:11	TRANSFORMER FAULT
207	3-Jun-2020	BENGALURU	66	HV1	KUMBALAGODU	11:39	11:54	0:15	TRANSFORMER FAULT
208	3-Jun-2020	BENGALURU	66	POTTERY ROAD - ITI 220	POTTERY ROAD	12:30	12:55	0:25	MAIN SUPPLY FAILURE
209	3-Jun-2020	BENGALURU	66	POTTERY ROAD - HEBBALA 220	POTTERY ROAD	13:07	13:12	0:05	LOAD CHANGE OVER
210	3-Jun-2020	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	12:25	13:13	0:48	LINE FAULT
211	3-Jun-2020	BENGALURU	66	HV2	R R NAGAR	10:51	14:10	3:19	LINE CLEAR AVAILED
212	3-Jun-2020	BENGALURU	66	HV2	REMCO	10:11	10:14	0:03	LOAD CHANGE OVER
213	3-Jun-2020	BENGALURU	66	HV2	REMCO	18:34	18:39	0:05	LOAD CHANGE OVER
214	3-Jun-2020	BENGALURU	66	HV1	VIJAYANAGARA	9:48	9:59	0:11	LOAD CHANGE OVER
215	3-Jun-2020	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	12:08	13:00	0:52	LINE CLEAR AVAILED
216	3-Jun-2020	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	15:57	16:04	0:06	LINE FAULT
217	3-Jun-2020	BENGALURU	66	CB PURA I/A - DB PURA 2	CB PURA I/A, CB PURA URBAN, NALLIMARDHANAHALLI	12:52	13:48	0:56	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
218	3-Jun-2020	BENGALURU	66	CB PURA I/A - DB PURA 1	CB PURA I/A, CB PURA URBAN, NALLIMARDHANAHALLI	12:52	13:48	0:56	LINE CLEAR AVAILED
219	3-Jun-2020	BENGALURU	66	HV2	SOMAYAJJANAHALLI	11:22	11:44	0:22	TRANSFORMER FAULT
220	3-Jun-2020	BENGALURU	220	NELAMANGALA 400 - DB PURA 220	NO STATIONS AFFECTED	11:55	14:51	2:55	LINE CLEAR AVAILED
221	3-Jun-2020	BENGALURU	220	BEGUR 220 - DB PURA 220	NO STATIONS AFFECTED	14:25	14:57	0:32	LOAD CURTAILMENT
222	3-Jun-2020	BENGALURU	66	ANEKAL - ATTIBELE	ATTIBELE	12:14	12:25	0:10	LOAD CHANGE OVER
223	3-Jun-2020	BENGALURU	66	ATTIBELE - SARIJAPURA 220	ATTIBELE	14:10	14:20	0:10	LOAD CHANGE OVER
224	3-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
225	3-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
226	3-Jun-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
227	3-Jun-2020	BENGALURU	66	HV1	RR NAGAR	11:11 (1-6-2020)			LINE OPEN, LINE CLEAR AVAILED
228	3-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
229	3-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
230	3-Jun-2020	GULBARGA	220	HV2	SEDAM_220	11:00(02.06.2020)	8:28	21:28HRS	TRANSFRMER CHARGED
231	3-Jun-2020	GULBARGA	220	HV1,LV1	HALBARGA_220	0:04	0:15	0:11	TRANSFORMER FAULT
232	3-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	10:27	10:36	0:09	LINE FAULT
233	3-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	11:43	11:49	0:06	LINE FAULT
234	3-Jun-2020	GULBARGA	110	HUMNABAD-SANTHAPUR	SANTHAPUR_110	0:10	0:17	0:07	LINE FAULT
235	3-Jun-2020	GULBARGA	110	HUMNABAD-SANTHAPUR	SANTHAPUR_110	5:44	5:52	0:08	LINE FAULT
236	3-Jun-2020	GULBARGA	110	HV2	CHITAGUPPA_110	7:08	7:48	0:40	LINE CLEAR AVAILED
237	3-Jun-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	2:40	2:50	0:10	LINE FAULT
238	3-Jun-2020	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	17:03	18:02	0:59	MAIN SUPPLY FAILURE
239	3-Jun-2020	GULBARGA	110	SEDAM-MALKHEDRAILWAYTRACK	MALKHEDRAILWAYTRACK_110	20:37	20:40	0:03	LINE CLEAR AVAILED
240	3-Jun-2020	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	4:55	5:10	0:15	LINE FAULT
241	3-Jun-2020	GULBARGA	110	RAICHUR-APMC2	APMC_110,CHIKSUGUR_110,SHAKTINAGAR_110,SURANA_IPP	7:43	15:30	7:47	LINE CLEAR AVAILED
242	3-Jun-2020	GULBARGA	110	KOLHAR-JANAWADA	JANAWADA_110,NSSK SUGAR FACTORY_IPP	0:05	0:15	0:10	LINE FAULT
243	3-Jun-2020	GULBARGA	110	HV1	KOLHAR_110	7:50	7:55	0:05	TRANSFORMER FAULT
244	3-Jun-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	0:30	0:35	0:05	LINE FAULT
245	3-Jun-2020	GULBARGA	110	SINDHANOOR-SUZLON2	SINDHANOOR_220	2:40	2:50	0:10	LINE FAULT
246	3-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_ WATERWORKS	3:15	3:25	0:10	LINE FAULT
247	3-Jun-2020	GULBARGA	110	SINDHANOOR-SINDHANOOR1	MASKI_110,MUDDAPUR_110	2:38	3:48	1:10	LINE FAULT
248	3-Jun-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	17:20	17:30	0:10	LINE FAULT
249	3-Jun-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	17:40	17:50	0:10	LINE FAULT
250	3-Jun-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	18:40	19:10	0:30	LINE FAULT
251	3-Jun-2020	GULBARGA	110	SINDHANOOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110,TEKKE LKOTE_110,NSLSUGAR_IPP	22:54	23:04	0:10	LINE FAULT
252	3-Jun-2020	GULBARGA	66	HV2	TAMBRAHALLI_66	13:00	13:52	0:52	TRANSFORMER FAULT
253	3-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
254	3-Jun-2020	HASSAN	110	JOG-AMBT2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
255	3-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
256	3-Jun-2020	HASSAN	110	HV1	STATION NOT AFFECTED	23:02 (01.06.2020)	18:53	44:51hrs	TRANSFRMER CHARGED
257	3-Jun-2020	HASSAN	220	MRSSHM-STRP1	MRSMG_220	22:34 (2.06.2020)	10:55	12:21hrs	LINE CHARGED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
258	3-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	22:52(03.06.2020)			LINE OPEN, LINE CLEAR AVAILED
259	3-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:52(03.06.2020)			LINE OPEN, LINE CLEAR AVAILED
260	3-Jun-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	9:03	11:08	2:05	LINE CLEAR AVAILED
261	3-Jun-2020	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	11:54	13:04	1:10	LINE CLEAR AVAILED
262	3-Jun-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	9:03	11:08	2:05	LINE CLEAR AVAILED
263	3-Jun-2020	HASSAN	220	VARAH1-SHIMOGA2	varahi_gen	11:54	13:04	1:10	LINE CLEAR AVAILED
264	3-Jun-2020	HASSAN	110	HV1	ARASIKERE_110	6:19	6:30	0:11	HAND TRIPPED
265	3-Jun-2020	HASSAN	110	HV1	ARASIKERE_220	11:30	13:15	1:45	LINE CLEAR AVAILED
266	3-Jun-2020	HASSAN	110	GAJNUR-IPP IC LINE	GAJANUR_110	10:06	17:22	7:16	LINE CLEAR AVAILED
267	3-Jun-2020	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	10:21	10:28	0:07	HAND TRIPPED
268	3-Jun-2020	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	10:30	10:37	0:07	HAND TRIPPED
269	3-Jun-2020	HASSAN	110	KAVOOR-Kulashkhara1	KAVOOR_220	10:38	10:41	0:03	HAND TRIPPED
270	3-Jun-2020	HASSAN	66	HV1	BAGUR_66	10:01	15:05	5:04	LINE CLEAR AVAILED
271	3-Jun-2020	HASSAN	66	HV2	BAGUR_66	10:01	15:03	5:02	LINE CLEAR AVAILED
272	3-Jun-2020	HASSAN	66	KANDLI-SAKLESHPUR	KANDLI_66	12:35	15:08	2:33	LINE CLEAR AVAILED
273	3-Jun-2020	HASSAN	66	HV1	MAGGE_66	12:41	15:13	2:32	MAIN SUPPLY FAILURE
274	3-Jun-2020	HASSAN	66	HV2	MAGGE_66	12:41	15:13	2:32	MAIN SUPPLY FAILURE
275	3-Jun-2020	HASSAN	66	HV2	RAMESHWARNAGARA_66	17:55	18:15	0:20	LINE CLEAR AVAILED
276	3-Jun-2020	HASSAN	66	SAKALE-HASSAN	SAKLESH PURA_66	12:40	15:10	2:30	NFBC ISSUED
277	3-Jun-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	13:15	13:26	0:11	LINE FAULT
278	3-Jun-2020	HASSAN	66	HV2	KIADB_66	16:35	18:32	1:57	LINE CLEAR AVAILED
279	3-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
280	3-Jun-2020	MYSURU	66	HV1	FTS_66	2:54	4:31	1:37	LINE CLEAR AVAILED
281	3-Jun-2020	MYSURU	66	HV2	HULLAHALLI_66	12:04	12:43	0:38	LINE CLEAR AVAILED
282	3-Jun-2020	MYSURU	66	HV1	PANDAVAPURA_66	10:16	14:56	4:40	LINE CLEAR AVAILED
283	3-Jun-2020	MYSURU	66	HV1	PANDAVAPURA_66	15:35	18:06	2:31	LINE CLEAR AVAILED
284	3-Jun-2020	MYSURU	66	HV2	PANDAVAPURA_66	9:04	9:58	0:53	LINE CLEAR AVAILED
285	3-Jun-2020	MYSURU	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 VADERALLI_66	19:07	19:15	0:07	LINE FAULT
286	3-Jun-2020	MYSURU	66	VAJMANGALA-KADAKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:45	18:54	0:09	LINE FAULT
287	3-Jun-2020	MYSURU	66	HV1	VIJAYANAGRAMYS_66	14:25	14:27	0:02	TRANSFORMER FAULT
288	3-Jun-2020	MYSURU	66	HV2	VIJAYANAGRAMYS_66	14:27	14:28	0:01	TRANSFORMER FAULT
289	3-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
290	3-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	15:20(02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
291	3-Jun-2020	TUMKUR	220	TR-2(HV SIDE)	ANCHEPALYA_220	12:08	12:32	0:24	LINE CLEAR AVAILED
292	3-Jun-2020	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	12:36	18:16	5:40	LINE CLEAR AVAILED
293	3-Jun-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	11:54	11:57	0:03	HAND TRIPPED
294	3-Jun-2020	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	16:45	16:48	0:03	HAND TRIPPED
295	3-Jun-2020	TUMKUR	66	TR-2(LV SIDE)	ANCHEPALYA_220	12:08	12:33	0:25	LINE CLEAR AVAILED
296	3-Jun-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	12:06	12:31	0:24	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
297	3-Jun-2020	TUMKUR	66	ANTHRASANAHALI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	18:23	18:26	0:03	LINE CLEAR AVAILED
298	3-Jun-2020	TUMKUR	66	TR-1	ANTHRASANAHALI_220	15:21	16:50	1:28	LINE CLEAR AVAILED
299	3-Jun-2020	TUMKUR	66	ANTHRASANAHALI 220kv- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	11:12	11:45	0:32	LINE CLEAR AVAILED
300	3-Jun-2020	TUMKUR	66	ANTHRASANAHALI 220KV- KORA	KORA_66, THOVINAKERE_66, BRAHMASANDRA_66, KALLAMBELLA_66	11:51	12:21	0:30	LINE CLEAR AVAILED
301	3-Jun-2020	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALI_220	12:36	18:17	5:41	LINE CLEAR AVAILED
302	3-Jun-2020	TUMKUR	66	ANTHRASANAHALI 220KV- MELEKOTE	DODDASARANGI_66,MELKOTE_66, BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	13:11	13:58	0:46	LINE CLEAR AVAILED
303	3-Jun-2020	TUMKUR	66	ANTHRASANAHALI 220KV- TUMKUR	TUMKUR_66	13:41	14:05	0:24	LINE CLEAR AVAILED
304	3-Jun-2020	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	13:02	13:54	0:52	HAND TRIPPED
305	3-Jun-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	13:02	13:54	0:52	LINE CLEAR AVAILED
306	3-Jun-2020	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	15:36	15:48	0:11	LINE CLEAR AVAILED
307	3-Jun-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	17:28	17:37	0:08	TRANSFORMER FAULT
308	3-Jun-2020	TUMKUR	66	KATTIGE- BEDRUGADDE	KATTIGE_66	18:36	19:35	0:59	LINE CLEAR AVAILED
309	3-Jun-2020	TUMKUR	66	TR-1	KATTIGE_66	18:36	19:38	1:01	LINE CLEAR AVAILED
310	3-Jun-2020	TUMKUR	66	KATTIGE- RENEW WIND IPP	RENEW WIND ENERGY_IPP_66	18:36	19:56	1:19	LINE CLEAR AVAILED
311	3-Jun-2020	TUMKUR	66	PAVAGADA-SHYLAPURA	SHYLAPURA_66,YNHOSKOTE_66,LINGDHALLI_66,MANGALWADA_66	13:22	14:03	0:40	LINE FAULT
312	3-Jun-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	8:03	17:52	9:49	LINE CLEAR AVAILED
313	3-Jun-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	13:22	14:05	0:42	MAIN SUPPLY FAILURE
314	3-Jun-2020	TUMKUR	66	TR-2	SANIKERE_66	8:00	12:56	4:55	LINE CLEAR AVAILED
315	3-Jun-2020	TUMKUR	66	THALLAK 220kv- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	14:50	15:57	1:06	LINE FAULT
316	3-Jun-2020	TUMKUR	66	TR-2(LV SIDE)	THALLAKK_220	1:46	8:10	6:23	LINE CLEAR AVAILED
317	3-Jun-2020	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	11:45	11:58	0:12	HAND TRIPPED
318	4-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
319	4-Jun-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
320	4-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
321	4-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
322	4-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)			LINE OPEN, LINE CLEAR AVAILED
323	4-Jun-2020	BAGALKOT	110	KUSTAGI(HANUMASAGAR)-GAJENDRAGAD	NO STATION EFFECTED GAJENDRAGAD_110	8:14 (24.05.2020)	18:13 (04.06.2020)	273:59hrs	LINE CHARGED
324	4-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
325	4-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
326	4-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
327	4-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
328	4-Jun-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	18:20 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
329	4-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
330	4-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
331	4-Jun-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	8:37 (31.05.2020)			LOAD CURTAILMENT
332	4-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	23:06 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
333	4-Jun-2020	BAGALKOT	220	BAGALKOT -GADAG 1	NO STATION EFFECTED BAGALKOT_220	17:45 (03.06.2020)	17:57 (04.06.2020)	24:12hrs	LINE CHARGED
334	4-Jun-2020	BAGALKOT	110	110/33KV,HV2	STATION NOT AFFECTED .BELGAUM_110	13:47 (02.06.2020)	16:01 (04.06.2020)	50:14hrs	TRANSFRMER CHARGED
335	4-Jun-2020	BAGALKOT	110	NARENDRA 220-UAS DHARWAD 1	STATION NOT AFFECTED UAS DHARWAD_110	22:54 (03.06.2020)	15:25 (04.06.2020)	20:24hrs	LINE CHARGED
336	4-Jun-2020	BAGALKOT	110	220/110,LV2	STATION NOT AFFECTED , MK HUBLI _220	23:05 (03.06.2020)	10:41 (04.06.2020)	23:02hrs	LINE CHARGED
337	4-Jun-2020	BAGALKOT	110	110/33KV,HV4	ANKALI_10	9:45	10:50	1:05	TRANSFORMER FAULT
338	4-Jun-2020	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	16:53	17:15	0:22	TRANSFORMER FAULT
339	4-Jun-2020	BAGALKOT	110	110/11KV,HV2	BANAHATTI_110	10:39	13:58	3:19	LINE CLEAR AVAILED
340	4-Jun-2020	BAGALKOT	220	BAGALKOT-GADAG	BAGALKOT_220	11:24	17:58	6:34	LINE CLEAR AVAILED
341	4-Jun-2020	BAGALKOT	110	CHIKKODI-WIND MILL	CHIKKODI_110	10:46	12:36	1:50	LINE CLEAR AVAILED
342	4-Jun-2020	BAGALKOT	110	CHIKKODI220-CHIKKODI110	CHIKKDODI_110	11:43	12:20	0:37	LINE CLEAR AVAILED
343	4-Jun-2020	BAGALKOT	110	110/33KV,HV3&4	GADAG_110& 33KVTDPL1&2,MALSMUDRA,NAGAVI,KAP PTGUDD,PIONEER,HULAKOTI&LAKKUNDI	10:06	18:34	8:28	LINE CLEAR AVAILED
344	4-Jun-2020	BAGALKOT	110	HIDIKAL-ITANAL	ITANAL_110	14:18	14:39	0:21	LINE CLEAR AVAILED
345	4-Jun-2020	BAGALKOT	110	ITANAL-BPCL	ITANAL_110	13:50	14:44	0:54	LINE CLEAR AVAILED
346	4-Jun-2020	BAGALKOT	110	110/11KV,HV 1	KHANAPUR_110	10:57	11:21	0:24	LINE CLEAR AVAILED
347	4-Jun-2020	BAGALKOT	110	110/33KV,HV2	SAVANR_110,HULAGUR_33,HESARUR_33, GOUDAGERI_33	16:04	18:15	2:11	LINE CLEAR AVAILED
348	4-Jun-2020	BAGALKOT	110	110/33KV,HV1	SAVANUR_110,HATTIMATTUR_33,BANKA PUR_33	11:55	18:05	6:10	LINE CLEAR AVAILED
349	4-Jun-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110,SHIGGON_110	16:15	16:55	0:40	HAND TRIPPED
350	4-Jun-2020	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	11:53	12:12	0:19	HAND TRIPPED
351	4-Jun-2020	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)_110	13:08	13:34	0:26	HAND TRIPPED
352	4-Jun-2020	BAGALKOT	110	110/11KV,HV1	NAREGAL_110	7:51	8:12	0:21	TRANSFORMER FAULT
353	4-Jun-2020	BAGALKOT	110	110/11KVHV-2	MALAGHAN-110	9:05	10:06	1:01	LINE CLEAR AVAILED
354	4-Jun-2020	BAGALKOT	110	110/11 KV.HV 1	LOKAPUR-110	11:09	12:40	1:31	LINE CLEAR AVAILED
355	4-Jun-2020	BAGALKOT	110	110/11KV.HV-4	KULIGOD-110	15:50	17:24	1:34	LINE CLEAR AVAILED
356	4-Jun-2020	BENGALURU	66	HV2	ELECTRONIC CITY P2 S1	10:52	11:06	0:14	LINE CLEAR AVAILED
357	4-Jun-2020	BENGALURU	66	HV1	GOKULA	9:11	10:13	1:02	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
358	4-Jun-2020	BENGALURU	66	HV1	HANUMANTHNAGARA	13:55	14:17	0:22	LINE CLEAR AVAILED
359	4-Jun-2020	BENGALURU	66	HV2	HANUMANTHNAGARA	12:07	14:17	2:10	LINE CLEAR AVAILED
360	4-Jun-2020	BENGALURU	66	HV2	NATIONAL COLLEGE	10:03	10:07	0:04	LINE CLEAR AVAILED
361	4-Jun-2020	BENGALURU	66	REMCO - VRISHBHAVATHI 220	REMCO	10:04	10:06	0:02	LOAD CHANGE OVER
362	4-Jun-2020	BENGALURU	66	REMCO - SUBRAMANYAPURA	NO STATION AFFECTED	15:38	15:41	0:03	LOAD CHANGE OVER
363	4-Jun-2020	BENGALURU	220	HV1	MITTEMARI 220	12:51	13:01	0:10	TRANSFORMER FAULT
364	4-Jun-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI, SOMNATHPURA	12:51	13:01	0:10	MAIN SUPPLY FAILURE
365	4-Jun-2020	BENGALURU	66	MITTEMARI 220 - SADLI	SADLI, JULLUPALYA	12:51	13:01	0:10	MAIN SUPPLY FAILURE
366	4-Jun-2020	BENGALURU	66	KEMPANAHALLI - RAMANAGARA	RAMANAGARA, MELEHALLI, JALAMANGALA, CHIKKAGANGANAWADI, KUTAGALLU	13:43	13:50	0:06	LINE CLEAR AVAILED
367	4-Jun-2020	BENGALURU	66	DB PURA 220 - DG 1	AIR(EHT)	6:01	6:09	0:08	LINE FAULT
368	4-Jun-2020	BENGALURU	220	HV1	BEGUR 220	10:11	15:09	4:58	LINE CLEAR AVAILED
369	4-Jun-2020	BENGALURU	220	HV2	BEGUR 220	15:20	19:45	4:24	LINE CLEAR AVAILED
370	4-Jun-2020	BENGALURU	66	HV2	VRISHBHAVATHI 220	9:23	12:54	3:31	LINE CLEAR AVAILED
371	4-Jun-2020	BENGALURU	220	HV2	VRISHBHAVATHI 220	10:30	15:25	4:54	LINE CLEAR AVAILED
372	4-Jun-2020	BENGALURU	66	HV1	VIJAYANAGARA	15:41	15:52	0:10	LOAD CHANGE OVER
373	4-Jun-2020	BENGALURU	220	HV2	TK HALLI 220	15:17	15:55	0:38	LINE CLEAR AVAILED
374	4-Jun-2020	BENGALURU	66	VR DODDI - SOMANAHALLI 220	VR DODDI, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/ A (EHT)	17:15	17:20	0:05	LOAD CHANGE OVER
375	4-Jun-2020	BENGALURU	66	VR DODDI - TK HALLI 220	VR DODDI, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/ A (EHT)	16:19	16:26	0:06	LOAD CHANGE OVER
376	4-Jun-2020	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA, INDIA GYPSUM (EHT), AO SMITH (EHT), BWSSB (EHT), HAROHALLI I/A (EHT)	16:16	17:09	0:53	LINE CLEAR AVAILED
377	4-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
378	4-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
379	4-Jun-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)			LINE OPEN, LINE CLEAR AVAILED
380	4-Jun-2020	BENGALURU	66	HV1	RR NAGAR	11:11 (1-6-2020)	19:08	55:56HRS	TRANSFRMER CHARGED
381	4-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
382	4-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
383	4-Jun-2020	GULBARGA	220	HV1	KUSTAGI_220	23:59(4.06.2020)			LINE OPEN, LINE CLEAR AVAILED
384	4-Jun-2020	GULBARGA	220	KUSTAGI-LINGASUGUR	LINGASUGUR_220	23:59	14:15	1:52	LINE CLEAR AVAILED
385	4-Jun-2020	GULBARGA	220	KUSHTAGI-LINGAPUR	LINGAPUR_220	0:29	1:10	0:41	LINE CLEAR AVAILED
386	4-Jun-2020	GULBARGA	110	HATTI-LINGASUGUR	HATTI_110,MASKI_110	11:36	11:39	0:03	LINE FAULT
387	4-Jun-2020	GULBARGA	110	HATTI-GMSH WIND	HATTI_110	11:36	11:56	0:20	LINE FAULT
388	4-Jun-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	10:00	10:15	0:15	LINE FAULT
389	4-Jun-2020	GULBARGA	110	KOLHAR-SHAHI_SLR	KOLHAR_110	13:05	13:15	0:10	LINE FAULT
390	4-Jun-2020	GULBARGA	110	HV2	MANVI_110	11:34	11:49	0:15	TRANSFORMER FAULT
391	4-Jun-2020	GULBARGA	110	HV2	MADIYAL_110	11:00	11:16	0:15	LINE CLEAR AVAILED
392	4-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	4:45	4:50	1:15	MAIN SUPPLY FAILURE
393	4-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	10:20	11:20	2:15	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
394	4-Jun-2020	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	11:38	11:43	3:15	MAIN SUPPLY FAILURE
395	4-Jun-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	1:35	1:55	0:20	LINE FAULT
396	4-Jun-2020	GULBARGA	110	SINDHANOOR-NIRLOOTI_IPP	SINDHANOOR_220	1:20	1:30	0:10	LINE FAULT
397	4-Jun-2020	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110, KAMPLI_110_GLB, BTPS_WATERWORKS	5:05	5:25	0:20	LINE FAULT
398	4-Jun-2020	GULBARGA	110	SINDHANOOR-SIRIGUPPA	DHADESUGUR_110,SIRIGUPPA_110,TEKKE LKOTE_110,NSLSUGAR_IPP	10:28	12:42	2:14	LINE CLEAR AVAILED
399	4-Jun-2020	GULBARGA	110	SINDHANOOR-TURVIHAL	TURVIHAL_110	12:15	12:30	0:15	LINE FAULT
400	4-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
401	4-Jun-2020	HASSAN	110	JOG-AMBTR2	STATION NOT AFFECTED	9:45 (25.05.2020)			LINE OPEN, LINE CLEAR AVAILED
402	4-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
403	4-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	22:52(03.06.2020)	6:56	7:02 hrs	LINE CHARGED
404	4-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:52(03.06.2020)	6:56	7:02 hrs	LINE CHARGED
405	4-Jun-2020	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:42	13:39	2:57	LINE CLEAR AVAILED
406	4-Jun-2020	HASSAN	220	VARAHI-KEMAR3	varahi_gen	10:42	13:39	2:57	NFBC ISSUED
407	4-Jun-2020	HASSAN	110	HV1	HALADY_110	14:40	16:32	1:52	LINE CLEAR AVAILED
408	4-Jun-2020	HASSAN	110	HV2	KONAJE_110	12:22	14:02	1:40	LINE CLEAR AVAILED
409	4-Jun-2020	HASSAN	66	CRPATNA-MATTANAVILE	CRPATNA_220	12:20	12:29	0:09	LINE CLEAR AVAILED
410	4-Jun-2020	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	11:03	12:48	1:45	LINE FAULT
411	4-Jun-2020	HASSAN	66	HV1	HANGARANAHALLY_66	11:44	12:49	1:05	LINE CLEAR AVAILED
412	4-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
413	4-Jun-2020	MYSURU	66	HV1	GUNDULPET_66	12:04	13:33	1:28	LINE CLEAR AVAILED
414	4-Jun-2020	MYSURU	66	HV2	HANNUR_66	15:19	18:19	2:59	LINE CLEAR AVAILED
415	4-Jun-2020	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	9:33	12:52	3:18	LINE CLEAR AVAILED
416	4-Jun-2020	MYSURU	66	HV1	HULLAHALLI_66	17:59	18:22	0:22	LINE CLEAR AVAILED
417	4-Jun-2020	MYSURU	66	JAKKANAHALLI-MAHADESHWARAPURA	MADESWARAPURA_66	9:30	12:25	2:55	NFBC ISSUED
418	4-Jun-2020	MYSURU	66	KR PETE 220-BOOKANAKERE	BOOKANAKERE_66 GANJIGERE_66	10:51	14:40	3:48	LINE CLEAR AVAILED
419	4-Jun-2020	MYSURU	66	KR PETE 220-CR PATNA	KRISHNAPURA_66	10:04	14:36	4:31	LINE CLEAR AVAILED
420	4-Jun-2020	MYSURU	66	HV1	KRPET_220	10:47	13:55	3:07	LINE CLEAR AVAILED
421	4-Jun-2020	MYSURU	66	HV2	KRPET_220	10:35	13:50	3:15	LINE CLEAR AVAILED
422	4-Jun-2020	MYSURU	66	KR PETE 220-KR PETE 1	KRPET_66 AKKIHEBBAL_66	10:16	14:38	4:21	LINE CLEAR AVAILED
423	4-Jun-2020	MYSURU	66	KR PETE 220-KR PETE 2	KRPET_66 AKKIHEBBAL_66	10:17	14:38	4:20	LINE CLEAR AVAILED
424	4-Jun-2020	MYSURU	66	KR PETE 220-MAHADESHWARAPURA	JAKKANAHALLY_66 BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, NAGAMANGALA_66	9:32	14:00	4:27	LINE CLEAR AVAILED
425	4-Jun-2020	MYSURU	66	KR PETE 220-SANTHEBACHALLI	NO STATIONS EFFECTED	9:47	14:45	4:57	LINE CLEAR AVAILED
426	4-Jun-2020	MYSURU	220	HV1	KRPET_220	10:35	13:50	3:15	LINE CLEAR AVAILED
427	4-Jun-2020	MYSURU	220	HV2	KRPET_220	10:35	13:50	3:15	LINE CLEAR AVAILED
428	4-Jun-2020	MYSURU	220	HV1	KUSHALNAGARA_220	15:56	16:50	0:53	LINE CLEAR AVAILED
429	4-Jun-2020	MYSURU	66	HV1	PANDAVAPURA_66	18:09	18:24	0:15	HAND TRIPPED
430	4-Jun-2020	MYSURU	66	SFC SIVA-PGL	NO STATIONS EFFECTED	9:00	9:30	0:29	LINE FAULT
431	4-Jun-2020	MYSURU	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	9:00	9:31	0:31	LINE FAULT
432	4-Jun-2020	MYSURU	66	HV1	SRIRANGAPATNA_66	11:53	14:25	2:31	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
433	4-Jun-2020	MYSURU	66	HV2	SRIRANGAPATNA_66	10:04	11:45	1:40	LINE CLEAR AVAILED
434	4-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
435	4-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	3:20:55 PM(02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
436	4-Jun-2020	TUMKUR	66	TR-1	HOLAVINAHALLY_66	4:15:56 PM(04.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
437	4-Jun-2020	TUMKUR	220	DAVANGERE SRS- GUTTUR-2	DAVANGERE_SRS_220	12:56	13:39	0:43	LINE CLEAR AVAILED
438	4-Jun-2020	TUMKUR	220	TR-3	DAVANGERE_SRS_220	14:54	15:55	1:01	LINE CLEAR AVAILED
439	4-Jun-2020	TUMKUR	220	GUTUR_400-DAVANGERE SRS2	DAVANGERE_SRS_220	12:56	13:39	0:43	LINE CLEAR AVAILED
440	4-Jun-2020	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	18:14	18:50	0:36	LINE CLEAR AVAILED
441	4-Jun-2020	TUMKUR	110	TR-1	TIMMANAHALLI_110	12:37	13:15	0:38	LINE CLEAR AVAILED
442	4-Jun-2020	TUMKUR	66	ANTHRASANAHALLI 220kv-KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:34	11:54	1:20	LINE CLEAR AVAILED
443	4-Jun-2020	TUMKUR	66	TR-2	AVAREGERE_66	12:10	17:26	5:16	LINE CLEAR AVAILED
444	4-Jun-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	10:38	10:43	0:04	MAIN SUPPLY FAILURE
445	4-Jun-2020	TUMKUR	66	BELADADARA-CTKERE	BELADARA_66	12:02	12:04	0:01	MAIN SUPPLY FAILURE
446	4-Jun-2020	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	17:55	18:39	0:43	LINE CLEAR AVAILED
447	4-Jun-2020	TUMKUR	66	TR-2	HALUVAGALU_66	16:07	16:18	0:10	TRANSFORMER FAULT
448	4-Jun-2020	TUMKUR	66	TR-2	HANAGAL_66	7:36	15:28	7:52	LINE CLEAR AVAILED
449	4-Jun-2020	TUMKUR	66	TR-1	HIREMALLANAHOLE_66	17:20	17:35	0:15	TRANSFORMER FAULT
450	4-Jun-2020	TUMKUR	66	TR-2	HONNUDIKE_66	17:42	18:18	0:35	LINE CLEAR AVAILED
451	4-Jun-2020	TUMKUR	66	TR-2	HONNUDIKE_66	22:31	22:41	0:10	LINE CLEAR AVAILED
452	4-Jun-2020	TUMKUR	66	TR-2	HOSAKERE_66	18:27	18:32	0:05	TRANSFORMER FAULT
453	4-Jun-2020	TUMKUR	66	TR-1	JAVAGONDANAHALLI_66	10:13	10:27	0:14	LINE CLEAR AVAILED
454	4-Jun-2020	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	11:28	11:32	0:03	LINE CLEAR AVAILED
455	4-Jun-2020	TUMKUR	66	TR-2	MATHOD_66	9:03	9:07	0:04	TRANSFORMER FAULT
456	4-Jun-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	8:10	17:26	9:15	LINE CLEAR AVAILED
457	4-Jun-2020	TUMKUR	66	TR-2	SANIKERE_66	12:35	13:04	0:28	LINE CLEAR AVAILED
458	4-Jun-2020	TUMKUR	66	TR-2	THOVINAKERE_66	15:00	15:40	0:39	LINE CLEAR AVAILED
459	5-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
460	5-Jun-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
461	5-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
462	5-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
463	5-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	19:14 (23.05.2020)	13:17 (05.06.2020)	306:03hrs	LINE CHARGED
464	5-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
465	5-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
466	5-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
467	5-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
468	5-Jun-2020	BAGALKOT	110	GADAG110-ANNIGERI	NO STATION EFFECTED ANNIGERI_110	18:20 (30.05.2020)	15:57 (05.06.2020)	117:37hrs	LINE CHARGED
469	5-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
470	5-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
471	5-Jun-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	8:37 (31.05.2020)			LOAD CURTAILMENT
472	5-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	23:06 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
473	5-Jun-2020	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	15:16	19:13	3:57	LINE FAULT
474	5-Jun-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	12:39	13:05	0:26	LINE FAULT
475	5-Jun-2020	BAGALKOT	110	AMBEWADI-NK2	KAVALAWAD_110	16:46	17:21	0:35	HAND TRIPPED
476	5-Jun-2020	BAGALKOT	110	BIDNAL-ANNIGERI	ANNIGERI_110	10:01	15:25	5:24	NFBC ISSUED
477	5-Jun-2020	BAGALKOT	110	HAVERI-HANAGALL	HANAGALL_110	6:13	6:30	0:17	LINE FAULT
478	5-Jun-2020	BAGALKOT	110	HAVERI-HANAGALL	HANAGALL_110	12:04	12:37	0:33	HAND TRIPPED
479	5-Jun-2020	BAGALKOT	110	110/11KV,HV 1	KHANAPUR_110	14:58	15:20	0:22	HAND TRIPPED
480	5-Jun-2020	BAGALKOT	110	220/110KV LV2	MK HUBLI_220	2:04	8:30	6:26	LINE CLEAR AVAILED
481	5-Jun-2020	BAGALKOT	110	110/11KV HV2	MALGHAN(B)_110	6:11	6:12	0:01	TRANSFORMER FAULT
482	5-Jun-2020	BAGALKOT	110	110/11KV,HV1	NAVANAGAR(H)	1:31	1:50	0:19	TRANSFORMER FAULT
483	5-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	18:43 (05.06.2020)			LINE OPEN, LINE CLEAR AVAILED
484	5-Jun-2020	BAGALKOT	110	NARENDRA-TADASINKOPPA	TADASINKOPPA_110	13:13	13:19	0:06	HAND TRIPPED
485	5-Jun-2020	BAGALKOT	110	TADASINKOPPA-TARIHAL	TARIHAL_110	13:19	18:31	5:12	LINE CLEAR AVAILED
486	5-Jun-2020	BAGALKOT	110	NARENDRA-TADASINKOPPA	TADASINKOPPA_110	18:31	18:46	0:15	HAND TRIPPED
487	5-Jun-2020	BAGALKOT	110	PG HUNSYAL -NAGANUR(MUDALAGI )	NAGANUR_110	12:17	12:46	0:29	LINE CLEAR AVAILED
488	5-Jun-2020	BAGALKOT	110	110/11KV,HV2	PG HUNSYAL_110	10:10	11:01	0:51	LINE CLEAR AVAILED
489	5-Jun-2020	BENGALURU	66	JAKKASANDRA - ADUGODI 1 & 2	ADUGODI, BOSCH(EHT)	17:08	17:39	0:31	LINE FAULT
490	5-Jun-2020	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	17:08	17:11	0:03	LINE FAULT
491	5-Jun-2020	BENGALURU	66	SOMANAHALLI 220 - JIGANI 2	BG ROAD, JIGANI 66, JIGANI LINK ROAD	15:30	15:46	0:16	LINE FAULT
492	5-Jun-2020	BENGALURU	66	HV1	CHATRA	10:00	10:30	0:30	LINE CLEAR AVAILED
493	5-Jun-2020	BENGALURU	66	HV2	CHATRA	10:00	10:30	0:30	LINE CLEAR AVAILED
494	5-Jun-2020	BENGALURU	66	HV2	GOKULA	8:10	8:17	0:07	TRANSFORMER FAULT
495	5-Jun-2020	BENGALURU	66	HAL 220 - HOODY 1	ISRO (EHT), KADUBISANAHALLI, CESSNO PARK	10:27	11:30	1:03	LINE FAULT
496	5-Jun-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	6:17	6:21	0:04	LINE FAULT
497	5-Jun-2020	BENGALURU	66	KANAKAPURA 220 - RAMANAGARA	ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA	8:06	8:13	0:07	LINE FAULT
498	5-Jun-2020	BENGALURU	66	KADUBISANAHALLI - CESSNA	KADUBISANAHALLI, EXORA	12:05	12:10	0:05	LOAD CHANGE OVER
499	5-Jun-2020	BENGALURU	66	HV1	KUMBALAGODU	19:35	19:50	0:15	TRANSFORMER FAULT
500	5-Jun-2020	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	17:52	18:42	0:50	LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
501	5-Jun-2020	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	17:53	18:42	0:49	LINE FAULT
502	5-Jun-2020	BENGALURU	66	NRS 220 - REMCO MY 1	CHANDRA LAYOUT	9:32	9:50	0:18	LOAD CHANGE OVER
503	5-Jun-2020	BENGALURU	66	YEDUMADU - KANAKPURA 220	YEDUMADU	10:25	11:35	1:10	LINE CLEAR AVAILED
504	5-Jun-2020	BENGALURU	66	HV2	SARJAPURA	8:41	8:53	0:12	TRANSFORMER FAULT
505	5-Jun-2020	BENGALURU	66	NANGLI - KOLAR 220	NANGLI	3:01	3:12	0:10	LINE FAULT
506	5-Jun-2020	BENGALURU	66	MITTEMARI 220 - PATHPALYA	PATHPALYA, THIMMAMPALLI, SOMNATHPURA	18:23	18:31	0:07	LINE FAULT
507	5-Jun-2020	BENGALURU	220	HV1	KHW PARK	9:49	14:23	4:34	LINE CLEAR AVAILED
508	5-Jun-2020	BENGALURU	220	HV2	KHW PARK	14:31	18:30	3:58	LINE CLEAR AVAILED
509	5-Jun-2020	BENGALURU	66	DABUSPET 220 - NELAMANGALA 66	NELAMANGALA 66	16:42	18:04	1:21	LINE FAULT
510	5-Jun-2020	BENGALURU	66	HV2	VIJAYNAGAR	9:38	9:46	0:08	LOAD CHANGE OVER
511	5-Jun-2020	BENGALURU	66	HV1	VIJAYNAGAR	17:55	18:02	0:06	LOAD CHANGE OVER
512	5-Jun-2020	BENGALURU	66	HV2	TALAGWARA	11:45	19:30	7:45	LINE CLEAR AVAILED
513	5-Jun-2020	BENGALURU	66	HV1	THIMMAMPALLI	8:40:48 AM(5-6-2020)			LINE OPEN, LINE CLEAR AVAILED
514	5-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
515	5-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
516	5-Jun-2020	BENGALURU	220	HOODY 220 - BEGUR 220	NO STATION AFFECTED	10:13 (26-5-2020)	17:16	92:32hrs	LINE CHARGED
517	5-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
518	5-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
519	5-Jun-2020	GULBARGA	220	HV1	KUSTAGI_220	23:59(4.06.2020)	19:15	43:15HRS	TRANSFRMER CHARGED
520	5-Jun-2020	GULBARGA	220	LINGAPUR-KUSTAGI	KUSTAGI_220	10:22	10:26	0:04	LINE FAULT
521	5-Jun-2020	GULBARGA	220	LINGAPUR-SINDHANOOR	KUSTAGI_220	11:17	15:03	3:46	LINE CLEAR AVAILED
522	5-Jun-2020	GULBARGA	110	HV3	BEVOOR_110	16:17	16:33	0:16	LINE CLEAR AVAILED
523	5-Jun-2020	GULBARGA	110	BEVOOR-KUSHTAGI	BEVOOR_110	10:20	10:40	0:20	MAIN SUPPLY FAILURE
524	5-Jun-2020	GULBARGA	110	CHITAGUPPA-ACMESOLAR IPP	CHITAGUPPA_110	11:15	11:28	0:13	MAIN SUPPLY FAILURE
525	5-Jun-2020	GULBARGA	110	GABUR-DEODURGA	DEODURGA_110	10:24	17:22	0:13	LINE CLEAR AVAILED
526	5-Jun-2020	GULBARGA	110	HANUMNAL-HIREGONNAGAR	HANUMANAL_110	8:55	9:10	0:15	MAIN SUPPLY FAILURE
527	5-Jun-2020	GULBARGA	110	HANUMNAL-HIREGONNAGAR	HANUMANAL_110	10:20	11:10	0:50	MAIN SUPPLY FAILURE
528	5-Jun-2020	GULBARGA	110	PDHALLI-CLNSLR	PD_HALLI_110	0:10	0:39	0:29	LINE FAULT
529	5-Jun-2020	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	10:15	10:45	0:30	MAIN SUPPLY FAILURE
530	5-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	10:57	11:01	0:29	LINE FAULT
531	5-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	11:15	11:19	0:29	LINE FAULT
532	5-Jun-2020	GULBARGA	110	KUSTAGI-HANUMASAGAR, YELBURGA, KANKAGIRI	KANKAGIRI_110, GANADAL_110, HANUMASAGAR_110,, HIREGONNAGAR_110, HANUMANAL_110, YELBURGA_110	18:27	19:34	0:29	LINE CLEAR AVAILED
533	5-Jun-2020	GULBARGA	110	KUSTAGI-INRSOLAR_IPP	KUSTAGI_220	18:47	19:27	0:29	LINE CLEAR AVAILED
534	5-Jun-2020	GULBARGA	110	KUSTAGI-KANKAGIRI_110	KANKAGIRI_110, GANADAL_110,	20:46	20:47	0:29	LINE CLEAR AVAILED
535	5-Jun-2020	GULBARGA	110	PDHALLI-CLNSLR	PDHALLI_110	21:12	20:23	0:29	LINE CLEAR AVAILED
536	5-Jun-2020	GULBARGA	66	HV1	HANASI_66	14:15	14:20	0:05	TRANSFORMER FAULT
537	5-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
538	5-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
539	5-Jun-2020	HASSAN	110	JOG110-AMBT2	JOG_110	9:45 (25.05.2020)	10:26	265:11 hrs	LINE CHARGED
540	5-Jun-2020	HASSAN	400	HASSAN40-UPCL1	SHANTHIGRAMA_400	1:02	6:34	5:32	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
541	5-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	1:02	6:34	5:32	LINE CLEAR AVAILED
542	5-Jun-2020	HASSAN	220	HV2	KADUR_220	10:00	12:30	2:30	LINE CLEAR AVAILED
543	5-Jun-2020	HASSAN	110	LV2	KADUR_220	10:00	12:30	2:30	LINE CLEAR AVAILED
544	5-Jun-2020	HASSAN	110	KADUR-NGNHL	KADUR_220	10:15	18:50	8:35	LINE CLEAR AVAILED
545	5-Jun-2020	HASSAN	220	KAVOOR-BAJPE 2	KAVOOR_220	0:44	0:46	0:02	HAND TRIPPED
546	5-Jun-2020	HASSAN	220	HV2	KEMAR_220	13:31	14:37	1:06	LINE CLEAR AVAILED
547	5-Jun-2020	HASSAN	220	KEMAR-BAJPE 2	KEMAR_220	0:40	0:51	0:11	HAND TRIPPED
548	5-Jun-2020	HASSAN	220	KEMAR-Varahi1	KEMAR_220	3:00	12:32	9:32	LINE CLEAR AVAILED
549	5-Jun-2020	HASSAN	110	LV2	KEMAR_220	13:31	14:37	1:06	LINE CLEAR AVAILED
550	5-Jun-2020	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	0:44	0:46	0:02	HAND TRIPPED
551	5-Jun-2020	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	0:40	0:51	0:11	HAND TRIPPED
552	5-Jun-2020	HASSAN	220	VARAHI-KEMAR1	varahi_gen	3:00	12:32	9:32	NFBC ISSUED
553	5-Jun-2020	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	13:09	13:48	0:39	LINE CLEAR AVAILED
554	5-Jun-2020	HASSAN	110	HV1	KARAYA_110	10:20	13:45	3:25	LINE CLEAR AVAILED
555	5-Jun-2020	HASSAN	110	HV1	NAVUNDA_110	8:04	8:38	0:34	TRANSFORMER FAULT
556	5-Jun-2020	HASSAN	110	HV2	NAVUNDA_110	8:04	8:45	0:41	TRANSFORMER FAULT
557	5-Jun-2020	HASSAN	110	NAVINDA-MADHUVANA	NAVUNDA_110	8:04	8:45	0:41	LINE FAULT
558	5-Jun-2020	HASSAN	110	HV1	SALATHUR_110	11:02	13:16	2:14	LINE CLEAR AVAILED
559	5-Jun-2020	HASSAN	66	DIDIGA-CRPATNA	DIDIGA_66	9:52	12:23	2:31	LINE CLEAR AVAILED
560	5-Jun-2020	HASSAN	66	HV1	DIDIGA_66	9:52	12:23	2:31	LINE CLEAR AVAILED
561	5-Jun-2020	HASSAN	66	HNPR2-CRPTN	HOLENARASIPURA_220	10:43	13:16	2:33	LINE CLEAR AVAILED
562	5-Jun-2020	HASSAN	66	KIADB HA-RAMESWARNAGAR	KIADB_66	5:45	6:03	0:18	LINE FAULT
563	5-Jun-2020	HASSAN	66	RMWNGR-SHANTI	RAMESHWARNAGAR_66	5:45	6:06	0:21	LINE FAULT
564	5-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
565	5-Jun-2020	MYSURU	66	KUSHALNAGARA 220-BYLKUPPE	BYLUKUPPE_66 PERIYAPATNA_66	11:05	14:47	3:42	LINE CLEAR AVAILED
566	5-Jun-2020	MYSURU	66	SFC SHIVA-PGL	NO STATIONS EFFECTED	10:04	11:15	1:10	LINE CLEAR AVAILED
567	5-Jun-2020	MYSURU	66	HV1	THALAKADU_66	12:15	13:30	1:15	LINE CLEAR AVAILED
568	5-Jun-2020	MYSURU	66	HV2	THALAKADU_66	12:53	13:56	1:02	LINE CLEAR AVAILED
569	5-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
570	5-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	3:20:55 PM(02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
571	5-Jun-2020	TUMKUR	66	TR-1	HOLAVINAHALLY_66	16:15:56 (04.06.2020)	14:19	21:54hrs	TRANSFRMER CHARGED
572	5-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	5:15:25 PM(05.06.2020			TRANSFORMER OPEN,TRANSFORMER FAULT
573	5-Jun-2020	TUMKUR	66	TR-1	HOLAVINAHALLY_66	14:16	14:37	0:20	TRANSFORMER FAULT
574	5-Jun-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	0:21	6:59	6:38	LINE CLEAR AVAILED
575	5-Jun-2020	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	14:07	14:43	0:35	LINE FAULT
576	5-Jun-2020	TUMKUR	220	HONNALLI 220KV- DAVANAGERE 220kv	HONNALLI_220	14:07	14:55	0:47	LINE FAULT
577	5-Jun-2020	TUMKUR	110	TR-1	HALKURKE_110	6:44	7:55	1:11	LINE CLEAR AVAILED
578	5-Jun-2020	TUMKUR	110	TR-1	TALKERE_110	10:29	16:29	5:59	LINE CLEAR AVAILED
579	5-Jun-2020	TUMKUR	66	ANTHRASANAHALLI 220KV- CHELUR	CHELURU_66, HOSAKERE_66, ANKASANDRA_66, HAGALWADI_66	5:25	5:39	0:13	LINE FAULT
580	5-Jun-2020	TUMKUR	66	TR-1	BHAKTHARAHALLI_66	16:25	17:15	0:50	LINE CLEAR AVAILED
581	5-Jun-2020	TUMKUR	66	TR-2	DAVANAGERE_66	16:33	17:22	0:49	LINE CLEAR AVAILED



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
582	5-Jun-2020	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJIHALLI_66	1:23	1:27	0:03	HAND TRIPPED
583	5-Jun-2020	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	14:10	14:55	0:45	MAIN SUPPLY FAILURE
584	5-Jun-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	16:00	16:41	0:41	LINE FAULT
585	5-Jun-2020	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	16:30	16:35	0:05	LINE FAULT
586	5-Jun-2020	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAGIRI_66	10:40	10:50	0:10	LINE FAULT
587	5-Jun-2020	TUMKUR	66	TR-1	PANDARAHALLI_66	14:35	14:38	0:02	HAND TRIPPED
588	5-Jun-2020	TUMKUR	66	PANDARAHALLI- SPML _WIND _IPP_66	SPML _WIND _IPP_66	20:01	21:15	1:13	LINE CLEAR AVAILED
589	5-Jun-2020	TUMKUR	66	RANGENAHALLI- DYVARANAHALLI	RANGENAHALLI_66	7:14	17:57	10:42	LINE CLEAR AVAILED
590	5-Jun-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	16:31	16:45	0:13	MAIN SUPPLY FAILURE
591	5-Jun-2020	TUMKUR	66	THALLAK 220kV- SEI VENUS DIAMOND _IPP_66	SEI VENUS DIAMOND _IPP_66	11:47	12:40	0:53	LINE CLEAR AVAILED
592	5-Jun-2020	TUMKUR	66	UCHANGIDURGA- PALLAGATTE	UCHCHANGIDURGA_66	14:25	15:31	1:05	LINE CLEAR AVAILED
593	5-Jun-2020	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	11:14	14:07	2:53	LINE CLEAR AVAILED
594	6-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
595	6-Jun-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
596	6-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
597	6-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
598	6-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
599	6-Jun-2020	BAGALKOT	110	RATTIHALI-HIREKERUR	NO STATION EFFECTED RATTIHALI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
600	6-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
601	6-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
602	6-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
603	6-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
604	6-Jun-2020	BAGALKOT	220	SHIROLKOPPA(BALLIGAVI)-RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	8:37 (31.05.2020)	11:23 (06.06.2020)	146:46hrs	LINE CHARGED
605	6-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	23:06 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
606	6-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	18:43 (05.06.2020)			LINE OPEN, LINE CLEAR AVAILED
607	6-Jun-2020	BAGALKOT	110	110/33KV,HV3	ANKALI_110	9:24	9:43	0:19	TRANSFORMER FAULT
608	6-Jun-2020	BAGALKOT	110	110/11KV,HV2(HV1)	ANKOLA_110MASTIKATTA_33,SEABIRD_33	15:31	15:42	0:11	TRANSFORMER FAULT
609	6-Jun-2020	BAGALKOT	110	110/11KV,HV2(HV1)	ANKOLA_110	15:59	16:49	0:50	TRANSFORMER FAULT
610	6-Jun-2020	BAGALKOT	220	NNARENDRA1-AMBEWADI	AMBEWADI_220	23:20 (06.06.2020)			LINE OPEN, LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
611	6-Jun-2020	BAGALKOT	220	BIDNAL-HIREBENDIGERI2(TADASA2)	BIDNAL_220	10:43	15:34	4:51	LINE CLEAR AVAILED
612	6-Jun-2020	BAGALKOT	110	BIDNAL-NAVALGUND	NAVALGUND_110	11:18	16:00	4:42	NFBC ISSUED
613	6-Jun-2020	BAGALKOT	110	AB-SOLAR-BELLATTI	BELLATTI_110	17:30	19:15	1:45	LINE CLEAR AVAILED
614	6-Jun-2020	BAGALKOT	110	110/11KV,HV3	GADAG_110,NAGAVI_33,MALLASAMUDR A_33,PIONEER_33,KAPPADAGUDDA_33	9:03	9:06	0:03	TRANSFORMER FAULT
615	6-Jun-2020	BAGALKOT	110	110/11KV,HV1	GADAG_110	9:25	9:55	0:30	LINE CLEAR AVAILED
616	6-Jun-2020	BAGALKOT	110	GOPPANAKOPPA-NARGUND	NARGUND_110	11:06	11:28	0:22	HAND TRIPPED
617	6-Jun-2020	BAGALKOT	220	VAISHALI1-BIJAPUR	BIJAPUR_220	18:59	19:25	0:26	LINE FAULT
618	6-Jun-2020	BAGALKOT	220	VAISHALI2-BIJAPUR	BIJAPUR_220	18:59	19:23	0:24	LINE FAULT
619	6-Jun-2020	BAGALKOT	220	HAVERI220-GUTTUR2	HAVERI_220	14:22	17:13	2:51	LINE CLEAR AVAILED
620	6-Jun-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	11:24	12:56	1:32	LINE CLEAR AVAILED
621	6-Jun-2020	BAGALKOT	110	110/11KV,HV3(HV1)	HIDIKAL DAM_110,RUSTUMPUR WATER SUPPLY_33,BGM WATERSUPPLY1_33,BGM WATER SUPPLY 2&3_33	15:24	15:58	0:34	LINE CLEAR AVAILED
622	6-Jun-2020	BAGALKOT	110	ITNAL-RAIBAG2	ITNAL_110	22:14	22:19	0:05	LINE FAULT
623	6-Jun-2020	BAGALKOT	110	BPCL(BORUKA)-ITNAL	ITNAL_110	22:14	22:24	0:10	LINE FAULT
624	6-Jun-2020	BAGALKOT	110	110/11KV,HV4	KANABARGI LAYOUT_110,KAKTI_33,SUZLON_33	11:22	12:18	0:56	LINE CLEAR AVAILED
625	6-Jun-2020	BAGALKOT	110	110/11KV, HV1	YELPARAHATT_110	14:50	15:37	0:47	LINE CLEAR AVAILED
626	6-Jun-2020	BAGALKOT	110	SOUDATTI220-RAMDURGA1	RAMDURGA_110	16:48	17:59	1:11	LINE FAULT
627	6-Jun-2020	BAGALKOT	110	SOUDATTI220-RAMDURGA2	RAMDURGA_110	16:48	17:34	0:46	LINE FAULT
628	6-Jun-2020	BAGALKOT	110	110/33KV, HV3	SATTI_110, SATTI_33	12:53	12:58	0:05	LINE CLEAR AVAILED
629	6-Jun-2020	BAGALKOT	110	DHARWADBIO- NAVALGUND	NAVALGUND_110	17:11 (06.06.2020)			LINE OPEN, LINE CLEAR AVAILED
630	6-Jun-2020	BAGALKOT	110	220/110KV, LV2	MK HUBLI_220	20:59	21:01	0:02	HAND TRIPPED
631	6-Jun-2020	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	11:15	11:55	0:40	LINE CLEAR AVAILED
632	6-Jun-2020	BAGALKOT	110	110/11KV, HV2	MALGHAN(B)_110	15:27	15:52	0:25	TRANSFORMER FAULT
633	6-Jun-2020	BAGALKOT	110	NAVALGUND-KONNUR	KONNUR_110	11:24	16:42	5:18	LINE CLEAR AVAILED
634	6-Jun-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	RANEBENNUR_220	11:23 (06.06.2020)			LINE OPEN, LINE CLEAR AVAILED
635	6-Jun-2020	BENGALURU	66	HV1	ABBIGERE	11:45	11:47	0:02	LINE CLEAR AVAILED
636	6-Jun-2020	BENGALURU	66	ABBIGERE - SRS PEENYA 220	ABBIGERE	16:15	16:45	0:30	LINE CLEAR AVAILED
637	6-Jun-2020	BENGALURU	66	HV2	ABBIGERE	13:35	13:48	0:13	LINE CLEAR AVAILED
638	6-Jun-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - NAGANATHPURA 220	ELECTRONIC CITY PH-2 SEC-2	10:40	10:57	0:17	LOAD CHANGE OVER
639	6-Jun-2020	BENGALURU	220	NRS 220 - SRS PEENYA 1 & 2	NRS 220	11:10	17:32	6:22	LINE CLEAR AVAILED
640	6-Jun-2020	BENGALURU	66	NRS 220 - TELECOM LAYOUT 1 & 2	TELECOM LAYOUT	10:49	17:40	6:51	LINE CLEAR AVAILED
641	6-Jun-2020	BENGALURU	66	NRS 220 - BRIGADE GATEWAY	BRIGADE GATEWAY	10:57	18:50	7:53	LINE CLEAR AVAILED
642	6-Jun-2020	BENGALURU	66	REMCO - NRS	VIJAYANAGARA	14:42	14:50	0:08	LINE CLEAR AVAILED
643	6-Jun-2020	BENGALURU	400	NELMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	1:43	7:14	5:30	LINE FAULT
644	6-Jun-2020	BENGALURU	66	HV2	BAGHMANE WORLD TECH PARK	10:31	10:38	0:06	LINE CLEAR AVAILED
645	6-Jun-2020	BENGALURU	66	HV1	ANDERSONPET	11:29	11:51	0:21	LINE CLEAR AVAILED
646	6-Jun-2020	BENGALURU	66	HV1	KAMASAMUDRA	20:54	23:59	3:04	TRANSFORMER FAULT
647	6-Jun-2020	BENGALURU	66	HV1	KAMASAMUDRA	19:00	19:30	0:30	TRANSFORMER FAULT
648	6-Jun-2020	BENGALURU	66	HV1	RR NAGARA	13:25:18	13:38:20	0:13	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
649	6-Jun-2020	BENGALURU	66	HV2	RR NAGARA	13:25:16	13:38:24	0:13	LINE CLEAR AVAILED
650	6-Jun-2020	BENGALURU	66	HV1	NANGLI	15:07:03	15:41:43	0:34	LINE CLEAR AVAILED
651	6-Jun-2020	BENGALURU	66	HV2	SARJAPURA 220	8:11	8:20	0:09	TRANSFORMER FAULT
652	6-Jun-2020	BENGALURU	66	HV2	SARJAPURA 220	18:28	18:40	0:12	TRANSFORMER FAULT
653	6-Jun-2020	BENGALURU	66	HV1	THIMAMPALLI	8:40:48 (5-6-2020)	13:02:41(6-6-2020)	28:20hrs	TRANSFRMER CHARGED
654	6-Jun-2020	BENGALURU	66	HV2	YELAHANKA 220	23:10:52(6-6-2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
655	6-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
656	6-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
657	6-Jun-2020	BENGALURU	66	HV1	KGF	19:50:14(06-06-2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
658	6-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
659	6-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
660	6-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	CHITAGUPPA_110	11:22	11:28	1:05	LINE FAULT
661	6-Jun-2020	GULBARGA	110	HUMNABAD-SASTHAPUR	SASTHAPUR_110	11:31	15:00	2:05	LINE CLEAR AVAILED
662	6-Jun-2020	GULBARGA	110	HV3	BEVOOR_110	3:04	3:31	0:27	LINE CLEAR AVAILED
663	6-Jun-2020	GULBARGA	110	HV2	MADIYAL_110	13:20	16:28	3:08	LINE CLEAR AVAILED
664	6-Jun-2020	GULBARGA	110	HV1	MANVI_110	12:11	13:05	0:54	LINE CLEAR AVAILED
665	6-Jun-2020	GULBARGA	110	HV2	MANVI_110	12:12	12:21	0:09	LINE CLEAR AVAILED
666	6-Jun-2020	GULBARGA	110	HV3	BEVOOR_110	21:13	21:34	0:21	LINE CLEAR AVAILED
667	6-Jun-2020	GULBARGA	110	HV1	BEVOOR_110	17:45	18:39	0:54	LINE CLEAR AVAILED
668	6-Jun-2020	GULBARGA	66	TBHALLI-ITTAGGI	TAMBRAHALLI_66	14:55	15:00	0:05	MAIN SUPPLY FAILURE
669	6-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
670	6-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
671	6-Jun-2020	HASSAN	220	GERSOPA-TALGUPA	gerusoppa_gen	11:36	12:03	0:27	LINE CLEAR AVAILED
672	6-Jun-2020	HASSAN	220	GERSOPA-SHIMOGA	gerusoppa_gen	11:34	12:01	0:27	LINE CLEAR AVAILED
673	6-Jun-2020	HASSAN	220	MRSSHM-STRP1	MRSMG_220	11:36	12:03	0:27	HAND TRIPPED
674	6-Jun-2020	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMG_220	9:50	11:22	1:32	LINE CLEAR AVAILED
675	6-Jun-2020	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	9:50	11:21	1:31	LINE CLEAR AVAILED
676	6-Jun-2020	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	11:34	12:01	0:27	HAND TRIPPED
677	6-Jun-2020	HASSAN	110	HV1	KALLUSADARAHALLY_110	10:38	15:13	4:35	LINE CLEAR AVAILED
678	6-Jun-2020	HASSAN	110	HV2	KARAYA_110	10:03	17:35	7:32	LINE CLEAR AVAILED
679	6-Jun-2020	HASSAN	110	HV4	MANIPAL_110	10:55	11:10	0:15	LINE CLEAR AVAILED
680	6-Jun-2020	HASSAN	66	CRPATNA-CRPTNA1	CRPATNA_110	11:40	12:37	0:57	LINE CLEAR AVAILED
681	6-Jun-2020	HASSAN	66	CRPATNA-CRPTNA2	CRPATNA_110	11:40	12:37	0:57	LINE CLEAR AVAILED
682	6-Jun-2020	HASSAN	66	HV1	DIDIGA_66	13:26	13:46	0:20	LINE CLEAR AVAILED
683	6-Jun-2020	HASSAN	66	HV2	RAMESHWARNAGARA_66	12:18	12:43	0:25	LINE CLEAR AVAILED
684	6-Jun-2020	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	10:01	15:41	5:40	LINE CLEAR AVAILED
685	6-Jun-2020	HASSAN	66	SAKALE-IPCL2	SAKLESH PURA_66	10:01	15:41	5:40	LINE CLEAR AVAILED
686	6-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
687	6-Jun-2020	MYSURU	66	COWDALLI-MARTHALLI	MARTAHALLI_66 RAMAPURA_MYS_66	10:01	16:22	6:20	LINE CLEAR AVAILED
688	6-Jun-2020	MYSURU	66	HV2	DODDINADUVADI_66	10:18	15:47	5:29	LINE CLEAR AVAILED
689	6-Jun-2020	MYSURU	66	HV1	DODDINADUVADI_66	10:18	15:47	5:29	LINE CLEAR AVAILED
690	6-Jun-2020	MYSURU	66	HV2	HANNUR_66	15:12	15:58	0:46	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
691	6-Jun-2020	MYSURU	66	HANNUR-MADHUVANAHALLI 3	NO STATIONS EFFECTED	17:12	19:10	1:58	LINE CLEAR AVAILED
692	6-Jun-2020	MYSURU	220	HOOTAGALLI-KADAKOLA	NO STATIONS EFFECTED	14:52	15:36	0:44	LINE FAULT
693	6-Jun-2020	MYSURU	66	HV1	HULLAHALLI_66	17:19	17:31	0:11	LINE CLEAR AVAILED
694	6-Jun-2020	MYSURU	66	JYOTHINAGARA-FTS	NO STATIONS EFFECTED	16:07	16:10	0:03	HAND TRIPPED
695	6-Jun-2020	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66	2:16	2:23	0:07	LINE FAULT
696	6-Jun-2020	MYSURU	66	KADAKOLA-SARGUR 2	CHANDRAVADI_66 DOORA_66 HULLAHALLI_66 HURA_66,	2:27	2:34	0:07	LINE FAULT
697	6-Jun-2020	MYSURU	66	HEBBANI-VADKEPURA	KIRUGAVALU_66 VADKEPURA_66	12:04	12:20	0:16	LINE FAULT
698	6-Jun-2020	MYSURU	66	KOLLEGALA-SATHEGALA	SATHEGALA_66	10:14	14:52	4:38	NFBC ISSUED
699	6-Jun-2020	MYSURU	66	HV2	KOPPA_66	10:43	13:01	2:17	LINE CLEAR AVAILED
700	6-Jun-2020	MYSURU	66	HV1	KOPPA_66	13:07	14:56	1:48	LINE CLEAR AVAILED
701	6-Jun-2020	MYSURU	66	HV2	MADDUR_66	17:19	17:36	0:16	LINE CLEAR AVAILED
702	6-Jun-2020	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	10:30	17:37	7:06	NFBC ISSUED
703	6-Jun-2020	MYSURU	66	HV2	MADHUVANAHALLI_220	11:56	13:05	1:08	LINE CLEAR AVAILED
704	6-Jun-2020	MYSURU	66	HV1	MADHUVANAHALLI_220	13:11	13:59	0:48	LINE CLEAR AVAILED
705	6-Jun-2020	MYSURU	66	SATHEGALA-BPCL	NO STATIONS EFFECTED	10:10	14:58	4:47	LINE CLEAR AVAILED
706	6-Jun-2020	MYSURU	66	SATHEGALA-SFC	NO STATIONS EFFECTED	10:25	16:01	5:36	LINE CLEAR AVAILED
707	6-Jun-2020	MYSURU	66	HV1	SANIVARASANTHE_66	4:32	4:40	0:08	TRANSFORMER FAULT
708	6-Jun-2020	MYSURU	66	HV5	SFCSHIVA_66	13:18	16:41	3:23	LINE CLEAR AVAILED
709	6-Jun-2020	MYSURU	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66 FTS_66	15:09	15:27	0:18	LINE FAULT
710	6-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
711	6-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	3:20:55 PM(02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
712	6-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	5:15:25 PM(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
713	6-Jun-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	2:05	6:59	4:54	LOAD CURTAILMENT
714	6-Jun-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	9:00:37 PM(06.06.2020)			LOAD CURTAILMENT
715	6-Jun-2020	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	12:08	13:26	1:18	LINE CLEAR AVAILED
716	6-Jun-2020	TUMKUR	66	BELADARA-CTKERE	BELADARA_66	10:12	10:17	0:04	LINE CLEAR AVAILED
717	6-Jun-2020	TUMKUR	66	BELADARA-CTKERE	BELADARA_66	16:38	16:43	0:04	LINE CLEAR AVAILED
718	6-Jun-2020	TUMKUR	66	TR-1	BELADARA_66	11:50	12:39	0:48	LINE CLEAR AVAILED
719	6-Jun-2020	TUMKUR	66	TR-2	HIRIYUR_66	10:03	11:44	1:41	LINE CLEAR AVAILED
720	6-Jun-2020	TUMKUR	66	TR-1	HULIYURDURGA_66	16:36	17:08	0:32	TRANSFORMER FAULT
721	6-Jun-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	13:29	13:51	0:21	HAND TRIPPED
722	6-Jun-2020	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	15:53	23:00	7:06	LINE CLEAR AVAILED
723	6-Jun-2020	TUMKUR	66	TR-1	KORATAGERE_66	10:14	16:49	6:34	LINE CLEAR AVAILED
724	6-Jun-2020	TUMKUR	66	TR-2	KORATAGERE_66	10:14	16:49	6:34	LINE CLEAR AVAILED
725	6-Jun-2020	TUMKUR	66	MADHUGIRI 66kV- BADAVANAHALLI	MADHUGIRI_66	11:13	14:11	2:57	LINE CLEAR AVAILED
726	6-Jun-2020	TUMKUR	66	MADHUGIRI 66kV- MADHUGIRI	MADHUGIRI_66	11:13	14:08	2:54	LINE CLEAR AVAILED
727	6-Jun-2020	TUMKUR	66	SHYLAPURA- MADHUGIRI	SHYLAPURA_66	13:29	13:51	0:21	HAND TRIPPED
728	6-Jun-2020	TUMKUR	66	VENKATAPURA- IMAMI_SOLAR_IPP	VENKATAPUR_66	15:54	17:01	1:06	LINE FAULT
729	7-Jun-2020	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
730	7-Jun-2020	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)			LOAD CURTAILMENT
731	7-Jun-2020	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT
732	7-Jun-2020	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
733	7-Jun-2020	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN, LINE FAULT
734	7-Jun-2020	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
735	7-Jun-2020	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
736	7-Jun-2020	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11 (29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
737	7-Jun-2020	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
738	7-Jun-2020	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
739	7-Jun-2020	BAGALKOT	220	BELGAUM-CHIKKODI2	NO STATION EFFECTED BELGAUM_220	23:06 (01.06.2020)	17:06 (07.06.2020)	213:06hrs	LINE CHARGED
740	7-Jun-2020	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	18:43 (05.06.2020)			LINE OPEN, LINE CLEAR AVAILED
741	7-Jun-2020	BAGALKOT	220	NNARENDRA1-AMBEWADI	NO STATION EFFECTED AMBEWADI_220	23:20 (06.06.2020)			LINE OPEN, LINE FAULT
742	7-Jun-2020	BAGALKOT	110	DHARWADBIO- NAVALGUND	NO STATION EFFECTED NAVALGUND_110	17:11 (06.06.2020)			LINE OPEN, LINE CLEAR AVAILED
743	7-Jun-2020	BAGALKOT	220	GUTTUR- RANEBENNUR	NO STATION EFFECTED RANEBENNUR_220	11:23 (06.06.2020)			LINE OPEN, LINE CLEAR AVAILED
744	7-Jun-2020	BAGALKOT	110	110/11KV,HV1	ARGA_110	1:58	5:19	3:21	TRANSFORMER FAULT
745	7-Jun-2020	BAGALKOT	220	NARENDRA2-AMBEWADI	AMBEWADI_220	11:15	15:34	4:19	LINE CLEAR AVAILED
746	7-Jun-2020	BAGALKOT	220	AMBEWADI-PONDA2	AMBEWADI_220	14:36	15:38	1:02	LINE FAULT
747	7-Jun-2020	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	9:03	14:31	5:28	LINE CLEAR AVAILED
748	7-Jun-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110,KARADI_33, AMINAGAD_33,MYTRA SOLAR_33	13:26	13:32	0:06	TRANSFORMER FAULT
749	7-Jun-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110,KARADI_33,AMINAGAD_33, MYTRA SOLAR_34	13:34	13:38	0:04	TRANSFORMER FAULT
750	7-Jun-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110,KARADI_33,AMINAGAD_33, MYTRA SOLAR_35	14:15	14:16	0:01	TRANSFORMER FAULT
751	7-Jun-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110,KARADI_33,AMINAGAD_33, MYTRA SOLAR_36	15:42	15:43	0:01	TRANSFORMER FAULT
752	7-Jun-2020	BAGALKOT	110	110/11KV,HV2	HUNGUND_110,KARADI_33,AMINAGAD_33, MYTRA SOLAR_37	17:05	17:07	0:02	TRANSFORMER FAULT
753	7-Jun-2020	BAGALKOT	110	VIJAYANAGAR SUGARS-MUNDARGI	MUNDARGI_110	12:11	13:10	0:59	LINE CLEAR AVAILED
754	7-Jun-2020	BAGALKOT	110	110/11KV, HV2	MUNVALLI_110	13:13	13:18	0:05	TRANSFORMER FAULT
755	7-Jun-2020	BAGALKOT	110	MK HUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	8:57	16:26	7:29	LINE CLEAR AVAILED
756	7-Jun-2020	BAGALKOT	110	MK HUBLI220- HIREBAGEWADI	HIREBAGEWADI_110	17:01	19:34	2:33	LINE CLEAR AVAILED
757	7-Jun-2020	BAGALKOT	110	MK HUBLI220- BAILHONGAL	BAILHONGAL_110	10:01	16:14	6:13	LINE CLEAR AVAILED
758	7-Jun-2020	BENGALURU	66	ADUGODI - HSR LAYOUT 1 & 2	ADUGODI, BOSCH (EHT)	8:15	8:23	0:08	LOAD CHANGE OVER
759	7-Jun-2020	BENGALURU	66	HV2	BYADRAHALLI	12:29	14:32	2:03	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
760	7-Jun-2020	BENGALURU	66	ELECTRONIC CITY PH-2 SEC-2 - KEONIC CITY	ELECTRONIC CITY PH-2 SEC-2	16:59	17:08	0:09	LOAD CHANGE OVER
761	7-Jun-2020	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	5:45	5:50	0:05	LOAD CHANGE OVER
762	7-Jun-2020	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	16:00	16:05	0:05	LOAD CHANGE OVER
763	7-Jun-2020	BENGALURU	66	HAMUMANTHNAGAR - KANAKAPURA 220	HANUMANTHNAGAR	11:15	12:20	1:05	MAIN SUPPLY FAILURE
764	7-Jun-2020	BENGALURU	220	NAGANATHPURA 220 - SOMANAHALLI 220	NAGANATHPURA 220	10:48	11:03	0:15	LOAD CHANGE OVER
765	7-Jun-2020	BENGALURU	220	NAGANATHPURA 220 - HSR LAYOUT 66	NAGANATHPURA 220	16:49	16:53	0:04	LOAD CHANGE OVER
766	7-Jun-2020	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	7:05	7:10	0:05	LOAD CHANGE OVER
767	7-Jun-2020	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	16:05	16:10	0:05	LOAD CHANGE OVER
768	7-Jun-2020	BENGALURU	66	T K HALLI 220 - BWSSB 2	NO STATION AFFECTED	11:17	12:22	1:05	LINE FAULT
769	7-Jun-2020	BENGALURU	66	YEDUMADU - KANAKPURA 220	YEDUMADU	11:15	12:07	0:52	LOAD CHANGE OVER
770	7-Jun-2020	BENGALURU	66	HV2	SOMAYAJANAHALLI	12:10	12:22	0:12	TRANSFORMER FAULT
771	7-Jun-2020	BENGALURU	66	HV1	SM MANGALA	8:03	8:42	0:39	LINE CLEAR AVAILED
772	7-Jun-2020	BENGALURU	400	NELMANGALA 400 - HIRIYUR 2	NO STATION AFFECTED	0:46	7:22	6:35	LINE FAULT
773	7-Jun-2020	BENGALURU	400	NELAMANGALA 400 - MYSORE 2	NO STATION AFFECTED	0:47	7:12	6:25	LINE FAULT
774	7-Jun-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	7:26	7:28	0:02	LINE CLEAR AVAILED
775	7-Jun-2020	BENGALURU	66	NELAMANGALA 66 - DABUSPET 220	NELAMANGALA 66	16:03	16:05	0:01	LINE CLEAR AVAILED
776	7-Jun-2020	BENGALURU	66	HV1	HOSKOTE 66	3:32	3:51	0:18	LINE CLEAR AVAILED
777	7-Jun-2020	BENGALURU	66	HV1	HOSPALYA CIRCLE	13:14	14:40	1:25	LINE CLEAR AVAILED
778	7-Jun-2020	BENGALURU	66	HV2	KANAKAPURA 66	11:46	11:49	0:02	LINE CLEAR AVAILED
779	7-Jun-2020	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, GODUR, HANUMANTHNAGAR, YEDUMADU	11:13	14:57	6:35	LINE FAULT
780	7-Jun-2020	BENGALURU	220	HV1	KANAKAPURA 220	11:13	11:33	6:25	TRANSFORMER FAULT
781	7-Jun-2020	BENGALURU	220	HV2	KANAKAPURA 220	11:13	11:33	0:02	TRANSFORMER FAULT
782	7-Jun-2020	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	7:28	7:34	0:01	LOAD CHANGE OVER
783	7-Jun-2020	BENGALURU	66	ALUR - NELAMANGALA 66	ALUR	16:03	16:13	0:18	LOAD CHANGE OVER
784	7-Jun-2020	BENGALURU	66	HV2	YELAHANKA 220	23:10:52(6-6-2020)	18:21:35(7-6-2020)	19:09hrs	TRANSFRMER CHARGED
785	7-Jun-2020	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
786	7-Jun-2020	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
787	7-Jun-2020	BENGALURU	66	HV1	KGF	19:50:14(06-06-2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
788	7-Jun-2020	GULBARGA	110	HUMNABAD-CHITAGUPPA	HUMNABAD_220	12:36	12:45	0:09	LINE FAULT
789	7-Jun-2020	GULBARGA	110	HV1	SHAHAPUR_220	9:40	9:48	0:08	TRANSFORMER FAULT
790	7-Jun-2020	GULBARGA	110	HV2	DEODURGA_110	13:08	13:32	0:24	TRANSFORMER FAULT
791	7-Jun-2020	GULBARGA	110	HV3	KOLHAR_110	10:04	15:43	5:39	LINE CLEAR AVAILED
792	7-Jun-2020	GULBARGA	110	YELBURGA-KUSHTAGI	YELBURGA_110	10:50	11:20	0:30	MAIN SUPPLY FAILURE
793	7-Jun-2020	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
794	7-Jun-2020	GULBARGA	220	HV1	KUSTAGI_220	10:48	11:00	0:12	TRANSFORMER FAULT
795	7-Jun-2020	GULBARGA	66	HV1	HANASI_66	16:26	16:53	0:27	TRANSFORMER FAULT
796	7-Jun-2020	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
797	7-Jun-2020	GULBARGA	66	BANAVEKAL-KUDLIGI	BANVEKAL_66	9:25	9:40	0:15	MAIN SUPPLY FAILURE
798	7-Jun-2020	GULBARGA	66	BANAVEKAL-KUDLIGI	BANVEKAL_66	15:15	15:30	0:15	MAIN SUPPLY FAILURE

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
799	7-Jun-2020	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
800	7-Jun-2020	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
801	7-Jun-2020	HASSAN	400	HASSAN4-UPCL1	SHANTHIGRAMA_400	17:15(07.06.2020)			LINE OPEN, LINE CLEAR AVAILED
802	7-Jun-2020	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(07.06.2020)			LINE OPEN, LINE CLEAR AVAILED
803	7-Jun-2020	HASSAN	220	HV2	KAVOOR_220	9:29	11:43	2:14	LINE CLEAR AVAILED
804	7-Jun-2020	HASSAN	110	KAVOOR-KLSKR2	KAVOOR_220	2:45	17:30	14:45	LINE FAULT
805	7-Jun-2020	HASSAN	110	LV2	KAVOOR_220	9:29	11:44	2:15	LINE CLEAR AVAILED
806	7-Jun-2020	HASSAN	110	HV2	KONAJE_110	3:19	3:41	0:22	MAIN SUPPLY FAILURE
807	7-Jun-2020	HASSAN	110	KULASH-KAVOOR 2	KULASHEKARA_110	2:45	17:33	14:48	LINE CLEAR AVAILED
808	7-Jun-2020	HASSAN	66	HV1	AREHALLI_66	9:09	10:49	1:40	LINE CLEAR AVAILED
809	7-Jun-2020	HASSAN	66	HV1	MAGGE_66	11:25	11:50	0:25	TRANSFORMER FAULT
810	7-Jun-2020	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	11:25	11:42	0:17	LINE FAULT
811	7-Jun-2020	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
812	7-Jun-2020	MYSURU	220	VAJMANGALA-TK HALLI	NO STATIONS EFFECTED	15:11	15:32	0:21	LINE FAULT
813	7-Jun-2020	MYSURU	66	MADHUVANAHALLI-KOLLEGALA1	KOLLEGALA_66	11:33	15:02	3:29	NFBC ISSUED
814	7-Jun-2020	MYSURU	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:11	16:23	5:11	NFBC ISSUED
815	7-Jun-2020	MYSURU	66	HAMPAPURA-MANDYA	HAMPAPURA_66 BASARALU_66, BESAGARAHALLI_66, KOPPA_66	15:17	15:30	0:13	LINE FAULT
816	7-Jun-2020	MYSURU	66	HV2	HONNALLY_MYS_66	15:16	15:24	0:07	TRANSFORMER FAULT
817	7-Jun-2020	MYSURU	66	KADAKOLA-SARGUR 2	CHANDRAVADI_66 DOORA_66 HULLAHALLI_66 HURA_66,	9:29	15:05	5:36	LINE CLEAR AVAILED
818	7-Jun-2020	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HAMPAPURA(K)_66 HDKOTE_66 ANTHARSANTHE_66 B MATKERE_66 SANTHESARAGUR_66	9:27	15:05	5:38	LINE CLEAR AVAILED
819	7-Jun-2020	MYSURU	66	HV1	K_HONNALGERE_66	11:17	11:38	0:20	TRANSFORMER FAULT
820	7-Jun-2020	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	KOLLEGALA_66	11:33	15:04	3:30	NFBC ISSUED
821	7-Jun-2020	MYSURU	66	KOLLEGALA-SATHEGALA	KOLLEGALA_66	11:22	16:13	4:51	NFBC ISSUED
822	7-Jun-2020	MYSURU	66	KOLLEGALA-TALKADU	KOLLEGALA_66	10:45	16:15	5:29	NFBC ISSUED
823	7-Jun-2020	MYSURU	66	SFC SIVA-PPCL	NO STATIONS EFFECTED	10:22	11:36	1:13	LINE CLEAR AVAILED
824	7-Jun-2020	MYSURU	66	TUBINKERE-ARAKERE	GAMANAHALLY_66 TARIPURA_66 ARAKERE_66	16:26	16:30	0:04	LINE FAULT
825	7-Jun-2020	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 MALAVALLI_66 HADLI_66 KOLKARANADODDI_66	9:03	15:12	6:08	LINE CLEAR AVAILED
826	7-Jun-2020	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 MALAVALLI_66 HADLI_66 KOLKARANADODDI_66	9:03	15:12	6:09	LINE CLEAR AVAILED
827	7-Jun-2020	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
828	7-Jun-2020	TUMKUR	110	TR-2	SAMPIGE_110	3:20:55 PM(02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
829	7-Jun-2020	TUMKUR	66	TR-2	YNHOSKOTE_66	5:15:25 PM(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
830	7-Jun-2020	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	9:00:37 PM(06.06.2020)			LOAD CURTAILMENT
831	7-Jun-2020	TUMKUR	110	TR-1	SAMPIGE_110	10:22	12:01	1:39	LINE CLEAR AVAILED
832	7-Jun-2020	TUMKUR	66	TR-1	CHITRADURGA_66	21:12	21:56	0:44	TRANSFORMER FAULT
833	7-Jun-2020	TUMKUR	66	TR-1	CHITRADURGA_66	21:56	23:15	1:18	LINE CLEAR AVAILED
834	7-Jun-2020	TUMKUR	66	TR-2	HALUVAGALU_66	6:53	7:06	0:12	TRANSFORMER FAULT
835	7-Jun-2020	TUMKUR	66	TR-2	HALUVAGALU_66	12:56	13:05	0:09	TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
836	7-Jun-2020	TUMKUR	66	KUKKAWADA- LINGADAHALLI	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:40	12:49	0:09	LINE FAULT
837	7-Jun-2020	TUMKUR	66	TR-1	MYLANAHALLI_66	12:45	12:53	0:08	TRANSFORMER FAULT
838	7-Jun-2020	TUMKUR	66	TR-1	NEELAGUNDA_220	9:19	9:34	0:15	TRANSFORMER FAULT
839	7-Jun-2020	TUMKUR	66	PAVAGADA-NAGALAMADIKE	PAVAGADA_220	17:58	18:04	0:05	LINE FAULT
840	08-Jun-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41(25.05.2020)			LINE OPEN, LINE FAULT
841	08-Jun-20	BAGALKOT	110	RATTIHALLI-HIREKERUR	NO STATION EFFECTED RATTIHALLI_110	16:34(28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
842	08-Jun-20	BAGALKOT	110	KUDALSANGAM -ACHANUR	NO STATION EFFECTED ACHANUR_110	18:26(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
843	08-Jun-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	NO STATION EFFECTED LOKAPUR_110	21:11(29.05.2020)			LINE OPEN, LINE CLEAR AVAILED
844	08-Jun-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1&2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN, LINE CLEAR AVAILED
845	08-Jun-20	BAGALKOT	110	TARIHAL-TADASINAKOPPA	NO STATION EFFECTED TARIHAL_110	18:43 (05.06.2020)			LINE OPEN, LINE CLEAR AVAILED
846	08-Jun-20	BAGALKOT	110	DHARWADBIO- NAVALGUND	NO STATION EFFECTED NAVALGUND_110	17:11 (06.06.2020)			LINE OPEN, LINE CLEAR AVAILED
847	08-Jun-20	BAGALKOT	110	110/11KV,HV2	AINAPUR_110	19:21	19:30	0:09	LOAD CURTAILMENT
848	08-Jun-20	BAGALKOT	110	110/11KV,HV1	BIJAPUR CITY_110	13:34	13:43	0:09	HAND TRIPPED
849	08-Jun-20	BAGALKOT	110	110/11KV,HV1	BELGAUM_110	10:37	18:05	7:28	LINE CLEAR AVAILED
850	08-Jun-20	BAGALKOT	110	MAHALINGPUR -DHAVALESHWAR	DHAVALESHWAR_110	10:57	13:01	2:04	NFBC ISSUED
851	08-Jun-20	BAGALKOT	110	110/11KV,HV4	GAJENDRAGAD_110	19:21	19:43	0:22	LOAD CURTAILMENT
852	08-Jun-20	BAGALKOT	110	10/11KV,HV3	GOPANAKOPPA_110	15:51	16:40	0:49	LINE CLEAR AVAILED
853	08-Jun-20	BAGALKOT	110	110/33KV,HV1	HANGAL_110,PALA_33	20:26	20:39	0:13	LOAD CURTAILMENT
854	08-Jun-20	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110	15:22	15:32	0:10	TRANSFORMER FAULT
855	08-Jun-20	BAGALKOT	110	110/11KV,HV2	HIDIKAL_110	19:14	19:20	0:06	LOAD CURTAILMENT
856	08-Jun-20	BAGALKOT	110	110/33KV,HV3	HIDIKAL_110ALAGAWADI_33,KOLIGUDDA_33	19:21	19:26	0:05	LOAD CURTAILMENT
857	08-Jun-20	BAGALKOT	110	110/11KV,HV1	KUDALASANGAM_110	19:21	19:26	0:05	TRANSFORMER FAULT
858	08-Jun-20	BAGALKOT	110	MK HUBLI220-HIREBAGEWADI	HIREBAGEWADI_110	7:00	8:27	1:27	LINE CLEAR AVAILED
859	08-Jun-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	16:12	16:24	0:12	TRANSFORMER FAULT
860	08-Jun-20	BAGALKOT	110	110/33KV, HV2	SAVALAGI_110, KALABILAGI_33, TUNGAL LIS_33, HIREPADASALAGI LIS_33	19:21	19:52	0:31	LOAD CURTAILMENT
861	08-Jun-20	BAGALKOT	110	110/11KV, HV2	SANKESHWAR_110	19:21	19:37	0:16	LOAD CURTAILMENT
862	08-Jun-20	BAGALKOT	110	110/11KV, HV2	RAIBAG_110	19:21	19:27	0:06	LOAD CURTAILMENT
863	08-Jun-20	BAGALKOT	110	HSSK-NIPPANI	NIPPANI_110	15:07	15:10	0:03	LINE FAULT
864	08-Jun-20	BAGALKOT	110	110/11KV, HV3	NIPPANI_110	15:06	15:13	0:07	TRANSFORMER FAULT
865	08-Jun-20	BAGALKOT	110	MRUTHYUNJAY NAGRA - NARENDRA2 (UAS)	UAS DHARWAD_110	12:47	15:09	2:22	LINE CLEAR AVAILED
866	08-Jun-20	BAGALKOT	220	BAGALKOT-VAJRAMATTI1	NO STATION EFFECTED BAGALKOT_220	9:16 (30.04.2020)			LINE OPEN, LINE FAULT
867	08-Jun-20	BAGALKOT	220	HARTI1&2-GADAG	NO STATION EFFECTED GADAG_220	22:43 (17.05.2020)	14:45(08.06.2020)	519 hrs	LINE CHARGED
868	08-Jun-20	BAGALKOT	220	SIRSI-HUBLI1	NO STATION EFFECTED SIRSI_220	17:36 (18.05.2020)			LOAD CURTAILMENT



SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
869	08-Jun-20	BAGALKOT	220	SIRSI-HUBLI2	NO STATION EFFECTED SIRSI_220	17:39 (18.05.2020)			LOAD CURTAILMENT
870	08-Jun-20	BAGALKOT	220	RAVIURJA2(KAKAMARI)-ATHANI	NO STATION EFFECTED ATHANI_220	17:49 (31.05.2020)			LINE OPEN, LINE CLEAR AVAILED
871	08-Jun-20	BAGALKOT	220	NNARENDRA1-AMBEWADI	NO STATION EFFECTED AMBEWADI_220	23:20 (06.06.2020)	18:26 (08.06.2020)	43 hrs	LINE CHARGED
872	08-Jun-20	BAGALKOT	220	GUTTUR- RANEENNUR	NO STATION EFFECTED RANEENNUR_220	11:23 (06.06.2020)			LOAD CURTAILMENT
873	08-Jun-20	BAGALKOT	220	AMBEWADI-NARENDRA 2	AMBEWADI_220	11:21	18:26	7:05	LINE CLEAR AVAILED
874	08-Jun-20	BAGALKOT	220	220/110KV, HV1& LV1	NARENDRA_220	17:26	17:50	0:24	TRANSFORMER FAULT
875	08-Jun-20	BAGALKOT	220	220/110KV, HV1& LV1	KARWAR_220	12:11	12:43	0:32	LINE CLEAR AVAILED
876	08-Jun-20	BENGALURU	66	ADUGODI - NIMHANS 220	ADUGODI, BOSCH (EHT)	6:00	6:22	0:22	LOAD CHANGE OVER
877	08-Jun-20	BENGALURU	66	HV1	HANUMANTHNAGARA	13:40	15:00	1:20	LINE CLEAR AVAILED
878	08-Jun-20	BENGALURU	66	HV2	HANUMANTHNAGARA	13:40	15:10	1:30	LINE CLEAR AVAILED
879	08-Jun-20	BENGALURU	66	HANUMANTHNAGAR - SOMANAHALLI 220	HANUMANTHNAGAR	6:30	6:35	0:05	LOAD CHANGE OVER
880	08-Jun-20	BENGALURU	66	HV1	KADUGODI	15:11	15:46	0:35	LINE CLEAR AVAILED
881	08-Jun-20	BENGALURU	66	HV2	KADUGODI	1:06	1:33	0:27	TRANSFORMER FAULT
882	08-Jun-20	BENGALURU	66	HV2	VIJAYANAGARA	14:17	14:26	0:09	LOAD CHANGE OVER
883	08-Jun-20	BENGALURU	66	HV2	ATTUR YELAHANKA	11:10	11:13	0:03	LINE CLEAR AVAILED
884	08-Jun-20	BENGALURU	66	HV1	ATTUR YELAHANKA	13:21	13:35	0:14	LINE CLEAR AVAILED
885	08-Jun-20	BENGALURU	66	CHINTAMANI 220 - IRAGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	20:10	20:32	0:22	LOAD CURTAILMENT
886	08-Jun-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	19:24	19:44	0:20	LOAD CURTAILMENT
887	08-Jun-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:28	6:44	0:16	LINE FAULT
888	08-Jun-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	20:25	20:46	0:21	LOAD CURTAILMENT
889	08-Jun-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	20:04	20:25	0:21	LOAD CURTAILMENT
890	08-Jun-20	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	19:24	19:45	0:21	LOAD CURTAILMENT
891	08-Jun-20	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	20:05	20:25	0:20	LOAD CURTAILMENT
892	08-Jun-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	19:25	19:45	0:20	LOAD CURTAILMENT
893	08-Jun-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	19:45	20:05	0:20	LOAD CURTAILMENT
894	08-Jun-20	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	19:44	20:02	0:18	LOAD CURTAILMENT
895	08-Jun-20	BENGALURU	66	LAKSHMIPURA - SOMAYAJANAHALLI	SOMAYAJANAHALLI	19:43	20:01	0:18	LOAD CURTAILMENT
896	08-Jun-20	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	19:26	20:39	1:13	LOAD CURTAILMENT
897	08-Jun-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	6:28	6:44	0:16	LOAD CURTAILMENT
898	08-Jun-20	BENGALURU	66	WELCAST - ABBIGERE	WELCAST	15:32	15:35	0:03	LOAD CHANGE OVER
899	08-Jun-20	BENGALURU	66	WELCAST - SRS PEENYA 220	WELCAST	17:52	17:55	0:03	LOAD CHANGE OVER
900	08-Jun-20	BENGALURU	66	HV1	YELAHANKA 220	0:05	0:21	0:16	TRANSFORMER FAULT
901	08-Jun-20	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	6:30	6:40	0:10	LOAD CHANGE OVER
902	08-Jun-20	BENGALURU	66	HV1	KODIHALLI	10:01	10:45	0:44	LINE CLEAR AVAILED
903	08-Jun-20	BENGALURU	66	JAYADEVA - SARAKKI 2	NO STATION AFFECTED	16:14 (27-5-2020)			LINE OPEN, LINE FAULT
904	08-Jun-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN, LINE FAULT
905	08-Jun-20	BENGALURU	66	HV1	KGF	19:50:14(06-06-2020)			TRANSFORMER OPEN,TRANSFORMER FAULT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
906	08-Jun-20	GULBARGA	66	HV1	SOVENAHALLI_66	19:20	19:25	0:05	LOAD CURTAILMENT
907	08-Jun-20	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	9:00	9:05	0:05	LINE CLEAR AVAILED
908	08-Jun-20	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	9:50	10:20	0:30	MAIN SUPPLY FAILURE
909	08-Jun-20	GULBARGA	66	HV2	TAMBRAHALLI_66	8:40	16:30	4:27	LINE CLEAR AVAILED
910	08-Jun-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	7:53	8:03	1:27	LINE FAULT
911	08-Jun-20	GULBARGA	110	RAICHUR-MATMARI	MATMARI_110	19:46	21:01	2:27	LINE CLEAR AVAILED
912	08-Jun-20	GULBARGA	110	RAICHUR-SHAHAPUR2	GOOGLE_110	19:46	21:01	2:27	LINE CLEAR AVAILED
913	08-Jun-20	GULBARGA	110	HV1	HANUMNAL_110	15:45	16:00	3:27	TRANSFORMER FAULT
914	08-Jun-20	GULBARGA	110	HV3	ALAND_110	19:20	19:35	0:15	LOAD CURTAILMENT
915	08-Jun-20	GULBARGA	110	HV3	BEVOOR_110	6:50	6:55	0:05	TRANSFORMER FAULT
916	08-Jun-20	GULBARGA	110	HV2	CHINCHOLI_110	19:20	19:40	0:20	LOAD CURTAILMENT
917	08-Jun-20	GULBARGA	110	HV4	DEODURGA_110	18:15	18:20	0:05	TRANSFORMER FAULT
918	08-Jun-20	GULBARGA	110	HV3	DEODURGA_110	18:15	18:40	0:25	LINE CLEAR AVAILED
919	08-Jun-20	GULBARGA	110	HV2	DEODURGA_110	9:47	9:58	0:11	TRANSFORMER FAULT
920	08-Jun-20	GULBARGA	110	HV2	HATTI_110	20:25	20:28	0:03	LOAD CURTAILMENT
921	08-Jun-20	GULBARGA	110	HV2	JEWARGI_110	19:20	19:26	0:06	LOAD CURTAILMENT
922	08-Jun-20	GULBARGA	110	HV2	JEWARGI_110	20:26	20:36	0:10	LOAD CURTAILMENT
923	08-Jun-20	GULBARGA	110	HV1	KEMBHAVI_110	19:20	19:25	0:05	LOAD CURTAILMENT
924	08-Jun-20	GULBARGA	110	HV1	KURKUNTA_110	19:21	19:30	0:09	LOAD CURTAILMENT
925	08-Jun-20	GULBARGA	110	HV1	KURKUNTA_110	20:25	20:30	0:05	LOAD CURTAILMENT
926	08-Jun-20	GULBARGA	110	HV1	MAHAGOAN_110	19:21	19:37	0:16	LOAD CURTAILMENT
927	08-Jun-20	GULBARGA	110	HV1	MAHAGOAN_110	20:26	20:40	0:14	LOAD CURTAILMENT
928	08-Jun-20	GULBARGA	110	HV1	PD_HALLI_110	19:21	19:25	0:04	LOAD CURTAILMENT
929	08-Jun-20	GULBARGA	110	HV1	PD_HALLI_110	20:26	20:30	0:04	LOAD CURTAILMENT
930	08-Jun-20	GULBARGA	220	KAPNOOR-SHAHPUR	NO STATION AFFECTED	17:15(17.4.2020)			LINE OPEN, LINE FAULT
931	08-Jun-20	GULBARGA	220	KAPNOOR-SHAHBAD	NO STATION AFFECTED	19:15(2.6.2020)			LINE OPEN, LINE CLEAR AVAILED
932	08-Jun-20	HASSAN	110	HV2	AJJAMPURA_110	16:45	18:10	1:25	LINE CLEAR AVAILED
933	08-Jun-20	HASSAN	110	GAJNUR-IPP IC LINE	GAJNUR_110	14:45	17:10	2:25	LINE CLEAR AVAILED
934	08-Jun-20	HASSAN	110	HV3	GURUVAYANAKERE_110	10:18	14:23	4:05	LINE CLEAR AVAILED
935	08-Jun-20	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	8:55	8:58	0:03	HAND TRIPPED
936	08-Jun-20	HASSAN	110	MRSSHM-BADRAVATY1	MRSMG_220	9:01	9:03	0:02	HAND TRIPPED
937	08-Jun-20	HASSAN	110	MRSSHM-MPM	MRSMG_220	10:21	10:39	0:18	LINE FAULT
938	08-Jun-20	HASSAN	220	KEMAR-Varahi3	KEMAR_220	10:37	13:34	2:57	LINE CLEAR AVAILED
939	08-Jun-20	HASSAN	220	VRAHI-KEMAR3	varahi_gen	10:37	13:34	2:57	NFBC ISSUED
940	08-Jun-20	HASSAN	400	UPCL-HASSAN2	STATION NOT AFFECTED	14:29 (01.06.2020)			LINE OPEN, LINE CLEAR AVAILED
941	08-Jun-20	HASSAN	400	HASSAN40-UPCL1	HASSAN40	17:15(07.06.2020)	8:24	15:08 hrs	LINE CHARGED
942	08-Jun-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	17:15(07.06.2020)	8:24	15:08 hrs	LINE CHARGED
943	08-Jun-20	HASSAN	66	BHADRA-LINGADAHALLI	STATION NOT AFFECTED	16:30 (20.05.2020)			LINE OPEN, LINE CLEAR AVAILED
944	08-Jun-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	9:23	16:08	6:45	LINE CLEAR AVAILED
945	08-Jun-20	HASSAN	66	HV2	CHANNARAYAPATNA_66	20:25	20:32	0:07	LOAD CURTAILMENT
946	08-Jun-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	22:16 (8.06.2020)			LINE OPEN, LINE CLEAR AVAILED
947	08-Jun-20	HASSAN	66	SAKALE-IPCL1	SAKLESH PURA_66	9:59	16:05	6:06	LINE CLEAR AVAILED
948	08-Jun-20	HASSAN	66	SAKALE-IIPCL2	SAKLESH PURA_66	9:59	16:05	6:06	LINE CLEAR AVAILED

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
949	08-Jun-20	MYSURU	66	DK MAIDANA-JYOTHINAGARA	NO STATIONS EFFECTED	17:35 (28.05.2020)			LINE OPEN, LINE CLEAR AVAILED
950	08-Jun-20	MYSURU	66	HV2	AKKIHEBBAL_66	20:25	20:44	0:18	LOAD CURTAILMENT
951	08-Jun-20	MYSURU	66	HV2	BOOKANAKERE_66	20:25	20:32	0:06	LOAD CURTAILMENT
952	08-Jun-20	MYSURU	66	HV2	CHINAKURALI_66	20:25	20:45	0:19	LOAD CURTAILMENT
953	08-Jun-20	MYSURU	66	DEVNUR(N'GUD)-BAS1	NO STATIONS EFFECTED	11:45	12:32	0:46	LINE CLEAR AVAILED
954	08-Jun-20	MYSURU	66	HV1	HANNUR_66	16:27	18:51	2:23	LINE CLEAR AVAILED
955	08-Jun-20	MYSURU	66	HV2	HANNUR_66	11:03	16:28	5:24	LINE CLEAR AVAILED
956	08-Jun-20	MYSURU	66	HV2	HDKOTE_66	13:31	14:38	1:07	LINE CLEAR AVAILED
957	08-Jun-20	MYSURU	66	HD KOTE-KADAKOLA	HDKOTE_66 ANTHARSANTHE_66	9:55	13:34	3:39	LINE FAULT
958	08-Jun-20	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	15:20	15:29	0:09	LINE FAULT
959	08-Jun-20	MYSURU	66	KADAKOLA-NANJANGUDU 2	NO STATIONS EFFECTED	15:29	19:22	3:52	LINE FAULT
960	08-Jun-20	MYSURU	66	KADAKOLA-SARGUR 2	DOORA_66 HULLAHALLI_66 HURA_66 B MATKERE_66 SANTHESARAGUR_66 CHANDRAVADI_66	19:44	20:04	0:19	LOAD CURTAILMENT
961	08-Jun-20	MYSURU	66	KADAKOLA-SARGUR 1	JAIPUR_66 HDKOTE_66 ANTHARSANTHE_66 HAMPAPURA(K)_66	19:41	20:04	0:22	LOAD CURTAILMENT
962	08-Jun-20	MYSURU	66	HV4	KUSHALANAGARA_66	15:17	15:43	0:25	TRANSFORMER FAULT
963	08-Jun-20	MYSURU	66	KUSHALNAGARA 220-MYSORE-2	NO STATIONS EFFECTED	14:32	14:42	0:10	LINE FAULT
964	08-Jun-20	MYSURU	66	HV5	SFCSHIVA_66	13:15	17:03	3:47	LINE CLEAR AVAILED
965	08-Jun-20	MYSURU	66	TUBINKERE-ARAKERE	ARAKERE, GAMANAHALLI & TARIPURA	12:43	12:54	0:11	HAND TRIPPED
966	08-Jun-20	MYSURU	66	HV1	YELANDUR_66	20:25	20:35	0:09	LOAD CURTAILMENT
967	08-Jun-20	TUMKUR	66	HIRIYUR 220KV-CHALLAKERE	CHALLAKERE_66, SANIKERE_66	16:26:50(26.05.20)			LINE OPEN, LINE FAULT
968	08-Jun-20	TUMKUR	66	TR-2	YNHOSKOTE_66	17:15(05.06.2020)			TRANSFORMER OPEN,TRANSFORMER FAULT
969	08-Jun-20	TUMKUR	66	AMRUTHUR-ANCHEPALYA	AMRUTHUR_66	19:23	20:15	0:52	LOAD CURTAILMENT
970	08-Jun-20	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	19:22	20:15	0:53	LOAD CURTAILMENT
971	08-Jun-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	11:33	11:40	0:07	LINE FAULT
972	08-Jun-20	TUMKUR	66	BUKKAPATNA-GOLDEN HATCHERIES_IPP_66	GOLDEN HATCHERIES_IPP_66	20:15	20:35	0:20	MAIN SUPPLY FAILURE
973	08-Jun-20	TUMKUR	66	TR-1	CHANNAGIRI_66	9:14	9:24	0:09	TRANSFORMER FAULT
974	08-Jun-20	TUMKUR	66	TR-1	CHITRADURGA_66	12:29	15:09	2:39	LINE CLEAR AVAILED
975	08-Jun-20	TUMKUR	66	TR-1	CHITRADURGA_66	15:40	16:50	1:09	TRANSFORMER FAULT
976	08-Jun-20	TUMKUR	66	TR-1	CHITRADURGA_66	17:41	18:29	0:47	LINE CLEAR AVAILED
977	08-Jun-20	TUMKUR	66	TR-1	CHITRADURGA_66	18:52	19:40	0:47	LINE CLEAR AVAILED
978	08-Jun-20	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	20:48	21:09	0:20	LINE FAULT
979	08-Jun-20	TUMKUR	66	TR-1	HARIHAR_66	13:58	14:13	0:14	TRANSFORMER FAULT
980	08-Jun-20	TUMKUR	66	TR-1	HARIHAR_66	14:20	14:52	0:31	LINE CLEAR AVAILED
981	08-Jun-20	TUMKUR	66	TR-1	HIEMALLANAHOLE_66	7:20	7:21	0:01	HAND TRIPPED
982	08-Jun-20	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	10:20	12:37	2:17	LINE CLEAR AVAILED
983	08-Jun-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	20:29	20:38	0:08	HAND TRIPPED
984	08-Jun-20	TUMKUR	66	HOLALKERE- RAMGIRI 2	CHIKKAJAJUR_66,MAYAKONDA_66,SASAL UHALLA_66	20:29	20:38	0:08	HAND TRIPPED
985	08-Jun-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	19:33	19:47	0:14	LOAD CURTAILMENT

SL no	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
986	08-Jun-20	TUMKUR	66	MADHUGIRI 220kV- SIRA	SIRA_66,GULIGENAHALLI_66,	20:16	20:24	0:08	LOAD CURTAILMENT
987	08-Jun-20	TUMKUR	66	TR-2	MATHOD_66	14:03	14:10	0:06	TRANSFORMER FAULT
988	08-Jun-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	19:44	19:47	0:02	HAND TRIPPED
989	08-Jun-20	TUMKUR	66	NEELAGUNDA 220kV-TELADI	TELADI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	5:03	5:15	0:12	LINE FAULT
990	08-Jun-20	TUMKUR	66	TR-1	SHYLA PURA_66	1:14	1:28	0:14	TRANSFORMER FAULT
991	08-Jun-20	TUMKUR	66	TR-1	THIMMASANDRA_66	19:22	20:24	1:01	MAIN SUPPLY FAILURE
992	08-Jun-20	TUMKUR	66	TR-2	THIMMASANDRA_66	19:22	20:24	1:01	MAIN SUPPLY FAILURE
993	08-Jun-20	TUMKUR	66	TR-1	VENKATAPURA_66	18:17	18:33	0:15	TRANSFORMER FAULT
994	08-Jun-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN,TRANSFORMER FAULT
995	08-Jun-20	TUMKUR	110	TR-1	TURUVEKERE_110	12:17	16:29	4:12	LINE CLEAR AVAILED
996	08-Jun-20	TUMKUR	110	TR-2	TURUVEKERE_110	13:13	15:12	1:59	LINE CLEAR AVAILED
997	08-Jun-20	TUMKUR	110	TURUVEKERE110-KBCROSS	TURUVEKERE_110	13:14	15:11	1:56	LINE CLEAR AVAILED
998	08-Jun-20	TUMKUR	110	TR-1	TANDAGA_110	11:24	16:00	4:35	LINE CLEAR AVAILED
999	08-Jun-20	TUMKUR	400	GUTTUR 400KV- KAIGA400KV	GUTUR_400	21:17 (06.06.2020)	8:17:55 (8.6.20)	35 hrs	LINE CHARGED