400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 03.11.20 to 09.11.20

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open _at	Closed_At	Duration	REASON
1	3-Nov-20	BAGALKOT	66	66/11KV,HV2	HARIHAR HOSPET_66	10:16	11:52	1:36	LINE CLEAR AVAILED
2	3-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
3	3-Nov-20	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	10:14	14:43	4:29	LINE CLEAR AVAILED
4	3-Nov-20	BAGALKOT	110	110/11KV, HV1	SIDDAPUR_110	13:09	14:11	1:02	LINE CLEAR AVAILED
5	3-Nov-20	BAGALKOT	110	110/11KV, HV1	NAREGAL_110	13:15	14:13	0:58	LINE CLEAR AVAILED
6	3-Nov-20	BAGALKOT	110	110/11KV, HV2	YELPARHATTI_110	10:14	14:42	4:28	LINE CLEAR AVAILED
7	3-Nov-20	BAGALKOT	110	110/11KV,HV1	ANKALI_110	14:46	14:49	0:03	TRANSFORMER FAULT
8	3-Nov-20	BAGALKOT	110	110/11KV,HV2	KADANAKOPPA_110	15:35	16:39	1:04	LINE CLEAR AVAILED
9	3-Nov-20	BAGALKOT	110	110/33KV, HV3	RANEBENNUR_220	11:46	17:12	5:26	LINE CLEAR AVAILED
10	3-Nov-20	BAGALKOT	110	110/33KV, HV4	RANEBENNUR_220	16:55 (03.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
11	3-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)			LINE OPEN: LINE FAULT
12	3-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN :LINE CLEAR AVAILED
13	3-Nov-20	BAGALKOT	110	BETAGERI- NAREGAL	NAREGAL_110	13:15	14:12	0:57	LINE CLEAR AVAILED
14	3-Nov-20	BAGALKOT	110	BETAGERI-NAREGALL	NAREGALL_110	13:16	14:12	0:56	HAND TRIPPED
15	3-Nov-20	BAGALKOT	110	GHATAPRABHA-HIDIKAL DAM	GHATAPRABHA_110	16:03	16:29	0:26	HAND TRIPPED
16	3-Nov-20	BAGALKOT	110	GOPANAKOPPA-NARGUND	NARAGUND_110	5:30	13:21	7:51	LINE FAULT
17	3-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN :LINE CLEAR AVAILED
18	3-Nov-20	BAGALKOT	110	HATTARAGI-DADDI	DADDI_110	10:25	10:35	0:10	LINE FAULT
19	3-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
20	3-Nov-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN :LINE CLEAR AVAILED
21	3-Nov-20	BAGALKOT	110	KARAWAR220- ARGA	ARGA_110	10:28	15:51	5:23	LINE CLEAR AVAILED
22	3-Nov-20	BAGALKOT	110	KARAWAR220- SOLARIS	KARWAR_220	10:53	15:51	4:58	LINE CLEAR AVAILED
23	3-Nov-20	BAGALKOT	110	KARAWAR220- SOLARIS	KARWAR_220	16:38	17:20	0:42	HAND TRIPPED
24	3-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN :LINE CLEAR AVAILED
25	3-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
26	3-Nov-20	BAGALKOT	110	KUDACHI220- YELPARHATTI	YELPARHATTI_110	10:15	14:42	4:27	LINE CLEAR AVAILED
27	3-Nov-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN :LINE CLEAR AVAILED
28	3-Nov-20	BAGALKOT	220	220/110KV, HV1&LV1	KARWAR_220	12:54	15:51	2:57	LINE CLEAR AVAILED
29	3-Nov-20	BAGALKOT	220	220/110KV, HV2&LV2	NARENDRA_220	19:49	21:05	1:16	LINE CLEAR AVAILED
30	3-Nov-20	BAGALKOT	220	220/110KV, LV1	KARWAR_220	16:38	19:31	2:53	LINE CLEAR AVAILED
31	3-Nov-20	BAGALKOT	220	220/110KV, LV2	MK HUBLI_220	0:45	7:45	7:00	LINE CLEAR AVAILED
32	3-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
33	3-Nov-20	BAGALKOT	220	AMBEWADI-PONDA 1	AMBEWADI_220	12:11	12:44	0:33	LINE FAULT

34	3-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN :LINE CLEAR AVAILED
35	3-Nov-20	BAGALKOT	220	BELGAUM- CHIKKODI1	BELGAUM_220	17:05	17:19	0:14	LINE CLEAR AVAILED
36	3-Nov-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN :LINE CLEAR AVAILED
37	3-Nov-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN :LINE CLEAR AVAILED
38	3-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN :LINE CLEAR AVAILED
39	3-Nov-20	BAGALKOT	220	HARTI1- BIDNAL	BIDNAL_220	13:02	17:02	4:00	LINE FAULT
40	3-Nov-20	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	12:16 (02.11.2020)			LINE OPEN: LINE FAULT
41	3-Nov-20	BAGALKOT	220	KADRA1- KARWAR	KARWAR_220	10:53	15:51	4:58	LINE CLEAR AVAILED
42	3-Nov-20	BAGALKOT	220	KADRA1- KARWAR	KARWAR_220	16:38 (03.11.2020)			LINE OPEN: LINE FAULT
43	3-Nov-20	BAGALKOT	220	KADRA2- KARWAR	KARWAR_220	10:30	19:20	8:50	LINE CLEAR AVAILED
44	3-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	SIRSI_220	9:03	16:13	7:10	LINE CLEAR AVAILED
45	3-Nov-20	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	12:17 (02.11.2020)			LINE OPEN: LINE FAULT
46	3-Nov-20	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	12:17 (02.11.2020)			LINE OPEN: LINE FAULT
47	3-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
48	3-Nov-20	BENGALURU	66	CHINTAMANI 220 - YENIGADALE	YENIGADALE, CHELUR, CHAKAVELU	10:55	12:10	1:15	LINE CLEAR AVAILED
49	3-Nov-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	13:13	13:15	0:02	LOAD CHANGE OVER
50	3-Nov-20	BENGALURU	66	HSR LAYOUT 220 - JAKKASANDRA	NO STATION AFFECTED	7:44	9:35	1:51	LINE FAULT
51	3-Nov-20	BENGALURU	66	HV1	CHIKKABALLAPURA IND AREA	11:00	11:45	0:45	LINE CLEAR AVAILED
52	3-Nov-20	BENGALURU	66	HV2	AMAR JYOTHI	0:25	2:13	1:48	TRANSFORMER FAULT
53	3-Nov-20	BENGALURU	66	HV2	SADALI	10:59	13:05	2:06	LINE CLEAR AVAILED
54	3-Nov-20	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	7:44	8:04	0:20	MAIN SUPPLY FAILURE
55	3-Nov-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGATUR, SM MANGALA	11:48	14:04	2:16	LINE CLEAR AVAILED
56	3-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:15	10:25	0:10	LINE FAULT
57	3-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:25	11:04	0:39	LINE FAULT
58	3-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:04	11:25	0:21	LINE FAULT
59	3-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:25	14:01	2:36	LINE CLEAR AVAILED
60	3-Nov-20	GULBARGA	110	GABUR-RAICHUR	GABUR_110,DEODURGA_110	5:20	5:25	0:05	MAIN SUPPLY FAILURE
61	3-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN: LINE FAULT
62	3-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN :LINE CLEAR AVAILED
63	3-Nov-20	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	5:20	5:27	0:07	LINE FAULT
64	3-Nov-20	GULBARGA	110	RAICHUR-SHAHAPUR1	GABBUR_110,DEODURGA_110	13:11	23:15	0:07	LINE FAULT
65	3-Nov-20	GULBARGA	110	RAICHUR-SINDHANOOR1	SIRWAR_110,ALKOD_110,BYAGAWAT_110,VAL KAMDINNI_110	17:57	18:08	10:04	LINE FAULT
66	3-Nov-20	GULBARGA	110	RAICHUR-SINDHANOOR2	KURGICROSS_110,MADALAPUR_110,MANVI_1 10	17:57	18:06	0:09	LINE FAULT
67	3-Nov-20	GULBARGA	110	SINDHANOOR-MUNIRABAD1	KARTAGI_110,SREERAMANAGAR_110,GANGAV ATHI_110,VENKATAGIRI_110	11:00	11:30	0:30	LINE CLEAR AVAILED
68	3-Nov-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110, SRERAMNAGAR_110,MALLAPUR_110	11:00	11:30	0:30	LINE CLEAR AVAILED

69	3-Nov-20	GULBARGA	110	SINDHANOOR-MUNIRABAD2	MUKUNDA_110,KAMPLI_110,YERADONA_110, SRERAMNAGAR_110,MALLAPUR_110	12:20	12:30	0:10	LINE FAULT
70	3-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
71	3-Nov-20	HASSAN	66	HV1	MATTANAVILE_66	8:10	8:40	0:30	MAIN SUPPLY FAILURE
72	3-Nov-20	HASSAN	66	HV1	SINGAPURA_66	8:13	8:45	0:32	MAIN SUPPLY FAILURE
73	3-Nov-20	HASSAN	66	HV1	UDAYAPURA_66	12:22	13:27	1:05	LINE CLEAR AVAILED
74	3-Nov-20	HASSAN	66	HV2	MATTANAVILE_66	8:10	8:40	0:30	MAIN SUPPLY FAILURE
75	3-Nov-20	HASSAN	66	HV2	SINGAPURA_66	8:13	8:45	0:32	MAIN SUPPLY FAILURE
76	3-Nov-20	HASSAN	66	HV2	TAVARECHATNAHALLY_66	14:27	14:54	0:27	LINE CLEAR AVAILED
77	3-Nov-20	HASSAN	66	HV2	UDAYAPURA_66	10:47	12:22	1:35	LINE CLEAR AVAILED
78	3-Nov-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	18:51	19:12	0:21	LINE FAULT
79	3-Nov-20	HASSAN	66	MATTNAV-HIRISAVE	MATTANAVILE_66	8:10	9:30	1:20	MAIN SUPPLY FAILURE
80	3-Nov-20	HASSAN	66	MATTNAV-YACHENAHALLY	MATTANAVILE_66	8:10	8:40	0:30	MAIN SUPPLY FAILURE
81	3-Nov-20	HASSAN	110	HALADY11-HOSANGADI	HALADY_110	9:36	13:32	3:56	NFBC ISSUED
82	3-Nov-20	HASSAN	110	HOSNGD-HALDY	HOSANGADI_110	9:30	13:40	4:10	LINE CLEAR AVAILED
83	3-Nov-20	HASSAN	110	HOSNGD-HULIKAL	HOSANGADI_110	9:30	13:40	4:10	LINE CLEAR AVAILED
84	3-Nov-20	HASSAN	110	HV1	ESSUR_110	15:10	16:13	1:03	LINE CLEAR AVAILED
85	3-Nov-20	HASSAN	110	HV1	GURUPURa_110	10:17	12:32	2:15	LINE CLEAR AVAILED
86	3-Nov-20	HASSAN	110	HV1	MOODABIDRE_110	10:00	15:35	5:35	LINE CLEAR AVAILED
87	3-Nov-20	HASSAN	110	HV2	ESSUR_110	16:15	18:09	1:54	LINE CLEAR AVAILED
88	3-Nov-20	HASSAN	110	HV3	MRSMG_220	10:42	10:56	0:14	HAND TRIPPED
89	3-Nov-20	HASSAN	110	HV4	MRSMG_220	10:42	10:56	0:14	HAND TRIPPED
90	3-Nov-20	HASSAN	110	HV4	MANIPAL_110	9:49	10:10	0:21	HAND TRIPPED
91	3-Nov-20	HASSAN	110	HV5	MRSMG_220	10:14	10:32	0:18	HAND TRIPPED
92	3-Nov-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	9:35	18:34	8:59	LINE CLEAR AVAILED
93	3-Nov-20	HASSAN	110	MANIPAL-HIRIYADKA	MANIPAL_110	9:37	10:11	0:34	HAND TRIPPED
94	3-Nov-20	HASSAN	110	MANIPAL-KEMAR1	MANIPAL_110	9:37	10:08	0:31	HAND TRIPPED
95	3-Nov-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	10:28	10:32	0:04	HAND TRIPPED
96	3-Nov-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:33 (3.11.2020)			LINE OPEN :LINE CLEAR AVAILED
97	3-Nov-20	HASSAN	110	SAGARA-JST2	SAGARA_110	12:01(30.10.2020)	17:20 (3.11.2020)	101:19hrs	LINE CHARGED
98	3-Nov-20	HASSAN	220	CRPATNA2-HUYGNH	CRPATNA_220	8:22	8:39	0:17	HAND TRIPPED
99	3-Nov-20	HASSAN	220	CRPATNA2-SHANTHIGRAMA	CRPATNA_220	8:11	8:38	0:27	LINE FAULT
100	3-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
101	3-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	10:58	11:08	0:10	LINE FAULT
102	3-Nov-20	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	19:51 (2.11.2020)	9:46 (3.11.2020)	13:55hrs	LINE CHARGED
103	3-Nov-20	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	10:58	11:08	0:10	LINE FAULT
104	3-Nov-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	9:03	16:13	7:10	LINE CLEAR AVAILED
105	3-Nov-20	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	19:51 (2.11.2020)	9:46 (3.11.2020)	13:55hrs	LINE CHARGED
106	3-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	7:43(2.11.2020)	7:22 (3.11.2020)	23:39hrs	LINE CHARGED
107	3-Nov-20	MYSORE	66	HV1	BASARALU_66	12:04	13:33	1:29	LINE CLEAR AVAILED

108	3-Nov-20	MYSORE	66	HV2	MADHUVANAHALLI_220	13:48 (02/11/2020)	10:27 (03/11/2020)	20.39 HRS	TRANSFORMER CHARGED
109	3-Nov-20	MYSORE	66	HV2	DUNDANAHALLI_66	11:54	13:04	1:10	LINE CLEAR AVAILED
110	3-Nov-20	MYSORE	66	HV2	KHBCOLONY_66	16:07	16:40	0:32	TRANSFORMER FAULT
111	3-Nov-20	MYSORE	66	HV3	KUSHALANAGARA_66	11:26	11:50	0:24	LINE CLEAR AVAILED
112	3-Nov-20	MYSORE	66	KOLLEGALA-SATHEGALA	NO STATIONS EFFECTED	14:03	14:12	0:09	LINE FAULT
113	3-Nov-20	MYSORE	66	KUNTHUR-BANNARI IPP	NO STATIONS EFFECTED	8:36	11:15	2:39	LINE FAULT
114	3-Nov-20	MYSORE	66	MADHUVANAHALLI-HANNUR 1	NO STATIONS EFFECTED	22:07	22:17	0:10	LINE FAULT
115	3-Nov-20	MYSORE	66	MADHUVANAHALLI-HEBBANI	NO STATIONS EFFECTED	11:31	11:43	0:11	LINE FAULT
116	3-Nov-20	MYSORE	66	TUBINKERE-G UKKADA	GARUDANAUKADDA_66 SRIRANGAPATNA_66	12:37	12:38	0:01	HAND TRIPPED
117	3-Nov-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI _66	6:19	6:24	0:04	LINE FAULT
118	3-Nov-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI _66	12:37	12:38	0:01	HAND TRIPPED
119	3-Nov-20	MYSORE	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY _66	12:37	12:38	0:01	HAND TRIPPED
120	3-Nov-20	MYSORE	66	TUBINKERE-PANDAVAPURA	DODDABYADARAHALLI_66 PANDAVAPURA_66	12:37	12:43	0:06	HAND TRIPPED
121	3-Nov-20	MYSORE	220	HV1	TUBINAKERE_220	8:15	10:42	2:27	MAIN SUPPLY FAILURE
122	3-Nov-20	MYSORE	220	HV2	TUBINAKERE_220	8:15	10:42	2:27	MAIN SUPPLY FAILURE
123	3-Nov-20	MYSORE	220	KR PETE 220-CR PATNA	AKKIHEBBAL_66, ANEGOLAL_66, KIKKERI_66, KRISHNAPURA_66, KRPET_220, KRPET_66, SANTHEBACHALLI_66, BOGADHI MANDYA_66, G MALLIGERE_66, GUDDENAHALLI_66, JAKKANAHALLY_66, MADESWARAPURA_66, NAGAMANGALA_66, SHEELUNERE_66, GANJIGERE_66, BOOKANAKERE_66, BANANGADI_66 CHINAKURALI_66	8:12	10:20	2:08	MAIN SUPPLY FAILURE
124	3-Nov-20	MYSORE	220	KR PETE 220-TUBINKERE	TUBINAKERE_220	8:11	10:42	2:31	MAIN SUPPLY FAILURE
125	3-Nov-20	MYSORE	220	KUSHALNAGARA-BASTIPURA 2	NO STATIONS EFFECTED	11:58	12:24	0:26	LINE FAULT
126	3-Nov-20	MYSORE	220	MADHUVANAHALLI-CR NAGARA 1	NO STATIONS EFFECTED	11:05	11:50	0:45	LINE CLEAR AVAILED
127	3-Nov-20	MYSORE	220	TUBINKERE-BASTIPURA	TUBINAKERE_220	8:15	10:00	1:45	LINE FAULT
128	3-Nov-20	MYSORE	220	TUBINKERE-BASTIPURA	NO STATIONS EFFECTED	10:40	14:45	4:05	LINE CLEAR AVAILED
129	3-Nov-20	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 1	CHITRADURGA_66	4:41	4:56	0:14	LINE FAULT
130	3-Nov-20	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 1	CHITRADURGA_66	5:46	6:00	0:14	LINE FAULT
131	3-Nov-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(HONNALLI)	TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	13:47	13:56	0:08	LINE FAULT
132	3-Nov-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	13:47	13:53	0:05	LINE FAULT
133	3-Nov-20	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	13:33	13:39	0:06	HAND TRIPPED
134	3-Nov-20	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	14:09	14:34	0:25	HAND TRIPPED

135	3-Nov-20	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	SIRA_66,GULIGENAHALLI_66,	17:54	17:58	0:04	LINE FAULT
136	3-Nov-20	TUMKUR	66	TR-1	HARIHAR_66	13:38	14:15	0:36	LINE CLEAR AVAILED
137	3-Nov-20	TUMKUR	66	TR-2	CHITRADURGA_66	14:52	15:26	0:34	TRANSFORMER FAULT
138	3-Nov-20	TUMKUR	66	TR-2	HARIHAR_66	12:13	13:18	1:04	LINE CLEAR AVAILED
139	3-Nov-20	TUMKUR	66	TR-2	HIREGUNTANUR_66	6:03	6:09	0:05	TRANSFORMER FAULT
140	3-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
1	4-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
2	4-Nov-20	BAGALKOT	110	110/11KV, HV1	TADASINAKOPPA_110	10:43	14:58	4:15	LINE CLEAR AVAILED
3	4-Nov-20	BAGALKOT	110	110/11KV, HV1	MRUTHYUNJAY NAGAR_110	11:51	15:03	3:12	LINE CLEAR AVAILED
4	4-Nov-20	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	15:22	15:45	0:23	LINE CLEAR AVAILED
5	4-Nov-20	BAGALKOT	110	110/11KV, HV2	MURDESHWAR_110	12:45	13:09	0:24	LINE CLEAR AVAILED
6	4-Nov-20	BAGALKOT	110	110/11KV,HV 1	KULIGOD_110	16:42	17:28	0:46	HAND TRIPPED
7	4-Nov-20	BAGALKOT	110	110/11KV,HV 2	KULIGOD_110	14:18	15:31	1:13	LINE CLEAR AVAILED
8	4-Nov-20	BAGALKOT	110	110/11KV,HV1	ARGA_110	11:56	12:31	0:35	LINE CLEAR AVAILED
9	4-Nov-20	BAGALKOT	110	110/11KV,HV2	ANAND NAGAR_110	12:07	12:48	0:41	LINE CLEAR AVAILED
10	4-Nov-20	BAGALKOT	110	110/33KV, HV3	RANEBENNUR_220	10:16	19:19	9:03	LINE CLEAR AVAILED
11	4-Nov-20	BAGALKOT	110	110/33KV, HV4	STATION NOT AFFECTED RANEBENNUR_220	16:55 (03.11.2020)	10:24 (04.11.2020)	17:29	TRANSFORMER CHARGED
12	4-Nov-20	BAGALKOT	110	110/33KV, HV4	ZALAKI_110, DHULKED_33, NEVARGI_33 & HALASANGI_33	7:01	7:12	0:11	TRANSFORMER FAULT
13	4-Nov-20	BAGALKOT	110	110/33KV,HV1	GADAG_110,LAKKUNDI_33,HULIKOTI_33,MALL ASAMUDRA_IPP,KAPPATGUDDA_IPP,NAGAVI_I PP,PIONEER_IPP,TDPL1&2_IPP	11:28	12:15	0:47	LINE CLEAR AVAILED
14	4-Nov-20	BAGALKOT	110	110/33KV,HV2	HUNGUND_110 & AMINAGAD ,KARADI_33	8:42	8:52	0:10	TRANSFORMER FAULT
15	4-Nov-20	BAGALKOT	110	110/33KV,HV3	KIADB BIJAPUR_110,HONNUTAGI_33,NAGATHAN_33	11:33	11:39	0:06	TRANSFORMER FAULT
16	4-Nov-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	1:03	8:49	7:46	LINE CLEAR AVAILED
17	4-Nov-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	15:33	18:30	2:57	LINE CLEAR AVAILED
18	4-Nov-20	BAGALKOT	110	220/110KV,LV1&LV2	AMBEWADI_220	10:10	16:28	6:18	LINE CLEAR AVAILED
19	4-Nov-20	BAGALKOT	110	220/110KV,LV1&LV2	KARAWAR_220	10:09	16:41	6:32	LINE CLEAR AVAILED
20	4-Nov-20	BAGALKOT	110	AMBEWADI-NK2(KAVALWADA)	STATION NOT AFFECTED KAVALWADA_110	8:56	8:58	0:02	LINE FAULT
21	4-Nov-20	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	16:16	16:28	0:12	LINE FAULT
22	4-Nov-20	BAGALKOT	110	ATHANI220-MAHALINGAPUR	STATION NOT AFFECTED ATHANI_220	16:16	17:17	1:01	LINE FAULT
23	4-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)			LINE OPEN: LINE FAULT
24	4-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN :LINE CLEAR AVAILED
25	4-Nov-20	BAGALKOT	110	BPCL- NARAGUND	NARAGUND_110	13:23	22:15	8:52	LINE CLEAR AVAILED

26	4-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN :LINE CLEAR AVAILED
27	4-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
28	4-Nov-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN :LINE CLEAR AVAILED
29	4-Nov-20	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	16:16	16:24	0:08	LINE FAULT
30	4-Nov-20	BAGALKOT	110	KARAWAR-ARAGA	ARAGA_110	10:02	10:09	0:07	HAND TRIPPED
31	4-Nov-20	BAGALKOT	110	KARAWAR-SOLARIS	SOLARIS(BINAGA)_110	10:03	10:23	0:20	HAND TRIPPED
32	4-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN :LINE CLEAR AVAILED
33	4-Nov-20	BAGALKOT	110	KERUR-KONNUR	KULAGERI CROSS_110	16:14	16:38	0:24	LINE CLEAR AVAILED
34	4-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
35	4-Nov-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN :LINE CLEAR AVAILED
36	4-Nov-20	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	12:18	13:05	0:47	HAND TRIPPED
37	4-Nov-20	BAGALKOT	110	KULIGOD-GAMESH	KULIGOD_110	17:58	18:16	0:18	HAND TRIPPED
38	4-Nov-20	BAGALKOT	110	MAHALINGAPUR-GSML1	MAHALINGAPUR_220	16:15	16:32	0:17	LINE FAULT
39	4-Nov-20	BAGALKOT	110	NARENDRA220- KUD1	STATION NOT AFFECTED KUD DHARWAD_110	12:04	20:05	8:01	LINE CLEAR AVAILED
40	4-Nov-20	BAGALKOT	110	PG HUNSHYAL- MUDALGI	MUDALGI_110	12:45	14:14	1:29	LINE CLEAR AVAILED
41	4-Nov-20	BAGALKOT	110	PG HUNSHYAL- MUDALGI	MUDALGI_110	15:38	18:10	2:32	LINE CLEAR AVAILED
42	4-Nov-20	BAGALKOT	110	PG HUNSHYAL- NAGNUR (MUDALGI)	NAGNUR_110	12:26	15:35	3:09	LINE CLEAR AVAILED
43	4-Nov-20	BAGALKOT	110	SOUDATTI220-UDIKERI(RAMDURG1)	UDIKERI(RAMDURG1)_110	10:50	11:40	0:50	LINE CLEAR AVAILED
44	4-Nov-20	BAGALKOT	220	220/110KV, HV2&LV2	STATION NOT AFFECTED NARENDRA_220	10:54	17:54	7:00	LINE CLEAR AVAILED
45	4-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
46	4-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN :LINE CLEAR AVAILED
47	4-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	0:10	7:53	7:43	LOAD CURTAILMENT
48	4-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:13 (04.11.2020)			LOAD CURTAILMENT
49	4-Nov-20	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	21:17 (04.11.2020)			LOAD CURTAILMENT
50	4-Nov-20	BAGALKOT	220	BIDNAL-HIREKERUR2	STATION NOT AFFECTED BIDNAL_220	12:45	15:15	2:30	LINE CLEAR AVAILED
51	4-Nov-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN :LINE CLEAR AVAILED
52	4-Nov-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)	19:10 (4.11.2020)	463:52 hrs	LINE CHARGED
53	4-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN :LINE CLEAR AVAILED
54	4-Nov-20	BAGALKOT	220	HUBLI-SIRSI2	STATION NOT AFFECTED HUBLI_220	12:16 (02.11.2020)	15:53 (04.11.2020)	51:37 hrs	LINE CHARGED
55	4-Nov-20	BAGALKOT	220	KADRA 2-KARAWAR	KARAWAR_220	10:15	16:09	5:54	LINE CLEAR AVAILED

56	4-Nov-20	BAGALKOT	220	KADRA1- KARWAR	STATION NOT AFFECTED KARWAR_220	16:38 (03.11.2020)	16:06 (4.11.2020)	23:28	LINE FAULT
57	4-Nov-20	BAGALKOT	220	KUDACHI-MAHALINGAPUR 2	KUDACHI_220	16:14	18:43	2:29	LINE FAULT
58	4-Nov-20	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	16:52 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
59	4-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	9:06 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
60	4-Nov-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	12:17 (02.11.2020)	17:39 (04.11.2020)	53:22 hrs	LINE CHARGED
61	4-Nov-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	12:17 (02.11.2020)	16:52 (04.11.2020)	52:35 hrs	LINE CHARGED
62	4-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
63	4-Nov-20	GULBARGA	110	GULBARGASOUTH-FARHATABAD	FARHATABAD_110	15:50	16:40	0:50	LINE CLEAR AVAILED
64	4-Nov-20	GULBARGA	110	GULBARGASOUTH-FARHATABAD	FARHATABAD_110	17:00	18:10	1:10	LINE CLEAR AVAILED
65	4-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN: LINE FAULT
66	4-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	14:04	15:10	1:06	LINE CLEAR AVAILED
67	4-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAWEST	GULBARGAWEST_110	16:40	17:00	0:20	LINE CLEAR AVAILED
68	4-Nov-20	GULBARGA	110	HV3	GULBARGASOUTH_110	17:40	17:55	0:15	LINE CLEAR AVAILED
69	4-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN :LINE CLEAR AVAILED
70	4-Nov-20	GULBARGA	110	SHAHAPUR-KEMBHAVI1	KEMBHAVI_110,ASKI_110,HUNSAGI_110,UGAR SUGAR_IPP	2:29	2:58	0:29	LINE FAULT
71	4-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
72	4-Nov-20	HASSAN	66	HV1	HAGARE_66	11:35	13:00	1:25	LINE CLEAR AVAILED
73	4-Nov-20	HASSAN	66	HV1	MALLAPURA_66	11:08	12:08	1:00	LINE CLEAR AVAILED
74	4-Nov-20	HASSAN	66	HV1	MATTNAVILE_66	1:40	1:45	0:05	MAIN SUPPLY FAILURE
75	4-Nov-20	HASSAN	66	HV1	SIGEBAGE_66	16:25	18:15	1:50	TRANSFORMER FAULT
76	4-Nov-20	HASSAN	66	HV1	BALEHONNUR_66	16:24	16:59	0:35	TRANSFORMER FAULT
77	4-Nov-20	HASSAN	66	HV2	HAGARE_66	10:40	12:00	1:20	LINE CLEAR AVAILED
78	4-Nov-20	HASSAN	66	HV2	MALLAPURA_66	12:09	12:26	0:17	LINE CLEAR AVAILED
79	4-Nov-20	HASSAN	66	HV2	MATTNAVILE_66	1:40	1:45	0:05	MAIN SUPPLY FAILURE
80	4-Nov-20	HASSAN	66	MATTNAV-HIRISAVE	MATTNAVILE_66	1:40	1:45	0:05	LINE FAULT
81	4-Nov-20	HASSAN	66	MATTNAV-YACHENAHALLY	MATTNAVILE_66	1:40	1:45	0:05	LINE FAULT
82	4-Nov-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	16:25	18:20	1:55	LINE FAULT
83	4-Nov-20	HASSAN	66	SIGEBAG-SMG-DVG2	SIGEBAGE_66	16:25	18:15	1:50	LINE FAULT
84	4-Nov-20	HASSAN	110	ALKOLA-SAGAR	ALKOLA_110	13:20	13:44	0:24	HAND TRIPPED
85	4-Nov-20	HASSAN	110	ANANDA-SHIMOGA	ANANDAPURA_110	14:07	14:20	0:13	HAND TRIPPED
86	4-Nov-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	10:55	11:20	0:25	HAND TRIPPED
87	4-Nov-20	HASSAN	110	ANAVATI-BARNGI	ANAVATTI_110	16:25	17:05	0:40	HAND TRIPPED
88	4-Nov-20	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	11:20	12:20	1:00	LINE CLEAR AVAILED
89	4-Nov-20	HASSAN	110	ANAVATI-JADE	ANAVATTI_110	16:25	17:05	0:40	HAND TRIPPED
90	4-Nov-20	HASSAN	110	HV1	ANAVATTI_110	16:25	17:05	0:40	MAIN SUPPLY FAILURE

91	4-Nov-20	HASSAN	110	HV1	HULICAL_110	9:32	10:28	0:56	HAND TRIPPED
92	4-Nov-20	HASSAN	110	HV1	KONAJE_110	10:43	14:10	3:27	LINE CLEAR AVAILED
93	4-Nov-20	HASSAN	110	HV1	KONAJE_110	2:24	2:32	0:08	MAIN SUPPLY FAILURE
94	4-Nov-20	HASSAN	110	HV2	KONAJE_110	2:24	2:32	0:08	MAIN SUPPLY FAILURE
95	4-Nov-20	HASSAN	110	HV3	GURUVAYANAKERE_110	11:03	13:56	2:53	LINE CLEAR AVAILED
96	4-Nov-20	HASSAN	110	HV3	KONAJE_110	2:24	2:32	0:08	MAIN SUPPLY FAILURE
97	4-Nov-20	HASSAN	110	JLT3	JOG	10:39	10:49	0:10	HAND TRIPPED
98	4-Nov-20	HASSAN	110	JLT3	JOG	10:39	10:48	0:09	HAND TRIPPED
99	4-Nov-20	HASSAN	110	JLT4	JOG	10:39	10:48	0:09	HAND TRIPPED
100	4-Nov-20	HASSAN	110	JLT4	JOG	10:38	10:47	0:09	HAND TRIPPED
101	4-Nov-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	2:24	3:00	0:36	MAIN SUPPLY FAILURE
102	4-Nov-20	HASSAN	110	LV1	SHIRALKOPPA_220	15:27	16:27	1:00	LINE CLEAR AVAILED
103	4-Nov-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	9:41	10:11	0:30	LINE FAULT
104	4-Nov-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	10:33 (3.11.2020)	9:46 (4.11.2020)	23:12 hrs	LINE CHARGED
105	4-Nov-20	HASSAN	110	MRSSHM-SS2	MRSMG_220	14:07	14:20	0:13	HAND TRIPPED
106	4-Nov-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	8:01 (4.11.2020)			LINE OPEN :LINE CLEAR AVAILED
107	4-Nov-20	HASSAN	110	SAGARA-ALKLA	SAGARA_110	13:20	13:43	0:23	HAND TRIPPED
108	4-Nov-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	7:33	22:21	14:48	NFBC ISSUED
109	4-Nov-20	HASSAN	220	HV1	SHIRALKOPPA_220	15:27	16:27	1:00	LINE CLEAR AVAILED
110	4-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
111	4-Nov-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	15:03	16:38	1:35	NFBC ISSUED
112	4-Nov-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	11:14	13:58	2:44	LINE CLEAR AVAILED
113	4-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	13:08	15:18	2:10	NFBC ISSUED
114	4-Nov-20	HASSAN	220	MRSSHM-VARAHI1	MRSMG_220	10:07	14:42	4:35	LINE CLEAR AVAILED
115	4-Nov-20	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	13:08	15:18	2:10	NFBC ISSUED
116	4-Nov-20	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	9:06	18:35	9:29	LINE CLEAR AVAILED
117	4-Nov-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	15:07	16:38	1:31	LINE CLEAR AVAILED
118	4-Nov-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	11:14	13:58	2:44	NFBC ISSUED
119	4-Nov-20	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	10:07	14:42	4:35	LINE CLEAR AVAILED
120	4-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:39 (4.11.2020)			LINE OPEN :LINE CLEAR AVAILED
121	4-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	1:15	7:29	6:14	LINE CLEAR AVAILED
122	4-Nov-20	MYSORE	66	HANNUR-MADHUVANAHALLI 1	NO STATIONS EFFECTED	6:22	6:35	0:13	LINE FAULT
123	4-Nov-20	MYSORE	66	HV1	MADDUR_66	10:06	17:36	7:30	LINE CLEAR AVAILED
124	4-Nov-20	MYSORE	66	HV1	SATHEGALA_66	10:32	12:28	1:55	LINE CLEAR AVAILED
125	4-Nov-20	MYSORE	66	HV2	MADDUR_66	10:06	17:24	7:18	LINE CLEAR AVAILED
126	4-Nov-20	MYSORE	66	HV2	SATHEGALA_66	12:27	14:08	1:41	LINE CLEAR AVAILED
127	4-Nov-20	MYSORE	66	HV2	TUBINAKERE_220	11:23	11:50	0:27	HAND TRIPPED
128	4-Nov-20	MYSORE	66	HV2	TUBINAKERE_220	12:05	12:13	0:07	HAND TRIPPED
129	4-Nov-20	MYSORE	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATIONS EFFECTED	17:53	19:09	1:15	LINE CLEAR AVAILED

130	4-Nov-20	MYSORE	66	MADDUR-KIADB MANDYA	MADDUR_66	10:06	12:26	2:19	LINE CLEAR AVAILED
131	4-Nov-20	MYSORE	66	MADDUR-SOMMANALLI	MADDUR_66	10:05	12:18	2:12	LINE CLEAR AVAILED
132	4-Nov-20	MYSORE	66	SFC SIVA-10MW	NO STATIONS EFFECTED	12:32	12:39	0:07	LINE FAULT
133	4-Nov-20	MYSORE	66	SFC SIVA-5MW	NO STATIONS EFFECTED	12:32	12:43	0:11	LINE FAULT
134	4-Nov-20	MYSORE	66	SFC SIVA-PGL	NO STATIONS EFFECTED	12:32	12:47	0:15	LINE FAULT
135	4-Nov-20	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	14:56	14:58	0:02	LINE CLEAR AVAILED
136	4-Nov-20	TUMKUR	66	HANAGAL-GUDEKOTE	HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66	18:44	19:03	0:19	LINE CLEAR AVAILED
137	4-Nov-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_66, BASAVAPATNA_66	12:01	12:10	0:09	LINE FAULT
138	4-Nov-20	TUMKUR	66	HOSADURGA-RAMAGIRI	RAMAGIRI_66,BAGUR_66,NEELAGUNDA_66	17:48	18:02	0:14	LINE FAULT
139	4-Nov-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:42	10:50	0:08	LINE FAULT
140	4-Nov-20	TUMKUR	66	LINGADAHALLI-CHANNAGIRI	LINGADAHALLI_SHIMOGA66	0:31	1:01	0:30	LINE FAULT
141	4-Nov-20	TUMKUR	66	LINGADAHALLI-CHANNAGIRI	LINGADAHALLI_SHIMOGA66	13:47	13:49	0:01	LINE FAULT
142	4-Nov-20	TUMKUR	66	LINGADAHALLI-CHANNAGIRI	LINGADAHALLI_SHIMOGA66	13:50	13:52	0:02	LINE FAULT
143	4-Nov-20	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	SIRA_66,GULIGENAHALLI_66,	11:04	11:29	0:25	HAND TRIPPED
144	4-Nov-20	TUMKUR	66	MADHUGIRI-SIRA-2(KALAMBELLA	SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66	11:01	11:28	0:27	HAND TRIPPED
145	4-Nov-20	TUMKUR	66	SIRA- BUKKAPATNA	SIRA_66	11:31	11:37	0:06	LINE FAULT
146	4-Nov-20	TUMKUR	66	SIRA- MADHUGIRI 2	SIRA_66	11:31	11:37	0:05	LINE FAULT
147	4-Nov-20	TUMKUR	66	TR-1	GARAGA_66	10:58	15:34	4:36	LINE CLEAR AVAILED
148	4-Nov-20	TUMKUR	66	TR-1	NEELAGUNDA_220	14:00	14:29	0:29	TRANSFORMER FAULT
149	4-Nov-20	TUMKUR	66	TR-1	RANGANATHAPURA_66	12:03	12:25	0:22	LINE CLEAR AVAILED
150	4-Nov-20	TUMKUR	66	TR-1	SOKKE_66	12:41	12:51	0:10	LINE CLEAR AVAILED
151	4-Nov-20	TUMKUR	66	TR-1(LV SIDE)	CHITRADURGA_220	13:30	13:38	0:07	TRANSFORMER FAULT
152	4-Nov-20	TUMKUR	66	TR-2	GARAGA_66	10:58	15:34	4:36	LINE CLEAR AVAILED
153	4-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
154	4-Nov-20	TUMKUR	110	TR-2	NITTUR_220	13:03	15:08	2:04	LINE CLEAR AVAILED
155	5-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
156	5-Nov-20	BAGALKOT	110	110/11KV, HV1	SIRSI_110	10:03	14:56	4:53	LINE CLEAR AVAILED
157	5-Nov-20	BAGALKOT	110	110/11KV, HV2	SIRSI_110	10:10	14:23	4:13	LINE CLEAR AVAILED
158	5-Nov-20	BAGALKOT	110	110/11KV,HV	KIRUVATTI_110	11:48	12:37	0:49	HAND TRIPPED
159	5-Nov-20	BAGALKOT	110	110/11KV,HV1	BANAHATTI_110	16:57	17:49	0:52	LINE CLEAR AVAILED
160	5-Nov-20	BAGALKOT	110	110/11KV,HV1	KIADB BIJAPUR_110	12:35	12:40	0:05	LINE CLEAR AVAILED
161	5-Nov-20	BAGALKOT	110	110/11KV,HV1	SIDDAPUR_110	15:18	16:37	1:19	LINE CLEAR AVAILED
162	5-Nov-20	BAGALKOT	110	110/11KV,HV2	DAVALESHWAR_110	15:51	16:19	0:28	HAND TRIPPED
163	5-Nov-20	BAGALKOT	110	110/11KV,HV2	SHIROL_110	12:02	14:14	2:12	LINE CLEAR AVAILED
164	5-Nov-20	BAGALKOT	110	110/33KV,HV3	RANEBENNUR_220,& RSNG,KUPPELUR _33	11:13	11:22	0:09	LINE CLEAR AVAILED
165	5-Nov-20	BAGALKOT	110	110/33KV,HV4	RANEBENNUR_220,& GUDADUR,MAIDUR _33	11:06	18:22	7:16	LINE CLEAR AVAILED

166	5-Nov-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	3:02	7:28	4:26	LINE CLEAR AVAILED
167	5-Nov-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	23:59 (05.11.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
168	5-Nov-20	BAGALKOT	110	AINAPUR-ATHANI SUGARS	AINAPUR_110	5:25	5:32	0:07	LINE FAULT
169	5-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)			LINE OPEN: LINE FAULT
170	5-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN :LINE CLEAR AVAILED
171	5-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN :LINE CLEAR AVAILED
172	5-Nov-20	BAGALKOT	110	HAVER-BYADAGI	BYADAGI_110	11:59	12:49	0:50	LINE CLEAR AVAILED
173	5-Nov-20	BAGALKOT	110	HAVER-BYADAGI	BYADAGI_110	14:53	17:09	2:16	LINE FAULT
174	5-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
175	5-Nov-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN :LINE CLEAR AVAILED
176	5-Nov-20	BAGALKOT	110	KAGAWAD-SHIRAGUPPI SUGARS	KAGAWAD_110	5:25	5:33	0:08	LINE FAULT
177	5-Nov-20	BAGALKOT	110	KARAWAR-ARAGA	ARAGA_110	15:07	16:43	1:36	LINE CLEAR AVAILED
178	5-Nov-20	BAGALKOT	110	KARAWAR-SOLARIS	BINAGA_110	2:49	16:41	13:52	LINE FAULT
179	5-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN :LINE CLEAR AVAILED
180	5-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
181	5-Nov-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)	13:13 (05.11.2020)	909:61 hrs	LINE CHARGED
182	5-Nov-20	BAGALKOT	110	SIRSI 1&2 -KUMATA	KUMATA_110	9:39	15:01	5:22	LINE CLEAR AVAILED
183	5-Nov-20	BAGALKOT	110	SIRSI- JOG1 (SIDDAPUR)	SIDDAPUR_110	10:20	15:15	4:55	LINE CLEAR AVAILED
184	5-Nov-20	BAGALKOT	110	SIRSI- JOG2	SIRSI_110	10:20	15:13	4:53	LINE CLEAR AVAILED
185	5-Nov-20	BAGALKOT	110	SIRSI- KUMTA2	STATION NOT AFFECTED KUMTA_110	9:56	14:55	4:59	LINE CLEAR AVAILED
186	5-Nov-20	BAGALKOT	110	SIRSI220- SIRSI1	SIRSI_110	10:16	14:54	4:38	LINE CLEAR AVAILED
187	5-Nov-20	BAGALKOT	110	SIRSI220- SIRSI2	SIRSI_110	10:16	15:00	4:44	LINE CLEAR AVAILED
188	5-Nov-20	BAGALKOT	110	VAJRAMATTI220- MANTUR2	STATION NOT AFFECTED MANTUR_110	11:10	14:05	2:55	LINE CLEAR AVAILED
189	5-Nov-20	BAGALKOT	220	220/110KV,HV2,LV2	STATION NOT AFFECTED HUBLI_220	9:46	18:20	8:34	LINE CLEAR AVAILED
190	5-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
191	5-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN :LINE CLEAR AVAILED
192	5-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	21:13 (04.11.2020)	5:41 (05.11.2020)	8:28	LOAD CURTAILMENT
193	5-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	15:37 (5.11.2020)			LINE OPEN :LINE CLEAR AVAILED
194	5-Nov-20	BAGALKOT	220	BELGAUM-NARENDRA2	STATION NOT AFFECTED BELGAUM_220	21:17 (04.11.2020)	6:58 (05.11.2020)	9:41	LOAD CURTAILMENT
195	5-Nov-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)	10:32 (5.11.2020)	479:15 hrs	LINE CHARGED

196	5-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN :LINE CLEAR AVAILED
197	5-Nov-20	BAGALKOT	220	HAVERI-NARENDRA	STATION NOT AFFECTED HAVERI_220	17:07	17:50	0:43	LINE CLEAR AVAILED
198	5-Nov-20	BAGALKOT	220	HUBLI-NARENDRA1	STATION NOT AFFECTED HUBLI_220	11:55	15:52	3:57	NFBC ISSUED
199	5-Nov-20	BAGALKOT	220	KUDUCHI-CHIKKODI2	STATION NOT AFFECTED KUDUCHI_220	5:24	5:52	0:28	LINE FAULT
200	5-Nov-20	BAGALKOT	220	NARENDRA-HUBLI1	STATION NOT AFFECTED NARENDRA_220	10:46	15:53	5:07	LINE FAULT
201	5-Nov-20	BAGALKOT	220	PONDA1-AMBEWADI1	STATION NOT AFFECTEDAMBEWADI_220	12:11	12:51	0:40	LINE FAULT
202	5-Nov-20	BAGALKOT	220	PONDA1-AMBEWADI2	STATION NOT AFFECTEDAMBEWADI_220	14:04 (05.11.2020)			LINE OPEN: LINE FAULT
203	5-Nov-20	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	16:52 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
204	5-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	9:06 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
205	5-Nov-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	19:16	19:40	0:24	MAIN SUPPLY FAILURE
206	5-Nov-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	20:40	20:45	0:05	LOAD CHANGE OVER
207	5-Nov-20	BENGALURU	66	ATTUR YELAHANKA - DG4	ATTUR YELAHANKA	20:45	20:48	0:03	LOAD CHANGE OVER
208	5-Nov-20	BENGALURU	66	ATTUR YELAHANKA - YELAHANKA 220	ATTUR YELAHANKA, WELCAST	17:10	17:17	0:07	LINE FAULT
209	5-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
210	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	10:38	10:52	0:14	LOAD CHANGE OVER
211	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - SIDLAGHATTA	SIDLAGHATTA, MELUR	18:44	18:58	0:14	LOAD CHANGE OVER
212	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	10:38	10:52	0:14	LOAD CHANGE OVER
213	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - GANJIGUNTE	GANJIGUNTE, DIBBURAHALLI, PALLICHERLU	18:44	18:58	0:14	LOAD CHANGE OVER
214	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	10:38	10:52	0:14	LOAD CHANGE OVER
215	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - IRGAMPALLI	IRAGAMPALLI, M GOLLAHALLI	18:44	18:58	0:14	LOAD CHANGE OVER
216	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	10:38	10:52	0:14	LOAD CHANGE OVER
217	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	TADIGOLU, LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	18:44	18:58	0:14	LOAD CHANGE OVER
218	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	10:38	10:52	0:14	LOAD CHANGE OVER
219	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - NANDIGANAHALLI	NANDIGANAHALLI	18:44	18:58	0:14	LOAD CHANGE OVER
220	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	10:38	10:52	0:14	LOAD CHANGE OVER
221	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA, YELDUR	18:44	18:58	0:14	LOAD CHANGE OVER
222	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	10:38	10:52	0:14	LOAD CHANGE OVER
223	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - TALAGAWARA	TALAGAWARA, Y HUNSENAHALLI, CHEEMANGALA	18:44	18:58	0:14	LOAD CHANGE OVER
224	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	10:38	10:52	0:14	LOAD CHANGE OVER
225	5-Nov-20	BENGALURU	66	CHINTAMANI 220 - YENNIGADALE	YENNIGADALE, CHELUR, CHAKAVELU	18:44	18:58	0:14	LOAD CHANGE OVER
226	5-Nov-20	BENGALURU	66	DABUSPET 220 - TYAMAGONDALU	TYAMAGONDALU, T BEGUR	12:12	13:40	1:27	LINE CLEAR AVAILED
227	5-Nov-20	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - BHP (EHT)	BHP (EHT)	18:55	19:32	0:36	MAIN SUPPLY FAILURE

228	5-Nov-20	BENGALURU	66	DEVANAHALLI HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	18:55	19:32	0:36	MAIN SUPPLY FAILURE
229	5-Nov-20	BENGALURU	66	HAL 220 - BMRCL	NO STATION AFFECTED	20:17(05-11-2020)			LINE OPEN: LINE FAULT
230	5-Nov-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	18:55	19:57	1:01	MAIN SUPPLY FAILURE
231	5-Nov-20	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	HBR LAYOUT, BELL CERAMICS (EHT)	18:55	19:57	1:01	MAIN SUPPLY FAILURE
232	5-Nov-20	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	18:55	19:37	0:41	MAIN SUPPLY FAILURE
233	5-Nov-20	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE, CHANNARAYAPATNA	18:55	19:38	0:42	MAIN SUPPLY FAILURE
234	5-Nov-20	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	18:55	19:38	0:42	MAIN SUPPLY FAILURE
235	5-Nov-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	15:51	15:55	0:04	LOAD CHANGE OVER
236	5-Nov-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	17:12	17:33	0:21	LOAD CHANGE OVER
237	5-Nov-20	BENGALURU	66	HV1	BANASHANKARI	10:29	10:35	0:06	LINE CLEAR AVAILED
238	5-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	21:12	21:19	0:07	TRANSFORMER FAULT
239	5-Nov-20	BENGALURU	66	HV1	HEJJALA	17:43	17:51	0:08	TRANSFORMER FAULT
240	5-Nov-20	BENGALURU	66	HV1	HEJJALA	18:13	18:21	0:08	TRANSFORMER FAULT
241	5-Nov-20	BENGALURU	66	HV1	MEI LAYOUT	18:29	18:39	0:10	TRANSFORMER FAULT
242	5-Nov-20	BENGALURU	66	HV1	RMV	19:20	19:40	0:20	TRANSFORMER FAULT
243	5-Nov-20	BENGALURU	66	HV1	KIADB HARDWARE PARK DEVANAHALLI 220	19:11	19:35	0:23	MAIN SUPPLY FAILURE
244	5-Nov-20	BENGALURU	66	HV1	CHAKAVELU	13:00	13:02	0:02	LINE CLEAR AVAILED
245	5-Nov-20	BENGALURU	66	HV2	BRIGADE MEADOWS	23:18	23:24	0:06	TRANSFORMER FAULT
246	5-Nov-20	BENGALURU	66	HV2	EPIP 220	16:18	16:49	0:31	TRANSFORMER FAULT
247	5-Nov-20	BENGALURU	66	HV2	PADMANABHANAGARA	12:19	12:21	0:02	LINE CLEAR AVAILED
248	5-Nov-20	BENGALURU	66	HV3	BANASHANKARI	12:10	12:20	0:10	TRANSFORMER FAULT
249	5-Nov-20	BENGALURU	66	KORAMANGALA - AUSTIN TOWN 1	NO STATION AFFECTED	19:12	20:48	1:36	LINE FAULT
250	5-Nov-20	BENGALURU	66	KOTHIPURA 220kV - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	11:00	16:40	5:40	LINE CLEAR AVAILED
251	5-Nov-20	BENGALURU	66	NELMANGALA 66 - ALUR	NELAMANGALA 66	19:38	19:44	0:06	LOAD CHANGE OVER
252	5-Nov-20	BENGALURU	66	NELMANGALA 66 - DABUSPET 220	NELAMANGALA 66	10:20	10:55	0:35	LOAD CHANGE OVER
253	5-Nov-20	BENGALURU	66	WELCAST STEEL - SRS PEENYA 220	WELCAST STEEL	20:56	21:01	0:05	LOAD CHANGE OVER
254	5-Nov-20	BENGALURU	220	DEVANAHALLI HARDWARE PARK 220 - BEGUR 220	DEVANAHALLI HARDWARE PARK 220, HOSKOTE 220	18:55	19:32	0:36	LINE FAULT
255	5-Nov-20	BENGALURU	220	HV1	KIADB HARDWARE PARK DEVANAHALLI 220	19:11	19:12	0:01	MAIN SUPPLY FAILURE
256	5-Nov-20	BENGALURU	220	HV2	HSR LAYOUT	17:10	17:23	0:13	TRANSFORMER FAULT
257	5-Nov-20	BENGALURU	220	HV2	KIADB HARDWARE PARK DEVANAHALLI 220	19:34	19:35	0:01	MAIN SUPPLY FAILURE
258	5-Nov-20	BENGALURU	220	NELMANGALA 220 - SRS PEENYA 1	NO STATION AFFECTED	22:53	23:02	0:08	LINE FAULT
259	5-Nov-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 1	NO STATION AFFECTED	23:02(05/11/2020)			LINE OPEN: LINE FAULT
260	5-Nov-20	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	13:52	13:58	0:06	LINE CLEAR AVAILED
261	5-Nov-20	GULBARGA	66	HV1	HANASI_66	13:29	13:57	0:28	LINE CLEAR AVAILED
262	5-Nov-20	GULBARGA	110	HUMANABAD-MANEKHALLI	MANEKHALLI_110	12:00	12:17	0:17	LINE FAULT
263	5-Nov-20	GULBARGA	110	HUMANABAD-SASTHAPUR	RAJESHWAR_110,SASTHAPUR_110,MANTHAL_110	12:00	12:18	0:18	LINE FAULT
264	5-Nov-20	GULBARGA	110	CHITGUPPA-ACMESLR_IPP	CHITGUPPA_110	18:08	19:15	1:07	LINE CLEAR AVAILED

265	5-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN: LINE FAULT
266	5-Nov-20	GULBARGA	110	HV1	CHIKSUGUR_110	15:07	20:05	4:58	LINE CLEAR AVAILED
267	5-Nov-20	GULBARGA	110	HV1	CHIKSUGUR_110	18:44	19:22	0:38	LINE CLEAR AVAILED
268	5-Nov-20	GULBARGA	110	HV2	JEEWARGI_110	8:50	9:00	0:10	TRANSFORMER FAULT
269	5-Nov-20	GULBARGA	110	HV3	JEEWARGI_110	15:45	16:45	1:00	LINE CLEAR AVAILED
270	5-Nov-20	GULBARGA	110	HV3	CHIKSUGUR_110	16:22	17:11	0:49	LINE CLEAR AVAILED
271	5-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN :LINE CLEAR AVAILED
272	5-Nov-20	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	12:05	12:20	0:15	MAIN SUPPLY FAILURE
273	5-Nov-20	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	12:25	12:35	0:10	MAIN SUPPLY FAILURE
274	5-Nov-20	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	12:50	13:00	0:10	MAIN SUPPLY FAILURE
275	5-Nov-20	GULBARGA	110	NIRNA-CHITAGUPPA	NIRNA_110	13:15	13:40	0:25	MAIN SUPPLY FAILURE
276	5-Nov-20	GULBARGA	110	SHAHABAD-BHAGYAWADI2	YADRAMI_110,MORATAGI_110	4:40	4:47	0:07	LINE FAULT
277	5-Nov-20	GULBARGA	110	SHAHABAD-BHAGYAWADI2	YADRAMI_110,MORATAGI_110	6:10	6:14	0:04	LINE FAULT
278	5-Nov-20	GULBARGA	110	SHAHABAD-RAICHUR1	JEEWARGI_110	6:03	6:08	0:05	LINE FAULT
279	5-Nov-20	GULBARGA	110	SHAHAOUR-KEMBHAVI	KEMBHAVI_110	19:15	19:25	0:10	LINE FAULT
280	5-Nov-20	GULBARGA	110	SHAHPUR-KEMBHAVI	KEMBHAVI_110	0:01	0:12	0:11	LINE FAULT
281	5-Nov-20	GULBARGA	110	SINDHANOOR-RAICHUR2	KURGICROSS_110,MADALAPUR_110,MANVI_110	21:55	22:10	0:15	LINE FAULT
282	5-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
283	5-Nov-20	GULBARGA	220	HV2	HUMANABAD_220	12:10	15:02	2:52	LINE CLEAR AVAILED
284	5-Nov-20	GULBARGA	220	SHAHPUR-RTPS1	RTPS1_220	14:11	15:04	0:53	LINE FAULT
285	5-Nov-20	HASSAN	66	ATTICHO-HNPURA	ATTICHOWDENAHALLY_66	11:09	13:25	2:16	NFBC ISSUED
286	5-Nov-20	HASSAN	66	BHADRA-SHMGA 2	bhadra_gen	6:30	7:43	1:13	LINE FAULT
287	5-Nov-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	20:10	20:14	0:04	LINE FAULT
288	5-Nov-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	11:09	13:25	2:16	NFBC ISSUED
289	5-Nov-20	HASSAN	66	HV1	CHANNARAYAPATNA_66	12:23	13:35	1:12	LINE CLEAR AVAILED
290	5-Nov-20	HASSAN	66	HV1	KUDLIGERE_66	12:44	14:26	1:42	LINE CLEAR AVAILED
291	5-Nov-20	HASSAN	66	HV2	CHANNARAYAPATNA_66	11:24	12:26	1:02	LINE CLEAR AVAILED
292	5-Nov-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:07	13:22	2:15	LINE CLEAR AVAILED
293	5-Nov-20	HASSAN	66	MRSSHM-BD-2	MRSMG_220	6:30	7:40	1:10	LINE FAULT
294	5-Nov-20	HASSAN	110	HV1	HOSANGADI_110	9:00	13:45	4:45	LINE CLEAR AVAILED
295	5-Nov-20	HASSAN	110	HV1	PUTTUR_110	9:43	14:41	4:58	LINE CLEAR AVAILED
296	5-Nov-20	HASSAN	110	HV2	KONAJE_110	20:04	20:26	0:22	MAIN SUPPLY FAILURE
297	5-Nov-20	HASSAN	110	HV3	SAGARA_110	10:48	12:59	2:11	LINE CLEAR AVAILED
298	5-Nov-20	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	20:04	20:45	0:41	MAIN SUPPLY FAILURE
299	5-Nov-20	HASSAN	110	LV1	ARASIKERE_220	11:55	14:15	2:20	LINE CLEAR AVAILED
300	5-Nov-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	8:07	10:45	2:38	LINE FAULT
301	5-Nov-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	10:47	10:50	0:03	HAND TRIPPED
302	5-Nov-20	HASSAN	110	MANIPAL-BRAMVR	MANIPAL_110	12:54	13:04	0:10	HAND TRIPPED
303	5-Nov-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	8:01 (4.11.2020)	14:42 (5.11.2020)	30:41 hrs	LINE CHARGED

304	5-Nov-20	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	19:02	19:43	0:41	LINE FAULT
305	5-Nov-20	HASSAN	110	PUTTUR-SULIA	PUTTUR_220	20:42	21:04	0:22	LINE FAULT
306	5-Nov-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	13:34	14:56	1:22	NFBC ISSUED
307	5-Nov-20	HASSAN	220	HV1	ARASIKERE_220	11:55	14:15	2:20	LINE CLEAR AVAILED
308	5-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
309	5-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	10:27	13:49	3:22	LINE FAULT
310	5-Nov-20	HASSAN	220	MRSSHM-VARAHI2	MRSMG_220	9:05	10:50	1:45	LINE CLEAR AVAILED
311	5-Nov-20	HASSAN	220	SHRAVTY-SHIMOGA3	sharvathy_gen	10:27	13:50	3:23	LINE FAULT
312	5-Nov-20	HASSAN	220	SHRAVTY-SIRISI 2	sharvathy_gen	8:48	16:05	7:17	LINE CLEAR AVAILED
313	5-Nov-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	9:05	10:50	1:45	LINE CLEAR AVAILED
314	5-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:39 (4.11.2020)			LINE OPEN :LINE CLEAR AVAILED
315	5-Nov-20	MYSORE	66	BOGADHI-GIS KALAMANDIR	KALAMANDIRA_66	15:50	16:14	0:23	LINE FAULT
316	5-Nov-20	MYSORE	66	BOGADHI-GIS KALAMANDIR	KALAMANDIRA_66	16:42			LINE OPEN: LINE FAULT
317	5-Nov-20	MYSORE	66	HANNUR-MADHUVANALLY 2	NO STATIONS EFFECTED	12:17	12:45	0:27	LINE CLEAR AVAILED
318	5-Nov-20	MYSORE	66	HV1	MALAVALLI_66	14:12	14:59	0:46	LINE CLEAR AVAILED
319	5-Nov-20	MYSORE	66	HV1	AKKIHEBBAL_66	13:11	13:36	0:24	LINE CLEAR AVAILED
320	5-Nov-20	MYSORE	66	HV1	AKKIHEBBAL_66	13:55	14:33	0:38	LINE CLEAR AVAILED
321	5-Nov-20	MYSORE	66	HV1	ANEGOLAL_66	10:20	11:49	1:29	LINE CLEAR AVAILED
322	5-Nov-20	MYSORE	66	HV1	KABHALLY_66	11:30	13:39	2:09	LINE CLEAR AVAILED
323	5-Nov-20	MYSORE	66	HV1	KABHALLY_66	15:24	15:37	0:12	LINE CLEAR AVAILED
324	5-Nov-20	MYSORE	66	HV2	DKMAIDANA_66	15:26	15:27	0:01	TRANSFORMER FAULT
325	5-Nov-20	MYSORE	66	HV2	NAGAMANGALA_66	13:20	14:47	1:27	LINE CLEAR AVAILED
326	5-Nov-20	MYSORE	66	KABBALLY-CLEAN SOLAR	NO STATIONS EFFECTED	17:42	18:44	1:02	LINE CLEAR AVAILED
327	5-Nov-20	MYSORE	66	KM DODDI-TK HALLI	KIADBMANDYA_66, KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE _66	23:12	23:26	0:14	LINE FAULT
328	5-Nov-20	MYSORE	66	KR PETE 220 -MAHADESWARAPURA	BOGADHI MANDYA_66 G MALLIGERE_66 GUDDENAHALLI_66 JAKKANAHALLY_66 MADESWARAPURA_66 NAGAMANGALA_66	18:55	19:05	0:10	LINE FAULT
329	5-Nov-20	MYSORE	66	MADHUVANALLY-HANNUR 1	NO STATIONS EFFECTED	18:05	18:17	0:11	LINE FAULT
330	5-Nov-20	MYSORE	66	MADHUVANALLY-PG PALYA	PGPALYA_66	5:59	6:05	0:06	LINE FAULT
331	5-Nov-20	MYSORE	66	TUBINKERE-MC 2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	19:00	19:16	0:15	LINE FAULT
332	5-Nov-20	MYSORE	66	TUBINKERE-MC 4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66, KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	19:00	19:20	0:19	LINE FAULT
333	5-Nov-20	MYSORE	66	TUBINKERE-NAGAMANGALA-1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI _66	18:08	18:15	0:06	LINE FAULT
334	5-Nov-20	MYSORE	220	HV2	TUBINAKERE_220	10:18	14:49	4:31	LINE CLEAR AVAILED

335	5-Nov-20	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	6:15	6:42	0:27	LINE FAULT
336	5-Nov-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	14:42	18:39	3:56	LINE CLEAR AVAILED
337	5-Nov-20	TUMKUR	66	CHITRADURGA 220kV- HIRIYUR	IMANGALA_66, RELIANCE_IPP_66, HIRIYUR_66	21:29	21:43	0:14	LINE FAULT
338	5-Nov-20	TUMKUR	66	TR-1	BADDIHALLI_66	12:10	12:16	0:05	LINE CLEAR AVAILED
339	5-Nov-20	TUMKUR	66	TR-1(LV SIDE)	HONNALLI_220	11:58	13:48	1:49	LINE CLEAR AVAILED
340	5-Nov-20	TUMKUR	66	TR-2	HONNALLI_220	11:56	13:54	1:57	LINE CLEAR AVAILED
341	5-Nov-20	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	14:47	18:39	3:52	LINE CLEAR AVAILED
342	5-Nov-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	14:45	15:15	0:29	HAND TRIPPED
343	5-Nov-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	18:24	18:44	0:19	HAND TRIPPED
344	5-Nov-20	TUMKUR	110	HONNAVALLI 110- KADUR	HONNAVALLI_110	10:30	17:45	7:15	LINE CLEAR- AVAILED
345	5-Nov-20	TUMKUR	110	HONNAVALLI 110-ADAN SOLAR_	ADAN SOLAR_IPP_66	10:30	17:46	7:15	LINE CLEAR AVAILED
346	5-Nov-20	TUMKUR	110	HONNAVALLI 110-DMKURKE	DMKURKE_110	10:30	17:46	7:15	LINE CLEAR AVAILED
347	5-Nov-20	TUMKUR	110	HONNAVALLI 110-TIPTUR	HALKURKE_110,KEREKODI_110,HUNSEGHATTA_110	17:37	17:44	0:07	HAND TRIPPED
348	5-Nov-20	TUMKUR	110	TR-1	HONNAVALLI_110	10:30	17:46	7:16	LINE CLEAR AVAILED
349	5-Nov-20	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	15:09	15:43	0:34	LINE CLEAR AVAILED
350	5-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
351	5-Nov-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	17:38	18:17	0:39	HAND TRIPPED
352	5-Nov-20	TUMKUR	220	TR-1	HONNALLI_220	11:59	13:44	1:45	LINE CLEAR AVAILED
353	5-Nov-20	TUMKUR	220	TR-1	NITTUR_220	15:09	15:43	0:34	LINE CLEAR AVAILED
1	6-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
2	6-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN :LINE CLEAR AVAILED
3	6-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
4	6-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN :LINE CLEAR AVAILED
5	6-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
6	6-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN :LINE CLEAR AVAILED
7	6-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN :LINE CLEAR AVAILED
8	6-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
9	6-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)			LINE OPEN: LINE FAULT
10	6-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN :LINE CLEAR AVAILED
11	6-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	9:06 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
12	6-Nov-20	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	16:52 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED

13	6-Nov-20	BAGALKOT	110	220/110KV,LV2	STATION NOT AFFECTED MK HUBLI_220	23:59 (05.11.2020)	7:48 (06.11.2020)	7:49hrs	TRANSFORMER CHARGED
14	6-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	15:37 (5.11.2020)	11:01 (6.11.2020)	19:24hrs	LINE CHARGED
15	6-Nov-20	BAGALKOT	220	PONDA2-AMBEWADI2	STATION NOT AFFECTED AMBEWADI_220	14:04 (05.11.2020)			LINE OPEN: LINE FAULT
16	6-Nov-20	BAGALKOT	110	110/11KV,HV1	ANKOLA_110	10:05	13:13	3:08	LINE CLEAR AVAILED
17	6-Nov-20	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	10:09	17:37	7:28	LINE CLEAR AVAILED
18	6-Nov-20	BAGALKOT	110	BELLATTI-AB SOLAR	BELLATTI_110	11:04	12:26	1:22	LINE CLEAR AVAILED
19	6-Nov-20	BAGALKOT	110	110/33KV, HV3	BELLATTI_110 & SURANAGI,HOLE ITAGI,RWSS JALAWADI_33	11:16	17:48	6:32	LINE CLEAR AVAILED
20	6-Nov-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	6:45	8:14	1:29	LINE CLEAR AVAILED
21	6-Nov-20	BAGALKOT	220	BELGAUM-NARENDRA 1	BELGAUM_220	15:16	16:48	1:32	LINE CLEAR AVAILED
22	6-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	16:51	18:55	2:04	LINE CLEAR AVAILED
23	6-Nov-20	BAGALKOT	110	BAGEWADI-MUDDEBIHAL	MUDDEBIHAL_110	16:19	16:27	0:08	HAND TRIPPED
24	6-Nov-20	BAGALKOT	110	BIDNAL-P H COMPOUND	PH COMPOUND_110	14:37 (6.11.2020)			LINE OPEN: LINE FAULT
25	6-Nov-20	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	11:07	15:19	4:12	LINE CLEAR AVAILED
26	6-Nov-20	BAGALKOT	110	GAJENDRAGAD-RON 1	GAJENDRAGAD_110	6:37	6:48	0:11	HAND TRIPPED
27	6-Nov-20	BAGALKOT	110	GAJENDRAGAD-RON 2	GAJENDRAGAD_110	6:37	6:48	0:11	HAND TRIPPED
28	6-Nov-20	BAGALKOT	110	GOPANAKOPPA-NARAGUND	NARAGUND_110	10:09	17:48	7:39	LINE CLEAR AVAILED
29	6-Nov-20	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	12:04	15:19	3:15	NFBC ISSUED
30	6-Nov-20	BAGALKOT	220	GHATAPRABHA-NARENDRA1	GHATAPRABHA_220	15:19	17:49	2:30	NFBC ISSUED
31	6-Nov-20	BAGALKOT	110	HAVERI-TILUVALLI	TILUVALLI_110	12:35	13:19	0:44	LINE CLEAR AVAILED
32	6-Nov-20	BAGALKOT	110	110/11KV, HV1	YELPARHATTI_110	13:38	14:40	1:02	LINE CLEAR AVAILED
33	6-Nov-20	BAGALKOT	110	110/11KV, HV2	SHIROL_110	2:04	2:16	0:12	TRANSFORMER FAULT
34	6-Nov-20	BAGALKOT	110	SADALAGA- BORAGOAN	BORGOAN_110	15:35	17:41	2:06	LINE CLEAR AVAILED
35	6-Nov-20	BAGALKOT	220	HUBLI- NARENDRA1	HUBLI_220	9:13	13:01	3:48	LINE CLEAR AVAILED
36	6-Nov-20	BAGALKOT	220	HUBLI- NARENDRA2	HUBLI_220	13:12	14:26	1:14	LINE CLEAR AVAILED
37	6-Nov-20	BAGALKOT	110	RON- HIREHAL	HIREHAL_110	6:35	6:57	0:22	HAND TRIPPED
38	6-Nov-20	BAGALKOT	110	GAMESHA- RON	RON_110	6:35	6:59	0:24	HAND TRIPPED
39	6-Nov-20	BAGALKOT	110	110/11KV, HV2	RANNABELAGALI_110	10:29	10:36	0:07	TRANSFORMER FAULT
40	6-Nov-20	BAGALKOT	110	110/33KV, HV4	RANEBENNUR_220	10:53	16:13	5:20	LINE CLEAR AVAILED
41	6-Nov-20	BAGALKOT	110	NAVALGUND- KONNUR	KONNUR_110	10:09	17:27	7:18	LINE CLEAR AVAILED
42	6-Nov-20	BAGALKOT	110	110/11KV, HV1	MUNDUGANUR_110	14:25	14:57	0:32	LINE CLEAR AVAILED
43	6-Nov-20	BAGALKOT	110	110/33KV, HV3	MAMADAPUR(B)_110, DEVARGENNUR_33, LINGADALLI_LIS	12:47	14:01	1:14	LINE CLEAR AVAILED
44	6-Nov-20	BAGALKOT	110	MKHUBLI220- BEDI	BEDI_110	5:42	6:03	0:21	LINE CLEAR AVAILED
45	6-Nov-20	BAGALKOT	110	LAXMESHWAR- BELLATTI	BELLATTI_110	11:20	12:25	1:05	LINE CLEAR AVAILED
46	6-Nov-20	BAGALKOT	110	110/11KV, HV2	LAKMANHALLI_110	10:54	14:47	3:53	LINE CLEAR AVAILED
47	6-Nov-20	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	12:13	12:25	0:12	LINE CLEAR AVAILED
48	6-Nov-20	BAGALKOT	110	110/11KV, HV4	HUKKERI_110	20:38	21:02	0:24	LINE CLEAR AVAILED
49	6-Nov-20	BENGALURU	66	HV2	B G ROAD	11:32	11:36	00:04	LINE CLEAR AVAILED
50	6-Nov-20	BENGALURU	66	BRIGADE MEADOWS - SOBHA FOREST	BRIGADE MEADOWS	12:48	13:10	00:22	LOAD CHANGE OVER

51	6-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	02:43	02:49	00:06	TRANSFORMER FAULT
52	6-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	03:34	03:40	00:06	TRANSFORMER FAULT
53	6-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	04:02	04:10	00:08	TRANSFORMER FAULT
54	6-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	14:08	14:15	00:07	TRANSFORMER FAULT
55	6-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	14:16	14:23	00:07	TRANSFORMER FAULT
56	6-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	16:37	16:38	00:01	LINE CLEAR AVAILED
57	6-Nov-20	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	18:10	19:10	01:00	MAIN SUPPLY FAILURE
58	6-Nov-20	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	18:10	19:10	01:00	MAIN SUPPLY FAILURE
59	6-Nov-20	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	18:10	19:10	01:00	LINE CLEAR AVAILED
60	6-Nov-20	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	18:10	19:10	01:00	LINE CLEAR AVAILED
61	6-Nov-20	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	19:55	20:02	00:07	LOAD CHANGE OVER
62	6-Nov-20	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	19:55	20:02	00:07	LOAD CHANGE OVER
63	6-Nov-20	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	19:55	20:02	00:07	LOAD CHANGE OVER
64	6-Nov-20	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	20:02	20:10	00:08	MAIN SUPPLY FAILURE
65	6-Nov-20	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	20:02	20:10	00:08	MAIN SUPPLY FAILURE
66	6-Nov-20	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	20:02	20:10	00:08	LINE CLEAR AVAILED
67	6-Nov-20	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	20:02	20:10	00:08	LINE CLEAR AVAILED
68	6-Nov-20	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	21:49	21:53	00:04	LOAD CHANGE OVER
69	6-Nov-20	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	21:49	21:53	00:04	LOAD CHANGE OVER
70	6-Nov-20	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	21:49	21:53	00:04	LOAD CHANGE OVER
71	6-Nov-20	BENGALURU	66	GOKULA - SRS PEENYA 2	NO STATION AFFECTED	22:02	22:17	00:15	LINE CLEAR AVAILED
72	6-Nov-20	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	NO STATION AFFECTED	18:10	19:55	01:45	LINE FAULT
73	6-Nov-20	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	NO STATION AFFECTED	18:10	19:55	01:45	LINE FAULT
74	6-Nov-20	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	NO STATION AFFECTED	20:02	21:40	01:38	LINE CLEAR AVAILED
75	6-Nov-20	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	NO STATION AFFECTED	20:02	21:40	01:38	LINE CLEAR AVAILED
76	6-Nov-20	BENGALURU	66	HV2	HAL 220	14:01	16:09	02:08	LINE CLEAR AVAILED
77	6-Nov-20	BENGALURU	66	HV1	HEBBALA 220	12:30	12:39	00:09	LINE CLEAR AVAILED
78	6-Nov-20	BENGALURU	66	HV2	HEJJALA	17:15	17:23	00:08	LINE CLEAR AVAILED
79	6-Nov-20	BENGALURU	66	HV2	HEJJALA	12:50	12:55	00:05	LINE CLEAR AVAILED
80	6-Nov-20	BENGALURU	66	HOODY 220 - HP(EHT)	HP(EHT)	11:47	11:53	00:06	LOAD CHANGE OVER
81	6-Nov-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	09:38	09:46	00:08	LOAD CHANGE OVER
82	6-Nov-20	BENGALURU	66	IISC - HEBBAL 220	IISC	18:50	18:55	00:05	LOAD CHANGE OVER
83	6-Nov-20	BENGALURU	220	HV2	KHODAYS 220	10:07	10:23	00:16	TRANSFORMER FAULT
84	6-Nov-20	BENGALURU	66	KHODAYS 220 - ELITE PROMENEDE	ELITE PROMENEDE	10:07	10:25	00:18	LINE CLEAR AVAILED
85	6-Nov-20	BENGALURU	66	KHODAYS 220 - BTM 4TH PHASE	BTM 4TH PHASE	10:07	10:25	00:18	LINE CLEAR AVAILED
86	6-Nov-20	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	18:06	18:19	00:13	MAIN SUPPLY FAILURE
87	6-Nov-20	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	23:20	23:24	00:04	LOAD CHANGE OVER
88	6-Nov-20	BENGALURU	66	HV1	MEI LAYOUT	13:27	13:32	00:05	TRANSFORMER FAULT
89	6-Nov-20	BENGALURU	66	HV2	R R NAGAR	13:13	13:28	00:15	TRANSFORMER FAULT
90	6-Nov-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	05:12	05:15	00:03	LOAD CHANGE OVER
91	6-Nov-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	08:57	08:59	00:02	LOAD CHANGE OVER
92	6-Nov-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	18:10	18:20	00:10	MAIN SUPPLY FAILURE

93	6-Nov-20	BENGALURU	66	SOBHA FOREST - KHODAYS 220	SOBHA FOREST	12:48	13:03	00:15	LOAD CHANGE OVER
94	6-Nov-20	BENGALURU	66	BAGHMANE WORLD TECH PARK - HOODY 2	BAGHMANE WORLD TECH PARK	09:25	09:30	00:05	LOAD CHANGE OVER
95	6-Nov-20	BENGALURU	66	HV1	DOMMASANDRA	11:28	11:38	00:10	TRANSFORMER FAULT
96	6-Nov-20	BENGALURU	66	HV2	MAASTHI	15:53	16:02	00:09	TRANSFORMER FAULT
97	6-Nov-20	BENGALURU	66	HV2	SOMANATHPURA	12:00	16:04	04:04	LINE CLEAR AVAILED
98	6-Nov-20	BENGALURU	66	HV1	VIJAYAPURA	15:02	15:40	00:37	LINE CLEAR AVAILED
99	6-Nov-20	BENGALURU	66	SM MANGALA - CHINTAMANI 66	NO STATION AFFECTED	10:36	11:40	01:04	LINE FAULT
100	6-Nov-20	BENGALURU	66	SM MANGALA - CHINTAMANI 66	NO STATION AFFECTED	11:45	11:49	00:04	LINE FAULT
101	6-Nov-20	BENGALURU	66	SM MANGALA - CHINTAMANI 66	NO STATION AFFECTED	02:27	10:36	08:09	LINE FAULT
102	6-Nov-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR, NELMANGALA 66	05:04	05:10	00:06	LOAD CHANGE OVER
103	6-Nov-20	BENGALURU	66	ALUR - SRS PEENYA 220	ALUR	09:00	09:06	00:06	LOAD CHANGE OVER
104	6-Nov-20	BENGALURU	220	SRS PEENYA 220 - NELAMANGALA 1	NO STATION AFFECTED	23:02(05/11/2020)	9:37(06/11/2020)	10:35hrs	LINE CHARGED
105	6-Nov-20	BENGALURU	66	HAL 220 - BMRCL	NO STATION AFFECTED	20:17(05-11-2020)			LINE OPEN: LINE FAULT
106	6-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
107	6-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN: LINE FAULT
108	6-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN :LINE CLEAR AVAILED
109	6-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
110	6-Nov-20	GULBARGA	220	HUMNABAD-SEDAM1	SEDAM_220	15:15	15:52	00:37	LINE CLEAR AVAILED
111	6-Nov-20	GULBARGA	220	HALBARGA-HUMNABAD2	HALBARGA_220	13:56	14:37	00:41	LINE FAULT
112	6-Nov-20	GULBARGA	220	SHAHAPUR-SEDAM	SEDAM_220	00:00	06:20	06:20	LINE CLEAR AVAILED
113	6-Nov-20	GULBARGA	220	HV2	HUMANABAD_220	16:24	16:50	00:26	LINE CLEAR AVAILED
114	6-Nov-20	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	15:08	15:54	00:46	LINE CLEAR AVAILED
115	6-Nov-20	GULBARGA	110	HANUMANAL-VARIKAL	HANUMANAL_110	07:30	10:25	02:55	LINE CLEAR AVAILED
116	6-Nov-20	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	05:49	06:03	00:14	LINE FAULT
117	6-Nov-20	GULBARGA	110	CHITAGUPPA-ACMESLR	CHITAGUPPA_110,NIRNA_110	16:16	16:51	00:35	LINE CLEAR AVAILED
118	6-Nov-20	GULBARGA	110	SEDAM-CHINCHOLI	CHINCHOLI_110	10:44	10:47	00:03	LINE CLEAR AVAILED
119	6-Nov-20	GULBARGA	110	SEDAM-MALKHEDRAILWAY	MALKHEDRAILWAY_110	17:46	18:25	00:39	LINE CLEAR AVAILED
120	6-Nov-20	GULBARGA	110	SEDAM-VCATSAGAR_IPP	SEDAM_220	17:48	18:20	00:32	LINE CLEAR AVAILED
121	6-Nov-20	GULBARGA	110	HV1	NIRNA_110	16:30	17:45	01:15	LINE CLEAR AVAILED
122	6-Nov-20	GULBARGA	110	LADHA-ACMESOLAR_IPP	LADHA_110	18:00(6.11.2020)			LINE OPEN :LINE CLEAR AVAILED
123	6-Nov-20	GULBARGA	110	HV1	CHINCHOLI_110	14:30	14:37	00:07	LINE CLEAR AVAILED
124	6-Nov-20	GULBARGA	110	HV1	CHINCHOLI_110	16:19	16:23	00:04	LINE CLEAR AVAILED
125	6-Nov-20	GULBARGA	110	HV2	CHINCHOLI_110	10:45	10:50	00:05	LINE CLEAR AVAILED
126	6-Nov-20	GULBARGA	66	ITTAGI-HUVINAHADAGALI	HUVINAHADAGALI_66	17:56	18:05	00:09	LINE FAULT
127	6-Nov-20	GULBARGA	66	ITTAGI-HIREHADAGALI	HIREHADAGALI_66	18:10	18:20	00:10	LINE FAULT
128	6-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:39 (4.11.2020)	10:01 (6.11.2020)	40:21 hrs	LINE CHARGED

129	6-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
130	6-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:09 (6.11.2020)			LINE OPEN :LINE CLEAR AVAILED
131	6-Nov-20	HASSAN	220	KEMAR-BAJPE2	KEMAR_220	13:25	15:24	01:59	LINE FAULT
132	6-Nov-20	HASSAN	220	MRSSHM-VARAHI2	MRSMG_220	04:49	10:42	05:53	LINE FAULT
133	6-Nov-20	HASSAN	110	MRSSHM-MYSORE	MRSMG_220	12:15	13:24	01:09	LINE FAULT
134	6-Nov-20	HASSAN	110	MRSSHM-MYSORE	MRSMG_220	14:28	16:45	02:17	LINE FAULT
135	6-Nov-20	HASSAN	220	HV1	MSEZ_220	17:05	18:20	01:15	TRANSFORMER FAULT
136	6-Nov-20	HASSAN	110	LV1	MSEZ_220	17:05	18:21	01:16	TRANSFORMER FAULT
137	6-Nov-20	HASSAN	220	MSEZ-KAVOOR1	MSEZ_220	17:05	18:16	01:11	LINE FAULT
138	6-Nov-20	HASSAN	220	MSEZ-KEMAR1	MSEZ_220	17:05	18:31	01:26	LINE FAULT
139	6-Nov-20	HASSAN	220	MSEZ-KEMAR2	MSEZ_220	13:25	15:23	01:58	LINE FAULT
140	6-Nov-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	16:39	18:57	02:18	LINE FAULT
141	6-Nov-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	16:39	19:09	02:30	LINE FAULT
142	6-Nov-20	HASSAN	220	VARAHI-KEMAR3	varahi_gen	17:30	18:54	01:24	LINE FAULT
143	6-Nov-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	04:50	10:43	05:53	LINE FAULT
144	6-Nov-20	HASSAN	110	BARANGI-SHR220	BARANGI_110	10:51	13:12	02:21	MAIN SUPPLY FAILURE
145	6-Nov-20	HASSAN	110	HV1	GERUMARA_110	12:20	13:56	01:36	LINE CLEAR AVAILED
146	6-Nov-20	HASSAN	110	HV2	GERUMARA_110	11:18	13:14	01:56	LINE CLEAR AVAILED
147	6-Nov-20	HASSAN	110	HV2	HOSANGADI_110	09:38	13:56	04:18	LINE CLEAR AVAILED
148	6-Nov-20	HASSAN	110	KADUR-NGNHL	KADUR_220	21:39	22:51	01:12	LINE FAULT
149	6-Nov-20	HASSAN	110	SALATHU-BNTWAL	SALATHUR_110	14:51	17:37	02:46	LINE CLEAR AVAILED
150	6-Nov-20	HASSAN	110	HV1	SALATHUR_110	11:40	14:01	02:21	LINE CLEAR AVAILED
151	6-Nov-20	HASSAN	110	SHRLKP-BARANG	SHIRALKOPPA_220	09:15	13:09	03:54	LINE FAULT
152	6-Nov-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	10:18	10:37	00:19	MAIN SUPPLY FAILURE
153	6-Nov-20	HASSAN	66	HV2	HIRISAVE_66	09:59	10:26	00:27	LINE CLEAR AVAILED
154	6-Nov-20	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	10:17	10:30	00:13	LINE FAULT
155	6-Nov-20	HASSAN	66	HV2	HNPURA_66	11:09	12:28	01:19	LINE CLEAR AVAILED
156	6-Nov-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	10:20	10:34	00:14	MAIN SUPPLY FAILURE
157	6-Nov-20	HASSAN	66	HV1	MALALI_66	10:18	10:34	00:16	MAIN SUPPLY FAILURE
158	6-Nov-20	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	10:28	18:44	08:16	LINE FAULT
159	6-Nov-20	MYSORE	66	BOGADHI-GIS KALAMANDIR	KALAMANDIRA_66	16:42 (5/11/2020)	11:00	18:17 HRS	LINE CHARGED
161	6-Nov-20	MYSORE	220	CR NAGARA-MADHUVANALLY 1	NO STATIONS EFFECTED	12:44	12:58	0:14	LINE FAULT
162	6-Nov-20	MYSORE	220	KR PETE 220-HV1	NO STATIONS EFFECTED	15:12	15:56	0:44	HAND TRIPPED
163	6-Nov-20	MYSORE	220	KR PETE 220-CR PATNA	NO STATIONS EFFECTED	12:07	13:18	1:11	LINE CLEAR AVAILED
164	6-Nov-20	MYSORE	220	HV2	KRPET_220	14:32	14:49	0:17	HAND TRIPPED
165	6-Nov-20	MYSORE	66	VAJMANGALA-JYOTHINAGARA	JYOTHINAGARA_66 DKMAIDANA_66 FTS_66	6:07	6:19	0:11	LINE FAULT
166	6-Nov-20	MYSORE	66	HV2	DKMAIDANA_66	12:32	12:35	0:03	TRANSFORMER FAULT
167	6-Nov-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	17:57	18:02	0:05	LINE FAULT
168	6-Nov-20	MYSORE	66	VIJAYANAGARA-HOOTAGALLY	NO STATIONS EFFECTED	14:07	16:25	2:18	LINE CLEAR AVAILED

169	6-Nov-20	MYSORE	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	8:15	8:29	0:14	LINE FAULT
170	6-Nov-20	MYSORE	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	9:07	9:11	0:03	LINE FAULT
171	6-Nov-20	MYSORE	66	HV1	HONNALY_MYS_66	19:22	20:54	1:31	TRANSFORMER FAULT
172	6-Nov-20	MYSORE	66	HV2	HONNALY_MYS_66	19:22	20:54	1:31	LINE CLEAR AVAILED
173	6-Nov-20	MYSORE	66	TALAKADU-ADANI SOLAR	NO STATIONS EFFECTED	18:15	21:49	3:34	LINE CLEAR AVAILED
174	6-Nov-20	MYSORE	66	HV2	BGPURA_66	6:20	6:30	0:09	TRANSFORMER FAULT
175	6-Nov-20	MYSORE	66	HV1	GUNDULPET_66	17:38	18:03	0:25	LINE CLEAR AVAILED
176	6-Nov-20	MYSORE	66	SHANIVARSANTHE-MALLIPATNA	SANIVARASANTHE_66	18:28	18:45	0:16	LINE FAULT
177	6-Nov-20	MYSORE	66	HV2	MADDUR_66	13:11	13:34	0:22	LINE CLEAR AVAILED
178	6-Nov-20	MYSORE	66	HV2	MALAVALLI_66	15:32	16:48	1:16	LINE CLEAR AVAILED
184	6-Nov-20	MYSORE	66	KUSHALNAGARA 220-BYLUKUPPE	BYLUKUPPE_66 PERIYAPATNA_66 PONNAMPET_66 VIRAJPET_66 HANAGODU_66	19:41	20:19	0:38	LINE FAULT
185	6-Nov-20	MYSORE	66	BYLUKUPPE-KUSHALNAGARA	BYLUKUPPE_66	12:01	15:36	3:35	LINE CLEAR AVAILED
187	6-Nov-20	MYSORE	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66 HANAGODU_66	11:35	11:50	0:15	LINE CLEAR AVAILED
188	6-Nov-20	MYSORE	66	PERIYAPATNA-HUNSUR	NO STATIONS EFFECTED	19:40(6.11.2020)			LINE OPEN: LINE FAULT
189	6-Nov-20	MYSORE	66	DUNDANALLY-HULIYUR DURGA	DUNDANAHALLI_66	8:40	8:45	0:05	HAND TRIPPED
190	6-Nov-20	MYSORE	66	KOLLEGALA-MADHUVANALLY	NO STATIONS EFFECTED	13:19	13:36	0:16	HAND TRIPPED
191	6-Nov-20	MYSORE	66	HV2	BGNAGARA_66	9:15	10:15	1:00	TRANSFORMER FAULT
192	6-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
193	6-Nov-20	TUMKUR	220	TR-1(HV SIDE)	ANTHRASANAHALLI_220	11:40	16:36	4:55	LINE CLEAR AVAILED
194	6-Nov-20	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:37	18:28	6:50	LINE CLEAR AVAILED
195	6-Nov-20	TUMKUR	220	ANCHEPALYA 220kV- NELMANGALA 1	ANCHEPALYA_220	14:09	14:55	0:45	LINE FAULT
196	6-Nov-20	TUMKUR	110	TR-1	BIDARE_110	9:50	9:58	0:08	TRANSFORMER FAULT
197	6-Nov-20	TUMKUR	110	TR-1	HANDANKERE_110	14:48	15:05	0:16	LINE CLEAR AVAILED
198	6-Nov-20	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	9:35	19:11	9:36	LINE CLEAR AVAILED
199	6-Nov-20	TUMKUR	66	TR-1(LV SIDE)	ANTHRASANAHALLI_220	11:40	16:37	4:56	LINE CLEAR AVAILED
200	6-Nov-20	TUMKUR	66	ANTHRASANAHALLI 220KV- KOLALA (dabaspete)	KOLALA_66, URDIGERE_66	11:28	17:51	6:23	LINE CLEAR AVAILED
201	6-Nov-20	TUMKUR	66	KALAMARANAHALLI- BPCLSOLAR_IPP_66	BPCLSOLAR_IPP_66	14:34	15:06	0:31	LINE FAULT
202	6-Nov-20	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	14:34	14:52	0:17	HAND TRIPPED
203	6-Nov-20	TUMKUR	66	KALAMARANAHALLI- PR PURA	KALAMARANAHALLI_66	14:48	15:19	0:31	HAND TRIPPED
204	6-Nov-20	TUMKUR	66	TR-1	MATHOD_66	10:33	10:40	0:07	TRANSFORMER FAULT
205	6-Nov-20	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHANGIDURGA_66, PALLAGATTE_66, SOKKE_66	6:22	6:34	0:11	LINE FAULT
206	6-Nov-20	TUMKUR	66	TR-1	SOKKE_66	12:00	14:28	2:27	LINE CLEAR AVAILED
207	6-Nov-20	TUMKUR	66	TR-2	URDIGERE_66	11:43	12:34	0:51	LINE CLEAR AVAILED
208	6-Nov-20	TUMKUR	66	URDIGERE-ANTHRASANAHALLI	URDIGERE_66	11:42	17:51	6:08	LINE CLEAR AVAILED
209	6-Nov-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	11:27	12:34	1:06	LINE CLEAR AVAILED
210	6-Nov-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	17:37	17:53	0:15	HAND TRIPPED
1	7-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT

#	Date	Region	kV	Line	Station	Time 1	Time 2	Duration	Remarks
2	7-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN :LINE CLEAR AVAILED
3	7-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
4	7-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN :LINE CLEAR AVAILED
5	7-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
6	7-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN :LINE CLEAR AVAILED
7	7-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN :LINE CLEAR AVAILED
8	7-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
9	7-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)			LINE OPEN: LINE FAULT
10	7-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN :LINE CLEAR AVAILED
11	7-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	9:06 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
12	7-Nov-20	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	16:52 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
13	7-Nov-20	BAGALKOT	220	PONDA2-AMBEWADI2	STATION NOT AFFECTED AMBEWADI_220	14:04 (05.11.2020)	12:37 (07.11.2020)	46:31hrs	LINE CHARGED
14	7-Nov-20	BAGALKOT	110	BIDNAL-P H COMPOUND	PH COMPOUND_110	14:37 (6.11.2020)	14:48 (07.11.2020)	24:11hrs	LINE CHARGED
15	7-Nov-20	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA_110	08:49	08:58	0:09	LINE FAULT
16	7-Nov-20	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA_110	9:19	9:33	0:14	LINE FAULT
17	7-Nov-20	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA_110	10:21	10:25	0:04	HAND TRIPPED
18	7-Nov-20	BAGALKOT	110	AMBEWADI- NK2 (KAVALWADA)	KAVALWADA_110	11:19	16:29	5:10	LINE FAULT
19	7-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	LOKAPUR_110	2:17	12:46	10:29	LINE FAULT
20	7-Nov-20	BAGALKOT	110	BELLATTI-ENERCON2	BELLATTI_110	14:04	14:34	0:30	HAND TRIPPED
21	7-Nov-20	BAGALKOT	110	BELLATTI-ADITYA BIRLA SLR	BELLATTI_110	14:03	14:32	0:29	HAND TRIPPED
22	7-Nov-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	19:43	20:15	0:32	LINE CLEAR AVAILED
23	7-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	0:30	8:14	7:44	LINE CLEAR AVAILED
24	7-Nov-20	BAGALKOT	220	BELGAUM-CHIKKODI1	BELGAUM_220	11:45	18:49	7:04	NFBC ISSUED
25	7-Nov-20	BAGALKOT	110	110/33KV, HV4	GAJENDRAGAD_110,WIND3&4_33	10:07	17:51	7:44	LINE CLEAR AVAILED
26	7-Nov-20	BAGALKOT	110	GAJENDRAGAD-RON1	STATON NOT AFFECTED GAJENDRAGAD_110	10:27	17:51	7:24	LINE CLEAR AVAILED
27	7-Nov-20	BAGALKOT	110	GAJENDRAGAD-RON2	STATON NOT AFFECTED GAJENDRAGAD_110	10:26	20:09	9:43	LINE CLEAR AVAILED
28	7-Nov-20	BAGALKOT	110	GAJENDRAGAD-RON1	STATON NOT AFFECTED GAJENDRAGAD_110	19:45	20:08	0:23	LINE CLEAR AVAILED
29	7-Nov-20	BAGALKOT	110	KUSHTAGI220-GAJENDRAGAD	STATON NOT AFFECTED GAJENDRAGAD_220	10:30	19:55	9:25	LINE CLEAR AVAILED
30	7-Nov-20	BAGALKOT	110	110/33KV, HV3	GOPANAKOPPA_110 KMC_33	13:08	14:14	1:06	LINE CLEAR AVAILED

31	7-Nov-20	BAGALKOT	110	HAVERI220-SAVANUR	STATION NOT AFFECTED SAVANUR_110	8:40	17:26	8:46	LINE CLEAR AVAILED
32	7-Nov-20	BAGALKOT	110	110/11KV, HV4	KERUR_110	10:01	10:34	0:33	LINE CLEAR AVAILED
33	7-Nov-20	BAGALKOT	110	KIRUVATTI-AMBEWADI220	STATION NOT AFFECTED KIRUVATTI_110	14:57	16:14	1:17	LINE CLEAR AVAILED
34	7-Nov-20	BAGALKOT	110	KARWAR220-BINAGA(SOLARIS)	BINAGA(SOLARIS)_110	12:33	13:08	0:35	LINE FAULT
35	7-Nov-20	BAGALKOT	220	KADRA1&2-KARWAR220	KARAWAR_220	12:14	12:27	0:13	LINE FAULT
36	7-Nov-20	BAGALKOT	110	110/33KV,HV4	ZALKI_110,HALASANGI_33,NEEVARGI_33,DULKHED_33	13:08	13:14	0:06	TRANSFORMER FAULT
37	7-Nov-20	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	10:07	11:03	0:56	LINE CLEAR AVAILED
38	7-Nov-20	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	13:53	14:51	0:58	LINE CLEAR AVAILED
39	7-Nov-20	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED KAVALWADA_110	8:50	8:59	0:09	LINE FAULT
40	7-Nov-20	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED KAVALWADA_110	9:20	9:57	0:37	LINE FAULT
41	7-Nov-20	BAGALKOT	110	SIRSI220-KAVALWADA	STATION NOT AFFECTED KAVALWADA_110	11:19	18:28	7:09	LINE FAULT
42	7-Nov-20	BAGALKOT	220	HUBLI-NARENDRA2	HUBLI_220	11:43	15:39	3:56	LINE FAULT
43	7-Nov-20	BAGALKOT	110	JOG1&2-SIRSI	SIRSI_110	10:10	11:05	0:55	LINE CLEAR AVAILED
44	7-Nov-20	BAGALKOT	110	JOG1&2-SIRSI	SIRSI_110	13:54	14:52	0:58	LINE CLEAR AVAILED
45	7-Nov-20	BAGALKOT	110	KUMTA1&2-SIRSI	STATION NOT AFFECTED KUMTA_110	8:55	18:35	9:40	LINE CLEAR AVAILED
46	7-Nov-20	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	7:24	9:03	1:39	LINE CLEAR AVAILED
47	7-Nov-20	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	11:38	11:49	0:11	TRANSFORMER FAULT
48	7-Nov-20	BAGALKOT	110	110/11KV,HV1	SAIDAPUR_110	13:34	14:05	0:31	LINE CLEAR AVAILED
49	7-Nov-20	BAGALKOT	110	RON-GAJENDRAGAD1&2	RON_110	10:35	17:34	6:59	LINE CLEAR AVAILED
50	7-Nov-20	BAGALKOT	110	110/11KV,HV2	RON_110	19:42	20:20	0:38	TRANSFORMER FAULT
51	7-Nov-20	BAGALKOT	110	110/11KV,HV2	RON_110	21:21	21:41	0:20	TRANSFORMER FAULT
52	7-Nov-20	BAGALKOT	110	GAMESH-RON	STATION NOT AFFECTED RON_110	20:20	20:23	0:03	HAND TRIPPED
53	7-Nov-20	BAGALKOT	110	RON-HIREHAL	STATION NOT AFFECTED HIREHAL_110	20:39	23:56	3:17	LINE FAULT
54	7-Nov-20	BAGALKOT	110	110/11KV,HV4	RANEBENNUR_220,RSNG_33,KUPPELLURE_33	10:12	17:56	7:44	LINE CLEAR AVAILED
55	7-Nov-20	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	14:48	15:43	0:55	TRANSFORMER FAULT
56	7-Nov-20	BAGALKOT	110	NAREGAL-RON	STATION NOT AFFECTED RON_110	19:43 (07.11.2020)			LINE OPEN: LINE FAULT
57	7-Nov-20	BAGALKOT	110	CHIKKODI_220-NANADI	NANADI_110	5:08	5:09	0:01	HAND TRIPPED
58	7-Nov-20	BAGALKOT	110	220/110KV,LV2	MK HUBLI_220	1:05	7:07	6:02	LOAD CURTAILMENT
59	7-Nov-20	BAGALKOT	110	110/11KV,HV1	MAMADAPUR(B)_110	4:26	4:38	0:12	TRANSFORMER FAULT
60	7-Nov-20	BAGALKOT	220	KUDUCHI-MAHALINGAPUR	STATION NOT AFFECTED KUDUCHI_220	12:34	14:37	2:03	LINE CLEAR AVAILED
61	7-Nov-20	BAGALKOT	110	LAXMESHWAR-BELLATTI	BELLATTI_110	13:58	14:29	0:31	LINE FAULT
62	7-Nov-20	BENGALURU	66	IISC - NRS 220	IISC	06:13	06:18	00:05	LOAD CHANGE OVER
63	7-Nov-20	BENGALURU	66	SRS PEENYA 220 - BYADRAHALLI	BYADRAHALLI, TAVAREKERE, KODIHALLI	07:44	09:15	01:31	LINE FAULT
64	7-Nov-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	08:48	09:43	00:55	LINE CLEAR AVAILED

65	7-Nov-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI,YEDUMADU	16:57	17:48	00:51	LINE CLEAR AVAILED
66	7-Nov-20	BENGALURU	66	KANAKAPURA 220 - TK HALLI 1	HUKUNDA, KODIHALLI, HUNSENAHALLI, HAROBELE	17:05	17:16	00:11	LINE FAULT
67	7-Nov-20	BENGALURU	66	HANUMANTHNAGARA - KANAKAPURA 220	HANUMANTHNAGARA	16:57	17:15	00:18	LOAD CHANGE OVER
68	7-Nov-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	06:35	06:40	00:05	LINE FAULT
69	7-Nov-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	08:49	08:52	00:03	LINE FAULT
70	7-Nov-20	BENGALURU	66	AGALAKOTE - MATHIKERE	MATHIKERE	19:35	22:26	02:50	LINE FAULT
71	7-Nov-20	BENGALURU	66	BAGHMANE WORLD TECH PARK - HAL 2	BAGHMANE WORLD TECH PARK	17:40	17:47	00:07	LOAD CHANGE OVER
72	7-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:20	11:23	01:03	MAIN SUPPLY FAILURE
73	7-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	22:05	22:08	00:03	LOAD CHANGE OVER
74	7-Nov-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	10:20	11:15	00:55	MAIN SUPPLY FAILURE
75	7-Nov-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:20	14:38	04:18	MAIN SUPPLY FAILURE
76	7-Nov-20	BENGALURU	66	LAKSHMIPURA - ADDAGAL	ADDAGAL	18:50	19:00	00:10	LINE CLEAR AVAILED
77	7-Nov-20	BENGALURU	66	SM MANGALA - CHINTAMANI 66	NO STATION AFFECTED	05:21	05:29	00:08	LINE FAULT
78	7-Nov-20	BENGALURU	66	SM MANGALA - CHINTAMANI 66	NO STATION AFFECTED	05:29	08:46	03:17	LINE FAULT
79	7-Nov-20	BENGALURU	66	SM MANGALA - CHINTAMANI 66	NO STATION AFFECTED	08:46	09:47	01:00	LINE FAULT
80	7-Nov-20	BENGALURU	66	HV1	D CROSS	06:41	06:46	00:04	TRANSFORMER FAULT
81	7-Nov-20	BENGALURU	66	HV1	D CROSS	08:30	08:35	00:04	TRANSFORMER FAULT
82	7-Nov-20	BENGALURU	66	HV2	HOSOR RAMAPURA	12:22	13:16	00:53	LINE CLEAR AVAILED
83	7-Nov-20	BENGALURU	220	HV3	KOLAR 220	10:20	14:33	04:13	TRANSFORMER FAULT
84	7-Nov-20	BENGALURU	66	HV1	SOMANATHPURA	09:57	11:10	01:12	LINE CLEAR AVAILED
85	7-Nov-20	BENGALURU	66	KACHMARANAHALLI - DOMMASANDRA	KACHMARANAHALLI	20:58	21:00	00:02	LOAD CHANGE OVER
86	7-Nov-20	BENGALURU	66	YEDUMADU - HANUMANTHNAGAR	YEDUMADU	08:50	09:50	01:00	MAIN SUPPLY FAILURE
87	7-Nov-20	BENGALURU	66	YEDUMADU - SOMANAHALLI 220	YEDUMADU	16:55	17:10	00:15	LOAD CHANGE OVER
88	7-Nov-20	BENGALURU	66	HOSKOTE 66- HOSKOTE 220	HOSKOTE 66	17:30	17:35	00:05	LOAD CHANGE OVER
89	7-Nov-20	BENGALURU	66	HAL 220 - BMRCL	NO STATION AFFECTED	20:17(05-11-2020)			LINE OPEN: LINE FAULT
90	7-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
91	7-Nov-20	GULBARGA	220	HALBARGA-HUMNABAD2	HALBARGA_220	18:30	19:06	00:36	LINE FAULT
92	7-Nov-20	GULBARGA	110	LADHA-ACMESOLAR_IPP	LADHA_110	18:00(6.11.2020)	2:00(7.11.2020)	8:00HRS	LINE CHARGED
93	7-Nov-20	GULBARGA	110	HV1	GURUMITAKAL_110	10:25	10:36	00:11	TRANSFORMER FAULT
94	7-Nov-20	GULBARGA	110	HV1	HARVI_110	13:24	13:27	00:03	LINE CLEAR AVAILED
95	7-Nov-20	GULBARGA	110	JANAWADA-SANTAPUR	JANAWADA_110	13:06	13:29	00:23	LINE CLEAR AVAILED
96	7-Nov-20	GULBARGA	110	HV2	KAMPLI_GLB_110	13:18	13:23	00:05	TRANSFORMER FAULT
97	7-Nov-20	GULBARGA	110	HV1	MANVI_110	11:06	11:21	00:15	TRANSFORMER FAULT
98	7-Nov-20	GULBARGA	110	HV2	NALWAR_110	16:25	16:30	00:05	TRANSFORMER FAULT
99	7-Nov-20	GULBARGA	110	NALWAR-WARDA_SLR	NALWAR_110	00:48	01:00	00:12	LINE FAULT
100	7-Nov-20	GULBARGA	110	STAR METALLIC-MUNIRABAD	STAR METALLIC_IPP	10:47	10:54	00:07	LINE FAULT
101	7-Nov-20	GULBARGA	110	TEKKALKOTE-SIRIGUPPA	TEKKALKOTE_110	09:50	10:20	00:30	LINE FAULT
102	7-Nov-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110,HUNASGI_110,ASKI_110,UGAR SUGAR_IPP	21:10	21:21	00:11	LINE FAULT

103	7-Nov-20	GULBARGA	110	HALBARGA-SANTPUR	SANTPUR_110	18:02	18:10	00:08	LINE FAULT
104	7-Nov-20	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:02	18:18	00:16	LINE FAULT
105	7-Nov-20	GULBARGA	110	HV2	KAMPLI_GLB_110	20:37	20:47	00:10	TRANSFORMER FAULT
106	7-Nov-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	19:46	19:51	00:05	LINE FAULT
107	7-Nov-20	GULBARGA	110	MASKI-HATTI	HATTI_110	19:46(7.11.2020)			LINE OPEN: LINE FAULT
108	7-Nov-20	GULBARGA	110	HV1	SIRWAR_110	10:30	17:30	07:00	LINE CLEAR AVAILED
109	7-Nov-20	GULBARGA	110	HV1	SIRWAR_110	17:50	18:50	01:00	LINE CLEAR AVAILED
110	7-Nov-20	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	18:51(7.11.2020)			LINE OPEN :LINE CLEAR AVAILED
111	7-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
112	7-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:09 (6.11.2020)			LINE OPEN :LINE CLEAR AVAILED
113	7-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	09:55	23:31	13:36	LINE CLEAR AVAILED
114	7-Nov-20	HASSAN	220	UPCL-KEMAR1	upcl_gen	11:34	12:51	01:17	LINE CLEAR AVAILED
115	7-Nov-20	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	17:11	19:17	02:06	LINE CLEAR AVAILED
116	7-Nov-20	HASSAN	220	KEMAR-BAJPE1	KEMAR_220	10:32	12:07	01:35	LINE CLEAR AVAILED
117	7-Nov-20	HASSAN	220	KEMAR-UPCL1	KEMAR_220	11:34	12:51	01:17	LINE CLEAR AVAILED
118	7-Nov-20	HASSAN	220	MRSSHM-KBCRS	MRSMG_220	13:15	15:18	02:03	LINE FAULT
119	7-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY1	MRSMG_220	09:16	17:11	07:55	LINE CLEAR AVAILED
120	7-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY4	MRSMG_220	14:00	14:35	00:35	LINE FAULT
121	7-Nov-20	HASSAN	66	MRSSHM-HOLUR	MRSMG_220	10:38	14:52	04:14	LINE CLEAR AVAILED
122	7-Nov-20	HASSAN	220	HV2	MSEZ_220	10:39	11:36	00:57	LINE CLEAR AVAILED
123	7-Nov-20	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	11:43	11:49	00:06	HAND TRIPPED
124	7-Nov-20	HASSAN	110	LV2	MSEZ_220	10:39	11:36	00:57	LINE CLEAR AVAILED
125	7-Nov-20	HASSAN	220	SHRAVTY-SHIMOGA4	sharavathy_gen	14:00	14:35	00:35	LINE FAULT
126	7-Nov-20	HASSAN	110	HV1	BANAVARA_110	16:04	16:17	00:13	LINE CLEAR AVAILED
127	7-Nov-20	HASSAN	110	KADUR-NGNHL	KADUR_220	13:58	14:22	00:24	HAND TRIPPED
128	7-Nov-20	HASSAN	110	PUTTUR-SLTR	PUTTUR_220	08:03	14:20	06:17	LINE CLEAR AVAILED
129	7-Nov-20	HASSAN	110	SALATHU-NTMDNOR	SALATHUR_110	07:41	14:25	06:44	NFBC ISSUED
130	7-Nov-20	HASSAN	66	BANDISH-ADANI	BANDISHETTYHALLI_66	18:25	21:39	03:14	LINE CLEAR AVAILED
131	7-Nov-20	HASSAN	66	HV1	HOLALUR_66	10:45	14:53	04:08	NFBC ISSUED
132	7-Nov-20	HASSAN	66	HV2	HOLALUR_66	10:45	14:56	04:11	NFBC ISSUED
133	7-Nov-20	HASSAN	66	HV1	KUDLIGERE_66	09:06	09:31	00:25	LINE CLEAR AVAILED
134	7-Nov-20	HASSAN	66	HV1	KUDLIGERE_66	12:09	12:43	00:34	LINE CLEAR AVAILED
135	7-Nov-20	MYSORE	66	CR NAGARA-KOLLEGALA	NO STATIONS EFFECTED	11:15	14:24	3:08	LINE CLEAR AVAILED
136	7-Nov-20	MYSORE	66	KUSHALNAGARA -RAMNATHPURA-1	ALUR SIDDAPURA_66 KANAGAL_66	10:55	15:23	4:28	LINE CLEAR AVAILED
137	7-Nov-20	MYSORE	66	HADLI-TUBINKERE	HADLI_66	10:01	13:28	3:27	LINE CLEAR AVAILED
138	7-Nov-20	MYSORE	66	CH KATTE-KUSHALNAGARA	CHUNCHUNKATTE_66	11:57	12:38	0:40	LINE CLEAR AVAILED
139	7-Nov-20	MYSORE	66	CH KATTE-KR NAGARA	CHUNCHUNKATTE_66	11:57	12:38	0:40	LINE CLEAR AVAILED
140	7-Nov-20	MYSORE	66	KIRUGA-MALIYURU	NO STATIONS EFFECTED	11:16	11:27	0:11	LINE FAULT
141	7-Nov-20	MYSORE	66	KABHALLY-CLEAN SOLAR	NO STATIONS EFFECTED	17:30	20:56	3:26	LINE CLEAR AVAILED
142	7-Nov-20	MYSORE	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66 HANAGODU_66	15:24	15:32	0:08	HAND TRIPPED

143	7-Nov-20	MYSORE	66	HV1	K_HONNALGERE_66	6:35	6:46	0:11	HAND TRIPPED
144	7-Nov-20	MYSORE	66	HV4	SFCSHIVA_66	11:14	16:22	5:08	LINE CLEAR AVAILED
145	7-Nov-20	MYSORE	66	PERIYAPATNA-HUNSUR	NO STATIONS EFFECTED	19:40 (06/11/2020)	18:15(7.11.20)	22:35 HRS	LINE CHARGED
146	7-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
147	7-Nov-20	TUMKUR	110	TR-1	TURUVEKERE_110	14:57	15:11	0:14	TRANSFORMER FAULT
148	7-Nov-20	TUMKUR	110	TR-1	KBCROSS_220	16:42	16:52	0:10	TRANSFORMER FAULT
149	7-Nov-20	TUMKUR	66	TR-3	IMANGALA_66	20:51	22:10	1:18	TRANSFORMER FAULT
150	7-Nov-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	21:28	21:48	0:20	LINE FAULT
151	7-Nov-20	TUMKUR	66	TR-1	BELADARA_66	12:41	12:46	0:04	LINE CLEAR AVAILED
152	7-Nov-20	TUMKUR	66	HONNALLI 220kV- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	21:32	21:43	0:11	LINE FAULT
153	7-Nov-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	6:04	6:14	0:10	LINE FAULT
154	7-Nov-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	15:04	15:46	0:42	TRANSFORMER FAULT
155	7-Nov-20	TUMKUR	66	MALEBENNUR-HONNALLI220	MALEBENNUR_66	18:12	18:34	0:22	LINE FAULT
156	7-Nov-20	TUMKUR	66	TR-2	NAYAKANAHATTI_66	12:40	13:18	0:37	LINE CLEAR AVAILED
157	7-Nov-20	TUMKUR	66	TR-1	THIMMASANDRA_66	6:11	6:20	0:08	TRANSFORMER FAULT
158	7-Nov-20	TUMKUR	66	TR-2	URDIGERE_66	15:59	17:17	1:17	LINE CLEAR AVAILED
159	8-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
160	8-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN :LINE CLEAR AVAILED
161	8-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
162	8-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN :LINE CLEAR AVAILED
163	8-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
164	8-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN :LINE CLEAR AVAILED
165	8-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN :LINE CLEAR AVAILED
166	8-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
167	8-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)			LINE OPEN: LINE FAULT
168	8-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN :LINE CLEAR AVAILED
169	8-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	9:06 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
170	8-Nov-20	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	16:52 (04.11.2020)			LINE OPEN :LINE CLEAR AVAILED
171	8-Nov-20	BAGALKOT	110	NAREGAL-RON	STATION NOT AFFECTED RON_110	19:43 (07.11.2020)	11:43 (08.11.2020)	16:00hrs	LINE CHARGED
172	8-Nov-20	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	20:45	21:03	0:18	TRANSFORMER FAULT

173	8-Nov-20	BAGALKOT	110	110/11KV, HV1	BETAGERI_110	10:01	15:26	5:25	LINE CLEAR AVAILED
174	8-Nov-20	BAGALKOT	110	BELGAUM220-UCHAGOAN	UCHAGOAN_110	8:45	13:33	4:48	LINE CLEAR AVAILED
175	8-Nov-20	BAGALKOT	220	220/110KV, HV2	BELGAUM_220	10:39	13:26	2:47	LINE CLEAR AVAILED
176	8-Nov-20	BAGALKOT	220	220/110KV,LV2	BELGAUM_220	10:39	13:26	2:47	LINE CLEAR AVAILED
177	8-Nov-20	BAGALKOT	220	BELGAUM-KANABARGI1	STATON NOT AFFECTED BELGAUM_220	23:26 (08.11.2020)			LINE OPEN :LINE CLEAR AVAILED
178	8-Nov-20	BAGALKOT	110	CHIKKODI220-NIPPANI	NIPPANI_110	12:24	13:16	0:52	LINE CLEAR AVAILED
179	8-Nov-20	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI220	STATON NOT AFFECTED GAJENDRAGAD_110	12:04 (08.11.2020)			LINE OPEN :LINE CLEAR AVAILED
180	8-Nov-20	BAGALKOT	110	GHATAPRABHA-HIDAKAL DAM	HIDAKAL DAM_110	23:29	23:47	0:18	LINE FAULT
181	8-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
182	8-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
183	8-Nov-20	BAGALKOT	220	KARWAR220-KADRA1&2	KARAWAR_220	17:25	18:30	1:05	LINE FAULT
184	8-Nov-20	BAGALKOT	220	VAJRAMATTI-MAHALINGAPUR2	VAJRAMATTI_220	13:24	14:38	1:14	LINE FAULT
185	8-Nov-20	BAGALKOT	110	UCHAGOAN-UDYAMBAG	STATION NOT AFFECTED UDYAMBAG_110	8:39	13:39	5:00	LINE CLEAR AVAILED
186	8-Nov-20	BAGALKOT	110	BELGAUM-UCHAGOAN	UCHAGOAN_110	9:57	13:39	3:42	LINE CLEAR AVAILED
187	8-Nov-20	BAGALKOT	110	110/11KV,HV1&2	UCHAGOAN_110	9:57	13:39	3:42	LINE CLEAR AVAILED
188	8-Nov-20	BAGALKOT	110	110/11KV,HV2	NIPPANI_110	12:15	18:16	6:01	LINE CLEAR AVAILED
189	8-Nov-20	BAGALKOT	110	110/33KV,HV3	NIPPANI_110,MAGNUM TUFF_33,BENADI_33	12:05	16:23	4:18	LINE CLEAR AVAILED
190	8-Nov-20	BAGALKOT	110	110/11KV,HV1	NIPPAN_110	12:15	16:05	3:50	LINE CLEAR AVAILED
191	8-Nov-20	BAGALKOT	110	NAREGAL-RON	RON_110	11:49	12:04	0:15	LINE CLEAR AVAILED
192	8-Nov-20	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	21:58	22:06	00:08	TRANSFORMER FAULT
193	8-Nov-20	BENGALURU	66	HV2	ELECTRONIC CITY P2 S2	23:26	23:31	00:05	TRANSFORMER FAULT
194	8-Nov-20	BENGALURU	66	GOKULA - SRS PEENYA 1	GOKULA, BEL (EHT), HMT (EHT)	15:55	17:00	01:05	LINE CLEAR AVAILED
195	8-Nov-20	BENGALURU	66	GOKULA - SRS PEENYA 2	GOKULA, BEL (EHT), HMT (EHT)	15:55	16:50	00:55	LINE CLEAR AVAILED
196	8-Nov-20	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	15:55	17:01	01:06	LINE CLEAR AVAILED
197	8-Nov-20	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	15:55	17:01	01:06	LINE CLEAR AVAILED
198	8-Nov-20	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	10:31	10:35	00:04	LOAD CHANGE OVER
199	8-Nov-20	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	11:08	11:12	00:04	LOAD CHANGE OVER
200	8-Nov-20	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	15:35	15:40	00:05	LOAD CHANGE OVER
201	8-Nov-20	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	17:05	17:10	00:05	LOAD CHANGE OVER
202	8-Nov-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	15:13	15:15	00:02	LOAD CHANGE OVER
203	8-Nov-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	17:06	17:09	00:03	LOAD CHANGE OVER
204	8-Nov-20	BENGALURU	66	YELAHANKA 220 - LINE 8	RAJANKUNTE	09:42	10:01	00:19	LINE FAULT
205	8-Nov-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	07:28	07:32	00:03	LOAD CHANGE OVER
206	8-Nov-20	BENGALURU	66	HV1	HOSUR RAMAPURA	15:32	15:51	00:18	TRANSFORMER FAULT
207	8-Nov-20	BENGALURU	66	HV1	KACHMARANAHALLI	11:30	11:35	00:04	LINE CLEAR AVAILED
208	8-Nov-20	BENGALURU	66	GODUR - MARALWADI	GODUR	08:48	17:50	09:02	MAIN SUPPLY FAILURE

209	8-Nov-20	BENGALURU	66	HAL 220 - BMRCL	NO STATION AFFECTED	20:17(05-11-2020)			LINE OPEN: LINE FAULT
210	8-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
211	8-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN: LINE FAULT
212	8-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN :LINE CLEAR AVAILED
213	8-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
214	8-Nov-20	GULBARGA	400	JINDAAL-BTPS	BTPS_400	21:45	07:56	10:12	LINE CLEAR AVAILED
215	8-Nov-20	GULBARGA	110	MASKI-HATTI	HATTI_110	19:46(7.11.2020)	12:37(8.11.2020)	16:51 HRS	LINE CHARGED
216	8-Nov-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110,HATTI_110	20:47	20:54	00:07	MAIN SUPPLY FAILURE
217	8-Nov-20	GULBARGA	110	MASKI-SINDHANOOR	MASKI_110	23:09	23:13	00:04	LINE FAULT
218	8-Nov-20	GULBARGA	110	MASKI-HATTI	HATTI_110	23:09(8.11.2020)			LINE OPEN: LINE FAULT
219	8-Nov-20	GULBARGA	110	VALKAMDINNI-SINDHANOOR(IDLE LINE)	BYAGAWAT_110(NO AFFECTED STATION)	00:50	18:10	17:20	LINE FAULT
220	8-Nov-20	GULBARGA	110	HV2	MADIYAL_110	11:10	11:34	00:24	TRANSFORMER FAULT
221	8-Nov-20	GULBARGA	110	HV2	NALWAR_110	13:04	13:09	00:05	TRANSFORMER FAULT
222	8-Nov-20	GULBARGA	110	NALWAR-CLNSLR	NALWAR_110	04:54	05:54	01:00	LINE FAULT
223	8-Nov-20	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	18:51(7.11.2020)	2:50(8.11.2020)	7:59 HRS	LINE CHARGED
224	8-Nov-20	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	19:15(8.11.2020)			LINE OPEN :LINE CLEAR AVAILED
225	8-Nov-20	GULBARGA	66	HV1	GUDEKOTE_66	09:51	10:25	00:34	LINE CLEAR AVAILED
226	8-Nov-20	GULBARGA	66	HV2	GUDEKOTE_66	10:20	10:25	00:05	LINE CLEAR AVAILED
227	8-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
228	8-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:09 (6.11.2020)			LINE OPEN :LINE CLEAR AVAILED
229	8-Nov-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	09:55	15:35	05:40	LINE CLEAR AVAILED
230	8-Nov-20	HASSAN	220	HV1	ARASIKERE_220	03:41	07:51	04:10	TRANSFORMER FAULT
231	8-Nov-20	HASSAN	110	LV1	ARASIKERE_220	03:41	07:51	04:10	TRANSFORMER FAULT
232	8-Nov-20	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	09:37	19:13	09:36	LINE CLEAR AVAILED
233	8-Nov-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	09:38	19:12	09:34	LINE CLEAR AVAILED
234	8-Nov-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMG_220	11:42	12:24	00:42	LINE FAULT
235	8-Nov-20	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	11:42	12:24	00:42	LINE FAULT
236	8-Nov-20	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	17:07	17:12	00:05	HAND TRIPPED
237	8-Nov-20	HASSAN	110	HV4	BAIKAMPADI_110	13:00	16:38	03:38	LINE CLEAR AVAILED
238	8-Nov-20	HASSAN	110	HV1	NANDIKUR_110	19:45	19:49	00:04	HAND TRIPPED
239	8-Nov-20	HASSAN	110	HV2	NANDIKUR_110	19:45	19:50	00:05	HAND TRIPPED
240	8-Nov-20	HASSAN	110	NANDIKU-ISTRL	NANDIKUR_110	19:44	19:58	00:14	HAND TRIPPED
241	8-Nov-20	HASSAN	110	NANDIKU-BELMAN	NANDIKUR_110	19:33	20:09	00:36	LINE FAULT
242	8-Nov-20	HASSAN	110	NANDIKU-KEMAR2	NANDIKUR_110	19:33	19:48	00:15	LINE FAULT
243	8-Nov-20	HASSAN	110	NANDIKU-MULKY	NANDIKUR_110	19:33	20:26	00:53	LINE FAULT

244	8-Nov-20	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	13:14	14:59	01:45	LINE CLEAR AVAILED
245	8-Nov-20	HASSAN	66	HNPR2-MYSOR1	HOLENARASIPURA_220	06:10	06:15	00:05	LINE FAULT
246	8-Nov-20	MYSORE	220	HOOTAGALLY-BASTHIPURA 1	NO STATIONS EFFECTED	10:25	16:25	6:00	LINE CLEAR AVAILED
247	8-Nov-20	MYSORE	220	HOOTAGALLY-BASTHIPURA 2	NO STATIONS EFFECTED	10:25	16:31	6:06	LINE CLEAR AVAILED
248	8-Nov-20	MYSORE	220	HOOTAGALLY-KADAKOLA	NO STATIONS EFFECTED	10:03	18:40	8:37	LINE CLEAR AVAILED
249	8-Nov-20	MYSORE	220	HOOTAGALLY-VAJMANGLA	NO STATIONS EFFECTED	10:02	16:45	6:43	LINE CLEAR AVAILED
250	8-Nov-20	MYSORE	66	CR NAGARA -KOLLEGALA	KOLLEGALA_66	9:55	17:39	7:44	NFBC ISSUED
251	8-Nov-20	MYSORE	66	KOLLEGALA-PARINAMIPURA	KOLLEGALA_66	10:08	17:48	7:39	LINE CLEAR AVAILED
252	8-Nov-20	MYSORE	66	SATHEGALA-HEBBANI	SATHEGALA_66	10:10	16:30	6:20	LINE CLEAR AVAILED
253	8-Nov-20	MYSORE	66	SATHEGALA-KOLLEGALA	SATHEGALA_66	10:10	16:30	6:20	LINE CLEAR AVAILED
254	8-Nov-20	MYSORE	66	SATHEGALA-BPCL	SATHEGALA_66	10:10	16:40	6:29	LINE CLEAR AVAILED
255	8-Nov-20	MYSORE	66	HEBBAL-HOOTAGALLY	HEBBAL_66	10:05	17:10	7:04	LINE CLEAR AVAILED
256	8-Nov-20	MYSORE	66	METAGALLY-HEBBAL	METAGALLY_66	10:03	17:15	7:12	LINE CLEAR AVAILED
257	8-Nov-20	MYSORE	66	METAGALLY-VIKRANTH	NO STATIONS EFFECTED	10:03	17:16	7:13	LINE CLEAR AVAILED
258	8-Nov-20	MYSORE	66	MADHUVANALLY-PG PALYA	PGPALYA_66	10:53	16:24	5:31	LINE CLEAR AVAILED
259	8-Nov-20	MYSORE	66	HV1	MADHUVANAHALLI_220	15:35	16:47	1:11	LINE CLEAR AVAILED
260	8-Nov-20	MYSORE	66	HV2	MADHUVANAHALLI_220	15:35	16:47	1:11	LINE CLEAR AVAILED
261	8-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
262	8-Nov-20	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	14:09	14:20	0:11	LINE FAULT
263	8-Nov-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	6:02	6:07	0:04	LINE FAULT
264	8-Nov-20	TUMKUR	66	MADHUGIRI 220kV- PULAMAGATTA	PULAMG_66	5:38	5:54	0:15	LINE FAULT
265	8-Nov-20	TUMKUR	66	NAGASAMUDRA- RAMPURA	NAGASAMUDRA_66	15:45	15:52	0:07	LINE FAULT
266	8-Nov-20	TUMKUR	66	PAVAGADA-NAGALAMADIKE	NAGALMADIKE_66	8:33	8:44	0:11	LINE FAULT
1	9-Nov-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN: LINE FAULT
2	9-Nov-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN :LINE CLEAR AVAILED
3	9-Nov-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN :LINE CLEAR AVAILED
4	9-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)	13:06 (09.11.2020)	1968:01hrs	LINE CHARGED
5	9-Nov-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN :LINE CLEAR AVAILED
6	9-Nov-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN :LINE CLEAR AVAILED
7	9-Nov-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN :LINE CLEAR AVAILED
8	9-Nov-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
9	9-Nov-20	BAGALKOT	110	BAGALKOT220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	23:18 (02.11.2020)	02:10 (09.11.2020)	170:52hrs	LINE CHARGED
10	9-Nov-20	BAGALKOT	220	BAGEWADI- ATRIA1	STATION NOT AFFECTED BAGEWADI_220	16:21 (02.11.2020)			LINE OPEN :LINE CLEAR AVAILED

11	9-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	9:06 (04.11.2020)	3:48 (09.11.2020)	114:52hrs	LINE CHARGED
12	9-Nov-20	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	16:52 (04.11.2020)	3:49 (09.11.2020)	106:57hrs	LINE CHARGED
13	9-Nov-20	BAGALKOT	220	BELGAUM-KANABARGI1(NARENDRA1)	STATON NOT AFFECTED BELGAUM_220	23:26 (08.11.2020)	9:14 (09.11.2020)	9:48hrs	LINE CHARGED
14	9-Nov-20	BAGALKOT	110	GAJENDRAGAD-KUSHTAGI220	STATON NOT AFFECTED GAJENDRAGAD_110	12:04 (08.11.2020)			LINE OPEN :LINE CLEAR AVAILED
15	9-Nov-20	BAGALKOT	220	220/110KV, HV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
16	9-Nov-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED KARWAR_220	19:07 (08.11.2020)			TRANSFORMER OPEN: TRANSFORMER FAULT
17	9-Nov-20	BAGALKOT	110	ANNIGERI-GADAG	ANNIGERI_110	09:25	16:47	7:22	LINE CLEAR AVAILED
18	9-Nov-20	BAGALKOT	110	110/11KV, HV2	AMBEWADI_220	8:18	8:27	0:09	TRANSFORMER FAULT
19	9-Nov-20	BAGALKOT	220	220/110KV, HV2	AMBEWADI_220	10:10	16:28	6:18	LINE CLEAR AVAILED
20	9-Nov-20	BAGALKOT	110	ATHANI220-SATTI	SATTI_110	10:31	18:45	8:14	LINE CLEAR AVAILED
21	9-Nov-20	BAGALKOT	110	110/11KV, HV2	BANAHATTI_110	8:18	8:28	0:10	TRANSFORMER FAULT
22	9-Nov-20	BAGALKOT	110	BIDNAL220-ANNIGERI	ANNIGERI_110	10:02	16:25	6:23	NFBC ISSUED
23	9-Nov-20	BAGALKOT	110	110/33KV, HV3	BIJAPUR KIADB_110, HONUTAGI_33, NAGTHAN_33	14:29	14:38	0:09	HAND TRIPPED
24	9-Nov-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	14:33 (09.11.2020)			LINE OPEN :LINE CLEAR AVAILED
25	9-Nov-20	BAGALKOT	110	110/33KV, HV4	STATION NOT AFFECTED GADAG_110	12:11	14:41	2:30	LINE CLEAR AVAILED
26	9-Nov-20	BAGALKOT	110	110/11KV, HV2	LOKAPUR_110	1:30	2:30	1:00	TRANSFORMER FAULT
27	9-Nov-20	BAGALKOT	110	110/11KV, HV1	LOKAPUR_110	1:30	2:30	1:00	TRANSFORMER FAULT
28	9-Nov-20	BAGALKOT	110	110/33KV, HV3	LOKAPUR_110, RSSKN_33, BATAKURKI_33	1:30	2:40	1:10	TRANSFORMER FAULT
29	9-Nov-20	BAGALKOT	220	SHARAVATHY2- SIRSI	STATION NOT AFFECTED SIRSI_220	4:01 (09.11.2020)			LINE OPEN :LINE CLEAR AVAILED
30	9-Nov-20	BAGALKOT	220	SHARAVATHY1- SIRSI	STATION NOT AFFECTED SIRSI_220	4:01 (09.11.2020)			LINE OPEN :LINE CLEAR AVAILED
31	9-Nov-20	BAGALKOT	220	HAVERI220-GUTTUR2	STATION NOT AFFECTED HAVERI_220	11:07	18:12	7:05	LINE CLEAR AVAILED
32	9-Nov-20	BAGALKOT	220	CHIKKODI-KUDUCHI	STATION NOT AFFECTED CHIKKODI_220	16:31	16:54	0:23	LINE CLEAR AVAILED
33	9-Nov-20	BAGALKOT	110	SATTI-RABAKAVI	STATION NOT AFFECTED RABAKAVI_110	18:51	19:02	0:11	LINE CLEAR AVAILED
34	9-Nov-20	BAGALKOT	110	110/33KV,HV2	MATTIHAL_110,KOLAR W/S_33,NTPCL_33,KARJOL LIS_33	15:06	15:12	0:06	TRANSFORMER FAULT
35	9-Nov-20	BAGALKOT	110	BELGUM220-KANABARGI LAYOUT	STATION NOT AFFECTED KANABARGI LAYOUT_110	13:08	14:34	1:26	LINE CLEAR AVAILED
36	9-Nov-20	BAGALKOT	110	NEHARU NAGAR -KANABARGI LAYOUT_110	STATION NOT AFFECTED KANABARGI LAYOUT_110	13:05	13:08	0:03	HAND TRIPPED
37	9-Nov-20	BAGALKOT	110	NEHARU NAGAR -KANABARGI LAYOUT_110	STATION NOT AFFECTED KANABARGI LAYOUT_110	14:34	14:36	0:02	HAND TRIPPED
38	9-Nov-20	BAGALKOT	110	110/11KV,HV4	HUKKERI_110	8:59	9:36	0:37	TRANSFORMER FAULT
39	9-Nov-20	BAGALKOT	110	110/11KV,HV2	GOKAK_110	15:47	16:06	0:19	LINE CLEAR AVAILED
40	9-Nov-20	BAGALKOT	110	ENERCON1-SOUDATTI	SOUDATTI_110	11:07	16:06	4:59	LINE CLEAR AVAILED

41	9-Nov-20	BAGALKOT	110	ENERCON2-SOUDATTI	SOUDATTI_110	17:53	20:27	2:34	LINE FAULT
42	9-Nov-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	15:34	15:43	00:09	LOAD CHANGE OVER
43	9-Nov-20	BENGALURU	220	NAGANATHPURA 220 - SOMANAHALLI 220	NAGANATHPURA 220	15:55	16:00	00:05	MAIN SUPPLY FAILURE
44	9-Nov-20	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S1	ELECTRONIC CITY P2 S1	15:55	16:00	00:05	LINE CLEAR AVAILED
45	9-Nov-20	BENGALURU	66	NAGNATHPUTRA 220 - ELECTRONIC CITY P2 S2	ELECTRONIC CITY P2 S2, BIOCON(EHT)	15:55	16:00	00:05	LINE CLEAR AVAILED
46	9-Nov-20	BENGALURU	66	HV1	ELECTRONIC CITY P2 S2	15:52	15:58	00:06	LINE CLEAR AVAILED
47	9-Nov-20	BENGALURU	220	HSR LAYOUT 220 - HOODY 400	HSR LAYOUT 220, KORAMANGALA 220	10:25	10:44	00:19	LINE FAULT
48	9-Nov-20	BENGALURU	220	HSR LAYOUT 220 - SOMANAHALLI 220	HSR LAYOUT 220, KORAMANGALA 220	11:11	12:37	01:26	LINE FAULT
49	9-Nov-20	BENGALURU	66	HSR LAYOUT 220 - ST. JOHNS	ST. JOHNS WOOD	10:25	10:44	00:19	LINE CLEAR AVAILED
50	9-Nov-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	10:25	10:44	00:19	LINE CLEAR AVAILED
51	9-Nov-20	BENGALURU	66	HSR LAYOUT 220 - DEVARBISANAHALLI	DEVARBISANAHALLI	11:11	12:37	01:26	LINE CLEAR AVAILED
52	9-Nov-20	BENGALURU	66	HSR LAYOUT 220 - SHOBHA APARTMENT	SHOBHA APARTMENT	11:11	12:37	01:26	LINE CLEAR AVAILED
53	9-Nov-20	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	10:25	10:51	00:26	LINE CLEAR AVAILED
54	9-Nov-20	BENGALURU	66	NIMHANS 220 - ADUGODI	ADUGODI	10:25	10:52	00:27	LINE CLEAR AVAILED
55	9-Nov-20	BENGALURU	66	NIMHANS 220 - JAYADEVA	JAYADEVA	10:25	10:52	00:27	LINE CLEAR AVAILED
56	9-Nov-20	BENGALURU	66	KADUGODI - ARMY WELFARE	ARMY WELFARE, KONDASPURA	08:37	10:28	01:51	LINE FAULT
57	9-Nov-20	BENGALURU	220	KORAMANGALA 220 - NIMHANS 220	NIMHANS 220	10:25	10:48	00:23	LINE CLEAR AVAILED
58	9-Nov-20	BENGALURU	66	KORAMANGALA 220 - K & C VALLEY	K & C VALLEY	10:25	10:48	00:23	LINE CLEAR AVAILED
59	9-Nov-20	BENGALURU	66	KORAMANGALA 220 - KORAMANGALA 66	KORAMANGALA 66	10:25	10:48	00:23	LINE CLEAR AVAILED
60	9-Nov-20	BENGALURU	66	PLATINUM CITY - YELAHANKA 220	PLATINUM CITY	11:05	11:20	00:15	LOAD CHANGE OVER
61	9-Nov-20	BENGALURU	66	PLATINUM CITY - SRS PEENYA 220	PLATINUM CITY	12:45	12:50	00:05	LOAD CHANGE OVER
62	9-Nov-20	BENGALURU	220	SOMANAHALLI 220 - HSR LAYOUT 220	HSR LAYOUT 220	11:15	18:20	07:05	LINE FAULT
63	9-Nov-20	BENGALURU	220	SOMANAHALLI 220 - NAGANATHPURA 220	NAGANATHPURA 220	15:55	17:40	01:45	LINE CLEAR AVAILED
64	9-Nov-20	BENGALURU	66	ST JOHNS WOOD - HSR LAYOUT 220	ST. JOHNS WOOD	11:12	11:52	00:40	MAIN SUPPLY FAILURE
65	9-Nov-20	BENGALURU	400	HOODY 400 - HSR LAYOUT 220	HSR LAYOUT 220	10:25	13:21	02:56	LINE FAULT
66	9-Nov-20	BENGALURU	66	JAKKASANDRA - ADUGODI	JAKKASANDRA	10:25	11:01	00:36	MAIN SUPPLY FAILURE
67	9-Nov-20	BENGALURU	66	JAKKASANDRA - HSR LAYOUT 220	JAKKASANDRA	11:12	11:25	00:13	MAIN SUPPLY FAILURE
68	9-Nov-20	BENGALURU	66	RBI - SOMANAHALLI 220	RBI	12:13	12:16	00:03	LOAD CHANGE OVER
69	9-Nov-20	BENGALURU	66	RBI - ELITA PROMENENDE	RBI	18:54	18:56	00:02	LOAD CHANGE OVER
70	9-Nov-20	BENGALURU	66	KOLAR 220 - NARASAPURA 2	NO STATION AFFECTED	02:55	04:15	01:20	LINE FAULT
71	9-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	05:22	05:37	00:15	LINE FAULT
72	9-Nov-20	BENGALURU	220	HV1	KOLAR 220	07:53	08:15	00:22	TRANSFORMER FAULT
73	9-Nov-20	BENGALURU	220	HV2	KOLAR 220	07:53	08:15	00:22	TRANSFORMER FAULT
74	9-Nov-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	07:53	08:20	00:27	MAIN SUPPLY FAILURE
75	9-Nov-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	07:53	08:20	00:27	MAIN SUPPLY FAILURE
76	9-Nov-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	07:53	08:20	00:27	MAIN SUPPLY FAILURE
77	9-Nov-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	07:53	8:38	00:45	MAIN SUPPLY FAILURE
78	9-Nov-20	BENGALURU	220	LV3	KOLAR 220	10:45	14:10	03:25	TRANSFORMER FAULT
79	9-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	10:45	11:10	00:25	MAIN SUPPLY FAILURE

80	9-Nov-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	10:45	11:10	00:25	MAIN SUPPLY FAILURE
81	9-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	11:30	11:40	00:10	LINE FAULT
82	9-Nov-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	12:07	12:12	00:05	LINE FAULT
83	9-Nov-20	BENGALURU	66	KOLAR 220 - VOKKALERI	VOKKALERI	10:45	14:15	03:30	MAIN SUPPLY FAILURE
84	9-Nov-20	BENGALURU	66	HAL 220 - BMRCL	NO STATION AFFECTED	20:17(05-11-2020)			LINE OPEN: LINE FAULT
85	9-Nov-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN: LINE FAULT
86	9-Nov-20	GULBARGA	110	GULBARGASOUTH-GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN: LINE FAULT
87	9-Nov-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN :LINE CLEAR AVAILED
88	9-Nov-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
89	9-Nov-20	GULBARGA	400	BTPS-RTPS2	RTPS_400	12:02(9.11.2020)			LINE OPEN: LINE FAULT
90	9-Nov-20	GULBARGA	220	SEDAM-SHAHAPUR	SEDAM_220	00:21	06:21	06:00	LINE FAULT
91	9-Nov-20	GULBARGA	220	SEDAM-HUMANABAD2	SEDAM_220	11:42	17:08	05:26	LINE CLEAR AVAILED
92	9-Nov-20	GULBARGA	220	SHAHAPUR-LINGASUGUR	LINGASUGUR_220	10:02	17:10	07:08	NFBC ISSUED
93	9-Nov-20	GULBARGA	110	MASKI-HATTI	HATTI_110	23:09(8.11.2020)	9:18(9.11.2020)	10:09 HRS	LINE CHARGED
94	9-Nov-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,HUNASGI_110,ASKI_110,UGAR SUGAR_IPP	03:17	03:27	00:10	LINE FAULT
95	9-Nov-20	GULBARGA	110	GURUMITAKAL-KONKAL	KONKAL_110	21:45	21:59	00:14	LINE FAULT
96	9-Nov-20	GULBARGA	110	GURUMITAKAL-SEDAM	GURUMITAKAL_110	21:45	21:55	00:10	MAIN SUPPLY FAILURE
97	9-Nov-20	GULBARGA	66	KOGALI-ASTROSLR	KOGALI_66	19:15(8.11.2020)	2:40(9.11.2020)	7:25 HRS	LINE CHARGED
98	9-Nov-20	HASSAN	220	HV2	GOPALAPURA_220	17:35(29.10.2020)			TRANSFORMER OPEN : LINE CLEAR AVAILED
99	9-Nov-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	23:32(9.11.2020)			LINE OPEN :LINE CLEAR AVAILED
100	9-Nov-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	17:09 (6.11.2020)	8:33(9.11.2020)	63:24hrs	LINE CHARGED
101	9-Nov-20	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	8:40(9.10.2020)			LINE OPEN :LINE CLEAR AVAILED
102	9-Nov-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	9:41 (9.11.2020)			LINE OPEN: LINE FAULT
103	9-Nov-20	HASSAN	220	GERSOPA-TALGUPA1	gerusoppa_gen	10:23	17:09	06:46	LINE CLEAR AVAILED
104	9-Nov-20	HASSAN	220	GERSOPA-TALGUPA2	gerusoppa_gen	10:25	16:52	06:27	LINE CLEAR AVAILED
105	9-Nov-20	HASSAN	220	KADUR-SHIMOGA	KADUR_220	15:53	18:24	02:31	LINE FAULT
106	9-Nov-20	HASSAN	220	KEMAR-PUTUR1	KEMAR_220	10:35	12:57	02:22	LINE CLEAR AVAILED
107	9-Nov-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	10:45	13:11	02:26	LINE CLEAR AVAILED
108	9-Nov-20	HASSAN	220	MRSSHM-KADUR	MRSMG_220	15:53	18:24	02:31	LINE FAULT
109	9-Nov-20	HASSAN	220	MSEZ-KAVOOR2	MSEZ_220	09:23	15:43	06:20	NFBC ISSUED
110	9-Nov-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	10:45	13:11	02:26	LINE CLEAR AVAILED
111	9-Nov-20	HASSAN	110	HV1	KALLUSADARAHALLI_110	14:45	14:54	00:09	HAND TRIPPED
112	9-Nov-20	HASSAN	110	SHRLKP-SHIRALKOPPA	SHIRALKOPPA_220	11:58	12:05	00:07	HAND TRIPPED
113	9-Nov-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	22:37 (9.11.2020)			LINE OPEN :LINE CLEAR AVAILED

114	9-Nov-20	HASSAN	66	HNPR2-HASS3	HOLENARASIPURA_220	21:42	21:47	00:05	LINE FAULT
115	9-Nov-20	HASSAN	66	HNPR2-MYSOR2	HOLENARASIPURA_220	18:25	18:40	00:15	LINE FAULT
116	9-Nov-20	HASSAN	66	HV1	MOSALEHOSAHALLI_66	22:23	22:57	00:34	LINE CLEAR AVAILED
117	9-Nov-20	MYSORE	220	MADHUVANALLY-WARDAH SOLAR	NO STATIONS EFFECTED	18:31(9.11.20)			LINE OPEN :LINE CLEAR AVAILED
118	9-Nov-20	MYSORE	66	ATIGULIPURA-HONNALY	ATTIGULIPURA_66	15:49	16:02	0:12	HAND TRIPPED
119	9-Nov-20	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 KESLAGERE_66 BASARALU_66 VADERALLI _66	11:43	11:53	0:09	LINE FAULT
120	9-Nov-20	MYSORE	66	HV2	SANTHESARAGUR_66	13:30	14:50	1:20	LINE CLEAR AVAILED
121	9-Nov-20	MYSORE	66	HV1	GUNDULPET_66	10:31	11:28	0:56	TRANSFORMER FAULT
122	9-Nov-20	MYSORE	66	HV1	GUNDULPET_66	11:30	13:38	2:07	LINE CLEAR AVAILED
123	9-Nov-20	MYSORE	66	HV1	BOOKANAKERE_66	17:33	18:08	0:35	LINE CLEAR AVAILED
124	9-Nov-20	MYSORE	66	HV1	KHBCOLONY_66	18:09	19:16	1:07	LINE CLEAR AVAILED
125	9-Nov-20	MYSORE	66	HV2	KIKKERI_66	15:01	16:09	1:07	LINE CLEAR AVAILED
126	9-Nov-20	MYSORE	66	HV1	MADDUR_66	17:05	18:06	1:01	LINE CLEAR AVAILED
127	9-Nov-20	MYSORE	66	HV1	MANDGERE_66	18:25	18:41	0:16	MAIN SUPPLY FAILURE
128	9-Nov-20	MYSORE	66	HV2	TERAKANAMBE_66	11:10	11:35	0:24	LINE CLEAR AVAILED
129	9-Nov-20	MYSORE	66	HV2	TERAKANAMBE-	15:50	16:21	0:30	LINE CLEAR AVAILED
130	9-Nov-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN: TRANSFORMER FAULT
131	9-Nov-20	TUMKUR	110	NITTUR 220kV- KALLUR	KALLUR_110	9:34	10:05	0:31	LINE CLEAR AVAILED
132	9-Nov-20	TUMKUR	66	TR-2	ANTHRASANAHALLI_220	19:11	19:44	0:33	TRANSFORMER FAULT
133	9-Nov-20	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66, BHARAMASAGARA_66	10:35	10:54	0:19	LINE FAULT
134	9-Nov-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	5:34	5:38	0:04	LINE FAULT
135	9-Nov-20	TUMKUR	66	TR-1	HULIYURDURGA_66	18:21	18:40	0:19	TRANSFORMER FAULT
136	9-Nov-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	13:04	13:06	0:01	HAND TRIPPED
137	9-Nov-20	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	12:59	13:25	0:26	TRANSFORMER FAULT
138	9-Nov-20	TUMKUR	66	PANDARAHALLI- HOLALKERE	HOLALKERE_66,HDPURA_66,RAMAGIRI_66	5:13	5:31	0:18	LINE FAULT