

400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 02.09.2019 TO 09.09.2019

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
1	3-Sep-19	BAGALKOT	110	110/11KV, HV2	YARGATTI_110	6:04	6:16	0:12	TRANSFORMER FAULT
2	3-Sep-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	14:04	14:07	0:03	LINE CLEAR AVAILED
3	3-Sep-19	BAGALKOT	110	110/11KV, HV1	TODALBAGI_110	17:22	18:02	0:40	LINE CLEAR AVAILED
4	3-Sep-19	BAGALKOT	110	110/33KV, HV3	TODALBAGI_110, BIDARI_33, HIREPADASALAGI_33	17:37	18:02	0:25	LINE CLEAR AVAILED
5	3-Sep-19	BAGALKOT	110	110/11KV, HV1	TILUVALI_110	13:39	23:59	10:20	LINE CLEAR AVAILED
6	3-Sep-19	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	4:56	23:59	19:03	LINE FAULT
7	3-Sep-19	BAGALKOT	220	NARENDRA-HUBLI2	NARENDRA_220	13:13	13:36	0:23	LINE CLEAR AVAILED
8	3-Sep-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	6:40	7:19	0:39	LINE FAULT
9	3-Sep-19	BAGALKOT	220	GUTTUR2-HAVERI	HAVERI_220	16:32	16:51	0:19	LINE FAULT
10	3-Sep-19	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALI_110	5:58	10:44	4:46	LINE FAULT
11	3-Sep-19	BAGALKOT	110	HAVERI220-TILUVALI	TILUVALI_110	11:20	11:23	0:03	HAND TRIPPED
12	3-Sep-19	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	5:57	6:12	0:15	LINE FAULT
13	3-Sep-19	BAGALKOT	110	110/11KV, HV4	GHATAPRABHA_110	8:31	8:33	0:02	TRANSFORMER FAULT
14	3-Sep-19	BAGALKOT	220	220/110KV, HV1&LV1	CHIKKODI_220	11:29	14:31	3:02	LINE CLEAR AVAILED
15	3-Sep-19	BAGALKOT	220	BIJAPUR-BAGEWADI2(GMR 2)	BIJAPUR_220	10:17	14:40	4:23	LINE CLEAR AVAILED
16	3-Sep-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	10:42	11:08	0:26	LINE CLEAR AVAILED
17	3-Sep-19	BAGALKOT	110	110/11KV, HV1	BABLESHWAR_110	8:53	9:27	0:34	LINE CLEAR AVAILED
18	3-Sep-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	14:09	14:22	0:13	LINE FAULT
19	3-Sep-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	9:45	9:55	0:10	LOAD CHANGEVER
20	3-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	20:05	20:10	0:05	LOAD CHANGEVER
21	3-Sep-19	BENGALURU	66	HV2	NARASAPURA	12:15	12:31	0:16	LINE CLEAR AVAILED
22	3-Sep-19	GULBARGA	220	RTPS-SHAHAPUR2	SHAHPUR_220	3:15	12:31	9:16	LINE FAULT
23	3-Sep-19	GULBARGA	220	RTPS-SEDAM2	SEDAM_220	23:08	23:24	0:16	LINE FAULT
24	3-Sep-19	GULBARGA	110	HALBARGA-KAMATHANA	KAMATHANA_110	2:19	2:27	0:08	LINE FAULT
25	3-Sep-19	GULBARGA	110	HALBARGA-SANTHAPUR	SANTHAPUR_110	6:05	6:13	0:08	LINE FAULT
26	3-Sep-19	GULBARGA	110	SINDHANOOR220-PGLRWIND_IPP	SIDHANOOR_220	23:09	23:24	0:15	LINE FAULT
27	3-Sep-19	GULBARGA	66	HV2	HAGARIBOMMANAHALLI_66	15:40	15:45	0:05	TRANSFORMER FAULT
28	3-Sep-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	12:55	13:20	0:25	TRANSFORMER FAULT
29	3-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	10:59	10:59	LINE CLEAR AVAILED
30	3-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:00	23:59	1:59	LINE CLEAR AVAILED
31	3-Sep-19	HASSAN	220	KADUR-DABUSET	KADUR_220	19:47	21:24	1:37	LINE FAULT
32	3-Sep-19	HASSAN	220	KADUR-DABUSET	KADUR_220	22:38	23:59	1:21	NFBC ISSUED
33	3-Sep-19	HASSAN	110	KONAJE-MANJESWARG	KONAJE_110	22:41	23:27	0:46	LINE FAULT
34	3-Sep-19	HASSAN	110	HV1	MANIPAL_110	13:08	13:32	0:24	LINE CLEAR AVAILED
35	3-Sep-19	MYSORE	66	HV1	ADICHUNCHANAGIRI_66	20:13	20:21	0:07	HAND TRIPPED
36	3-Sep-19	MYSORE	66	HV2	KHBCOLONY_66	13:35	14:46	1:11	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
37	3-Sep-19	MYSORE	66	KIADB MANDYA-MADDUR	MADDUR_66, SOMANAHALLI_66	11:17	11:28	0:11	LINE FAULT
38	3-Sep-19	MYSORE	66	MADDUR-SOMNAHALLY	SOMANAHALLI_66	11:17	11:54	0:37	LINE FAULT
39	3-Sep-19	MYSORE	66	TUBINKERE-NAGAMANGALA 1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI_66 BASARALU_66 KESLAGERE_66	20:06	20:12	0:06	LINE FAULT
40	3-Sep-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	16:50	18:24	1:33	LINE CLEAR AVAILED
41	3-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	0:32	0:38	0:06	LINE FAULT
42	3-Sep-19	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	7:26	7:29	0:02	LINE FAULT
43	3-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	0:24	8:05	7:41	LINE FAULT
44	3-Sep-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	12:39	12:43	0:04	HAND TRIPPED
45	3-Sep-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 1	12:39	12:43	0:04	HAND TRIPPED
46	3-Sep-19	TUMKUR	66	TR-1	YNHOSKOTE_66	11:04	11:07	0:03	TRANSFORMER FAULT
47	3-Sep-19	TUMKUR	66	TR-1	YNHOSKOTE_66	13:16	13:24	0:07	TRANSFORMER FAULT
48	4-Sep-19	BAGALKOT	110	BAGALKOT-KERUR	KERUR_110	11:27	14:44	3:17	LINE CLEAR AVAILED
49	4-Sep-19	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	14:21	14:32	0:11	HAND TRIPPED
50	4-Sep-19	BAGALKOT	110	BAGEWADI-MAMADAPUR 1&2	MAMADAPUR_110	16:01	16:05	0:04	HAND TRIPPED
51	4-Sep-19	BAGALKOT	110	110/11KV,HV 2	BHUTANAL_110	13:17	14:05	0:48	LINE CLEAR AVAILED
52	4-Sep-19	BAGALKOT	110	GHATAPRABHA-SHIRAGOAN	SHIRAGOAN_110	18:53	19:07	0:14	LINE FAULT
53	4-Sep-19	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	14:25	17:46	3:21	LINE CLEAR AVAILED
54	4-Sep-19	BAGALKOT	110	220/110KV,LV 2	HAVERI_220	14:51	17:37	2:46	LINE CLEAR AVAILED
55	4-Sep-19	BAGALKOT	110	HIREHAL-IDLE(BADAMI)	HIREHAL_110	12:01	12:02	0:01	HAND TRIPPED
56	4-Sep-19	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAL_110	12:01	12:19	0:18	HAND TRIPPED
57	4-Sep-19	BAGALKOT	110	HIREHAL-IDLE(BADAMI)	HIREHAL_110	18:23	18:43	0:20	HAND TRIPPED
58	4-Sep-19	BAGALKOT	110	HIREHAL-MFR SOLAR	HIREHAL_110	18:27	18:43	0:16	HAND TRIPPED
59	4-Sep-19	BAGALKOT	110	110/11KV, HV1&HV2	YELPARHATTI_110	10:33	15:11	4:38	LINE CLEAR AVAILED
60	4-Sep-19	BAGALKOT	110	KUDACHI220-YELPARHATTI	YELPARHATTI_110	10:38	15:11	4:33	LINE CLEAR AVAILED
61	4-Sep-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	11:22	13:02	1:40	LINE CLEAR AVAILED
62	4-Sep-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	11:36	11:39	0:03	HAND TRIPPED
63	4-Sep-19	BAGALKOT	110	RON-HIREHAL	HIREHAL_110	18:29	18:36	0:07	HAND TRIPPED
64	4-Sep-19	BAGALKOT	110	110/11KV,HV1	RATTIHALLI_110	11:49	12:20	0:31	LINE CLEAR AVAILED
65	4-Sep-19	BAGALKOT	220	NAGJHARI2-HUBLI	HUBLI_220	0:00	19:02	19:02	LINE CLEAR AVAILED
66	4-Sep-19	BAGALKOT	220	NAGJHARI1-HUBLI	HUBLI_220	11:23	17:35	6:12	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
67	4-Sep-19	BAGALKOT	110	110/33KV, HV2	HUNGUND_110, AMINGAD_33, KARADI_33	18:41	18:49	0:08	TRANSFORMER FAULT
68	4-Sep-19	BAGALKOT	110	HUNGUND-KUDAL SANGAM	KUDAL SANGAM_110	18:55	19:51	0:56	LINE FAULT
69	4-Sep-19	BAGALKOT	110	ILKAL1-HUNGUND	HUNGUND_110	18:55	19:29	0:34	LINE FAULT
70	4-Sep-19	BAGALKOT	110	ILKAL2-HUNGUND	HUNGUND_110	18:55	19:45	0:50	LINE FAULT
71	4-Sep-19	BENGALURU	66	VRISHBHAVATHI 220 - REMCO	REMCO	6:54	7:58	1:03	LINE FAULT
72	4-Sep-19	BENGALURU	66	HV1	VIJAYANAGARA	6:53	7:07	0:14	MAIN SUPPLY FAILURE
73	4-Sep-19	BENGALURU	66	HV1	VIJAYANAGARA	13:30	13:32	0:02	LOAD CHANGEVER
74	4-Sep-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	9:50	9:55	0:05	LOAD CHANGEVER
75	4-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	20:50	20:55	0:05	LOAD CHANGEVER
76	4-Sep-19	GULBARGA	110	SINDHANOOR220-LINGASUGUR	SIDHANOOR_220, LINGAPUR_220	2:02	2:12	0:10	LINE FAULT
77	4-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	0:00	6:18	6:18	LINE CLEAR AVAILED
78	4-Sep-19	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:11	23:59	1:48	LINE CLEAR AVAILED
79	4-Sep-19	HASSAN	220	KEMAR-Varahi1	KEMAR_220	19:31	21:43	2:12	NFBC ISSUED
80	4-Sep-19	HASSAN	220	KEMAR-Varahi2	KEMAR_220	15:05	15:22	0:17	LINE FAULT
81	4-Sep-19	HASSAN	220	MRSSHM-ANTRSNH	MRSMSG_220	11:18	15:30	4:12	NFBC ISSUED
82	4-Sep-19	HASSAN	220	MRSSHM-SHARAVATHY2	MRSMSG_220	15:11	16:43	1:32	NFBC ISSUED
83	4-Sep-19	HASSAN	220	SHRAVTY-SHIMOGA1	sharavathy_gen	15:11	16:43	1:32	LINE CLEAR AVAILED
84	4-Sep-19	HASSAN	220	VARAHI-KEMAR1	varahi_gen	19:31	21:43	2:12	LINE CLEAR AVAILED
85	4-Sep-19	HASSAN	220	VARAHI-KEMAR2	varahi_gen	15:05	15:22	0:17	LINE FAULT
86	4-Sep-19	HASSAN	110	NITUR110-MANIPAL	NITTUR_110	12:05	12:06	0:01	HAND TRIPPED
87	4-Sep-19	HASSAN	66	HAGARE-HASSAN	HAGARE_66	10:40	11:50	1:10	MAIN SUPPLY FAILURE
88	4-Sep-19	HASSAN	66	HASSN220-UDDURKOPLU	HASSAN_220	10:37	11:50	1:13	LINE FAULT
89	4-Sep-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	2:45	2:50	0:05	LINE FAULT
90	4-Sep-19	HASSAN	66	HNPR2-HASS2	HOLENARASIPURA_220	3:50	3:58	0:08	LINE FAULT
91	4-Sep-19	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	10:37	17:05	6:28	LINE FAULT
92	4-Sep-19	MYSORE	66	HV2	CHANDAKAVADI_66	13:31	15:07	1:36	LINE CLEAR AVAILED
93	4-Sep-19	MYSORE	66	HV1	HONNALY_MYS_66	11:00	14:50	3:50	LINE CLEAR AVAILED
94	4-Sep-19	MYSORE	66	HV1	HONNALY_MYS_66	17:35	18:10	0:34	LINE CLEAR AVAILED
95	4-Sep-19	MYSORE	66	HV2	HONNALY_MYS_66	14:44	16:39	1:54	LINE CLEAR AVAILED
96	4-Sep-19	MYSORE	66	KADAKOLA-SARAGURU 2	CHANDRAVADI_66, DOORA_66, HURA_66, HULLAHALLI_66	22:52	22:58	0:05	LINE FAULT
97	4-Sep-19	MYSORE	66	HV1	KOPPA_66	10:22	10:51	0:29	HAND TRIPPED
98	4-Sep-19	MYSORE	66	HV2	KOPPA_66	10:22	10:51	0:29	HAND TRIPPED
99	4-Sep-19	MYSORE	66	HV1	SFCSHIVA_66	9:55	13:29	3:34	LINE CLEAR AVAILED
100	4-Sep-19	MYSORE	66	HV2	SFCSHIVA_66	9:55	13:29	3:34	LINE CLEAR AVAILED
101	4-Sep-19	MYSORE	66	HV3	SFCSHIVA_66	9:55	13:32	3:37	LINE CLEAR AVAILED
102	4-Sep-19	MYSORE	66	HV4	SFCSHIVA_66	9:55	13:32	3:37	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
103	4-Sep-19	MYSORE	66	HV5	SFCSHIVA_66	9:55	13:33	3:38	LINE CLEAR AVAILED
104	4-Sep-19	MYSORE	66	TARIPURA-TUBINAKERE	TARIPURA_66	10:17	16:48	6:31	LINE CLEAR AVAILED
105	4-Sep-19	MYSORE	66	TUBINAKERE-NAGAMANGALA-2	SHIVALLY_66	7:42	7:47	0:05	LINE FAULT
106	4-Sep-19	MYSORE	66	HV1	TUBINAKERE_220	10:09	17:46	7:37	LINE CLEAR AVAILED
107	4-Sep-19	MYSORE	66	HV2	TUBINAKERE_220	10:09	14:31	4:22	LINE CLEAR AVAILED
108	4-Sep-19	MYSORE	66	TUBINAKERE-ARAKERE	ARAKERE_66, GAMANAHALLY_66I	10:10	16:23	6:13	LINE CLEAR AVAILED
109	4-Sep-19	MYSORE	66	TUBINAKERE-MC-4	BESAGARAHALLI_66, CHIKKA_MANDYA_66, HAMPAPURA_66, HADLI_66, KOPPA_66, KADUKOTHNAHALLI_66, MALAVALLI_66,MANDYA_66	10:16	10:42	0:26	LINE FAULT
110	4-Sep-19	MYSORE	66	TUBINAKERE-NAGAMANGALA-1	ADDIHALLI_66 HARADANAHALLI(JAK)_66 BGNAGARA_66 ADICHUNCHANAGIRI_66 VADERALLI _66 BASARALU_66 KESLAGERE_66	14:45	14:51	0:06	HAND TRIPPED
111	4-Sep-19	MYSORE	66	TUBINAKERE-NAGAMANGALA-2	SHIVALLY_66	14:45	14:51	0:06	HAND TRIPPED
112	4-Sep-19	TUMKUR	110	TR-1	CHIKKANAYAKANAHALLI_110	12:22	12:51	0:28	LINE CLEAR AVAILED
113	4-Sep-19	TUMKUR	66	CHITRADURGA 220kV-CHITRADURGA2	CHITRADURGA_220	12:35	13:23	0:48	LINE FAULT
114	4-Sep-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	13:01	13:49	0:48	LINE FAULT
115	4-Sep-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	13:18	13:23	0:05	LINE FAULT
116	4-Sep-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	5:57	11:35	5:37	LINE FAULT
117	4-Sep-19	TUMKUR	66	TR-1	DYAVARANAHALLI_66	5:57	11:31	5:33	TRANSFORMER FAULT
118	4-Sep-19	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	5:57	11:34	5:36	LINE FAULT
119	4-Sep-19	TUMKUR	66	DYAVARANAHALLI-RANGENAHALLI (P R PURA)	PRPURA_66, LINGADAHALLI_TMK2_66	5:57	11:34	5:36	LINE FAULT
120	4-Sep-19	TUMKUR	66	NEELAGUNDA 220kV-HARAPPANAHALLI	HARAPPANAHALLI_66	6:02	6:17	0:14	LINE FAULT
121	4-Sep-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	10:49	11:20	0:31	HAND TRIPPED
122	4-Sep-19	TUMKUR	66	RANGANATHAPURA-HIRIYUR	RANGENAHALLI_66	11:20	16:52	5:31	LINE CLEAR AVAILED
123	5-Sep-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	22:07	23:59	1:52	LINE FAULT
124	5-Sep-19	BAGALKOT	220	NAGJHARI1-AMBEWADI	AMBEWADI_220	22:08	22:42	0:34	HAND TRIPPED
125	5-Sep-19	BAGALKOT	220	BIJAPUR-BAGEWADI1 (GMR1)	BIJAPUR_220	11:47	14:28	2:41	LINE CLEAR AVAILED
126	5-Sep-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	16:11	23:59	7:48	LINE FAULT
127	5-Sep-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1(B)	MAMDAPUR(B)_110	15:23	16:36	1:13	LINE CLEAR AVAILED
128	5-Sep-19	BAGALKOT	110	BAGEWADI220-MAMADAPUR1(B)	MAMDAPUR(B)_110	16:37	17:14	0:37	LINE CLEAR AVAILED
129	5-Sep-19	BAGALKOT	110	CHIKKODI220-CHIKKODI	CHIKKODI_110	18:53	19:24	0:31	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
130	5-Sep-19	BAGALKOT	110	HATTARGI-BELGAUM(DADDI)	DADDI_110	12:55	13:20	0:25	LINE FAULT
131	5-Sep-19	BAGALKOT	220	GADAG-BAGALKOT1&2	GADAG_220	10:20	23:59	13:39	LINE CLEAR AVAILED
132	5-Sep-19	BAGALKOT	110	110/11KV, HV1	KHANAPUR_110	21:45	21:51	0:06	TRANSFORMER FAULT
133	5-Sep-19	BAGALKOT	110	SIRSI-SIDDAPUR	SIDDAPUR_110	15:19	21:03	5:44	LINE FAULT
134	5-Sep-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	9:35	23:59	14:24	LINE CLEAR AVAILED
135	5-Sep-19	BAGALKOT	220	220/110KV, HV1&LV1	SOUDATTI_220	12:04	13:01	0:57	LINE CLEAR AVAILED
136	5-Sep-19	BAGALKOT	110	ZALKI-CHADCHAN	CHADCHAN_110	9:10	12:19	3:09	LINE CLEAR AVAILED
137	5-Sep-19	BENGALURU	66	GOWRIBIDANUR 220 - BAGEPALLI 1	VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHAPURA	12:34	12:52	0:18	LINE FAULT
138	5-Sep-19	BENGALURU	66	KEMBODI - KOLAR 220	KEMBODI	11:58	12:09	0:11	LINE FAULT
139	5-Sep-19	BENGALURU	66	KEMBODI - NANGLI	MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	11:58	12:17	0:19	LINE FAULT
140	5-Sep-19	BENGALURU	66	HV2	KYALANUR	14:11	14:21	0:10	LINE CLEAR AVAILED
141	5-Sep-19	BENGALURU	66	HV2	THIMAMPALLI	12:17	12:23	0:06	TRANSFORMER FAULT
142	5-Sep-19	BENGALURU	66	HV2	CHAKAVELU	18:00	18:14	0:13	TRANSFORMER FAULT
143	5-Sep-19	BENGALURU	220	EPIP 220 - HSR LAYOUT 220	HSR LAYOUT 220	13:20	17:13	3:53	LINE FAULT
144	5-Sep-19	BENGALURU	220	HOODY 400 - ITPL (EHT)	ITPL (EHT)	13:20	17:35	4:15	LINE FAULT
145	5-Sep-19	BENGALURU	66	NIMHANS 220 - JAYANAGAR	JAYANAGAR, NATIONAL COLLEGE, PADMANABHANAGAR	13:20	13:31	0:10	LINE FAULT
146	5-Sep-19	BENGALURU	66	TK HALLI 220 - MANDYA 2	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:29	15:37	0:07	MAIN SUPPLY FAILURE
147	5-Sep-19	BENGALURU	66	TK HALLI 220 - MANDYA 1	KM DODDI, KK DODDI, KIADB MANDYA, MADDUR, MANDYA	15:29	15:37	0:07	MAIN SUPPLY FAILURE
148	5-Sep-19	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	15:29	15:37	0:07	MAIN SUPPLY FAILURE
149	5-Sep-19	BENGALURU	220	HV2	TK HALLI 220	15:29	15:36	0:06	TRANSFORMER FAULT
150	5-Sep-19	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	2:25	2:36	0:11	LINE FAULT
151	5-Sep-19	GULBARGA	110	SHAHPUR-SHORAPUR	SHORAPUR_110	5:45	5:55	0:10	LINE FAULT
152	5-Sep-19	GULBARGA	220	KUSTAGI-LINGAPUR	LINGAPUR_220	13:45	14:10	0:25	LINE FAULT
153	5-Sep-19	GULBARGA	110	KUSTAGI-KUSTAGISLR_IPP	KUSTAGI_220	4:40	4:55	0:15	LINE FAULT
154	5-Sep-19	GULBARGA	66	HV2	KOTTUR_66	15:40	16:30	0:50	HAND TRIPPED
155	5-Sep-19	GULBARGA	66	HV3	HAGARIBOMMANAHALLI_66	15:15	15:55	0:40	TRANSFORMER FAULT
156	5-Sep-19	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	17:15	18:18	1:03	LINE FAULT
157	5-Sep-19	GULBARGA	220	SEDAM-HUMNABAD1	SEDAM_220	10:45	14:13	3:28	NFBC ISSUED
158	5-Sep-19	GULBARGA	110	RAICHUR-SHAHPUR2	GOOGLE_110	4:30	4:38	0:08	LINE FAULT
159	5-Sep-19	GULBARGA	110	SIDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	23:45	23:58	0:13	LINE FAULT
160	5-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	2:24	2:57	0:33	TRANSFORMER FAULT
161	5-Sep-19	GULBARGA	110	HV2	SHORAPUR_110	5:44	5:57	0:13	TRANSFORMER FAULT
162	5-Sep-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	0:00	7:39	7:39	LINE CLEAR AVAILED
163	5-Sep-19	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:11	23:59	1:48	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
164	5-Sep-19	HASSAN	220	UPCL-KEMAR1	upcl_gen	6:37	6:51	0:14	LINE FAULT
165	5-Sep-19	HASSAN	220	UPCL-KEMAR2	upcl_gen	6:37	6:51	0:14	LINE FAULT
166	5-Sep-19	HASSAN	220	UPCL-TALGUPA2	gerusoppa_gen	15:06	23:59	8:53	LINE FAULT
167	5-Sep-19	HASSAN	220	HV1	PUTTUR_220	10:07	13:48	3:41	LINE CLEAR AVAILED
168	5-Sep-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	15:06	23:59	8:53	LINE FAULT
169	5-Sep-19	HASSAN	110	GURUVA-KEMAR1	GURUVAYANAKERE_110	8:10	11:45	3:35	MAIN SUPPLY FAILURE
170	5-Sep-19	HASSAN	110	GURUVA-KEMAR2	GURUVAYANAKERE_110	8:10	12:50	4:40	MAIN SUPPLY FAILURE
171	5-Sep-19	HASSAN	110	HV1	NANDIKUR_110	10:25	13:31	3:06	LINE CLEAR AVAILED
172	5-Sep-19	HASSAN	110	LV1	PUTTUR_220	10:07	13:48	3:41	LINE CLEAR AVAILED
173	5-Sep-19	HASSAN	66	HV1	HARIHARAPURA_66	13:47	13:53	0:06	TRANSFORMER FAULT
174	5-Sep-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	14:35	14:40	0:05	HAND TRIPPED
175	5-Sep-19	HASSAN	66	HNPURA-SOMANAHALLI	HNPURA_66	16:20	16:23	0:03	HAND TRIPPED
176	5-Sep-19	HASSAN	66	HV1	MOSALEHOSAHALLI_66	1:51	1:54	0:03	TRANSFORMER FAULT
177	5-Sep-19	MYSORE	66	HV2	BILIKERE_66	16:56	17:15	0:19	LINE CLEAR AVAILED
178	5-Sep-19	MYSORE	66	KADAKOLA-SARAGURU 1	ANTHARSANTHE_66, JAIPUR_66, HAMPAPURA(K)_66, HDKOTE_66	1:08	1:12	0:04	LINE FAULT
179	5-Sep-19	MYSORE	66	HV1	K_HONNALGERE_66	15:33	15:37	0:04	HAND TRIPPED
180	5-Sep-19	MYSORE	66	HV2	K_HONNALGERE_66	15:33	15:37	0:04	HAND TRIPPED
181	5-Sep-19	MYSORE	66	HV1	KIADBMANDYA_66	15:33	15:39	0:05	HAND TRIPPED
182	5-Sep-19	MYSORE	66	HV2	KIADBMANDYA_66	15:33	15:39	0:05	HAND TRIPPED
183	5-Sep-19	MYSORE	66	HV1	KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	15:33	15:38	0:05	HAND TRIPPED
184	5-Sep-19	MYSORE	66	HV2	KMDODDI_66, KOLKARANADODDI_66, MADDUR_66, SOMANAHALLI_66, TUMBEKERE_66	15:33	15:38	0:05	HAND TRIPPED
185	5-Sep-19	TUMKUR	400	TR-1(HV SIDE)	GUTUR_400	14:11	14:43	0:32	TRANSFORMER FAULT
186	5-Sep-19	TUMKUR	220	HONNALLI 220kV-DAVANAGERE SRS	HONNALLI_220	11:53	13:52	1:58	LINE CLEAR AVAILED
187	5-Sep-19	TUMKUR	220	HONNALLI 220kV- SUZLON1	SUZLON_IPP_66	10:37	13:44	3:07	LINE CLEAR AVAILED
188	5-Sep-19	TUMKUR	220	HONNALLI 220kV- SUZLON2	SUZLON_IPP_66	10:37	13:44	3:07	LINE FAULT
189	5-Sep-19	TUMKUR	220	TR-1(HV SIDE)	HONNALLI_220	11:47	11:56	0:08	HAND TRIPPED
190	5-Sep-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	6:22	6:56	0:34	TRANSFORMER FAULT
191	5-Sep-19	TUMKUR	220	TR-2(HV SIDE)	KBCROSS_220	12:52	13:01	0:09	TRANSFORMER FAULT
192	5-Sep-19	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	11:52	14:31	2:38	LINE CLEAR AVAILED
193	5-Sep-19	TUMKUR	220	DAVANGERE SRS- HONNALI	HONNALLI_220	12:01	13:30	1:29	LINE FAULT
194	5-Sep-19	TUMKUR	220	TR-2(HV SIDE)	DAVANGERE_SRS_220	11:44	13:04	1:19	TRANSFORMER FAULT
195	5-Sep-19	TUMKUR	220	TR-1(HV SIDE)	MADHUGIRI_220	11:52	14:31	2:38	LINE CLEAR AVAILED
196	5-Sep-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	6:22	6:56	0:34	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
197	5-Sep-19	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	12:52	13:01	0:09	TRANSFORMER FAULT
198	5-Sep-19	TUMKUR	66	TR-1	CHIKKABANAGERE_66	12:09	13:42	1:33	LINE CLEAR AVAILED
199	5-Sep-19	TUMKUR	66	CHITRADURGA 220KV- PANDARAHALLI 1	HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66	14:53	15:09	0:16	LINE FAULT
200	5-Sep-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	11:47	12:46	0:58	LINE FAULT
201	5-Sep-19	TUMKUR	66	DAVANGERE SRS- DAVANGERE	DAVANAGERE_66	20:06	20:19	0:13	LINE FAULT
202	5-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	11:48	13:49	2:01	LINE CLEAR AVAILED
203	5-Sep-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	11:48	13:49	2:01	LINE CLEAR AVAILED
204	5-Sep-19	TUMKUR	66	TR-2(LV SIDE)	DAVANGERE_SRS_220	11:48	12:43	0:54	TRANSFORMER FAULT
205	5-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:48	12:54	1:06	LINE CLEAR AVAILED
206	5-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	0:50	1:02	0:11	LINE FAULT
207	5-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	11:47	13:49	2:01	LINE CLEAR AVAILED
208	5-Sep-19	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66	11:48	12:47	0:59	HAND TRIPPED
209	5-Sep-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	13:20	13:52	0:32	LINE CLEAR AVAILED
210	5-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	11:57	14:18	2:20	LINE CLEAR AVAILED
211	5-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	11:59	12:08	0:08	HAND TRIPPED
212	5-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:07	12:12	0:05	HAND TRIPPED
213	5-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	9:59	10:16	0:17	HAND TRIPPED
214	5-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	11:57	12:04	0:06	HAND TRIPPED
215	5-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	RANGANATHAPURA_66	14:10	14:18	0:07	HAND TRIPPED
216	5-Sep-19	TUMKUR	66	TR-1& TR-2(HV SIDE)	HONNALLI_220	11:46	12:01	0:14	HAND TRIPPED
217	5-Sep-19	TUMKUR	66	HONNALLI 220kv- BANUVALLI	BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66	11:46	12:05	0:19	HAND TRIPPED
218	5-Sep-19	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	11:45	12:03	0:17	HAND TRIPPED
219	5-Sep-19	TUMKUR	66	HONNALLI 220kv- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	11:46	15:31	3:44	LINE CLEAR AVAILED
220	5-Sep-19	TUMKUR	66	TR-1& TR-2(LV SIDE)	HONNALLI_220	11:46	12:00	0:14	HAND TRIPPED
221	5-Sep-19	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66	11:46	15:31	3:45	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
222	5-Sep-19	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	11:39	17:55	6:15	LINE CLEAR AVAILED
223	5-Sep-19	TUMKUR	66	TR-1	KORA_66	12:45	13:04	0:19	LINE CLEAR AVAILED
224	5-Sep-19	TUMKUR	66	MADHUGIRI-SIRA-2	KALLAMBELLA_66, BUKKAPATNA_66	12:18	12:37	0:18	HAND TRIPPED
225	5-Sep-19	TUMKUR	66	TR-1(LV SIDE)	MADHUGIRI_220	11:52	14:33	2:41	LINE CLEAR AVAILED
226	5-Sep-19	TUMKUR	66	MADHUGIRI 220kV- SIRA 1	GULIGENAHALLI_66,SIRA_66	12:18	12:21	0:03	HAND TRIPPED
227	5-Sep-19	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66,HARAPPANA HALLI_66,HALUVAGALU_66,TELAGI_66	7:27	7:44	0:17	LINE FAULT
228	5-Sep-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	11:25	13:16	1:51	LINE CLEAR AVAILED
229	5-Sep-19	TUMKUR	66	TR-1	YNHOSKOTE_66	12:25	12:33	0:07	TRANSFORMER FAULT
230	6-Sep-19	BAGALKOT	220	PONDA1-AMBEWADI	AMBEWADI_220	11:55	15:05	3:10	LINE CLEAR AVAILED
231	6-Sep-19	BAGALKOT	220	BELGAUM-CHIKKODI2	BELGAUM_220	8:43	10:43	2:00	LINE CLEAR AVAILED
232	6-Sep-19	BAGALKOT	220	BELGAUM-NARENDRA1	BELGAUM_220	0:00	10:41	10:41	LINE CLEAR AVAILED
233	6-Sep-19	BAGALKOT	220	CHIKKODI-KUDUCHI	CHIKKODI_220	8:52	10:44	1:52	LINE CLEAR AVAILED
234	6-Sep-19	BAGALKOT	220	220/110KV,HV1&LV1	GHATAPRABHA_220	12:25	13:03	0:38	LINE CLEAR AVAILED
235	6-Sep-19	BAGALKOT	110	HAVERI220-SAVANUR	SAVANUR_110	10:36	13:09	2:33	LINE CLEAR AVAILED
236	6-Sep-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	14:11	23:59	9:48	LINE CLEAR AVAILED
237	6-Sep-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	10:58	16:54	5:56	LINE FAULT
238	6-Sep-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	16:55	20:02	3:07	LINE FAULT
239	6-Sep-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	11:28	16:51	5:23	LINE CLEAR AVAILED
240	6-Sep-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	18:51	19:54	1:03	LINE CLEAR AVAILED
241	6-Sep-19	BAGALKOT	220	SHARAVATHI2-SIRSI	SIRSI_220	5:54	23:59	18:05	LINE FAULT
242	6-Sep-19	BAGALKOT	110	110/11KV,HV2	JAMAKHADI_110	15:25	16:09	0:44	LINE CLEAR AVAILED
243	6-Sep-19	BAGALKOT	110	110/11KV,HV1	MUKARTIHAL_110	12:03	15:13	3:10	LINE CLEAR AVAILED
244	6-Sep-19	BENGALURU	66	HV1	BAIRAKUR	16:41	17:05	0:24	LINE CLEAR AVAILED
245	6-Sep-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	10:00	10:05	0:05	LOAD CHANGEOVER
246	6-Sep-19	BENGALURU	66	HV1	CHAKAVELU	14:40	15:07	0:27	TRANSFORMER FAULT
247	6-Sep-19	BENGALURU	66	CHINTAMANI 220 - LAKSHMIPURA	LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI	15:19	16:06	0:46	LINE CLEAR AVAILED
248	6-Sep-19	BENGALURU	66	HV1	D CROSS	12:01	12:08	0:06	LINE CLEAR AVAILED
249	6-Sep-19	BENGALURU	66	HV1	D CROSS	14:35	14:37	0:02	LINE CLEAR AVAILED
250	6-Sep-19	BENGALURU	66	HV1	HOSKOTE 66	14:42	14:50	0:08	LINE CLEAR AVAILED
251	6-Sep-19	BENGALURU	66	HV2	KGF	12:10	12:38	0:27	LINE CLEAR AVAILED
252	6-Sep-19	BENGALURU	66	HV1	THAYALUR	13:03	13:07	0:03	LINE CLEAR AVAILED
253	6-Sep-19	BENGALURU	66	HV1	WELCAST	12:19	12:21	0:01	LINE CLEAR AVAILED
254	6-Sep-19	BENGALURU	66	HV1	WELCAST	13:14	13:16	0:02	LINE CLEAR AVAILED
255	6-Sep-19	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	11:15	15:50	4:35	LINE CLEAR AVAILED
256	6-Sep-19	GULBARGA	220	SEDAM-RTPS1	SEDAM_220	0:00	16:20	16:20	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
257	6-Sep-19	GULBARGA	220	ITTAGI-LINGAPUR	LINGAPUR_220	13:10	15:10	2:00	LINE CLEAR AVAILED
258	6-Sep-19	GULBARGA	220	BMMISPAT-ITTAGI	ITTAGI_220	13:15	15:10	1:55	LINE CLEAR AVAILED
259	6-Sep-19	GULBARGA	110	HV1	KUDITINI_110	10:35	10:45	0:10	TRANSFORMER FAULT
260	6-Sep-19	GULBARGA	110	HV1	KUDITINI_110	14:04	14:09	0:05	TRANSFORMER FAULT
261	6-Sep-19	GULBARGA	110	KUSTAGI-KUSTAGISLR_IPP	KUSTAGI_220	4:20	4:30	0:10	LINE FAULT
262	6-Sep-19	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_GLB_110, SAIDAPUR_110, WASAGERA_110, SANNATHI_IPP,COREGREEN_IPP,SU GAR_IPP NALWARA_110	2:07	2:17	0:10	LINE FAULT
263	6-Sep-19	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110, UGARSUGAR_IPP	2:29	2:37	0:08	LINE FAULT
264	6-Sep-19	GULBARGA	110	SINDHANOOR220-SINDHANOOR1	MASKI_110, MUDDAPURA_110	22:28	22:40	0:12	LINE FAULT
265	6-Sep-19	GULBARGA	110	SIDHANOOR220-MUNIRABAD2	MUKUNDA_110,KAMPLI_GLB_110,B TPS WATERWORKS	22:28	22:50	0:22	LINE FAULT
266	6-Sep-19	GULBARGA	110	SIDHANOOR220-NIRLOOTI_IPP	SIDHANOOR_220	22:28	22:50	0:22	LINE FAULT
267	6-Sep-19	GULBARGA	110	SIDHANOOR220-TURVIHAL	TURVIHAL_110	22:28	22:52	0:24	LINE FAULT
268	6-Sep-19	GULBARGA	110	JANAWADA-SANTHAPUR	SANTHAPUR_110	18:40	18:55	0:15	LINE FAULT
269	6-Sep-19	GULBARGA	66	KOGALI-ASTRSLR_IPP	KOTTUR_66	8:55	9:03	0:08	LINE CLEAR AVAILED
270	6-Sep-19	GULBARGA	66	ITTAGI-TAMBRAHALLI	TAMBRAHALLI_66	7:10	7:22	0:12	LINE FAULT
271	6-Sep-19	HASSAN	400	UPCL-HASSAN2	UPCL	0:00	10:15	10:15	LINE CLEAR AVAILED
272	6-Sep-19	HASSAN	400	UPCL-HASSAN2	UPCL	22:35	23:59	1:24	LINE CLEAR AVAILED
273	6-Sep-19	HASSAN	220	GERSOPA-TALGUPA2	GERSOPA	12:54	23:59	11:05	LINE FAULT
274	6-Sep-19	HASSAN	220	KAVOOR-KEMR2	KAVOOR_220	12:51	16:47	3:56	LINE CLEAR AVAILED
275	6-Sep-19	HASSAN	220	HV3	KEMAR_220	10:33	11:53	1:20	TRANSFORMER FAULT
276	6-Sep-19	HASSAN	110	LV3	KEMAR_220	10:33	11:53	1:20	TRANSFORMER FAULT
277	6-Sep-19	HASSAN	220	SHRAVTY-SIRISI 2	SHRAVTY	5:54	23:59	18:05	LINE FAULT
278	6-Sep-19	HASSAN	220	TALAGU-STRP2	TALAGUPPA_400	12:54	23:59	11:05	LINE FAULT
279	6-Sep-19	HASSAN	110	HV2	ALKOLA_110	10:18	10:59	0:41	TRANSFORMER FAULT
280	6-Sep-19	HASSAN	110	HV3	BANTWALA_110	10:26	12:00	1:34	LINE CLEAR AVAILED
281	6-Sep-19	HASSAN	66	HV1	BAGUR_66	15:10	15:30	0:20	HAND TRIPPED
282	6-Sep-19	HASSAN	66	HV1	BAGUR_66	16:45	19:25	2:40	LINE CLEAR AVAILED
283	6-Sep-19	HASSAN	66	HV1	HASSAN_66	11:33	12:10	0:37	LINE CLEAR AVAILED
284	6-Sep-19	HASSAN	66	RAMNAT-BNDSTHL	RAMNATHPURA_66	11:39	12:58	1:19	LINE CLEAR AVAILED
285	6-Sep-19	HASSAN	66	UDAYAP-BAGUR	UDAYAPURA_66	15:16	15:28	0:12	LINE FAULT
286	6-Sep-19	MYSORE	66	HV2	DUNDANAHALLI_66	9:05	9:45	0:40	LINE CLEAR AVAILED
287	6-Sep-19	MYSORE	66	DODDINADUVADI-KOTTANUR	KOTTANUR_66	11:45	17:25	5:40	LINE CLEAR AVAILED
288	6-Sep-19	MYSORE	66	HANNUR-KOTTANUR	KOTTANUR_66	11:51	17:06	5:14	NFBC ISSUED
289	6-Sep-19	MYSORE	66	HV2	MALAVALLI_66	20:11	20:37	0:26	TRANSFORMER FAULT
290	6-Sep-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	8:41	8:45	0:04	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
291	6-Sep-19	TUMKUR	220	TR-3(HV SIDE)	HIRIYUR_220	11:50	12:25	0:35	HAND TRIPPED
292	6-Sep-19	TUMKUR	110	TR-1	KADABA_110	13:43	16:44	3:01	LINE CLEAR AVAILED
293	6-Sep-19	TUMKUR	110	TR-1	KADABA_110	18:10	18:26	0:15	LINE CLEAR AVAILED
294	6-Sep-19	TUMKUR	66	DAVANGERE SRS- GUTTUR66	GUTTUR_66	15:02	15:24	0:21	HAND TRIPPED
295	6-Sep-19	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	15:02	15:23	0:20	HAND TRIPPED
296	6-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:04	11:47	1:42	LINE CLEAR AVAILED
297	6-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	15:24	15:31	0:06	HAND TRIPPED
298	6-Sep-19	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	15:02	15:23	0:20	HAND TRIPPED
299	6-Sep-19	TUMKUR	66	DYAVARANAHALLI- CELESTIALSOLAR	CELESTIALSOLAR_IPP_66	11:51	12:20	0:29	LINE FAULT
300	6-Sep-19	TUMKUR	66	TR-1	DYAVARANAHALLI_66	11:51	13:22	1:31	TRANSFORMER FAULT
301	6-Sep-19	TUMKUR	66	DYAVARANAHALLI-MYLANAHALLI	DYAVARANAHALLI_66	11:30	13:22	1:51	LINE FAULT
302	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	8:40	8:59	0:18	HAND TRIPPED
303	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	9:56	10:37	0:40	HAND TRIPPED
304	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	12:06	12:25	0:19	HAND TRIPPED
305	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	8:48	8:58	0:09	HAND TRIPPED
306	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	9:56	9:57	0:01	HAND TRIPPED
307	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:05	12:25	0:20	HAND TRIPPED
308	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	8:40	8:58	0:18	HAND TRIPPED
309	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	9:56	9:58	0:01	HAND TRIPPED
310	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP 1	RKP1_IPP_66	12:05	12:25	0:20	HAND TRIPPED
311	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	8:40	8:58	0:18	HAND TRIPPED
312	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	9:56	9:58	0:01	HAND TRIPPED
313	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RKP2	RKP2_IPP_66	12:05	12:25	0:19	HAND TRIPPED
314	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	8:39	8:57	0:17	HAND TRIPPED
315	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	9:56	10:27	0:30	HAND TRIPPED
316	6-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	10:47	16:46	5:58	LINE CLEAR AVAILED
317	6-Sep-19	TUMKUR	66	JAVAGONDANAHALLI- BEVINAHALLI	JAVAGONDANAHALLI_66	11:24	11:33	0:08	HAND TRIPPED
318	6-Sep-19	TUMKUR	66	KALAMARANAHALLI- HIRIYUR	KALAMARANAHALLI_66	8:59	15:28	6:28	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
319	6-Sep-19	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	6:00	6:12	0:11	LINE FAULT
320	6-Sep-19	TUMKUR	66	NAGALAMADIKE- SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	8:49	10:36	1:47	LINE FAULT
321	6-Sep-19	TUMKUR	66	NAGALAMADIKE- SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	10:37	10:42	0:05	LINE FAULT
322	6-Sep-19	TUMKUR	66	NAGALAMADIKE- SUNDARRAJSOLAR_IPP_66	SUNDARRAJSOLAR_IPP_66	10:43	13:45	3:01	LINE FAULT
323	6-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	3:35	3:46	0:11	LINE FAULT
324	6-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	4:53	5:03	0:10	LINE FAULT
325	6-Sep-19	TUMKUR	66	RANGENAHALLI- BORUKHASOLAR	BORUKHASOLAR_IPP_66	12:27	12:45	0:18	HAND TRIPPED
326	6-Sep-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR1	WELSPUN_IPP_SOLAR_66 1	16:56	17:07	0:11	HAND TRIPPED
327	6-Sep-19	TUMKUR	66	RANGANATHAPURA-WLSPNSOLAR2	WELSPUN_IPP_SOLAR_66 2	16:56	17:07	0:11	HAND TRIPPED
328	6-Sep-19	TUMKUR	66	TR-2	TELAGI_66	16:48	16:58	0:10	LINE CLEAR AVAILED
329	6-Sep-19	TUMKUR	66	TR-2	THOVINAKERE_66	13:40	17:26	3:45	LINE CLEAR AVAILED
330	6-Sep-19	TUMKUR	66	TR-1	YNHOSKOTE_66	12:55	13:43	0:47	TRANSFORMER FAULT
331	7-Sep-19	BAGALKOT	220	AMBEWADI-NARENDRA1	AMBEWADI_220	10:25	15:10	4:45	LINE CLEAR AVAILED
332	7-Sep-19	BAGALKOT	220	AMBEWADI-NARENDRA2	AMBEWADI_220	0:00	15:09	15:09	LINE CLEAR AVAILED
333	7-Sep-19	BAGALKOT	110	110/11KV,HV2	BAGALKOT_110	16:21	16:39	0:18	HAND TRIPPED
334	7-Sep-19	BAGALKOT	110	BAGEWADI220-SINDAGI	SINDAGI_110	11:00	12:05	1:05	LINE CLEAR AVAILED
335	7-Sep-19	BAGALKOT	110	BAGEWADI220-MUDDEBIHAL	MUDDEBIHAL_110	12:10	12:41	0:31	LINE CLEAR AVAILED
336	7-Sep-19	BAGALKOT	110	BAGEWADI220-NIDAGUNDI	NIDAGUNDI_110	12:48	13:22	0:34	LINE CLEAR AVAILED
337	7-Sep-19	BAGALKOT	110	GADAG220-DAMBAL	DAMBAL_110	10:06	18:15	8:09	LINE CLEAR AVAILED
338	7-Sep-19	BAGALKOT	110	110/33KV,HV3	DAMBAL_110	10:00	18:20	8:20	LINE CLEAR AVAILED
339	7-Sep-19	BAGALKOT	110	110/11KV,HV1&HV2	DAMBAL_110	10:08	18:15	8:07	LINE CLEAR AVAILED
340	7-Sep-19	BAGALKOT	110	SUZLON1&2-DAMBAL	DAMBAL_110	11:35	18:38	7:03	LINE CLEAR AVAILED
341	7-Sep-19	BAGALKOT	110	110/33KV,HV3&HV4	GOPANAKOPPA_110,KUSAGAL_33	19:50	23:03	3:13	TRANSFORMER FAULT
342	7-Sep-19	BAGALKOT	110	110/11KV,HV1	GULEDAGUDDA_110	13:06	13:46	0:40	LINE CLEAR AVAILED
343	7-Sep-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	0:00	11:50	11:50	LINE CLEAR AVAILED
344	7-Sep-19	BAGALKOT	110	AMBEWADI220-KIRUVATTI	KIRUVATTI_110	12:42	23:59	11:17	LINE CLEAR AVAILED
345	7-Sep-19	BAGALKOT	110	DAMBAL-MUNDARAGI	MUNDARAGI_110	10:10	17:59	7:49	LINE CLEAR AVAILED
346	7-Sep-19	BAGALKOT	110	MUNDARAGI-VIJAYANAGAR SUGARS	MUNDARAGI_110	10:10	17:59	7:49	LINE CLEAR AVAILED
347	7-Sep-19	BAGALKOT	110	110/11KV,HV1	NIDAGUNDI_110	11:21	11:36	0:15	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
348	7-Sep-19	BAGALKOT	220	DHONI1-GADAG	GADAG_220	2:17	17:43	15:26	LINE FAULT
349	7-Sep-19	BAGALKOT	220	DHONI2-GADAG	GADAG_220	2:17	17:43	15:26	LINE CLEAR AVAILED
350	7-Sep-19	BAGALKOT	110	110/11KV,HV1	LOKAPUR_110	18:01	18:05	0:04	HAND TRIPPED
351	7-Sep-19	BAGALKOT	110	GSML1-MAHALINGAPUR	MAHALINGAPUR_220	16:23	16:24	0:01	HAND TRIPPED
352	7-Sep-19	BAGALKOT	110	110/11KV,HV1	YARAGATTI_110	14:40	15:07	0:27	LINE CLEAR AVAILED
353	7-Sep-19	BAGALKOT	110	110/11KV,HV1	TILUVALI_110	0:00	15:56	15:56	LINE CLEAR AVAILED
354	7-Sep-19	BAGALKOT	220	HUBLI-SIRSI2	HUBLI_220	0:00	17:33	17:33	LINE CLEAR AVAILED
355	7-Sep-19	BAGALKOT	220	SIRSI-HUBLI1	SIRSI_220	12:32	23:59	11:27	LINE CLEAR AVAILED
356	7-Sep-19	BAGALKOT	220	SIRSI-HUBLI2	SIRSI_220	12:36	17:11	4:35	LINE CLEAR AVAILED
357	7-Sep-19	BAGALKOT	220	SIRSI-SHARAVATHI2	SIRSI_220	0:00	12:26	12:26	LINE CLEAR AVAILED
358	7-Sep-19	BAGALKOT	220	SIRSI-SHARAVATHI1	SIRSI_220	11:18	12:27	1:09	LINE CLEAR AVAILED
359	7-Sep-19	BAGALKOT	110	110/11KV,HV1	NARAGAL_110	19:06	19:48	0:42	LINE CLEAR AVAILED
360	7-Sep-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	14:10	17:17	3:07	LINE FAULT
361	7-Sep-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	14:36	17:14	2:38	LINE CLEAR AVAILED
362	7-Sep-19	BENGALURU	66	CHIKKENAHALLI - CHANNAPATNA	CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR	5:38	5:42	0:04	LINE FAULT
363	7-Sep-19	BENGALURU	66	CHINTAMANI 220 - SRINIVASPURA	KODIHALLI, SRINIVASPURA	10:39	11:02	0:22	LINE CLEAR AVAILED
364	7-Sep-19	BENGALURU	66	HV1	DABUSPET 220	12:29	15:19	2:50	LINE CLEAR AVAILED
365	7-Sep-19	BENGALURU	220	HV1	MITTEMARI 220	4:42	9:02	4:20	TRANSFORMER FAULT
366	7-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	4:42	4:55	0:13	MAIN SUPPLY FAILURE
367	7-Sep-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	9:50	9:55	0:05	LOAD CHANGEVER
368	7-Sep-19	BENGALURU	66	MITTEMARI 220 - SOMENAHALLI	PERESANDRA, SOMENAHALLI, MANDIKALLU	18:05	18:10	0:05	LOAD CHANGEVER
369	7-Sep-19	BENGALURU	220	DB PURA 220 - BEGUR 220	BEGUR 220	17:20	17:23	0:03	LINE FAULT
370	7-Sep-19	BENGALURU	66	BEGUR 220 - BIAL 1	BIAL (EHT)	17:20	17:54	0:34	MAIN SUPPLY FAILURE
371	7-Sep-19	BENGALURU	66	BEGUR 220 - BIAL 2	BIAL (EHT)	17:20	17:44	0:24	MAIN SUPPLY FAILURE
372	7-Sep-19	BENGALURU	66	BEGUR 220 - ITC (EHT)	ITC (EHT)	17:20	17:44	0:24	MAIN SUPPLY FAILURE
373	7-Sep-19	BENGALURU	66	BEGUR 220 - BOODIGERE	BOODIGERE	17:20	17:46	0:26	MAIN SUPPLY FAILURE
374	7-Sep-19	BENGALURU	220	BEGUR 220 - HOSKOTE 220	HOSKOTE 220, KIADB HARDWARE PARK 220	17:20	17:20	0:00	MAIN SUPPLY FAILURE
375	7-Sep-19	BENGALURU	66	HV1	BEGUR 220	17:20	17:44	0:24	MAIN SUPPLY FAILURE
376	7-Sep-19	BENGALURU	66	HV2	BEGUR 220	17:20	17:43	0:23	MAIN SUPPLY FAILURE
377	7-Sep-19	BENGALURU	66	KIADB HARDWARE PARK 220 - SHELL (EHT)	SHELL (EHT)	17:20	17:20	0:00	MAIN SUPPLY FAILURE
378	7-Sep-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 2	BELL CERAMICS (EHT)	17:15	18:06	0:51	LINE FAULT
379	7-Sep-19	BENGALURU	66	HOSKOTE 220 - HOSKOTE 1	GRINDWELL (EHT)	17:20	17:51	0:31	MAIN SUPPLY FAILURE
380	7-Sep-19	BENGALURU	66	HOSKOTE 220 - PILLAGUMPA	PILLAGUMPA	17:20	17:52	0:32	MAIN SUPPLY FAILURE
381	7-Sep-19	BENGALURU	66	HOSKOTE 220 - VOLVO	VOLVO, NANDAGUDI	17:20	17:55	0:35	MAIN SUPPLY FAILURE
382	7-Sep-19	BENGALURU	66	HOSKOTE 220 - SULIBELE	SULIBELE	17:20	17:53	0:33	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
383	7-Sep-19	BENGALURU	66	HV1	HOSKOTE 220	17:20	17:51	0:31	MAIN SUPPLY FAILURE
384	7-Sep-19	BENGALURU	66	HBR LAYOUT - LR BANDE	HBR LAYOUT	18:12	18:20	0:08	LOAD CHANGEVER
385	7-Sep-19	BENGALURU	66	HBR LAYOUT - HOSKOTE 220	HBR LAYOUT	17:20	17:41	0:21	MAIN SUPPLY FAILURE
386	7-Sep-19	BENGALURU	66	MAHALAKSHMI LAYOUT - NRS 220	MAHALAKSHMI LAYOUT	13:10	13:15	0:05	LOAD CHANGEVER
387	7-Sep-19	BENGALURU	66	SRS PEENYA 220 - NRS 2	MAHALAKSHMI LAYOUT	11:35	12:02	0:27	LINE FAULT
388	7-Sep-19	BENGALURU	66	HV1	HANUMANTHNAGAR	10:41	10:55	0:13	TRANSFORMER FAULT
389	7-Sep-19	BENGALURU	66	HV2	KADUGODI	14:37	15:05	0:27	LINE CLEAR AVAILED
390	7-Sep-19	BENGALURU	66	HV1	KADUBISANAHALLI	9:07	9:44	0:37	LINE CLEAR AVAILED
391	7-Sep-19	BENGALURU	66	HV2	NRS 220	17:44	17:50	0:06	MAIN SUPPLY FAILURE
392	7-Sep-19	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	12:40	23:59	11:19	LINE CLEAR AVAILED
393	7-Sep-19	GULBARGA	110	GULBARGANORTH-GULUNI	GULUNI_110	16:55	17:05	0:10	MAIN SUPPLY FAILURE
394	7-Sep-19	GULBARGA	110	HALBARGA-HALIKHED	HALIKHED_110	19:12	19:19	0:07	LINE FAULT
395	7-Sep-19	GULBARGA	66	HV1,HV2	HAMPASAGAR_66	14:21	19:08	4:47	LINE CLEAR AVAILED
396	7-Sep-19	GULBARGA	66	ITTAGI-CLEANMAX1	ITTAGI_220	11:04	11:10	0:06	LINE CLEAR AVAILED
397	7-Sep-19	GULBARGA	66	ITTAGI-BENNEHALLI	BENNEHALLI_66	11:10	11:15	0:05	LINE CLEAR AVAILED
398	7-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRSMG_220	14:08	18:30	4:22	LINE FAULT
399	7-Sep-19	HASSAN	220	SHRAVTY-SIRISI 1	sharavathy_gen	11:17	12:32	1:15	LINE CLEAR AVAILED
400	7-Sep-19	HASSAN	220	SHRAVTY-SIRISI 2	sharavathy_gen	0:00	12:33	12:33	LINE FAULT
401	7-Sep-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	14:08	18:30	4:22	LINE FAULT
402	7-Sep-19	HASSAN	110	HV1	KALLUSADARAHALLY_110	16:59	17:30	0:31	LINE CLEAR AVAILED
403	7-Sep-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	22:29	23:59	1:30	LINE CLEAR AVAILED
404	7-Sep-19	HASSAN	66	HV1	ALDUR_66	11:14	11:41	0:27	LINE CLEAR AVAILED
405	7-Sep-19	HASSAN	66	BHADRA-LINGADAHALLI	BHADRA_66	13:41	13:44	0:03	LINE FAULT
406	7-Sep-19	HASSAN	66	HV1	HOLALUR_66	10:25	12:10	1:45	LINE CLEAR AVAILED
407	7-Sep-19	HASSAN	66	HV1	HOLALUR_66	12:15	12:50	0:35	LINE CLEAR AVAILED
408	7-Sep-19	HASSAN	66	HV2	HOLALUR_66	10:25	12:10	1:45	LINE CLEAR AVAILED
409	7-Sep-19	HASSAN	66	HV2	HOLALUR_66	12:15	12:50	0:35	LINE CLEAR AVAILED
410	7-Sep-19	HASSAN	66	UDDURKO-CHIKMANGLUR	UDDURKOPLU_66	15:53	16:04	0:11	LINE FAULT
411	7-Sep-19	MYSORE	66	HV2	BOGADHI_66	12:00	13:20	1:20	LINE CLEAR AVAILED
412	7-Sep-19	MYSORE	66	HV2	HDKOTE_66	4:00	4:10	0:10	TRANSFORMER FAULT
413	7-Sep-19	MYSORE	66	HV1	THALAKADU_66	9:30	17:00	7:30	LINE CLEAR AVAILED
414	7-Sep-19	MYSORE	66	HV2	THALAKADU_66	9:30	17:01	7:31	LINE CLEAR AVAILED
415	7-Sep-19	MYSORE	66	TALAKADU-BG PURA	BGPURA_66, CHANDALLI_66	9:50	9:55	0:05	LINE FAULT
416	7-Sep-19	MYSORE	66	TALAKADU-BG PURA	BGPURA_66, CHANDALLI_66	10:05	10:10	0:05	LINE FAULT
417	7-Sep-19	MYSORE	66	TALAKADU-BG PURA	BGPURA_66, CHANDALLI_66	10:15	10:30	0:15	LINE FAULT
418	7-Sep-19	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	10:23	10:24	0:00	HAND TRIPPED
419	7-Sep-19	TUMKUR	110	DODDAGUNI- SAMPIGE	SAMPIGE_110	12:00	12:00	0:00	HAND TRIPPED
420	7-Sep-19	TUMKUR	110	TR-1	GUBBI_110	13:06	18:10	5:04	LINE CLEAR AVAILED
421	7-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	MELKOTE_66, BADDIHALLI_66	12:02	13:17	1:15	LINE CLEAR AVAILED
422	7-Sep-19	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	7:23	9:24	2:01	MAIN SUPPLY FAILURE
423	7-Sep-19	TUMKUR	66	BELLAVI-ANTHRASANAHALLI	BELLAVI_66	11:37	13:26	1:49	MAIN SUPPLY FAILURE

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
424	7-Sep-19	TUMKUR	66	TR-2	BUKKAPATNA_66	18:08	18:10	0:01	TRANSFORMER FAULT
425	7-Sep-19	TUMKUR	66	CHITRADURGA 220kV- PANDARAHALLI 2	PANDARAHALLI_66, HDPURA_66, HOLALKERE_66,RAMAGIRI_66	13:03	18:17	5:14	LINE FAULT
426	7-Sep-19	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	PANDARAHALLI_66	13:03	18:59	5:55	LINE FAULT
427	7-Sep-19	TUMKUR	66	TR-2	DAVANAGERE_66	22:27	22:35	0:08	TRANSFORMER FAULT
428	7-Sep-19	TUMKUR	66	DODDASARANGI-ANCHEPALYA	DODDASARANGI_66	8:35	13:27	4:52	LINE CLEAR AVAILED
429	7-Sep-19	TUMKUR	66	DODDASARANGI- ANTHRASANAHALLI	DODDASARANGI_66	13:27	13:40	0:12	HAND TRIPPED
430	7-Sep-19	TUMKUR	66	DAVANGERE SRS- KUKKAWADA	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:13	9:29	0:16	LINE FAULT
431	7-Sep-19	TUMKUR	66	TR-2	GULIGENAHALLI_66	12:09	12:42	0:33	LINE CLEAR AVAILED
432	7-Sep-19	TUMKUR	66	TR-2	GUTTUR_66	12:37	13:39	1:02	LINE CLEAR AVAILED
433	7-Sep-19	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	12:06	12:12	0:06	HAND TRIPPED
434	7-Sep-19	TUMKUR	66	HIRIYUR 220KV- RANGANATHPURA	DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66	11:17	11:23	0:05	HAND TRIPPED
435	7-Sep-19	TUMKUR	66	NAYAKANAHATTI66-HIREMALLANHOLE	HIREMALLANAHOLE_66	12:43	13:44	1:01	LINE FAULT
436	7-Sep-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	13:39	14:04	0:25	HAND TRIPPED
437	7-Sep-19	TUMKUR	66	TR-2	THOVINAKERE_66	11:25	13:09	1:43	LINE CLEAR AVAILED
438	8-Sep-19	BAGALKOT	220	NAGJHARI2-AMBEWADI	AMBEWADI_220	5:54	13:11	7:17	LINE FAULT
439	8-Sep-19	BAGALKOT	110	NARENDRA1&2-BELUR	BELUR_110	14:56	15:24	0:28	HAND TRIPPED
440	8-Sep-19	BAGALKOT	110	110/33KV,HV3&HV5	BELUR_110,TATA1&2_33,UAS_33	15:00	15:40	0:40	HAND TRIPPED
441	8-Sep-19	BAGALKOT	110	110/11KV,HV1,HV2&HV4	BELUR_110	15:00	15:55	0:55	HAND TRIPPED
442	8-Sep-19	BAGALKOT	110	110/33KV,HV3	LOKAPUR_110,BATAKURKI_33	14:10	14:12	0:02	TRANSFORMER FAULT
443	8-Sep-19	BAGALKOT	220	HUBLI-NAGJHARI3	HUBLI_220	9:48	10:19	0:31	LINE FAULT
444	8-Sep-19	BAGALKOT	110	110/11KV,HV2	SHIROL_110	16:20	16:27	0:07	TRANSFORMER FAULT
445	8-Sep-19	BAGALKOT	110	110/11KV,HV2	SANKESHWAR_110	12:31	13:20	0:49	LINE CLEAR AVAILED
446	8-Sep-19	BAGALKOT	110	110/33KV,HV3	SANKESHWAR_110,HEBBAL_33KV,K ANAGAL_33KV	11:33	12:09	0:36	LINE CLEAR AVAILED
447	8-Sep-19	BAGALKOT	110	110/11KV,HV1	RAIBAG_110	7:09	7:37	0:28	TRANSFORMER FAULT
448	8-Sep-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	19:04	19:18	0:14	LINE FAULT
449	8-Sep-19	BAGALKOT	110	JOG1-SIRSI	SIRSI_110	19:37	22:05	2:28	LINE CLEAR AVAILED
450	8-Sep-19	BAGALKOT	110	JOG2-SIRSI	SIRSI_110	20:05	21:50	1:45	LINE CLEAR AVAILED
451	8-Sep-19	BENGALURU	66	JIGANI 66 - BG ROAD	JIGANI 66	13:28	14:52	1:23	LINE CLEAR AVAILED
452	8-Sep-19	BENGALURU	66	HV2	JANGAMAKOTE	11:53	12:09	0:16	TRANSFORMER FAULT
453	8-Sep-19	BENGALURU	66	MALUR 220 - MAASTHI	LAKKUR, DEVANAGONDHI, MAASTHI	14:29	14:38	0:08	LINE FAULT
454	8-Sep-19	BENGALURU	66	MANDKALLU - GOWRIBIDANUR 220	PERESANDRA, SOMENAHALLI, MANDIKALLU	10:00	10:02	0:02	LOAD CHANGEVER

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
455	8-Sep-19	GULBARGA	110	SHAHAPUR-SHAHAPUR1	SHAHAPUR_110	0:00	12:48	12:48	LINE CLEAR AVAILED
456	8-Sep-19	GULBARGA	66	LV2	ITTAGI_220	6:52	7:02	0:10	TRANSFORMER FAULT
457	8-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	11:46	23:59	12:13	LINE FAULT
458	8-Sep-19	HASSAN	110	HV1	JOG_110	8:28	9:46	1:18	LINE CLEAR AVAILED
459	8-Sep-19	HASSAN	110	KADUR-NGNHL	KADUR_220	13:15	13:39	0:24	LINE FAULT
460	8-Sep-19	HASSAN	110	KAVOOR-MCFLine	KAVOOR_220	0:00	0:16	0:16	LINE CLEAR AVAILED
461	8-Sep-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	9:59	10:28	0:29	LINE FAULT
462	8-Sep-19	MYSORE	66	CR NAGARA-DR PETE 1	DODDARAYAPET_66	10:49	17:38	6:48	NFBC ISSUED
463	8-Sep-19	MYSORE	66	CR NAGARA-DR PETE 2	DODDARAYAPET_66	10:49	17:39	6:50	NFBC ISSUED
464	8-Sep-19	MYSORE	66	CR NAGARA-PANNYADAHUNDI	PANDYADAHUNDI_66	12:21	15:01	2:40	LINE CLEAR AVAILED
465	8-Sep-19	MYSORE	66	ELAVALA-HUNSUR	GAVADAGERE_66	2:45	2:56	0:11	LINE FAULT
466	8-Sep-19	MYSORE	66	HV1	ELAVALA_66	8:27	8:39	0:12	TRANSFORMER FAULT
467	8-Sep-19	MYSORE	66	FTS-HOOTAGALLI 2	FTS_66	7:37	18:36	10:59	LINE CLEAR AVAILED
468	8-Sep-19	MYSORE	66	FTS-HOOTAGALLI 1	FTS_66	7:38	18:36	10:58	LINE CLEAR AVAILED
469	8-Sep-19	MYSORE	66	HUNSUR-ELAVALA	GAVADAGERE_66	2:44	2:58	0:14	LINE FAULT
470	8-Sep-19	MYSORE	66	HV1	PANDYADAHUNDI_66	8:30	13:40	5:10	LINE CLEAR AVAILED
471	8-Sep-19	MYSORE	66	HV2	PANDYADAHUNDI_66	8:30	13:40	5:10	LINE CLEAR AVAILED
472	8-Sep-19	TUMKUR	220	HIRIYUR 220kV- PGCIL	HIRIYUR_220	13:52	19:04	5:11	LINE CLEAR AVAILED
473	8-Sep-19	TUMKUR	110	TR-1	GUBBI_110	15:55	16:48	0:52	LINE CLEAR AVAILED
474	8-Sep-19	TUMKUR	110	TR-1	SAMPIGE_110	9:32	16:06	6:33	LINE CLEAR AVAILED
475	8-Sep-19	TUMKUR	110	TR-2	SAMPIGE_110	9:32	10:55	1:22	LINE CLEAR AVAILED
476	8-Sep-19	TUMKUR	66	CHITRADURGA 66kV- MEGMICON 1	MEGMICON 1_IPP_66	16:11	16:21	0:10	HAND TRIPPED
477	8-Sep-19	TUMKUR	220	CHITRADURGA 66kV- MEGMICON 2	MEGMICON 1_IPP_66	16:11	16:22	0:10	HAND TRIPPED
478	8-Sep-19	TUMKUR	110	DAVANGERE SRS- GUTTUR66	GUTTUR_66	3:16	3:27	0:11	LINE FAULT
479	8-Sep-19	TUMKUR	110	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	13:30	13:37	0:06	HAND TRIPPED
480	8-Sep-19	TUMKUR	110	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	13:00	13:05	0:05	HAND TRIPPED
481	8-Sep-19	TUMKUR	66	RANGENAHALLI -AZURESOLAR	AZURESOLAR_IPP_66	15:01	16:10	1:09	LINE CLEAR AVAILED
482	8-Sep-19	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	14:25	14:44	0:19	HAND TRIPPED
483	8-Sep-19	TUMKUR	66	MEDIGESHI- CLEANSOLAR IPP	CLEANSOLAR_IPP_66	15:13	15:17	0:03	HAND TRIPPED
484	8-Sep-19	TUMKUR	66	I D HALLI- CLEAN MAX SOLAR	CLEANMAXSOLAR_IPP_66	14:23	14:30	0:07	LOAD CURTAILMENT
485	8-Sep-19	TUMKUR	66	HONNALLI 220kV- CHANNAGIRI(NALLUR)	CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66	18:38	18:50	0:11	LINE FAULT
486	9-Sep-19	BAGALKOT	110	ANKALAGI-ISLAMPUR	ISLAMPUR_110	2:30	2:57	0:27	LINE FAULT
487	9-Sep-19	BAGALKOT	110	ATHANI SUGARS-AINAPUR	AINAPUR_110	1:08	1:13	0:05	LINE FAULT
488	9-Sep-19	BAGALKOT	110	KUMTA-ANKOLA	ANKOLA_110	13:48	23:59	10:11	LINE FAULT
489	9-Sep-19	BAGALKOT	110	BAGALKOT220-NAVANAGAR1	NAVANAGAR_110	9:30	10:05	0:35	LINE FAULT
490	9-Sep-19	BAGALKOT	110	110/11KV,HV2	BHUTHNAL_110	9:14	9:18	0:04	TRANSFORMER FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
491	9-Sep-19	BAGALKOT	220	GHATAPRABHA220-KUDUCHI	GHATAPRABHA_220	10:03	15:03	5:00	LINE CLEAR AVAILED
492	9-Sep-19	BAGALKOT	220	GHATAPRABHA220-CHIKKODI	GHATAPRABHA_220	10:12	14:43	4:31	LINE CLEAR AVAILED
493	9-Sep-19	BAGALKOT	110	GHATAPRABHA220-P G HUNSYAL	P G HUNSYAL_110	4:34	4:55	0:21	LINE FAULT
494	9-Sep-19	BAGALKOT	220	RBRK-BAGEWADI	BAGEWADI_220	9:25	10:37	1:12	LINE CLEAR AVAILED
495	9-Sep-19	BAGALKOT	220	FORTUNE2-BAGEWADI	BAGEWADI_220	10:39	10:43	0:04	HAND TRIPPED
496	9-Sep-19	BAGALKOT	220	BIDNAL-HUBLI2	BIDNAL_220	9:17	15:00	5:43	LINE CLEAR AVAILED
497	9-Sep-19	BAGALKOT	220	BIDNAL-HUBLI2	BIDNAL_220	15:07	18:05	2:58	LINE CLEAR AVAILED
498	9-Sep-19	BAGALKOT	110	110/11KV,HV1	BILAGI_110	8:46	16:20	7:34	LINE CLEAR AVAILED
499	9-Sep-19	BAGALKOT	110	MY FAIR SOLAR-HIREHAL	HIREHAL_110	10:08	10:16	0:08	HAND TRIPPED
500	9-Sep-19	BAGALKOT	110	SOVERGN-TERDAL	TERDAL_110	19:53	23:59	4:06	LINE FAULT
501	9-Sep-19	BAGALKOT	110	SIRSI220-SIRSI1&2	SIRSI_110	13:35	14:13	0:38	LINE CLEAR AVAILED
502	9-Sep-19	BAGALKOT	110	GHATAPRABHA220-PG HUNSHYAL	PG HUNSHYAL_110	4:34	4:59	0:25	LINE FAULT
503	9-Sep-19	BAGALKOT	110	SATTI SUGARS-PG HUNSHYAL	PG HUNSHYAL_110	4:34	4:58	0:24	LINE FAULT
504	9-Sep-19	BAGALKOT	110	BELGAUM SOLAR-MAMDAPUR(B)	MAMDAPUR(B)_110	10:29	10:32	0:03	HAND TRIPPED
505	9-Sep-19	BAGALKOT	110	SIRIS110-KUMTA	KUMTA_110	13:29	14:25	0:56	MAIN SUPPLY FAILURE
506	9-Sep-19	BAGALKOT	110	110/33KV, HV2	KUDACHI_110, CHINCHLI_33	10:38	13:45	3:07	LINE CLEAR AVAILED
507	9-Sep-19	BAGALKOT	220	220/110KV, HV1, HV2, LV1&LV2	KUDACHI_220, KUDACHI_110, UGARKHUD_110, AINAPUR_110, TERDAL_110, MORAB_110, YELPARATTI_110, KAGAWAD_110	0:52	1:04	0:12	TRANSFORMER FAULT
508	9-Sep-19	BAGALKOT	220	220/110KV, HV1&LV1	KUDACHI_220, TERDAL_110	7:08	7:17	0:09	TRANSFORMER FAULT
509	9-Sep-19	BAGALKOT	110	KUDACHI220-UGARKHUD	UGARKHUD_110	10:47	12:31	1:44	LINE CLEAR AVAILED
510	9-Sep-19	BAGALKOT	110	SHIRGUPPI SUGARS-KAGAWAD	KAGAWAD_110	1:14	1:20	0:06	LINE FAULT
511	9-Sep-19	BAGALKOT	110	VISHWANATH SUGARS-HUKKERI	HUKKERI_110	11:07	16:07	5:00	LINE CLEAR AVAILED
512	9-Sep-19	BENGALURU	66	HV2	NRS 220	6:24	6:28	0:03	LOAD CHANGEVER
513	9-Sep-19	BENGALURU	66	HV3	CHIKKABALLAPURA I/A	12:23	13:27	1:03	LINE CLEAR AVAILED
514	9-Sep-19	BENGALURU	66	DB PURA 220 - DG 2	GUNDAMGERE, DODDABELAVANGALA	16:26	16:37	0:11	LINE FAULT
515	9-Sep-19	BENGALURU	66	HV2	GUNDAMGERE	16:26	16:53	0:26	TRANSFORMER FAULT
516	9-Sep-19	BENGALURU	66	HV2	KANAKAPURA 66	11:46	12:41	0:55	LINE CLEAR AVAILED
517	9-Sep-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	11:51	12:01	0:10	LINE FAULT
518	9-Sep-19	BENGALURU	66	KOLAR 220 - NANGLI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI	12:11	13:47	1:36	LINE CLEAR AVAILED
519	9-Sep-19	BENGALURU	66	KOLAR 220 - THAYALUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	12:52	13:44	0:51	LINE CLEAR AVAILED
520	9-Sep-19	BENGALURU	66	HV1	KEMBODI	13:51	14:41	0:50	LINE CLEAR AVAILED
521	9-Sep-19	BENGALURU	66	HV2	KYALANUR	9:55	10:05	0:10	TRANSFORMER FAULT
522	9-Sep-19	BENGALURU	66	HV2	KYALANUR	17:21	17:25	0:03	LINE CLEAR AVAILED

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
523	9-Sep-19	BENGALURU	66	HV2	NARASAPURA	7:06	7:15	0:08	TRANSFORMER FAULT
524	9-Sep-19	GULBARGA	110	KAPNOOR-HUMNABAD1	MAHAGOAN_110, MARGUTTI_110	14:22	14:29	0:07	LINE FAULT
525	9-Sep-19	GULBARGA	110	KAVITAL-MALLAT	KAVITAL_110	3:12	3:30	0:18	MAIN SUPPLY FAILURE
526	9-Sep-19	GULBARGA	110	HV1	KOLHAR_110	9:30	11:03	1:33	TRANSFORMER FAULT
527	9-Sep-19	GULBARGA	110	SINDHANOOR-SIRIGUPPA	TEKKELKOTE_110,DHADESUGUR_110,SIRIGUPPA_110,NSLSUGAR_IPP	16:16	16:26	0:10	LINE FAULT
528	9-Sep-19	GULBARGA	110	SINDHANOOR-SIRIGUPPA	TEKKELKOTE_110,DHADESUGUR_110,SIRIGUPPA_110,NSLSUGAR_IPP	16:48	16:58	0:10	LINE FAULT
529	9-Sep-19	GULBARGA	110	SINDHANOOR-SIRIGUPPA	TEKKELKOTE_110,DHADESUGUR_110,SIRIGUPPA_110,NSLSUGAR_IPP	17:01	18:45	1:44	LINE FAULT
530	9-Sep-19	GULBARGA	110	SINDHANOOR-TURUVIHAL	TURUVIHAL_110	22:36	22:46	0:10	LINE FAULT
531	9-Sep-19	GULBARGA	110	ALIPUR-PDHALLI	PDHALLI_110	15:53	23:59	8:06	MAIN SUPPLY FAILURE
532	9-Sep-19	GULBARGA	110	HV3	SHORAPUR_110	10:25	16:57	6:32	LINE CLEAR AVAILED
533	9-Sep-19	GULBARGA	110	KUSHTAGI_KUSHTAGISLR_IPP	KUSHTAGI_220	19:10	20:20	1:10	LINE FAULT
534	9-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR1	ITTAGI_220	15:31	15:35	0:04	LINE CLEAR AVAILED
535	9-Sep-19	GULBARGA	66	ITTAGI-RENEWSOLAR2	ITTAGI_220	15:05	15:07	0:02	LINE CLEAR AVAILED
536	9-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	0:00	12:44	12:44	LINE FAULT
537	9-Sep-19	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	12:45	23:59	11:14	LINE FAULT
538	9-Sep-19	HASSAN	220	MRSSHM-VARAH1	MRSMSG_220	12:52	23:59	11:07	LINE FAULT
539	9-Sep-19	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	8:55	9:01	0:06	LINE FAULT
540	9-Sep-19	HASSAN	220	HV2	PUTTUR-220	11:14	13:46	2:32	LINE CLEAR AVAILED
541	9-Sep-19	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	12:52	23:59	11:07	LINE FAULT
542	9-Sep-19	HASSAN	110	HV4	BAIKAMPADI_110	15:37	15:46	0:09	TRANSFORMER FAULT
543	9-Sep-19	HASSAN	110	HV4	BAIKAMPADI_110	16:22	16:44	0:22	TRANSFORMER FAULT
544	9-Sep-19	HASSAN	110	LV2	PUTTUR_220	11:14	13:46	2:32	LINE CLEAR AVAILED
545	9-Sep-19	HASSAN	110	HV2	SORABA_110	9:32	12:31	2:59	LINE CLEAR AVAILED
546	9-Sep-19	HASSAN	110	HV2	SORABA_110	12:34	13:03	0:29	LINE CLEAR AVAILED
547	9-Sep-19	HASSAN	110	HV2	SORABA_110	14:46	15:06	0:20	LINE CLEAR AVAILED
548	9-Sep-19	HASSAN	66	SAKALE-IPCL1	SAKLESHPURA_66	16:52	18:12	1:20	LINE CLEAR AVAILED
549	9-Sep-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	11:53	12:03	0:10	LINE FAULT
550	9-Sep-19	HASSAN	66	SAKALE-IPCL2	SAKLESHPURA_66	15:32	18:13	2:41	LINE CLEAR AVAILED
551	9-Sep-19	HASSAN	66	UDDURKO-CKNDGL	UDDURKOPLU_66	15:45	16:11	0:26	LINE CLEAR AVAILED
552	9-Sep-19	MYSORE	66	HV2	KADAKOLA_220	14:36	15:21	0:45	LINE CLEAR AVAILED
553	9-Sep-19	MYSORE	66	KUSHALANAGARA 220-BYLUKUPPE	BYLUKUPPE_66	8:48	8:52	0:04	LINE FAULT
554	9-Sep-19	MYSORE	66	PERIYAPATANA -KUSHALANAGARA 1	BYLUKUPPE_66	8:50	9:00	0:10	LINE FAULT
555	9-Sep-19	MYSORE	66	PERIYAPATANA -KUSHALANAGARA 2	PERIYAPATNA_66, PONNAMPET_66, VIRAJPET_66	8:50	9:00	0:10	LINE FAULT

Sl.No.	DATE	Tr_ZONE	Voltage	Line	Station_Name	Open_At	Closed_At	Duration	REASON
556	9-Sep-19	MYSORE	66	HV1	THALAKADU_66	6:04	6:09	0:05	HAND TRIPPED
557	9-Sep-19	MYSORE	66	HV2	THALAKADU_66	6:04	6:09	0:05	HAND TRIPPED
558	9-Sep-19	TUMKUR	220	CHITRADURGA 220kV- THALLAK	CHITRADURGA_220	10:43	16:08	5:25	LINE CLEAR AVAILED
559	9-Sep-19	TUMKUR	220	DAVANGERE SRS- GUTTUR-3	DAVANGERE_SRS_220	11:46	12:48	1:02	LINE CLEAR AVAILED
560	9-Sep-19	TUMKUR	220	THALLAK 220kV-CHITRADURGA	CHITRADURGA_220	10:43	16:02	5:19	LINE CLEAR AVAILED
561	9-Sep-19	TUMKUR	110	TR-1	GUBBI_110	11:57	12:03	0:05	TRANSFORMER FAULT
562	9-Sep-19	TUMKUR	110	TR-1	GUBBI_110	15:30	16:51	1:20	LINE CLEAR AVAILED
563	9-Sep-19	TUMKUR	66	TR-2(HV SIDE)	ANTHRASANAHALLI_220	10:43	10:54	0:10	LINE CLEAR AVAILED
564	9-Sep-19	TUMKUR	66	ANTHRASANAHALLI 220kV- KORATAGERE	CHIKKATOTLUKERE_66, BELADARA_66, KORATAGERE_66	10:08	10:31	0:23	LINE CLEAR AVAILED
565	9-Sep-19	TUMKUR	66	TR-1	DAVANGERE_SRS_220	11:55	12:15	0:19	LINE CLEAR AVAILED
566	9-Sep-19	TUMKUR	66	TR-1	HANAGAL_66	10:01	10:10	0:08	LINE CLEAR AVAILED
567	9-Sep-19	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 1	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	18:58	19:05	0:07	LINE FAULT
568	9-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	18:26	18:34	0:07	LINE FAULT
569	9-Sep-19	TUMKUR	66	NEELAGUNDA- TELAGI	TELAGI_66, KURUBARAHALLI_66, YARAGUNTA_66, OBAJJIHALLI_66	20:13	20:36	0:22	LINE FAULT
570	9-Sep-19	TUMKUR	66	SAVALANGA 66kV-HNLI220_NYMT	SAVALANGA_66	12:29	12:48	0:19	LINE CLEAR AVAILED
571	9-Sep-19	TUMKUR	66	TR-1	SAVALANGA_66	12:01	12:49	0:47	LINE CLEAR AVAILED
572	9-Sep-19	TUMKUR	66	THALLAK 220kV- NAYAKANHATTI	NAYAKANHATTI_66, HIREMALLANAHOLE_66	18:31	18:43	0:12	LINE FAULT