

### 400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 20.10.20 TO 26.10.20

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
1	20-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET 66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVALIED
2	20-Oct-20	BAGALKOT	110	110/11KV, HV1	VAJRAMATTI_110	16:44	17:00	0:16	TRANSFORMER FAULT
3	20-Oct-20	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	15:35	17:36	2:01	LINE CLEAR AVALIED
4	20-Oct-20	BAGALKOT	110	110/11KV, HV1	KUDAL SANGAM_110	17:51	18:39	0:48	LINE CLEAR AVALIED
5	20-Oct-20	BAGALKOT	110	110/11KV, HV2	NIPPANI_110	5:35	5:56	0:21	TRANSFORMER FAULT
6	20-Oct-20	BAGALKOT	110	110/11KV, HV2	NANADI_110	11:51	12:35	0:44	TRANSFORMER FAULT
7	20-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
8	20-Oct-20	BAGALKOT	110	110/11KV,HV2	ITANAL_110	15:50	16:51	1:01	LINE CLEAR AVALIED
9	20-Oct-20	BAGALKOT	110	110/33KV, HV3	NIPPANI_110, BENNADI_33	5:35	5:58	0:23	TRANSFORMER FAULT
10	20-Oct-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	14:52 (20.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVALIED
11	20-Oct-20	BAGALKOT	110	BAGEWADI-MAMADAPUR1	MAMADAPUR_110	19:55	20:25	0:30	LINE FAULT
12	20-Oct-20	BAGALKOT	110	BANAHATTI-NAVALAGI	NAVALAGI_110	18:30	18:35	0:05	HAND TRIPPED
13	20-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVALIED
14	20-Oct-20	BAGALKOT	110	BPCL- NARAGUND	NARAGUND_110	11:55	14:00	2:05	LINE FAULT
15	20-Oct-20	BAGALKOT	110	BPCL- NARAGUND	NARAGUND_110	15:20	20:45	5:25	LINE FAULT
16	20-Oct-20	BAGALKOT	110	CHIKKODI-SADALAGA	SADALAGA_110	10:35	10:55	0:20	LINE FAULT
17	20-Oct-20	BAGALKOT	110	GHATAPRABHA220-GHATAPRABHA 2	GHATAPRABHA_110	5:54	12:56	7:02	LINE FAULT
18	20-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVALIED
19	20-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVALIED
20	20-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVALIED
21	20-Oct-20	BAGALKOT	110	HAVERI-HANAGALL	HANAGAL_110	8:40	10:25	1:45	LINE CLEAR AVALIED
22	20-Oct-20	BAGALKOT	110	HUDLI-ANKALAGI	ANKALAGI_110	15:10	15:53	0:43	LINE FAULT
23	20-Oct-20	BAGALKOT	110	KAVALLWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVALIED
24	20-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
25	20-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVALIED
26	20-Oct-20	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	15:41	15:59	0:18	LINE FAULT
27	20-Oct-20	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	17:16	18:27	1:11	LINE FAULT
28	20-Oct-20	BAGALKOT	110	SOUDATTI220- BENAKATTI	BENAKATTI_110, YARAGATTI_110, KATAKOL_110	15:16 (20.10.2020)			LINE OPEN : LINE FAULT
29	20-Oct-20	BAGALKOT	110	SOUDATTI220-MUNAVALLI	MUNAVALLI_110	15:16 (20.10.2020)			LINE OPEN : LINE FAULT
30	20-Oct-20	BAGALKOT	110	VAJRAMATTI220- JK CEMENT	VAJRAMATTI_220	16:53	19:20	2:27	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
31	20-Oct-20	BAGALKOT	220	220/110KV, HV2&LV2	MAHALINGAPUR_220	17:16	19:20	2:04	TRANSFORMER FAULT
32	20-Oct-20	BAGALKOT	220	220/110KV, HV1, LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN: LINE CLEAR AVOIDED
33	20-Oct-20	BAGALKOT	220	220/110KV, HV2	HAVERI_220	14:54	15:20	0:26	HAND TRIPPED
34	20-Oct-20	BAGALKOT	220	220/110KV, HV2, LV2	BIJAPUR_220	14:57	16:14	1:17	LINE CLEAR AVOIDED
35	20-Oct-20	BAGALKOT	220	BAGALKOT-GADAG1	STATION NOT AFFECTED BAGALKOT_220	2:08 (20.10.2020)			LOAD CURTAILMENT
36	20-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA2	STATION NOT AFFECTED BAGEWADI_220	16:28 (16.09.2020)	17:55 (20.10.2020)	817:33hrs	LINE CHARGED
37	20-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI 1	BELGAUM_220	21:46 (19.10.2020)	5:45 (20.10.2020)	7:59hrs	LOAD CURTAILMENT
38	20-Oct-20	BAGALKOT	220	BIDNAL-NARENDRA	BIDNAL_220	5:36	12:50	7:14	LINE FAULT
39	20-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVOIDED
40	20-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVOIDED
41	20-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVOIDED
42	20-Oct-20	BAGALKOT	220	CHIKKODI-KUDACHI	CHIKKODI_220	5:40	6:20	0:40	LINE FAULT
43	20-Oct-20	BAGALKOT	220	DONI-GADAG	GADAG_220	19:48 (20.10.2020)			LINE OPEN : LINE FAULT
44	20-Oct-20	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	22:42 (20.10.2020)			LOAD CURTAILMENT
45	20-Oct-20	BAGALKOT	220	HUBLI- BIDNAL1	HUBLI_220	16:32 (20.10.2020)			LINE OPEN : LINE FAULT
46	20-Oct-20	BAGALKOT	220	MAHALINGAPUR- KUDACHI	KUDACHI_220	17:48	21:20	3:32	LINE FAULT
47	20-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	STATION NOT AFFECTED SIRSI_220	5:43 (19.10.2020)	15:03 (20.10.2020)	33:20hrs	LOAD CURTAILMENT
48	20-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	STATION NOT AFFECTED SIRSI_220	5:43 (19.10.2020)	15:03 (20.10.2020)	33:20hrs	LOAD CURTAILMENT
49	20-Oct-20	BAGALKOT	220	VAJRAMATTI- MAHALINGAPUR2	VAJRAMATTI_220	15:15	15:20	0:05	LINE FAULT
50	20-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
51	20-Oct-20	BENGALURU	66	CB PURA I/A - DB PURA 1	CB PURA I/A, CB PURA URBAN	14:57	15:00	00:03	LINE CLEAR AVOIDED
52	20-Oct-20	BENGALURU	66	CB PURA I/A - DB PURA 2	CB PURA I/A	14:57	15:01	00:03	LINE CLEAR AVOIDED
53	20-Oct-20	BENGALURU	66	HV1	YARANDANAHALLI	12:49	18:01	05:12	LINE CLEAR AVOIDED
54	20-Oct-20	BENGALURU	66	HV1	SIDDALAGATTA	07:50	08:10	00:20	TRANSFORMER FAULT
55	20-Oct-20	BENGALURU	66	HV1	CHAKAVELU	04:04	04:15	00:10	TRANSFORMER FAULT
56	20-Oct-20	BENGALURU	66	HV2	HANUMANTHAGARA	22:43	22:46	00:03	TRANSFORMER FAULT
57	20-Oct-20	BENGALURU	66	HV2	VICTORIA	11:20	11:24	00:04	LINE CLEAR AVOIDED
58	20-Oct-20	BENGALURU	66	HV2	CB PURA I/A	12:15	13:50	01:35	LINE CLEAR AVOIDED
59	20-Oct-20	BENGALURU	66	ITI 220 - POTTERY ROAD	POTTERY ROAD	22:11	22:44	00:33	LINE FAULT
60	20-Oct-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	00:06	01:10	01:04	LINE FAULT
61	20-Oct-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 1	ISRO LAYOUT	14:48	14:55	00:07	LINE CLEAR AVOIDED
62	20-Oct-20	BENGALURU	66	SUBRAMANYAPURA 220 - SARAKKI 2	SARAKKI	14:48	14:55	00:07	LINE CLEAR AVOIDED
63	20-Oct-20	BENGALURU	66	YARANDANAHALLI 220 - ELECTRONIC CITY 1	ELECTRONIC CITY, INFOSYS (EHT)	12:49	13:08	00:19	LINE CLEAR AVOIDED
64	20-Oct-20	BENGALURU	220	HV2	YARANDANAHALLI	12:49	13:06	00:17	TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
65	20-Oct-20	BENGALURU	220	HV2	BEGUR 220	12:40	12:57	00:17	LINE CLEAR AVAILED
66	20-Oct-20	BENGALURU	220	HV2	BEGUR 220	15:40	15:56	00:16	TRANSFORMER FAULT
67	20-Oct-20	BENGALURU	220	YELAHANKA 220 - YCCP 1	NO STATION AFFECTED	11:26	12:03	00:37	LINE FAULT
68	20-Oct-20	GULBARGA	110	GULBARGASOUTH- GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
69	20-Oct-20	GULBARGA	110	HV1	MANTHAL_110	14:40	15:00	00:20	TRANSFORMER FAULT
70	20-Oct-20	GULBARGA	110	HV2	HATTI_110	11:16	11:22	00:06	TRANSFORMER FAULT
71	20-Oct-20	GULBARGA	110	HV2	HATTI_110	17:02	17:26	00:24	TRANSFORMER FAULT
72	20-Oct-20	GULBARGA	110	HV2	HATTI_110	19:06	19:11	00:05	TRANSFORMER FAULT
73	20-Oct-20	GULBARGA	110	HV2	HATTI_110	20:06	20:20	00:14	TRANSFORMER FAULT
74	20-Oct-20	GULBARGA	110	LINGSUGUR-MUDGAL_110	MUDGAL_110	17:19	18:44	01:25	LINE FAULT
75	20-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
76	20-Oct-20	GULBARGA	110	SHAHAPUR-KEMBHAVI	KEMBHAVI_110,UGAR SUGAR IPP,HUNASGI_110,ASKI_110	16:19	16:39	00:20	LINE FAULT
77	20-Oct-20	GULBARGA	110	SHAHAPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110 ,SAIDAPUR_110,CORE GREEN SUGAR IPP,SANNATHI IPP	16:04	16:25	00:21	LINE FAULT
78	20-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
79	20-Oct-20	GULBARGA	220	HV2	LINGSUGUR_220	17:19	17:30	00:11	TRANSFORMER FAULT
80	20-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	21:27(20.10.2020)			LINE OPEN: LINE CLEAR AVAILED
81	20-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	HUMNABAD_220	02:35	06:37	04:02	LINE CLEAR AVAILED
82	20-Oct-20	GULBARGA	220	LINGSUGUR-RTPS2	RTPS_220	13:48	15:09	01:21	LINE FAULT
83	20-Oct-20	GULBARGA	220	SEDAM-HUMNABAD2	HUMNABAD_220	23:00(20.10.2020)			LINE OPEN: LINE CLEAR AVAILED
84	20-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	18:30(19.10.2020)			LINE OPEN : LINE FAULT
85	20-Oct-20	HASSAN	66	BANDISH-ADANI	BANDISHETTIHALLY_66	18:20	19:22	01:02	LINE CLEAR AVAILED
86	20-Oct-20	HASSAN	66	BANDISH-RAMNATHPURA	BANDISHETTIHALLY_66	10:10	18:00	07:50	LINE CLEAR AVAILED
87	20-Oct-20	HASSAN	66	CHANNARA-HIRESAVE	CHANNARAYAPATNA_66	11:06	11:28	00:22	LINE CLEAR AVAILED
88	20-Oct-20	HASSAN	66	HASSN220-BELUR	HASSAN_220	08:06	08:14	00:08	LINE FAULT
89	20-Oct-20	HASSAN	66	HV2	HOLALUR_66	19:15 (20.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
90	20-Oct-20	HASSAN	66	HV2	HOLALUR_66	22:26 (19.10.2020)	11:06 (20.10.2020)	12:40hrs	LINE CHARGED
91	20-Oct-20	HASSAN	66	UDDURKO-HASSAN2	UDDURKOPLU_66	08:06	08:20	00:14	LINE FAULT
92	20-Oct-20	HASSAN	110	HV1	ESSUR_110	16:11	17:54	01:43	LINE CLEAR AVAILED
93	20-Oct-20	HASSAN	110	HV1	GANDASI_110	10:28	13:38	03:10	LINE CLEAR AVAILED
94	20-Oct-20	HASSAN	110	HV1	GERUMARA_110	11:14	11:53	00:39	LINE CLEAR AVAILED
95	20-Oct-20	HASSAN	110	HV2	GANDASI_110	13:39	16:58	03:19	LINE CLEAR AVAILED
96	20-Oct-20	HASSAN	110	HV2	GERUMARA_110	11:55	12:00	00:05	LINE CLEAR AVAILED
97	20-Oct-20	HASSAN	110	HV4	BAIKAMPADY_110	13:01	14:12	01:11	LINE CLEAR AVAILED
98	20-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
99	20-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
100	20-Oct-20	HASSAN	110	LV1	KEMAR_220	11:53	13:37	01:44	LINE CLEAR AVAILED
101	20-Oct-20	HASSAN	110	LV2	MRSMSG_220	15:33 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
102	20-Oct-20	HASSAN	110	MOODAB-GURUPURA	MOODABIDRE_110	11:05	12:30	01:25	HAND TRIPPED
103	20-Oct-20	HASSAN	220	HV1	KEMAR_220	11:53	13:37	01:44	LINE CLEAR AVAILED
104	20-Oct-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	10:13	15:05	04:52	LINE CLEAR AVAILED
105	20-Oct-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	09:38	19:19	09:41	NFBC ISSUED
106	20-Oct-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	10:13	15:06	04:53	NFBC ISSUED
107	20-Oct-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	09:39	19:20	09:41	LINE CLEAR AVAILED
108	20-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
109	20-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:54 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
110	20-Oct-20	MYSURU	66	ATTIGULIPURA-HONNALLY	ATTIGULIPURA_66	11:24	17:41	6:17	LINE CLEAR AVAILED
111	20-Oct-20	MYSURU	66	CR NAGARA-HONNALLI	HONNALLY_MYS_66	11:23	16:39	5:16	LINE CLEAR AVAILED
112	20-Oct-20	MYSURU	66	HOOTAGALLI-BARC 2	NO STATION EFFECTED	11:31	11:46	0:14	LINE FAULT
113	20-Oct-20	MYSURU	66	HV1	ADDIHALI_66	12:49	13:06	0:17	LINE CLEAR AVAILED
114	20-Oct-20	MYSURU	66	HV1	JAKKANAHALLY_66	15:35	15:41	0:06	LINE CLEAR AVAILED
115	20-Oct-20	MYSURU	66	HV1	MALAVALLI_66	20:46	21:40	0:54	LINE CLEAR AVAILED
116	20-Oct-20	MYSURU	66	HV2	HEBBAL_66	8:46	9:14	0:28	HAND TRIPPED
117	20-Oct-20	MYSURU	66	HV2	MALAVALLI_66	20:15	21:39	1:23	LINE CLEAR AVAILED
118	20-Oct-20	MYSURU	66	HV2	SANTHEMARAHALLI_66	12:29	13:00	0:31	LINE CLEAR AVAILED
119	20-Oct-20	MYSURU	66	KOLLEGALA-SATHEGALA	NO STATION EFFECTED	4:50	4:56	0:05	LINE FAULT
120	20-Oct-20	MYSURU	66	KUNTHUR-DR PETE	SANTHEMARAHALLI_66 MUGUR_66 THAYURU_66 TNARASIPURA_66	14:52	14:58	0:06	LINE FAULT
121	20-Oct-20	MYSURU	66	MADDUR-KIADB MANDYA	NO STATION EFFECTED	12:24	13:24	1:00	HAND TRIPPED
122	20-Oct-20	MYSURU	66	MANDYA -M2	MALAVALLI_66 KADKOTHANAHALLI_66 HADLI_66	19:33	19:45	0:12	LINE FAULT
123	20-Oct-20	MYSURU	66	MEGALAPURA-SFC	THUMBLA_66 VYASRAJPURA_66 GARGESHWARI_66 CHIDRAVALLI_66 BGPURA_66	11:27	11:36	0:09	LINE FAULT
124	20-Oct-20	MYSURU	66	PERIYAPATNA-HANGODU	PONNAMPET_66 VIRAJPET_66 HANAGODU_66	13:00	13:10	0:10	LINE FAULT
125	20-Oct-20	MYSURU	66	TUBINKERE-MC-2	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66,KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66 HADLI_66	16:46	16:53	0:07	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
126	20-Oct-20	MYSURU	66	TUBINKERE-MC-4	MANDYA_66 CHIKKA_MANDYA_66 HAMPAPURA_66 BESAGARAHALLI_66,KOPPA_66 KADKOTHANAHALLI_66 MALAVALLI_66,HADLI_66	16:46	16:53	0:07	LINE FAULT
127	20-Oct-20	MYSURU	220	HV2	TUBINAKERE_220	15:49	15:59	0:09	HAND TRIPPED
128	20-Oct-20	TUMKUR	66	ANTHRASANAHALLI 220KV- MELEKOTE	DODDASARANGI_66,MELKOTE_66 , BADDIHALLI_66, HONNUDIKE_66, HIREHALLY_66	18:38	19:15	0:36	LINE FAULT
129	20-Oct-20	TUMKUR	66	BADDIHALLI- MELEKOTE	BADDIHALLI_66	19:06	19:22	0:15	MAIN SUPPLY FAILURE
130	20-Oct-20	TUMKUR	66	BANUVALLI- HONNALLI	BANUVALLI_66	17:47	17:52	0:05	LINE FAULT
131	20-Oct-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:22	10:24	0:02	LINE CLEAR AVAILED
132	20-Oct-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	10:50	18:51	8:00	LINE CLEAR AVAILED
133	20-Oct-20	TUMKUR	66	HONNALLI 220KV- KUNDUR	KUNDUR_66,MALEBENNUR_66	17:47	18:01	0:13	LINE FAULT
134	20-Oct-20	TUMKUR	66	HONNALLI 220KV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	9:33	9:43	0:09	LINE FAULT
135	20-Oct-20	TUMKUR	66	HONNALLI 66KV- HONNALLI	HONNALLI_66	10:25	16:01	5:36	LINE CLEAR AVAILED
136	20-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	10:54	11:05	0:10	LINE FAULT
137	20-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:36	11:45	0:08	LINE FAULT
138	20-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	12:35	12:57	0:22	LINE FAULT
139	20-Oct-20	TUMKUR	66	MADHUGIRI 220KV- PULAMAGATTA	PULAMG_66	18:15	18:26	0:11	LINE FAULT
140	20-Oct-20	TUMKUR	66	MELKOTE-BADIHALLI	MELKOTE_66	19:20	19:22	0:01	MAIN SUPPLY FAILURE
141	20-Oct-20	TUMKUR	66	PULAMGHATTA66- MADHUGIRI 220kV	PULAMG_66	18:25	18:28	0:03	MAIN SUPPLY FAILURE
142	20-Oct-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	16:49	17:12	0:23	LINE CLEAR AVAILED
143	20-Oct-20	TUMKUR	66	TR-1	DEVARAHALLI_66	20:08	20:10	0:02	TRANSFORMER FAULT
144	20-Oct-20	TUMKUR	66	TR-1	HONNALLI_66	10:25	16:02	5:36	LINE CLEAR AVAILED
145	20-Oct-20	TUMKUR	66	TR-1	KOLALA_66	14:12	14:27	0:15	HAND TRIPPED
146	20-Oct-20	TUMKUR	66	TR-1	SOKKE_66	16:52	17:24	0:32	LINE CLEAR AVAILED
147	20-Oct-20	TUMKUR	66	TR-2	HONNALLI_66	10:25	16:02	5:37	LINE CLEAR AVAILED
148	20-Oct-20	TUMKUR	66	TR-2	HONNUDIKE_66	9:49	17:39	7:49	LINE CLEAR AVAILED
149	20-Oct-20	TUMKUR	66	TR-2	KUKKAWADA_66	16:12	17:16	1:03	LINE CLEAR AVAILED
150	20-Oct-20	TUMKUR	66	URDIGERE-KOLALA	URDIGERE_66	10:58	12:13	1:14	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
151	20-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
152	20-Oct-20	TUMKUR	110	TR-3	GUBBI_110	11:52	12:38	0:45	LINE CLEAR AVAILED
153	21-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
154	21-Oct-20	BAGALKOT	110	110/11KV, HV1	MUDALGI_110	15:56	16:18	0:22	LINE CLEAR AVAILED
155	21-Oct-20	BAGALKOT	110	110/11KV, HV2	RON_110	11:35	15:09	3:34	LINE CLEAR AVAILED
156	21-Oct-20	BAGALKOT	110	110/11KV, HV2	RON_110	15:09	17:11	2:02	TRANSFORMER FAULT
157	21-Oct-20	BAGALKOT	110	110/11KV, HV2	NANADI_110	11:15	15:52	4:37	LINE CLEAR AVAILED
158	21-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
159	21-Oct-20	BAGALKOT	110	110/33KV, HV2	RATTIHALLI_110, HALLUR_33, MASUR_33	15:52	16:23	0:31	LINE CLEAR AVAILED
160	21-Oct-20	BAGALKOT	110	110/33KV,HV4	LAKAMANAHALLI_110 & ALNAVAR_33,TIGADI_33	19:10	19:26	0:16	TRANSFORMER FAULT
161	21-Oct-20	BAGALKOT	110	220/110KV, LV2	STATION NOT AFFECTED MK HUBLI_220	14:52 (20.10.2020)	10:15 (21.10.2020)	19:23hrs	LINE CHARGED
162	21-Oct-20	BAGALKOT	110	ATHANI220- SATTI	STATION NOT AFFECTED SATTI_110	15:56 (21.10.2020)			LINE OPEN : LINE FAULT
163	21-Oct-20	BAGALKOT	110	BAGEWADI- MAMDAPUR2	STATION NOT AFFECTED MAMDAPUR(B)_110	17:04	17:13	0:09	LINE CLEAR AVAILED
164	21-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
165	21-Oct-20	BAGALKOT	110	GHATAPRABHA220-GOKAK	GOKAK_110	3:08	3:22	0:14	LINE FAULT
166	21-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
167	21-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
168	21-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
169	21-Oct-20	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	5:25	5:47	0:22	LINE FAULT
170	21-Oct-20	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	6:12	9:37	3:25	LINE FAULT
171	21-Oct-20	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	10:45	13:07	2:22	LINE FAULT
172	21-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
173	21-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
174	21-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
175	21-Oct-20	BAGALKOT	110	MAHALINGAPUR- BANAHATTI	BANAHATTI_110	18:25	18:40	0:15	LINE FAULT
176	21-Oct-20	BAGALKOT	110	MANALI SUGARS- MALGHAN(S)	MALGHAN(S)_110	4:00	4:09	0:09	LINE FAULT
177	21-Oct-20	BAGALKOT	110	SHIRHATTI- LAXMESHWAR	LAXMESHWAR_110	0:38	7:47	7:09	LINE FAULT
178	21-Oct-20	BAGALKOT	110	SODATTI220- BENAKATTI	BENAKATTI_110, YARAGATTI_110, KATAKOL_110	15:16 (20.10.2020)	10:47 (21.10.2020)	19:31hrs	LINE FAULT
179	21-Oct-20	BAGALKOT	110	SODATTI220-MUNAVALLI	MUNAVALLI_110	15:16 (20.10.2020)	11:27 (21.10.2020)	20:11hrs	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
180	21-Oct-20	BAGALKOT	220	220/110KV,HV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)	14:29 (21.10.2020)	219:00hrs	TRANSFORMER CHARGED
181	21-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
182	21-Oct-20	BAGALKOT	220	BAGALKOT-GADAG1	STATION NOT AFFECTED BAGALKOT_220	2:08 (20.10.2020)			LOAD CURTAILMENT
183	21-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
184	21-Oct-20	BAGALKOT	220	BIDNAL-HUBLI 1	BIDNAL_220	16:32 (20.10.2020)	17:09 (21.10.2020)	24:37hrs	LINE FAULT
185	21-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
186	21-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
187	21-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
188	21-Oct-20	BAGALKOT	220	DHONI-GADAG	GADAG_220	19:48 (20.10.2020)			LINE OPEN : LINE FAULT
189	21-Oct-20	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	22:42 (20.10.2020)			LOAD CURTAILMENT
190	21-Oct-20	BAGALKOT	220	NAGAJHARI 1- BIDNAL	BIDNAL_220	14:53	17:07	2:14	LINE CLEAR AVAILED
191	21-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	20:46 (21.10.2020)			LINE OPEN : LINE FAULT
192	21-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
193	21-Oct-20	BENGALURU	66	GOKULA - BEL (EHT)	BEL (EHT)	00:22	01:08	00:46	MAIN SUPPLY FAILURE
194	21-Oct-20	BENGALURU	66	GOKULA - HEBBALA 220	GOKULA, BEL (EHT), HMT (EHT)	03:25	03:32	00:07	LOAD CHANGE OVER
195	21-Oct-20	BENGALURU	66	GOKULA - HMT (EHT)	HMT (EHT)	00:22	01:08	00:46	MAIN SUPPLY FAILURE
196	21-Oct-20	BENGALURU	66	HOODY 220 - HP	HP	12:45	14:26	01:41	LINE CLEAR AVAILED
197	21-Oct-20	BENGALURU	66	HV1	KUMBALAGODU	13:15	14:15	01:00	LINE CLEAR AVAILED
198	21-Oct-20	BENGALURU	66	HV1	CHINTAMANI	10:57	11:09	00:12	TRANSFORMER FAULT
199	21-Oct-20	BENGALURU	66	HV1	MAGADI 66	12:08	12:47	00:39	LINE CLEAR AVAILED
200	21-Oct-20	BENGALURU	66	HV2	MAGADI 66	01:40	01:59	00:19	TRANSFORMER FAULT
201	21-Oct-20	BENGALURU	66	HV2	SADLI	13:55	16:20	02:25	LINE CLEAR AVAILED
202	21-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	08:18	08:34	00:16	LINE FAULT
203	21-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	09:15	10:25	01:10	LINE CLEAR AVAILED
204	21-Oct-20	BENGALURU	66	KANAKAPURA 220 - SOMANAHALLI 1	CHATRA, MARALWADI, HANUMANTHNAGAR, YEDUMADU	17:10	18:50	01:40	LINE CLEAR AVAILED
205	21-Oct-20	BENGALURU	66	KODIGENAHALLI - T G HALLI	TAVAREKERE	13:38	15:09	01:31	LINE CLEAR AVAILED
206	21-Oct-20	BENGALURU	66	KORAMANGALA 220 - GOLF LINK HAL 2	K & C VALLEY	15:54	15:56	00:02	LINE CLEAR AVAILED
207	21-Oct-20	BENGALURU	66	MATHIKERE - GOKULA	MATHIKERE	00:22	00:56	00:34	MAIN SUPPLY FAILURE
208	21-Oct-20	BENGALURU	66	MATHIKERE - HEBBAL 220	MATHIKERE	03:50	03:56	00:06	LOAD CHANGE OVER

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
209	21-Oct-20	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	18:02	18:08	00:06	LINE FAULT
210	21-Oct-20	BENGALURU	66	RMV - GOKULA	RMV, TATA INSTITUTE (EHT)	00:22	01:00	00:38	MAIN SUPPLY FAILURE
211	21-Oct-20	BENGALURU	66	RMV - HEBBAL 220	RMV, TATA INSTITUTE (EHT)	03:45	03:50	00:05	LOAD CHANGE OVER
212	21-Oct-20	BENGALURU	66	SM MANGALA - KOLAR 220	SM MANGALA	12:00	12:48	00:48	LINE CLEAR AVAILED
213	21-Oct-20	BENGALURU	66	SRS PEENYA 220 - GOKULA 1	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	00:22	01:05	00:43	LINE FAULT
214	21-Oct-20	BENGALURU	66	SRS PEENYA 220 - GOKULA 2	GOKULA, RMV, MATHIKERE, BEL (EHT), HMT (EHT), TATA INSTITUTE (EHT)	00:22	01:05	00:43	LINE FAULT
215	21-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	15:48	15:56	00:07	LINE FAULT
216	21-Oct-20	BENGALURU	66	YELAHANKA 220 - LINE7	KANASWADI	16:26	20:40	04:13	LINE CLEAR AVAILED
217	21-Oct-20	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	02:06	06:55	04:48	LINE FAULT
218	21-Oct-20	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	11:32	11:38	00:06	LINE FAULT
219	21-Oct-20	BENGALURU	220	MITTEMARI 220 - GOWRIBIDANUR 2	NO STATION AFFECTED	19:02	19:10	00:08	LINE FAULT
220	21-Oct-20	GULBARGA	110	GULBARGASOUTH- GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
221	21-Oct-20	GULBARGA	110	HV1	SHAHAPUR_220	11:53	12:03	00:10	TRANSFORMER FAULT
222	21-Oct-20	GULBARGA	110	HV1	SHAHAPUR_220	11:53	12:03	00:10	TRANSFORMER FAULT
223	21-Oct-20	GULBARGA	110	HV2	HANUMANAL_110	10:25	10:50	00:25	TRANSFORMER FAULT
224	21-Oct-20	GULBARGA	110	HV2	SINDHANOOR_110	10:30	10:40	00:10	TRANSFORMER FAULT
225	21-Oct-20	GULBARGA	110	HV2	HANUMANAL_110	10:25	10:50	00:25	TRANSFORMER FAULT
226	21-Oct-20	GULBARGA	110	HV2	SINDHANOOR_110	10:30	10:40	00:10	TRANSFORMER FAULT
227	21-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
228	21-Oct-20	GULBARGA	110	MASKI-RNWSOLAR_IPP	MASK_110	13:25	13:40	00:15	LINE FAULT
229	21-Oct-20	GULBARGA	110	MASKI-RNWSOLAR_IPP	MASK_110	15:40	15:48	00:08	LINE FAULT
230	21-Oct-20	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	02:50	03:50	01:00	MAIN SUPPLY FAILURE
231	21-Oct-20	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	02:50	03:50	01:00	MAIN SUPPLY FAILURE
232	21-Oct-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110 ,SAIDAPUR_110,CORE GREEN SUGAR IPP,SANNATHI IPP	00:26	00:36	00:10	LINE FAULT
233	21-Oct-20	GULBARGA	110	SHAHPUR-KHANAPUR	KHANAPUR_110,WADAGERA_110 ,SAIDAPUR_110,CORE GREEN SUGAR IPP,SANNATHI IPP	00:26	00:36	00:10	LINE FAULT
234	21-Oct-20	GULBARGA	110	SINDHANOOR-SIDHANOOR220	SINDHANOOR_110	15:55(21.10.2020)			LINE OPEN : LINE FAULT
235	21-Oct-20	GULBARGA	110	SINDHANOOR-SIDHANOOR220	SINDHANOOR_110	15:55	16:05	00:10	LINE FAULT
236	21-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
237	21-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	21:27(20.10.2020)	7:11(21.10.2020)	9:44HRS	LINE CHARGED
238	21-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	21:27(20.10.2020)	7:11(21.10.2020)	9:44HRS	LINE CHARGED
239	21-Oct-20	GULBARGA	220	SEADM-HUMNABAD2	HUMNABAD_220	23:00(20.10.2020)	4:57(21.10.2020)	5:57HRS	LINE CHARGED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
240	21-Oct-20	GULBARGA	220	SEADM-HUMNABAD2	HUMNABAD_220	23:00(20.10.2020)	4:57(21.10.2020)	5:57HRS	LINE CHARGED
241	21-Oct-20	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	04:57	13:10	08:13	LINE CLEAR AVAILED
242	21-Oct-20	GULBARGA	220	SEDAM-HUMNABAD1	HUMNABAD_220	04:57	13:10	08:13	LINE CLEAR AVAILED
243	21-Oct-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	06:02	06:13	00:11	LINE FAULT
244	21-Oct-20	GULBARGA	220	SEDAM-RTPS2	SEDAM_220	06:02	06:13	00:11	LINE FAULT
245	21-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	18:30(19.10.2020)			LINE OPEN : LINE FAULT
246	21-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	3:40(21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
247	21-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	3:40(21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
248	21-Oct-20	HASSAN	66	CRPATNA2-MATTANAVILE	CRPATNA_220	07:09	07:34	00:25	LINE FAULT
249	21-Oct-20	HASSAN	66	HV1	CHIKKAKONDAGOLA_66	09:47	16:06	06:19	LINE CLEAR AVAILED
250	21-Oct-20	HASSAN	66	HV1	DIDIGA_66	14:26	14:50	00:24	TRANSFORMER FAULT
251	21-Oct-20	HASSAN	66	HV1	RAMPURA_66	00:19	18:00	17:41	HAND TRIPPED
252	21-Oct-20	HASSAN	66	HV2	HOLALUR_66	19:15(20.10.2020)	15:35(21.10.2020)	20:20hrs	LINE CHARGED
253	21-Oct-20	HASSAN	66	SAKALE-HANBAL	SAKLESH PURA_66	13:13	13:30	00:17	HAND TRIPPED
254	21-Oct-20	HASSAN	66	UDAYAP-SATHENAHALLI	UDAYAPURA_66	12:39	12:46	00:07	LINE FAULT
255	21-Oct-20	HASSAN	110	GAJNUR-SHIMOGA IC LINE	GAJAMUR_110	10:05	13:34	03:29	NFBC ISSUED
256	21-Oct-20	HASSAN	110	HV1	KONDENALU_110	10:42	13:30	02:48	LINE CLEAR AVAILED
257	21-Oct-20	HASSAN	110	HV2	KARAYA_110	10:35	12:55	02:20	LINE CLEAR AVAILED
258	21-Oct-20	HASSAN	110	HV2	KONAJE_110	10:28	11:19	00:51	LINE CLEAR AVAILED
259	21-Oct-20	HASSAN	110	HV2	KONDENALU_110	10:42	17:06	06:24	LINE CLEAR AVAILED
260	21-Oct-20	HASSAN	110	HV3	HIRIYADKA_110	12:19	14:21	02:02	LINE CLEAR AVAILED
261	21-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
262	21-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
263	21-Oct-20	HASSAN	110	LV2	MRS MG_220	15:33 (12.10.2020)	14:47 (21.10.2020)	215:14hrs	LINE CHARGED
264	21-Oct-20	HASSAN	110	MRSSH M-GAJNUR	MRS MG_220	09:48	13:37	03:49	LINE CLEAR AVAILED
265	21-Oct-20	HASSAN	110	MRSSH M-GAJNUR	MRS MG_220	13:50	14:10	00:20	HAND TRIPPED
266	21-Oct-20	HASSAN	110	MRSSH M-SS1	MRS MG_220	14:53	14:58	00:05	HAND TRIPPED
267	21-Oct-20	HASSAN	110	MRSSH M-SS2	MRS MG_220	14:58	15:07	00:09	HAND TRIPPED
268	21-Oct-20	HASSAN	220	HV2	MRS MG_220	10:56	14:46	03:50	LINE CLEAR AVAILED
269	21-Oct-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:52 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
270	21-Oct-20	HASSAN	220	MRSSH MVARAH I2	MRS MG_220	23:47 (21.10.2020)			LINE OPEN : LINE FAULT
271	21-Oct-20	HASSAN	220	MRSSH M-VARAH I2	MRS MG_220	00:44	22:11	21:27	LINE FAULT
272	21-Oct-20	HASSAN	220	VARAH I-KEMAR1	varahi_gen	8:52 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
273	21-Oct-20	HASSAN	220	VARAH I-SHIMOGA2	varahi_gen	23:47 (21.10.2020)			LINE OPEN : LINE FAULT
274	21-Oct-20	HASSAN	220	VARAH I-SHIMOGA2	varahi_gen	00:44	22:28	21:44	LINE FAULT
275	21-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
276	21-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	21:54 (18.10.2020)	14:58 (21.10.2020)	65:04hrs	LINE CHARGED
277	21-Oct-20	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	14:18	14:47	0:28	HAND TRIPPED
278	21-Oct-20	MYSURU	66	HANNUR-KOTHANUR	NO STATION EFFECTED	6:02	6:16	0:14	LINE FAULT
279	21-Oct-20	MYSURU	66	HARADANALLI (JAK)-LAXJEET	NO STATION EFFECTED	16:18	16:22	0:04	LINE FAULT
280	21-Oct-20	MYSURU	66	HOOTAGALLI-BOGADHI	NO STATION EFFECTED	14:04	14:06	0:02	HAND TRIPPED
281	21-Oct-20	MYSURU	66	HOOTAGALLI-FTS1	NO STATION EFFECTED	8:44	13:36	4:52	HAND TRIPPED
282	21-Oct-20	MYSURU	66	HV1	DATTAGALLY_66	10:43	12:07	1:23	LINE CLEAR AVAILED
283	21-Oct-20	MYSURU	66	HV2	BOMMALAPURA_66	14:10	14:32	0:21	HAND TRIPPED
284	21-Oct-20	MYSURU	66	HV2	DATTAGALLY_66	10:43	12:07	1:23	LINE CLEAR AVAILED
285	21-Oct-20	MYSURU	66	HV2	HANNUR_66	16:39	17:25	0:46	TRANSFORMER FAULT
286	21-Oct-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	13:12	13:19	0:07	LINE FAULT
287	21-Oct-20	MYSURU	66	TALAKADU-ADANI	NO STATION EFFECTED	17:59	18:17	0:18	LINE FAULT
288	21-Oct-20	TUMKUR	66	HIREGUNTANUR- CHITRADURGA	HIREGUNTANUR_66	9:52	10:19	0:26	LINE FAULT
289	21-Oct-20	TUMKUR	66	HIRIYUR 220KV- BEVINAHALLI	BEVINAHALLI_66	6:21	6:37	0:16	LINE FAULT
290	21-Oct-20	TUMKUR	66	HONNALLI 220kv- NALLUR	NALLUR_66,GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	6:01	6:09	0:08	LINE FAULT
291	21-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_6 6, BASAVAPATNA_66	10:32	10:42	0:09	LINE FAULT
292	21-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_6 6, BASAVAPATNA_66	13:28	14:23	0:55	LINE FAULT
293	21-Oct-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	6:15	6:20	0:05	LINE FAULT
294	21-Oct-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	6:25	6:34	0:08	LINE FAULT
295	21-Oct-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	8:51	16:30	7:38	LINE CLEAR AVAILED
296	21-Oct-20	TUMKUR	66	TR-1	BELADARA_66	11:24	11:33	0:08	HAND TRIPPED
297	21-Oct-20	TUMKUR	66	TR-1	KANCHIPURA_66	10:07	13:46	3:38	LINE CLEAR AVAILED
298	21-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	15:26	15:30	0:04	TRANSFORMER FAULT
299	21-Oct-20	TUMKUR	66	TR-1	SOKKE_66	8:55	10:36	1:40	LINE CLEAR AVAILED
300	21-Oct-20	TUMKUR	66	TR-2	HANAGAL_66	11:08	11:41	0:32	HAND TRIPPED
301	21-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	10:21	12:05	1:44	LINE CLEAR AVAILED
302	21-Oct-20	TUMKUR	110	BANDIHALLI- KB CROSS	BANDIHALLI_110	0:00	0:53	0:53	LINE FAULT
303	21-Oct-20	TUMKUR	110	KALLUR- NITTUR	KALLUR_110	15:17	17:09	1:52	LINE CLEAR AVAILED
304	21-Oct-20	TUMKUR	110	KB CROSS 220kv- MAYASANDRA	MAYASANDRA_110,TALKERE_110	15:37	15:48	0:11	HAND TRIPPED
305	21-Oct-20	TUMKUR	110	TR-1	BANDIHALLI_110	0:00	0:57	0:57	HAND TRIPPED
306	21-Oct-20	TUMKUR	110	TR-1	KALLUR_110	15:17	17:10	1:53	LINE CLEAR AVAILED
307	21-Oct-20	TUMKUR	110	TR-1	SAMPIGE_110	11:51	12:30	0:38	LINE CLEAR AVAILED
308	21-Oct-20	TUMKUR	110	TR-1	SAMPIGE_110	15:31	17:16	1:44	LINE CLEAR AVAILED
309	21-Oct-20	TUMKUR	110	TR-1(LV SIDE)	KBCROSS_220	15:37	16:45	1:07	HAND TRIPPED
310	21-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
311	21-Oct-20	TUMKUR	110	TR-2(HV SIDE)	KBCROSS_220	15:37	15:48	0:11	HAND TRIPPED
312	21-Oct-20	TUMKUR	110	TR-2(LV SIDE)	KBCROSS_220	15:37	15:45	0:07	HAND TRIPPED
313	21-Oct-20	TUMKUR	220	TR-1	KBCROSS_220	15:51	15:58	0:07	HAND TRIPPED
314	21-Oct-20	TUMKUR	220	TR-1	KBCROSS_220	16:04	16:44	0:40	HAND TRIPPED
315	22-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
316	22-Oct-20	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	10:15	10:36	0:21	TRANSFORMER FAULT
317	22-Oct-20	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	11:55	12:15	0:20	TRANSFORMER FAULT
318	22-Oct-20	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	11:55	12:16	0:21	TRANSFORMER FAULT
319	22-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
320	22-Oct-20	BAGALKOT	110	110/11KV,HV2	ITNAL_110	12:05	13:52	1:47	LINE CLEAR AVAILED
321	22-Oct-20	BAGALKOT	110	ATHANI220- SATTI	STATION NOT AFFECTED SATTI_110	15:56 (21.10.2020)	14:30 (22.10.2020)	22:34hrs	LINE FAULT
322	22-Oct-20	BAGALKOT	110	BAGALKOT220-LOKAPUR	LOKAPUR_110	12:35	12:40	0:05	LINE FAULT
323	22-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
324	22-Oct-20	BAGALKOT	110	CHIKKODI1- RAIBAG	STATION NOT AFFECTED RAIBAG_110	10:55	18:47	7:52	LINE FAULT
325	22-Oct-20	BAGALKOT	110	GADAG-BETAGERI	BETAGERI_110	20:36	21:43	1:07	LINE FAULT
326	22-Oct-20	BAGALKOT	110	GADAG-LAXMESHWAR	STATION NOT AFFECTED LAXMESHWAR_110	2:29	7:25	4:56	LINE FAULT
327	22-Oct-20	BAGALKOT	110	GHATAPRABHA-PG HUNSHYAL	PG HUNSHYAL_110	9:32	9:48	0:16	LINE FAULT
328	22-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)			LINE OPEN: LINE CLEAR AVAILED
329	22-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
330	22-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
331	22-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED HIDIKAL_110	5:15	17:11	11:56	HAND TRIPPED
332	22-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
333	22-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
334	22-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
335	22-Oct-20	BAGALKOT	110	RAIBAG1-ITNAL	STATION NOT AFFECTED ITNAL_110	5:23	5:37	0:14	HAND TRIPPED
336	22-Oct-20	BAGALKOT	110	RAIBAG2-ITNAL	STATION NOT AFFECTED ITNAL_110	5:23	17:15	11:52	HAND TRIPPED
337	22-Oct-20	BAGALKOT	110	VAJRAMATTI220- LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	3:26	10:10	6:44	LINE FAULT
338	22-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
339	22-Oct-20	BAGALKOT	220	BAGALKOT-GADAG1	STATION NOT AFFECTED BAGALKOT_220	2:08 (20.10.2020)	15:16 (22.10.2020)	61:08hrs	LOAD CURTAILMENT
340	22-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
341	22-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
342	22-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
343	22-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
344	22-Oct-20	BAGALKOT	220	DHONI1-GADAG	GADAG_220	19:48 (20.10.2020)	21:49 (22.10.2020)	50:01hrs	LINE FAULT
345	22-Oct-20	BAGALKOT	220	DHONI2-GADAG	STATION NOT AFFECTED GADAG_220	15:22	21:50	6:28	LINE CLEAR AVOIDED
346	22-Oct-20	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	22:42 (20.10.2020)			LOAD CURTAILMENT
347	22-Oct-20	BAGALKOT	220	GHATAPRABHA-KUDUCHI	GHATAPRABHA_220	7:19	10:09	2:50	LINE FAULT
348	22-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	20:46 (21.10.2020)			LINE OPEN : LINE FAULT
349	22-Oct-20	BAGALKOT	220	SIRSI- HUBLI1&2	SIRSI_220	16:45 (22.10.2020)			LOAD CURTAILMENT
350	22-Oct-20	BAGALKOT	220	SIRSI- HUBLI1&2	SIRSI_220	16:45 (22.10.2020)			LOAD CURTAILMENT
351	22-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
352	22-Oct-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	23:31	23:39	00:08	TRANSFORMER FAULT
353	22-Oct-20	BENGALURU	66	HV1	KONDASPURA	13:13	13:55	00:42	LINE CLEAR AVOIDED
354	22-Oct-20	BENGALURU	66	HV1	KONDASPURA	14:12	14:17	00:05	LINE CLEAR AVOIDED
355	22-Oct-20	BENGALURU	66	HV2	ANEKAL	12:30	12:35	00:05	LINE CLEAR AVOIDED
356	22-Oct-20	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	12:57	13:01	00:04	LINE CLEAR AVOIDED
357	22-Oct-20	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	15:15	15:19	00:04	LINE CLEAR AVOIDED
358	22-Oct-20	GULBARGA	66	HANASI-KUDLIGI	HANASI_66	15:24	15:48	00:24	LINE CLEAR AVOIDED
359	22-Oct-20	GULBARGA	66	HV1	HANASI_66	11:55	13:02	01:07	LINE CLEAR AVOIDED
360	22-Oct-20	GULBARGA	66	HV1	HANASI_66	14:49	15:20	00:31	LINE CLEAR AVOIDED
361	22-Oct-20	GULBARGA	66	HV1	HANASI_66	15:24	15:50	00:26	LINE CLEAR AVOIDED
362	22-Oct-20	GULBARGA	66	HV1	ITTAGI_220	11:18	11:23	00:05	TRANSFORMER FAULT
363	22-Oct-20	GULBARGA	110	GULBARGASOUTH- GULBARGAUNIVERSITY	GULBARGAUNIVERSITY_110	10:10(10.10.2020)			LINE OPEN : LINE FAULT
364	22-Oct-20	GULBARGA	110	HV1, HV2	VALKAMDINNI_110	07:30	08:25	00:55	LINE CLEAR AVOIDED
365	22-Oct-20	GULBARGA	110	HV2	SINDHANOOR_110	09:25	09:30	00:05	TRANSFORMER FAULT
366	22-Oct-20	GULBARGA	110	HV3	VALKAMDINNI_110	07:05	16:10	09:05	LINE CLEAR AVOIDED
367	22-Oct-20	GULBARGA	110	HV4	SHORAPUR_110	10:32	16:05	05:33	LINE CLEAR AVOIDED
368	22-Oct-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110	06:59	07:06	00:07	LINE FAULT
369	22-Oct-20	GULBARGA	110	KAPNOOR-MADIYAL	MADIYAL_110	06:44	06:51	00:07	LINE FAULT
370	22-Oct-20	GULBARGA	110	MALLAT-SIRWAR	SIRWAR_110	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
371	22-Oct-20	GULBARGA	110	NALWAR-SHAHAPUR	NALWAR_110	04:10	04:40	00:30	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
372	22-Oct-20	GULBARGA	110	NALWAR-SHAHBAD	NALWAR_110	03:10	03:20	00:10	LINE FAULT
373	22-Oct-20	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110, KONKAL_110	06:20	06:30	00:10	LINE FAULT
374	22-Oct-20	GULBARGA	110	SHAHPUR-KEMBHAVI1	KEMBHAVI_110,UGAR SUGAR IPP,HUNASGI_110,ASKI_110	09:37	11:02	01:25	LINE FAULT
375	22-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
376	22-Oct-20	GULBARGA	220	HV2	ITTAGI_220	08:41	11:54	03:13	LINE CLEAR AVAILED
377	22-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	01:07	07:36	06:29	LINE CLEAR AVAILED
378	22-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	14:25(22.10.2020)			LINE OPEN : LINE FAULT
379	22-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	18:30(19.10.2020)	14:16(22.10.2020)	67:46HRS	LINE FAULT
380	22-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	3:40(21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
381	22-Oct-20	GULBARGA	220	SHAHPUR-LINGASUGUR	SHAHAPUR_220	03:04	03:05	00:01	LINE FAULT
382	22-Oct-20	GULBARGA	220	SHAHPUR-RTPS1	SHAHPUR_220	04:02	05:18	01:16	LINE FAULT
383	22-Oct-20	GULBARGA	400	JSWL-GUTTUR	GUTTUR_400	18:11(22.10.2020)			LINE OPEN : LINE FAULT
384	22-Oct-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	11:04	14:37	03:33	LINE CLEAR AVAILED
385	22-Oct-20	HASSAN	66	HV1	CHIKMAGALUR	01:08	12:10	11:02	LINE CLEAR AVAILED
386	22-Oct-20	HASSAN	66	HV1	CHIKMAGALUR	12:58	13:07	00:09	LINE CLEAR AVAILED
387	22-Oct-20	HASSAN	66	HV2	CHIKMAGALUR	12:01	13:07	01:06	LINE CLEAR AVAILED
388	22-Oct-20	HASSAN	66	MALLIPA-SANIVARSANTE	MALLIPATNA_66	13:27	13:42	00:15	LINE FAULT
389	22-Oct-20	HASSAN	66	MRSSHM-HOLUR	MRSMSG_220	13:10	13:16	00:06	LINE FAULT
390	22-Oct-20	HASSAN	110	HV1	BANAVARA_110	10:47	17:10	06:23	LINE CLEAR AVAILED
391	22-Oct-20	HASSAN	110	HV1	NAVUNDA_110	07:35	08:28	00:53	TRANSFORMER FAULT
392	22-Oct-20	HASSAN	110	HV1	NAVUNDA_110	09:40	12:53	03:13	TRANSFORMER FAULT
393	22-Oct-20	HASSAN	110	HV2	KARAYA_110	11:18	12:15	00:57	LINE CLEAR AVAILED
394	22-Oct-20	HASSAN	110	HV2	KEMAR_220	10:58	16:38	05:40	LINE CLEAR AVAILED
395	22-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
396	22-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
397	22-Oct-20	HASSAN	110	LV1	KEMAR_220	10:31	10:35	00:04	HAND TRIPPED
398	22-Oct-20	HASSAN	110	LV2	KEMAR_220	10:42	10:45	00:03	HAND TRIPPED
399	22-Oct-20	HASSAN	110	LV3	KEMAR_220	10:38	10:40	00:02	HAND TRIPPED
400	22-Oct-20	HASSAN	110	MOODAB-KEMAR	MOODABIDRE_110	11:01	11:14	00:13	HAND TRIPPED
401	22-Oct-20	HASSAN	220	HV1	KEMAR_220	10:31	10:35	00:04	HAND TRIPPED
402	22-Oct-20	HASSAN	220	HV2	KEMAR_220	10:42	10:45	00:03	HAND TRIPPED
403	22-Oct-20	HASSAN	220	HV3	KEMAR_220	10:38	10:40	00:02	HAND TRIPPED
404	22-Oct-20	HASSAN	220	KADUR-SHIMOGA	KADUR_220	16:40 (22.10.2020)			LINE OPEN : LINE FAULT
405	22-Oct-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:52 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
406	22-Oct-20	HASSAN	220	MRSSHM-KADUR	MRSMSG_220	16:40 (22.10.2020)			LINE OPEN : LINE FAULT
407	22-Oct-20	HASSAN	220	MRSSHM-VARAH12	MRSMSG_220	23:47 (21.10.2020)	10:42 (22.10.2020)	10:55hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
408	22-Oct-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:52 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
409	22-Oct-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	23:47 (21.10.2020)	10:42(22.10.2020)	10:55hrs	LINE CHARGED
410	22-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
411	22-Oct-20	MYSURU	66	HOOTAGALLI-DATAGALLI	NO STATION EFFECTED	16:34	18:16	1:41	HAND TRIPPED
412	22-Oct-20	MYSURU	66	HOOTAGALLI-FTS 1	NO STATION EFFECTED	10:42	12:59	2:16	HAND TRIPPED
413	22-Oct-20	MYSURU	66	HV1	BETTADHAPURA_66	15:10	15:50	0:40	LINE CLEAR AVAILED
414	22-Oct-20	MYSURU	66	HV1	MALAVALLI_66	18:16	18:55	0:39	LINE CLEAR AVAILED
415	22-Oct-20	MYSURU	66	HV2	MALAVALLI_66	18:16	19:02	0:46	LINE CLEAR AVAILED
416	22-Oct-20	MYSURU	66	HV2	SANTHEMARAHALLI_66	11:51	12:06	0:14	LINE CLEAR AVAILED
417	22-Oct-20	MYSURU	66	HV4	KUSHALNAGARA_220	3:41	3:49	0:08	HAND TRIPPED
418	22-Oct-20	MYSURU	66	HV4	KUSHALNAGARA_220	15:13	16:35	1:21	LINE CLEAR AVAILED
419	22-Oct-20	MYSURU	66	KABHALLY-CLEAN SOLAR	NO STATION EFFECTED	7:17	7:33	0:15	LINE FAULT
420	22-Oct-20	MYSURU	66	KUSHALNAGARA 220-HARANGI	NO STATION EFFECTED	3:40	3:52	0:12	HAND TRIPPED
421	22-Oct-20	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATION EFFECTED	14:20	16:13	1:53	NFBC ISSUED
422	22-Oct-20	MYSURU	66	RK NAGARA-MANTAGALLY	RKNAGARA_66 MANDAKALLI_66 DATTAGALLI	12:43	16:29	3:46	LINE FAULT
423	22-Oct-20	MYSURU	66	SANIVARSANTHE-YESSLUR	NO STATION EFFECTED	13:26	13:55	0:28	LINE FAULT
424	22-Oct-20	MYSURU	66	TUBINKERE-NAGAMANGALA 2	SHIVALLY_66	10:37	10:49	0:12	LINE FAULT
425	22-Oct-20	MYSURU	66	VAJMANGALA-KADKOLA 1	AYRALLI_66 MARADIHUNDI_66	18:05	18:14	0:09	LINE FAULT
426	22-Oct-20	MYSURU	220	HV2	KUSHALNAGARA_220	3:06	3:44	0:38	TRANSFORMER FAULT
427	22-Oct-20	MYSURU	220	HV2	TUBINAKERE_220	10:51	16:28	5:36	LINE CLEAR AVAILED
428	22-Oct-20	TUMKUR	66	BANUVALLI- NANDUGUDI	BANUVALLI_66	9:25	9:43	0:18	LINE FAULT
429	22-Oct-20	TUMKUR	66	HIREHALLI - BADDIHALLI	HIREHALLY_66	14:54	17:38	2:43	LINE CLEAR AVAILED
430	22-Oct-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	17:51	17:55	0:04	LINE FAULT
431	22-Oct-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	13:27	13:53	0:26	LINE FAULT
432	22-Oct-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	15:36	15:48	0:12	LINE FAULT
433	22-Oct-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	22:27	22:35	0:07	LINE FAULT
434	22-Oct-20	TUMKUR	66	NEELAGUNDA 220kv- PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	22:45	22:55	0:10	LINE FAULT
435	22-Oct-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	6:45	6:50	0:05	LINE FAULT
436	22-Oct-20	TUMKUR	66	SOKKE-JAGLUR	JAGLUR	18:54	19:41	0:47	LINE FAULT
437	22-Oct-20	TUMKUR	66	TR-1	GOWRASAMUDRA_66	20:23	20:45	0:21	TRANSFORMER FAULT
438	22-Oct-20	TUMKUR	66	TR-1	HANAGAL_66	12:18	14:30	2:12	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
439	22-Oct-20	TUMKUR	66	TR-1	HOLALKERE_66	15:57	16:13	0:15	LINE CLEAR AVAILED
440	22-Oct-20	TUMKUR	66	TR-1	KUNIGAL_66	10:31	13:47	3:15	LINE CLEAR AVAILED
441	22-Oct-20	TUMKUR	66	TR-1	MATHOD_66	6:19	6:34	0:14	TRANSFORMER FAULT
442	22-Oct-20	TUMKUR	66	TR-1	MELKOTE_66	12:12	13:04	0:52	LINE CLEAR AVAILED
443	22-Oct-20	TUMKUR	66	TR-1	SHYLAPURA_66	20:05	20:23	0:17	TRANSFORMER FAULT
444	22-Oct-20	TUMKUR	66	TR-2	HOLALKERE_66	15:52	16:13	0:20	LINE CLEAR AVAILED
445	22-Oct-20	TUMKUR	66	TR-2	TELAGI_66	9:00	9:03	0:02	TRANSFORMER FAULT
446	22-Oct-20	TUMKUR	110	HUNSEGHATTA- K B CROSS	HUNSEGHATTA_110	9:00	9:27	0:26	LINE FAULT
447	22-Oct-20	TUMKUR	110	BANDIHALLI- TIPTUR	TIPTUR_110, HONNAVALLI_110	15:17	15:24	0:07	HAND TRIPPED
448	22-Oct-20	TUMKUR	110	HONNAVALLI 110- KADUR	HONNAVALLI_110	9:00	9:13	0:13	HAND TRIPPED
449	22-Oct-20	TUMKUR	110	TR-1	DODDAGUNI_110	15:26	17:47	2:21	LINE CLEAR AVAILED
450	22-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
451	22-Oct-20	TUMKUR	110	TR-2	CHIKKANAYAKANAHALLI_110	13:22	13:52	0:29	TRANSFORMER FAULT
452	23-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
453	23-Oct-20	BAGALKOT	110	110/11KV, HV1	TODALABAGI_110	11:35	14:10	2:35	HAND TRIPPED
454	23-Oct-20	BAGALKOT	110	110/11KV, HV1	RAIBAG_110	16:35	16:42	0:07	LINE CLEAR AVAILED
455	23-Oct-20	BAGALKOT	110	110/11KV, HV1	MUNAVALLI_110	16:07	17:39	1:32	LINE CLEAR AVAILED
456	23-Oct-20	BAGALKOT	110	110/11KV, HV2	RAIBAG_110	16:35	17:01	0:26	LINE CLEAR AVAILED
457	23-Oct-20	BAGALKOT	110	110/11KV, HV2	RAIBAG_110	17:05	17:20	0:15	LINE CLEAR AVAILED
458	23-Oct-20	BAGALKOT	110	110/11KV, HV2	MUNAVALLI_110	15:00	16:00	1:00	LINE CLEAR AVAILED
459	23-Oct-20	BAGALKOT	110	110/11KV, HV3	RAIBAG_110	16:17	17:35	1:18	LINE CLEAR AVAILED
460	23-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
461	23-Oct-20	BAGALKOT	110	110/11KV,HV1&2	BYADAGI_110	20:13	20:29	0:16	TRANSFORMER FAULT
462	23-Oct-20	BAGALKOT	110	110/33KV, HV3	TODALABAGI_110, HIREPADASALAGI_33, BIDARI_33, JRK SOLAR IPP_33	15:58	17:02	1:04	HAND TRIPPED
463	23-Oct-20	BAGALKOT	110	110/33KV, HV3	MUNAVALLI_110, MUNAVALLI/HULIKATTI_33, MALUR_33	12:35	14:00	1:25	LINE CLEAR AVAILED
464	23-Oct-20	BAGALKOT	110	220/110, LV2	STATION NOT AFFECTED MK HUBLI220	21:41 (23.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
465	23-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
466	23-Oct-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	16:24	16:49	0:25	HAND TRIPPED
467	23-Oct-20	BAGALKOT	110	BIDNAL220-NAVALGUND	NAVALGUND_110	20:58	21:24	0:26	HAND TRIPPED
468	23-Oct-20	BAGALKOT	110	GADAG-BETAGERI	STATION NOT AFFECTED BETAGERI_110	16:44 (23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
469	23-Oct-20	BAGALKOT	110	GADAG-BETAGERI	STATION NOT AFFECTED GADAG_220	16:19 (23.10.2020)			LINE OPEN : LINE FAULT
470	23-Oct-20	BAGALKOT	110	GHATAPRABHA220- MANTUR(MUDALAGI)	MANTUR_110	17:19	19:04	1:45	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
471	23-Oct-20	BAGALKOT	110	GHATAPRABHA220-P. G HUNSHYAL	P G HUNSHYAL_110	19:33	19:52	0:19	LINE FAULT
472	23-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	17:05 (04.10.2020)	12:40 (23.10.2020)	451:35hrs	LINE CHARGED
473	23-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
474	23-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
475	23-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
476	23-Oct-20	BAGALKOT	110	HAVERI220-BYADAGI	STATION NOT AFFECTED BYADAGI_110	18:07	22:30	4:23	LINE FAULT
477	23-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
478	23-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
479	23-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
480	23-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
481	23-Oct-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD_110	12:00	16:47	4:47	HAND TRIPPED
482	23-Oct-20	BAGALKOT	110	NAREGAL-BETAGERI	STATION NOT AFFECTED BETAGERI_110	16:30	18:16	1:46	LOAD CURTAILMENT
483	23-Oct-20	BAGALKOT	110	NAVALGUND-KONNUR(BIDNAL)	KONNUR_110	20:59	21:25	0:26	HAND TRIPPED
484	23-Oct-20	BAGALKOT	110	PGHUNSYAL-GHATAPRABHA	PGHUNASHYAL_110	19:33	19:58	0:25	LINE FAULT
485	23-Oct-20	BAGALKOT	110	PGHUNSYAL-MUDALGI(NAGANUR)	MUDALGI(NAGANUR)_110	19:40	19:58	0:18	HAND TRIPPED
486	23-Oct-20	BAGALKOT	110	PGHUNSYAL-SATISHSUGARS	SATISHSUGARS_110	19:40	20:00	0:20	HAND TRIPPED
487	23-Oct-20	BAGALKOT	110	RANEBENNUR-BYADAGI	BYADAGI_110	20:13	20:22	0:09	LINE FAULT
488	23-Oct-20	BAGALKOT	110	RANEBENNUR-TUMMINAKATTI	TUMMINAKATTI_110	6:52	7:04	0:12	LINE FAULT
489	23-Oct-20	BAGALKOT	110	SANKESHWER-HIRASUGARS1&2	HIRASUGARS IPP_110	11:50	11:55	0:05	HAND TRIPPED
490	23-Oct-20	BAGALKOT	110	SANKESHWER-HUKKERI	HUKKERI_110	11:42	11:47	0:05	HAND TRIPPED
491	23-Oct-20	BAGALKOT	110	SHIROL-PRBLGSH/JAMAKHANDI	PRBLGSH/JAMAKHANDI_110	16:54	17:18	0:24	LINE FAULT
492	23-Oct-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN: LINE CLEAR AVAILED
493	23-Oct-20	BAGALKOT	220	ADPH1-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	12:27 (22.10.2020)	19:11 (23.10.2020)	30:44hrs	LINE FAULT
494	23-Oct-20	BAGALKOT	220	ADPH2-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	12:27 (22.10.2020)	19:11 (23.10.2020)	30:44hrs	LINE FAULT
495	23-Oct-20	BAGALKOT	220	AMBEWADI-PONDA(XELDOM)1	STATION NOT AFFECTED AMBEWADI_220	6:07	11:05	4:58	LINE CLEAR AVAILED
496	23-Oct-20	BAGALKOT	220	AMBEWADI-PONDA(XELDOM)1	STATION NOT AFFECTED AMBEWADI_220	12:13	12:55	0:42	LINE FAULT
497	23-Oct-20	BAGALKOT	220	AMBEWADI-PONDA(XELDOM)1	STATION NOT AFFECTED AMEWADI_220	13:25	14:40	1:15	LINE FAULT
498	23-Oct-20	BAGALKOT	220	BAGALKOT-ALAMATTI1&2	STATION NOT AFFECTED BAGALKOT_220	14:43	19:05	4:22	LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
499	23-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
500	23-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
501	23-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
502	23-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
503	23-Oct-20	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	22:42 (20.10.2020)			LOAD CURTAILMENT
504	23-Oct-20	BAGALKOT	220	HUBLI-NARENDRA2	STATION NOT AFFECTED NARENDRA_220	12:38	16:28	3:50	LINE FAULT
505	23-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	20:46 (21.10.2020)			LINE OPEN : LINE FAULT
506	23-Oct-20	BAGALKOT	220	NARENDRA-HUBLI2	STATION NOT AFFECTED NARENDRA_220	12:38	16:27	3:49	LINE FAULT
507	23-Oct-20	BAGALKOT	220	SIRSI- HUBLI1	SIRSI_220	16:45 (22.10.2020)	5:03 (23.10.2020)	12:18hrs	LOAD CURTAILMENT
508	23-Oct-20	BAGALKOT	220	SIRSI- HUBLI2	SIRSI_220	16:45 (22.10.2020)	5:03 (23.10.2020)	12:18hrs	LOAD CURTAILMENT
509	23-Oct-20	BENGALURU	66	ATTIBELE - ANEKAL	ATTIBELE	11:55	12:10	00:15	LOAD CHANGE OVER
510	23-Oct-20	BENGALURU	66	ATTIBELE - SARJAPURA 220	ATTIBELE	22:10	22:15	00:05	LOAD CHANGE OVER
511	23-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
512	23-Oct-20	BENGALURU	66	ELECTRONIC CITY - ELECTRONIC CITY P2 S1	ELECTRONIC CITY, INFOSYS (EHT)	11:57	12:04	00:07	LOAD CHANGE OVER
513	23-Oct-20	BENGALURU	66	HOSKOTE 220 - BIAL BEGUR	NO STATION AFFECTED	16:28	18:01	01:32	LINE FAULT
514	23-Oct-20	BENGALURU	66	HOSKOTE 220 - BIAL(EHT)	BIAL(EHT)	16:28	18:01	01:33	LINE FAULT
515	23-Oct-20	BENGALURU	66	HOSKOTE 220 - BOODIGERE	NO STATION AFFECTED	16:28	17:49	01:20	LINE FAULT
516	23-Oct-20	BENGALURU	66	HOSKOTE 220 - BUDIGERE	NO STATION AFFECTED	16:28	17:49	01:21	LINE FAULT
517	23-Oct-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	00:33	00:38	00:05	TRANSFORMER FAULT
518	23-Oct-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	06:29	06:34	00:05	TRANSFORMER FAULT
519	23-Oct-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	09:10	09:16	00:06	TRANSFORMER FAULT
520	23-Oct-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	10:56	11:19	00:23	LINE CLEAR AVALIED
521	23-Oct-20	BENGALURU	66	HV2	HANUMANTHAGARA	18:50	19:00	00:10	TRANSFORMER FAULT
522	23-Oct-20	BENGALURU	66	HV2	SADLI	15:38	17:36	01:57	LINE CLEAR AVALIED
523	23-Oct-20	BENGALURU	66	HV2	MALLASANDRA	13:14	14:02	00:47	LINE CLEAR AVALIED
524	23-Oct-20	BENGALURU	66	KOLAR 220 - BANGARPET 2	BANGARPET	21:35	22:02	00:27	MAIN SUPPLY FAILURE
525	23-Oct-20	BENGALURU	66	KOLAR 220 - MULBAGAL	AVANI, MULBAGAL	21:35	22:02	00:27	MAIN SUPPLY FAILURE
526	23-Oct-20	BENGALURU	66	KOLAR 220 - NANGALI	KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI	21:35	22:02	00:27	MAIN SUPPLY FAILURE
527	23-Oct-20	BENGALURU	66	KOLAR 220 - PGCIL	PGCIL, SUGUTUR, SM MANGALA	21:35	22:02	00:27	MAIN SUPPLY FAILURE
528	23-Oct-20	BENGALURU	66	KOLAR 220 - THAYLUR	THAYALUR, TAMAKA, NG HULKUR, MALLANAYAKANAHALLI	21:35	22:02	00:27	MAIN SUPPLY FAILURE
529	23-Oct-20	BENGALURU	66	KOLAR 220 - VEMGAL	VEMGAL, KYALANUR	21:35	22:02	00:27	MAIN SUPPLY FAILURE

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
530	23-Oct-20	BENGALURU	66	KOLAR 220 - VOKKALERI 2	NARASAPURA	21:35	22:02	00:27	MAIN SUPPLY FAILURE
531	23-Oct-20	BENGALURU	66	MALUR 220 - HOSKOTE 1	MALUR I/A, STAR PANEL (EHT)	21:35	22:12	00:37	MAIN SUPPLY FAILURE
532	23-Oct-20	BENGALURU	66	MALUR 220 - HOSKOTE 2	JADIGENAHALLI	21:35	22:12	00:37	MAIN SUPPLY FAILURE
533	23-Oct-20	BENGALURU	66	MALUR 220 - KGF 1	KGF, TEKAL, BUDIKOTE, KAMASAMUDRA	21:35	22:11	00:36	MAIN SUPPLY FAILURE
534	23-Oct-20	BENGALURU	66	MALUR 220 - KGF 2	ANDERSONPET, BEML (EHT), KYASAMBALLI, DODDAKARI	21:35	22:11	00:36	MAIN SUPPLY FAILURE
535	23-Oct-20	BENGALURU	66	MALUR 220 - MAASTHI	MAASTHI, DEVANGONDHI, LAKKUR	21:35	22:10	00:35	MAIN SUPPLY FAILURE
536	23-Oct-20	BENGALURU	66	MALUR 220 - MALUR 66	MALUR 66	21:35	22:10	00:35	MAIN SUPPLY FAILURE
537	23-Oct-20	BENGALURU	66	SARJAPURA 220 - ATTIBELE	ATTIBELE	21:35	22:15	00:40	MAIN SUPPLY FAILURE
538	23-Oct-20	BENGALURU	66	SARJAPURA 220 - CHANDAPURA	CHANDAPURA	21:35	22:12	00:37	MAIN SUPPLY FAILURE
539	23-Oct-20	BENGALURU	66	SARJAPURA 220 - DOMMASANDRA	DOMMASANDRA	21:35	22:13	00:38	MAIN SUPPLY FAILURE
540	23-Oct-20	BENGALURU	66	TK HALLI 220 - HAROHALLI 2	VR DODDI, GURUVINAPURA	06:08	06:24	00:16	LINE FAULT
541	23-Oct-20	BENGALURU	66	VIKAS TECH PARK 220 - EMBASSY TECH VILLAGE	EMBASSY TECH VILLAGE	21:35	22:06	00:31	MAIN SUPPLY FAILURE
542	23-Oct-20	BENGALURU	66	VIKAS TECH PARK 220 - GLOBAL TECH PARK	GLOBAL TECH PARK	21:35	22:06	00:31	MAIN SUPPLY FAILURE
543	23-Oct-20	BENGALURU	66	VIKAS TECH PARK 220 - PRIMAL PROJECT	PRIMAL PROJECT	21:35	22:06	00:31	MAIN SUPPLY FAILURE
544	23-Oct-20	BENGALURU	66	VIKAS TECH PARK 220 - RMZ	RMZ	21:35	22:06	00:31	MAIN SUPPLY FAILURE
545	23-Oct-20	BENGALURU	220	HV1	MALUR 220	21:35	22:06	00:31	MAIN SUPPLY FAILURE
546	23-Oct-20	BENGALURU	220	HV2	MALUR 220	21:35	22:06	00:31	MAIN SUPPLY FAILURE
547	23-Oct-20	BENGALURU	220	SARJAPURA 220 - MALUR 220	SARJAPURA 220	21:35	22:09	00:34	MAIN SUPPLY FAILURE
548	23-Oct-20	GULBARGA	110	GULBARGASOUTH- GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN : LINE FAULT
549	23-Oct-20	GULBARGA	110	HALBURGA-BHALKI	BHALKI_110, ;ADHA_110, MGSSK IPP, BHALKISUGARS IPP	06:56	07:08	00:12	LINE FAULT
550	23-Oct-20	GULBARGA	110	HV1	KUDLIGI_66	14:12	16:06	01:54	LINE CLEAR AVOIDED
551	23-Oct-20	GULBARGA	110	HV1	KUDLIGI_66	11:54	12:15	00:21	LINE CLEAR AVOIDED
552	23-Oct-20	GULBARGA	110	HV1	KUDLIGI_110	12:00	12:05	00:05	TRANSFORMER FAULT
553	23-Oct-20	GULBARGA	110	HV1	KUDLIGI_110	14:20	16:00	01:40	LINE CLEAR AVOIDED
554	23-Oct-20	GULBARGA	110	HV1	KUDLIGI_110	16:10	16:15	00:05	TRANSFORMER FAULT
555	23-Oct-20	GULBARGA	110	HV1	KUDLIGI_110	17:10	17:15	00:05	TRANSFORMER FAULT
556	23-Oct-20	GULBARGA	110	HV2	DEODURGA_110	22:10:00	22:20	00:10	TRANSFORMER FAULT
557	23-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVOIDED
558	23-Oct-20	GULBARGA	110	YELBURGA-PARAMPUJYASLR_IPP	YELBURGA_110	05:40	05:50	00:10	LINE FAULT
559	23-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
560	23-Oct-20	GULBARGA	220	KAPNOOR-HUMNABAD1	KAPNOOR_220	01:52	08:17	06:25	LINE CLEAR AVOIDED
561	23-Oct-20	GULBARGA	220	LINGAPUR-GADAG2	ARESS STEELS_IPP	15:43			LINE OPEN : LINE FAULT
562	23-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	14:25(22.10.2020)	12:50(23/10/2020)	22:25 HRS	LINE FAULT
563	23-Oct-20	GULBARGA	220	SHAHAPUR-SEDAM	SHAHAPUR_220	14:25(22.10.2020)	12:50(23.10.2020)	22:25 HRS	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
564	23-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	3:40(21.10.2020)	9:29(23/10/2020)	57:49HRS	LINE CHARGED
565	23-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD	SHAHABAD_220	3:40(21.10.2020)	9:29(23.10.2020)	53:49HRS	LINE CHARGED
566	23-Oct-20	GULBARGA	220	SHAHAPUR-SHAHABAD_220	SHAHABAD_220	23:54(23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
567	23-Oct-20	GULBARGA	400	JSWL-GUTTUR	GUTTUR_400	18:11(22.10.2020)			LINE OPEN : LINE FAULT
568	23-Oct-20	HASSAN	66	ALDUR-BALEHONNUR	ALDUR_66	15:42	16:00	00:18	LINE FAULT
569	23-Oct-20	HASSAN	66	HV2	SINGAPURA_66	01:40	01:56	00:16	TRANSFORMER FAULT
570	23-Oct-20	HASSAN	66	TAVAREC-HONNALLI	TAVARECHATNAHALLY_66	06:24	06:50	00:26	LINE FAULT
571	23-Oct-20	HASSAN	110	HV1	ESSUR_110	10:38	13:52	03:14	LINE CLEAR AVAILED
572	23-Oct-20	HASSAN	110	HV1	HOSANAGADI_110	10:17	10:45	00:28	LINE CLEAR AVAILED
573	23-Oct-20	HASSAN	110	HV2	ESSUR_110	10:38	13:51	03:13	LINE CLEAR AVAILED
574	23-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
575	23-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
576	23-Oct-20	HASSAN	110	MRSSHM-MPM	MRS MG_220	11:08	12:39	01:31	LINE FAULT
577	23-Oct-20	HASSAN	220	KADUR-SHIMOGA	KADUR_220	16:40 (22.10.2020)	8:24(23.10.2020)	15:44hrs	LINE CHARGED
578	23-Oct-20	HASSAN	220	KEMAR-Varahi1	KEMAR_220	8:52 (21.10.2020)	13:09(23.10.2020)	28:17hrs	NFBC ISSUED
579	23-Oct-20	HASSAN	220	MRSSHM-KADUR	MRS MG_220	16:40 (22.10.2020)	8:24(23.10.2020)	15:44hrs	LINE CHARGED
580	23-Oct-20	HASSAN	220	MRSSHM-VARAH12	MRS MG_220	11:46	20:40	08:54	LINE CLEAR AVAILED
581	23-Oct-20	HASSAN	220	VARAHI-KEMAR1	varahi_gen	8:52 (21.10.2020)	13:11(23.10.2020)	28:19hrs	LINE CHARGED
582	23-Oct-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	11:46	20:40	08:54	LINE CLEAR AVAILED
583	23-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
584	23-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:27(23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
585	23-Oct-20	MYSURU	66	HV1	HADLI_66	11:02	11:16	0:13	HAND TRIPPED
586	23-Oct-20	MYSURU	66	KUSHALNAGARA 220-SUNTIKOPPA	NO STATION EFFECTED	12:43	12:54	0:11	LINE FAULT
587	23-Oct-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	12:35	13:52	1:16	LINE CLEAR AVAILED
588	23-Oct-20	MYSURU	66	MYSORE SOUTH-KADAKOLA	NO STATION EFFECTED	11:12	12:15	1:02	LINE CLEAR AVAILED
589	23-Oct-20	MYSURU	220	HV1	TUBINAKERE_220	9:35	14:49	5:14	LINE CLEAR AVAILED
590	23-Oct-20	TUMKUR	66	HOLALKERE- RAMGIRI 1	HOLALKERE_66	7:35	8:09	0:33	LINE FAULT
591	23-Oct-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	10:29	10:42	0:13	LINE FAULT
592	23-Oct-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	12:40	12:50	0:10	LINE FAULT
593	23-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	8:33	8:36	0:03	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
594	23-Oct-20	TUMKUR	66	KUKKAWADA- SRS DAVANGERE	KUKKAWADA_66	8:18	8:33	0:14	LINE FAULT
595	23-Oct-20	TUMKUR	66	MADHUGIRI 220kV- KORATAGERE 2	KORATAGERE_66, CHIKKATOTLUKERE_66, BELADARA_66	1:22	1:37	0:15	LINE FAULT
596	23-Oct-20	TUMKUR	66	MATHOD- PANCHANAHALLI	PANCHANAHALLI_66, GARAGA_66	18:50	18:57	0:06	LINE FAULT
597	23-Oct-20	TUMKUR	66	TR-1	MATHOD_66	6:27	6:32	0:05	TRANSFORMER FAULT
598	23-Oct-20	TUMKUR	66	TR-1	MATHOD_66	6:44	6:49	0:04	TRANSFORMER FAULT
599	23-Oct-20	TUMKUR	66	TR-1	MATHOD_66	11:31	11:42	0:10	TRANSFORMER FAULT
600	23-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	14:51	14:53	0:01	TRANSFORMER FAULT
601	23-Oct-20	TUMKUR	66	TR-1	PAVAGADA_220	15:20	15:22	0:01	LINE CLEAR AVAILED
602	23-Oct-20	TUMKUR	66	TR-2	HOLALKERE_66	11:35	12:43	1:08	LINE CLEAR AVAILED
603	23-Oct-20	TUMKUR	66	TR-2	MANGALWADA_66	4:05	4:09	0:03	TRANSFORMER FAULT
604	23-Oct-20	TUMKUR	66	TR-2	MANGALWADA_66	10:22	14:16	3:53	LINE CLEAR AVAILED
605	23-Oct-20	TUMKUR	66	TR-2(LV SIDE)	ANTHRASANAHALLI_220	6:38	6:40	0:01	TRANSFORMER FAULT
606	23-Oct-20	TUMKUR	110	TR-1	KALLUR_110	13:29	15:40	2:11	LINE CLEAR AVAILED
607	23-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
608	23-Oct-20	TUMKUR	220	ANTHRASANAHALLI 220KV- VASANTHNARASAPURA 2	ANTHRASANAHALLI_220	6:38	11:52	5:13	LINE FAULT
609	23-Oct-20	TUMKUR	220	TR-2(HV SIDE)	ANTHRASANAHALLI_220	6:38	6:40	0:01	TRANSFORMER FAULT
610	24-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
611	24-Oct-20	BAGALKOT	110	110/11KV, HV1	KUDALSANGAM_110	12:30	13:33	1:03	TRANSFORMER FAULT
612	24-Oct-20	BAGALKOT	110	110/11KV, HV1	SADALAGA_110	17:39	18:00	0:21	LINE CLEAR AVAILED
613	24-Oct-20	BAGALKOT	110	110/11KV, HV1	NANADI_110	12:52	14:10	1:18	LINE CLEAR AVAILED
614	24-Oct-20	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	12:37	13:27	0:50	LINE CLEAR AVAILED
615	24-Oct-20	BAGALKOT	110	110/11KV, HV2	NANADI_110	10:53	12:46	1:53	LINE CLEAR AVAILED
616	24-Oct-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MRUTYUNJAYNAGAR_110	17:48 (24.10.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
617	24-Oct-20	BAGALKOT	110	110/11KV, HV4	SADALAGA_110	16:57	17:29	0:32	LINE CLEAR AVAILED
618	24-Oct-20	BAGALKOT	110	110/11KV, HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
619	24-Oct-20	BAGALKOT	110	110/33KV, HV2	SADALAGA_110, BHOJ_33	16:08	16:45	0:37	LINE CLEAR AVAILED
620	24-Oct-20	BAGALKOT	110	110/33KV, HV4	LAKAMANHALLI_110	21:23	21:27	0:04	TRANSFORMER FAULT
621	24-Oct-20	BAGALKOT	110	220/110, LV2	STATION NOT AFFECTED MK HUBLI220	21:41 (23.10.2020)	9:25 (24.10.2020)	11:44	LOAD CURTAILMENT
622	24-Oct-20	BAGALKOT	110	220/110, LV2	STATION NOT AFFECTED MK HUBLI220	23:34 (24.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
623	24-Oct-20	BAGALKOT	110	BAGALKOT-LOKAPUR1	LOKAPUR_110	5:49	5:59	0:10	LINE FAULT
624	24-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
625	24-Oct-20	BAGALKOT	110	BETAGERI-NAREGAL	NAREGAL_110	12:18	18:26	6:08	LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
626	24-Oct-20	BAGALKOT	110	BIJAPUR220-ENERCON	STATION NOT AFFECTEDBIJAPUR_220	9:51	9:58	0:07	LINE FAULT
627	24-Oct-20	BAGALKOT	110	GADAG-BETAGERI	STATION NOT AFFECTED BETAGERI_110	16:44 (23.10.2020)	12:17 (24.10.2020)	19:33hrs	LINE CHARGED
628	24-Oct-20	BAGALKOT	110	GADAG-BETAGERI	STATION NOT AFFECTED GADAG_220	16:19 (23.10.2020)	12:18 (24.10.2020)	19:59hrs	LINE FAULT
629	24-Oct-20	BAGALKOT	110	GAMESHA WIND- KULIGOD	KULIGOD_110	13:15	13:31	0:16	HAND TRIPPED
630	24-Oct-20	BAGALKOT	110	GAMESHA WIND- KULIGOD	KULIGOD_110	14:46	15:20	0:34	HAND TRIPPED
631	24-Oct-20	BAGALKOT	110	GHATAPRABHA220-P. G HUNSHYAL	STATION NOT AFFECTED P G HUNSHYAL_110	13:19	15:14	1:55	NFBC ISSUED
632	24-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
633	24-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
634	24-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
635	24-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
636	24-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
637	24-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
638	24-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
639	24-Oct-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD_110	18:26 (24.10.2020)			LINE OPEN: LINE CLEAR AVAILED
640	24-Oct-20	BAGALKOT	110	PGHUNSYAL-GHATAPRABHA	PGHUNASHYAL_110	13:18	15:21	2:03	LOAD CHANGE OVER
641	24-Oct-20	BAGALKOT	110	PGHUNSYAL-MUDALGI(NAGANUR)	MUDALGI(NAGANUR)_110	14:57	15:18	0:21	LOAD CHANGE OVER
642	24-Oct-20	BAGALKOT	110	PGHUNSYAL-SATISHSUGARS	SATISHSUGARS_110	13:08	13:31	0:23	LOAD CHANGE OVER
643	24-Oct-20	BAGALKOT	220	220/110KV, LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
644	24-Oct-20	BAGALKOT	220	ADPH1-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	12:24	12:50	0:26	LINE FAULT
645	24-Oct-20	BAGALKOT	220	BAGALKOT-HIREBENDIGERI2	STATION NOT AFFECTED BAGALKOT_220	5:48	14:16	8:28	LINE FAULT
646	24-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
647	24-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
648	24-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
649	24-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
650	24-Oct-20	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	22:42 (20.10.2020)			LOAD CURTAILMENT
651	24-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	20:46 (21.10.2020)			LINE OPEN : LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
652	24-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
653	24-Oct-20	BENGALURU	66	CHIKKABALLAPURA I/A - DB PURA 1	CHIKKABALLAPURA I/A	17:36	17:50	00:14	LINE FAULT
654	24-Oct-20	BENGALURU	66	HV2	ELECTRONIC CITY PH-2 SEC-2	00:04	00:09	00:05	TRANSFORMER FAULT
655	24-Oct-20	BENGALURU	66	HV2	KHODAYS 220	08:44	08:50	00:06	TRANSFORMER FAULT
656	24-Oct-20	BENGALURU	66	HV2	LEELA VENTURE	11:36	13:07	01:31	LINE CLEAR AVOIDED
657	24-Oct-20	BENGALURU	66	KODIGENAHALLI - BYADRAHALLI	KODIGENAHALLI,TAVAREKERE	13:51	14:14	00:23	LINE FAULT
658	24-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	06:43	06:53	00:10	LINE FAULT
659	24-Oct-20	BENGALURU	66	KOTHIPURA - RAMANAGARA	RAMANAGARA, BEVOOR, SANKALGERE, DASHAVARA	07:14	07:20	00:06	LINE FAULT
660	24-Oct-20	BENGALURU	66	MITTEMARI 220 - BAGEPALLI 2	BAGEPALLI	03:27	03:36	00:08	LINE FAULT
661	24-Oct-20	BENGALURU	66	TK HALLI 220 - AKKURMOLE	AKKURMOLE, IGGALUR, K HONALGERE	06:09	06:20	00:11	LINE FAULT
662	24-Oct-20	GULBARGA	110	GULBARGASOUTH- GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN : LINE FAULT
663	24-Oct-20	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_ IPP,BSSK IPP	13:11	13:24	00:13	LINE FAULT
664	24-Oct-20	GULBARGA	110	HUMNABAD-BHALKI	BHALKI_110,LADHA_110,MGSSK_ IPP,BSSK IPP	14:10	18:09	03:59	LINE CLEAR AVOIDED
665	24-Oct-20	GULBARGA	110	HV1	BYAGWAT_110	12:00	13:45	01:45	LINE CLEAR AVOIDED
666	24-Oct-20	GULBARGA	110	HV1	KUDITINI_110	10:20	11:20	01:00	LINE CLEAR AVOIDED
667	24-Oct-20	GULBARGA	110	KAPNOOR-HUMNABAD2	ALAND_110,KADAGANCHI_110	17:48	17:55	00:07	LINE FAULT
668	24-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVOIDED
669	24-Oct-20	GULBARGA	110	RAICHUR-VALKAMDINI_110	VALKAMDINI_110	11:45	12:40	00:55	MAIN SUPPLY FAILURE
670	24-Oct-20	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	22:01	22:12	00:11	LINE FAULT
671	24-Oct-20	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	23:50	23:58	00:08	LINE FAULT
672	24-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE LINE)	MASKI_110,MUDDAPUR_110	05:10	05:30	00:20	LINE FAULT
673	24-Oct-20	GULBARGA	110	SINDHANOOR-RAICHUR2(IDLE LINE)	MASKI_110,MUDDAPUR_110	20:30	20:42	00:12	LINE FAULT
674	24-Oct-20	GULBARGA	110	SINDNOOR-MASKI_110	MASKI_110	04:38	04:52	00:14	MAIN SUPPLY FAILURE
675	24-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVOIDED
676	24-Oct-20	GULBARGA	220	RTPS-SEDAM1	SEDAM_220	00:19	00:49	00:30	LINE FAULT
677	24-Oct-20	GULBARGA	220	SHAHPUR-SHAHBAD_220	SHAHABAD_220	23:54(23.10.2020)	9:19(24.10.2020)	9:25 HRS	LINE CHARGED
678	24-Oct-20	GULBARGA	400	JSWL-GUTTUR	GUTTUR_400	18:11(22.10.2020)			LINE OPEN : LINE FAULT
679	24-Oct-20	HASSAN	66	HNPR2-RNPR1	HOLENARASIPURA_220	01:52	01:57	00:05	LINE FAULT
680	24-Oct-20	HASSAN	66	HNPR2-RNPR2	HOLENARASIPURA_220	18:15	18:22	00:07	LINE FAULT
681	24-Oct-20	HASSAN	110	HV1	SINGATGERE_110	14:51	16:34	01:43	LINE CLEAR AVOIDED
682	24-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVOIDED
683	24-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVOIDED
684	24-Oct-20	HASSAN	110	SINGATG-YAGATI	SINGATGERE_110	14:51	16:34	01:43	LINE CLEAR AVOIDED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
685	24-Oct-20	HASSAN	220	KADUR-DABUSET	KADUR_220	15:24	21:41	06:17	LINE FAULT
686	24-Oct-20	HASSAN	220	MRSSHM-SHARAVATHY3	MRSMSG_220	06:47	07:44	00:57	LINE FAULT
687	24-Oct-20	HASSAN	220	MRSSHM-VARAH13	MRSMSG_220	09:15	20:35	11:20	LINE CLEAR AVAILED
688	24-Oct-20	HASSAN	220	SHRAVTY-SHIMOGA3	sharavathy_gen	06:47	07:44	00:57	LINE FAULT
689	24-Oct-20	HASSAN	220	VARAHI-SHMG3	varahi_gen	09:15	20:35	11:20	LINE CLEAR AVAILED
690	24-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
691	24-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:31(24.10.2020)			LINE OPEN: LINE CLEAR AVAILED
692	24-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:27(23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
693	24-Oct-20	MYSURU	66	DEVNUR(N'GUD)-SUTTUR	SUTTUR_66	18:16	18:26	0:09	LINE FAULT
694	24-Oct-20	MYSURU	66	HV1	BGPURA_66	6:50	7:02	0:11	MAIN SUPPLY FAILURE
695	24-Oct-20	MYSURU	66	HV1	JYOTHINAGARA_66	18:31	19:30	0:58	TRANSFORMER FAULT
696	24-Oct-20	MYSURU	66	HV1	KABHALLY_66	7:53	8:00	0:06	TRANSFORMER FAULT
697	24-Oct-20	MYSURU	66	HV2	BGPURA_66	6:50	7:02	0:11	MAIN SUPPLY FAILURE
698	24-Oct-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	17:02	17:09	0:07	LINE FAULT
699	24-Oct-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	17:21			LINE OPEN: LINE CLEAR AVAILED
700	24-Oct-20	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATION EFFECTED	14:36	14:41	0:05	LINE FAULT
701	24-Oct-20	MYSURU	66	MANDGERE-HOLENARSIPURA	MANDGERE_66	9:08	9:15	0:06	LINE FAULT
702	24-Oct-20	MYSURU	66	VAJMANGALA-BANNUR	BANNUR_66 MALIYURU_66	10:17	10:32	0:15	LINE FAULT
703	24-Oct-20	TUMKUR	66	ANCHEPALYA 220kV- HULIYURDURGA	HULIYURDURGA_66, CHAWANAKUPPE_66	17:07	22:07	5:00	LINE FAULT
704	24-Oct-20	TUMKUR	66	CHITRADURGA 66kV- PANDARAHALLI 2	CHITRADURGA_66	2:50	6:32	3:41	LINE FAULT
705	24-Oct-20	TUMKUR	66	HONNALLI 220kV- NALLUR	NALLUR_66, GOPPENAHALLI_66, TAVAREKERE(C)_66, DEVARAHALLI_66, BENKIKERE_66, RAMAGIRI_66	18:56	19:46	0:50	LINE CLEAR AVAILED
706	24-Oct-20	TUMKUR	66	HONNALLI 220kV- SASUVEHALLI	SASUVEHALLI_66, CHANNAGIRI_66, BASAVAPATNA_66	18:56	19:45	0:49	LINE CLEAR AVAILED
707	24-Oct-20	TUMKUR	66	JAVAGONDANAHALLI- INFOSYS-1	INFOSYS-1	9:30	9:40	0:09	HAND TRIPPED
708	24-Oct-20	TUMKUR	66	KUKKAWADA- LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	9:07	9:28	0:21	LINE FAULT
709	24-Oct-20	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHAN GIDURGA_66, PALLAGATTE_66, SOKKE_66	0:04	0:18	0:13	LINE FAULT
710	24-Oct-20	TUMKUR	66	NEELAGUNDA 220kV- PUNABHAGHATTA	PUNABHAGHATTA_66, UCHCHAN GIDURGA_66, PALLAGATTE_66, SOKKE_66	3:23	3:35	0:12	LINE FAULT
711	24-Oct-20	TUMKUR	66	THALLAK 220kV- WELSPUN SOLAR1	WELSPUNSOLAR1_IPP_66	7:44	7:57	0:13	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
712	24-Oct-20	TUMKUR	66	TR-1	KATTIGE_66	11:44	12:34	0:49	LINE CLEAR AVAILED
713	24-Oct-20	TUMKUR	66	TR-1	MATHOD_66	8:45	8:52	0:06	TRANSFORMER FAULT
714	24-Oct-20	TUMKUR	66	TR-2	JAVAGONDANAHALLI_66	10:10	18:12	8:02	LINE CLEAR AVAILED
715	24-Oct-20	TUMKUR	66	TR-2	SASALUHALLA_66	13:54	14:04	0:09	TRANSFORMER FAULT
716	24-Oct-20	TUMKUR	66	TR-2	MADANAYAKANAHALLI_66	18:00	18:17	0:17	TRANSFORMER FAULT
717	24-Oct-20	TUMKUR	110	TR-1(LV SIDE)	NITTUR_220	5:27	15:41	10:14	TRANSFORMER FAULT
718	24-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
719	24-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	9:03	10:36	1:32	HAND TRIPPED
720	24-Oct-20	TUMKUR	220	TR-1(HV SIDE)	NITTUR_220	5:27	15:40	10:13	TRANSFORMER FAULT
721	25-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
722	25-Oct-20	BAGALKOT	110	110/11KV, HV2	STATION NOT AFFECTED MRUTYUNJAYNAGAR_110	17:48 (24.10.2020)	09:02 (25.10.2020)	15:14hrs	LINE CHARGED
723	25-Oct-20	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	8:08	8:18	0:10	TRANSFORMER FAULT
724	25-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
725	25-Oct-20	BAGALKOT	110	110/11KV,HV1	STATION NOT AFFECTED ANKALI_110	10:45	12:48	2:03	LINE CLEAR AVAILED
726	25-Oct-20	BAGALKOT	110	220/110, LV1	STATION NOT AFFECTED MK HUBLI_220	23:39 (25.10.2020)			LOAD CURTAILMENT
727	25-Oct-20	BAGALKOT	110	220/110, LV2	STATION NOT AFFECTED MK HUBLI_220	23:34 (24.10.2020)			LOAD CURTAILMENT
728	25-Oct-20	BAGALKOT	110	220/110KV,LV2	HAVERI_220	18:06	19:59	1:53	HAND TRIPPED
729	25-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
730	25-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
731	25-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
732	25-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)- GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
733	25-Oct-20	BAGALKOT	110	HAVERI-BASAVANAKATTI	BASAVANAKATTI_110	17:05	17:41	0:36	HAND TRIPPED
734	25-Oct-20	BAGALKOT	110	HAVERI-GM SUGARS	HAVERI_220	17:05	20:02	2:57	HAND TRIPPED
735	25-Oct-20	BAGALKOT	110	HAVERI-HANAGAL	HANAGAL_110	17:05	18:05	1:00	HAND TRIPPED
736	25-Oct-20	BAGALKOT	110	HAVERI-HAVERI	HAVERI_110	17:05	18:03	0:58	HAND TRIPPED
737	25-Oct-20	BAGALKOT	110	HAVERI-KNNL	HAVERI_220	17:05	19:56	2:51	HAND TRIPPED
738	25-Oct-20	BAGALKOT	110	HAVERI-SAVANUR	SAVANUR_110	17:05	17:40	0:35	HAND TRIPPED
739	25-Oct-20	BAGALKOT	110	HAVERI-TILUVALI	TILUVALI_110	17:05	20:23	3:18	HAND TRIPPED
740	25-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
741	25-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)- KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED



SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
742	25-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
743	25-Oct-20	BAGALKOT	110	KONNUR- ANANTPUR SOLAR	STATION NOT AFFECTED KONNUR_110	18:36 (25.10.2020)			LINE OPEN: LINE CLEAR AVAILED
744	25-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
745	25-Oct-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD_110	18:26 (24.10.2020)			LINE OPEN: LINE CLEAR AVAILED
746	25-Oct-20	BAGALKOT	110	MAHALINGAPUR-RANNABELAGALI	STATION NOT AFFECTED MAHALINGAPUR_220	7:50	10:25	2:35	LINE CLEAR AVAILED
747	25-Oct-20	BAGALKOT	110	RANNABELAGALI-MAHALINGPUR220	RANNABELAGALI_110	2:33	3:05	0:32	HAND TRIPPED
748	25-Oct-20	BAGALKOT	110	RANNABELAGALI-MAHALINGPUR220	STATION NOT AFFECTED RANNABELAGALI_110	3:23	12:45	9:22	HAND TRIPPED
749	25-Oct-20	BAGALKOT	110	RANNABELAGALI-MUDHOL/UTTUR	MUDHOL/UTTUR_110	2:58	7:31	4:33	HAND TRIPPED
750	25-Oct-20	BAGALKOT	110	UMMACHAGI-ESALE/(SIRSI)	STATION NOT AFFECTED ESALE/SIRSI_110	23:09 (25.10.2020)			LINE OPEN : LINE FAULT
751	25-Oct-20	BAGALKOT	110	UTTUR-ICPL	UTTUR_110	2:16	3:30	1:14	LINE FAULT
752	25-Oct-20	BAGALKOT	110	UTTUR-RANNABELAGALI	STATION NOT AFFECTED RANNABELAGALI_110	2:16	7:26	5:10	HAND TRIPPED
753	25-Oct-20	BAGALKOT	110	VADAGOAN-BELGAUM220	STATION NOT AFFECTED VADAGOAN_110	5:08	8:51	3:43	HAND TRIPPED
754	25-Oct-20	BAGALKOT	220	220/110KV,HV1	HAVERI_220	17:05	19:50	2:45	TRANSFORMER FAULT
755	25-Oct-20	BAGALKOT	220	220/110KV,HV2	HAVERI_220	17:05	19:58	2:53	TRANSFORMER FAULT
756	25-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
757	25-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
758	25-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	2:16 (25.10.2020)			LOAD CURTAILMENT
759	25-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	23:05 (25.10.2020)			LOAD CURTAILMENT
760	25-Oct-20	BAGALKOT	220	BIDNAL-HAVERI	HAVERI_220	17:05	20:25	3:20	LINE FAULT
761	25-Oct-20	BAGALKOT	220	BIDNAL-NARENDRA	STATION NOT AFFECTED BIDNAL_220	12:57	17:57	5:00	LINE FAULT
762	25-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
763	25-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
764	25-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED
765	25-Oct-20	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	22:42 (20.10.2020)			LOAD CURTAILMENT
766	25-Oct-20	BAGALKOT	220	GUTTUR1&2-HAVERI	HAVERI_220	17:05	19:39	2:34	LINE FAULT
767	25-Oct-20	BAGALKOT	220	HUBLI-NAGJHARI3	STATION NOT AFFECTED NAGAJHARI_220	13:07	15:50	2:43	LINE FAULT
768	25-Oct-20	BAGALKOT	220	LINGASUR1-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	12:55	13:33	0:38	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
769	25-Oct-20	BAGALKOT	220	LINGASUR2-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	12:55	13:35	0:40	LINE FAULT
770	25-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	20:46 (21.10.2020)			LINE OPEN : LINE FAULT
771	25-Oct-20	BAGALKOT	220	NARENDRA-BIDNAL(HAVERI1)	STATION NOT AFFECTED NARENDRA_220	12:57	17:57	5:00	LINE FAULT
772	25-Oct-20	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED HAVERI_220	17:05 (25.10.2020)			LINE OPEN : LINE FAULT
773	25-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
774	25-Oct-20	BENGALURU	66	HV1	ELECTRONIC CITY PH-2 SEC-2	02:04	02:09	00:05	TRANSFORMER FAULT
775	25-Oct-20	BENGALURU	66	HV1	L R BANDE	20:02	20:18	00:16	TRANSFORMER FAULT
776	25-Oct-20	BENGALURU	220	DABUSPET 220 - KADUR 220	NO STATION AFFECTED	10:14	16:09	05:55	LINE FAULT
777	25-Oct-20	GULBARGA	110	GULBARGASOUTH- GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN : LINE FAULT
778	25-Oct-20	GULBARGA	110	HV2	DEODURGA_110	15:40	15:55	00:15	TRANSFORMER FAULT
779	25-Oct-20	GULBARGA	110	HV3	YELBURGA_110	10:22	10:35	00:13	TRANSFORMER FAULT
780	25-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
781	25-Oct-20	GULBARGA	110	SHAHPUR-KEMBHAVI2	KBJNL_IPP	00:43	08:21	07:38	LINE FAULT
782	25-Oct-20	GULBARGA	110	YELBURGA-PRPJSLR_IPP	YELBURGA_110	10:22	10:35	00:13	LINE FAULT
783	25-Oct-20	GULBARGA	110	YELBURGA-TALAKUTAI_IPP	YELBURGA_110	10:22	10:35	00:13	LINE FAULT
784	25-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
785	25-Oct-20	GULBARGA	220	LINGAPUR-BAGEWAADI2	BAGEWAADI_220	12:53	13:35	00:42	LINE FAULT
786	25-Oct-20	GULBARGA	220	LINGAPUR-GADAG2	ARESS STEELS_IPP	15:43(23/10/2020)	16:14(25/10/2020)	48:31 HRS	LINE FAULT
787	25-Oct-20	GULBARGA	220	LINGAPUR-HALWARTHI	HALWARTHI_220	08:40	16:18	07:38	LINE CLEAR AVAILED
788	25-Oct-20	GULBARGA	220	SHAHAPUR-LINGSUGUR	LINGSUGUR_220	12:55	13:39	00:44	LINE FAULT
789	25-Oct-20	GULBARGA	400	JSWL-GUTTUR	GUTTUR_400	18:11(22.10.2020)	9:48(25.10.2020)	63:37 HRS	LINE FAULT
790	25-Oct-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	12:44	12:51	00:07	LINE FAULT
791	25-Oct-20	HASSAN	66	KUDLIGE-ANVRPP	KUDLIGERE_66	16:08	16:29	00:21	LINE FAULT
792	25-Oct-20	HASSAN	110	HV2	BHADRAVATHI_110	17:36	19:00	01:24	LINE CLEAR AVAILED
793	25-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
794	25-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
795	25-Oct-20	HASSAN	220	KADUR-DABUSET	KADUR_220	10:14	16:11	05:57	LINE FAULT
796	25-Oct-20	HASSAN	220	KEMAR-Varahi2	KEMAR_220	12:23	14:58	02:35	NFBC ISSUED
797	25-Oct-20	HASSAN	220	VARAHI-KEMAR2	varahi_gen	12:22	14:59	02:37	LINE CLEAR AVAILED
798	25-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
799	25-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:33(25.10.2020)			LINE OPEN: LINE CLEAR AVAILED
800	25-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:31(24.10.2020)	12:13(25.10.2020)	13:42hrs	LINE CHARGED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
801	25-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:27(23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
802	25-Oct-20	MYSURU	66	KUSHALNAGARA -RAMNATHPURA 1	ALUR SIDDAPURA_66 KANAGAL_66	3:15	3:26	0:10	LINE FAULT
803	25-Oct-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	17:21 (24/10/2020)			LINE OPEN: LINE CLEAR AVAILED
804	25-Oct-20	MYSURU	66	TUBINKERE-MC-4	NO STATION EFFECTED	13:40	13:46	0:06	LINE FAULT
805	25-Oct-20	TUMKUR	66	DAVANGERE SRS- HARIHARA	HARIHAR_66, HARIHAR- HOSPET_66, BANUVALLI_66, NANDIGUDI_66	4:12	4:47	0:34	HAND TRIPPED
806	25-Oct-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	4:12	4:46	0:34	HAND TRIPPED
807	25-Oct-20	TUMKUR	66	DAVANGERE SRS- SOKKE	MELLEKATTE_66, SOKKE_66	8:28	8:43	0:15	HAND TRIPPED
808	25-Oct-20	TUMKUR	66	DAVANGERE SRS- YARAGUNTA	YARAGUNTA_66, OBAJJIHALLI_66	4:12	4:47	0:34	HAND TRIPPED
809	25-Oct-20	TUMKUR	66	HONNALLI 220KV- SASUVEHALLI	SASUVEHALLI_66,CHANNAGIRI_6 6, BASAVAPATNA_66	12:16	12:24	0:07	LINE FAULT
810	25-Oct-20	TUMKUR	66	MAYAKONDA- DAVANAGERE SRS 220KV	MAYAKONDA_66	8:28	9:03	0:35	LINE FAULT
811	25-Oct-20	TUMKUR	66	THALLAK 220kv -BGKERE 1	BGKERE_66	12:20	12:31	0:11	HAND TRIPPED
812	25-Oct-20	TUMKUR	66	TR-1(LV SIDE)	DAVANGERE_SRS_220	3:59	4:46	0:46	TRANSFORMER FAULT
813	25-Oct-20	TUMKUR	66	TR-2	SASALUHALLA_66	13:54	14:04	0:09	TRANSFORMER FAULT
814	25-Oct-20	TUMKUR	66	UCHANGIDURGA- I/C220SRSDAVANGERE	UCHCHANGIDURGA_66	14:38	15:01	0:22	LINE FAULT
815	25-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
816	25-Oct-20	TUMKUR	220	NITTUR 220kv- NELAMANGALA	NITTUR_220	12:28	15:31	3:02	LINE CLEAR AVAILED
817	25-Oct-20	TUMKUR	220	TR-1(HV SIDE)	DAVANGERE_SRS_220	3:59	4:45	0:46	TRANSFORMER FAULT
818	26-Oct-20	BAGALKOT	66	HONNALLI(BANUVALLI)-HARIHAR HOSPET	STATION NOT AFFECTED HARIHAR HOSPET_66	12:45 (04.09.2020)			LINE OPEN: LINE CLEAR AVAILED
819	26-Oct-20	BAGALKOT	110	110/11KV, HV1	PH COMPOUND_110	8:50	10:15	1:25	HAND TRIPPED
820	26-Oct-20	BAGALKOT	110	110/11KV, HV2	ITANAL_110	22:01	22:09	0:08	TRANSFORMER FAULT
821	26-Oct-20	BAGALKOT	110	110/11KV, HV2	ITANAL_110	22:44	22:52	0:08	TRANSFORMER FAULT
822	26-Oct-20	BAGALKOT	110	110/11KV, HV2	MAMADAPUR(B)_110	18:58	21:20	2:22	TRANSFORMER FAULT
823	26-Oct-20	BAGALKOT	110	110/11KV, HV2	KALGHATAGI_110	6:12	10:30	4:18	LINE CLEAR AVAILED
824	26-Oct-20	BAGALKOT	110	110/11KV, HV3	MUDHOL_110	13:04	13:11	0:07	LINE CLEAR AVAILED
825	26-Oct-20	BAGALKOT	110	110/11KV,HV 1	STATION NOT AFFECTED DAMBAL_110	14:14 (16.09.2020)			TRANSFORMER OPEN : TRANSFORMER FAULT
826	26-Oct-20	BAGALKOT	110	110/33KV, HV4	LAKAMANHALLI_110	19:22	19:28	0:06	TRANSFORMER FAULT
827	26-Oct-20	BAGALKOT	110	220/110, LV1	STATION NOT AFFECTED MK HUBLI_220	23:39 (25.10.2020)	07:00 (26.10.2020)	7:51hrs	LOAD CURTAILMENT
828	26-Oct-20	BAGALKOT	110	220/110, LV2	STATION NOT AFFECTED MK HUBLI_220	23:34 (24.10.2020)			LOAD CURTAILMENT
829	26-Oct-20	BAGALKOT	110	BELGAUM-KANABARGI LAYOUT	STATION NOT AFFECTED BELGAUM_110	13:05 (19.08.2020)			LINE OPEN: LINE CLEAR AVAILED
830	26-Oct-20	BAGALKOT	110	GOPPANAKOPPA- MRUTHYUNJAYNAGAR1	NO STATION EFFECTED GOPPANAKOPPA_110	15:20 (23.10.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
831	26-Oct-20	BAGALKOT	110	GOPPANAKOPPA-MRUTHYUNJAYNAGAR2	NO STATION EFFECTED GOPPANAKOPPA_110	18:28 (30.05.2020)			LINE OPEN: LINE CLEAR AVAILED
832	26-Oct-20	BAGALKOT	110	HAVERI 1(GUTTAL SWITCHING)-GUTTAL	STATION NOT AFFECTED GUTTAL_110	18:00 (21.07.2020)			LINE OPEN: LINE CLEAR AVAILED
833	26-Oct-20	BAGALKOT	110	HIDIKAL-ITNAL	STATION NOT AFFECTED ITNAL_110	(16:22) 23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
834	26-Oct-20	BAGALKOT	110	KAVALWADA(AMBEWADI)-KADANAKOPPA	STATION NOT AFFECTED KADANAKOPPA_110	20:38 (22.09.2020)			LINE OPEN: LINE CLEAR AVAILED
835	26-Oct-20	BAGALKOT	110	KIADB BIJAPUR-BIJAPUR CITY(BAGEWADI)	NO STATION EFFECTED KIADB BIJAPUR_110	19:41 (25.05.2020)			LINE OPEN : LINE FAULT
836	26-Oct-20	BAGALKOT	110	KONNUR- ANANTPUR SOLAR	STATION NOT AFFECTED KONNUR_110	18:36 (25.10.2020)	4:44 (26.10.2020)	10:08hrs	LINE CHARGED
837	26-Oct-20	BAGALKOT	110	KUDALASANGAM-ACHANUR	STATION NOT AFFECTED ACHANUR_110	16:02 (28.09.2020)			LINE OPEN: LINE CLEAR AVAILED
838	26-Oct-20	BAGALKOT	110	KUSTAGI-GAJENDRAGAD	STATION NOT AFFECTED GAJENDRAGAD_110	18:26 (24.10.2020)			LINE OPEN: LINE CLEAR AVAILED
839	26-Oct-20	BAGALKOT	110	PGHUNSAL-MUDALGI(NAGANUR)	MUDALGI(NAGANUR)_110	23:41	23:51	0:10	LINE FAULT
840	26-Oct-20	BAGALKOT	110	UMMACHAGI-ESALE/(SIRSI)	STATION NOT AFFECTED ESALE/SIRSI_110	23:09 (25.10.2020)	07:25 (26.10.2020)	8:16hrs	LINE FAULT
841	26-Oct-20	BAGALKOT	110	VAJRAMATTI220-LOKAPUR	STATION NOT AFFECTED LOKAPUR_110	3:26	7:41	4:15	LINE FAULT
842	26-Oct-20	BAGALKOT	220	220/110KV,LV1	STATION NOT AFFECTED BAGALKOT_220	11:29 (12.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
843	26-Oct-20	BAGALKOT	220	BAGEWADI-ATRIA 1	BAGEWADI_220	19:25 (21.10.2020)			LINE OPEN: LINE CLEAR AVAILED
844	26-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	2:16 (25.10.2020)	7:06 (26.10.2020)	4:50hrs	LOAD CURTAILMENT
845	26-Oct-20	BAGALKOT	220	BELGAUM-CHIKKODI1	STATION NOT AFFECTED BELGAUM_220	23:12 (26.10.2020)			LINE OPEN: LINE CLEAR AVAILED
846	26-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	23:05 (25.10.2020)	7:31 (26.10.2020)	8:26hrs	LOAD CURTAILMENT
847	26-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	2:01	8:46	6:45	LOAD CURTAILMENT
848	26-Oct-20	BAGALKOT	220	BELGAUM-NARENDRA1	STATION NOT AFFECTED BELGAUM_220	23:10 (26.10.2020)			LOAD CURTAILMENT
849	26-Oct-20	BAGALKOT	220	BIDNAL-HARTHI1	STATION NOT AFFECTED BIDNAL_220	12:00	17:39	5:39	LINE FAULT
850	26-Oct-20	BAGALKOT	220	BIDNAL-HUBLI3	STATION NOT AFFECTED BIDNAL_220	12:46	15:41	2:55	LINE FAULT
851	26-Oct-20	BAGALKOT	220	BIDNAL-NAGHJARI2	STATION NOT AFFECTED BIDNAL_220	14:21	18:31	4:10	LINE FAULT
852	26-Oct-20	BAGALKOT	220	CHIKKODI- MUDASHINGI (KOLAPUR2)	STATION NOT AFFECTED CHIKKODI_220	11:17 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
853	26-Oct-20	BAGALKOT	220	CHIKKODI- TALANDAGE (KOLAPUR1)	STATION NOT AFFECTED CHIKKODI_220	11:18 (16.10.2020)			LINE OPEN: LINE CLEAR AVAILED
854	26-Oct-20	BAGALKOT	220	CHIKKODI-GHATAPRABHA1	STATION NOT AFFECTED CHIKKODI_220	10:29 (21.09.2020)			LINE OPEN: LINE CLEAR AVAILED

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
855	26-Oct-20	BAGALKOT	220	FORTUNEFIVE 1&2-BAGEWADI	STATION NOT AFFECTED BAGEWADI_220	9:44	13:46	4:02	LINE CLEAR AVAILED
856	26-Oct-20	BAGALKOT	220	GADAG-HARTI 1	GADAG_220	22:42 (20.10.2020)	12:37 (26.10.2020)	133:55hrs	LOAD CURTAILMENT
857	26-Oct-20	BAGALKOT	220	HUBLI-BIDNAL2	STATION NOT AFFECTED HUBLI_220	12:46	15:44	2:58	LINE FAULT
858	26-Oct-20	BAGALKOT	220	HUBLI-SIRSI1	STATION NOT AFFECTED HUBLI_220	13:05 (26.10.2020)			LINE OPEN : LINE FAULT
859	26-Oct-20	BAGALKOT	220	NARENDRA- AMBEWADI2	STATION NOT AFFECTED NARENDRA_220	20:46 (21.10.2020)			LINE OPEN : LINE FAULT
860	26-Oct-20	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED HAVERI_220	17:05 (25.10.2020)			LINE OPEN : LINE FAULT
861	26-Oct-20	BAGALKOT	220	NARENDRA-HAVERI	STATION NOT AFFECTED NARENDRA_220	10:50	13:42	2:52	LINE CLEAR AVAILED
862	26-Oct-20	BAGALKOT	220	SIRSI-HUBLI1	STATION NOT AFFECTED SIRSI_220	13:05 (26.10.2020)			LINE OPEN : LINE FAULT
863	26-Oct-20	BAGALKOT	220	SIRSI-HUBLI2	STATION NOT AFFECTED SIRSI_220	16:35 (26.10.2020)			LOAD CURTAILMENT
864	26-Oct-20	BENGALURU	66	BEGUR 220 - VIJAYAPURA 2(HOSKOTE)	NO STATION AFFECTED	19:55 (26-5-2020)			LINE OPEN : LINE FAULT
865	26-Oct-20	BENGALURU	66	BG ROAD - JIGANI LINK ROAD	JIGANI LINK ROAD	12:49	13:10	00:21	LINE CLEAR AVAILED
866	26-Oct-20	BENGALURU	66	BG ROAD - SOMANAHALLI 220	BG ROAD,JIGANI LINK ROAD	13:05	13:10	00:05	LINE CLEAR AVAILED
867	26-Oct-20	BENGALURU	66	HULIMANGALA - ELECTRONIC CITY PH- 2 SEC-1	HULIMANGALA	13:33	18:55	05:22	LINE CLEAR AVAILED
868	26-Oct-20	BENGALURU	66	HV1	L R BANDE	10:48	10:58	00:10	TRANSFORMER FAULT
869	26-Oct-20	BENGALURU	66	HV2	LEELA VENTURE	11:39	14:03	02:24	LINE CLEAR AVAILED
870	26-Oct-20	BENGALURU	66	MITTEMARI 220 - JULLUPALYA	JULLUPALYA	12:15	14:21	02:06	LINE FAULT
871	26-Oct-20	GULBARGA	110	CHINCHOLI-RENEW WIND_IPP	CHINCHOLI_110	17:48	23:09	05:21	LINE CLEAR AVAILED
872	26-Oct-20	GULBARGA	110	GULBARGASOUTH- GULBARGAUNIVERSITY	NO AFFECTED STATION	10:10(10.10.2020)			LINE OPEN : LINE FAULT
873	26-Oct-20	GULBARGA	110	HV2	DEODURGA_110	17:35	18:05	00:30	TRANSFORMER FAULT
874	26-Oct-20	GULBARGA	110	HV4	YELBURGA_110	12:43	12:59	00:16	TRANSFORMER FAULT
875	26-Oct-20	GULBARGA	110	MALLAT-SIRWAR	NO AFFECTED STATION	7:05(29.08.2020)			LINE OPEN: LINE CLEAR AVAILED
876	26-Oct-20	GULBARGA	110	SEDAM-GURUMITAKAL	GURUMITAKAL_110,KONKAL_110	03:50	04:00	00:10	LINE FAULT
877	26-Oct-20	GULBARGA	110	SINDNOOR-MASKI_110	MASKI_110	13:58	14:22	00:24	MAIN SUPPLY FAILURE
878	26-Oct-20	GULBARGA	110	SINDNOOR-MASKI_110	MASKI_110	19:54	20:05	00:11	MAIN SUPPLY FAILURE
879	26-Oct-20	GULBARGA	220	HV1	SEDAM_220	10:50(13.10.2020)			TRANSFORMER OPEN:LINE CLEAR AVAILED
880	26-Oct-20	HASSAN	66	BHADRA-LINGADAHALLI	bhadra_gen	11:38	11:46	00:08	LINE FAULT
881	26-Oct-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	06:02	06:09	00:07	TRANSFORMER FAULT
882	26-Oct-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	08:04	08:14	00:10	TRANSFORMER FAULT
883	26-Oct-20	HASSAN	66	HV1	ATTICHOWDENAHALLY_66	08:48	09:06	00:18	TRANSFORMER FAULT
884	26-Oct-20	HASSAN	66	MALALI-CRPATNA	MALALI_66	11:44	11:58	00:14	LINE FAULT
885	26-Oct-20	HASSAN	66	SIGEBAG-KDLGRE	SIGEBAGE_66	10:01	10:18	00:17	LINE FAULT

SL NO	DATE	Tr_ZONE	Voltage	Line/Transformer	NAME OF THE STATION	open_at	Closed_At	Duration	REASON
886	26-Oct-20	HASSAN	110	HV2	ARASIKERE_110	10:49	11:07	00:18	TRANSFORMER FAULT
887	26-Oct-20	HASSAN	110	HV2	PUTTUR_110	09:40	12:30	02:50	LINE CLEAR AVAILED
888	26-Oct-20	HASSAN	110	JOG-NK1	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
889	26-Oct-20	HASSAN	110	JOG-NK2	mghejog_gen	12:55 (1.10.2020)			LINE OPEN: LINE CLEAR AVAILED
890	26-Oct-20	HASSAN	110	SAGARA-LST4	SAGARA_110	10:52	13:25	02:33	LINE CLEAR AVAILED
891	26-Oct-20	HASSAN	220	MRSSHM-VARAHI1	MRSMSG_220	13:08	16:58	03:50	LINE FAULT
892	26-Oct-20	HASSAN	220	MRSSHM-VARAHI2	MRSMSG_220	14:24	19:23	04:59	LINE FAULT
893	26-Oct-20	HASSAN	220	VARAHI-SHIMOGA1	varahi_gen	13:08	16:59	03:51	LINE FAULT
894	26-Oct-20	HASSAN	220	VARAHI-SHIMOGA2	varahi_gen	14:24	19:24	05:00	LINE FAULT
895	26-Oct-20	HASSAN	400	TALAGU-NELAMANGALA#2	TALAGUPPA_400	16:52 (18.10.2020)			LINE OPEN: LINE CLEAR AVAILED
896	26-Oct-20	HASSAN	400	UPCL-HASSAN1	upcl_gen	22:33(25.10.2020)	9:47(26.10.2020)	11:14hrs	LINE CHARGED
897	26-Oct-20	HASSAN	400	UPCL-HASSAN2	upcl_gen	22:27(23.10.2020)			LINE OPEN: LINE CLEAR AVAILED
898	26-Oct-20	MYSURU	66	HV1	KABHALLY_66	11:25	13:19	1:54	LINE CLEAR AVAILED
899	26-Oct-20	MYSURU	66	HV1	DEVANOORMYS_66	16:36	16:49	0:12	TRANSFORMER FAULT
900	26-Oct-20	MYSURU	66	KIRUGAVALU-MALIYUR	NO STATION EFFECTED	13:16	13:28	0:11	LINE FAULT
901	26-Oct-20	MYSURU	66	KOLLEGALA-MADHUVANAHALLI	NO STATION EFFECTED	12:11	12:21	0:09	LINE FAULT
902	26-Oct-20	MYSURU	66	MADHUVANAHALLI-HEBBANI	NO STATION EFFECTED	17:21 (24/10/2020)	13:05(26.10.2020)	43:44Hrs	LINE CHARGED
903	26-Oct-20	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATION EFFECTED	6:17	6:22	0:05	LINE FAULT
904	26-Oct-20	MYSURU	66	MADHUVANAHALLI-KOLLEGALA	NO STATION EFFECTED	12:13	12:20	0:07	LINE FAULT
905	26-Oct-20	MYSURU	66	MADHUVANAHALLI-PG PALYA	PGPALYA_66	3:38	3:43	0:05	LINE FAULT
906	26-Oct-20	TUMKUR	66	HIRIYUR 220KV- ENERCON-1	ENERCON1_IPP_66	22:42	23:01	0:18	LINE FAULT
907	26-Oct-20	TUMKUR	66	KUKKAWADA-LINGADAHALLI(CHANNAGIRI)	KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66	11:11	11:22	0:10	LINE FAULT
908	26-Oct-20	TUMKUR	66	MADANAYAKANAHALLI-CHITRADURGA220	MADANAYAKANAHALLI_66	15:59	16:10	0:11	LINE FAULT
909	26-Oct-20	TUMKUR	66	MADANAYAKANAHALLI-TURUVANUR	MADANAYAKANAHALLI_66	15:59	16:17	0:18	LINE FAULT
910	26-Oct-20	TUMKUR	66	NEELAGUNDA 220kv-PUNABHAGHATTA	PUNABHAGHATTA_66,UCHCHAN GIDURGA_66,PALLAGATTE_66, SOKKE_66	22:13	22:22	0:09	LINE FAULT
911	26-Oct-20	TUMKUR	66	TR-1	CHITRADURGA_66	10:38	10:46	0:07	TRANSFORMER FAULT
912	26-Oct-20	TUMKUR	66	TR-1	MATHOD_66	7:05	7:11	0:05	TRANSFORMER FAULT
913	26-Oct-20	TUMKUR	110	TR-2	SAMPIGE_110	13:20 (02.06.20)			TRANSFORMER OPEN : TRANSFORMER FAULT
914	26-Oct-20	TUMKUR	220	DAVANGERE SRS- SHIMOGA 2	DAVANGERE_SRS_220	10:03(26.10.2020)			LINE OPEN: LINE CLEAR AVAILED