400/220/110/66 kV TRANSMISSION SYSTEM OUTAGES FROM 16.10.2018 TO 22.10.2018

| SL NO | DATE | Tr_ZONE | Voltage | Line/Transformer | NAME OF THE STATION | open _at | Closed_At | Duration | REASON |
|-------|-----------|----------|---------|-----------------------|-------------------------|----------|-----------|----------|---------------------|
| 1 | 16-Oct-18 | BAGALKOT | 220 | ATHANI-MAHALINGAPUR | ATHANI_220 | 19:47 | 20:37 | 0:50 | LINE FAULT |
| 2 | 16-Oct-18 | BAGALKOT | 220 | ATHANI-MAHALINGAPUR | ATHANI_220 | 23:19 | 23:59 | 0:40 | LINE FAULT |
| 3 | 16-Oct-18 | BAGALKOT | 110 | AMBEWADI-NK2 | KAVALWADA_110 | 9:39 | 13:39 | 4:00 | LINE CLEAR AVAILED |
| 4 | 16-Oct-18 | BAGALKOT | 110 | AMBEWADI-NK1 | HALIYAL_110 | 0:00 | 13:57 | 13:57 | LINE CLEAR AVAILED |
| 5 | 16-Oct-18 | BAGALKOT | 110 | SUPA1-AMBEWADI | AMBEWADI_220 | 11:40 | 13:44 | 2:04 | HAND TRIPPED |
| 6 | 16-Oct-18 | BAGALKOT | 110 | SUPA2-AMBEWADI | AMBEWADI_220 | 11:40 | 14:41 | 3:01 | HAND TRIPPED |
| 7 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV, HV3 | ANKALI_110 | 19:10 | 19:39 | 0:29 | TRANSFORMER FAULT |
| 8 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV, HV1 | ATHARGA_110 | 14:56 | 15:40 | 0:44 | LOAD CURTAILMENT |
| 9 | 16-Oct-18 | BAGALKOT | 220 | ALAMATTI2-BAGALKOT | BAGALKOT_220 | 13:10 | 19:40 | 6:30 | LINE FAULT |
| 10 | 16-Oct-18 | BAGALKOT | 220 | ALAMATTI1-BAGALKOT | BAGALKOT_220 | 17:00 | 19:39 | 2:39 | LINE CLEAR AVAILED |
| 11 | 16-Oct-18 | BAGALKOT | 110 | ENERCON2-BELLATTI | BELLATTI_110 | 19:34 | 23:59 | 4:25 | LINE FAULT |
| 12 | 16-Oct-18 | BAGALKOT | 220 | HIREBENDIGERI2-BIDNAL | BIDNAL_220 | 0:00 | 14:13 | 14:13 | LINE CLEAR AVAILED |
| 13 | 16-Oct-18 | BAGALKOT | 220 | CHIKKODI-BELGAUM2 | CHIKKODI_220 | 19:28 | 23:59 | 4:31 | LINE FAULT |
| 14 | 16-Oct-18 | BAGALKOT | 220 | CHIKKODI-BELGAUM1 | CHIKKODI_220 | 22:54 | 23:59 | 1:05 | LINE CLEAR AVAILED |
| 15 | 16-Oct-18 | BAGALKOT | 220 | ARESS STEEL-GADAG | GADAG_220 | 21:39 | 23:59 | 2:20 | LINE FAULT |
| 16 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV, HV4 | GAJENDRAGAD_110 | 14:55 | 15:30 | 0:35 | LOAD CURTAILMENT |
| 17 | 16-Oct-18 | BAGALKOT | 110 | KUSTAGI-GAJENDRAGAD | GAJENDRAGAD_110 | 21:50 | 22:35 | 0:45 | HAND TRIPPED |
| 18 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV, HV2 | GOPPANAKOPPA_110 | 15:48 | 18:20 | 2:32 | LINE CLEAR AVAILED |
| 19 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV, HV2 | GULEDGUDDA_110 | 10:14 | 10:22 | 0:08 | TRANSFORMER FAULT |
| 20 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV, HV2 | GULEDGUDDA_110 | 13:16 | 13:25 | 0:09 | TRANSFORMER FAULT |
| 21 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV, HV1 | HALIYAL_110 | 16:18 | 18:31 | 2:13 | LINE CLEAR AVAILED |
| 22 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV, HV3 | HIDIKAL_110 | 11:45 | 12:26 | 0:41 | LINE CLEAR AVAILED |
| 23 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV, HV4 | HIDIKAL_110 | 11:46 | 12:56 | 1:10 | LINE CLEAR AVAILED |
| 24 | 16-Oct-18 | BAGALKOT | 110 | MAHALINGAPUR-HIDIKAL | HIDIKAL_110, ITANAL_110 | 12:39 | 12:43 | 0:04 | HAND TRIPPED |
| 25 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV, HV3 | HIDIKAL_110 | 14:56 | 15:10 | 0:14 | LOAD CURTAILMENT |
| 26 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV, HV1 | KUDACHI_110 | 14:47 | 15:15 | 0:28 | LINE CLEAR AVAILED |
| 27 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV, HV2 | AINAPUR_110 | 14:55 | 15:16 | 0:21 | LOAD CURTAILMENT |
| 28 | 16-Oct-18 | BAGALKOT | 110 | ATHANI220-AIGALI | AIGALI_110 | 7:08 | 7:17 | 0:09 | LINE FAULT |
| 29 | 16-Oct-18 | BAGALKOT | 110 | ATHANI220-AIGALI | AIGALI_110 | 7:58 | 8:05 | 0:07 | LINE FAULT |
| 30 | 16-Oct-18 | BAGALKOT | 110 | SIRSI1-KUMATA | KUMATA_110 | 12:49 | 23:59 | 11:10 | LINE FAULT |
| 31 | 16-Oct-18 | BAGALKOT | 110 | SAVANUR-SHIGGAON | SHIGGAON_110 | 7:18 | 7:24 | 0:06 | MAIN SUPPLY FAILURE |
| 32 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV, HV2 | UGAR KHUD_110 | 16:02 | 16:09 | 0:07 | TRANSFORMER FAULT |
| 33 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | TIKOTA_110 | 14:55 | 15:05 | 0:10 | LOAD CURTAILMENT |
| 34 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | TIKOTA_110 | 22:51 | 23:34 | 0:43 | TRANSFORMER FAULT |
| 35 | 16-Oct-18 | BAGALKOT | 110 | TIKOTA-BHUTNAL | TIKOTA_110 | 22:51 | 23:30 | 0:39 | MAIN SUPPLY FAILURE |
| 36 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 10:34 | 10:37 | 0:03 | TRANSFORMER FAULT |
| 37 | 16-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 11:40 | 11:44 | 0:04 | TRANSFORMER FAULT |
| 38 | 16-Oct-18 | BAGALKOT | 110 | SIRSI220-KAVALWADA | KAVALWADA_110 | 9:38 | 9:45 | 0:07 | HAND TRIPPED |
| 39 | 16-Oct-18 | BAGALKOT | 110 | SIRSI-KUMATA 2 | KUMATA_110 | 12:34 | 12:43 | 0:09 | LINE FAULT |
| 40 | 16-Oct-18 | BAGALKOT | 110 | SIRSI-KUMATA 1 | KUMATA_110 | 12:34 | 14:47 | 2:13 | LINE FAULT |
| 41 | 16-Oct-18 | BAGALKOT | 110 | SIRSI-KUMATA 1 | KUMATA_110 | 14:47 | 23:59 | 9:12 | LINE FAULT |

| 42 | 16-Oct-18 | BAGALKOT | 220 | HUBLI220-NARENDRA2 | HUBLI_220 | 11:46 | 17:06 | 5:20 | NBFC ISSUED |
|----|-----------|----------|-----|-------------------------|---|-------|-------|-------|--------------------|
| 43 | 16-Oct-18 | BAGALKOT | 220 | NAGJARI 2-HUBLI 220 | HUBLI_220 | 13:29 | 16:58 | 3:29 | LINE FAULT |
| 44 | 16-Oct-18 | BAGALKOT | 110 | SHIRAHATTI-LAXMESWAR | LAXMESWAR_110 | 19:23 | 23:03 | 3:40 | LINE FAULT |
| 45 | 16-Oct-18 | BAGALKOT | 110 | CHIKKODI 220-SANKESHWAR | SANKESHWAR_110 | 17:54 | 18:11 | 0:17 | LINE FAULT |
| 46 | 16-Oct-18 | BAGALKOT | 220 | NARENDRA-BELGUM 1 | NARENDRA_220 | 19:14 | 23:59 | 4:45 | LINE FAULT |
| 47 | 16-Oct-18 | BAGALKOT | 220 | NARENDRA-HUBLI2 | NARENDRA_220 | 11:46 | 18:28 | 6:42 | LINE CLEAR AVAILED |
| 48 | 16-Oct-18 | BAGALKOT | 110 | RON -GAJENDRAGAD1 | GAJENDRAGAD_110 | 10:05 | 21:53 | 11:48 | HAND TRIPPED |
| 49 | 16-Oct-18 | BAGALKOT | 110 | GAMESH WIND-RON | RON_110 | 10:05 | 10:11 | 0:06 | HAND TRIPPED |
| 50 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | P H HUNSYAL_110 | 15:15 | 16:23 | 1:08 | HAND TRIPPED |
| 51 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | NIDAGUNDI_110 | 15:10 | 15:56 | 0:46 | HAND TRIPPED |
| 52 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | NIDAGUNDI_110 | 12:05 | 12:59 | 0:54 | HAND TRIPPED |
| 53 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | LOKAPUR_110 | 10:23 | 16:49 | 6:26 | HAND TRIPPED |
| 54 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | LOKAPUR_110 | 18:06 | 19:23 | 1:17 | TRANSFORMER FAULT |
| 55 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | LAXMESHWAR_110 | 14:46 | 15:59 | 1:13 | LOAD CURTAILMENT |
| 56 | 16-Oct-18 | BAGALKOT | 110 | 110/11KV,HV3 | LAXMESHWAR_110 | 14:58 | 18:53 | 3:55 | TRANSFORMER FAULT |
| 57 | 16-Oct-18 | BAGALKOT | 110 | LAXMESHWAR-SHIRAHATTI | SHIRAHATTI_110 | 19:23 | 23:00 | 3:37 | LINE FAULT |
| 58 | 16-Oct-18 | BAGALKOT | 66 | 66/11 KV,HV2 | HARIHAR-HOSPET_66 | 3:08 | 3:15 | 0:07 | TRANSFORMER FAULT |
| 59 | 16-Oct-18 | BAGALKOT | 66 | 66/11 KV,HV4 | HARIHAR-HOSPET_66 | 16:26 | 17:20 | 0:54 | TRANSFORMER FAULT |
| 60 | 16-Oct-18 | BAGALKOT | 66 | 66/11 KV,HV2 | HARIHAR-HOSPET_66 | 18:06 | 18:35 | 0:29 | TRANSFORMER FAULT |
| 61 | 16-Oct-18 | BAGALKOT | 66 | 66/11 KV,HV2 | HARIHAR-HOSPET_66 | 19:14 | 23:59 | 4:45 | TRANSFORMER FAULT |
| 62 | 17-Oct-18 | BAGALKOT | 220 | XELDOM-AMBEWADI | AMBEWADI_220 | 12:45 | 14:05 | 1:20 | LINE FAULT |
| 63 | 17-Oct-18 | BAGALKOT | 110 | AMBEWADI-NK1 | HALIYAL_110 | 12:14 | 16:31 | 4:17 | LINE FAULT |
| 64 | 17-Oct-18 | BAGALKOT | 110 | AMBEWADI-NK2 | KAVALWADA_110 | 16:09 | 16:31 | 0:22 | LINE CLEAR AVAILED |
| 65 | 17-Oct-18 | BAGALKOT | 110 | 110/33KV, HV3 | ANKALI_110 | 12:11 | 12:42 | 0:31 | LINE CLEAR AVAILED |
| 66 | 17-Oct-18 | BAGALKOT | 110 | 110/33KV, HV3 | ANKALI_110 | 15:31 | 16:03 | 0:32 | LINE CLEAR AVAILED |
| 67 | 17-Oct-18 | BAGALKOT | 220 | ATHANI-MAHALINGAPUR | ATHANI_220 | 0:00 | 0:26 | 0:26 | LINE CLEAR AVAILED |
| 68 | 17-Oct-18 | BAGALKOT | 220 | ATHANI-MAHALINGAPUR | ATHANI_220 | 4:31 | 13:28 | 8:57 | LINE FAULT |
| 69 | 17-Oct-18 | BAGALKOT | 110 | ENERCON2-BELLATTI | BELLATTI_110 | 0:00 | 16:18 | 16:18 | LINE CLEAR AVAILED |
| 70 | 17-Oct-18 | BAGALKOT | 110 | BAGEWADI-NIDAGUNDI | NIDAGUNDI_110 | 18:06 | 18:12 | 0:06 | HAND TRIPPED |
| 71 | 17-Oct-18 | BAGALKOT | 110 | BAGEWADI-MAMDAPUR1&2 | MAMDAPUR_110 | 18:06 | 18:11 | 0:05 | HAND TRIPPED |
| 72 | 17-Oct-18 | BAGALKOT | 110 | BAGEWADI-MUDDEBIHAL | MUDDEBIHAL_110 | 18:06 | 18:13 | 0:07 | HAND TRIPPED |
| 73 | 17-Oct-18 | BAGALKOT | 220 | CHIKKODI-BELAGAUM2 | CHIKKODI_220 | 0:00 | 2:28 | 2:28 | LINE CLEAR AVAILED |
| 74 | 17-Oct-18 | BAGALKOT | 220 | CHIKKODI-BELAGAUM1 | CHIKKODI_220 | 0:00 | 2:28 | 2:28 | HAND TRIPPED |
| 75 | 17-Oct-18 | BAGALKOT | 220 | LINGAPUR-GADAG | GADAG_220 | 19:42 | 23:59 | 4:17 | LINE FAULT |
| 76 | 17-Oct-18 | BAGALKOT | 110 | 110/33KV, HV4 | GADAG_110 | 20:59 | 22:54 | 1:55 | TRANSFORMER FAULT |
| 77 | 17-Oct-18 | BAGALKOT | 220 | NARENDRA-BELGAUM 1 | NARENDRA_220 | 0:00 | 13:12 | 13:12 | LINE CLEAR AVAILED |
| 78 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | NANADI_110 | 16:40 | 17:32 | 0:52 | LINE CLEAR AVAILED |
| 79 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | NANADI_110 | 17:34 | 18:21 | 0:47 | LINE CLEAR AVAILED |
| 80 | 17-Oct-18 | BAGALKOT | 110 | 110/33KV,HV3 | MUNAVALLI_110,MUNAVALLI_33,MALLUR_33 KV | 14:32 | 15:42 | 1:10 | LINE CLEAR AVAILED |
| 81 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | MUNAVALLI_110 | 17:20 | 18:15 | 0:55 | LINE CLEAR AVAILED |
| 82 | 17-Oct-18 | BAGALKOT | 110 | 110/33KV,HV2 | MATTIHAL_110,NTPC_33KV,WATER SUPPLY_33KV,KARJOL_33KV | 15:31 | 15:40 | 0:09 | TRANSFORMER FAULT |

| 85 1: 86 1: 87 1: 88 1: 89 1: 90 1: 91 1: 92 1: | 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 | BAGALKOT BAGALKOT BAGALKOT BAGALKOT BAGALKOT BAGALKOT | 110 110 110 110 | 110/11,HV2 110/33KV,HV4 110/33KV,HV4 | SUPPLY_33KV,KARJOL_33KV MAMADPURA_110 ZALKI_110 | 14:01 | 14:53 | 0:52 | LINE CLEAR AVAILED |
|--|--|---|--------------------------|--|---|-------|-------|-------|--------------------|
| 85 1: 86 1: 87 1: 88 1: 89 1: 90 1: 91 1: 92 1: | 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 | BAGALKOT BAGALKOT BAGALKOT BAGALKOT | 110 110 110 | 110/33KV,HV4 | - | | | 0.02 | |
| 86 11 87 1 88 12 89 11 90 12 91 11 92 12 | 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 | BAGALKOT BAGALKOT BAGALKOT | 110 110 | | · · · | 9:02 | 9:06 | 0:04 | TRANSFORMER FAULT |
| 87 11 88 11 89 11 90 11 91 11 92 11 | 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 17-Oct-18 | BAGALKOT BAGALKOT BAGALKOT | 110 | | ZALKI_110 | 17:52 | 17:59 | 0:07 | TRANSFORMER FAULT |
| 89 17 90 17 91 17 92 17 | 17-Oct-18 17-Oct-18 17-Oct-18 | BAGALKOT BAGALKOT | 440 | VAJRAMATTI 220-J K CEMENT | VAJRAMATTI 220 | 10:20 | 10:38 | 0:18 | LINE FAULT |
| 89 17 90 17 91 17 92 17 | 17-Oct-18 17-Oct-18 17-Oct-18 | BAGALKOT | 110 | SOVEREIGN-TERDAL | TERDAL_110 | 14:45 | 18:30 | 3:45 | LINE CLEAR AVAILED |
| 90 17 91 17 92 17 | 17-Oct-18 17-Oct-18 | | 110 | 110/33KV,HV2 | HUBLI _220 | 10:05 | 14:55 | 4:50 | LINE CLEAR AVAILED |
| 92 17 | | BAGALKOT | 220 | HUBLI -NARENDRA1 | HUBLI_220 | 8:32 | 13:38 | 5:06 | NBFC ISSUED |
| | | BAGALKOT | 220 | HUBLI-NAGJHARI2 | HUBLI_220 | 10:31 | 16:32 | 6:01 | HAND TRIPPED |
| 02 4 | 17-Oct-18 | BAGALKOT | 220 | SHARAVATHI 1-SIRSI 220 | SIRSI_220 | 10:14 | 14:04 | 3:50 | HAND TRIPPED |
| 93 17 | 17-Oct-18 | BAGALKOT | 220 | SHARAVATHI 2-SIRSI 220 | SIRSI_220 | 0:00 | 14:46 | 14:46 | LINE CLEAR AVAILED |
| 94 17 | 17-Oct-18 | BAGALKOT | 110 | SHIRAHATTI-LAXMESWAR | LAXMESWAR_110 | 10:26 | 10:42 | 0:16 | LINE FAULT |
| 95 17 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | SAIDAPUR_110 | 12:15 | 12:23 | 0:08 | TRANSFORMER FAULT |
| 96 17 | 17-Oct-18 | BAGALKOT | 110 | 110/33KV,HV2 | SADALAGA_110 | 13:17 | 13:48 | 0:31 | HAND TRIPPED |
| 97 17 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV3 | RATTIHALI_110 | 3:09 | 9:04 | 5:55 | TRANSFORMER FAULT |
| 98 17 | 17-Oct-18 | BAGALKOT | 110 | RANEBENNUR-HONNATTI | HONNATTI_110 | 12:26 | 12:49 | 0:23 | LINE FAULT |
| 99 17 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-1 | HIDIKAL_110 | 15:35 | 16:04 | 0:29 | HAND TRIPPED |
| 100 17 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-1 | KIRUVATTI_110 | 0:02 | 9:35 | 9:33 | TRANSFORMER FAULT |
| 101 17 | 17-Oct-18 | BAGALKOT | 110 | KUDACHI-UGARKHUD | UGAR KHUD_110 | 3:36 | 3:53 | 0:17 | LINE FAULT |
| 102 17 | 17-Oct-18 | BAGALKOT | 110 | LAXMESHWAR-BELLLATTI | BELLATTI_110 | 9:38 | 10:10 | 0:32 | LINE FAULT |
| 103 17 | 17-Oct-18 | BAGALKOT | 110 | 110/33KV,HV-3 | LOKAPUR_110 | 10:05 | 10:40 | 0:35 | TRANSFORMER FAULT |
| 104 17 | 17-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-2 | MALAGHAN_110 | 18:14 | 18:16 | 0:02 | TRANSFORMER FAULT |
| 105 17 | 17-Oct-18 | BAGALKOT | 66 | 66/11KV,HV-2 | HARIHAR-HOSPET_66 | 0:00 | 16:05 | 16:05 | LINE CLEAR AVAILED |
| 106 17 | 17-Oct-18 | BAGALKOT | 66 | 66/11KV,HV-4 | HARIHAR-HOSPET_66 | 16:05 | 17:15 | 1:10 | HAND TRIPPED |
| 107 18 | 18-Oct-18 | BAGALKOT | 220 | XELDOM-AMBEWADI | AMBEWADI_220 | 5:56 | 15:49 | 9:53 | LINE FAULT |
| 108 18 | 18-Oct-18 | BAGALKOT | 110 | 110/11KV, HV1 | BAGALKOT_110 | 8:22 | 8:49 | 0:27 | LINE CLEAR AVAILED |
| 109 18 | 18-Oct-18 | BAGALKOT | 220 | CHIKKODI-BELAGAUM1&2 | CHIKKODI_220 | 2:09 | 10:18 | 8:09 | HAND TRIPPED |
| 110 18 | 18-Oct-18 | BAGALKOT | 220 | CHIKKODI-BELAGAUM2 | CHIKKODI_220 | 20:56 | 23:59 | 3:03 | HAND TRIPPED |
| 111 18 | 18-Oct-18 | BAGALKOT | 110 | 220/110KV, LV2 | BELGAUM_220 | 2:24 | 5:01 | 2:37 | HAND TRIPPED |
| 112 18 | 18-Oct-18 | BAGALKOT | 220 | LINGAPUR-GADAG | GADAG_220 | 0:00 | 12:47 | 12:47 | LINE CLEAR AVAILED |
| 113 18 | 18-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | MUNDARAGI_110 | 13:56 | 15:39 | 1:43 | LINE CLEAR AVAILED |
| 114 18 | 18-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 5:26 | 5:40 | 0:14 | TRANSFORMER FAULT |
| 115 18 | 18-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 10:52 | 11:01 | 0:09 | TRANSFORMER FAULT |
| 116 18 | 18-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 11:48 | 11:56 | 0:08 | TRANSFORMER FAULT |
| 117 18 | 18-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 13:12 | 13:14 | 0:02 | TRANSFORMER FAULT |
| 118 18 | 18-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-1 | GUTTAL_110 | 2:12 | 8:59 | 6:47 | TRANSFORMER FAULT |
| 119 18 | 18-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-1 | GUTTAL_110 | 17:04 | 18:52 | 1:48 | HAND TRIPPED |
| 120 18 | 18-Oct-18 | BAGALKOT | 110 | 110/33KV,HV-3 | LOKAPUR_110 | 16:25 | 16:40 | 0:15 | TRANSFORMER FAULT |
| 121 18 | 18-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-2 | MALAGHAN_110 | 10:20 | 10:23 | 0:03 | TRANSFORMER FAULT |
| 122 19 | 19-Oct-18 | BAGALKOT | 110 | ATHANI220-ATHANI110 | ATHANI_110 | 16:08 | 17:13 | 1:05 | LINE FAULT |
| 123 19 | 19-Oct-18 | BAGALKOT | 110 | 110/11,HV-3 | BILAGI_110 | 21:15 | 21:27 | 0:12 | TRANSFORMER FAULT |
| 124 19 | 19-Oct-18 | BAGALKOT | 110 | 110/11,HV-1 | KALAGHATGI_110 | 12:20 | 15:08 | 2:48 | HAND TRIPPED |
| 125 19 | 19-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-1 | LOKAPUR_110 | 11:51 | 12:02 | 0:11 | HAND TRIPPED |

| 1906-116 SAGALIOT 200 PORDAS-AMERINAD AMERINAD 200 1505 | 126 | 19-Oct-18 | BAGALKOT | 110 | MK HUBLI-KITTUR | KITTUR_110 | 8:14 | 9:09 | 0:55 | LINE FAULT |
|--|-----|-----------|----------|-----|---------------------|--|-------|-------|-------|--------------------|
| 190 | | | | | | | | | | |
| 190 19-01-18 BAGALRIT 200 ARSS STREI-GADAG GADAG_220 GADAG_220 19-23 19-23 19-23 INFICITION AND ALL STREET 10-10 19-01-18 BAGALRIT 10-10 10-23W/HV4 ALSANG_33W/W ALSANG_33W/W B | | | | | | <u> </u> | | | | |
| 190 19 Oct 18 BACALKOT 110 110/38V/HV4 ALSKAFL 38V/ ANAKACI, | | | | | | | | | | |
| ALSANG, 33V POL-18 BROAUKOT 10 110/38V/HV4 PALSANG, 33V PALSANG, 33 | 127 | 17-001-18 | | 220 | ARESS STEEL-GADAG | <u> </u> | 0.00 | 12.23 | 12.23 | |
| ALSANG, 38V 100 10 | 130 | 19-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ALSANGI_33KV | 7:14 | 7:21 | 0:07 | TRANSFORMER FAULT |
| ALSANG SWARM 100 | 131 | 19-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110,DULKHED_33KV,NIVARAGI_33KV,H ALSANGI_33KV | 8:38 | 8:45 | 0:07 | TRANSFORMER FAULT |
| ASANGL_38Y ASA | 132 | 19-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ALSANGI_33KV | 12:01 | 12:22 | 0:21 | TRANSFORMER FAULT |
| ASANGLI | 133 | 19-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | | 12:30 | 12:34 | 0:04 | TRANSFORMER FAULT |
| 196 19-Oct-18 BAGALKOT 110 SIRS-KUMATA2 NO STATION INTERRUPTED 15:32 20:22 4:50 NBFC ISSUED | 134 | 19-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | | 15:53 | 16:01 | 0:08 | TRANSFORMER FAULT |
| 190-ct-18 BAGALKOT 110 KAGWAD-UGARKHUD UGARKHUD_110 14:23 14:30 0:07 TRANSFORMER FAULT | 135 | 19-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | ZALKI_110 | 16:50 | 16:58 | 0:08 | TRANSFORMER FAULT |
| 190c+18 BAGALKOT 110 110/11KV,HV2 UGARKHUD_110 14:23 14:30 0:07 TRANSFORMER FAULT | 136 | 19-Oct-18 | BAGALKOT | 110 | SIRSI-KUMATA2 | NO STATION INTERRUPTED | 15:32 | 20:22 | 4:50 | NBFC ISSUED |
| 19-0ct-18 BAGALKOT 110 110/11KV,HV2 UGARKHUD_110 16:08 16:20 0:12 TRANSFORMER FAULT | 137 | 19-Oct-18 | BAGALKOT | 110 | KAGWAD-UGARKHUD | UGARKHUD_110 | 6:48 | 6:56 | 0:08 | LINE FAULT |
| 140 19-Oct-18 BAGAIKOT 110 110/11KV,HV2 UGARKHUD_110 16:23 16:27 0:04 TRANSFORMER FAULT | 138 | 19-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | UGARKHUD_110 | 14:23 | 14:30 | 0:07 | TRANSFORMER FAULT |
| 141 20-Oct-18 BAGALKOT 110 110/11KY, HV1 GUTAL_110 11:23 13:08 1:45 LINE CLEAR AVAILED 142 20-Oct-18 BAGALKOT 110 110/11KY, HV1 GUTAL_110 11:23 13:08 1:45 LINE CLEAR AVAILED 143 20-Oct-18 BAGALKOT 110 110/11KY, HV1 HATTARGL_110 11:31 14:52 3:21 LINE CLEAR AVAILED 144 20-Oct-18 BAGALKOT 120 HUNGUND-KPINL(LIS) HUNGUND_110 11:47 12:23 0:36 HAND TRIPPED 145 20-Oct-18 BAGALKOT 120 NARENDRA AVBEWADI1 NARENDRA_220 12:24 15:55 3:31 LINE CLEAR AVAILED 147 20-Oct-18 BAGALKOT 110 110/11KY, HV2 MALGHAN(B)_110 11:28 16:23 4:55 TARANFORMER FAULT 148 20-Oct-18 BAGALKOT 110 110/11KY, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KY, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KY, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KY, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KY, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KY, HV2 BHUTNAL_110 8:25 11:44 3:22 NBFC ISSUED 150 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 13:30 14:05 0:35 HAND TRIPPED 152 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 13:30 14:05 0:35 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 13:00 14:06 14:08 0:02 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 13:00 14:06 0:35 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 19:00 10:45 0:05 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 19:00 10:45 0:05 TRANSF | 139 | 19-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | UGARKHUD_110 | 16:08 | 16:20 | 0:12 | TRANSFORMER FAULT |
| 142 20-Oct-18 BAGALKOT 110 110/11kV, HV1 GUTTAL_110 11:23 13:08 1:45 LINE CLEAR AVAILED 143 20-Oct-18 BAGALKOT 110 110/11kV, HV1 HATTARGL_110 11:31 14:52 3:21 LINE CLEAR AVAILED 144 20-Oct-18 BAGALKOT 20 NARENDRA-AMBEWADI1 NARENDRA-20 12:24 15:55 3:31 LINE CLEAR AVAILED 145 20-Oct-18 BAGALKOT 20 NARENDRA-AMBEWADI1 NARENDRA-20 12:24 15:55 3:31 LINE CLEAR AVAILED 146 20-Oct-18 BAGALKOT 110 110/11kV, HV2 MALGHAN(B)_110 11:28 16:23 4:55 TRANSFORMER FAULT 147 20-Oct-18 BAGALKOT 110 110/11kV, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 148 20-Oct-18 BAGALKOT 110 110/11kV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11kV, HV2 BHUTNAL_110 12:10 2:10 2:12 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11kV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 JOGIGE-SIRS SIRSI_110 13:30 14:06 0:36 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JI0/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 J10/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 J10/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 J10/33KV,HV4 ZALKI_110 9:31 9:20 0:07 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 J10/33KV,HV4 ZALKI_110 9:31 9:20 0:07 TRANSFORMER FAULT | 140 | 19-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | UGARKHUD_110 | 16:23 | 16:27 | 0:04 | TRANSFORMER FAULT |
| 143 20-Oct-18 BAGALKOT 110 110/11KV, HV1 HATTARGI_110 11:31 14:52 3:21 LINE CLEAR AVAILED 144 20-Oct-18 BAGALKOT 110 HUNGUND-KPINI(LIS) HUNGUND_110 11:47 12:23 0:36 HAND TRIPPED 145 20-Oct-18 BAGALKOT 220 NARENDRA-AMBEWADI1 NARENDRA_220 12:24 15:55 3:31 LINE CLEAR AVAILED 146 20-Oct-18 BAGALKOT 110 110/11KV, HV2 MALGHANB]_110 11:28 16:23 4:55 TRANSFORMER FAULT 147 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 148 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 13:30 14:05 0:35 HAND TRIPPED 152 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 156 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 157 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 158 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 16:04 1 | 141 | 20-Oct-18 | BAGALKOT | 220 | AMBEWADI-NARENDRA2 | AMBEWADI_220 | 8:47 | 12:18 | 3:31 | NBFC ISSUED |
| 144 20-Oct-18 BAGALKOT 110 HUNGUND-KPINL(LIS) HUNGUND_110 11:47 12:23 0:36 HAND TRIPPED 145 20-Oct-18 BAGALKOT 220 NARENDRA-MBEWADI1 NARENDRA_220 12:24 15:55 3:31 LINE CLEAR AVAILED 146 20-Oct-18 BAGALKOT 110 110/11KV, HV2 MAIGHAN(B)_110 11:28 16:23 4:55 TRANSFORMER FAULT 147 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 148 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:05 0:35 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:06 0:36 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG3*KVHV4 ZALKI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 JOG3*KVHV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 JIO/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 JIO/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 JIO/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 JIO/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 JIO/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 JIO/33KV,HV4 ZALKI_110 10:03 10:16 0:05 TRANSFORMER FAULT 150 20-Oct-18 BAGA | 142 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV, HV1 | GUTTAL_110 | 11:23 | 13:08 | 1:45 | LINE CLEAR AVAILED |
| 145 20-Oct-18 BAGALKOT 220 NARENDRA-AMBEWADI1 NARENDRA_220 12:24 15:55 3:31 LINE CLEAR AVAILED 146 20-Oct-18 BAGALKOT 110 110/11KV, HV2 MALGHAN(B]_110 11:28 16:23 4:55 TRANSFORMER FAULT 147 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 148 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRS-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 JOGL&-SIRSI SIRSI_110 13:30 14:05 0:35 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 SIRS-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 10:40 10:45 0:05 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 120 110/33KV,HV4 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 161 20-Oct-18 BAGALKOT 20 SHAR | 143 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV, HV1 | HATTARGI_110 | 11:31 | 14:52 | 3:21 | LINE CLEAR AVAILED |
| 146 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 148 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 153 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:05 0:35 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 0:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:20 9:49 0:29 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/33KV,HV4 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 HUBLIT&2-SIRSI SIRSI_220 9:55 18:57 9:01 HAND TRIPPED 163 20-Oct-18 BAGALKOT 220 HUBLIT&2-SIRSI | 144 | 20-Oct-18 | BAGALKOT | 110 | HUNGUND-KPJNL(LIS) | HUNGUND_110 | 11:47 | 12:23 | 0:36 | HAND TRIPPED |
| 147 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 11:49 11:51 0:02 TRANSFORMER FAULT 148 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 15:10 2:02 NBFC ISSUED 15:10 2:03 14:05 0:05 NBFC ISSUED 15:10 2:00-0ct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 15:10 13:30 14:05 0:35 HAND TRIPPED 15:10 13:30 14:05 0:36 HAND TRIPPED 15:10 10:05 13:30 14:05 0:36 HAND TRIPPED 15:10 13:30 14:05 14:08 0:02 HAND TRIPPED 15:10 | 145 | 20-Oct-18 | BAGALKOT | 220 | NARENDRA-AMBEWADI1 | NARENDRA_220 | 12:24 | 15:55 | 3:31 | LINE CLEAR AVAILED |
| 148 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 15:53 15:55 0:02 TRANSFORMER FAULT 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:05 0:36 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:40 10:45 0:05 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGON_110 12:05 13:01 0:56 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 162 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 163 20-Oct-18 BAGALKOT 120 NAGIHARI1-HUBLI HUBLI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI\$\frac{1}{1}\$ SHIRGOR SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI\$\frac{1}{1}\$ SHIRGOR SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI\$\frac{1}{1}\$ SHIRGOR SIRSI_22 | 146 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV, HV2 | MALGHAN(B)_110 | 11:28 | 16:23 | 4:55 | TRANSFORMER FAULT |
| 149 20-Oct-18 BAGALKOT 110 110/11KV, HV2 BHUTNAL_110 2:10 2:12 0:02 TRANSFORMER FAULT 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:05 0:35 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 20 NAGIHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHIB&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 SHARAVATHIB&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 SHARAVATHIB&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 SHARAVATHIB&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 SHARAVATHIB&2-SIRSI SIRSI_220 9:56 18:57 9 | 147 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV, HV2 | BHUTNAL_110 | 11:49 | 11:51 | 0:02 | TRANSFORMER FAULT |
| 150 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 8:22 11:44 3:22 NBFC ISSUED 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:05 0:35 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 110/11KV,HV2 SIRSI_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 0:57 7:00 0:03 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 0:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 165 20-Oct-18 BAGALKOT 220 HUBLI&2-SIRSI SIRSI_220 9:55 18:57 9:01 HAND TRIPPED 165 20-Oct-18 BAGALKOT 220 HUBLI&2-SIRSI SIRSI_220 9:55 18:57 9:01 HAND TRIPPED 166 20-Oct-18 BAGALKOT 220 HUBLI&2-SIRSI SIRSI_220 9:55 18:57 9:01 HAND TRIPPED 167 40-Oct-18 BAGALKOT 220 HUBLI&2-SIRSI SIRSI_220 9:55 18:57 | 148 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV, HV2 | BHUTNAL_110 | 15:53 | 15:55 | 0:02 | TRANSFORMER FAULT |
| 151 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA1 KUMATA_110 8:45 11:42 2:57 NBFC ISSUED 152 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:05 0:35 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 110/11KV,HV2 SIRSI_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI_4U KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 | 149 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV, HV2 | BHUTNAL_110 | 2:10 | 2:12 | 0:02 | TRANSFORMER FAULT |
| 152 20-Oct-18 BAGALKOT 110 JOG1&2-SIRSI SIRSI_110 13:30 14:05 0:35 HAND TRIPPED 153 20-Oct-18 BAGALKOT 110 110/11KV,HV2 SIRSI_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 9:53 19:01 9:08 HAND TRIPPED 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 165 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 166 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 167 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 168 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 169 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 | 150 | 20-Oct-18 | BAGALKOT | 110 | SIRSI-KUMATA2 | KUMATA_110 | 8:22 | 11:44 | 3:22 | NBFC ISSUED |
| 153 20-Oct-18 BAGALKOT 110 110/11KV,HV2 SIRSI_110 13:30 14:06 0:36 HAND TRIPPED 154 20-Oct-18 BAGALKOT 110 SIRSI_HUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/13KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SAN | 151 | 20-Oct-18 | BAGALKOT | 110 | SIRSI-KUMATA1 | KUMATA_110 | 8:45 | 11:42 | 2:57 | NBFC ISSUED |
| 154 20-Oct-18 BAGALKOT 110 SIRSI-KUMATA2 KUMATA_110 14:06 14:08 0:02 HAND TRIPPED 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 165 20-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 165 20-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 166 20-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 167 40-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 168 20-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 169 40-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 160 40-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED 161 40-Oct-18 BAGALKOT 220 HUBLIS2-SIRSI SIRSI_220 9:56 18:57 9: | 152 | 20-Oct-18 | BAGALKOT | 110 | JOG1&2-SIRSI | SIRSI_110 | 13:30 | 14:05 | 0:35 | HAND TRIPPED |
| 155 20-Oct-18 BAGALKOT 110 JOG2-SIRSI SIRSI_110 16:49 23:59 7:10 LINE FAULT 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI | 153 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | SIRSI_110 | 13:30 | 14:06 | 0:36 | HAND TRIPPED |
| 156 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 9:13 9:20 0:07 TRANSFORMER FAULT 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI <td>154</td> <td>20-Oct-18</td> <td>BAGALKOT</td> <td>110</td> <td>SIRSI-KUMATA2</td> <td>KUMATA_110</td> <td>14:06</td> <td>14:08</td> <td>0:02</td> <td>HAND TRIPPED</td> | 154 | 20-Oct-18 | BAGALKOT | 110 | SIRSI-KUMATA2 | KUMATA_110 | 14:06 | 14:08 | 0:02 | HAND TRIPPED |
| 157 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 10:40 10:45 0:05 TRANSFORMER FAULT 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI | 155 | 20-Oct-18 | BAGALKOT | 110 | JOG2-SIRSI | SIRSI_110 | 16:49 | 23:59 | 7:10 | LINE FAULT |
| 158 20-Oct-18 BAGALKOT 110 110/33KV,HV4 ZALKI_110 6:57 7:00 0:03 TRANSFORMER FAULT 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED | 156 | 20-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 9:13 | 9:20 | 0:07 | TRANSFORMER FAULT |
| 159 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SHIRGOAN_110 12:05 13:01 0:56 HAND TRIPPED 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED | 157 | 20-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 10:40 | 10:45 | 0:05 | TRANSFORMER FAULT |
| 160 20-Oct-18 BAGALKOT 110 110/11KV,HV1 SANKESHWAR_110 9:20 9:49 0:29 HAND TRIPPED 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED | 158 | 20-Oct-18 | BAGALKOT | 110 | 110/33KV,HV4 | ZALKI_110 | 6:57 | 7:00 | 0:03 | TRANSFORMER FAULT |
| 161 20-Oct-18 BAGALKOT 110 110/33KV,HV3 SANKESHWAR_110 10:03 10:18 0:15 HAND TRIPPED 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED | 159 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | SHIRGOAN_110 | 12:05 | 13:01 | 0:56 | HAND TRIPPED |
| 162 20-Oct-18 BAGALKOT 220 NAGJHARI1-HUBLI HUBLI_220 10:38 10:50 0:12 LINE FAULT 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED | 160 | 20-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | SANKESHWAR_110 | 9:20 | 9:49 | 0:29 | HAND TRIPPED |
| 163 20-Oct-18 BAGALKOT 220 SHARAVATHI1&2-SIRSI SIRSI_220 9:53 19:01 9:08 HAND TRIPPED 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED | 161 | 20-Oct-18 | BAGALKOT | 110 | 110/33KV,HV3 | SANKESHWAR_110 | 10:03 | 10:18 | 0:15 | HAND TRIPPED |
| 164 20-Oct-18 BAGALKOT 220 HUBLI1&2-SIRSI SIRSI_220 9:56 18:57 9:01 HAND TRIPPED | 162 | 20-Oct-18 | BAGALKOT | 220 | NAGJHARI1-HUBLI | HUBLI_220 | 10:38 | 10:50 | 0:12 | LINE FAULT |
| | 163 | 20-Oct-18 | BAGALKOT | 220 | SHARAVATHI1&2-SIRSI | SIRSI_220 | 9:53 | 19:01 | 9:08 | HAND TRIPPED |
| 165 21-Oct-18 BAGALKOT 110 110/11KV, HV1 BILAGI_110 10:09 10:44 0:35 LINE CLEAR AVAILED | 164 | 20-Oct-18 | BAGALKOT | 220 | HUBLI1&2-SIRSI | SIRSI_220 | 9:56 | 18:57 | 9:01 | HAND TRIPPED |
| | 165 | 21-Oct-18 | BAGALKOT | 110 | 110/11KV, HV1 | BILAGI_110 | 10:09 | 10:44 | 0:35 | LINE CLEAR AVAILED |

| 166 | 21-Oct-18 | BAGALKOT | 110 | BELGAUM220-ANKALGI | ANKALGI_110,HUDLI_110 | 11:18 | 17:04 | 5:46 | LINE CLEAR AVAILED |
|-----|-----------|----------|-----|-----------------------------|--------------------------------------|-------|-------|-------|--------------------|
| 167 | 21-Oct-18 | BAGALKOT | 220 | NAGJHARI2-BIDNAL | BIDNAL_220 | 11:30 | 12:09 | 0:39 | LINE FAULT |
| 168 | 21-Oct-18 | BAGALKOT | 110 | SHIVKUMAR SUGARS-HIREBEVNUR | HIREBEVNUR_110 | 12:06 | 12:57 | 0:51 | HAND TRIPPED |
| 169 | 21-Oct-18 | BAGALKOT | 110 | SIRSI-KUMTA1 | KUMTA_110 | 0:00 | 19:22 | 19:22 | LINE CLEAR AVAILED |
| 170 | 21-Oct-18 | BAGALKOT | 110 | JOG1-SIRSI | SIRSI_110 | 11:20 | 11:38 | 0:18 | NBFC ISSUED |
| 171 | 21-Oct-18 | BAGALKOT | 110 | JOG2-SIRSI | SIRSI_110 | 0:00 | 11:48 | 11:48 | LINE CLEAR AVAILED |
| 172 | 21-Oct-18 | BAGALKOT | 220 | NARENDRA1-HUBLI | HUBLI_220 | 5:32 | 9:01 | 3:29 | LINE FAULT |
| 173 | 21-Oct-18 | BAGALKOT | 220 | NAGJHARI3-HUBLI | HUBLI_220 | 17:31 | 23:59 | 6:28 | LINE FAULT |
| 174 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | ACHANUR_110 | 18:33 | 18:45 | 0:12 | LOAD CURTAILMENT |
| 175 | 22-Oct-18 | BAGALKOT | 110 | ATHANI220-AIGALI | AIGALI_110,KARIMASUTI_110,SATTI_110 | 14:03 | 14:08 | 0:05 | LINE FAULT |
| 176 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV2 | AINAPUR_110 | 18:33 | 18:36 | 0:03 | LOAD CURTAILMENT |
| 177 | 22-Oct-18 | BAGALKOT | 220 | RAVIURJA1-ATHANI | ATHANI_220 | 14:03 | 14:10 | 0:07 | LINE FAULT |
| 178 | 22-Oct-18 | BAGALKOT | 110 | 220/110KV,LV1 | ATHANI_220 | 14:03 | 14:06 | 0:03 | TRANSFORMER FAULT |
| 179 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | ATHANI_220 | 14:03 | 14:08 | 0:05 | TRANSFORMER FAULT |
| 180 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | ATHARGA_110 | 18:34 | 18:52 | 0:18 | LOAD CURTAILMENT |
| 181 | 22-Oct-18 | BAGALKOT | 220 | CHIKKODI2-BELGAUM | BELGAUM_220 | 7:32 | 17:03 | 9:31 | HAND TRIPPED |
| 182 | 22-Oct-18 | BAGALKOT | 220 | CHIKKODI1-BELGAUM | BELGAUM_220 | 7:36 | 17:03 | 9:27 | HAND TRIPPED |
| 183 | 22-Oct-18 | BAGALKOT | 110 | NARENDRA220- BELUR 2 | BELUR_110 (NO STATION INTERRUPTED) | 22:18 | 22:19 | 0:01 | HAND TRIPPED |
| 184 | 22-Oct-18 | BAGALKOT | 220 | NAGJHARI2-BIDNAL | BIDNAL_220 | 13:01 | 16:02 | 3:01 | LINE FAULT |
| 185 | 22-Oct-18 | BAGALKOT | 220 | BELGAUM-CHIKKODI | CHIKKODI_220 | 7:33 | 18:09 | 10:36 | HAND TRIPPED |
| 186 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV4 | GAJENDRAGAD_110 | 18:33 | 19:11 | 0:38 | LOAD CURTAILMENT |
| 187 | 22-Oct-18 | BAGALKOT | 110 | ATHANI220-HALIYAL | HALIYAL_110 | 14:03 | 14:28 | 0:25 | LINE FAULT |
| 188 | 22-Oct-18 | BAGALKOT | 110 | MAHALINGAPUR- HIDIKAL | HIDIKAL_110 | 5:52 | 8:35 | 2:43 | LOAD CURTAILMENT |
| 189 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-1 | HIDIKAL_110 | 16:22 | 16:27 | 0:05 | HAND TRIPPED |
| 190 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-3 | HIDIKAL_110 | 18:34 | 18:46 | 0:12 | LOAD CURTAILMENT |
| 191 | 22-Oct-18 | BAGALKOT | 110 | MAHALINGPUR220-HIDIKAL | HIDIKAL_110 | 5:37 | 5:52 | 0:15 | LINE FAULT |
| 192 | 22-Oct-18 | BAGALKOT | 110 | 110/33KV,HV-1 | JAMAKHANDI_110 | 19:46 | 19:49 | 0:03 | HAND TRIPPED |
| 193 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV-2A | JAMAKHANDI_110 | 19:46 | 19:50 | 0:04 | HAND TRIPPED |
| 194 | 22-Oct-18 | BAGALKOT | 110 | 110/33KV,HV-2 | JAMAKHANDI_110 | 19:46 | 19:49 | 0:03 | HAND TRIPPED |
| 195 | 22-Oct-18 | BAGALKOT | 220 | KUDACHI-MAHALINGAPUR | KUDACHI_220 | 16:07 | 17:45 | 1:38 | LINE CLEAR AVAILED |
| 196 | 22-Oct-18 | BAGALKOT | 220 | KUDACHI-ATHANI | KUDACHI_220 | 17:53 | 19:05 | 1:12 | LINE CLEAR AVAILED |
| 197 | 22-Oct-18 | BAGALKOT | 110 | KUMATA-SIRSI 1 | KUMATA_110 | 14:56 | 23:59 | 9:03 | LOAD CHANGEOVER |
| 198 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | LAXMESHWAR_110 | 18:32 | 18:42 | 0:10 | LOAD CURTAILMENT |
| 199 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV ,HV2 | MALGHAN_110(B) | 12:08 | 12:42 | 0:34 | LINE CLEAR AVAILED |
| 200 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV ,HV2 | MALGHAN(B)_110 | 17:08 | 17:35 | 0:27 | LINE CLEAR AVAILED |
| 201 | 22-Oct-18 | BAGALKOT | 220 | NARENDRA -BELGAUM 1 | NARENDRA_220 | 12:24 | 16:53 | 4:29 | HAND TRIPPED |
| 202 | 22-Oct-18 | BAGALKOT | 110 | JOG 1-SIRSI | SIRSI_110(NO STATION INTERRUPTED) | 12:23 | 12:44 | 0:21 | HAND TRIPPED |
| 203 | 22-Oct-18 | BAGALKOT | 110 | ATHANI220-TAUSHI | TAUSHI_110 | 14:03 | 14:07 | 0:04 | LINE FAULT |
| 204 | 22-Oct-18 | BAGALKOT | 110 | KUDACHI-TERADAL | TERADAL_110 | 11:34 | 15:37 | 4:03 | LINE CLEAR AVAILED |
| 205 | 22-Oct-18 | BAGALKOT | 110 | MAHALINGPUR220-TERDAL | TERDAL_110 | 12:05 | 12:16 | 0:11 | LINE FAULT |
| 206 | 22-Oct-18 | BAGALKOT | 110 | MAHALINGPUR220-TERDAL | TERDAL_110 | 12:29 | 14:31 | 2:02 | HAND TRIPPED |
| 207 | 22-Oct-18 | BAGALKOT | 110 | 110/33KV,HV1 | TIKOTA_110,BIJJARAGI_33KV | 18:34 | 18:44 | 0:10 | LOAD CURTAILMENT |
| 208 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | TODALBAGI_110 | 17:00 | 17:24 | 0:24 | LOAD CURTAILMENT |

| 209 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | UGAR KHUD_110 | 10:54 | 11:00 | 0:06 | LINE CLEAR AVAILED |
|-----|-----------|-----------|-----|--------------------------------------|--|-------|-------|------|---------------------|
| 210 | 22-Oct-18 | BAGALKOT | 110 | 110/11KV,HV1 | UGAR KHUD_110 | 15:06 | 15:13 | 0:07 | TRANSFORMER FAULT |
| 211 | 16-Oct-18 | BANGALORE | 66 | AUSTIN TOWN - KORMANGALA | KORMANGALA | 6:03 | 6:43 | 0:39 | LINE FAULT |
| 212 | 16-Oct-18 | BANGALORE | 66 | AUSTIN TOWN - KORMANGALA | NO STATION AFFECTED | 6:03 | 12:10 | 6:07 | LINE FAULT |
| 213 | 16-Oct-18 | BANGALORE | 66 | HV2 | ELECTRONIC CITY P2 S2 | 18:15 | 18:18 | 0:03 | TRANSFORMER FAULT |
| 214 | 16-Oct-18 | BANGALORE | 66 | HV2 | KORMANGALA | 6:03 | 6:20 | 0:16 | MAIN SUPPLY FAILURE |
| 215 | 16-Oct-18 | BANGALORE | 66 | TK HALLI 220 - HAROHALLI 2 | VR DODDI | 19:38 | 19:52 | 0:13 | LINE FAULT |
| 216 | 16-Oct-18 | BANGALORE | 66 | HV1 | YELLARBANDE | 11:44 | 11:51 | 0:06 | LINE CLEAR AVAILED |
| 217 | 16-Oct-18 | BANGALORE | 66 | HV2 | CHIKKENAHALLI | 19:50 | 20:25 | 0:35 | TRANSFORMER FAULT |
| 218 | 16-Oct-18 | BANGALORE | 66 | CHINTAMANI 220 - LAKSHMIPURA | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI | 6:35 | 6:46 | 0:10 | LINE FAULT |
| 219 | 16-Oct-18 | BANGALORE | 66 | CHINTAMANI 220 - LAKSHMIPURA | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI | 11:47 | 11:52 | 0:04 | LINE FAULT |
| 220 | 16-Oct-18 | BANGALORE | 66 | CHINTAMANI 220 - LAKSHMIPURA | LAKSHMIPURA, ADDAGAL, SOMAYAJANAHALLI | 11:59 | 12:09 | 0:10 | LINE FAULT |
| 221 | 16-Oct-18 | BANGALORE | 66 | HV1 | HAROBELE | 16:35 | 16:57 | 0:22 | TRANSFORMER FAULT |
| 222 | 16-Oct-18 | BANGALORE | 66 | HV1 | HAROBELE | 16:58 | 17:38 | 0:39 | TRANSFORMER FAULT |
| 223 | 16-Oct-18 | BANGALORE | 66 | HV1 | HAROBELE | 17:38 | 18:00 | 0:21 | TRANSFORMER FAULT |
| 224 | 16-Oct-18 | BANGALORE | 66 | KODIHALLI - HUNSENAHALLI | HUNSENAHALLI, BIJJALLI | 19:50 | 20:06 | 0:16 | LINE FAULT |
| 225 | 16-Oct-18 | BANGALORE | 66 | HV2 | S M MANGALA | 13:07 | 13:40 | 0:32 | LINE CLEAR AVAILED |
| 226 | 16-Oct-18 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA | 19:53 | 20:14 | 0:21 | LINE FAULT |
| 227 | 17-Oct-18 | BANGALORE | 66 | CHINTAMANI 220 - GANJIGUNTE 1 | GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 17:59 | 18:06 | 0:06 | LINE FAULT |
| 228 | 17-Oct-18 | BANGALORE | 66 | CHINTAMANI 220 - TALAGAWARA | TALAGAWARA, CHEEMANGALA, Y HUNSENAHALLI | 15:34 | 15:40 | 0:06 | LINE FAULT |
| 229 | 17-Oct-18 | BANGALORE | 66 | GANJIGUNTE - CHINTAMANI 2 | GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 17:59 | 18:06 | 0:06 | LINE FAULT |
| 230 | 17-Oct-18 | BANGALORE | 66 | HV2 | CHIKKENAHALLI | 9:00 | 9:05 | 0:05 | TRANSFORMER FAULT |
| 231 | 17-Oct-18 | BANGALORE | 66 | DB PURA 220 - DG 1 | AIR (EHT) | 20:11 | 20:33 | 0:22 | LINE FAULT |
| 232 | 17-Oct-18 | BANGALORE | 66 | DB PURA 220 - DG 1 | AIR (EHT) | 20:34 | 23:55 | 3:21 | LINE FAULT |
| 233 | 17-Oct-18 | BANGALORE | 66 | HAROBELE - KANAKAPURA 220 | HAROBELE, HUKUNDA, KODIHALLI, HUNSENAHALLI | 0:25 | 0:30 | 0:04 | LINE CLEAR AVAILED |
| 234 | 17-Oct-18 | BANGALORE | 66 | HV1 | HAROBELE | 0:25 | 0:51 | 0:26 | LINE CLEAR AVAILED |
| 235 | 17-Oct-18 | BANGALORE | 220 | GOWRIBIDANUR 220 - KIADB DB PURA 220 | KIADB DB PURA 220 | 18:20 | 18:45 | 0:25 | LINE FAULT |
| 236 | 17-Oct-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - AFTL SOLAR (IPP) | NO STATION AFFECTED | 18:20 | 18:45 | 0:25 | LINE FAULT |
| 237 | 17-Oct-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - PERESANDRA | PERESANDRA, MANDIKALLU, D PALYA, GUDIBANDE | 18:30 | 18:50 | 0:20 | LINE FAULT |
| 238 | 17-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS | 7:03 | 7:31 | 0:28 | LINE FAULT |
| | 17-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS | 7:31 | 7:51 | 0:19 | LINE FAULT |
| 239 | 17-001-10 | | | | | | | | |
| 239 | | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS | 7:57 | 8:15 | 0:17 | LINE FAULT |

| 242 | 17-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS | 19:26 | 20:22 | 0:55 | LINE FAULT |
|-----|-----------|-----------|----|-----------------------------------|--|-------|-------|------|---------------------|
| 243 | 17-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS | 20:22 | 20:40 | 0:17 | LINE FAULT |
| 244 | 17-Oct-18 | BANGALORE | 66 | VIDYANAGAR - HOSKOTE 220 | VIDYANAGAR | 20:40 | 21:05 | 0:25 | MAIN SUPPLY FAILURE |
| 245 | 17-Oct-18 | BANGALORE | 66 | HENNUR CROSS - SAHAKARINAGAR | HENNUR CROSS | 11:10 | 11:15 | 0:05 | LOAD CHANGEOVER |
| 246 | 17-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 23:42 | 23:53 | 0:10 | LINE CLEAR AVAILED |
| 247 | 17-Oct-18 | BANGALORE | 66 | HV1 | JANGAMAKOTE | 1:08 | 1:18 | 0:09 | TRANSFORMER FAULT |
| 248 | 17-Oct-18 | BANGALORE | 66 | BAGHMANE WORLD TECH PARK - HAL 2 | NGEF, NGEF (EHT) | 11:46 | 11:52 | 0:06 | LINE CLEAR AVAILED |
| 249 | 17-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), | 22:28 | 23:59 | 1:30 | LINE FAULT |
| 250 | 17-Oct-18 | BANGALORE | 66 | HAL 220 - HOODY 2 | BAGMANE TECH PARK, GTRE (EHT) | 12:47 | 13:17 | 0:30 | LINE CLEAR AVAILED |
| 251 | 17-Oct-18 | BANGALORE | 66 | HSR LAYOUT 220 - KORMANGALA | KORMANGALA, K & C VALLEY, NAL (EHT) | 15:57 | 16:21 | 0:24 | LINE FAULT |
| 252 | 17-Oct-18 | BANGALORE | 66 | HV2 | KUMBALAGODU | 12:40 | 13:15 | 0:34 | LINE CLEAR AVAILED |
| 253 | 17-Oct-18 | BANGALORE | 66 | NRS 220 - TELECOM LAYOUT 2 | TELECOM LAYOUT | 18:49 | 19:21 | 0:32 | LINE CLEAR AVAILED |
| 254 | 17-Oct-18 | BANGALORE | 66 | SIR MV LAYOUT - VRISHBHAVATHI 220 | SIR MV LAYOUT, KENGERI SATELLITE TOWN | 22:30 | 23:00 | 0:30 | LINE FAULT |
| 255 | 17-Oct-18 | BANGALORE | 66 | SUBRAMANYAPURA 220 - REMCO 2 | GLOBAL VILLAGE (EHT) | 7:11 | 7:22 | 0:10 | LOAD CHANGEOVER |
| 256 | 18-Oct-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 7 | KANASWADI | 17:49 | 22:01 | 4:11 | LINE FAULT |
| 257 | 18-Oct-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 8 | RAJANKUNTE | 17:49 | 18:36 | 0:46 | LINE FAULT |
| 258 | 18-Oct-18 | BANGALORE | 66 | HV2 | THIMMAMPALLI | 17:07 | 17:29 | 0:21 | TRANSFORMER FAULT |
| 259 | 18-Oct-18 | BANGALORE | 66 | HV1 | TUBUGERE | 20:09 | 20:19 | 0:10 | TRANSFORMER FAULT |
| 260 | 18-Oct-18 | BANGALORE | 66 | KEMBODI - KOLAR 220 | MUDIYANUR, H GOLLAHALLI, BAIRAKURU, NANGALI | 13:56 | 14:11 | 0:14 | LINE FAULT |
| 261 | 18-Oct-18 | BANGALORE | 66 | JIGANI 220 - JIGANI 66 | JIGANI 66 | 0:23 | 0:35 | 0:12 | LINE FAULT |
| 262 | 18-Oct-18 | BANGALORE | 66 | HAROBELE - KANAKAPURA 220 | HAROBELE, HUKUNDA, KODIHALLI | 16:25 | 16:50 | 0:25 | LINE FAULT |
| 263 | 18-Oct-18 | BANGALORE | 66 | KODIHALLI - HUNSENAHALLI | HUNSENAHALLI, BIJJALLI | 16:25 | 16:57 | 0:32 | LINE FAULT |
| 264 | 18-Oct-18 | BANGALORE | 66 | VIDYANAGAR - HENNUR CROSS | VIDYANAGAR | 0:15 | 0:20 | 0:05 | LOAD CHANGEOVER |
| 265 | 18-Oct-18 | BANGALORE | 66 | HENNUR CROSS - SAHAKARINAGAR | HENNUR CROSS | 0:20 | 0:25 | 0:05 | LOAD CHANGEOVER |
| 266 | 18-Oct-18 | BANGALORE | 66 | HV3 | CHIKKABALLAPURA I/A | 4:59 | 6:00 | 1:00 | TRANSFORMER FAULT |
| 267 | 18-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), | 0:01 | 0:05 | 0:03 | LINE CLEAR AVAILED |
| 268 | 18-Oct-18 | BANGALORE | 66 | A STATION 220 - A STATION 2 | A STATION 66 | 6:20 | 6:47 | 0:27 | LINE CLEAR AVAILED |
| 269 | 18-Oct-18 | BANGALORE | 66 | HV3 | A STATION 66 | 6:20 | 6:47 | 0:27 | MAIN SUPPLY FAILURE |
| 270 | 18-Oct-18 | BANGALORE | 66 | HV4 | A STATION 66 | 6:20 | 6:47 | 0:27 | MAIN SUPPLY FAILURE |
| 271 | 18-Oct-18 | BANGALORE | 66 | BG ROAD - JIGANI LINK ROAD | JIGANI LINK ROAD | 6:08 | 6:41 | 0:32 | LINE FAULT |
| 272 | 18-Oct-18 | BANGALORE | 66 | SOMANAHALLI 220 - JIGANI 2 | BG ROAD, JIGANI 66 | 6:08 | 6:36 | 0:27 | LINE FAULT |
| 273 | 18-Oct-18 | BANGALORE | 66 | HV2 | EPIP 220 | 18:49 | 21:26 | 2:37 | TRANSFORMER FAULT |
| 274 | 18-Oct-18 | BANGALORE | 66 | RAJANKUNTE - DB PURA 220 | RAJANKUNTE | 22:15 | 22:40 | 0:24 | LOAD CHANGEOVER |
| 275 | 19-Oct-18 | BANGALORE | 66 | HAL 220 - HOODY 1 | KADUBISANAHALLI, CESSNO, CESSNO (EHT), ISRO(EHT) | 12:34 | 13:43 | 1:08 | LINE CLEAR AVAILED |
| 276 | 19-Oct-18 | BANGALORE | 66 | KANAKAPURA 220 - RAMANAGARA | ALLIMARADANAHALLI, CHIKKENAHALLI, SHIVANAHALLI, CHANNAPATNA, SANKALGERE, BEVOOR, DASHAWARA | 9:09 | 9:19 | 0:10 | LINE FAULT |
| 277 | 19-Oct-18 | BANGALORE | 66 | SOMANAHALLI 220 - KUMBALAGODU | KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE | 10:40 | 11:11 | 0:30 | LINE FAULT |
| 278 | 19-Oct-18 | BANGALORE | 66 | SOMANAHALLI 220 - KUMBALAGODU | KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE | 11:24 | 12:42 | 1:18 | LINE FAULT |
| | | | | | • | | | | • |

| 279 | 19-Oct-18 | BANGALORE | 66 | KUMBALAGODU - KENGERI SATELLITE TOWN | KUMBALAGODU, PROVIDENT HOUSING, CHANDRAPPA CIRCLE | 16:48 | 16:50 | 0:02 | LOAD CHANGEOVER |
|-----|-----------|-----------|-----|--------------------------------------|--|-------|-------|------|---------------------|
| 280 | 19-Oct-18 | BANGALORE | 220 | HV4 | SRS PEENYA 220 | 22:47 | 23:30 | 0:42 | TRANSFORMER FAULT |
| 281 | 19-Oct-18 | BANGALORE | 220 | SRS PEENYA 220 - NRS 220 | NRS 220 | 22:52 | 23:59 | 1:06 | LINE FAULT |
| 282 | 19-Oct-18 | BANGALORE | 220 | NRS 220 - VRISHBHAVATHI 220 | NO STATIONS AFFECTED | 22:48 | 23:59 | 1:10 | LINE FAULT |
| 283 | 19-Oct-18 | BANGALORE | 66 | SRS PEENYA 220 - NELAKADERANAHALLI | NELAKADERANAHALLI | 22:47 | 23:31 | 0:43 | LINE FAULT |
| 284 | 19-Oct-18 | BANGALORE | 66 | SRS PEENYA 220 - GOKULA 1 | GOKULA, HMT (EHT), BEL (EHT) | 22:47 | 23:32 | 0:45 | LINE FAULT |
| 285 | 19-Oct-18 | BANGALORE | 66 | SRS PEENYA 220 - GOKULA 2 | GOKULA, HMT (EHT), BEL (EHT) | 22:47 | 23:32 | 0:45 | LINE FAULT |
| 286 | 19-Oct-18 | BANGALORE | 220 | NRS 220 - A STATION 220 | A STATION 220 | 22:52 | 23:00 | 0:07 | MAIN SUPPLY FAILURE |
| 287 | 19-Oct-18 | BANGALORE | 66 | A STATION 220 - A STATION 2 | A STATION 66 | 22:52 | 23:00 | 0:07 | MAIN SUPPLY FAILURE |
| 288 | 19-Oct-18 | BANGALORE | 66 | A STATION 220 - KANTEERAVA STADIUM | KANTEERAVA STADIUM | 22:52 | 23:00 | 0:07 | MAIN SUPPLY FAILURE |
| 289 | 19-Oct-18 | BANGALORE | 66 | HV3 | A STATION 66 | 22:52 | 23:00 | 0:07 | MAIN SUPPLY FAILURE |
| 290 | 19-Oct-18 | BANGALORE | 66 | HV4 | A STATION 66 | 22:52 | 23:00 | 0:07 | MAIN SUPPLY FAILURE |
| 291 | 19-Oct-18 | BANGALORE | 66 | GOKULA - MATHIKERE | GOKULA, HMT (EHT), BEL (EHT) | 23:45 | 23:50 | 0:05 | LOAD CHANGEOVER |
| 292 | 19-Oct-18 | BANGALORE | 66 | MATHIKERE - GOKULA | MATHIKERE | 22:47 | 23:10 | 0:22 | MAIN SUPPLY FAILURE |
| 293 | 19-Oct-18 | BANGALORE | 66 | MATHIKERE - HEBBAL 220 | MATHIKERE | 23:50 | 23:54 | 0:04 | LOAD CHANGEOVER |
| 294 | 19-Oct-18 | BANGALORE | 66 | RMV - GOKULA | RMV, TATA INSTITUTE (EHT) | 22:47 | 22:54 | 0:06 | MAIN SUPPLY FAILURE |
| 295 | 19-Oct-18 | BANGALORE | 66 | RMV - HEBBAL 220 | RMV, TATA INSTITUTE (EHT) | 23:32 | 23:54 | 0:22 | LOAD CHANGEOVER |
| 296 | 19-Oct-18 | BANGALORE | 66 | HV1 | NRS 220 | 22:52 | 23:59 | 1:06 | MAIN SUPPLY FAILURE |
| 297 | 19-Oct-18 | BANGALORE | 66 | HV3 | NRS 220 | 22:52 | 23:59 | 1:06 | MAIN SUPPLY FAILURE |
| 298 | 19-Oct-18 | BANGALORE | 66 | HV4 | NRS 220 | 22:52 | 23:59 | 1:06 | MAIN SUPPLY FAILURE |
| 299 | 19-Oct-18 | BANGALORE | 66 | HV5 | NRS 220 | 22:52 | 23:59 | 1:06 | MAIN SUPPLY FAILURE |
| 300 | 19-Oct-18 | BANGALORE | 66 | NRS 220 - TELECOM LAYOUT 2 | TELECOM LAYOUT | 22:52 | 23:59 | 1:06 | MAIN SUPPLY FAILURE |
| 301 | 19-Oct-18 | BANGALORE | 66 | NRS 220 - BRIGADE GATEWAY | BRIGADE GATEWAY | 22:52 | 23:59 | 1:06 | MAIN SUPPLY FAILURE |
| 302 | 19-Oct-18 | BANGALORE | 66 | NRS 220 - MYSORE ROAD 1 & 2 | VIJAYANAGARA | 22:52 | 23:59 | 1:06 | MAIN SUPPLY FAILURE |
| 303 | 19-Oct-18 | BANGALORE | 66 | CHINTAMANI 220 - GANJIGUNTE 2 | GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 0:50 | 1:05 | 0:15 | LINE FAULT |
| 304 | 19-Oct-18 | BANGALORE | 66 | GANJIGUNTE - CHINTAMANI 1 | GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 0:50 | 1:05 | 0:15 | LINE FAULT |
| 305 | 19-Oct-18 | BANGALORE | 66 | GANJIGUNTE - CHINTAMANI 2 | GANJIGUNTE, PALLICHERLU, DIBBURAHALLI, SADALI, JULUPALYA, SOMENAHALLI | 0:50 | 1:05 | 0:15 | LINE FAULT |
| 306 | 19-Oct-18 | BANGALORE | 66 | HULLENAHALLI - KUDURU | KUDURU | 14:33 | 15:11 | 0:38 | LINE CLEAR AVAILED |
| 307 | 19-Oct-18 | BANGALORE | 66 | KANASWADI - DB PURA 220 | KANASWADI | 7:39 | 7:45 | 0:05 | LOAD CHANGEOVER |
| 308 | 19-Oct-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 8 | RAJANKUNTE | 15:49 | 16:13 | 0:23 | LINE FAULT |
| 309 | 19-Oct-18 | BANGALORE | 66 | GOWRIBIDANUR 220 - BAGEPALLI 1 | VATADAHOSAHALLI, PATHPALYA, THIMAMPALLI, SOMANATHPURA | 5:35 | 5:50 | 0:15 | LINE FAULT |
| 310 | 19-Oct-18 | BANGALORE | 400 | NELAMANGALA 400 - HIRIYUR 2 | NO STATION AFFECTED | 2:53 | 7:47 | 4:54 | LINE FAULT |
| 311 | 20-Oct-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 3 | MANYATA TECH PARK | 14:18 | 14:42 | 0:24 | LINE FAULT |
| 312 | 20-Oct-18 | BANGALORE | 66 | DB PURA 220 - DG 1 | AIR (EHT) | 11:12 | 13:41 | 2:28 | LINE CLEAR AVAILED |
| 313 | 20-Oct-18 | BANGALORE | 66 | DB PURA 220 - DG 2 | GUNDAMGERE, DODDABELAVANGALA | 13:31 | 13:41 | 0:10 | LINE CLEAR AVAILED |
| 314 | 20-Oct-18 | BANGALORE | 66 | CHIKKENAHALLI - CHANNAPATNA | CHANNAPATNA, SHIVANAHALLI, DASHAWARA, SANKALGERE, BEVOOR | 14:57 | 15:10 | 0:13 | LINE CLEAR AVAILED |
| 315 | 20-Oct-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 6 | SOLADEVANAHALLI | 15:02 | 15:19 | 0:16 | LINE FAULT |
| 316 | 20-Oct-18 | BANGALORE | 66 | YELAHANKA 220 - LINE 6 | SOLADEVANAHALLI | 15:19 | 15:31 | 0:12 | LINE FAULT |

| | | | | | | - | | ı | Г |
|-----|-----------|------------------|-----|--|--|--------|-------|------|---------------------|
| 317 | 20-Oct-18 | BANGALORE | 66 | HV1 | HOSKOTE 66 | 13:00 | 13:08 | 0:08 | LINE CLEAR AVAILED |
| 318 | 20-Oct-18 | BANGALORE | 66 | HV1 | HOSKOTE 66 | 14:13 | 14:31 | 0:18 | LINE CLEAR AVAILED |
| 319 | 20-Oct-18 | BANGALORE | 66 | HV2 | HOSKOTE 66 | 1:06 | 2:50 | 1:43 | TRANSFORMER FAULT |
| 320 | 20-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 6:08 | 6:29 | 0:20 | LINE FAULT |
| 321 | 20-Oct-18 | BANGALORE | 66 | HULLENAHALLI - KUDUR | KUDUR | 13:13 | 15:07 | 1:54 | LINE CLEAR AVAILED |
| 322 | 20-Oct-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | MALUR I/A, JADIGENAHALLI, STAR PANEL(EHT) | 5:48 | 6:04 | 0:15 | LINE FAULT |
| 323 | 20-Oct-18 | BANGALORE | 66 | SOMAYAJANAHALLI - LAKSHMIPURA | SOMAYAJANAHALLI | 13:05 | 17:15 | 4:10 | LINE CLEAR AVAILED |
| 324 | 20-Oct-18 | BANGALORE | 66 | HV1 | TEMAGONDALU | 21:25 | 21:35 | 0:10 | TRANSFORMER FAULT |
| 325 | 20-Oct-18 | BANGALORE | 66 | ANJANAPURA - KHODAYS 220 | ANJANAPURA | 12:50 | 13:09 | 0:19 | LINE CLEAR AVAILED |
| 326 | 20-Oct-18 | BANGALORE | 66 | HV2 | BIDADI 220 | 12:42 | 13:49 | 1:07 | LINE CLEAR AVAILED |
| 327 | 20-Oct-18 | BANGALORE | 66 | BOODIGERE - BEGUR 220 | BOODIGERE | 11:29 | 11:37 | 0:08 | LOAD CHANGEOVER |
| 328 | 20-Oct-18 | BANGALORE | 66 | ELECTRONIC CITY P2 S2 - NAGANATHAPURA 220 | ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT) | 10:10 | 10:20 | 0:10 | LOAD CHANGEOVER |
| 329 | 20-Oct-18 | BANGALORE | 66 | ELECTRONIC CITY P2 S2 - ELECTRONIC CITY | ELECTRONIC CITY P2 S2 | 10:21 | 10:23 | 0:02 | LINE CLEAR AVAILED |
| 330 | 20-Oct-18 | BANGALORE | 66 | ELECTRONIC CITY P2 S2 - BIOCON(EHT) | BIOCON(EHT) | 10:21 | 11:00 | 0:39 | LINE CLEAR AVAILED |
| 331 | 20-Oct-18 | BANGALORE | 66 | ELECTRONIC CITY P2 S2 - TECH MAHINDRA(EHT) | TECH MAHINDRA(EHT) | 10:21 | 11:26 | 1:05 | LINE CLEAR AVAILED |
| 332 | 20-Oct-18 | BANGALORE | 66 | ELECTRONIC CITY P2 S2 - ELECTRONIC CITY | ELECTRONIC CITY P2 S2, BIOCON(EHT), TECH MAHINDRA(EHT) | 16:18 | 16:23 | 0:05 | LOAD CHANGEOVER |
| 333 | 20-Oct-18 | BANGALORE | 66 | HV2 | EPIP 220 | 15:30 | 17:38 | 2:07 | LINE CLEAR AVAILED |
| 334 | 20-Oct-18 | BANGALORE | 66 | HEBBAL 220 - BANASWADI | BANASWADI | 14:39 | 15:06 | 0:26 | LINE FAULT |
| 335 | 20-Oct-18 | BANGALORE | 66 | HV2 | HEJJALA | 6:04 | 6:13 | 0:09 | TRANSFORMER FAULT |
| 336 | 20-Oct-18 | BANGALORE | 66 | SOLDEVANAHALLI - SRS PEENYA 220 | SOLDEVANAHALLI | 18:06 | 18:15 | 0:09 | LOAD CHANGEOVER |
| 337 | 20-Oct-18 | BANGALORE | 66 | ATTUR YELAHANKA - DG3 | ATTUR YELAHANKA | 14:18 | 14:43 | 0:25 | LINE FAULT |
| 338 | 20-Oct-18 | BANGALORE | 66 | ATTUR YELAHANKA - DG4 | ATTUR YELAHANKA | 16:33 | 16:41 | 0:08 | LOAD CHANGEOVER |
| 339 | 20-Oct-18 | BANGALORE | 66 | ABBIGERE - ATTUR YELAHANKA | ABBIGERE | 14:18 | 15:02 | 0:44 | MAIN SUPPLY FAILURE |
| 340 | 20-Oct-18 | BANGALORE | 66 | ABBIGERE - WELCAST | ABBIGERE | 16:52 | 16:56 | 0:03 | LOAD CHANGEOVER |
| 341 | 20-Oct-18 | BANGALORE | 66 | HV1 | VIJAYANAGARA | 0:00 | 0:14 | 0:14 | MAIN SUPPLY FAILURE |
| 342 | 20-Oct-18 | BANGALORE | 66 | HV2 | VIJAYANAGARA | 0:00 | 0:10 | 0:10 | MAIN SUPPLY FAILURE |
| 343 | 20-Oct-18 | BANGALORE | 66 | HV1 | VIJAYANAGARA | 1:33 | 1:38 | 0:05 | LOAD CHANGEOVER |
| 344 | 20-Oct-18 | BANGALORE | 66 | HV2 | VIJAYANAGARA | 1:33 | 1:38 | 0:05 | LOAD CHANGEOVER |
| 345 | 20-Oct-18 | BANGALORE | 66 | HV1 | VIJAYANAGARA | 13:27 | 14:01 | 0:33 | LINE CLEAR AVAILED |
| 346 | 20-Oct-18 | BANGALORE | 66 | HV2 | VIJAYANAGARA | 13:27 | 14:01 | 0:33 | LINE CLEAR AVAILED |
| 347 | | BANGALORE | 66 | HV1 | NRS 220 | 0:00 | 0:56 | 0:56 | MAIN SUPPLY FAILURE |
| 348 | | BANGALORE | 66 | HV3 | NRS 220 | 0:00 | 0:56 | 0:56 | MAIN SUPPLY FAILURE |
| 349 | | BANGALORE | 66 | HV4 | NRS 220 | 0:00 | 0:56 | 0:56 | MAIN SUPPLY FAILURE |
| 350 | | BANGALORE | 66 | HV5 | NRS 220 | 0:00 | 0:56 | 0:56 | MAIN SUPPLY FAILURE |
| 351 | | BANGALORE | 66 | NRS 220 - TELECOM LAYOUT 2 | TELECOM LAYOUT | 0:00 | 0:56 | 0:56 | MAIN SUPPLY FAILURE |
| 352 | | BANGALORE | 66 | NRS 220 - BRIGADE GATEWAY | BRIGADE GATEWAY | 0:00 | 0:56 | 0:56 | MAIN SUPPLY FAILURE |
| 353 | | BANGALORE | 220 | SRS PEENYA 220 - NRS 220 | NRS 220 | 0:00 | 0:54 | 0:54 | LINE FAULT |
| 354 | | BANGALORE | 220 | NRS 220 - VRISHBHAVATHI 220 | NO STATIONS AFFECTED | 0:00 | 4:21 | 4:21 | LINE FAULT |
| 355 | | BANGALORE | 66 | HV1 | SUGATUR | 14:22 | 14:36 | 0:14 | TRANSFORMER FAULT |
| 555 | _1 000 10 | S, II TO/TEOTILE | | | 55 S. 11 OK | - 1.22 | 1 | J.1- | |

| 356 | 21-Oct-18 | BANGALORE | 66 | DB PURA 220 - DG 1 | AIR (EHT) | 11:24 | 15:55 | 4:31 | LINE FAULT |
|-----|-----------|-----------|-----|--|---|-------|-------|------|--------------------|
| 357 | 21-Oct-18 | BANGALORE | 66 | HEBBAL 220 - LR BANDE | LR BANDE | 13:08 | 13:31 | 0:22 | LINE FAULT |
| 358 | 21-Oct-18 | BANGALORE | 66 | HV2 | SOUTH CITY | 4:11 | 5:03 | 0:52 | TRANSFORMER FAULT |
| 359 | 21-Oct-18 | BANGALORE | 66 | JIGANI 220 - JIGANI 66 | JIGANI 66 | 11:06 | 11:15 | 0:09 | LOAD CHANGEOVER |
| 360 | 21-Oct-18 | BANGALORE | 66 | YARANDANAHALLI 220 - JIGANI 66 | JIGANI 66 | 12:30 | 13:04 | 0:34 | LOAD CHANGEOVER |
| 361 | 21-Oct-18 | BANGALORE | 66 | HV2 | YARANDANAHALLI 220 | 12:45 | 12:50 | 0:05 | LINE CLEAR AVAILED |
| 362 | 21-Oct-18 | BANGALORE | 66 | YARANDANAHALLI 220 - ANEKAL 1 & 2 | ANEKAL, SURYANAGAR | 13:14 | 15:25 | 2:11 | LINE CLEAR AVAILED |
| 363 | 21-Oct-18 | BANGALORE | 66 | YARANDANAHALLI 220 - ELECTRONIC CITY 2 | BOMMASANDRA I/A, BIOCON (EHT) | 13:14 | 15:25 | 2:11 | LINE CLEAR AVAILED |
| 364 | 21-Oct-18 | BANGALORE | 66 | YARANDANAHALLI 220 - TIMES OF INDIA(EHT) | TIMES OF INDIA(EHT) | 13:15 | 15:25 | 2:10 | LINE CLEAR AVAILED |
| 365 | 21-Oct-18 | BANGALORE | 66 | HV2 | YARANDANAHALLI 220 | 13:15 | 14:58 | 1:43 | LINE CLEAR AVAILED |
| 366 | 21-Oct-18 | BANGALORE | 220 | YARANDANAHALLI 220 - HOSUR 220 | YARANDANAHALLI 220 | 13:47 | 14:53 | 1:06 | LINE CLEAR AVAILED |
| 367 | 21-Oct-18 | BANGALORE | 220 | YARANDANAHALLI 220 - SOMANAHALLI 220 | YARANDANAHALLI 220 | 13:43 | 15:15 | 1:32 | LINE CLEAR AVAILED |
| 368 | 21-Oct-18 | BANGALORE | 66 | HV1 | YARANDANAHALLI 220 | 13:42 | 14:58 | 1:16 | LINE CLEAR AVAILED |
| 369 | 21-Oct-18 | BANGALORE | 66 | HV3 | YARANDANAHALLI 220 | 13:42 | 14:58 | 1:16 | LINE CLEAR AVAILED |
| 370 | 21-Oct-18 | BANGALORE | 66 | ELECTRONIC CITY - YARANDANAHALLI 1 & 2 | ELECTRONIC CITY, INFOSYS (EHT) | 13:00 | 13:05 | 0:05 | LOAD CHANGEOVER |
| 371 | 21-Oct-18 | BANGALORE | 66 | ELECTRONIC CITY - ELECTRONIC CITY P2 S1 | ELECTRONIC CITY, INFOSYS (EHT) | 15:30 | 15:35 | 0:05 | LOAD CHANGEOVER |
| 372 | 22-Oct-18 | BANGALORE | 66 | HV2 | EPIP 220 | 16:35 | 18:54 | 2:19 | LINE CLEAR AVAILED |
| 373 | 22-Oct-18 | BANGALORE | 66 | HV3 | HEBBAL 220 | 12:06 | 12:13 | 0:06 | LINE CLEAR AVAILED |
| 374 | 22-Oct-18 | BANGALORE | 66 | SUBRAMANYAPURA 220 - REMCO 1 | AREHALLI | 12:45 | 13:03 | 0:18 | LOAD CHANGEOVER |
| 375 | 22-Oct-18 | BANGALORE | 66 | SUBRAMANYAPURA 220 - PADMANABHANAGARA | PADMANABHANAGARA | 12:45 | 12:50 | 0:05 | LOAD CHANGEOVER |
| 376 | 22-Oct-18 | BANGALORE | 66 | SUBRAMANYAPURA 220 - SARAKKI 1 | ISRO LAYOUT | 10:42 | 11:05 | 0:23 | LOAD CHANGEOVER |
| 377 | 22-Oct-18 | BANGALORE | 66 | SUBRAMANYAPURA 220 - SARAKKI 2 | SARAKKI | 10:37 | 10:56 | 0:19 | LOAD CHANGEOVER |
| 378 | 22-Oct-18 | BANGALORE | 66 | HV1 | CHIKKABALLAPURA URBAN | 12:08 | 12:15 | 0:06 | LINE CLEAR AVAILED |
| 379 | 22-Oct-18 | BANGALORE | 66 | HV2 | CHIKKABALLAPURA URBAN | 14:24 | 14:30 | 0:05 | LINE CLEAR AVAILED |
| 380 | 22-Oct-18 | BANGALORE | 66 | DB PURA 220 - DEVANAHALLI 1 | KUNDANA | 20:49 | 20:59 | 0:09 | LINE FAULT |
| 381 | 22-Oct-18 | BANGALORE | 66 | DB PURA 220 - DEVANAHALLI 2 | DEVANAHALLI | 20:48 | 21:00 | 0:11 | LINE CLEAR AVAILED |
| 382 | 22-Oct-18 | BANGALORE | 66 | DB PURA 220 - DEVANAHALLI 1 | KUNDANA | 21:04 | 23:59 | 2:54 | LINE CLEAR AVAILED |
| 383 | 22-Oct-18 | BANGALORE | 66 | DB PURA 220 - DEVANAHALLI 2 | DEVANAHALLI | 21:04 | 23:59 | 2:54 | LINE CLEAR AVAILED |
| 384 | 22-Oct-18 | BANGALORE | 66 | DB PURA 220 - DG 1 | AIR (EHT) | 11:16 | 15:24 | 4:07 | LINE CLEAR AVAILED |
| 385 | 22-Oct-18 | BANGALORE | 66 | HV2 | DOMMASANDRA | 16:17 | 16:25 | 0:07 | LINE CLEAR AVAILED |
| 386 | 22-Oct-18 | BANGALORE | 66 | HBR LAYOUT - LR BANDE | HBR LAYOUT | 19:26 | 19:36 | 0:10 | LOAD CHANGEOVER |
| 387 | 22-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 1 | GRINDWELL (EHT), VIDYANAGARA, HENNUR CROSS | 17:22 | 18:56 | 1:34 | LINE CLEAR AVAILED |
| 388 | 22-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - HOSKOTE 2 | HBR LAYOUT, BELL CERAMICS (EHT) | 14:41 | 15:57 | 1:16 | LINE CLEAR AVAILED |
| 389 | 22-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - PILAGUMPA | PILAGUMPA | 17:23 | 18:45 | 1:22 | LINE CLEAR AVAILED |
| 390 | 22-Oct-18 | BANGALORE | 66 | HOSKOTE 220 - VOLVO | VOLVO, NANDAGUDI | 17:23 | 18:50 | 1:27 | LINE CLEAR AVAILED |
| 391 | 22-Oct-18 | BANGALORE | 66 | KOLAR 220 - VOKKALERI | VOKKALERI | 16:55 | 17:45 | 0:50 | LOAD CURTAILMENT |
| 392 | 22-Oct-18 | BANGALORE | 66 | KOLAR 220 - NANGLI | KEMBODI, MUDIYANUR, H GOLLAHALLI, BAIRAKUR, NANGLI | 17:05 | 17:45 | 0:39 | LOAD CURTAILMENT |
| 393 | 22-Oct-18 | BANGALORE | 66 | MALUR 220 - HOSKOTE 2 | JADIGENAHALLI, MALUR I/A, STAR PANEL (EHT) | 6:50 | 6:57 | 0:07 | LINE FAULT |
| 394 | 22-Oct-18 | BANGALORE | 66 | HV1 | SM MANGALA | 10:04 | 13:46 | 3:42 | LINE CLEAR AVAILED |
| 395 | 22-Oct-18 | BANGALORE | 66 | HV2 | SM MANGALA | 10:04 | 13:46 | 3:42 | LINE CLEAR AVAILED |

| | | 1 | | T | | | | | |
|-----|-----------|-----------|-----|-----------------------------|--|-------|-------|-------|--------------------|
| 396 | 22-Oct-18 | BANGALORE | 66 | | TTUR YELAHANKA, ESCORTS (EHT), IANYATHA TECH PARK, ABBIGERE | 12:46 | 13:10 | 0:24 | LINE FAULT |
| 397 | 16-Oct-18 | GULBARGA | 400 | GDHALLI-GUTTUR GU | UTTUR_400 | 7:06 | 17:52 | 10:46 | LINE CLEAR AVAILED |
| 398 | 16-Oct-18 | GULBARGA | 220 | LINGAPUR-GADAG2 LIN | NGAPUR_220 | 13:08 | 15:46 | 2:38 | LINE FAULT |
| 399 | 16-Oct-18 | GULBARGA | 220 | SHAHAPUR-SEDAM SH | HAHPUR_220 | 4:31 | 23:59 | 19:28 | LINE FAULT |
| 400 | 16-Oct-18 | GULBARGA | 220 | RTPS-LINGASUGUR1 LIN | NGASUGUR_220 | 23:46 | 23:59 | 0:13 | LINE FAULT |
| 401 | 16-Oct-18 | GULBARGA | 220 | RTPS-LINGASUGUR3 LIN | NGASUGUR_220,MALLAT_220 | 23:04 | 23:59 | 0:55 | LINE FAULT |
| 402 | 16-Oct-18 | GULBARGA | 220 | HV1 M | IALLAT_220 | 2:45 | 2:50 | 0:05 | TRANSFORMER FAULT |
| 403 | 16-Oct-18 | GULBARGA | 220 | | ANTHAPUR_110,DONGARGOAN_110,KAMALA AGAR_110 | 23:05 | 23:21 | 0:16 | LINE FAULT |
| 404 | 16-Oct-18 | GULBARGA | 220 | HV1 KU | JSTAGI_220 | 21:35 | 22:34 | 0:59 | TRANSFORMER FAULT |
| 405 | 16-Oct-18 | GULBARGA | 220 | LINGAPUR-BMM ISPAT BN | MM ISPAT_IPP | 12:48 | 23:59 | 11:11 | LINE FAULT |
| 406 | 16-Oct-18 | GULBARGA | 110 | | ANTHAPUR_110,JANAWADA_110,DONGRAG A_110,DIGGI_110 | 6:16 | 6:25 | 0:09 | LINE FAULT |
| 407 | 16-Oct-18 | GULBARGA | 110 | HV1,HV2 LIN | NGASUGUR_220 | 14:55 | 15:07 | 0:12 | LOAD CURTAILMENT |
| 408 | 16-Oct-18 | GULBARGA | 110 | HV3 LIN | NGASUGUR_220 | 15:07 | 15:13 | 0:06 | LOAD CURTAILMENT |
| 409 | 16-Oct-18 | GULBARGA | 110 | HV1 PC | DHALLI_110 | 14:55 | 15:05 | 0:10 | LOAD CURTAILMENT |
| 410 | 16-Oct-18 | GULBARGA | 110 | | AMPLI_110,KPC,MUKUNDA_110,KEREHALLI_1 D,MALLAPUR_110 | 12:15 | 12:28 | 0:13 | LINE FAULT |
| 411 | 16-Oct-18 | GULBARGA | 110 | SEDAM-KURKUNTA KU | JRKUNTA_110 | 0:28 | 0:55 | 0:27 | LINE FAULT |
| 412 | 16-Oct-18 | GULBARGA | 110 | SEDAM-VASAVADATTA SE | EDAM_220 | 0:28 | 0:32 | 0:04 | LINE FAULT |
| 413 | 16-Oct-18 | GULBARGA | 110 | SEDAM-GURUMITKAL GU | URUMITKAL_110 | 16:05 | 16:20 | 0:15 | LINE FAULT |
| 414 | 16-Oct-18 | GULBARGA | 110 | SINDHANOOR-PGLR_WIND SIE | DHANOOR_220 | 12:20 | 12:49 | 0:29 | LINE FAULT |
| 415 | 16-Oct-18 | GULBARGA | 110 | HV2 SIF | RIGUPPA_110 | 14:55 | 15:03 | 0:08 | LOAD CURTAILMENT |
| 416 | 16-Oct-18 | GULBARGA | 110 | HV1 SIF | RWAR_110 | 14:55 | 15:00 | 0:05 | LOAD CURTAILMENT |
| 417 | 16-Oct-18 | GULBARGA | 110 | HV1 TE | EKKALAKOTE_110 | 14:55 | 15:20 | 0:25 | LOAD CURTAILMENT |
| 418 | 16-Oct-18 | GULBARGA | 110 | MUNIRABAD-STAR METALLIC M | IUNIRABAD POWER HOUSE | 12:10 | 12:23 | 0:13 | LINE FAULT |
| 419 | 16-Oct-18 | GULBARGA | 110 | MUNIRABAD-STAR METALLIC M | IUNIRABAD POWER HOUSE | 12:48 | 12:58 | 0:10 | LINE FAULT |
| 420 | 16-Oct-18 | GULBARGA | 110 | MUNIRABAD-STAR METALLIC M | IUNIRABAD POWER HOUSE | 13:05 | 13:17 | 0:12 | LINE FAULT |
| 421 | 16-Oct-18 | GULBARGA | 110 | HV3,HV4 YE | ELBURGA_110 | 14:55 | 15:02 | 0:07 | LOAD CURTAILMENT |
| 422 | 16-Oct-18 | GULBARGA | 110 | HATTI-GAMESHA HA | ATTI_110 | 20:20 | 20:26 | 0:06 | LINE FAULT |
| 423 | 16-Oct-18 | GULBARGA | 110 | STARMETALLIC -MUNIRABAD MI | IUNIRABAD_220 | 16:33 | 17:50 | 1:17 | LINE FAULT |
| 424 | 16-Oct-18 | GULBARGA | 110 | SHAHAPUR-KBJNL KB | BJNL_IPP | 5:30 | 5:50 | 0:20 | LINE FAULT |
| 425 | 16-Oct-18 | GULBARGA | 110 | HV1 SH | HAHPUR_220 | 6:22 | 6:42 | 0:20 | TRANSFORMER FAULT |
| 426 | 16-Oct-18 | GULBARGA | 110 | | RIGUPPA_110,TEKKALAKOTE_110,DHADESUG R_110 | 23:09 | 23:17 | 0:08 | LINE FAULT |
| 427 | 16-Oct-18 | GULBARGA | 110 | SEDAM-VASVADATTA CEMENTS SE | EDAM_220 | 17:42 | 18:14 | 0:32 | LINE FAULT |
| 428 | 16-Oct-18 | GULBARGA | 110 | SEDAM-KURUKUNTA KU | JRKUNTA_110 | 17:42 | 18:39 | 0:57 | LINE FAULT |
| 429 | 16-Oct-18 | GULBARGA | 110 | | AGARI_110,KAMALAPUR_110,SANKLAPUR_1),TORANGALLU,KUDITINI_110 | 18:40 | 19:10 | 0:30 | LINE FAULT |
| 430 | 16-Oct-18 | GULBARGA | 110 | MALLAT-SIRWAR SIF | RWAR_110 | 2:45 | 2:55 | 0:10 | LINE FAULT |
| 431 | 16-Oct-18 | GULBARGA | 110 | MALLAT-ALKOD AL | LKOD_110 | 4:20 | 4:25 | 0:05 | LINE FAULT |
| 432 | 16-Oct-18 | GULBARGA | 110 | MALLAT-ALKOD AL | LKOD_110 | 4:25 | 4:35 | 0:10 | LINE FAULT |
| 433 | 16-Oct-18 | GULBARGA | 110 | MALLAT-SIRWAR SIF | RWAR_110 | 4:55 | 5:05 | 0:10 | LINE FAULT |
| 434 | 16-Oct-18 | GULBARGA | 110 | MALLAT-ALKOD AL | LKOD_110 | 19:13 | 19:18 | 0:05 | LINE FAULT |

| | | | | | | - | - | | 1 |
|-----|-----------|----------|-----|------------------------|---|-------|-------|-------|--------------------|
| 435 | 16-Oct-18 | GULBARGA | 110 | | MADALAPURA_110,VADAVATTI_110,MANVI_1 10 | 21:30 | 21:35 | 0:05 | LINE FAULT |
| 436 | 16-Oct-18 | GULBARGA | 110 | | HANUMSAGAR_110,HANUMNAL_110,HIREGO NNAGAR_110 | 21:35 | 23:59 | 2:24 | LINE FAULT |
| 437 | 16-Oct-18 | GULBARGA | 110 | HV4 | LINGASUGUR_220 | 20:40 | 23:05 | 2:25 | TRANSFORMER FAULT |
| 438 | 16-Oct-18 | GULBARGA | 110 | SANTHAPUR-WARDHA SOLAR | SANTHAPUR_110 | 11:34 | 11:50 | 0:16 | LINE FAULT |
| 439 | 16-Oct-18 | GULBARGA | 110 | HV1 | DHADESUGUR_110 | 15:45 | 15:55 | 0:10 | TRANSFORMER FAULT |
| 440 | 16-Oct-18 | GULBARGA | 66 | HV1,HV2 | HIREHADAGALLI_66 | 10:20 | 14:50 | 4:30 | LINE CLEAR AVAILED |
| 441 | 16-Oct-18 | GULBARGA | 66 | GUDEKOTE-KUDLIGI | GUDEKOTE_66 | 21:15 | 23:59 | 2:44 | LINE FAULT |
| 442 | 16-Oct-18 | GULBARGA | 66 | MUNIRABAD-MSD LINE | HANASI_66 | 16:34 | 16:55 | 0:21 | LINE FAULT |
| 443 | 16-Oct-18 | GULBARGA | 66 | | VENKATAPURA_66,UPANAYAKANAHALLI_66,H AGARIBOMMANAHALLI_66,RRSTEELS_IPP | 16:41 | 17:03 | 0:22 | LINE FAULT |
| 444 | 17-Oct-18 | GULBARGA | 400 | JSWVL400-GUTTUR | GUTTUR_400 | 2:02 | 23:59 | 21:57 | LINE FAULT |
| 445 | 17-Oct-18 | GULBARGA | 220 | RTPS-LINGASUGUR1 | LINGASUGUR_220 | 0:00 | 0:12 | 0:12 | LINE FAULT |
| 446 | 17-Oct-18 | GULBARGA | 220 | RTPS-LINGASUGUR3 | LINGASUGUR_220,MALLAT_220 | 0:00 | 6:40 | 6:40 | LINE FAULT |
| 447 | 17-Oct-18 | GULBARGA | 220 | ALIPUR-BTPS | ALIPUR_220 | 3:35 | 4:05 | 0:30 | LINE FAULT |
| 448 | 17-Oct-18 | GULBARGA | 220 | HV2 | ALIPUR_220 | 3:35 | 4:07 | 0:32 | TRANSFORMER FAULT |
| 449 | 17-Oct-18 | GULBARGA | 220 | SEDAM-GURUMITKAL | GURUMITKAL_110 | 1:35 | 1:48 | 0:13 | LINE FAULT |
| 450 | 17-Oct-18 | GULBARGA | 220 | SEDAM-SHAHPUR | SHAHPUR_220 | 4:26 | 16:41 | 12:15 | LINE FAULT |
| 451 | 17-Oct-18 | GULBARGA | 220 | SEDAM-RTPS1 | SEDAM_220 | 6:31 | 16:27 | 9:56 | LINE FAULT |
| 452 | 17-Oct-18 | GULBARGA | 220 | LINGAPUR-KUSTAGI | KUSTAGI_220 | 5:54 | 15:57 | 10:03 | LINE FAULT |
| 453 | 17-Oct-18 | GULBARGA | 220 | LINGAPUR-BMMISPAT_IPP | BMM_ISPAT_IPP | 0:00 | 19:13 | 19:13 | LINE FAULT |
| 454 | 17-Oct-18 | GULBARGA | 220 | | ILC_IPP,XINDIA_IPP,DHRUVADESH_IPP,GADAG _220 | 19:41 | 23:59 | 4:18 | LINE FAULT |
| 455 | 17-Oct-18 | GULBARGA | 220 | HV1 | KUSTAGI_220 | 15:30 | 15:50 | 0:20 | TRANSFORMER FAULT |
| 456 | 17-Oct-18 | GULBARGA | 220 | HV2,LV2 | ITTAGI_220 | 1:34 | 1:45 | 0:11 | TRANSFORMER FAULT |
| 457 | 17-Oct-18 | GULBARGA | 220 | HV2 | ITTAGI_220 | 1:35 | 13:34 | 11:59 | TRANSFORMER FAULT |
| 458 | 17-Oct-18 | GULBARGA | 220 | HV1,LV1 | ITTAGI_220 | 13:46 | 15:50 | 2:04 | TRANSFORMER FAULT |
| 459 | 17-Oct-18 | GULBARGA | 220 | HV1,LV1 | ITTAGI_220 | 16:05 | 17:13 | 1:08 | TRANSFORMER FAULT |
| 460 | 17-Oct-18 | GULBARGA | 110 | SINDHANOOR-RAICHUR2 | MANVI_110,MADALAPUR_110 | 2:54 | 6:58 | 4:04 | LINE FAULT |
| 461 | 17-Oct-18 | GULBARGA | 110 | | TEKKALAKOTE_110,DHADESUGUR_110,SIRIGU PPA_110,NSL SUGURS_IPP | 9:51 | 9:59 | 0:08 | LINE FAULT |
| 462 | 17-Oct-18 | GULBARGA | 110 | HV2 | SHORAPUR_110 | 5:18 | 5:30 | 0:12 | TRANSFORMER FAULT |
| 463 | 17-Oct-18 | GULBARGA | 110 | HV2 | SHORAPUR_110 | 7:35 | 7:48 | 0:13 | TRANSFORMER FAULT |
| 464 | 17-Oct-18 | GULBARGA | 110 | HV2 | SHORAPUR_110 | 14:17 | 14:33 | 0:16 | TRANSFORMER FAULT |
| 465 | 17-Oct-18 | GULBARGA | 110 | SANTHAPUR-WARDASLR | SANTHAPUR_110 | 13:10 | 13:20 | 0:10 | LINE FAULT |
| 466 | 17-Oct-18 | GULBARGA | 110 | KAPNOOR-HUMNABAD1 | MAHAGOAN_110,MARAGUTTI_110 | 2:56 | 3:12 | 0:16 | LINE FAULT |
| 467 | 17-Oct-18 | GULBARGA | 110 | JANAWADA-SANTHAPUR . | JANAWADA_110 | 2:06 | 2:14 | 0:08 | LINE FAULT |
| 468 | 17-Oct-18 | GULBARGA | 110 | JANAWADA-SANTHAPUR | JANAWADA_110 | 6:39 | 6:43 | 0:04 | LINE FAULT |
| 469 | 17-Oct-18 | GULBARGA | 110 | HUMNABAD-CHITAGUPPA | CHITAGUPPA_110 | 6:45 | 7:07 | 0:22 | LINE FAULT |
| 470 | 17-Oct-18 | GULBARGA | 110 | ALIPUR-BELLARYSOUTH2 | BELLARY SOUTH_110,HALKUNDI_110 | 0:04 | 0:28 | 0:24 | LINE FAULT |
| 471 | 17-Oct-18 | GULBARGA | 110 | ALIPUR-MUNIRABAD | TORANAGALLU_110,KUDITINI_110,KURUGOD_ 110,SHATHAVAHANA_IPP,AGARWAL_IPP,SUZL ON_IPP,KAMLAPUR_110,MATRI_110,RBNS FACTORY | 3:36 | 4:38 | 1:02 | LINE FAULT |

| MAPPEL GELEBACK 10 MAPPEL MAPPEL GELEBACK 10 MARADECHINE MARADECHINE | 472 | 17-Oct-18 | GULBARGA | 110 | JANAWADA-SANTHAPUR | SANTHAPUR_110 | 23:58 | 23:59 | 0:01 | LINE FAULT |
|--|-----|-----------|----------|-----|-----------------------|---|-------|-------|-------|--------------------|
| 474 77 CT. 18 GURBARCA 110 GURBIMITANEL KONNAL GURBIMITANEL SONNAL GURBIMITANEL SONNAL GURBIMITANEL SONNAL SIRCHANDOROSCO PARCHUSZ MARCHAPIRA 110 MANNI 110 2.28 6.28 6.29 1.00 UNE FAULT | | | | | | | | | | |
| 170 170 170 18 18 18 18 19 19 18 18 | | | | | GURUMITAKAI -KONKAI | | | | | |
| 476 77-0c-18 ULBARGA 110 SINCHANOGRZOS RIACHIZE MADIALPIRA, 110 19-20 19-30 0.10 LINE FAULT | | | | | | | | | | |
| Processor Proc | | | | | | | | | | |
| 17-7 17-0-18 GULBARGA 110 HALBURGA-SANTHAPUR SANTHAPUR, 110,DANGRAGOA, 110,DIGGL 1 6-66 0-10 LINE FAULT | | | | | | DHADESUGUR_110,SIRIGUPPA_110,TEKKALAK | | | | |
| 17-0c-18 CULBARGA 110 HALBURGA KOLHAR2 KOLHAR_110_IANAWADA_110,NSSK_SUGARFA 17:50 18:09 0:19 LINE FAULT | 478 | 17-Oct-18 | GULBARGA | 110 | HALBURGA-SANTHAPUR | | 2:03 | 2:15 | 0:12 | LINE FAULT |
| 17-0ct-18 GUIBARGA 110 HABUNGA-KOLHAR2 CTORY_IPP 17-0ct-18 GUIBARGA 110 HABUNGA-KOLHAR2 CTORY_IPP CTORY_IPP 17-0ct-18 GUIBARGA 110 HV2 LINGASUGUR_220 11:22 11:32 0:10 LINE FAULT | 479 | 17-Oct-18 | GULBARGA | 110 | HALBURGA-SANTHAPUR | | 6:36 | 6:46 | 0:10 | LINE FAULT |
| CTORY IPP 18-13 18-15 | 480 | 17-Oct-18 | GULBARGA | 110 | HALBURGA-KOLHAR2 | | 17:50 | 18:09 | 0:19 | LINE FAULT |
| 483 17-Oct-18 GULBARGA 110 MY2 LINGASUGUR_220 11:22 11:32 0:10 LINE CLEAR AVAILED | 481 | 17-Oct-18 | | 110 | HALBURGA-KOLHAR2 | | 18:15 | 18:19 | 0:04 | LINE FAULT |
| 484 17-Oct-18 GULBARGA 110 LV1 KUSTAGI_220 8.49 9.35 0.46 TRANSFORMER FAULT | 482 | | | | | | | | | |
| HANDMARAGAR_110 | 483 | | | 110 | HV2 | | 11:22 | 11:32 | 0:10 | LINE CLEAR AVAILED |
| Consideration Consideratio | 484 | 17-Oct-18 | GULBARGA | 110 | LV1 | KUSTAGI_220 | 8:49 | 9:35 | 0:46 | TRANSFORMER FAULT |
| 487 17-Oct-18 GULBARGA 110 MALLAT220-ALKOD ALKOD_110 ALKOD_110 18:25 18:30 0:05 LINE FAULT | 485 | 17-Oct-18 | GULBARGA | 110 | KUSTAGI-GAJENDRAGAD | | 0:00 | 19:20 | 19:20 | LINE FAULT |
| 17-Oct-18 GULBARGA 110 MUNIRABAD-SINDHANOOR1 VENKATAGILL 110,GANGAVATHI 110,SRERAM 22:42 22:50 0:08 LINE FAULT 18/9 17-Oct-18 GULBARGA 110 MUNIRABAD-HAGRI HAGRI 110,KANATAGL 110 0:43 0:49 0:06 LINE FAULT 19:35 17-Oct-18 GULBARGA 110 MUNIRABAD-HAGRI HAGRI 110,KANATAPUR 110 19:35 19:45 0:10 LINE FAULT 17-Oct-18 GULBARGA 110 MUNIRABAD-HAGRI HAGRI 110,KUDITINI 110 19:35 19:45 0:10 LINE FAULT 17-Oct-18 GULBARGA 110 MUNIRABAD-MSDLINE HANASI 66 19:42 19:47 0:05 LINE FAULT 19:35 17-Oct-18 GULBARGA 66 GUDEKOTE-KUDILIGI GUDEKOTE 66 16:07 16:12 0:05 LINE CLEAR AVAILED 17-Oct-18 GULBARGA 66 HV1 BANAVEKAL 66 17:00 17:40 0:40 LINE CLEAR AVAILED 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE 66 23:30 23:40 0:10 TRANSFORMER FAULT 19:40 17-Oct-18 GULBARGA 66 KOGALI-KUDILIGI GUDEKOTE 66, CINANUCKAL 66:10 17:22 18:09 0:47 LINE CLEAR AVAILED 17-Oct-18 GULBARGA 66 KOGALI-KUDILIGI GUDEKOTE 66, CINANUCKAL 66:10 17:22 18:09 0:47 LINE CLEAR AVAILED 17-Oct-18 GULBARGA 66 KOGALI-KITSOLR KOGALI 66, CINANUCKAL 66:10 17:22 18:09 0:47 LINE CLEAR AVAILED 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI LIAGRIBOMMANAHALLI 66, UPANAYAKANAHAL 16:12 17:10 0:58 LINE FAULT 17-Oct-18 GULBARGA 66 LITAGI-HBHALLI HAGRIBOMMANAHALLI 66, UPANAYAKANAHAL 17:13 17:20 0:07 HAND TRIPPED 17-Oct-18 GULBARGA 66 LITAGI-HBHALLI HAGRIBOMMANAHALLI 66, HANASI 66 20:55 21:15 0:20 LINE FAULT 17-Oct-18 GULBARGA 66 LITAGI-HUDILIGI KUDILIGI 66, KOGALI 66, HANASI 66 20:55 21:15 0:20 LINE FAULT 17-Oct-18 GULBARGA 66 LITAGI-HUDILIGI KUDILIGI 66, KOGALI 66, HANASI 66 20:55 21:10 LINE FAULT 17-Oct-18 GULBARGA 66 LITAGI-HUDILIGI KUDILIGI 66, KOGALI 66, HANASI 66 20:55 21:50 LINE FAULT 17-Oct-18 GULBARGA 66 LITAGI-HUDILIGI KUDILIGI 66, KOGALI 66, HANASI 66 20:55 21:50 LINE FAULT 17 | 486 | 17-Oct-18 | GULBARGA | 110 | MALLAT220-KAVITHAL | KAVITAL_110 | 23:28 | 23:36 | 0:08 | LINE FAULT |
| ANAGAR_110,KARATAGI_110 | 487 | 17-Oct-18 | GULBARGA | 110 | MALLAT220-ALKOD | ALKOD_110 | 18:25 | 18:30 | 0:05 | LINE FAULT |
| 17-Oct-18 GUBARGA 110 MUNIRABAD-HAGRI 1 | 488 | 17-Oct-18 | GULBARGA | 110 | MUNIRABAD-SINDHANOOR1 | VENKATAGIRI_110,GANGAVATHI_110,SRERAM ANAGAR_110,KARATAGI_110 | 22:42 | 22:50 | 0:08 | LINE FAULT |
| 17-Oct-18 GUBARGA 110 MUNIRABAD-MSDLINE HANASI_66 19:42 19:47 0:05 LINE FAULT | 489 | 17-Oct-18 | GULBARGA | 110 | MUNIRABAD-HAGRI | HAGRI_110,KAMALAPUR_110,SANKLAPUR_110 ,TORANAGALLU_110,KUDITINI_110 | 0:43 | 0:49 | 0:06 | LINE FAULT |
| 492 17-Oct-18 GULBARGA 66 GUDEKOTE-KUDILIGI GUDEKOTE-66 16:07 16:12 0:05 LINE CLEAR AVAILED 493 17-Oct-18 GULBARGA 66 HV1 BANAVEKAL_66 17:00 17:40 0:40 LINE CLEAR AVAILED 494 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE_66 23:30 23:40 0:10 TRANSFORMER FAULT 495 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE_66 23:45 23:59 0:14 TRANSFORMER FAULT 496 17-Oct-18 GULBARGA 66 KOGALI-KUDLIGI KUDLIGI 66:CHORNOOR_66.BANAVEKAL_66, UDEKOTE_66, CIHALIL_66.HOSAHALIL_66, UDEKOTE_66, UDEKOT | 490 | 17-Oct-18 | | 110 | MUNIRABAD-HAGRI | HAGRI_110,KAMALAPUR_110,SANKLAPUR_110 ,TORANAGALLU_110,KUDITINI_110 | 19:35 | 19:45 | 0:10 | |
| 493 17-Oct-18 GULBARGA 66 HV1 BANAVEKAL_66 17:00 17:40 0:40 LINE CLEAR AVAILED 494 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE_66 23:30 23:40 0:10 TRANSFORMER FAULT 495 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE_66 23:45 23:59 0:14 TRANSFORMER FAULT 496 17-Oct-18 GULBARGA 66 KOGALI-KUDLIGI KUDLIGI_66,CHORNOOR_66,BANAVEKAL_66,G 17:15 17:20 0:05 LINE CLEAR AVAILED 497 17-Oct-18 GULBARGA 66 KOGALI-ATRSOLR KOGALI_66 17:15 17:20 0:05 LINE CLEAR AVAILED 498 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI HAGRIBOMMANAHALLI_66,UPANAYAKANAHAL 16:12 17:10 0:58 LINE FAULT 499 17-Oct-18 GULBARGA 66 IVT ITTAGI-HBHALLI HAGRIBOMMANAHALLI_66,UPANAYAKANAHAL 17:13 17:20 0:07 HAND TRIPPED 500 17-Oct-18 </td <td>491</td> <td>17-Oct-18</td> <td>GULBARGA</td> <td>110</td> <td>MUNIRABAD-MSDLINE</td> <td>HANASI_66</td> <td>19:42</td> <td>19:47</td> <td>0:05</td> <td>LINE FAULT</td> | 491 | 17-Oct-18 | GULBARGA | 110 | MUNIRABAD-MSDLINE | HANASI_66 | 19:42 | 19:47 | 0:05 | LINE FAULT |
| 494 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE_66 23:30 23:40 0:10 TRANSFORMER FAULT 495 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE_66 23:45 23:59 0:14 TRANSFORMER FAULT 496 17-Oct-18 GULBARGA 66 KOGALI-KUDLIGI KUDLIGI_66,CHORNOOR_66,BANAVEKAL_66,G UDEKOTE_66,CJHALIL_66,HOSAHALIL_66 17:15 17:20 0:05 LINE CLEAR AVAILED 497 17-Oct-18 GULBARGA 66 KOGALI-ATRSOLR KOGALI_66 17:22 18:09 0:47 LINE CLEAR AVAILED 498 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI HAGRIBOMMANHALLI_66,UPANAYAKANAHAL LI_66 16:12 17:10 0:58 LINE FAULT 499 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI HITAGIBOMMANHALLI_66,UPANAYAKANAHAL LI_66 17:13 17:20 0:07 HAND TRIPPED 500 17-Oct-18 GULBARGA 66 LIVI ITTAGI-SUDA 20:20 21:10 0:50 TRANSFORMER FAULT 501< | 492 | 17-Oct-18 | GULBARGA | 66 | GUDEKOTE-KUDILIGI | GUDEKOTE_66 | 16:07 | 16:12 | 0:05 | LINE CLEAR AVAILED |
| 495 17-Oct-18 GULBARGA 66 HV2 GUDEKOTE_66 23:45 23:59 0:14 TRANSFORMER FAULT 496 17-Oct-18 GULBARGA 66 KOGALI-KUDLIGI KUDLIGI_66,CHORNOOR_66,BANAVEKAL_66,G UDEKOTE_66,CHALLI_66 17:15 17:20 0:05 LINE CLEAR AVAILED 497 17-Oct-18 GULBARGA 66 KOGALI-ATRSOLR KOGALI_66 17:22 18:09 0:47 LINE CLEAR AVAILED 498 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI HAGRIBOMMANAHALLI_66,UPANAYAKANAHAL I. 16:12 17:10 0:58 LINE FAULT 499 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI ITTAGI_220 20:20 21:10 0:50 TRANSFORMER FAULT 500 17-Oct-18 GULBARGA 66 LV1 ITTAGI_220 20:20 21:10 0:50 TRANSFORMER FAULT 501 17-Oct-18 GULBARGA 66 ITTAGI-KUDILGI1 KUDILGI_66,KOGALI_66,HANASI_66 20:55 21:15 0:20 LINE FAULT 502 17-Oct- | 493 | 17-Oct-18 | GULBARGA | 66 | HV1 | BANAVEKAL_66 | 17:00 | 17:40 | 0:40 | LINE CLEAR AVAILED |
| 496 17-Oct-18 GULBARGA 66 KOGALI-KUDLIGI KUDLIGI_66,CHORNOOR_66,BANAVEKAL_66,G UDEKOTE_66,CHALLI_66 17:15 17:20 0:05 LINE CLEAR AVAILED 497 17-Oct-18 GULBARGA 66 KOGALI-ATRSOLR KOGALI_66 17:22 18:09 0:47 LINE CLEAR AVAILED 498 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI HAGRIBOMMANAHALLI_66,UPANAYAKANAHAL IDEGULATION IN ITTAGI-UDEGULATION IN ITTAGI-UDEGUL | 494 | 17-Oct-18 | GULBARGA | 66 | HV2 | GUDEKOTE_66 | 23:30 | 23:40 | 0:10 | TRANSFORMER FAULT |
| 17-Oct-18 GULBARGA 66 KOGALI-ATRSOLR KOGALI_66 17:22 18:09 0:47 LINE CLEAR AVAILED | 495 | 17-Oct-18 | GULBARGA | 66 | HV2 | GUDEKOTE_66 | 23:45 | 23:59 | 0:14 | TRANSFORMER FAULT |
| 498 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI HAGRIBOMMANAHALLI_66,UPANAYAKANAHAL LI_66,UPANAYAKANAHAL LI_66 16:12 17:10 0:58 LINE FAULT 499 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI HAGRIBOMMANAHALLI_66,UPANAYAKANAHAL LI_66,UPANAYAKANAHAL LI_66 17:13 17:20 0:07 HAND TRIPPED 500 17-Oct-18 GULBARGA 66 LV1 ITTAGI_220 20:20 21:10 0:50 TRANSFORMER FAULT 501 17-Oct-18 GULBARGA 66 ITTAGI-KUDILGI1 KUDILIGI_66,KOGALI_66,HANASI_66 20:55 21:15 0:20 LINE FAULT 502 17-Oct-18 GULBARGA 66 ITTAGI-KUDILGI2 CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BAN VEKAL_66,CHORNOOR_66 20:55 22:05 1:10 LINE FAULT 503 18-Oct-18 GULBARGA 400 JSWVL400-GUTTUR GUTTUR_400 0:00 17:37 17:37 LINE FAULT 504 18-Oct-18 GULBARGA 220 LINGAPUR-GADAG1 ILC_IPP,XINDIA_IPP,DHRUVADESH_IPP,GADAG 0:00 13:01 LI | 496 | 17-Oct-18 | GULBARGA | 66 | KOGALI-KUDLIGI | KUDLIGI_66,CHORNOOR_66,BANAVEKAL_66,G UDEKOTE_66,CJHALLI_66,HOSAHALLI_66 | 17:15 | 17:20 | 0:05 | LINE CLEAR AVAILED |
| 17-Oct-18 GULBARGA 66 ITTAGI-HBHALLI II_66 IITAGI-HBHALLI II_66 ITTAGI-HBHALLI II_66 ITTAGI-HBHALLI ITTAGI-Z20 ITTAGI-Z20 ITTAGI-KUDILGI ITTAGI-KUDI | 497 | 17-Oct-18 | GULBARGA | 66 | KOGALI-ATRSOLR | KOGALI_66 | 17:22 | 18:09 | 0:47 | LINE CLEAR AVAILED |
| 17-Oct-18 GULBARGA 66 LV1 ITTAGI_220 20:20 21:10 0:50 TRANSFORMER FAULT | 498 | 17-Oct-18 | GULBARGA | 66 | ITTAGI-HBHALLI | | 16:12 | 17:10 | 0:58 | LINE FAULT |
| 501 17-Oct-18 GULBARGA 66 ITTAGI-KUDILGI1 KUDILIGI_66,KOGALI_66,HANASI_66 20:55 21:15 0:20 LINE FAULT 502 17-Oct-18 GULBARGA 66 ITTAGI-KUDILGI2 CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BAN VEKAL_66,CHORNOOR_66 20:55 22:05 1:10 LINE FAULT 503 18-Oct-18 GULBARGA 400 JSWVL400-GUTTUR GUTTUR_400 0:00 17:37 17:37 LINE FAULT 504 18-Oct-18 GULBARGA 220 LINGAPUR-GADAG1 ILC_IPP,XINDIA_IPP,DHRUVADESH_IPP,GADAG _220 0:00 13:01 13:01 LINE FAULT | 499 | 17-Oct-18 | | 66 | ITTAGI-HBHALLI | | 17:13 | 17:20 | 0:07 | HAND TRIPPED |
| 502 17-Oct-18 GULBARGA 66 ITTAGI-KUDILGI2 CJHALLI_66,GUDEKOTE_66,HOSAHALLI_66,BAN VEKAL_66,CHORNOOR_66 20:55 22:05 1:10 LINE FAULT 503 18-Oct-18 GULBARGA 400 JSWVL400-GUTTUR GUTTUR_400 0:00 17:37 17:37 LINE FAULT 504 18-Oct-18 GULBARGA 220 LINGAPUR-GADAG1 ILC_IPP,XINDIA_IPP,DHRUVADESH_IPP,GADAG _220 0:00 13:01 13:01 LINE FAULT | 500 | 17-Oct-18 | GULBARGA | 66 | LV1 | ITTAGI_220 | 20:20 | 21:10 | 0:50 | TRANSFORMER FAULT |
| 502 17-Oct-18 GULBARGA 66 111AGI-RODILGI2 VEKAL_66,CHORNOOR_66 20:55 22:05 1:10 LINE FAULT 503 18-Oct-18 GULBARGA 400 JSWVL400-GUTTUR GUTTUR_400 0:00 17:37 17:37 LINE FAULT 504 18-Oct-18 GULBARGA 220 LINGAPUR-GADAG1 ILC_IPP,XINDIA_IPP,DHRUVADESH_IPP,GADAG _220 0:00 13:01 13:01 LINE FAULT | 501 | 17-Oct-18 | GULBARGA | 66 | ITTAGI-KUDILGI1 | | 20:55 | 21:15 | 0:20 | LINE FAULT |
| 504 18-Oct-18 GULBARGA 220 LINGAPUR-GADAG1 ILC_IPP,XINDIA_IPP,DHRUVADESH_IPP,GADAG 0:00 13:01 13:01 LINE FAULT | 502 | 17-Oct-18 | GULBARGA | 66 | ITTAGI-KUDILGI2 | | 20:55 | 22:05 | 1:10 | LINE FAULT |
| 504 18-Oct-18 GULBARGA 220 LINGAPUR-GADAG1220 | 503 | 18-Oct-18 | GULBARGA | 400 | JSWVL400-GUTTUR | GUTTUR_400 | 0:00 | 17:37 | 17:37 | LINE FAULT |
| 505 18-Oct-18 GULBARGA 110 JANAWADA-SANTHAPUR SANTHAPUR_110 0:00 0:02 0:02 LINE FAULT | 504 | 18-Oct-18 | GULBARGA | 220 | LINGAPUR-GADAG1 | | 0:00 | 13:01 | 13:01 | LINE FAULT |
| | 505 | 18-Oct-18 | GULBARGA | 110 | JANAWADA-SANTHAPUR | SANTHAPUR_110 | 0:00 | 0:02 | 0:02 | LINE FAULT |

| 506 | 18-Oct-18 | GULBARGA | 110 | HV2 KAMPL | LI_GLB_110 12 | 2:29 | 12:33 | 0:04 | TRANSFORMER FAULT |
|-----|-----------|----------|-----|---|-------------------------------------|------|-------|------|--------------------|
| 507 | 18-Oct-18 | GULBARGA | 110 | | | 8:40 | 19:05 | 0:25 | LINE CLEAR AVAILED |
| 508 | 18-Oct-18 | GULBARGA | 110 | | | 9:10 | 9:17 | 0:07 | LINE CLEAR AVAILED |
| 509 | 18-Oct-18 | GULBARGA | 110 | | | 9:00 | 19:12 | 0:12 | LINE FAULT |
| 510 | 18-Oct-18 | GULBARGA | 110 | | | 3:05 | 13:15 | 0:12 | TRANSFORMER FAULT |
| 511 | 18-Oct-18 | GULBARGA | 110 | | | 2:41 | 12:50 | 0:09 | LINE FAULT |
| 512 | 18-Oct-18 | GULBARGA | 110 | | | 7:43 | 8:22 | 0:39 | LINE CLEAR AVAILED |
| 513 | 18-Oct-18 | GULBARGA | 110 | | | 2:53 | 13:33 | 0:40 | LINE CLEAR AVAILED |
| 514 | 18-Oct-18 | GULBARGA | 110 | | | 1:34 | 3:15 | 1:41 | LINE FAULT |
| 515 | 18-Oct-18 | GULBARGA | 110 | | | 5:25 | 5:34 | 0:09 | TRANSFORMER FAULT |
| | | | | | | 7:15 | 7:20 | | |
| 516 | 18-Oct-18 | GULBARGA | 110 | | | | | 0:05 | TRANSFORMER FAULT |
| 517 | 18-Oct-18 | GULBARGA | 110 | | _ | 7:25 | 12:26 | 5:01 | TRANSFORMER FAULT |
| 518 | 18-Oct-18 | GULBARGA | 110 | HALBURGA-SANTHAPUR SANTHA | IAPUR_110,DONGRAGOA_110,DIGGI_11 0: | 0:06 | 0:08 | 0:02 | LINE FAULT |
| 519 | 18-Oct-18 | GULBARGA | 110 | HV1 LINGAS | SUGUR_220 7: | 7:50 | 10:30 | 2:40 | TRANSFORMER FAULT |
| 520 | 18-Oct-18 | GULBARGA | 110 | HV2 LINGAS | SUGUR_220 10 | 0:20 | 10:30 | 0:10 | LINE CLEAR AVAILED |
| 521 | 18-Oct-18 | GULBARGA | 110 | MALLAT220-KAVITHAL KAVITAI | AL_110 5 | 5:00 | 5:05 | 0:05 | LINE FAULT |
| 522 | 18-Oct-18 | GULBARGA | 110 | MALLAT220-SIRWAR SIRWAR | R_110 8 | 3:15 | 8:50 | 0:35 | LINE FAULT |
| 523 | 18-Oct-18 | GULBARGA | 110 | KAPNOOR220-HUMNABAD1 MARGU | UTTI_110,MAHAGOAN_110 22 | 2:48 | 23:20 | 0:32 | LINE FAULT |
| 524 | 18-Oct-18 | GULBARGA | 110 | KUSTAGI-YELBURGA YELBUR | RGA_110 9 | 9:54 | 17:00 | 7:06 | LINE FAULT |
| 525 | 18-Oct-18 | GULBARGA | 66 | HV2 GUDEK | OTE_66 0 | 0:00 | 0:30 | 0:30 | TRANSFORMER FAULT |
| 526 | 18-Oct-18 | GULBARGA | 66 | HV2 GUDEK | OTE_66 0: | 0:40 | 1:40 | 1:00 | TRANSFORMER FAULT |
| 527 | 18-Oct-18 | GULBARGA | 66 | HANASI-KADALIGI HANAS | 61_66 7: | 7:00 | 7:18 | 0:18 | LINE CLEAR AVAILED |
| 528 | 19-Oct-18 | GULBARGA | 220 | LINGASUGUR-RTPS3 LINGAS | SUGUR_220 21 | 1:55 | 22:40 | 0:45 | LINE FAULT |
| 529 | 19-Oct-18 | GULBARGA | 220 | MALLAT-LINGASUGUR MALLAT | AT_220 21 | 1:50 | 22:40 | 0:50 | LINE FAULT |
| 530 | 19-Oct-18 | GULBARGA | 110 | HV2 KAMPL | LI_GLB_110 8 | 3:29 | 8:37 | 0:08 | TRANSFORMER FAULT |
| 531 | 19-Oct-18 | GULBARGA | 110 | HV1 BYAGAV | WAT_110 13 | 3:40 | 14:00 | 0:20 | TRANSFORMER FAULT |
| 532 | 19-Oct-18 | GULBARGA | 110 | SINDHANOOR220-MUNIRABAD2 KAMPL RWORK | LI_GLB_110,MUKUNDA_110,BTPS_WATE KS | 4:16 | 4:22 | 0:06 | LINE FAULT |
| 533 | 19-Oct-18 | GULBARGA | 110 | SINDHANOOR220-MUNIRABAD2 KAMPL RWORK | LI_GLB_110,MUKUNDA_110,BTPS_WATE KS | 2:30 | 2:40 | 0:10 | LINE FAULT |
| 534 | 19-Oct-18 | GULBARGA | 110 | LV1 ITTAGI_ | _220 19 | 9:00 | 19:14 | 0:14 | TRANSFORMER FAULT |
| 535 | 19-Oct-18 | GULBARGA | 110 | HALBURGA-ACMESOLAR_IPP HALBUI | JRGA_220 11 | 1:06 | 11:09 | 0:03 | LINE FAULT |
| 536 | 19-Oct-18 | GULBARGA | 110 | HUMNABAD220-BIDAR1 HALIKH | HED_110 18 | 8:01 | 18:25 | 0:24 | LINE FAULT |
| 537 | 19-Oct-18 | GULBARGA | 110 | MASKI-SINDHANOOR MASKI_ | | 1:54 | 22:01 | 0:07 | LINE FAULT |
| 538 | 19-Oct-18 | GULBARGA | 110 | MUNIDADAD SINDHANOOD1 VENKA | TAGIDI 110 CANGAVATHI 110 SPEDAM | 7:02 | 7:10 | 0:08 | LINE FAULT |
| 539 | 19-Oct-18 | GULBARGA | 66 | | | 9:00 | 19:20 | 0:20 | LINE FAULT |
| 540 | 20-Oct-18 | | 220 | | | 6:15 | 17:30 | 1:15 | LINE FAULT |
| 541 | 20-Oct-18 | GULBARGA | 220 | | | 7:40 | 17:55 | 0:15 | HAND TRIPPED |
| 542 | 20-Oct-18 | GULBARGA | 220 | | | 2:37 | 3:11 | 0:34 | LINE FAULT |
| 543 | 20-Oct-18 | GULBARGA | 110 | | _ | 9:27 | 16:07 | 6:40 | LINE CLEAR AVAILED |
| 544 | 20-Oct-18 | GULBARGA | 110 | | | 0:00 | 10:24 | 0:24 | LINE CLEAR AVAILED |
| 545 | 20-Oct-18 | GULBARGA | 110 | MALLAT-ALKOD ALKOD | _ | 5:55 | 6:30 | 0:35 | LINE FAULT |
| 546 | 20-Oct-18 | GULBARGA | 110 | - | | 7:30 | 9:30 | 2:00 | LINE CLEAR AVAILED |
| | | | | 10.000 | | | - | | |

| 540 | | GULBARGA | 110 | HUMNABAD-BHALKI | BHALKI_110,LADHA_110,BSSK_IPP ,MGSSK SUGUR FACTORY | 12:17 | 16:30 | 4:13 | LINE CLEAR AVAILED |
|--------|-----------|----------|-----|------------------------------------|---|-------|-------|------|---------------------|
| 548 20 | 20-Oct-18 | GULBARGA | 110 | SIRIGUPPA-SINDHANOOR | SIRIGUPPA_110 | 20:49 | 21:00 | 0:11 | LINE FAULT |
| 549 20 | 20-Oct-18 | GULBARGA | 110 | SIRIGUPPA-SINDHANOOR | SIRIGUPPA_110 | 21:29 | 22:51 | 1:22 | LINE FAULT |
| 550 20 | 20-Oct-18 | GULBARGA | 110 | HV2 | YELBURGA_110 | 6:32 | 6:47 | 0:15 | TRANSFORMER FAULT |
| 551 20 | 20-Oct-18 | GULBARGA | 110 | KOLHAR-SHAHI SLR | KOLHAR_110 | 15:31 | 15:45 | 0:14 | LINE FAULT |
| 552 20 | 20-Oct-18 | GULBARGA | 66 | KOGALI-ATRSOLR | KOGALI_66 | 10:34 | 11:45 | 1:11 | LINE CLEAR AVAILED |
| 553 20 | 20-Oct-18 | GULBARGA | 66 | ITTAGI-RNWSLR1 | ITTAGI_220 | 9:12 | 9:29 | 0:17 | LINE CLEAR AVAILED |
| 554 20 | 20-Oct-18 | GULBARGA | 66 | ITTAGI-CLNMAX2 | ITTAGI_220 | 9:38 | 9:43 | 0:05 | LINE CLEAR AVAILED |
| 555 20 | 20-Oct-18 | GULBARGA | 66 | ITTAGI-RNWSLR1 | ITTAGI_220 | 10:05 | 10:28 | 0:23 | LINE CLEAR AVAILED |
| 556 23 | 21-Oct-18 | GULBARGA | 220 | HV1 | HUMNABAD_220 | 14:35 | 14:42 | 0:07 | TRANSFORMER FAULT |
| 557 23 | 21-Oct-18 | GULBARGA | 220 | HV1 | ITTAGI_220 | 10:10 | 10:55 | 0:45 | LINE CLEAR AVAILED |
| 558 23 | 21-Oct-18 | GULBARGA | 110 | HV1 | MALLAT_220 | 21:35 | 23:59 | 2:24 | TRANSFORMER FAULT |
| 559 23 | 21-Oct-18 | GULBARGA | 66 | LV1 | ITTAGI_220 | 10:10 | 14:40 | 4:30 | LINE CLEAR AVAILED |
| 560 23 | 21-Oct-18 | GULBARGA | 66 | HAGRIBOMMANAHALLI-UPANAYAKANAHALLI | UPANAYAKANAHALLI_66 | 11:31 | 11:51 | 0:20 | MAIN SUPPLY FAILURE |
| 561 23 | 21-Oct-18 | GULBARGA | 66 | HAGRIBOMMANAHALLI-UPANAYAKANAHALLI | NO EFFECTED STATION | 14:44 | 23:59 | 9:15 | MAIN SUPPLY FAILURE |
| 562 23 | 21-Oct-18 | GULBARGA | 66 | KOTTUR-BENNEHALLI | KOTTUR_66 | 10:11 | 14:46 | 4:35 | MAIN SUPPLY FAILURE |
| 563 22 | 22-Oct-18 | GULBARGA | 110 | HV2 | KAMPLI_GLB_110 | 7:46 | 8:10 | 0:24 | TRANSFORMER FAULT |
| 564 22 | 22-Oct-18 | GULBARGA | 110 | HV2 | KAMPLI_GLB_110 | 16:04 | 16:13 | 0:09 | TRANSFORMER FAULT |
| 565 22 | 22-Oct-18 | GULBARGA | 110 | HV2 | DEODURGA_110 | 16:17 | 16:27 | 0:10 | TRANSFORMER FAULT |
| 566 22 | 22-Oct-18 | GULBARGA | 110 | HV4 | KUSTAGI_220 | 17:00 | 17:12 | 0:12 | LOAD CURTAILMENT |
| 567 22 | 22-Oct-18 | GULBARGA | 110 | HV2 | LINGASUGUR_220 | 17:00 | 17:03 | 0:03 | LOAD CURTAILMENT |
| 568 22 | 22-Oct-18 | GULBARGA | 110 | HV3 | LINGASUGUR_220 | 17:00 | 17:15 | 0:15 | LOAD CURTAILMENT |
| 569 22 | 22-Oct-18 | GULBARGA | 110 | HV4 | YELBURGA_110 | 17:00 | 17:14 | 0:14 | LOAD CURTAILMENT |
| 570 22 | 22-Oct-18 | GULBARGA | 110 | HV1 | DHADESUGUR_110 | 18:32 | 18:41 | 0:09 | LOAD CURTAILMENT |
| 571 22 | 22-Oct-18 | GULBARGA | 110 | KOLHAR-SHAHI_SLR | KOLHAR_110 | 21:30 | 22:32 | 1:02 | LINE FAULT |
| 572 22 | 22-Oct-18 | GULBARGA | 110 | RAICHUR-MATMARI | MATMARI_110 | 17:20 | 19:03 | 1:43 | LOAD CURTAILMENT |
| 573 22 | 22-Oct-18 | GULBARGA | 110 | RAICHUR-SINDHANOOR2 | KURDICROSS_110 | 18:20 | 18:35 | 0:15 | LOAD CURTAILMENT |
| 574 22 | 22-Oct-18 | GULBARGA | 110 | HV1 | HATTI_110 | 18:32 | 18:34 | 0:02 | LOAD CURTAILMENT |
| 575 22 | 22-Oct-18 | GULBARGA | 110 | HV1 | MAHAGOAN_110 | 17:00 | 18:00 | 1:00 | LOAD CURTAILMENT |
| 576 22 | 22-Oct-18 | GULBARGA | 110 | SINDHANOOR-RAICHUR2 | MANVI_110,MADALAPUR_110 | 19:37 | 20:00 | 0:23 | LINE FAULT |
| 577 16 | 16-Oct-18 | HASSAN | 220 | HNPR2-GPLPR2 | HOLENARASIPURA_220 | 11:57 | 13:36 | 1:39 | LINE CLEAR AVAILED |
| 578 16 | 16-Oct-18 | HASSAN | 220 | KEMAR-Kavoor1 | KEMAR_220 | 15:18 | 16:46 | 1:28 | LINE FAULT |
| 579 16 | 16-Oct-18 | HASSAN | 220 | KEMAR-Kavoor2 | KEMAR_220 | 15:18 | 16:55 | 1:37 | LINE FAULT |
| 580 16 | 16-Oct-18 | HASSAN | 220 | KEMAR-PUTUR1 | KEMAR_220 | 15:41 | 16:12 | 0:31 | LINE FAULT |
| 581 16 | 16-Oct-18 | HASSAN | 220 | KEMAR-PUTUR2 | KEMAR_220 | 15:42 | 16:12 | 0:30 | LINE FAULT |
| 582 16 | 16-Oct-18 | HASSAN | 220 | KEMAR-UPCL2 | KEMAR_220 | 14:40 | 16:27 | 1:47 | LINE FAULT |
| 583 16 | 16-Oct-18 | HASSAN | 220 | KEMAR-Varahi1 | KEMAR_220 | 12:34 | 13:11 | 0:37 | LINE FAULT |
| 584 16 | 16-Oct-18 | HASSAN | 110 | KEMAR-Guruvykere1 | KEMAR_220 | 16:30 | 17:32 | 1:02 | LINE FAULT |
| 585 16 | 16-Oct-18 | HASSAN | 110 | KEMAR-Guruvykere2 | KEMAR_220 | 16:30 | 17:35 | 1:05 | LINE FAULT |
| 586 16 | 16-Oct-18 | HASSAN | 110 | KEMAR-NANDHIKUR1 | KEMAR_220 | 14:42 | 16:14 | 1:32 | LINE FAULT |
| 587 16 | 16-Oct-18 | HASSAN | 110 | KEMAR-NANDHIKUR2 | KEMAR_220 | 14:47 | 16:14 | 1:27 | LINE FAULT |
| 588 16 | 16-Oct-18 | HASSAN | 220 | MRSSHM-DAVANGERE | MRSMG_220 | 9:44 | 14:40 | 4:56 | LOAD CURTAILMENT |
| 589 16 | 16-Oct-18 | HASSAN | 220 | MRSSHM-HONNALLI | MRSMG_220 | 9:44 | 14:40 | 4:56 | LOAD CURTAILMENT |

| 590 | 16-Oct-18 | HASSAN | 66 | MRSSHM-BD-1 | MRSMG_220 | 19:04 | 19:30 | 0:26 | LINE FAULT |
|-----|-----------|--------|-----|-----------------------|--------------------|-------|-------|-------|--------------------|
| 591 | 16-Oct-18 | HASSAN | 66 | LV2 | MRSMG_220 | 0:00 | 16:52 | 16:52 | TRANSFORMER FAULT |
| 592 | 16-Oct-18 | HASSAN | 110 | MRSSHM-BADRAVATY2 | MRSMG_220 | 19:10 | 21:46 | 2:36 | LINE FAULT |
| 593 | 16-Oct-18 | HASSAN | 110 | MRSSHM-BADRAVATY2 | MRSMG_220 | 21:47 | 21:53 | 0:06 | HAND TRIPPED |
| 594 | 16-Oct-18 | HASSAN | 110 | HV2 | MRSMG_220 | 0:00 | 15:55 | 15:55 | TRANSFORMER FAULT |
| 595 | 16-Oct-18 | HASSAN | 110 | MRSSHM-MPM | MRSMG_220 | 18:36 | 22:45 | 4:09 | LINE FAULT |
| 596 | 16-Oct-18 | HASSAN | 220 | MSEZ-KAVOOR2 | MSEZ_220 | 15:52 | 16:39 | 0:47 | LINE FAULT |
| 597 | 16-Oct-18 | HASSAN | 220 | MSEZ-KEMAR1 | MSEZ_220 | 15:18 | 16:46 | 1:28 | LINE FAULT |
| 598 | 16-Oct-18 | HASSAN | 220 | MSEZ-KEMAR2 | MSEZ_220 | 15:18 | 16:55 | 1:37 | LINE FAULT |
| 599 | 16-Oct-18 | HASSAN | 220 | HV2 | PUTTUR_220 | 15:42 | 16:15 | 0:33 | LOAD CURTAILMENT |
| 600 | 16-Oct-18 | HASSAN | 220 | PUTTUR-KEMAR1 | PUTTUR_220 | 15:45 | 16:13 | 0:28 | LOAD CURTAILMENT |
| 601 | 16-Oct-18 | HASSAN | 220 | PUTTUR-KEMAR2 | PUTTUR_220 | 15:45 | 16:13 | 0:28 | LOAD CURTAILMENT |
| 602 | 16-Oct-18 | HASSAN | 220 | UPCL-KEMAR2 | upcl_gen | 14:28 | 16:27 | 1:59 | LINE FAULT |
| 603 | 16-Oct-18 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 12:44 | 13:12 | 0:28 | LINE FAULT |
| 604 | 16-Oct-18 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 15:41 | 15:50 | 0:09 | LINE FAULT |
| 605 | 16-Oct-18 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 15:41 | 15:51 | 0:10 | LINE FAULT |
| 606 | 16-Oct-18 | HASSAN | 110 | HALADY1-HIRIYADKA | HALADY_110 | 13:34 | 14:40 | 1:06 | HAND TRIPPED |
| 607 | 16-Oct-18 | HASSAN | 110 | HALADY1-HOSANGADI | HALADY_110 | 13:35 | 14:40 | 1:05 | HAND TRIPPED |
| 608 | 16-Oct-18 | HASSAN | 110 | HV1 | HALADY_110 | 13:33 | 14:47 | 1:14 | HAND TRIPPED |
| 609 | 16-Oct-18 | HASSAN | 110 | HV2 | HALADY_110 | 13:34 | 14:44 | 1:10 | HAND TRIPPED |
| 610 | 16-Oct-18 | HASSAN | 110 | HV2 | ARASIKERE_110 | 15:17 | 15:28 | 0:11 | TRANSFORMER FAULT |
| 611 | 16-Oct-18 | HASSAN | 110 | GURUVA-KEMAR2 | GURUVAYANAKERE_110 | 16:29 | 17:37 | 1:08 | LINE FAULT |
| 612 | 16-Oct-18 | HASSAN | 110 | KAVOOR-MCFLine | KAVOOR_220 | 15:52 | 16:35 | 0:43 | LINE FAULT |
| 613 | 16-Oct-18 | HASSAN | 110 | KONAJE-MANJESWARG | KONAJE_110 | 15:43 | 15:51 | 0:08 | LOAD CURTAILMENT |
| 614 | 16-Oct-18 | HASSAN | 110 | KUNDAP-MADHUV | KUNDAPURA_110 | 10:44 | 10:52 | 0:08 | LOAD CURTAILMENT |
| 615 | 16-Oct-18 | HASSAN | 110 | LPH-LST4 | lph_gen | 14:39 | 15:31 | 0:52 | LINE FAULT |
| 616 | 16-Oct-18 | HASSAN | 110 | MOODAB-GURUPURA | MOODABIDRE_110 | 15:05 | 15:29 | 0:24 | LOAD CURTAILMENT |
| 617 | 16-Oct-18 | HASSAN | 110 | MOODAB-GURUPURA | MOODABIDRE_110 | 15:47 | 16:10 | 0:23 | LOAD CURTAILMENT |
| 618 | 16-Oct-18 | HASSAN | 110 | MOODAB-SOHAM1 | MOODABIDRE_110 | 15:05 | 15:29 | 0:24 | LOAD CURTAILMENT |
| 619 | 16-Oct-18 | HASSAN | 110 | MOODAB-SOHAM1 | MOODABIDRE_110 | 15:47 | 16:10 | 0:23 | LOAD CURTAILMENT |
| 620 | 16-Oct-18 | HASSAN | 110 | MOODAB-SOHAM2 | MOODABIDRE_110 | 15:05 | 15:29 | 0:24 | LOAD CURTAILMENT |
| 621 | 16-Oct-18 | HASSAN | 110 | MOODAB-SOHAM2 | MOODABIDRE_110 | 15:47 | 16:10 | 0:23 | LOAD CURTAILMENT |
| 622 | 16-Oct-18 | HASSAN | 110 | LV2 | PUTTUR_220 | 15:42 | 16:16 | 0:34 | LOAD CURTAILMENT |
| 623 | 16-Oct-18 | HASSAN | 110 | PUTTUR-PUTUR 1 | PUTTUR_220 | 15:42 | 16:16 | 0:34 | LOAD CURTAILMENT |
| 624 | 16-Oct-18 | HASSAN | 110 | PUTTUR-SLTR | PUTTUR_220 | 15:46 | 16:22 | 0:36 | LOAD CURTAILMENT |
| 625 | 16-Oct-18 | HASSAN | 110 | PUTTUR-KARAYA | PUTTUR_220 | 15:46 | 16:19 | 0:33 | LOAD CURTAILMENT |
| 626 | 16-Oct-18 | HASSAN | 110 | KITTADAHALLI-BELIGAVI | KITTADAHALLI_110 | 10:15 | 19:30 | 9:15 | LINE CLEAR AVAILED |
| 627 | 16-Oct-18 | HASSAN | 110 | HV1 | SHIKARIPURA_110 | 15:20 | 17:05 | 1:45 | LINE CLEAR AVAILED |
| 628 | 16-Oct-18 | HASSAN | 110 | SHRLKP-KITTADAHALLI | SHIRALKOPPA_220 | 12:49 | 23:59 | 11:10 | HAND TRIPPED |
| 629 | 16-Oct-18 | HASSAN | 110 | HV2 | VITLA_110 | 15:15 | 15:18 | 0:03 | HAND TRIPPED |
| 630 | 16-Oct-18 | HASSAN | 110 | HV2 | VITLA_110 | 17:02 | 17:24 | 0:22 | LOAD CURTAILMENT |
| 631 | 16-Oct-18 | HASSAN | 66 | HV1 | HANGRANAHALLI_66 | 23:24 | 23:34 | 0:10 | TRANSFORMER FAULT |
| 632 | 16-Oct-18 | HASSAN | 66 | HV2 | HIRISAVE_66 | 14:09 | 14:40 | 0:31 | LINE CLEAR AVAILED |

| 633 | 16-Oct-18 | HASSAN | 66 | HV2 | HIRISAVE_66 | 15:41 | 16:02 | 0:21 | LINE CLEAR AVAILED |
|-----|-----------|--------|-----|--------------------|-----------------|-------|-------|-------|--------------------|
| 634 | 16-Oct-18 | HASSAN | 66 | HV2 | HNPURA_66 | 15:32 | 16:21 | 0:49 | LINE CLEAR AVAILED |
| 635 | 16-Oct-18 | HASSAN | 66 | HV1 | HNPURA_66 | 12:15 | 14:10 | 1:55 | LINE CLEAR AVAILED |
| 636 | 16-Oct-18 | HASSAN | 66 | HNPURA-SOMANAHALLI | HNPURA_66 | 23:24 | 23:34 | 0:10 | LOAD CURTAILMENT |
| 637 | 17-Oct-18 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 11:20 | 23:59 | 12:39 | LINE FAULT |
| 638 | 17-Oct-18 | HASSAN | 220 | HV2 | PUTTUR_220 | 14:33 | 15:00 | 0:27 | LINE CLEAR AVAILED |
| 639 | 17-Oct-18 | HASSAN | 220 | SHRAVTY-SIRISI 1 | sharavathy_gen | 10:14 | 14:32 | 4:18 | HAND TRIPPED |
| 640 | 17-Oct-18 | HASSAN | 220 | SHRAVTY-SIRISI 2 | sharavathy_gen | 0:00 | 9:17 | 9:17 | LINE FAULT |
| 641 | 17-Oct-18 | HASSAN | 220 | HV1 | SHIRALKOPPA_220 | 18:01 | 18:20 | 0:19 | HAND TRIPPED |
| 642 | 17-Oct-18 | HASSAN | 66 | HASSN22-ARAKALGUD | HASSAN_220 | 6:38 | 6:53 | 0:15 | LINE FAULT |
| 643 | 17-Oct-18 | HASSAN | 66 | BALLUPE-HASSAN | BALLUPETE_66 | 10:11 | 14:04 | 3:53 | NBFC ISSUED |
| 644 | 17-Oct-18 | HASSAN | 66 | GORUR-ARAKALGUD | GORUR_66 | 6:52 | 7:03 | 0:11 | LOAD CURTAILMENT |
| 645 | 17-Oct-18 | HASSAN | 66 | HV1 | MAGGE_66 | 10:21 | 14:05 | 3:44 | NBFC ISSUED |
| 646 | 17-Oct-18 | HASSAN | 66 | HV2 | MAGGE_66 | 10:21 | 14:08 | 3:47 | NBFC ISSUED |
| 647 | 17-Oct-18 | HASSAN | 66 | HV1 | SIGEBAGE_66 | 10:03 | 10:22 | 0:19 | TRANSFORMER FAULT |
| 648 | 18-Oct-18 | HASSAN | 220 | GERSOPA-TALGUPA1 | gerusoppa_gen | 16:01 | 16:58 | 0:57 | HAND TRIPPED |
| 649 | 18-Oct-18 | HASSAN | 220 | GERSOPA-TALGUPA1 | gerusoppa_gen | 6:53 | 7:31 | 0:38 | HAND TRIPPED |
| 650 | 18-Oct-18 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 0:00 | 18:30 | 18:30 | LINE FAULT |
| 651 | 18-Oct-18 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 13:29 | 19:07 | 5:38 | LINE FAULT |
| 652 | 18-Oct-18 | HASSAN | 220 | KEMAR-Varahi3 | KEMAR_220 | 6:42 | 8:17 | 1:35 | LINE FAULT |
| 653 | 18-Oct-18 | HASSAN | 220 | MRSSHM-ANTRSNH | MRSMG_220 | 6:53 | 7:29 | 0:36 | HAND TRIPPED |
| 654 | 18-Oct-18 | HASSAN | 220 | MRSSHM-DAVANGERE | MRSMG_220 | 6:53 | 7:30 | 0:37 | HAND TRIPPED |
| 655 | 18-Oct-18 | HASSAN | 220 | MRSSHMHASSAN | MRSMG_220 | 6:53 | 7:20 | 0:27 | HAND TRIPPED |
| 656 | 18-Oct-18 | HASSAN | 220 | MRSSHM-HONNALLI | MRSMG_220 | 6:53 | 7:31 | 0:38 | HAND TRIPPED |
| 657 | 18-Oct-18 | HASSAN | 220 | MRSSHM-HSN4001 | MRSMG_220 | 6:53 | 7:23 | 0:30 | HAND TRIPPED |
| 658 | 18-Oct-18 | HASSAN | 220 | HV1 | MRSMG_220 | 6:53 | 7:15 | 0:22 | HAND TRIPPED |
| 659 | 18-Oct-18 | HASSAN | 220 | HV2 | MRSMG_220 | 6:53 | 7:17 | 0:24 | HAND TRIPPED |
| 660 | 18-Oct-18 | HASSAN | 220 | HV3 | MRSMG_220 | 6:53 | 7:16 | 0:23 | HAND TRIPPED |
| 661 | 18-Oct-18 | HASSAN | 220 | MRSSHM-KADUR | MRSMG_220 | 6:53 | 7:20 | 0:27 | HAND TRIPPED |
| 662 | 18-Oct-18 | HASSAN | 220 | MRSSHM-KBCRS | MRSMG_220 | 7:34 | 7:36 | 0:02 | HAND TRIPPED |
| 663 | 18-Oct-18 | HASSAN | 220 | MRSSHM-KBCRS | MRSMG_220 | 7:26 | 7:29 | 0:03 | HAND TRIPPED |
| 664 | 18-Oct-18 | HASSAN | 220 | MRSSHM-KBCRS | MRSMG_220 | 6:53 | 7:29 | 0:36 | HAND TRIPPED |
| 665 | 18-Oct-18 | HASSAN | 220 | MRSSHM-KBCRS | MRSMG_220 | 7:25 | 7:30 | 0:05 | HAND TRIPPED |
| 666 | 18-Oct-18 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMG_220 | 6:53 | 7:31 | 0:38 | HAND TRIPPED |
| 667 | 18-Oct-18 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMG_220 | 16:00 | 16:58 | 0:58 | HAND TRIPPED |
| 668 | 18-Oct-18 | HASSAN | 220 | MRSSHM-SHARAVATHY2 | MRSMG_220 | 6:53 | 7:12 | 0:19 | HAND TRIPPED |
| 669 | 18-Oct-18 | HASSAN | 220 | MRSSHM-SHARAVATHY3 | MRSMG_220 | 6:53 | 7:11 | 0:18 | HAND TRIPPED |
| 670 | 18-Oct-18 | HASSAN | 220 | MRSSHM-SHARAVATHY4 | MRSMG_220 | 6:53 | 7:12 | 0:19 | HAND TRIPPED |
| 671 | 18-Oct-18 | HASSAN | 220 | MRSSHM-VARAHI1 | MRSMG_220 | 6:53 | 7:34 | 0:41 | HAND TRIPPED |
| 672 | 18-Oct-18 | HASSAN | 220 | MRSSHM-VARAHI2 | MRSMG_220 | 6:53 | 7:51 | 0:58 | HAND TRIPPED |
| 673 | 18-Oct-18 | HASSAN | 220 | MRSSHM-VARAHI3 | MRSMG_220 | 6:53 | 23:59 | 17:06 | HAND TRIPPED |
| 674 | 18-Oct-18 | HASSAN | 220 | MRSSHM-VARAHI1 | MRSMG_220 | 17:54 | 20:33 | 2:39 | LINE FAULT |
| 675 | 18-Oct-18 | HASSAN | 66 | MRSSHM-BD-1 | MRSMG_220 | 7:01 | 7:27 | 0:26 | HAND TRIPPED |

| (7, | 10.0 . 10 | | | A ADOQUIA A DD O | 1 4D01 40 000 | 7.04 | 0.40 | 4.40 | LUAND TRIBBED |
|-----|-----------|--------|-----|--------------------|--------------------|-------|-------|------|--------------------|
| 676 | 18-Oct-18 | HASSAN | 66 | MRSSHM-BD-2 | MRSMG_220 | 7:01 | 8:13 | 1:12 | HAND TRIPPED |
| 677 | 18-Oct-18 | HASSAN | 66 | MRSSHM-DVG2 | MRSMG_220 | 6:53 | 7:26 | 0:33 | HAND TRIPPED |
| 678 | 18-Oct-18 | HASSAN | 66 | MRSSHM-DVG2 | MRSMG_220 | 11:44 | 12:37 | 0:53 | HAND TRIPPED |
| 679 | 18-Oct-18 | HASSAN | 66 | MRSSHM-HOLUR | MRSMG_220 | 6:53 | 7:26 | 0:33 | HAND TRIPPED |
| 680 | 18-Oct-18 | HASSAN | 66 | LV1 | MRSMG_220 | 7:01 | 7:25 | 0:24 | HAND TRIPPED |
| 681 | 18-Oct-18 | HASSAN | 66 | LV2 | MRSMG_220 | 7:01 | 7:25 | 0:24 | HAND TRIPPED |
| 682 | 18-Oct-18 | HASSAN | 66 | LV3 | MRSMG_220 | 7:01 | 7:25 | 0:24 | HAND TRIPPED |
| 683 | 18-Oct-18 | HASSAN | 66 | LV4 | MRSMG_220 | 7:01 | 7:24 | 0:23 | HAND TRIPPED |
| 684 | 18-Oct-18 | HASSAN | 220 | SHRAVTY-STRP2 | sharavathy_gen | 13:29 | 19:07 | 5:38 | LINE FAULT |
| 685 | 18-Oct-18 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 6:42 | 8:59 | 2:17 | LINE FAULT |
| 686 | 18-Oct-18 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 6:42 | 7:09 | 0:27 | LINE FAULT |
| 687 | 18-Oct-18 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 8:17 | 8:24 | 0:07 | LINE FAULT |
| 688 | 18-Oct-18 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 13:37 | 13:49 | 0:12 | LINE FAULT |
| 689 | 18-Oct-18 | HASSAN | 220 | VARAHI-KEMAR3 | varahi_gen | 6:42 | 15:50 | 9:08 | LINE FAULT |
| 690 | 18-Oct-18 | HASSAN | 220 | VARAHI-SHIMOGA1 | varahi_gen | 6:53 | 8:56 | 2:03 | LINE FAULT |
| 691 | 18-Oct-18 | HASSAN | 220 | VARAHI-SHIMOGA1 | varahi_gen | 17:54 | 20:33 | 2:39 | LINE FAULT |
| 692 | 18-Oct-18 | HASSAN | 220 | VARAHISHIMOGA2 | varahi_gen | 6:53 | 8:57 | 2:04 | LINE FAULT |
| 693 | 18-Oct-18 | HASSAN | 220 | VARAHI-SHMG3 | varahi_gen | 7:18 | 16:38 | 9:20 | LINE FAULT |
| 694 | 18-Oct-18 | HASSAN | 110 | HALADY1HIRIYADKA | HALADY_110 | 6:42 | 6:54 | 0:12 | LINE FAULT |
| 695 | 18-Oct-18 | HASSAN | 110 | HALADY1-HIRIYADKA | HALADY_110 | 8:17 | 8:38 | 0:21 | LINE FAULT |
| 696 | 18-Oct-18 | HASSAN | 110 | HALADY1-HOSANGADI | HALADY_110 | 6:42 | 7:02 | 0:20 | LINE FAULT |
| 697 | 18-Oct-18 | HASSAN | 110 | HALADY1-HOSANGADI | HALADY_110 | 8:17 | 8:39 | 0:22 | LINE FAULT |
| 698 | 18-Oct-18 | HASSAN | 66 | ALDUR-BALEHONNUR | ALDUR_66 | 13:47 | 13:57 | 0:10 | HAND TRIPPED |
| 699 | 18-Oct-18 | HASSAN | 66 | CHIKMAL1-ALDUR | CHIKMAGALUR_66 | 14:39 | 14:55 | 0:16 | LINE FAULT |
| 700 | 18-Oct-18 | HASSAN | 66 | HV1 | HAGARE_66 | 10:29 | 10:39 | 0:10 | TRANSFORMER FAULT |
| 701 | 18-Oct-18 | HASSAN | 66 | HV1 | HAGARE_66 | 10:43 | 10:47 | 0:04 | TRANSFORMER FAULT |
| 702 | 18-Oct-18 | HASSAN | 66 | HV1 | HASSAN_66 | 11:39 | 13:19 | 1:40 | LINE CLEAR AVAILED |
| 703 | 18-Oct-18 | HASSAN | 66 | HNPR2-HNPR1 | HOLENARASIPURA_220 | 18:57 | 20:10 | 1:13 | LINE FAULT |
| 704 | 18-Oct-18 | HASSAN | 66 | MOSALEH-HNPRA | MOSALEHOSAHALLI_66 | 7:25 | 7:27 | 0:02 | LINE CLEAR AVAILED |
| 705 | 18-Oct-18 | HASSAN | 66 | HV1 | MOSALEHOSAHALLI_66 | 7:24 | 7:27 | 0:03 | HAND TRIPPED |
| 706 | 18-Oct-18 | HASSAN | 66 | SAKALE-IPCL1 | SAKLESHAPURA_66 | 16:43 | 17:05 | 0:22 | LINE FAULT |
| 707 | 18-Oct-18 | HASSAN | 66 | SAKALE-IPCL2 | SAKLESHAPURA_66 | 16:43 | 17:04 | 0:21 | LINE FAULT |
| 708 | 18-Oct-18 | HASSAN | 66 | SIGEBAG-SMG-DVG2 | SIGEBAGE_66 | 11:43 | 12:25 | 0:42 | LOAD CURTAILMENT |
| 709 | 18-Oct-18 | HASSAN | 66 | HV1 | MALLAPURA_66 | 11:24 | 11:59 | 0:35 | TRANSFORMER FAULT |
| 710 | 18-Oct-18 | HASSAN | 66 | HV2 | MALLAPURA_66 | 11:24 | 12:00 | 0:36 | TRANSFORMER FAULT |
| 711 | 19-Oct-18 | HASSAN | 220 | KEMARVarahi1 | KEMAR_220 | 14:46 | 15:00 | 0:14 | LINE FAULT |
| 712 | 19-Oct-18 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 14:46 | 15:00 | 0:14 | LINE FAULT |
| 713 | 19-Oct-18 | HASSAN | 220 | MRSSHMVARAHI1 | MRSMG_220 | 14:06 | 14:15 | 0:09 | LINE FAULT |
| 714 | 19-Oct-18 | HASSAN | 220 | SHRAVTY-TALAGUPPA1 | sharavathy_gen | 18:50 | 18:55 | 0:05 | LINE FAULT |
| 715 | 19-Oct-18 | HASSAN | 220 | VARAHI-KEMAR1 | varahi_gen | 14:46 | 15:00 | 0:14 | LINE FAULT |
| 716 | 19-Oct-18 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 14:46 | 15:01 | 0:15 | LINE FAULT |
| 717 | 19-Oct-18 | HASSAN | 220 | VARAHI-SHIMOGA1 | varahi_gen | 14:06 | 14:15 | 0:09 | LINE FAULT |
| | 19-Oct-18 | HASSAN | 220 | VARAHI-SHMG3 | varahi_gen | 14:46 | 14:56 | 0:10 | LINE FAULT |

| 719 | 19-Oct-18 | HASSAN | 66 | BALLUPE-HASSAN | BALLUPETE_66 | 14:45 | 16:40 | 1:55 | LOAD CURTAILMENT |
|-----|-----------|--------|-----|--------------------|----------------------|-------|-------|-------|--------------------|
| 720 | 19-Oct-18 | HASSAN | 66 | HV1 | HAGARE_66 | 8:22 | 8:54 | 0:32 | TRANSFORMER FAULT |
| 721 | 19-Oct-18 | HASSAN | 66 | HV1 | MOSALEHOSAHALLI_66 | 18:30 | 18:47 | 0:17 | TRANSFORMER FAULT |
| 722 | 19-Oct-18 | HASSAN | 66 | HV1 | MOSALEHOSAHALLI_66 | 18:51 | 18:57 | 0:06 | TRANSFORMER FAULT |
| 723 | 20-Oct-18 | HASSAN | 220 | MRSMG_220 | MRSSHM-VARAHI3 | 0:00 | 11:52 | 11:52 | HAND TRIPPED |
| 724 | 20-Oct-18 | HASSAN | 220 | MRSMG_220 | MRSSHM-VARAHI3 | 11:53 | 14:47 | 2:54 | LINE CLEAR AVAILED |
| 725 | 20-Oct-18 | HASSAN | 220 | SHRAVATY_GEN | SHRAVTY-SIRISI 1 | 9:53 | 19:49 | 9:56 | NBFC ISSUED |
| 726 | 20-Oct-18 | HASSAN | 220 | SHRAVATY_GEN | SHRAVTY-SIRISI 2 | 9:54 | 19:40 | 9:46 | NBFC ISSUED |
| 727 | 20-Oct-18 | HASSAN | 220 | SHRAVATY_GEN | SHRAVTY-TALAGUPPA1 | 1:40 | 13:13 | 11:33 | LINE FAULT |
| 728 | 20-Oct-18 | HASSAN | 220 | SHRAVATY_GEN | SHRAVTY-TALAGUPPA1 | 13:14 | 23:59 | 10:45 | LINE FAULT |
| 729 | 20-Oct-18 | HASSAN | 220 | TALAGUPPA_400 | TALAGU-SGS1 | 14:13 | 23:59 | 9:46 | LINE FAULT |
| 730 | 20-Oct-18 | HASSAN | 220 | VARAHI_GEN | VARAHI-SHMG3 | 11:26 | 14:49 | 3:23 | LINE CLEAR AVAILED |
| 731 | 20-Oct-18 | HASSAN | 110 | HALADY_110 | HALADY-HIRIYADKA | 15:05 | 16:21 | 1:16 | LINE CLEAR AVAILED |
| 732 | 20-Oct-18 | HASSAN | 110 | HALADY_110 | HALADY-HIRIYADKA | 18:35 | 19:15 | 0:40 | LINE CLEAR AVAILED |
| 733 | 20-Oct-18 | HASSAN | 110 | HALADY_110 | HALADY-HOSANGADI | 15:05 | 16:23 | 1:18 | LINE CLEAR AVAILED |
| 734 | 20-Oct-18 | HASSAN | 110 | HALADY_110 | HALADY-HOSANGADI | 18:35 | 19:16 | 0:41 | LINE CLEAR AVAILED |
| 735 | 20-Oct-18 | HASSAN | 66 | HASSAN_220 | HASSN22-SAKLESHPURA1 | 8:35 | 8:49 | 0:14 | LINE FAULT |
| 736 | 20-Oct-18 | HASSAN | 66 | BALLUPETE_66 | BALLUPESAKLESHPURA | 8:35 | 8:57 | 0:22 | LINE FAULT |
| 737 | 21-Oct-18 | HASSAN | 220 | TALAGUPPA_400 | TALAGU-SGS1 | 0:00 | 12:11 | 12:11 | LINE FAULT |
| 738 | 21-Oct-18 | HASSAN | 220 | TALAGUPPA_400 | TALAGU-SGS1 | 12:17 | 23:59 | 11:42 | LINE FAULT |
| 739 | 21-Oct-18 | HASSAN | 220 | VARAHI_GEN | VARAHI-KEMAR3 | 13:38 | 20:15 | 6:37 | LINE FAULT |
| 740 | 21-Oct-18 | HASSAN | 220 | VARAHI_GEN | VARAHI-SHIMOGA1 | 21:06 | 22:23 | 1:17 | LINE CLEAR AVAILED |
| 741 | 21-Oct-18 | HASSAN | 220 | VARAHI_GEN | VARAHISHIMOGA2 | 17:04 | 22:45 | 5:41 | LINE FAULT |
| 742 | 21-Oct-18 | HASSAN | 220 | VARAHI_GEN | VARAHI-SHMG3 | 5:08 | 5:19 | 0:11 | LINE FAULT |
| 743 | 21-Oct-18 | HASSAN | 220 | SHRAVATY_GEN | SHRAVTY-TALAGUPPA1 | 0:00 | 12:11 | 12:11 | LINE FAULT |
| 744 | 21-Oct-18 | HASSAN | 220 | SHRAVATY_GEN | SHRAVTY-TALAGUPPA1 | 12:17 | 23:59 | 11:42 | LINE FAULT |
| 745 | 21-Oct-18 | HASSAN | 220 | MRSMG_220 | MRSSHM-VARAHI1 | 21:06 | 22:24 | 1:18 | LINE CLEAR AVAILED |
| 746 | 21-Oct-18 | HASSAN | 220 | MRSMG_220 | MRSSHM-VARAHI2 | 17:04 | 22:45 | 5:41 | LINE FAULT |
| 747 | 21-Oct-18 | HASSAN | 220 | MRSMG_220 | MRSSHM-VARAHI3 | 5:06 | 5:20 | 0:14 | LINE FAULT |
| 748 | 21-Oct-18 | HASSAN | 220 | KEMAR_220 | KEMAR-Varahi3 | 13:36 | 20:16 | 6:40 | LINE FAULT |
| 749 | 21-Oct-18 | HASSAN | 110 | GAJNUR_110 | GAJNUR-IPP IC LINE | 5:06 | 5:12 | 0:06 | LINE FAULT |
| 750 | 21-Oct-18 | HASSAN | 110 | JOG_GEN | JOG-NK2 | 11:49 | 13:25 | 1:36 | LINE FAULT |
| 751 | 21-Oct-18 | HASSAN | 66 | CHANNARAYAPATNA_66 | CHANNAR-MALLALI | 2:15 | 2:21 | 0:06 | LINE FAULT |
| 752 | 22-Oct-18 | HASSAN | 220 | GERSOPA-SHIMOGA | gerusoppa_gen | 14:31 | 17:29 | 2:58 | LINE CLEAR AVAILED |
| 753 | 22-Oct-18 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 11:54 | 12:24 | 0:30 | LINE FAULT |
| 754 | 22-Oct-18 | HASSAN | 220 | GERSOPA-TALGUPA2 | gerusoppa_gen | 13:50 | 14:16 | 0:26 | LINE FAULT |
| 755 | 22-Oct-18 | HASSAN | 220 | KAVOOR-KEMAR3 | KAVOOR_220 | 10:17 | 17:53 | 7:36 | LINE CLEAR AVAILED |
| 756 | 22-Oct-18 | HASSAN | 220 | KEMAR-Varahi2 | KEMAR_220 | 10:00 | 13:44 | 3:44 | NFBC ISSUED |
| 757 | 22-Oct-18 | HASSAN | 220 | KEMAR-Varahi3 | KEMAR_220 | 15:53 | 16:52 | 0:59 | LINE FAULT |
| 758 | 22-Oct-18 | HASSAN | 220 | KEMAR-Varahi3 | KEMAR_220 | 17:00 | 23:59 | 6:59 | HAND TRIPPED |
| 759 | 22-Oct-18 | HASSAN | 220 | MRSSHM-SHARAVATHY1 | MRSMG_220 | 14:31 | 17:29 | 2:58 | LINE CLEAR AVAILED |
| 760 | 22-Oct-18 | HASSAN | 220 | MRSSHM-VARAHI1 | MRSMG_220 | 13:58 | 17:45 | 3:47 | LINE CLEAR AVAILED |
| 761 | 22-Oct-18 | HASSAN | 220 | MRSSHM-VARAHI2 | MRSMG_220 | 13:58 | 17:46 | 3:48 | LINE CLEAR AVAILED |

| 1802 20-02-18 IMASSAN 220 SHRAYIYTALAGUPRA 2 SHARYIYTALAGUPRA 2 SHARYIYTALAGUPR | 762 | 22-Oct-18 | HASSAN | 66 | MRSSHM-BD-1 | MRSMG_220 | 10:38 | 10:48 | 0:10 | LINE FAULT |
|--|-----|-----------|--------|-----|----------------------------|--------------------------------|-------|-------|-------|---------------------|
| 1961 22 Oct 18 HASSAN 220 SHAWIYT FULLOCUPPAL SHAROWER 900 1345 1345 LINE FRUIT 1970 22 Oct 18 HASSAN 220 TALAGUESSES TALAGUEPPA, 400 10.00 1345 1345 LINE FRUIT 1970 22 Oct 18 HASSAN 220 TALAGUESSES TALAGUEPPA, 400 10.00 1345 1345 LINE FRUIT 1970 22 Oct 18 HASSAN 220 TALAGUESSES TALAGUEPPA, 400 10.00 1350 1415 0.25 LINE FRUIT 1970 22 Oct 18 HASSAN 220 TALAGUESPES TALAGUEPPA, 400 1350 1415 0.25 LINE FRUIT 1970 22 Oct 18 HASSAN 220 VARAHI ESMARIS Warming 930 1344 1350 1415 0.25 LINE FRUIT 1970 22 Oct 18 HASSAN 220 VARAHI ESMARIS Warming 930 1344 343 LINE FRUIT 1970 22 Oct 18 HASSAN 220 VARAHI ESMARIS Warming 930 1344 343 LINE FRUIT 1970 22 Oct 18 HASSAN 220 VARAHI ESMARIS Warming 930 1344 343 LINE FRUIT 1970 22 Oct 18 HASSAN 220 VARAHI ESMARIS Warming 1554 1554 2359 605 LINE FRUIT 1970 22 Oct 18 HASSAN 220 VARAHI SHIMOGAI Warming 1359 1745 344 NBFC ISSUED 1970 22 Oct 18 HASSAN 220 VARAHI SHIMOGAI Warming 1359 1745 344 NBFC ISSUED 1970 22 Oct 18 HASSAN 220 VARAHI SHIMOGAI Warming 1359 1745 344 NBFC ISSUED 1970 22 Oct 18 HASSAN 120 VARAHI SHIMOGAI Warming 1359 1745 344 NBFC ISSUED 1970 22 Oct 18 HASSAN 120 VARAHI SHIMOGAI Warming 1359 1745 346 NBFC ISSUED 1970 22 Oct 18 HASSAN 120 VARAHI SHIMOGAI Warming 1554 1554 1559 1745 345 LINE FRUIT 1970 22 Oct 18 HASSAN 120 VARAHI SHIMOGAI Warming 1554 1554 1559 1745 345 LINE FRUIT 1970 22 Oct 18 HASSAN 120 VARAHI SHIMOGAI Warming 1554 1559 1745 345 LINE FRUIT 1970 1 | | | | | | | | | | |
| 1565 22 Oct-18 HASSAN 220 TALAGUESTS TALAGUEPRA, 400 10-26 1302 2356 HANDREPED 1506 22 Oct-18 HASSAN 220 TALAGUESTS TALAGUEPRA, 400 11-56 12-24 0.30 UNE FAULT 1507 12-26 1305 UNE FAULT 1507 UNE FAULT UNE | 764 | - | HASSAN | 220 | SHRAVTY-TALAGUPPA1 | | 0:00 | 13:45 | 13:45 | LINE FAULT |
| Total Tota | | - | | | | | | | | |
| 166 22 Oct 18 HASSAN 220 TALAGU STRP2 TALAGU PRA (400 1154 1224 0.30 LINE FAULT | 766 | | HASSAN | | | | 10:26 | | | HAND TRIPPED |
| 1868 22 Oct-18 HASSAN 220 VARAHHEMBAE1 Vorini_gen 15:54 16:49 0:55 LINE FAULT | | | | | | | | | | |
| 290 22-00:18 MASSAN 220 VARAH-KEMAR1 Varial_gen 15:54 16:49 0.55 LINE FAULT T70 22-00:18 MASSAN 220 VARAH-KEMAR2 Varial_gen 15:54 16:47 0.53 LINE FAULT T77 22-00:18 MASSAN 220 VARAH-KEMAR3 Varial_gen 15:54 28:59 8:05 LINE FAULT T77 22-00:18 MASSAN 220 VARAH-KEMAR3 Varial_gen 15:54 28:59 8:05 LINE FAULT T77 22-00:18 MASSAN 220 VARAH-KEMAR3 Varial_gen 15:54 28:59 8:05 LINE FAULT T77 22-00:18 MASSAN 220 VARAH-SHIMOGAL Varial_gen 13:59 17:45 3:44 NBIC EISUED T77 22-00:18 MASSAN 220 VARAH-SHIMOGAL Varial_gen 13:59 17:45 3:44 NBIC EISUED T77 22-00:18 MASSAN 220 VARAH-SHIMOGAL Varial_gen 13:59 17:46 3:47 NBIC EISUED T77 22-00:18 MASSAN 220 VARAH-SHIMGS Varial_gen 13:59 17:46 3:47 NBIC EISUED T77 22-00:19 MASSAN 110 HV2 BAIKAMPRDY_110 18:56 23:59 5:03 TRANSFORMER FAULT T77 22-00:19 MASSAN 110 HV2 ESUR. 110 13:08 16:01 0:33 LINE GLERA AVAILED T77 22-00:19 MASSAN 110 KADUR NERELEKERE KADUR_220 11:00 12:49 1:49 LINE CLERA AVAILED T77 22-00:19 MASSAN 110 KADUR NERELEKERE KADUR_220 14:11 14:16 0:05 MANI SUPPLY FAILURE T8:04 T8: | | | | | | | 13:50 | | 0:25 | |
| 270 22 Oct 13 HASSAN 220 VARAH-KEMAR2 variali_gen 9:99 13:44 3:45 LINE CEAR AVAILED 777 22 Oct 18 HASSAN 220 VARAH-KEMAR2 variali_gen 15:54 23:59 8:05 LINE FAULT 772 22 Oct 18 HASSAN 220 VARAH-KEMAR2 variali_gen 13:59 17:45 3:46 NBEC ISSUED 774 22-05:18 HASSAN 220 VARAH-KEMAR2 variali_gen 13:59 17:45 3:46 NBEC ISSUED 774 22-05:18 HASSAN 220 VARAH-KEMAR2 variali_gen 13:59 17:46 3:47 NBEC ISSUED 777 22-05:18 HASSAN 220 VARAH-SHIMOGA2 variali_gen 13:59 17:46 3:47 NBEC ISSUED 777 22-05:18 HASSAN 10 HV2 BAIKAMPROY_110 18:56 23:99 5:03 TRANSFORMER FAULT 777 22-05:18 HASSAN 110 HV2 BAIKAMPROY_110 18:56 23:99 5:03 TRANSFORMER FAULT 777 22-05:18 HASSAN 110 HV2 ESSUE, 130 15:08 16:01 0:33 LINE FAULT 777 22-05:18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:00 12:49 1:49 LINE CLEAR AVAILED 779 22-05:18 HASSAN 110 KADUR-NERELEKERE KADUR_220 14:11 14:16 0:05 HANTTHIPPED 780 22-05:18 HASSAN 110 KADUR-NERELEKERE KADUR_220 18:29 15:19 0:50 MARS SUPPLY FAILURE 781 22-05:18 HASSAN 110 KADUR-NERELEKERE KADUR_220 18:29 15:19 0:50 MARS SUPPLY FAILURE 781 22-05:18 HASSAN 10 SIRIKE-BARANG SIRIKANDOPA_220 17:39 17:50 0:11 MASSUPPLY FAILURE 781 22-05:18 HASSAN 10 SIRIKE-BARANG SIRIKANDOPA_220 17:39 17:50 0:11 MASSUPPLY FAILURE 782 22-05:18 HASSAN 10 SIRIKE-BARANG SIRIKANDOPA_220 17:39 17:50 0:11 MASSUPPLY FAILURE 787 22-05:18 HASSAN 10 SIRIKE-BARANG SIRIKANDOPA_220 17:39 17:50 0:11 MASSUPPLY FAILURE 787 22-05:18 HASSAN 66 BARAGAN-SHMGA SIRIKANDOPA_220 17:39 17:50 0:11 MASSUPPLY FAILURE 787 22-05:18 HASSAN 66 BARAGAN-SHMGA SIRIKANDOPA_220 17:39 17:50 0:11 MASSUPPLY FAILURE 787 22-05:18 HASSAN 66 BARAGAN-SHMGA SIRIKANDOPA_220 17:39 17:50 0:11 | 769 | | | 220 | | | | | | |
| 272 22-0ct-18 HASSAN 220 VARAH-KENAR2 VARAH-LEMAR3 V | 770 | 22-Oct-18 | HASSAN | 220 | VARAHI-KEMAR2 | | 9:59 | 13:44 | 3:45 | LINE CLEAR AVAILED |
| 774 22-Oct-18 HASSAN 220 VARAHI-SHIMOGA1 Varahi_gen 13:59 17:45 3:46 NBFC ISSUED 774 22-Oct-18 HASSAN 220 VARAHI-SHIMOGA2 Varahi_gen 13:59 17:46 3:47 NBFC ISSUED 775 22-Oct-18 HASSAN 220 VARAHI-SHIMOGA2 Varahi_gen 15:54 16:49 0:55 LINE FAULT 776 22-Oct-18 HASSAN 110 HV2 BAIKAMPADY_110 18:56 23:59 5:03 TRANSFORMER FAULT 777 22-Oct-18 HASSAN 110 HV2 BAIKAMPADY_110 18:56 23:59 5:03 TRANSFORMER FAULT 778 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:00 12:49 1:49 LINE CLEAR AVAILED 779 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:00 12:49 1:49 LINE CLEAR AVAILED 780 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:00 12:49 1:49 LINE CLEAR AVAILED 781 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:00 12:49 1:49 LINE CLEAR AVAILED 782 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:10 1:11 1:41 1:41 1:41 781 22-Oct-18 HASSAN 110 SHIKAPLOPERUR SHIKALOPPA_220 17:39 17:50 O:11 MAIN SUPPLY FAILURE 782 22-Oct-18 HASSAN 110 SHIKAPLOPERUR SHIKAPLOPPA_210 11:10 1:11 1:41 NBFC ISSUED 783 22-Oct-18 HASSAN 110 SHIKAPL-NEREKERE SHIKAPLOPPA_210 11:10 1:251 1:41 NBFC ISSUED 784 22-Oct-18 HASSAN 16 SHIKAPL-NEREKERE SHIKAPLOPPA_220 10:00 10:42 0:42 MAIN SUPPLY FAILURE 785 22-Oct-18 HASSAN 16 SHIKAPL-NEREKERE SHIKAPLOPPA_220 10:00 10:41 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 16 SHIKAPLOPPA_220 10:00 10:41 1:10 1:251 1:41 NBFC ISSUED 787 22-Oct-18 HASSAN 16 SHIKAPLOPPA_220 10:00 10:42 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 16 SHIKAPLOPPA_220 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 10 SHIKAPLOPPA_220 10:00 10:42 0:42 MAIN SUPPLY FAILURE 788 22-Oct-18 HASSAN 10 SHIKA | 771 | 22-Oct-18 | HASSAN | 220 | VARAHI-KEMAR2 | varahi_gen | 15:54 | 16:47 | 0:53 | LINE FAULT |
| 2776 22-Oct-18 HASSAN 220 VARAHI-SHIMOGA2 Variahl_gen 13:59 17:46 3:47 NBFC ISSUED 775 22-Oct-18 HASSAN 220 VARAHI-SHIMG3 Variahl_gen 15:54 16:49 0:55 LINE FAULT 776 22-Oct-18 HASSAN 110 HV2 BAIKAMPADY_110 18:56 29:59 5:03 TRANSFORMER FAULT 777 22-Oct-18 HASSAN 110 HV2 ESSUR_110 15:08 16:01 0:53 LINE CLEAR AVAILED 779 22-Oct-18 HASSAN 110 KADUR NERELEKERE KADUR_220 11:00 12:49 1:49 LINE CLEAR AVAILED 779 22-Oct-18 HASSAN 110 KADUR NERELEKERE KADUR_220 14:11 14:16 0:05 HAND TRIPPED 780 22-Oct-18 HASSAN 110 KADUR NERELEKERE KADUR_220 14:11 14:16 0:05 MAIN SUPPLY FAILURE 781 22-Oct-18 HASSAN 110 SHURE-BARANG SHIRALDOFPA_220 17:39 17:50 0:11 MAN SUPPLY FAILURE 782 22-Oct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:18 12:57 1:39 NBFC ISSUED 782 22-Oct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:18 12:57 1:39 NBFC ISSUED 782 22-Oct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:18 12:57 1:39 NBFC ISSUED 782 22-Oct-18 HASSAN 10 SHIVAPU-BIRUR SHIVAPURA_110 11:18 12:57 1:39 NBFC ISSUED 782 22-Oct-18 HASSAN 66 HASSY2-SKPURA HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 782 22-Oct-18 HASSAN 66 HASSY2-SKPURA HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 782 22-Oct-18 HASSAN 66 BHADRA-LINGADAHALLI bhadra_gen 10:00 10:42 O:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRA-LINGADAHALLI bhadra_gen 10:00 10:42 O:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 CHANNAR-UNAPATRA_04 CHANNAR-WARATRA_04 64 14:00 0:42 MAIN SUPPLY FAILURE 788 22-Oct-18 HASSAN 66 CHANNAR-UNAPATRA_04 CHANNAR-WARATRA_04 64 14:00 0:00 10:42 0:42 MAIN SUPPLY FAILURE 788 22-Oct-18 HASSAN 66 CHANNAR-UNAPATRA_04 CHANNAR-WARATRA_04 64 14:00 0:00 0:00 LINE FAULT LINE FAULT L | 772 | 22-Oct-18 | HASSAN | 220 | VARAHI-KEMAR3 | varahi_gen | 15:54 | 23:59 | 8:05 | LINE FAULT |
| 2776 22-Oct-18 HASSAN 220 VARAHI-SHIMOGA2 VARAHI-SHIMOGA2 VARAHI-SHIMOGA2 VARAHI-SHIMOGA2 VARAHI-SHIMOGA2 VARAHI-SHIMOGA2 VARAHI-SHIMOGA2 VARAHI-SHIMOGA3 VARAHI-SHIMOGA3 VARAHI-SHIMOGA 15:54 16:49 0:55 LINE FAULT 777 22-Oct-18 HASSAN 110 HV2 BAIKAMPADY 110 18:56 23:59 5:03 TRANSFORMER FAULT 777 22-Oct-18 HASSAN 110 HV2 ESSUR_110 15:08 16:01 0:53 LINE CLEAR AVAILED 779 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:100 12:49 14:94 LINE CLEAR AVAILED 779 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 14:11 14:16 0:05 HAND TRIPPED 780 22-Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 18:29 19:19 0:50 MAIN SUPPLY FAILURE 781 22-Oct-18 HASSAN 110 SHIMAPU-BIRUR SHIMAPURA_110 11:18 12:57 1:39 NBFC ISSUED 782 22-Oct-18 HASSAN 110 SHIMAPU-BIRUR SHIMAPURA_110 11:18 12:57 1:39 NBFC ISSUED 783 22-Oct-18 HASSAN 110 SHIMAPU-BIRUR SHIMAPURA_110 11:10 12:11 14:1 NBFC ISSUED 784 22-Oct-18 HASSAN 66 HASSN2-SKPURA HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 785 22-Oct-18 HASSAN 66 BHADRA-LINGADAH-LILL Dibadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 66 BHADRA-SHIMGA Dibadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRA-SHIMGA Dibadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 788 22-Oct-18 HASSAN 66 BHADRA-SHIMGA Dibadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 789 22-Oct-18 HASSAN 66 CHANNAR CARABAD Dibadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 789 22-Oct-18 HASSAN 66 CHANNAR CARABAD Dibadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 789 22-Oct-18 HASSAN 66 CHANNAR CARABAD DIBADRA CARABAD DIBADR | 773 | 22-Oct-18 | HASSAN | 220 | VARAHI-SHIMOGA1 | varahi_gen | 13:59 | 17:45 | 3:46 | NBFC ISSUED |
| 776 22 Oct 18 | 774 | 22-Oct-18 | HASSAN | 220 | VARAHI-SHIMOGA2 | | 13:59 | 17:46 | 3:47 | NBFC ISSUED |
| 22-Oct-18 | 775 | 22-Oct-18 | HASSAN | 220 | VARAHI-SHMG3 | varahi_gen | 15:54 | 16:49 | 0:55 | LINE FAULT |
| 778 22 Oct-18 HASSAN 110 KADUR-NERELEKERE KADUR_220 11:00 12:49 1:49 1:49 1:41 11:10 12:51 1:41 14:16 0:05 HAND TRIPPED 1:49 | 776 | 22-Oct-18 | HASSAN | 110 | HV2 | BAIKAMPADY_110 | 18:56 | 23:59 | 5:03 | TRANSFORMER FAULT |
| 779 22-Oct-18 HASSAN 110 KADUR-NERELEKER KADUR_220 14:11 14:16 0:05 HAND TRIPPED | 777 | 22-Oct-18 | HASSAN | 110 | HV2 | ESSUR_110 | 15:08 | 16:01 | 0:53 | LINE CLEAR AVAILED |
| 780 22-Oct-18 HASSAN 110 KADURYGTI KADUR_220 18:29 19:19 0:50 MAIN SUPPLY FAILURE 781 22-Oct-18 HASSAN 110 SHRIKP-BARANG SHIRAKDPA_220 17:39 17:50 O:11 MAIN SUPPLY FAILURE 782 22-Oct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:18 12:57 1:39 NBFC ISSUED 783 22-Oct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:10 12:51 1:41 NBFC ISSUED 784 22-Oct-18 HASSAN 100 SHIVAPU-BIRUR SHIVAPURA_110 11:10 12:51 1:41 NBFC ISSUED 785 22-Oct-18 HASSAN 66 BHADRA-LINGADHALLI Bhadra_gen 10:00 10:04 0:42 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 66 BHADRA-SHINGA 1 Bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRA-SHINGA 1 Bhadra_gen 10:00 10:39 0:39 UINE FAULT 788 22-Oct-18 HASSAN 66 BHADRA-SHINGA 2 Bhadra_gen 10:00 10:39 0:39 UINE FAULT 788 22-Oct-18 HASSAN 66 BHADRA-SHINGA 2 Bhadra_gen 10:00 10:39 0:39 UINE FAULT 789 22-Oct-18 HASSAN 66 HASSAN 66 HAV1 HARIHARAPURA_66 11:33 11:40 0:07 HAND TRIPPED 789 22-Oct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPTNA_66 14:02 14:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE AKKIHEBBAL_66 13:22 14:40 1:17 UINE CLEAR AVAILED 793 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE BASARALU_66 13:22 14:40 1:17 UINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HADPAURA-BASARALU BOSABALU_66 14:09 1:18 1:08 UINE FAULT 797 16-Oct-18 MYSORE 66 HADPAURA-BASARALU BOSABALU_66 14:09 1:29 1:10 UINE FAULT 798 16-Oct-18 MYSORE 66 HADPAURA-BASARALU BOSABALU_66 14:09 1:29 1:10 UINE FAULT | 778 | 22-Oct-18 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 11:00 | 12:49 | 1:49 | LINE CLEAR AVAILED |
| 781 22-Oct-18 HASSAN 110 SHRIKP-BARANG SHIRALKOPPA_220 17:39 17:50 0:11 MAIN SUPPLY FAILURE 782 22-Oct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:18 12:57 1:39 NBFC ISSUED 783 22-Oct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:10 12:51 1:41 NBFC ISSUED 784 22-Oct-18 HASSAN 66 HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 785 22-Oct-18 HASSAN 66 HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 786 22-Oct-18 HASSAN 66 BHADRA-HINGADAHALLI Dhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 66 BHADRA-HIMGADAHALLI Dhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRA-HIMGA 2 Dhadra_gen 10:00 10:39 0:39 LINE FAULT 788 22-Oct-18 HASSAN 66 BHADRA-HIMGA 2 Dhadra_gen 10:00 10:39 0:39 LINE FAULT 788 22-Oct-18 HASSAN 66 HV1 HARIHARAPURA_66 11:33 11:40 0:07 HAND TRIPPED 789 22-Oct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPATINA_66 14:02 14:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE AKKIHEBBAL-66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE AKKIHEBBAL-66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 HV2 BOGADHI-66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HV2 BOGADHI-66 13:22 14:40 1:17 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU BOGADHI-66 14:09 15:18 1:08 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU BOGADHI-66 14:09 15:18 1:08 LINE FAULT 797 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU BOGADHI-66 14:09 15:18 1:09 LINE FAULT 798 16-Oct-18 MYSORE 66 AMADHUVANAHALLI NO STATION 19:15 19:29 0:14 LINE FAULT 800 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA NO STATION 0:19 1:39 | 779 | 22-Oct-18 | HASSAN | 110 | KADUR-NERELEKERE | KADUR_220 | 14:11 | 14:16 | 0:05 | HAND TRIPPED |
| 782 22-0ct-18 HASSAN 110 SHIVAPU-BIRUR SHIVAPURA_110 11:18 12:57 1:39 NBFC ISSUED 783 22-0ct-18 HASSAN 110 SHIVAPU-HERLEKERE SHIVAPURA_110 11:10 12:51 1:41 NBFC ISSUED 784 22-0ct-18 HASSAN 66 HASSAN2-SKPURA HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 785 22-0ct-18 HASSAN 66 BHADRA-LINGADAHALLI bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 786 22-0ct-18 HASSAN 66 BHADRA-SHMGA 1 bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-0ct-18 HASSAN 66 BHADRA-SHMGA 2 bhadra_gen 10:00 10:39 0:39 0:39 LINE FAULT 788 22-0ct-18 HASSAN 66 BHADRA-SHMGA 2 bhadra_gen 10:00 10:39 0:39 0:39 LINE FAULT 789 22-0ct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPATNA_66 11:33 11:40 0:07 HAND TRIPPED 790 16-0ct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-0ct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-0ct-18 MYSORE 66 AKKIHEBBAL-KAVERY HYDRO NO STATION 23:18 23:40 0:22 LINE FAULT 793 16-0ct-18 MYSORE 66 HV2 BASARAU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-0ct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 795 16-0ct-18 MYSORE 66 HANNAR-MADHUVANAHALLI NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-0ct-18 MYSORE 66 HANNAR-MADHUVANAHALLI NO STATION 19:15 19:29 0:14 LINE FAULT 797 16-0ct-18 MYSORE 66 ARNARARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 798 16-0ct-18 MYSORE 66 ARNARARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 799 16-0ct-18 MYSORE 66 ARNARARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 799 16-0ct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-0ct-18 MYSORE 66 MADHUVANAHALLI-H | 780 | 22-Oct-18 | HASSAN | 110 | KADURYGTI | KADUR_220 | 18:29 | 19:19 | 0:50 | MAIN SUPPLY FAILURE |
| 783 22-Oct-18 HASSAN 110 SHIVAPU-NERLEKERE SHIVAPURA_110 11:10 12:51 1:41 NBFC ISSUED 784 22-Oct-18 HASSAN 66 HASSN22-SKPURA HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 785 22-Oct-18 HASSAN 66 BHADRA-LINGADAHALLI bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 66 BHADRA-SHMGA 1 bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRA-SHMGA 2 bhadra_gen 10:00 10:39 0:39 LINE FAULT 788 22-Oct-18 HASSAN 66 BHADRA-SHMGA 2 bhadra_gen 10:00 10:39 0:39 LINE FAULT 789 22-Oct-18 HASSAN 66 HY1 HARIHARAPURA_66 11:33 11:40 0:07 HAND TRIPPED 789 22-Oct-18 MASSAN 66 CHANNAR-JUDAYAPURA CHANNARAYAPATNA_66 14:02 4:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU BOGADHI_66 21:23 21:38 0:14 LINE FAULT 798 16-Oct-18 MYSORE 66 HANDUVANAHALLI NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 66 HANDUVANAHALLI NO STATION 0:19 1:39 1:20 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUTHUR NO STATION 12:58 15:55 2:56 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUTHUR N | 781 | 22-Oct-18 | HASSAN | 110 | SHRLKP-BARANG | SHIRALKOPPA_220 | 17:39 | 17:50 | 0:11 | MAIN SUPPLY FAILURE |
| 784 22-Oct-18 HASSAN 66 HASSN2-SKPURA HASSAN_220 10:08 11:43 1:35 LINE CLEAR AVAILED 785 22-Oct-18 HASSAN 66 BHADRA-LINGADAHALII bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 66 BHADRA-SHMGA 1 bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRA-SHMGA 2 bhadra_gen 10:00 10:39 0:39 0:39 LINE FAULT 788 22-Oct-18 HASSAN 66 BHADRA-SHMGA 2 bhadra_gen 10:00 10:39 0:39 0:39 LINE FAULT 789 22-Oct-18 HASSAN 66 HV1 HARIHARAPURA_66 11:33 11:40 0:07 HAND TRIPPED 789 22-Oct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPATNA_66 14:02 14:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAYER HYDRO NO STATION 23:18 23:40 0:02 LINE FAULT 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 796 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 797 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALU_66 21:23 21:38 0:14 LINE FAULT 798 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:29 1:00 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANDUR 1 NO STATION 15:26 15:32 0:06 LINE FAULT 803 16-Oct-18 MY | 782 | 22-Oct-18 | HASSAN | 110 | SHIVAPU-BIRUR | SHIVAPURA_110 | 11:18 | 12:57 | 1:39 | NBFC ISSUED |
| 785 22-Oct-18 HASSAN 66 BHADRA-LINGADAHALLI bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 786 22-Oct-18 HASSAN 66 BHADRA-SHMGA 1 bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRA-SHMGA 2 bhadra_gen 10:00 10:39 0:39 LINE FAULT 788 22-Oct-18 HASSAN 66 HV1 HARIHARAPURA_66 11:33 11:40 0:07 HAND TRIPPED 789 22-Oct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPATNA_66 14:02 14:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAYERY HYDRO NO STATION 23:18 23:40 0:22 LINE FAULT 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 796 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 797 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALL_66 21:23 21:38 0:14 LINE FAULT 798 16-Oct-18 MYSORE 66 HAMNAR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 20 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 804 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 12:58 15:55 2:56 | 783 | 22-Oct-18 | HASSAN | 110 | SHIVAPU-NERLEKERE | SHIVAPURA_110 | 11:10 | 12:51 | 1:41 | NBFC ISSUED |
| 786 22-Oct-18 HASSAN 66 BHADRA-SHMGA 1 Bhadra_gen 10:00 10:42 0:42 MAIN SUPPLY FAILURE 787 22-Oct-18 HASSAN 66 BHADRASHMGA 2 Bhadra_gen 10:00 10:39 0:39 LINE FAULT 788 22-Oct-18 HASSAN 66 HV1 HARIHARAPURA_66 11:33 11:40 0:07 HAND TRIPPED 789 22-Oct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPATNA_66 14:02 14:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAVERY HYDRO NO STATION 23:18 23:40 0:02 LINE FAULT 793 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 13:22 14:40 1:17 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLL_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLL_66 21:23 21:38 0:14 LINE FAULT 798 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-SARGURU 2 DOORA_66 HULLAHALLI_66 7:26 7:30 0:04 LINE FAULT 800 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KAUNTHUR NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 804 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KAUNTHUR NO STATION 12:58 | 784 | 22-Oct-18 | HASSAN | 66 | HASSN22-SKPURA | HASSAN_220 | 10:08 | 11:43 | 1:35 | LINE CLEAR AVAILED |
| 787 22-Oct-18 HASSAN 66 BHADRASHMGA 2 Bhadra_gen 10:00 10:39 0:39 LINE FAULT 788 22-Oct-18 HASSAN 66 HV1 HARIHARAPURA_66 11:33 11:40 0:07 HAND TRIPPED 789 22-Oct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPATNA_66 14:02 14:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAYERY HYDRO NO STATION 23:18 23:40 0:02 LINE FAULT 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLI_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 790 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 790 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 790 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 790 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 790 16-Oct-18 MYSORE 66 | 785 | 22-Oct-18 | HASSAN | 66 | BHADRA-LINGADAHALLI | bhadra_gen | 10:00 | 10:42 | 0:42 | MAIN SUPPLY FAILURE |
| 788 22-Oct-18 HASSAN 66 HV1 | 786 | 22-Oct-18 | HASSAN | 66 | BHADRA-SHMGA 1 | bhadra_gen | 10:00 | 10:42 | 0:42 | MAIN SUPPLY FAILURE |
| 789 22-Oct-18 HASSAN 66 CHANNAR-UDAYAPURA CHANNARAYAPATNA_66 14:02 14:08 0:06 HAND TRIPPED 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAVERY HYDRO NO STATION 23:18 23:40 0:07 HAND TRIPPED 793 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAVERY HYDRO NO STATION 23:18 23:40 0:02 LINE FAULT 794 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HANDTU | 787 | 22-Oct-18 | HASSAN | 66 | BHADRASHMGA 2 | bhadra_gen | 10:00 | 10:39 | 0:39 | LINE FAULT |
| 790 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 1 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KA PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAVERY HYDRO NO STATION 23:18 23:40 0:02 LINE FAULT 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HV2 BOGADH_66 14:09 15:18 1:08 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU NO STATION 3:44 3:54 0:09 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 66 HANDHUVANHALLI 1 | 788 | 22-Oct-18 | HASSAN | 66 | HV1 | HARIHARAPURA_66 | 11:33 | 11:40 | 0:07 | HAND TRIPPED |
| 791 16-Oct-18 MYSORE 66 AKKIHEBBAL-KR PETE 2 AKKIHEBBAL_66 23:32 23:40 0:07 HAND TRIPPED 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAVERY HYDRO NO STATION 23:18 23:40 0:22 LINE FAULT 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_C6 BESAGARAHALLI_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 20 KADAKOLA-CR NAGARA 1 < | 789 | 22-Oct-18 | HASSAN | 66 | CHANNAR-UDAYAPURA | CHANNARAYAPATNA_66 | 14:02 | 14:08 | 0:06 | HAND TRIPPED |
| 792 16-Oct-18 MYSORE 66 AKKIHEBBAL-KAVERY HYDRO NO STATION 23:18 23:40 0:22 LINE FAULT 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLI_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 66 KADAKOLA-CR NAGARA 2 </td <td>790</td> <td>16-Oct-18</td> <td>MYSORE</td> <td>66</td> <td>AKKIHEBBAL-KR PETE 1</td> <td>AKKIHEBBAL_66</td> <td>23:32</td> <td>23:40</td> <td>0:07</td> <td>HAND TRIPPED</td> | 790 | 16-Oct-18 | MYSORE | 66 | AKKIHEBBAL-KR PETE 1 | AKKIHEBBAL_66 | 23:32 | 23:40 | 0:07 | HAND TRIPPED |
| 793 16-Oct-18 MYSORE 66 HV2 BASARALU_66 13:22 14:40 1:17 LINE CLEAR AVAILED 794 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLI_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 KADAKOLA-SARGURU 2 | 791 | 16-Oct-18 | MYSORE | 66 | AKKIHEBBAL-KR PETE 2 | AKKIHEBBAL_66 | 23:32 | 23:40 | 0:07 | HAND TRIPPED |
| 794 16-Oct-18 MYSORE 66 HV2 BOGADHI_66 14:09 15:18 1:08 LINE CLEAR AVAILED 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLI_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 220 KADAKOLA-SARGURU 2 NO STATION 0:19 1:39 1:20 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 15:26 15:32 0:06 LINE FAULT 802 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOL | 792 | 16-Oct-18 | MYSORE | 66 | AKKIHEBBAL-KAVERY HYDRO | NO STATION | 23:18 | 23:40 | 0:22 | LINE FAULT |
| 795 16-Oct-18 MYSORE 66 CR NAGARA-KOLLEGALA NO STATION 3:44 3:54 0:09 LINE FAULT 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLI_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 KADAKOLA-SARGURU 2 DOORA_66 HURA_66 HULLAHALLI_66 7:26 7:30 0:04 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 15:26 15:32 0:06 LINE FAULT 803 16-Oct-18 MYSORE 66 | 793 | 16-Oct-18 | MYSORE | 66 | HV2 | BASARALU_66 | 13:22 | 14:40 | 1:17 | LINE CLEAR AVAILED |
| 796 16-Oct-18 MYSORE 66 HAMPAPURA-BASARALU KOPPA_66 BESAGARAHALLI_66 DUNDANAHALLI_66 21:23 21:38 0:14 LINE FAULT 797 16-Oct-18 MYSORE 66 HANNUR-MADHUVANAHALLI 1 NO STATION 19:15 19:29 0:14 LINE FAULT 798 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 KADAKOLA-SARGURU 2 DOORA_66 HURA_66 HULLAHALLI_66 7:26 7:30 0:04 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 15:26 15:32 0:06 LINE FAULT 802 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSOR | 794 | 16-Oct-18 | MYSORE | 66 | HV2 | BOGADHI_66 | 14:09 | 15:18 | 1:08 | LINE CLEAR AVAILED |
| The first content of the fir | 795 | 16-Oct-18 | MYSORE | 66 | CR NAGARA-KOLLEGALA | NO STATION | 3:44 | 3:54 | 0:09 | LINE FAULT |
| 798 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 1 NO STATION 0:19 1:29 1:10 LINE FAULT 799 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 KADAKOLA-SARGURU 2 DOORA_66 HURA_66 HULLAHALLI_66 7:26 7:30 0:04 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 15:26 15:32 0:06 LINE FAULT 802 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 6:08 6:14 0:06 LINE FAULT | 796 | 16-Oct-18 | MYSORE | 66 | HAMPAPURA-BASARALU | | 21:23 | 21:38 | 0:14 | LINE FAULT |
| 799 16-Oct-18 MYSORE 220 KADAKOLA-CR NAGARA 2 NO STATION 0:19 1:39 1:20 LINE FAULT 800 16-Oct-18 MYSORE 66 KADAKOLA-SARGURU 2 DOORA_66 HURA_66 HULLAHALLI_66 7:26 7:30 0:04 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 15:26 15:32 0:06 LINE FAULT 802 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 6:08 6:14 0:06 LINE FAULT | 797 | 16-Oct-18 | MYSORE | 66 | HANNUR-MADHUVANAHALLI 1 | NO STATION | 19:15 | 19:29 | 0:14 | LINE FAULT |
| 800 16-Oct-18 MYSORE 66 KADAKOLA-SARGURU 2 DOORA_66 HURA_66 HULLAHALLI_66 7:26 7:30 0:04 LINE FAULT 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 15:26 15:32 0:06 LINE FAULT 802 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 6:08 6:14 0:06 LINE FAULT | 798 | 16-Oct-18 | MYSORE | 220 | KADAKOLA-CR NAGARA 1 | NO STATION | 0:19 | 1:29 | 1:10 | LINE FAULT |
| 801 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KUNTHUR NO STATION 15:26 15:32 0:06 LINE FAULT 802 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 6:08 6:14 0:06 LINE FAULT | 799 | 16-Oct-18 | MYSORE | 220 | KADAKOLA-CR NAGARA 2 | NO STATION | 0:19 | 1:39 | 1:20 | LINE FAULT |
| 802 16-Oct-18 MYSORE 66 MADHUVANAHALLI-HANNUR 1 NO STATION 12:58 15:55 2:56 LINE CLEAR AVAILED 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 6:08 6:14 0:06 LINE FAULT | 800 | 16-Oct-18 | MYSORE | 66 | KADAKOLA-SARGURU 2 | DOORA_66 HURA_66 HULLAHALLI_66 | 7:26 | 7:30 | 0:04 | LINE FAULT |
| 803 16-Oct-18 MYSORE 66 MADHUVANAHALLI-KOLLEGALA 1 NO STATION 6:08 6:14 0:06 LINE FAULT | 801 | 16-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-KUNTHUR | NO STATION | 15:26 | 15:32 | 0:06 | LINE FAULT |
| | 802 | 16-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-HANNUR 1 | NO STATION | 12:58 | 15:55 | 2:56 | LINE CLEAR AVAILED |
| 804 16-Oct-18 MYSORE 66 MADHUVANAHALLI-PG PALYA PGPALYA_66 19:16 19:27 0:11 LINE FAULT | 803 | 16-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-KOLLEGALA 1 | NO STATION | 6:08 | 6:14 | 0:06 | LINE FAULT |
| | 804 | 16-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-PG PALYA | PGPALYA_66 | 19:16 | 19:27 | 0:11 | LINE FAULT |

| 805 | 16-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-PG PALYA | PGPALYA_66 | 19:27 | 20:06 | 0:38 | LINE FAULT |
|-----|-----------|--------|-----|----------------------------|--|-------|-------|------|--------------------|
| 806 | 16-Oct-18 | MYSORE | 66 | | NO STATION | 19:24 | 19:27 | 0:03 | HAND TRIPPED |
| 807 | 16-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-YELANDUR | NO STATION | 19:24 | 19:36 | 0:12 | HAND TRIPPED |
| 808 | 16-Oct-18 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 12:26 | 18:30 | 6:04 | LINE CLEAR AVAILED |
| 809 | 16-Oct-18 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 18:41 | 18:47 | 0:05 | HAND TRIPPED |
| 810 | 16-Oct-18 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 19:12 | 19:18 | 0:06 | TRANSFORMER FAULT |
| 811 | 16-Oct-18 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 21:31 | 21:37 | 0:05 | TRANSFORMER FAULT |
| 812 | 16-Oct-18 | MYSORE | 66 | HV2 | SANTHESARAGUR_66 | 13:31 | 13:37 | 0:06 | HAND TRIPPED |
| 813 | 16-Oct-18 | MYSORE | 66 | HV2 | SANTHESARAGUR_66 | 18:24 | 18:30 | 0:05 | HAND TRIPPED |
| 814 | 16-Oct-18 | MYSORE | 66 | HV2 | SANTHEMARAHALLI_66 | 11:59 | 13:00 | 1:01 | LINE CLEAR AVAILED |
| 815 | 16-Oct-18 | MYSORE | 66 | HV2 | SANTHEMARAHALLI_66 | 13:00 | 13:05 | 0:04 | TRANSFORMER FAULT |
| 816 | 17-Oct-18 | MYSORE | 66 | HV2 | BOGADHI_66 | 12:23 | 15:41 | 3:18 | LINE CLEAR AVAILED |
| 817 | 17-Oct-18 | MYSORE | 66 | HV2 | DEVANOORNGUDU_66 | 15:50 | 16:15 | 0:24 | LINE CLEAR AVAILED |
| 818 | 17-Oct-18 | MYSORE | 66 | HV1 | NAGAMANGALA_66 | 13:33 | 14:05 | 0:31 | HAND TRIPPED |
| 819 | 17-Oct-18 | MYSORE | 66 | HV5 | SFCSHIVA_66 | 14:58 | 16:18 | 1:19 | HAND TRIPPED |
| 820 | 17-Oct-18 | MYSORE | 66 | HV1 | SFCSHIVA_66 | 15:00 | 16:17 | 1:17 | HAND TRIPPED |
| 821 | 17-Oct-18 | MYSORE | 66 | HV2 | SFCSHIVA_66 | 15:00 | 16:17 | 1:17 | HAND TRIPPED |
| 822 | 17-Oct-18 | MYSORE | 66 | HV3 | SFCSHIVA_66 | 15:00 | 16:17 | 1:17 | HAND TRIPPED |
| 823 | 17-Oct-18 | MYSORE | 66 | HV4 | SFCSHIVA_66 | 15:00 | 16:17 | 1:17 | HAND TRIPPED |
| 824 | 17-Oct-18 | MYSORE | 66 | HV2 | DKMAIDANA_66 | 7:41 | 7:47 | 0:05 | TRANSFORMER FAULT |
| 825 | 17-Oct-18 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 12:06 | 12:14 | 0:07 | TRANSFORMER FAULT |
| 826 | 17-Oct-18 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 13:03 | 14:00 | 0:57 | TRANSFORMER FAULT |
| 827 | 17-Oct-18 | MYSORE | 220 | KADAKOLA-KOZIKODE | NO STATION | 10:16 | 16:06 | 5:50 | NBFC ISSUED |
| 828 | 17-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-PG PALYA | PGPALYA_66 | 6:26 | 7:33 | 1:07 | LINE CLEAR AVAILED |
| 829 | 17-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-PG PALYA | PGPALYA_66 | 8:15 | 9:21 | 1:06 | LINE CLEAR AVAILED |
| 830 | 17-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-SFC | NO STATION | 15:03 | 15:05 | 0:01 | HAND TRIPPED |
| 831 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-PGL | NO STATION | 14:52 | 16:17 | 1:25 | HAND TRIPPED |
| 832 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-PPCL | NO STATION | 14:48 | 16:17 | 1:29 | HAND TRIPPED |
| 833 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-SATHEGALA | NO STATION | 14:51 | 16:17 | 1:25 | HAND TRIPPED |
| 834 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-ATRIA | NO STATION | 14:58 | 16:21 | 1:22 | HAND TRIPPED |
| 835 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-SHIMSHA | NO STATION | 14:55 | 16:44 | 1:49 | HAND TRIPPED |
| 836 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-TK HALLI | NO STATION | 15:05 | 16:44 | 1:39 | HAND TRIPPED |
| 837 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-MADHUVANAHALLI | NO STATION | 15:05 | 16:17 | 1:12 | HAND TRIPPED |
| 838 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-VAJAMANGALA | NO STATION | 15:05 | 16:30 | 1:25 | HAND TRIPPED |
| 839 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-5 MW | NO STATION | 14:45 | 16:20 | 1:35 | HAND TRIPPED |
| 840 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-10MW | NO STATION | 14:45 | 16:20 | 1:35 | HAND TRIPPED |
| 841 | 17-Oct-18 | MYSORE | 66 | HANNUR-COWDALLI | BANDALLI_66, COWDALLI_66, MARTAHALLI_66 RAMAPURA_MYS_66 | 14:58 | 15:08 | 0:10 | LINE FAULT |
| 842 | 17-Oct-18 | MYSORE | 66 | HANNUR-MADHUVANAHALLI 1 | NO STATION | 14:58 | 15:08 | 0:10 | LINE FAULT |
| 843 | 17-Oct-18 | MYSORE | 66 | KOLLEGALA-TALAKADU | THALAKADU_66, PARINAMIPURA _66 | 5:04 | 5:13 | 0:09 | LINE FAULT |
| 844 | 17-Oct-18 | MYSORE | 66 | PG PALYA-MADHUVANAHALLI | PGPALYA_66 | 11:55 | 11:58 | 0:03 | LINE FAULT |
| 845 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-MEGHALAPURA | BGPURA_66 CHIDRAVALLI_66 | 13:47 | 16:21 | 2:33 | LINE FAULT |
| 846 | 17-Oct-18 | MYSORE | 66 | SFC SIVA-PGL | NO STATION | 13:47 | 13:56 | 0:08 | LINE FAULT |
| 847 | 18-Oct-18 | MYSORE | 220 | CR NAGARA-MADHUVANAHALLI 2 | NO STATION | 11:16 | 14:49 | 3:32 | HAND TRIPPED |

| 848 | 18-Oct-18 | MYSORE | 66 | DK MAIDANA-KADAKOLA | NO STATION | 14:10 | 15:52 | 1:41 | LINE CLEAR AVAILED |
|-----|-----------|--------|-----|-------------------------------|---|-------|-------|------|---------------------|
| 849 | 18-Oct-18 | MYSORE | 66 | ELAVALA-HOOTAGALLY | ELAVALA_66 | 13:17 | 13:49 | 0:31 | LINE CLEAR AVAILED |
| 850 | 18-Oct-18 | MYSORE | 66 | ELAVALA-HUNSUR | ELAVALA_66 | 13:16 | 13:51 | 0:34 | LINE CLEAR AVAILED |
| 851 | 18-Oct-18 | MYSORE | 66 | ELAVALA-HUNSUR | NO STATION | 10:57 | 11:06 | 0:09 | HAND TRIPPED |
| 852 | 18-Oct-18 | MYSORE | 66 | TARIPURA-MHS | TARIPURA_66 | 13:37 | 13:50 | 0:12 | HAND TRIPPED |
| 853 | 18-Oct-18 | MYSORE | 66 | TARIPURA-TUBINAKERE | TARIPURA_66 | 13:38 | 13:48 | 0:09 | HAND TRIPPED |
| 854 | 18-Oct-18 | MYSORE | 66 | CHUNCHUNKATTE-KR NAGARA | NO STATION | 10:33 | 10:40 | 0:06 | LINE FAULT |
| 855 | 18-Oct-18 | MYSORE | 220 | CR NAGARA-MADHUVANAHALLI 2 | NO STATION | 10:29 | 10:39 | 0:09 | LINE FAULT |
| 856 | 18-Oct-18 | MYSORE | 220 | CR NAGARA-MADHUVANAHALLI 2 | NO STATION | 10:39 | 11:12 | 0:33 | LINE FAULT |
| 857 | 18-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-HANNUR 1 | NO STATION | 6:23 | 6:27 | 0:04 | LINE FAULT |
| 858 | 18-Oct-18 | MYSORE | 66 | RAVANDURU-ADANI | NO STATION | 10:33 | 10:40 | 0:06 | LINE FAULT |
| 859 | 19-Oct-18 | MYSORE | 66 | HV2 | HAMPAPURA_66 | 21:33 | 22:44 | 1:11 | TRANSFORMER FAULT |
| 860 | 19-Oct-18 | MYSORE | 66 | HOOTAGALLI-ELWALA | ELAVALA_66 | 19:26 | 19:33 | 0:06 | LINE FAULT |
| 861 | 19-Oct-18 | MYSORE | 66 | KABHALLY-GUNDLUPETE | NO STATION | 16:17 | 16:34 | 0:17 | LINE FAULT |
| 862 | 19-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-KUNTHUR | NO STATION | 14:08 | 14:13 | 0:05 | LINE FAULT |
| 863 | 19-Oct-18 | MYSORE | 66 | SFC SIVA-PGL | NO STATION | 15:53 | 16:05 | 0:11 | LINE FAULT |
| 864 | 19-Oct-18 | MYSORE | 66 | SFC SIVA-PPCL | NO STATION | 15:53 | 16:03 | 0:10 | LINE FAULT |
| 865 | 19-Oct-18 | MYSORE | 66 | SFC SIVA-5MW | NO STATION | 15:53 | 16:20 | 0:26 | LINE FAULT |
| 866 | 19-Oct-18 | MYSORE | 66 | SFC SIVA-10MW | NO STATION | 15:53 | 16:25 | 0:31 | LINE FAULT |
| 867 | 19-Oct-18 | MYSORE | 220 | CR NAGARA-MADHUVANAHALLI 1 | NO STATION | 10:10 | 14:48 | 4:38 | NBFC ISSUED |
| 868 | 19-Oct-18 | MYSORE | 66 | KOLLEGALA-MADHUVANAHALLI | NO STATION | 17:04 | 18:01 | 0:56 | HAND TRIPPED |
| 869 | 19-Oct-18 | MYSORE | 66 | SFC SIVA-MADHUVANAHALLI | NO STATION | 12:06 | 14:33 | 2:27 | NBFC ISSUED |
| 870 | 19-Oct-18 | MYSORE | 66 | SFC SIVA-SHIMSHA | NO STATION | 16:30 | 17:44 | 1:13 | HAND TRIPPED |
| 871 | 19-Oct-18 | MYSORE | 66 | SFC SIVA-TK HALLI | NO STATION | 16:30 | 17:43 | 1:12 | HAND TRIPPED |
| 872 | 20-Oct-18 | MYSORE | 66 | HV2 | KIKKERI_66 | 12:02 | 13:24 | 1:22 | LINE CLEAR AVAILED |
| 873 | 20-Oct-18 | MYSORE | 66 | HV2 | KRPET_66 | 13:17 | 13:55 | 0:37 | LINE CLEAR AVAILED |
| 874 | 20-Oct-18 | MYSORE | 66 | HV1 | KRPET_220 | 16:47 | 17:33 | 0:45 | LINE CLEAR AVAILED |
| 875 | 20-Oct-18 | MYSORE | 220 | HV1 | VAJAMANGALA_220 | 11:54 | 13:22 | 1:27 | LINE CLEAR AVAILED |
| 876 | 20-Oct-18 | MYSORE | 66 | CHUNCHUNAKATTE-KR NAGARA | CHUNCHUNKATTE_66 | 4:31 | 4:43 | 0:12 | LINE FAULT |
| 877 | 20-Oct-18 | MYSORE | 66 | CR NAGARA-YALANDUR | YELANDUR_66 | 23:18 | 23:24 | 0:06 | LINE FAULT |
| 878 | 20-Oct-18 | MYSORE | 66 | JAKKANAHALLI-NAGMANGALA | NO STATION | 18:22 | 18:40 | 0:17 | LINE FAULT |
| 879 | 20-Oct-18 | MYSORE | 66 | KABHALLY-CLEAN SOLAR | NO STATION | 15:42 | 15:52 | 0:09 | LINE FAULT |
| 880 | 20-Oct-18 | MYSORE | 66 | KUSHALANAGARA 220-BETTADAPURA | BETTADHAPURA_66, KITTUR_66, RAVANDUR_66 | 4:31 | 4:41 | 0:09 | LINE FAULT |
| 881 | 20-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-YELANDUR | NO STATION | 6:09 | 6:15 | 0:06 | LINE FAULT |
| 882 | 20-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-YELANDUR | YELANDUR_66 | 23:19 | 23:27 | 0:08 | LINE FAULT |
| 883 | 20-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-KUNTHUR | NO STATION | 8:22 | 8:27 | 0:04 | LINE FAULT |
| 884 | 20-Oct-18 | MYSORE | 66 | MADHUVANAHALLI-PG PALYA | PGPALYA_66 | 17:26 | 17:34 | 0:08 | LINE FAULT |
| 885 | 20-Oct-18 | MYSORE | 66 | ATTIGULIPURA-HONNALLY | ATTIGULIPURA_66 | 12:34 | 12:50 | 0:15 | HAND TRIPPED |
| 886 | 20-Oct-18 | MYSORE | 66 | MIRLE-KR NAGARA | MIRLE_66 | 19:20 | 19:28 | 0:07 | LINE CLEAR AVAILED |
| 887 | 20-Oct-18 | MYSORE | 66 | VAJMANGALA-DEVNUR(MYS) | NO STATION | 13:06 | 13:27 | 0:21 | LOAD CHANGEOVER |
| 888 | 21-Oct-18 | MYSORE | 66 | HV2 | THALAKADU_66 | 20:18 | 20:29 | 0:10 | MAIN SUPPLY FAILURE |
| 889 | 21-Oct-18 | MYSORE | 66 | HV1 | THALAKADU_66 | 20:18 | 20:29 | 0:10 | MAIN SUPPLY FAILURE |
| 890 | 21-Oct-18 | MYSORE | 66 | HV1 | KADAKOLA_220 | 23:57 | 0:00 | 0:02 | TRANSFORMER FAULT |
| | | | | | - | | | | |

| 001 | 21-Oct-18 | MYSORE | | 1)/2 | I/ADAYOLA 220 | 22.57 | 0.00 | 0.00 | TDANICEODAED FALLIT |
|-----|-----------|--------|----|--|---|-------|-------|-------|---------------------|
| 891 | | | 66 | LV2 | KADAKOLA_220 | 23:57 | 0:00 | 0:02 | TRANSFORMER FAULT |
| 892 | 21-Oct-18 | MYSORE | 66 | KOLLEGALA-MADHUVANAHALLI | NO STATION | 8:35 | 8:52 | 0:17 | LOAD CURTAILMENT |
| 893 | 21-Oct-18 | MYSORE | 66 | SFC SIVA-SHIMSHA | NO STATION | 8:33 | 10:26 | 1:53 | LOAD CURTAILMENT |
| 894 | 21-Oct-18 | MYSORE | 66 | SFC SIVA-TK HALLI | NO STATION | 8:33 | 10:26 | 1:53 | LOAD CURTAILMENT |
| 895 | 21-Oct-18 | MYSORE | 66 | KADAKOLA-DK MAIDANA | DKMAIDANA_66 | 23:57 | 0:00 | 0:02 | LINE FAULT |
| 896 | 21-Oct-18 | MYSORE | 66 | KADAKOLA-SARGURU 2 | DOORA_66, HURA_66 HULLAHALLI_66 | 23:57 | 0:00 | 0:02 | LINE FAULT |
| 897 | 21-Oct-18 | MYSORE | 66 | KADAKOLA-SARGURU 1 | ANTHARSANTHE_66,B MATKERE_66, HDKOTE_66, HAMPAPURA_66, JAIPUR_66 SANTHESARAGUR_66 | 23:57 | 0:00 | 0:02 | LINE FAULT |
| 898 | 21-Oct-18 | MYSORE | 66 | KADAKOLA-VAJMANGALA 1 | MARDIHUNDI_66,AYRALLI_66 | 23:57 | 0:00 | 0:02 | LINE FAULT |
| 899 | 21-Oct-18 | MYSORE | 66 | KADAKOLA-VAJMANGALA 2 | MARDIHUNDI_66,AYRALLI_66 | 23:57 | 0:00 | 0:02 | LINE FAULT |
| 900 | 22-Oct-18 | MYSORE | 66 | DK MAIDANA-KADAKOLA | NO STATION | 11:04 | 18:22 | 7:17 | LOAD CHANGEOVER |
| 901 | 22-Oct-18 | MYSORE | 66 | G UKKADA-METAGALLY | SRIRANGAPATNA_66 | 8:05 | 15:20 | 7:15 | LINE CLEAR AVAILED |
| 902 | 22-Oct-18 | MYSORE | 66 | HV1 | HAMPAPURA_66 | 12:20 | 12:43 | 0:22 | LINE CLEAR AVAILED |
| 903 | 22-Oct-18 | MYSORE | 66 | HV2 | JYOTHINAGARA_66 | 14:29 | 15:07 | 0:37 | LINE CLEAR AVAILED |
| 904 | 22-Oct-18 | MYSORE | 66 | KOLLEGALA-TALAKADU | THALAKADU_66 PARINAMIPURA_66 | 6:23 | 6:34 | 0:11 | LINE FAULT |
| 905 | 22-Oct-18 | MYSORE | 66 | HV2 | PERIYAPATNA_66 | 17:26 | 18:01 | 0:35 | TRANSFORMER FAULT |
| 906 | 22-Oct-18 | MYSORE | 66 | HV1 | SANTHESARAGUR_66 | 12:23 | 13:24 | 1:01 | LINE CLEAR AVAILED |
| 907 | 22-Oct-18 | MYSORE | 66 | VAJAMANGALA-DK MAIDANA | NO STATION | 10:10 | 11:01 | 0:50 | LOAD CHANGEOVER |
| 908 | 16-Oct-18 | TUMKUR | 66 | ANCHEPALYA 220kV- YEDIYUR | YEDIYUR_66 | 22:29 | 23:05 | 0:36 | LINE FAULT |
| 909 | 16-Oct-18 | TUMKUR | 66 | TR-2 | BRAHMASANDRA_66 | 15:03 | 16:30 | 1:26 | LINE CLEAR AVAILED |
| 910 | 16-Oct-18 | TUMKUR | 66 | CHELUR- ANTHRASANAHALLI | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 6:44 | 7:03 | 0:18 | LINE CLEAR AVAILED |
| 911 | 16-Oct-18 | TUMKUR | 66 | TR-2 | CHELURU_66 | 7:35 | 0:00 | 16:25 | LINE CLEAR AVAILED |
| 912 | 16-Oct-18 | TUMKUR | 66 | DYAVARANAHALLI- CELESTIALSOLAR | CELESTIALSOLAR_IPP_66 | 18:47 | 19:53 | 1:06 | LINE FAULT |
| 913 | 16-Oct-18 | TUMKUR | 66 | DYAVARANAHALLI- CELESTIALSOLAR | CELESTIALSOLAR_IPP_66 | 21:47 | 22:16 | 0:28 | LINE FAULT |
| 914 | 16-Oct-18 | TUMKUR | 66 | TR-1 | HALUVAGALU_66 | 12:04 | 13:00 | 0:56 | LINE CLEAR AVAILED |
| 915 | 16-Oct-18 | TUMKUR | 66 | HANAGAL- RAMPURA | NAGASAMUDRA_66, RAMPURA_66 | 20:53 | 20:57 | 0:03 | LINE FAULT |
| 916 | 16-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- RKP 2, HIRIYUR 220KV- RKP 1, HIRIYUR 220KV- ENERCON-1, HIRIYUR 220KV- ENERCON-2 | RKP2_IPP_66,RKP1_IPP_66, ENERCON1_IPP_66, ENERCON2_IPP_66 | 19:15 | 21:46 | 2:31 | LINE FAULT |
| 917 | 16-Oct-18 | TUMKUR | 66 | TR-1 | HONNALI_66 | 10:39 | 12:01 | 1:21 | LINE CLEAR AVAILED |
| 918 | 16-Oct-18 | TUMKUR | 66 | TR-2 | HONNALI_66 | 11:40 | 12:43 | 1:02 | LINE CLEAR AVAILED |
| 919 | 16-Oct-18 | TUMKUR | 66 | HONNALLI 220kV- BANUVALLI | BANUVALLI_66, NANDIGUDI_66, KARGIL_EHT_66 | 6:36 | 6:44 | 0:08 | LINE FAULT |
| 920 | 16-Oct-18 | TUMKUR | 66 | HONNALLI 220kV- CHANNAGIRI | CHANNAGIRI_66, DEVARAHALLI_66, BENKIKERE_66, TAVAREKERE(C)_66, GOPPENAHALLI_66 | 11:34 | 11:45 | 0:10 | LINE FAULT |
| 921 | 16-Oct-18 | TUMKUR | 66 | KALAMARANAHALLI- PR PURA | KALAMARANAHALLI_66 | 18:31 | 18:50 | 0:19 | HAND TRIPPED |
| 922 | 16-Oct-18 | TUMKUR | 66 | KALAMRANAHALLI- TATASOLAR IPP | TATASOLAR_IPP_66 | 13:26 | 13:37 | 0:11 | LINE FAULT |
| 923 | 16-Oct-18 | TUMKUR | 66 | KALAMRANAHALLI- TATASOLAR IPP | TATASOLAR_IPP_66 | 17:53 | 21:01 | 3:07 | LINE FAULT |
| 924 | 16-Oct-18 | TUMKUR | 66 | KEMPANAHALLI - AGALAKOTE | AGALKOTE 66 | 12:36 | 14:00 | 1:23 | LINE CLEAR AVAILED |
| | | 1 | | | | | ,•• | | |

| 925 | 16-Oct-18 | TUMKUR | 66 | KUKKAWADA- LINGADAHALLI | TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 11:36 | 11:49 | 0:13 | LINE FAULT |
|-----|-----------|--------|-----|-----------------------------------|---|-------|-------|------|--------------------|
| 926 | 16-Oct-18 | TUMKUR | 66 | TR-2 | KUKKAWADA_66 | 12:20 | 14:40 | 2:20 | LINE CLEAR AVAILED |
| 927 | 16-Oct-18 | TUMKUR | 66 | KUKKAWADA- SRS DAVANGERE | KUKKAWADA_66, TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 11:36 | 11:44 | 0:08 | LINE FAULT |
| 928 | 16-Oct-18 | TUMKUR | 66 | KUNDUR- RSOLAR | RSOLAR_IPP_66 | 18:22 | 18:35 | 0:12 | LINE FAULT |
| 929 | 16-Oct-18 | TUMKUR | 66 | LINGADAHALLI- P R PURA | LINGADAHALLI_TMK2_66 | 18:37 | 20:18 | 1:40 | HAND TRIPPED |
| 930 | 16-Oct-18 | TUMKUR | 66 | LINGADAHALLI- SHYLAPURA | LINGADAHALLI_TMK2_66 | 18:42 | 18:47 | 0:04 | HAND TRIPPED |
| 931 | 16-Oct-18 | TUMKUR | 66 | MADHUGIRI 220kV- MEDIGESHI | MEDIGESHI_66, HOSKERE_66, PAVAGADA_66, VENKATAPURA_66 | 19:48 | 19:58 | 0:10 | LINE FAULT |
| 932 | 16-Oct-18 | TUMKUR | 66 | NAGALAMADIKE-MADHUGIRI | NAGALMADIKE_66 | 22:02 | 22:29 | 0:27 | LINE FAULT |
| 933 | 16-Oct-18 | TUMKUR | 66 | TR-1 | RAMPURA_66 | 9:43 | 10:28 | 0:45 | LINE CLEAR AVAILED |
| 934 | 16-Oct-18 | TUMKUR | 66 | TR-2 | RAMPURA_66 | 20:29 | 21:00 | 0:31 | TRANSFORMER FAULT |
| 935 | 16-Oct-18 | TUMKUR | 66 | ANCHEPALYA 220kV- YEDIYUR | YEDIYUR_66 | 12:05 | 14:03 | 1:58 | LINE CLEAR AVAILED |
| 936 | 16-Oct-18 | TUMKUR | 66 | TR-1 & 2 | YEDIYUR_66 | 10:59 | 14:04 | 3:04 | LINE CLEAR AVAILED |
| 937 | 16-Oct-18 | TUMKUR | 66 | TR-1 | YNHOSKOTE_66 | 20:22 | 20:27 | 0:05 | TRANSFORMER FAULT |
| 938 | 16-Oct-18 | TUMKUR | 110 | TR-1 | HONNAVALLI_110 | 14:08 | 14:39 | 0:31 | LINE CLEAR AVAILED |
| 939 | 16-Oct-18 | TUMKUR | 110 | TR-1 | AMMASANDRA_110 | 12:05 | 12:47 | 0:41 | LINE CLEAR AVAILED |
| 940 | 16-Oct-18 | TUMKUR | 110 | KB CROSS 220kV- MAYASANDRA | MAYASANDRA_110, TANDAGA_110, KADEHALLI_110 | 11:10 | 15:25 | 4:14 | HAND TRIPPED |
| 941 | 16-Oct-18 | TUMKUR | 110 | TR-1 | KEREKODI_110 | 11:29 | 12:27 | 0:58 | LINE CLEAR AVAILED |
| 942 | 16-Oct-18 | TUMKUR | 220 | TR-3 | HIRIYUR_220 | 19:15 | 19:33 | 0:18 | TRANSFORMER FAULT |
| 943 | 17-Oct-18 | TUMKUR | 110 | TR-1 | GUNGURMALE_110 | 12:54 | 16:21 | 3:26 | LINE CLEAR AVAILED |
| 944 | 17-Oct-18 | TUMKUR | 66 | TR-1 | YNHOSKOTE_66 | 21:32 | 21:38 | 0:05 | TRANSFORMER FAULT |
| 945 | 17-Oct-18 | TUMKUR | 66 | BENNEHALLI-SUZLON | SUZLON_IPP_66 | 17:54 | 18:21 | 0:27 | LOAD CURTAILMENT |
| 946 | 17-Oct-18 | TUMKUR | 66 | CHITRADURGA 220kV- HGML | HGML_IPP_66 | 18:49 | 19:10 | 0:21 | LINE FAULT |
| 947 | 17-Oct-18 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 2 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 14:51 | 15:15 | 0:24 | LINE FAULT |
| 948 | 17-Oct-18 | TUMKUR | 66 | CHITRADURGA 66kV- PANDARAHALLI 2 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 14:50 | 15:20 | 0:30 | LINE FAULT |
| 949 | 17-Oct-18 | TUMKUR | 66 | TR-3 | DAVANGERE_SRS_220 | 23:35 | 23:53 | 0:18 | TRANSFORMER FAULT |
| 950 | 17-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- SOKKE | MELLEKATTE_66, SOKKE_66 | 12:46 | 13:12 | 0:26 | LINE FAULT |
| 951 | 17-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- YARAGUNTA | YARAGUNTA_66, OBAJJIHALLI_66 | 12:13 | 12:26 | 0:12 | LINE FAULT |
| 952 | 17-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- YARAGUNTA | YARAGUNTA_66, OBAJJIHALLI_66 | 12:27 | 15:08 | 2:40 | LINE FAULT |
| 953 | 17-Oct-18 | TUMKUR | 66 | DYAVARANAHALLI- CELESTIALSOLAR | CELESTIALSOLAR_IPP_66 | 6:12 | 6:41 | 0:28 | LINE FAULT |
| 954 | 17-Oct-18 | TUMKUR | 66 | HANAGAL- B G KERE | HANAGAL_66, NAGASAMUDRA_66, RAMPURA_66 | 20:55 | 21:16 | 0:20 | LINE FAULT |
| 955 | 17-Oct-18 | TUMKUR | 66 | TR-1 | HANAGAL_66 | 9:10 | 9:15 | 0:05 | TRANSFORMER FAULT |
| 956 | 17-Oct-18 | TUMKUR | 66 | TR-1 | HANAGAL_66 | 10:02 | 11:04 | 1:02 | TRANSFORMER FAULT |
| 957 | 17-Oct-18 | TUMKUR | 66 | TR-1 | HARAPPANAHALLI_66 | 20:45 | 20:50 | 0:04 | TRANSFORMER FAULT |
| 958 | 17-Oct-18 | TUMKUR | 66 | KUKKAWADA- LINGADAHALLI | TYAVANAGI_66, BASAVAPATNA_66, SANTEBENNUR_66 | 10:11 | 10:17 | 0:05 | LINE FAULT |
| 959 | 17-Oct-18 | TUMKUR | 66 | TR-1 & 2 | LINGDHALLI_66 | 9:17 | 9:35 | 0:18 | HAND TRIPPED |
| 960 | 17-Oct-18 | TUMKUR | 66 | TR-1 | LINGDHALLI_66 | 20:53 | 20:56 | 0:03 | HAND TRIPPED |
| 961 | 17-Oct-18 | TUMKUR | 66 | THALLAK 220kV- CHALLAKERE-2 | CHALLAKERE_66, SANIKERE_66 | 22:35 | 23:39 | 1:03 | LINE FAULT |
| 962 | 18-Oct-18 | TUMKUR | 220 | TR-2 | MADHUGIRI_220 | 3:42 | 8:50 | 5:07 | TRANSFORMER FAULT |
| | | | | • | • | | | | • |

| 963 | 18-Oct-18 | TUMKUR | 220 | TR-3 | HIRIYUR_220 | 1:26 | 8:44 | 7:17 | TRANSFORMER FAULT |
|-----|-----------|--------|-----|---|--|-------|-------|------|---------------------|
| 964 | 18-Oct-18 | TUMKUR | 220 | TR-3 | HIRIYUR_220 | 22:27 | 23:51 | 1:23 | TRANSFORMER FAULT |
| 965 | 18-Oct-18 | TUMKUR | 220 | TR-3 | HIRIYUR_220 | 1:24 | 1:26 | 0:01 | TRANSFORMER FAULT |
| 966 | 18-Oct-18 | TUMKUR | 220 | TR-3 | DAVANGERE_SRS_220 | 4:41 | 5:43 | 1:02 | LINE CLEAR AVAILED |
| 967 | 18-Oct-18 | TUMKUR | 110 | TR-1 | KALLUR_110 | 5:11 | 6:55 | 1:43 | TRANSFORMER FAULT |
| 968 | 18-Oct-18 | TUMKUR | 66 | TR-2 | DAVANAGERE_66 | 0:14 | 1:21 | 1:06 | MAIN SUPPLY FAILURE |
| 969 | 18-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- DAVANGERE | DAVANAGERE_66 | 11:17 | 11:28 | 0:11 | LINE FAULT |
| 970 | 18-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- H- HOSPET | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 3:55 | 5:47 | 1:52 | LINE FAULT |
| 971 | 18-Oct-18 | TUMKUR | 66 | TR-3 | DAVANGERE_SRS_220 | 3:55 | 5:33 | 1:38 | LINE CLEAR AVAILED |
| 972 | 18-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- SOKKE | MELLEKATTE_66, SOKKE_66 | 3:54 | 5:47 | 1:52 | LINE FAULT |
| 973 | 18-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- H- HOSPET | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 12:32 | 12:44 | 0:12 | LINE FAULT |
| 974 | 18-Oct-18 | TUMKUR | 66 | TR-1 | HANAGAL_66 | 14:33 | 14:43 | 0:10 | TRANSFORMER FAULT |
| 975 | 18-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- ENERCON-2, HIRIYUR 220KV- ENERCON-2, HIRIYUR 220KV- RKP 1, HIRIYUR 220KV- RKP 2, HIRIYUR 220KV- BEVINAHALLI, HIRIYUR 220KV- RANGANATHPURA | ENERCON1_IPP_66, ENERCON2_IPP_66, RKP1_IPP_66, RKP2_IPP_66, DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66, RANGANATHAPURA_66 | 8:33 | 8:48 | 0:15 | LINE FAULT |
| 976 | 18-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- RKP 1, HIRIYUR 220KV- RKP 2 | RKP1_IPP_66, RKP2_IPP_66 | 1:24 | 1:26 | 0:01 | LINE FAULT |
| 977 | 18-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- RANGANATHPURA | RANGANATHAPURA_66 | 10:42 | 10:47 | 0:04 | LINE FAULT |
| 978 | 18-Oct-18 | TUMKUR | 66 | HONNALLI 220KV- KUNDUR | KUNDUR_66 | 11:06 | 11:19 | 0:13 | LINE FAULT |
| 979 | 18-Oct-18 | TUMKUR | 66 | KALAMRANAHALLI- TATASOLAR IPP | TATASOLAR_IPP_66 | 19:23 | 20:12 | 0:48 | LINE FAULT |
| 980 | 18-Oct-18 | TUMKUR | 66 | KUNDUR- SUZLON | SUZLON_IPP_66 | 11:19 | 12:27 | 1:07 | LINE FAULT |
| 981 | 18-Oct-18 | TUMKUR | 66 | MADHUGIRI 220kV- SIRA-1 & 2 | SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66 | 21:17 | 21:42 | 0:25 | LINE FAULT |
| 982 | 18-Oct-18 | TUMKUR | 66 | TR-2 | MADHUGIRI_220 | 3:42 | 8:51 | 5:08 | TRANSFORMER FAULT |
| 983 | 18-Oct-18 | TUMKUR | 66 | TR-1 | RAMPURA_66 | 6:53 | 7:02 | 0:09 | LINE CLEAR AVAILED |
| 984 | 18-Oct-18 | TUMKUR | 66 | SIRA- KALLAMBELLA, SIRA- MADHUGIRI 2 | KALLAMBELLA_66, BUKKAPATNA_66, KALLAMBELLA_66 | 10:43 | 11:00 | 0:17 | HAND TRIPPED |
| 985 | 18-Oct-18 | TUMKUR | 66 | SIRA- MADHUGIRI 1 | SIRA_66 | 22:28 | 22:41 | 0:12 | HAND TRIPPED |
| 986 | 18-Oct-18 | TUMKUR | 66 | THALLAK 220kV- CHALLAKERE-2 | CHALLAKERE_66, SANIKERE_66 | 12:50 | 12:55 | 0:05 | LINE FAULT |
| 987 | 18-Oct-18 | TUMKUR | 66 | THALLAK 220kV- NAYAKANHATTI | NAYAKANHATTI_66, HIREMALLANAHOLE_66 | 6:48 | 6:58 | 0:09 | LINE FAULT |
| 988 | 19-Oct-18 | TUMKUR | 220 | TR-3 | HIRIYUR_220 | 6:10 | 6:28 | 0:17 | TRANSFORMER FAULT |
| 989 | 19-Oct-18 | TUMKUR | 220 | TR-3 | HIRIYUR_220 | 18:38 | 18:48 | 0:10 | TRANSFORMER FAULT |
| 990 | 19-Oct-18 | TUMKUR | 110 | TR-1 | KALLUR_110 | 10:13 | 12:30 | 2:16 | LINE CLEAR AVAILED |
| 991 | 19-Oct-18 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 12:58 | 14:31 | 1:33 | LINE FAULT |
| 992 | 19-Oct-18 | TUMKUR | 66 | ANCHEPALYA 220kV- YEDIYUR | YEDIYUR_66 | 8:23 | 8:33 | 0:10 | LINE FAULT |
| 993 | 19-Oct-18 | TUMKUR | 66 | BUKKAPATNA- GOLDENHATCHERIES_IPP | GOLDENHATCHERIES_IPP_66 | 11:55 | 12:15 | 0:20 | MAIN SUPPLY FAILURE |
| 994 | 19-Oct-18 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 1 | PANDARAHALLI_66, HDPURA_66, HOLALKERE_66, CHIKKAJAJUR_66, MAYAKONDA_66, SASALUHALLA_66 | 9:32 | 9:56 | 0:24 | LINE FAULT |
| 995 | 19-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- H- HOSPET | HARIHAR_66, HARIHAR-HOSPET_66, BANUVALLI_66, NANDIGUDI_66 | 10:42 | 10:52 | 0:10 | LINE FAULT |
| | | | | | | | | | |

| 051 | 40.0 : :0 | TI IN (1717) | | D. W. W. GERE ORG. D. W. W. GERE | D.W.W. 0505 // | 10.15 | 40 | 0.5- | |
|------|-----------|--------------|-----|---|---|-------|-------|------|--------------------|
| 996 | 19-Oct-18 | TUMKUR | 66 | DAVANGERE SRS- DAVANGERE | DAVANAGERE_66 | 13:49 | 13:57 | 0:07 | LINE FAULT |
| 997 | 19-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- ENERCON-1, HIRIYUR 220KV- ENERCON-2, HIRIYUR 220kV- BEVINAHALLI, HIRIYUR 220KV- RKP 1, HIRIYUR 220KV- RKP 2 | ENERCON1_IPP_66, ENERCON2_IPP_66, DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66, RKP1_IPP_66, RKP2_IPP_66 | 6:25 | 6:29 | 0:04 | LINE FAULT |
| 998 | 19-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- ENERCON-1, HIRIYUR 220KV- ENERCON-2, HIRIYUR 220KV- BEVINAHALLI, HIRIYUR 220KV- RKP 1, HIRIYUR 220KV- RKP 2, HIRIYUR 220KV- RANGANATHPURA | ENERCON1_IPP_66, ENERCON2_IPP_66, DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66, RKP1_IPP_66, RKP2_IPP_66, RANGANATHAPURA_66 | 18:42 | 18:54 | 0:12 | LINE FAULT |
| 999 | 19-Oct-18 | TUMKUR | 66 | HOSADURGA-MATHOD | HOSADURGA_66, RAMAGIRI_66 | 8:08 | 11:54 | 3:45 | LINE CLEAR AVAILED |
| 1000 | 19-Oct-18 | TUMKUR | 66 | MADHUGIRI 220kV- SIRA | SIRA_66, KALLAMBELLA_66, BUKKAPATNA_66 | 11:00 | 12:06 | 1:05 | LINE CLEAR AVAILED |
| 1001 | 19-Oct-18 | TUMKUR | 66 | NAGALAMADIKE-MADHUGIRI | NAGALMADIKE_66 | 8:56 | 9:12 | 0:16 | LINE FAULT |
| 1002 | 19-Oct-18 | TUMKUR | 66 | NAGALAMADIKE- RNSSOLAR_IPP_66 | RNSSOLAR_IPP_66 | 8:56 | 9:23 | 0:26 | LINE FAULT |
| 1003 | 19-Oct-18 | TUMKUR | 66 | SIRA- BUKKAPATNA, SIRA- KALLAMBELLA, SIRA- MADHUGIRI 1 | BUKKAPATNA_66, KALLAMBELLA_66, SIRA_66 | 11:56 | 12:08 | 0:11 | HAND TRIPPED |
| 1004 | 19-Oct-18 | TUMKUR | 66 | TR-2 | TAVAREKERE(C)_66 | 12:01 | 12:07 | 0:05 | TRANSFORMER FAULT |
| 1005 | 20-Oct-18 | TUMKUR | 220 | TR-3 | HIRIYUR_220 | 7:07 | 7:14 | 0:07 | TRANSFORMER FAULT |
| 1006 | 20-Oct-18 | TUMKUR | 66 | ANCHEPALYA 220kV- HULIYURDURGA | HULIYURDURGA_66, CHAWANAKUPPE_66 | 5:44 | 5:57 | 0:12 | LINE FAULT |
| 1007 | 20-Oct-18 | TUMKUR | 66 | CHIKKABANAGERE- GLOBAL IPP | GLOBALTECHPARK_IPP_66 | 9:29 | 9:33 | 0:04 | LOAD CURTAILMENT |
| 1008 | 20-Oct-18 | TUMKUR | 66 | CHITRADURGA 220kV- PANDARAHALLI 2 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 19:16 | 19:34 | 0:17 | LINE FAULT |
| 1009 | 20-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- ENERCON-1, HIRIYUR 220kV- BEVINAHALLI, HIRIYUR 220KV- RANGANATHPURA, HIRIYUR 220KV- RKP 1, HIRIYUR 220KV- RKP 2 | ENERCON1_IPP_66, DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66, RANGANATHAPURA_66, RKP1_IPP_66, RKP2_IPP_66 | 7:07 | 7:19 | 0:11 | LINE FAULT |
| 1010 | 20-Oct-18 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66 | 12:06 | 12:36 | 0:29 | LINE FAULT |
| 1011 | 20-Oct-18 | TUMKUR | 66 | KALAMRANAHALLI- TATASOLAR IPP | TATASOLAR_IPP_66 | 10:06 | 10:14 | 0:07 | LINE FAULT |
| 1012 | 20-Oct-18 | TUMKUR | 66 | TR-1 | LINGADAHALLI_TMK2_66 | 6:42 | 6:45 | 0:02 | TRANSFORMER FAULT |
| 1013 | 20-Oct-18 | TUMKUR | 66 | THALLAK 220kV- CHALLAKERE | CHALLAKERE_66, SANIKERE_66 | 0:19 | 0:31 | 0:12 | LINE FAULT |
| 1014 | 20-Oct-18 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 9:33 | 13:33 | 4:00 | LINE FAULT |
| 1015 | 20-Oct-18 | TUMKUR | 66 | TR-2 | YARAGUNTA_66 | 13:31 | 15:34 | 2:03 | LINE CLEAR AVAILED |

| 1016 | 21-Oct-18 | TUMKUR | 66 | ANCHEPALYA 220kV- ANCHEPALYA | ANCHEPALYA_66, BHAKTHARAHALLI_66, THIMMASANDRA_66 | 16:14 | 16:32 | 0:18 | LINE FAULT |
|------|-----------|--------|----|----------------------------------|---|-------|-------|------|---------------------|
| 1017 | 21-Oct-18 | TUMKUR | 66 | ANTHRASANAHALLI 220KV- CHELUR | CHELURU_66, HOSAKERE_66, ANKASANDRA_66 | 5:49 | 6:15 | 0:26 | LINE FAULT |
| 1018 | 21-Oct-18 | TUMKUR | 66 | CHITRADURGA 66kV- PANDARAHALLI 2 | HIREGUNTANUR_66, SIRIGERE_66, BRAHMASAGARA_IPP_66 | 6:14 | 6:31 | 0:16 | LINE FAULT |
| 1019 | 21-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- ENERCON-1 | ENERCON1_IPP_66 | 11:24 | 13:19 | 1:55 | LINE FAULT |
| 1020 | 21-Oct-18 | TUMKUR | 66 | HIRIYUR 220KV- RANGANATHPURA | RANGANATHAPURA_66 | 11:24 | 11:41 | 0:17 | LINE FAULT |
| 1021 | 21-Oct-18 | TUMKUR | 66 | TR-2 | KUKKAWADA_66 | 13:31 | 14:48 | 1:16 | LINE CLEAR AVAILED |
| 1022 | 21-Oct-18 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 10:48 | 15:35 | 4:46 | LINE FAULT |
| 1023 | 22-Oct-18 | TUMKUR | 66 | KB CROSS 220kV- SHIMOGA | MRSMG_220 | 17:41 | 20:42 | 3:01 | LOAD CURTAILMENT |
| 1024 | 22-Oct-18 | TUMKUR | 66 | TR-1 | NEELAGUNDA_220 | 2:30 | 2:44 | 0:14 | TRANSFORMER FAULT |
| 1025 | 22-Oct-18 | TUMKUR | 66 | BHAKTARAHALLI- ANCHEPALYA | BHAKTHARAHALLI_66 | 10:36 | 10:53 | 0:17 | MAIN SUPPLY FAILURE |
| 1026 | 22-Oct-18 | TUMKUR | 66 | TR-1 | HALUVAGALU_66 | 11:08 | 11:33 | 0:25 | HAND TRIPPED |
| 1027 | 22-Oct-18 | TUMKUR | 66 | TR-1 | HARAPPANAHALLI_66 | 11:25 | 13:12 | 1:46 | LINE CLEAR AVAILED |
| 1028 | 22-Oct-18 | TUMKUR | 66 | TR-2 | HARAPPANAHALLI_66 | 11:22 | 12:41 | 1:18 | LINE CLEAR AVAILED |
| 1029 | 22-Oct-18 | TUMKUR | 66 | HIRIYUR 220kV- BEVINAHALLI | DASUDI_66, JAVAGONDANAHALLI_66, BEVINAHALLI_66 | 13:31 | 13:50 | 0:18 | LOAD CURTAILMENT |
| 1030 | 22-Oct-18 | TUMKUR | 66 | HOLALKERE- PANDARAHALLI 2 | HOLALKERE_66 | 11:53 | 12:04 | 0:10 | LINE FAULT |
| 1031 | 22-Oct-18 | TUMKUR | 66 | HOLALKERE- RAMGIRI 2 | HOLALKERE_66 | 12:04 | 12:17 | 0:13 | LOAD CURTAILMENT |
| 1032 | 22-Oct-18 | TUMKUR | 66 | HONNALLI 220KV- SASUVEHALLI | SASUVEHALLI_66 | 23:33 | 23:57 | 0:23 | LINE FAULT |
| 1033 | 22-Oct-18 | TUMKUR | 66 | TR-1 | LINGADAHALLI_TMK2_66 | 4:23 | 4:26 | 0:02 | TRANSFORMER FAULT |
| 1034 | 22-Oct-18 | TUMKUR | 66 | TR-1 | NEELAGUNDA_220 | 2:30 | 2:44 | 0:14 | TRANSFORMER FAULT |
| 1035 | 22-Oct-18 | TUMKUR | 66 | NEELAGUNDA 220kV- PUNABHAGHATTA | PUNABHAGHATTA_66, PALLAGATTE_66, UCHCHANGIDURGA_66 | 1:01 | 1:20 | 0:19 | LINE FAULT |
| 1036 | 22-Oct-18 | TUMKUR | 66 | NEELAGUNDA 220kV- PUNABHAGHATTA | PUNABHAGHATTA_66, PALLAGATTE_66, UCHCHANGIDURGA_66 | 2:35 | 2:48 | 0:13 | LINE FAULT |
| 1037 | 22-Oct-18 | TUMKUR | 66 | TR-1 | RAMPURA_66 | 13:23 | 13:35 | 0:12 | LINE CLEAR AVAILED |
| 1038 | 22-Oct-18 | TUMKUR | 66 | TR-2 | RAMPURA_66 | 14:17 | 14:29 | 0:11 | LINE CLEAR AVAILED |
| 1039 | 22-Oct-18 | TUMKUR | 66 | SHYLAPURA- MADHUGIRI | SHYLAPURA_66, YNHOSKOTE_66, MANGALWADA_66 | 8:53 | 8:57 | 0:04 | HAND TRIPPED |
| 1040 | 22-Oct-18 | TUMKUR | 66 | THALLAK 220kV- WELSPUN SOLAR1 | WELSPUNSOLAR1_IPP_66 | 10:22 | 14:46 | 4:23 | LINE FAULT |
| 1041 | 22-Oct-18 | TUMKUR | 66 | MELEKOTE HEBBUR-THIMMASANDRA | THIMMASANDRA_66 | 10:43 | 10:57 | 0:13 | MAIN SUPPLY FAILURE |
| | | | | | | | | | |

